

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	Amps A Ø	130.0	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	Follow-up Action Required?	n	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	General Comments		
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	Operations This Read SF6	0	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	Operations Counter AL	716	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	Operations Counter AF	716	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	Num Operations Last 9 Months	7	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Readings	Maintenance Operations	0	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	Unknown Operations	0	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	Switching Operations	0	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	Operations This Read SF6	0	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	Operations Counter AL	355	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	Operations Counter AF	355	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	Amps A Ø	40.0	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	Amps B Ø	40.0	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	Amps C Ø	60.0	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	Fault Operations	0	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	Num Operations Last 9 Months	2	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	Follow-up Action Required?	n	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	Maintenance Operations	0	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Readings	General Comments		
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Battery Bank Amps	0.0	AMPS
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Battery Bank Volts	53.5	VDC
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BCH001018	Charger	WP-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Follow-up Action Required?	n	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Follow-up Action Required?	n	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Foundation Condition	Good	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	General Comments		
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BCH001018	Charger	WP-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BCH001018	Charger	WP-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BCH001018	Charger	WP-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BCH001018	Charger	WP-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BCH001018	Charger	WP-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BCH001018	Charger	WP-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	42	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Fault Operations Ground	0	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Fault Operations C Ø	0	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Fault Operations B Ø	0	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	PF001255	PowerFuse	WP-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	PF001255	PowerFuse	WP-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	9 Month Operations	0	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Amps A Ø	30.0	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Amps B Ø	51.0	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Amps C Ø	61.0	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Bushing Condition	Good	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	General Comments		
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Fault Operations A Ø	0	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	General Comments		
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	SPPC Berms in Good Condition	Good	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	SPPC Strongwell Containment OK	y	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Vegetation	None	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	General Comments		
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	PF000254	PowerFuse	MU-33KV TR 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Ambient Temp	32	°F
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	Oil Temp Present	27	°C
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	Oil Temp Max	35	°C
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Min	0.00	MegaWatts
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Max	0.00	MegaWatts
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Min	0.00	MegaVars
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Max	0.00	MegaVars
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	PF000254	PowerFuse	MU-33KV TR 1	Disconnect Powerfuse Inspection	General Comments	ok	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Unknown Operations	0	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Tank Paint Condition	Good	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Switching Operations	0	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Operations This Read Vac	0	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Operations Counter AL	224	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Operations Counter AF	224	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Maintenance Operations	0	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Grounds in Place?	y	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	General Comments	cant get readings off SATEC	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	y	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	General Comments		
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Ambient Temp	32	*F
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	51	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	LTC Min Tap Position	5L	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	LTC Max Tap Position	3L	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	LTC Current Tap Position	4L	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	LTC As Left Counter	168526	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	LTC As Found Counter	168526	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	LTC Current Tap Position	7L	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	LTC Max Tap Position	6L	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	LTC Min Tap Position	8L	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	General Comments		
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	PF001197	PowerFuse	WP-33KV TR 1	Disconnect Powerfuse Inspection	General Comments	ok	
12/23/2020 12:28	Distribution	West Point Quarterly Inspection	PF001197	PowerFuse	WP-33KV TR 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Vegetation	None	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	General Comments		
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	General Comments		
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Readings	General Comments		
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	LTC As Found Counter	214299	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	LTC As Left Counter	214299	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Readings	Oil Temp Present	35	°C
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Readings	Oil Temp Max	45	°C
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	General Comments	needs nitro	
12/23/2020 12:10	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	9 Month Operations	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Unknown Operations	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Switching Operations	1	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Operations This Read Vac	7	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Operations Counter AL	87	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Fault Operations B Ø	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Operations Counter AF	87	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Fault Operations C Ø	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Fault Operations Ground	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Patrol Inspection	Follow-up Action Required?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Follow-up Action Required?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Patrol Inspection	General Comments		
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	Totalizer Meter Reading	.8082	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Unknown Operations	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Switching Operations	1	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Operations This Read AM	1	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Amps A Ø	0.0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Amps B Ø	0.0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Amps C Ø	0.0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Fault Operations A Ø	0	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	110.00	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Fault Operations B Ø	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Fault Operations C Ø	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Fault Operations Ground	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Patrol Inspection	Follow-up Action Required?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Follow-up Action Required?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Fault Operations A Ø	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Amps C Ø	120.0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Amps B Ø	127.0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Amps A Ø	112.0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Patrol Inspection	General Comments		
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	General Comments		
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Maintenance Operations	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Operations Counter AF	13	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Operations Counter AL	13	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Operations This Read Vac	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Switching Operations	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Unknown Operations	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	9 Month Operations	6	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Switching Operations	24	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Unknown Operations	0	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Fault Operations A Ø	0	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Fault Operations B Ø	0	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Fault Operations C Ø	0	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Fault Operations Ground	0	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Follow-up Action Required?	n	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Follow-up Action Required?	n	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Foundation Condition	Good	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	General Comments		
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	General Comments		
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Grounds in Place?	y	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Maintenance Operations	0	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Operations Counter AF	258	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Operations Counter AL	258	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Operations This Read Vac	0	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Switching Operations	0	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Tank Paint Condition	Good	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Unknown Operations	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Low	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	General Comments	Oil level is low	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1898	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1898	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	LTCC000872	LTCControl	091-6	LTC Control Insp	All Connections OK?	y	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	LTCC000872	LTCControl	091-6	LTC Control Insp	Follow-up Action Required?	n	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	LTCC000872	LTCControl	091-6	LTC Control Insp	General Comments		
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	LTCC000872	LTCControl	091-6	LTC Control Insp	LTC Operation Checked?	y	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	LTCC000872	LTCControl	091-6	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	LTCC000872	LTCControl	091-6	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	LTCC000872	LTCControl	091-6	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	LTCC000872	LTCControl	091-6	LTC Control Insp	VRR Time Delay	30	Seconds
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	LTCC000873	LTCControl	091-5	LTC Control Insp	All Connections OK?	y	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	LTCC000873	LTCControl	091-5	LTC Control Insp	Follow-up Action Required?	n	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	LTCC000873	LTCControl	091-5	LTC Control Insp	General Comments		
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	LTCC000873	LTCControl	091-5	LTC Control Insp	LTC Operation Checked?	y	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	LTCC000873	LTCControl	091-5	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	LTCC000873	LTCControl	091-5	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	LTCC000873	LTCControl	091-5	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	LTCC000873	LTCControl	091-5	LTC Control Insp	VRR Time Delay	30	Seconds
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Maintenance Operations	6	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	General Comments		
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Patrol Inspection	General Comments		
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Follow-up Action Required?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Patrol Inspection	Follow-up Action Required?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Fault Operations Ground	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Fault Operations C Ø	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Fault Operations B Ø	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Fault Operations A Ø	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Amps C Ø	54.0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Operations Counter AL	200	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Bushing Condition	Good	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Amps C Ø	125.0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Operations This Read Vac	1	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Switching Operations	1	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Tank Paint Condition	Good	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Amps B Ø	165.0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Unknown Operations	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Switching Operations	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Operations This Read Vac	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Operations Counter AL	69	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Operations Counter AF	69	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Maintenance Operations	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	General Comments		
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Patrol Inspection	General Comments		
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Follow-up Action Required?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Patrol Inspection	Follow-up Action Required?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Fault Operations Ground	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Fault Operations C Ø	0	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Amps A Ø	165.0	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	9 Month Operations	11	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Patrol Inspection	Follow-up Action Required?	n	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Fault Operations Ground	0	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Fault Operations C Ø	0	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Fault Operations B Ø	0	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Fault Operations A Ø	0	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Patrol Inspection	Bushing Condition	Good	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Amps C Ø	75.0	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Amps B Ø	85.0	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Amps A Ø	80.0	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	9 Month Operations	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Fault Operations B Ø	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Unknown Operations	0	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Follow-up Action Required?	n	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Patrol Inspection	Foundation Condition	Good	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Patrol Inspection	General Comments		
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	9 Month Operations	10	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Amps A Ø	115.0	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Amps B Ø	120.0	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Amps C Ø	75.0	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Bushing Condition	Good	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	General Comments		
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Patrol Inspection	Grounds in Place?	y	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Fault Operations A Ø	0	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Fault Operations B Ø	0	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Fault Operations C Ø	0	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Fault Operations Ground	0	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Follow-up Action Required?	n	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Follow-up Action Required?	n	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Foundation Condition	Good	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	General Comments		
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	General Comments		
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Grounds in Place?	y	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Maintenance Operations	0	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Operations Counter AF	159	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Operations Counter AL	159	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Operations This Read Vac	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Unknown Operations	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Switching Operations	1	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Operations This Read AM	1	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Operations Counter AL	755	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Operations Counter AF	755	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Maintenance Operations	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	General Comments		
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Patrol Inspection	General Comments		
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Follow-up Action Required?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Fault Operations Ground	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Fault Operations C Ø	0	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Tank Paint Condition	Good	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Switching Operations	0	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Operations This Read Vac	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Fault Operations B Ø	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Fault Operations A Ø	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Amps C Ø	118.0	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Operations Counter AL	190	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Operations Counter AF	190	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Amps B Ø	126.0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Amps A Ø	114.0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	9 Months Operations	3	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Switching Operations	0	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Patrol Inspection	Tank Paint Condition	Good	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK001411	BreakerVacuum	091-0922	VCB Readings	Unknown Operations	0	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Maintenance Operations	0	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Grounds in Place?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	9 Months Operations	2	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	General Comments		
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	General Comments		
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	General Comments		
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	LTC Totalizer Reading	7758.72	kw
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	Oil Temp Max	35	°C
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	Oil Temp Present	35	°C
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Amps A Ø	130.0	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Amps B Ø	110.0	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Amps C Ø	115.0	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Bushing Condition	Good	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Fault Operations A Ø	0	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Fault Operations B Ø	0	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Fault Operations C Ø	0	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Fault Operations Ground	0	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Follow-up Action Required?	n	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Follow-up Action Required?	n	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Foundation Condition	Good	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	General Comments		
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	General Comments		
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Grounds in Place?	y	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Maintenance Operations	0	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Fault Operations A Ø	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Amps C Ø	356.0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Amps B Ø	338.0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Amps A Ø	328.0	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Unknown Operations	0	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	9 Month Operations	12	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	9 Month Operations	2	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Unknown Operations	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	General Comments		
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	Oil Temp Max	60	°C
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	Oil Temp Present	34	°C
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	LTC Operations Since Last Insp	483	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Switching Operations	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Operations This Read Vac	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Operations Counter AL	71	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Operations Counter AF	71	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Maintenance Operations	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	General Comments		
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Patrol Inspection	General Comments		
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	LTC Min Tap Position	16L	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	LTC Max Tap Position	10L	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	LTC Current Tap Position	14L	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	LTC As Left Counter	208595	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	LTC As Found Counter	208595	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Mechanism Patrol Inspection	General Comments		
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	66	°C
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	37	°C
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	67	°C
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	37	°C
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	General Comments		
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	Follow-up Action Required?	n	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	9 Month Operations	25	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Accumulated Fault Duty A Ph V	1.13	%
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Accumulated Fault Duty B Ph V	1.13	%
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Accumulated Fault Duty C Ph V	1.13	%
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Amps A Ø	124.0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Amps B Ø	122.0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Amps C Ø	117.0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	67	°C
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	37	°C
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	SWG000018	Switchgear	CL-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	SWG000018	Switchgear	CL-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Amps A Ø	0.0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Follow-up Action Required?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Patrol Inspection	General Comments		
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	General Comments		
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Maintenance Operations	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Operations Counter AF	743	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Operations Counter AL	743	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Operations This Read AM	1	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Amps B Ø	0.0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Amps C Ø	0.0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Bushing Condition	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Bushings Connection/Risers	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Cabinet Paint Condition	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Equipment Properly Labeled?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Fault Operations	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Follow-up Action Required?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Follow-up Action Required?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Foundation Condition	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	General Comments		
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	General Comments		
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Grounds in Place?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Maintenance Operations	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Moisture and Leak Free?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Number of Ops last 9 Months	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Operations Counter AF	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Operations Counter AL	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Operations This Read Oil	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Switching Operations	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Tank 1 Oil Level	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Tank 2 Oil level	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Tank 3 Oil Level	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Tank Leaks	None	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Tank Oil Level	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Tank Paint Condition	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Unknown Operations	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Switching Operations	1	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Patrol Inspection	General Comments		
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Follow-up Action Required?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Fault Operations Ground	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Fault Operations C Ø	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Fault Operations B Ø	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Fault Operations A Ø	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Amps C Ø	0.0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Amps B Ø	0.0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Amps A Ø	0.0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	9 Months Operations	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1482	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	9 Months Operations	1	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Amps A Ø	0.0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Amps B Ø	0.0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Amps C Ø	0.0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Fault Operations A Ø	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Fault Operations B Ø	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Fault Operations C Ø	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Fault Operations Ground	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1482	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	SWG000018	Switchgear	CL-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	SWG000018	Switchgear	CL-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	35	°C
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	55	°C
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	40	°C
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	55	°C
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	45	°C
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	60	°C
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	30.00	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	Oil Temp Present	40	°C
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	Oil Temp Max	55	°C
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1725	psi
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.3	psi
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	General Comments		
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	PF000088	PowerFuse	CL-14KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	PF000089	PowerFuse	CL-STA SER NO 5	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	PF000089	PowerFuse	CL-STA SER NO 5	Disconnect Powerfuse Inspection	General Comments	ok	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	PF000090	PowerFuse	CL-12KV TR 5 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	PF000090	PowerFuse	CL-12KV TR 5 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	PF000036	PowerFuse	CG-14KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	PF000036	PowerFuse	CG-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	PF000036	PowerFuse	CG-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	PF000037	PowerFuse	CG-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	PF000037	PowerFuse	CG-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	PF000037	PowerFuse	CG-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	9 Months Operations	6	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	General Comments		
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	LTC As Found Counter	28050	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Amps A Ø	46.0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Amps B Ø	63.0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Unknown Operations	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	7.0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	7.0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	7.0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LTCC000489	LTCControl	CL-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LTCC000489	LTCControl	CL-TRANS 1	LTC Control Insp	General Comments	ok	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1577	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1577	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	PF000083	PowerFuse	CL-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	PF000083	PowerFuse	CL-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	PF000084	PowerFuse	CL-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	PF000084	PowerFuse	CL-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	PF000086	PowerFuse	CL-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	PF000086	PowerFuse	CL-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	PF000088	PowerFuse	CL-14KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	Follow-up Action Required?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	General Comments		
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	General Comments		
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	Oil Temp Max	50	°C
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	Oil Temp Present	40	°C
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	X1 Winding Temp Max	50	°C
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	X1 Winding Temp Present	27	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	X2 Winding Temp Max	50	°C
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	X2 Winding Temp Present	27	°C
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	X3 Winding Temp Max	50	°C
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	X3 Winding Temp Present	27	°C
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Foundation Condition	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Follow-up Action Required?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Unknown Operations	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Switching Operations	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Operations This Read AM	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Operations Counter AL	310	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Operations Counter AF	310	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Maintenance Operations	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	General Comments		
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Patrol Inspection	General Comments		
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Follow-up Action Required?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Unknown Operations	0	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Tank Paint Condition	Good	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Switching Operations	0	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Operations This Read Vac	0	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Operations Counter AL	379	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Operations Counter AF	379	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	B0339	LTCMechanism	091-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	B0339	LTCMechanism	091-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	B0339	LTCMechanism	091-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	B0339	LTCMechanism	091-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	B0339	LTCMechanism	091-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Maintenance Operations	0	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Grounds in Place?	y	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	General Comments		
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	General Comments		
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Foundation Condition	Good	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Follow-up Action Required?	n	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Follow-up Action Required?	n	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Fault Operations Ground	0	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Fault Operations C ∅	0	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Fault Operations B ∅	0	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Fault Operations A ∅	0	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Bushing Condition	Good	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Amps C ∅	0.0	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Amps B ∅	0.0	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Amps A ∅	0.0	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	9 Month Operations	2	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Tank Leaks	None	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Radiator Leaks	None	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Grounds in Place?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	General Comments	needs nitro	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Amps C ∅	192.0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Amps B ∅	192.0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Amps A ∅	251.0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	General Comments		
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	General Comments	Needs Nitro	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	LV Winding Temp Max	40	°C
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	LV Winding Temp Present	20	°C
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	Oil Temp Max	54	°C
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	Oil Temp Present	28	°C
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	9 Months Operations	7	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Amps A Ø	344.0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	9 Months Operations	12	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Bushing Condition	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Unknown Operations	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Switching Operations	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Operations This Read AM	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Operations Counter AL	318	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Operations Counter AF	318	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Maintenance Operations	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	General Comments		
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Fault Operations Ground	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Fault Operations C Ø	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Fault Operations B Ø	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Amps C Ø	0.0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Amps B Ø	0.0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Amps A Ø	0.0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Unknown Operations	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Switching Operations	2	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Operations This Read AM	2	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Operations Counter AL	629	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Operations Counter AF	629	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Maintenance Operations	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	General Comments		
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Patrol Inspection	General Comments		
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Follow-up Action Required?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Fault Operations Ground	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Fault Operations C Ø	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Fault Operations B Ø	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Fault Operations A Ø	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Amps C Ø	316.0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Amps B Ø	362.0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Unknown Operations	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Switching Operations	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	LTC Min Tap Position	8L	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	LTC Max Tap Position	6L	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	LTC Current Tap Position	6L	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	LTC As Left Counter	38895	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	LTC As Found Counter	38895	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Amps A Ø	389.0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Amps B Ø	356.0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Amps C Ø	367.0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Operations This Read Vac	0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Switching Operations	0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Unknown Operations	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	PF000087	PowerFuse	CL-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	PF000082	PowerFuse	CL-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	PF000082	PowerFuse	CL-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Panels Dusted?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	General Comments		
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Evidence of Insects	None	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	9 Month Operations	11	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Accumulated Fault Duty A Ph V	14.68	%
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Accumulated Fault Duty B Ph V	14.68	%
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Accumulated Fault Duty C Ph V	13.55	%
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Amps A Ø	555.0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Amps B Ø	558.0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Amps C Ø	558.0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Adjusted Amps A Phase V	29.39	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Adjusted Amps B Phase V	29.39	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Adjusted Amps C Phase V	29.39	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Operations A Ø	0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Operations B Ø	0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Operations C Ø	0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Operations Ground	0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Follow-up Action Required?	n	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	General Comments		
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Operations Counter AF	184	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Operations Counter AL	184	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Operations This Read Vac	2	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Switching Operations	0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Unknown Operations	2	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Amps C Ø	431.0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Amps B Ø	478.0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Amps A Ø	456.0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	9 Months Operations	11	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	PF000085	PowerFuse	CL-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	PF000085	PowerFuse	CL-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	PF000081	PowerFuse	CL-GND TR 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	PF000081	PowerFuse	CL-GND TR 1	Disconnect Powerfuse Inspection	General Comments	ok	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	91.0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	96.0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	93.0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	PF000087	PowerFuse	CL-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	9 Month Operations	0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	1.13	%
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	1.13	%
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	1.13	%
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Amps A Ø	935.0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Amps B Ø	953.0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Amps C Ø	938.0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Operations A Ø	0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Operations B Ø	0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Operations C Ø	0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Operations Ground	0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Follow-up Action Required?	n	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	General Comments		
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Maintenance Operations	0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Operations Counter AF	237	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Operations Counter AL	237	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	LTC As Left Counter	73815	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	LTC As Found Counter	73815	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	Follow-up Action Required?	n	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	General Comments		
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	LTC Totalizer Reading	6773.76	kw
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	Oil Temp Max	30	°C
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	Oil Temp Present	30	°C
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LTCC000658	LTCControl	CL-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallellND	Position
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LTCC000658	LTCControl	CL-TRANS 3	LTC Control Insp	General Comments		
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LTCC000658	LTCControl	CL-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	1188	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	16	°C
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	46	°C
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	LTC Min Tap Position	4L	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	LTC Max Tap Position	7R	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Amps C Ø	64.0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Fault Operations A Ø	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Fault Operations B Ø	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Fault Operations C Ø	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Fault Operations Ground	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Follow-up Action Required?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Patrol Inspection	General Comments		
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	General Comments		
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Maintenance Operations	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Operations Counter AF	900	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Operations Counter AL	900	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Operations This Read AM	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Switching Operations	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Unknown Operations	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	LTC As Left Counter	28050	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	LTC Current Tap Position	2R	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	LTC Max Tap Position	2R	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	LTC Min Tap Position	2R	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	204	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	9 Months Operations	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	LTC Operations Since Last Insp	107	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	LTC Min Tap Position	8L	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	LTC Max Tap Position	6L	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	LTC Current Tap Position	6L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	LTC Current Tap Position	3R	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	Totalizer Meter Reading	.7056	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	200.00	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	LTC As Left Counter	32434	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LTC0000540	LTCControl	CL-TRANS 5	LTC Control Insp	Follow-up Action Required?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	General Comments		
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	LTC As Found Counter	197581	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	LTC As Left Counter	197581	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	LTC Current Tap Position	12L	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	LTC Max Tap Position	7L	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	LTC Min Tap Position	15L	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	510	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	LTC As Found Counter	32434	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	General Comments		
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/22/2020 11:28	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Mechanism Patrol Inspection	General Comments		
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	General Comments		
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	Follow-up Action Required?	n	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/22/2020 13:42	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	927	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	927	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	210.0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	4	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	190.0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0066	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	220.0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0065	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Fault Operations B Ø	0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Fault Operations A Ø	0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	General Comments		
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	n	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	General Comments	Heater fan motor is bad, sent Maint a email	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	5.5	amps
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	9 Months Operations	2	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Amps A Ø	20.0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Amps B Ø	20.0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Amps C Ø	20.0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Fault Operations A Ø	0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Fault Operations B Ø	0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Fault Operations C Ø	0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Follow-up Action Required?	n	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Patrol Inspection	General Comments		
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Switching Operations	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	PF000015	PowerFuse	AL-14KV BUS SEC 3 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	PF000014	PowerFuse	AL-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	PF000014	PowerFuse	AL-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	PF000014	PowerFuse	AL-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	9 Months Operations	3	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Amps A Ø	0.0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Amps B Ø	0.0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Amps C Ø	0.0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations A Ø	0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Operations Counter AL	325	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Operations Counter AF	325	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Maintenance Operations	0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	General Comments		
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Patrol Inspection	General Comments		
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Amps C Ø	200.0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Amps B Ø	200.0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Amps A Ø	200.0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	9 Months Operations	1	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations B Ø	0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations C Ø	0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations Ground	0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Follow-up Action Required?	n	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Patrol Inspection	General Comments		
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	LTC As Found Counter	181236	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	LTC As Left Counter	181236	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	LTC Current Tap Position	12L	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Amps C Ø	100.0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Amps B Ø	100.0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Amps A Ø	100.0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	9 Months Operations	2	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	19	°C
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	525	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	General Comments		
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	General Comments		
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Maintenance Operations	0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Operations Counter AF	624	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Operations Counter AL	624	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Operations This Read AM	0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	PF001207	PowerFuse	AL-14KV TR 4 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	PF001207	PowerFuse	AL-14KV TR 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	PF001206	PowerFuse	AL-14KV TR 3 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	PF001206	PowerFuse	AL-14KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	PF001206	PowerFuse	AL-14KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	PF001206	PowerFuse	AL-14KV TR 3 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	PF001205	PowerFuse	AL-14KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	PF001205	PowerFuse	AL-14KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	PF001205	PowerFuse	AL-14KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Switching Operations	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	PF000016	PowerFuse	AL-14KV BUS SEC 4 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	PF000016	PowerFuse	AL-14KV BUS SEC 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	PF000016	PowerFuse	AL-14KV BUS SEC 4 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Switching Operations	0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Operations This Read AM	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	PF000015	PowerFuse	AL-14KV BUS SEC 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	PF000015	PowerFuse	AL-14KV BUS SEC 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Follow-up Action Required?	n	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Patrol Inspection	General Comments		
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	PF000007	PowerFuse	AL-GND TR 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	PF000007	PowerFuse	AL-GND TR 1	Disconnect Powerfuse Inspection	General Comments	ok	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	General Comments		
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Maintenance Operations	0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Operations Counter AF	557	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Operations Counter AL	557	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Operations This Read AM	0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Switching Operations	0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	9 Months Operations	3	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	PF000055	PowerFuse	BI-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	PF000055	PowerFuse	BI-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	PF000054	PowerFuse	BI-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	OK	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	PF000054	PowerFuse	BI-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	PF000013	PowerFuse	AL-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	PF000013	PowerFuse	AL-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	PF000013	PowerFuse	AL-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	PF000011	PowerFuse	AL-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	PF000011	PowerFuse	AL-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	PF000011	PowerFuse	AL-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	PF000010	PowerFuse	AL-GND TR 4	Disconnect Powerfuse Inspection	General Comments	ok	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	PF000010	PowerFuse	AL-GND TR 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	PF000010	PowerFuse	AL-GND TR 4	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	PF000009	PowerFuse	AL-GND TR 3	Disconnect Powerfuse Inspection	General Comments	ok	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	PF000009	PowerFuse	AL-GND TR 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	PF000009	PowerFuse	AL-GND TR 3	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	PF000008	PowerFuse	AL-GND TR 2	Disconnect Powerfuse Inspection	General Comments	ok	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	PF000008	PowerFuse	AL-GND TR 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	9 Month Operations	4	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	9 Month Operations	0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	PF000019	PowerFuse	BI-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	PF000019	PowerFuse	BI-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	ANN000010	Annunciator	BI-Annunciator Panel	Annunciator Patrol Inspection	General Comments		
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	PF000012	PowerFuse	AL-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	PF000012	PowerFuse	AL-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	PF000012	PowerFuse	AL-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	ANN000010	Annunciator	BI-Annunciator Panel	Annunciator Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Unknown Operations	0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Switching Operations	0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Operations This Read Vac	0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	ANN000010	Annunciator	BI-Annunciator Panel	Annunciator Patrol Inspection	ESOC Received Alarm Test?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	ANN000010	Annunciator	BI-Annunciator Panel	Annunciator Patrol Inspection	Control House Alarm Audible?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	ANN000010	Annunciator	BI-Annunciator Panel	Annunciator Patrol Inspection	All Lights Functioning?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	PF000007	PowerFuse	AL-GND TR 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Operations Counter AL	191	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Operations Counter AF	191	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Maintenance Operations	0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	General Comments		
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Follow-up Action Required?	n	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Fault Operations Ground	0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Fault Operations C Ø	0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Fault Operations B Ø	0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Fault Operations A Ø	0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Amps B Ø	50.0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Amps C Ø	50.0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Amps C Ø	154.0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Amps B Ø	159.0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Amps A Ø	159.0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Amps A Ø	50.0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Fault Operations A Ø	0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Fault Operations B Ø	0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Fault Operations C Ø	0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Fault Operations Ground	0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	PF000018	PowerFuse	BI-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	PF000018	PowerFuse	BI-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	51	°C
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	LTC Min Tap Position	12L	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	LTC Max Tap Position	4L	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	8L	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	9 Month Operations	9	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Amps A Ø	659.0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Amps B Ø	601.0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Amps C Ø	665.0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Adjusted Amps A Phase V	132.27	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Adjusted Amps B Phase V	132.27	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Adjusted Amps C Phase V	132.27	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Operations A Ø	0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Operations B Ø	0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Operations C Ø	0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Fault Operations Ground	0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Follow-up Action Required?	n	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	General Comments		
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Maintenance Operations	0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Operations Counter AF	182	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Operations Counter AL	182	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Operations This Read Vac	9	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Switching Operations	0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Readings	Unknown Operations	9	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	230962	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	230962	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	General Comments		
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Amps A Ø	1083.0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Amps B Ø	1035.0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Amps C Ø	1057.0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Operations A Ø	0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Operations B Ø	0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Operations C Ø	0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Fault Operations Ground	0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Follow-up Action Required?	n	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	General Comments		
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Maintenance Operations	0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Operations Counter AF	237	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Operations Counter AL	237	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Operations This Read Vac	0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Switching Operations	0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Readings	Unknown Operations	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	PF000008	PowerFuse	AL-GND TR 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	PF000006	PowerFuse	AL-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	PF000006	PowerFuse	AL-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	PF000006	PowerFuse	AL-STA SER NO 3	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	General Comments		
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	General Comments		
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Broom on Site?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	50	°C
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	30	°C
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	45	°C
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	25	°C
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	25	°C
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	25	°C
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	Oil Temp Present	30	°C
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	Oil Temp Max	45	°C
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	400	psi
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	General Comments	X3 gauge is full of water, hard to read	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Vegetation	None	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	General Comments		
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LTCC000403	LTCControl	BI-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LTCC000403	LTCControl	BI-TRANS 2	LTC Control Insp	General Comments		
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LTCC000403	LTCControl	BI-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Ambient Temp	39	°F
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Follow-up Action Required?	n	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Fault Operations Ground	0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Fault Operations C Ø	0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Fault Operations B Ø	0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Fault Operations A Ø	0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Amps C Ø	30.0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Amps B Ø	30.0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Amps A Ø	30.0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	9 Months Operations	8	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Fault Operations Ground	0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Follow-up Action Required?	n	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	General Comments		
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Maintenance Operations	0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Operations Counter AF	174	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Operations Counter AL	174	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Operations This Read Vac	0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Switching Operations	0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Unknown Operations	0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Patrol Inspection	General Comments		
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	General Comments		
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Maintenance Operations	0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Operations Counter AF	944	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Operations Counter AL	944	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Operations This Read AM	0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Switching Operations	0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Fault Operations C Ø	0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Fault Operations B Ø	0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Fault Operations A Ø	0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Amps C Ø	76.0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Amps B Ø	75.0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Amps A Ø	71.0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Readings	9 Month Operations	1	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Trash Emptied?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	General Comments		
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Operations This Read AM	1	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Unknown Operations	2	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Switching Operations	0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	60	°C
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	Oil Temp Max	68	°C
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	Oil Temp Present	60	°C
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Operations This Read Vac	2	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Operations Counter AL	173	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Operations Counter AF	173	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Maintenance Operations	0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	General Comments		
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Follow-up Action Required?	n	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Operations Ground	0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Operations C ∅	0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Operations B ∅	0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Operations A ∅	0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Adjusted Amps C Phase V	29.39	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Adjusted Amps B Phase V	29.39	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Adjusted Amps A Phase V	29.39	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Switching Operations	1	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	65	°C
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	75	°C
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	50	°C
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	60	°C
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	65	°C
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	75	°C
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	LTC Max Tap Position	6L	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	LTC Min Tap Position	15L	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	173	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	General Comments		
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	9 Month Operations	2	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Amps A ∅	159.0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Amps B ∅	159.0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Amps C ∅	154.0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Maintenance Operations	0	
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AF	32	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	General Comments		
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	70	°C
12/21/2020 10:40	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AL	32	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	General Comments		
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Patrol Inspection	General Comments		
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Follow-up Action Required?	n	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Fault Operations Ground	0	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Fault Operations C ∅	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Fault Operations B Ø	0	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Fault Operations A Ø	0	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Maintenance Operations	0	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Operations Counter AF	325	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Operations Counter AL	325	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	9 Months Operations	0	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Unknown Operations	0	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Operations This Read AM	0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Amps A Ø	25.0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Amps B Ø	25.0	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Switching Operations	0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	9 Months Operations	0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Amps A Ø	200.0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Amps A Ø	400.0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Amps B Ø	250.0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Amps C Ø	280.0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Fault Operations A Ø	0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Fault Operations B Ø	0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Fault Operations C Ø	0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Fault Operations Ground	0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Follow-up Action Required?	n	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Amps B Ø	250.0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Amps C Ø	260.0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Fault Operations A Ø	0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Fault Operations B Ø	0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Fault Operations C Ø	0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Fault Operations Ground	0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Follow-up Action Required?	n	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Patrol Inspection	General Comments		
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	General Comments		
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Patrol Inspection	General Comments		
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	General Comments		
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Maintenance Operations	0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Operations Counter AF	549	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Operations Counter AL	549	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Operations This Read AM	0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Switching Operations	0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Unknown Operations	0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	CH000448	ControlHouse	WE-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	CH000448	ControlHouse	WE-Battery Control House	Control House Patrol Inspection	General Comments		
12/18/2020 10:44	Distribution	Western Quarterly Inspection	CH000448	ControlHouse	WE-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	CH000448	ControlHouse	WE-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	CH000448	ControlHouse	WE-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	CH000448	ControlHouse	WE-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	CH000448	ControlHouse	WE-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	CH000448	ControlHouse	WE-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	CH000448	ControlHouse	WE-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	Oil Temp Present	20	°C
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	Oil Temp Max	50	°C
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Min	2.70	MegaWatts
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Max	3.00	MegaWatts
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Min	-.20	MegaVars
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Max	.20	MegaVars
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	General Comments		
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Amps C Ø	25.0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Fault Operations A Ø	0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Fault Operations B Ø	0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Fault Operations C Ø	0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Fault Operations Ground	0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Follow-up Action Required?	n	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Patrol Inspection	General Comments		
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	General Comments		
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Maintenance Operations	0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Operations Counter AF	1006	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Operations Counter AL	1006	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Operations This Read AM	0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Switching Operations	0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Unknown Operations	0	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Amps C Ø	60.0	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Amps B Ø	60.0	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Amps A Ø	80.0	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	9 Months Operations	1	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	BCH001337	Charger	SS-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.6	VDC
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	BCH001337	Charger	SS-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.6	VDC
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	BCH001337	Charger	SS-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	BCH001337	Charger	SS-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	BCH001337	Charger	SS-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	BCH001337	Charger	SS-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	9 Months Operations	0	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Amps A Ø	0.0	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Amps B Ø	0.0	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Amps C Ø	0.0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	LTC Min Tap Position	8L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	LTC Max Tap Position	6L	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	LTC Current Tap Position	7L	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	LTC As Left Counter	237566	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	LTC As Found Counter	237566	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	General Comments		
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	Oil Temp Present	40	°C
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	Oil Temp Max	50	°C
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	MegaWatt Demand Meter Min	.40	MegaWatts
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	94	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	LTC Min Tap Position	8L	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	LTC Max Tap Position	7L	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	LTC Current Tap Position	7L	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	MegaWatt Demand Meter Max	.70	MegaWatts
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	MegaVar Demand Meter Min	-.60	MegaVars
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	MegaVar Demand Meter Max	.10	MegaVars
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	General Comments	needs nitro	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	General Comments		
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
12/18/2020 10:44	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
12/18/2020 10:44	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	General Comments		
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	H1 Winding Temp Max	35	°C
12/18/2020 10:44	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2020 10:44	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	H1 Winding Temp Present	0	°C
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	35	°C
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	0	°C
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	H3 Winding Temp Max	35	°C
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	245.00	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	H3 Winding Temp Present	0	°C
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	Oil Temp Max	35	°C
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	Oil Temp Present	10	°C
12/18/2020 10:44	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	88	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	General Comments		
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Patrol Inspection	General Comments		
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Follow-up Action Required?	n	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Fault Operations Ground	0	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Fault Operations C ∅	0	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Fault Operations B ∅	0	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Fault Operations A ∅	0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	9 Months Operations	2	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	9 Months Operations	0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Amps A ∅	50.0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Amps B ∅	50.0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Amps C ∅	50.0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Fault Operations A ∅	0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Fault Operations B ∅	0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Fault Operations C ∅	0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Fault Operations Ground	0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Follow-up Action Required?	n	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Patrol Inspection	General Comments		
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	General Comments		
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	General Comments	TR-1 & SEC-1 is carded	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Maintenance Operations	0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Operations Counter AF	421	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Operations Counter AL	421	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Operations This Read AM	0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Switching Operations	0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Unknown Operations	0	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	40	*F
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	37	*F
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	General Comments		
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	LTC As Left Counter	18568	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	LTC As Found Counter	18568	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	General Comments		
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Unknown Operations	0	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Switching Operations	1	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Operations This Read AM	1	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Operations Counter AL	471	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Operations Counter AF	471	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Maintenance Operations	0	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	General Comments		
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Ambient Temp	28	°F
12/18/2020 10:44	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Vegetation	None	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
12/18/2020 10:44	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	General Comments		
12/18/2020 10:44	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/18/2020 10:44	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	BCH000091	Charger	VE-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	BCH000091	Charger	VE-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	0.0	VDC
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	BCH000091	Charger	VE-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	0.0	VDC
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	BCH000091	Charger	VE-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
12/18/2020 10:44	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/18/2020 10:44	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/18/2020 10:44	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	31	°F
12/18/2020 10:44	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Fault Operations Ground	0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Follow-up Action Required?	n	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Patrol Inspection	General Comments		
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Fault Operations A Ø	0	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Fault Operations B Ø	0	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Fault Operations C Ø	0	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Fault Operations Ground	0	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Follow-up Action Required?	n	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Patrol Inspection	General Comments		
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	General Comments		
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Maintenance Operations	0	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Operations Counter AF	469	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Operations Counter AL	469	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Operations This Read AM	1	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Switching Operations	1	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Unknown Operations	0	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	General Comments		
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Maintenance Operations	0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Operations Counter AF	612	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Operations Counter AL	612	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Operations This Read AM	0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Switching Operations	0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Unknown Operations	0	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2020 10:44	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Vegetation	None	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Amps B Ø	50.0	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Amps C Ø	100.0	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Fault Operations A Ø	0	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Fault Operations B Ø	0	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Fault Operations C Ø	0	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Fault Operations Ground	0	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Follow-up Action Required?	n	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Patrol Inspection	General Comments		
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Maintenance Operations	0	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Operations Counter AF	414	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Operations Counter AL	414	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Operations This Read AM	1	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Switching Operations	1	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Unknown Operations	0	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Maintenance Operations	0	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	General Comments		
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Patrol Inspection	General Comments		
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Follow-up Action Required?	n	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Fault Operations A Ø	0	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Fault Operations B Ø	0	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Fault Operations C Ø	0	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Fault Operations Ground	0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Ambient Temp	31	*F
12/18/2020 10:44	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	General Comments		
12/18/2020 10:44	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Unknown Operations	0	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Switching Operations	0	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Operations This Read AM	0	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Operations Counter AL	295	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Operations Counter AF	295	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	BCH000091	Charger	VE-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	BCH000091	Charger	VE-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	BCH000091	Charger	VE-Battery Charger	Battery Charger Patrol Insp	General Comments	TR-1 is carded, No AC to battery charger	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	BCH000093	Charger	WE-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/18/2020 10:44	Distribution	Western Quarterly Inspection	BCH000093	Charger	WE-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.6	VDC
12/18/2020 10:44	Distribution	Western Quarterly Inspection	BCH000093	Charger	WE-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.6	VDC
12/18/2020 10:44	Distribution	Western Quarterly Inspection	BCH000093	Charger	WE-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
12/18/2020 10:44	Distribution	Western Quarterly Inspection	BCH000093	Charger	WE-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/18/2020 10:44	Distribution	Western Quarterly Inspection	BCH000093	Charger	WE-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	BCH000093	Charger	WE-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	9 Months Operations	1	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	104	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	LTC Min Tap Position	13L	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	LTC Max Tap Position	9L	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	LTC Current Tap Position	11L	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	LTC As Left Counter	427096	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	LTC As Found Counter	427096	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	General Comments		
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Amps A Ø	140.0	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Amps B Ø	80.0	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Amps C Ø	60.0	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	9 Months Operations	0	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Amps A Ø	0.0	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	CH000461	ControlHouse	SS-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Maintenance Operations	0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Operations Counter AF	489	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Operations Counter AL	489	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Operations This Read AM	0	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	95	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	LTC Min Tap Position	12L	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	LTC Max Tap Position	9L	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	LTC Current Tap Position	11L	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	LTC As Left Counter	160	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Operations Counter AL	254	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Operations Counter AF	254	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Maintenance Operations	0	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	CH000461	ControlHouse	SS-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	CH000461	ControlHouse	SS-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Switching Operations	0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Unknown Operations	0	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	General Comments		
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Patrol Inspection	General Comments		
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Follow-up Action Required?	n	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Fault Operations Ground	0	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Fault Operations B Ø	0	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Fault Operations A Ø	0	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Amps C Ø	50.0	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Amps B Ø	50.0	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Amps A Ø	100.0	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Unknown Operations	0	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Switching Operations	0	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Operations This Read AM	0	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	General Comments		
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Ambient Temp	37	°F
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	CH000462	ControlHouse	VE-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.0	amps
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	CH000462	ControlHouse	VE-Battery Control House	Control House Patrol Inspection	General Comments		
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	CH000462	ControlHouse	VE-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	CH000462	ControlHouse	VE-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	CH000462	ControlHouse	VE-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	CH000462	ControlHouse	VE-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	CH000462	ControlHouse	VE-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	CH000462	ControlHouse	VE-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	CH000461	ControlHouse	SS-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	CH000461	ControlHouse	SS-Battery Control House	Control House Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	CH000461	ControlHouse	SS-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	CH000461	ControlHouse	SS-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	CH000461	ControlHouse	SS-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Fault Operations A Ø	0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Fault Operations B Ø	0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Fault Operations C Ø	0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Fault Operations Ground	0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Follow-up Action Required?	n	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Patrol Inspection	General Comments		
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	9 Months Operations	1	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Amps A Ø	100.0	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Amps B Ø	90.0	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Amps C Ø	40.0	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	General Comments		
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Maintenance Operations	0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Operations Counter AF	421	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Operations Counter AL	421	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Operations This Read AM	0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Switching Operations	0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Unknown Operations	0	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Readings	General Comments		
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/18/2020 10:44	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/18/2020 10:44	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	General Comments		
12/18/2020 10:44	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	9 Months Operations	0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Amps A Ø	140.0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Amps B Ø	150.0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Amps C Ø	130.0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Fault Operations A Ø	0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Fault Operations B Ø	0	
12/18/2020 10:44	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Fault Operations C Ø	0	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Vegetation	None	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	9 Months Operations	0	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	LTC As Found Counter	160	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	General Comments		
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/18/2020 11:51	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/18/2020 11:37	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	2.6	%
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	2.6	%
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	5	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	8.43	%
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	6.02	%
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	13.25	%
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	25.0	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	25.0	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LB0799	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	25.0	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Vegetation	None	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	194	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	194	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	LTC Operations Since Last Insp	273	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	LTC Min Tap Position	4L	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Amps A Ø	150.0	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Amps B Ø	100.0	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	LTC Max Tap Position	2R	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	LTCC000770	LTCControl	690-2	LTC Control Insp	General Comments		
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	LTCC000770	LTCControl	690-2	LTC Control Insp	LTC Operation Checked?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	LTCC000770	LTCControl	690-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	LTCC000770	LTCControl	690-2	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	LTCC000770	LTCControl	690-2	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	LTCC000770	LTCControl	690-2	LTC Control Insp	VRR Time Delay	30	Seconds
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	LTC Current Tap Position	1L	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Amps C Ø	100.0	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Fault Operations A Ø	0	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Fault Operations B Ø	0	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Fault Operations C Ø	0	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Fault Operations Ground	0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	9 Months Operations	0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Accumulated Fault Duty A Ph AM	2.13	%
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Accumulated Fault Duty B Ph AM	2.13	%
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Accumulated Fault Duty C Ph AM	2.13	%
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Amps A Ø	50	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Follow-up Action Required?	n	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Patrol Inspection	General Comments		
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	9 Months Operations	2	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Accumulated Fault Duty A Ph AM	10.67	%
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Accumulated Fault Duty B Ph AM	7.47	%
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Accumulated Fault Duty C Ph AM	7.47	%
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Amps A Ø	210	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Amps B Ø	230	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Amps C Ø	205	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Operations B Ø	0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Operations C Ø	0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Operations Ground	0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Follow-up Action Required?	n	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Patrol Inspection	General Comments		
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	General Comments		
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Maintenance Operations	0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Patrol Inspection	General Comments		
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	General Comments		
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Maintenance Operations	0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Operations Counter AF	391	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BCH001343	Charger	690-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	General Comments		
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Operations Counter AL	391	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Operations This Read AM	0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Switching Operations	0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Unknown Operations	0	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	General Comments		
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	FE000580	Fence	OR-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Maintenance Operations	0	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	6	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	6	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	General Comments		
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	2	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	254	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	Follow-up Action Required?	n	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	General Comments		
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Regulator As Left Counter	18879	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	LTC As Left Counter	5342	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	LTC As Found Counter	5342	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Mechanism Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	254	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	10.0	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	10.0	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	10.0	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	10	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	General Comments		
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Ambient Temp	34	°F
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	240.0	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	150.0	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	200.0	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Operations Counter AF	396	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Amps B Ø	50	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Amps C Ø	50	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Fault Operations A Ø	0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Fault Operations B Ø	0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Fault Operations C Ø	0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Fault Operations Ground	0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Follow-up Action Required?	n	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Patrol Inspection	General Comments		
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	General Comments		
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Maintenance Operations	0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Operations Counter AF	236	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Operations Counter AL	236	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Operations This Read AM	0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Switching Operations	0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Unknown Operations	0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Operations Counter AL	396	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Operations This Read AM	0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Switching Operations	0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Unknown Operations	0	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Operations Counter AF	462	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Operations Counter AL	462	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Operations This Read AM	0	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Switching Operations	0	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Unknown Operations	0	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Operations Counter AF	385	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Maintenance Operations	0	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	General Comments		
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Patrol Inspection	General Comments		
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Follow-up Action Required?	n	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Fault Operations Ground	0	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Fault Operations C Ø	0	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Fault Operations B Ø	0	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Fault Operations A Ø	0	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Amps C Ø	200.0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	LTC Min Tap Position	7L	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	LTC Max Tap Position	7L	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	LTC Current Tap Position	7L	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	LTC As Left Counter	409425	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	LTC As Found Counter	409425	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Amps B Ø	100.0	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Amps A Ø	100.0	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	9 Months Operations	0	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Vegetation	None	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	General Comments		
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	Percent Thermal Load A Ø Max	-60	%
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	150.0	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	150.0	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	General Comments		
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	5	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	470	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	470	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	3	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	Oil Temp Present	20	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	Oil Temp Max	25	°C
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Min	.20	MegaWatts
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Max	2.20	MegaWatts
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Min	.10	MegaVars
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Unknown Operations	0	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Switching Operations	0	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	3	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Operations This Read AM	0	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0705	BreakerAirMagnetic	OR-1	AMCB Readings	Operations Counter AL	385	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Max	.30	MegaVars
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	General Comments		
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	General Comments		
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Vegetation	None	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	General Comments		
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	General Comments		
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2699.52	kw
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	Totalizer Meter Reading	.8436	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	General Comments		
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Ambient Temp	34	°F
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	YD000585	Yard	OR-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	General Comments		
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	General Comments		Taps have not changed in several months
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	General Comments	OIL LOW	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	Follow-up Action Required?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Amps A Ø	170	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Amps B Ø	210	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Amps C Ø	225	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Fault Operations A Ø	0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Fault Operations B Ø	0	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	LTCC000770	LTCControl	690-2	LTC Control Insp	Follow-up Action Required?	n	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	LTCC000770	LTCControl	690-2	LTC Control Insp	All Connections OK?	y	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	BCH000131	Charger	OR-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	BCH000131	Charger	OR-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.7	VDC
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	BCH000131	Charger	OR-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.7	VDC
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Fault Operations C Ø	0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Fault Operations Ground	0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Follow-up Action Required?	n	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Patrol Inspection	General Comments		
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	General Comments		
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Maintenance Operations	0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Operations Counter AF	570	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Operations Counter AL	570	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Operations This Read AM	0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Switching Operations	0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Unknown Operations	0	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	BCH000131	Charger	OR-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	1	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	0	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	1	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	159	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	159	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	General Comments		
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0707	BreakerAirMagnetic	OR-3	AMCB Readings	9 Months Operations	1	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	9 Months Operations	0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Accumulated Fault Duty A Ph AM	0	%
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Accumulated Fault Duty B Ph AM	0	%
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Accumulated Fault Duty C Ph AM	0	%
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Amps A Ø	0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Amps B Ø	0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Amps C Ø	0	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Follow-up Action Required?	n	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Operations Ground	0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Operations C Ø	0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Operations B Ø	0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Operations A Ø	0	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	General Comments		
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Amps C Ø	150	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Amps B Ø	120	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Amps A Ø	75	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Accumulated Fault Duty C Ph AM	3.2	%
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Accumulated Fault Duty B Ph AM	3.2	%
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Accumulated Fault Duty A Ph AM	3.2	%
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	9 Months Operations	0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	213	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	LTC Min Tap Position	5L	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1L	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	LTC Current Tap Position	3L	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	LTC As Left Counter	421618	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	LTC As Found Counter	421618	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	General Comments	GAUGE SHOWS LOW	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	General Comments		
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	9 Months Operations	3	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Accumulated Fault Duty A Ph AM	4.27	%
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Accumulated Fault Duty B Ph AM	14.94	%
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Accumulated Fault Duty C Ph AM	17.08	%
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Fault Operations B Ø	0	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Fault Operations A Ø	0	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Amps C Ø	0.0	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Amps B Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Amps A Ø	0.0	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Accumulated Fault Duty C Ph V	.05	%
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Accumulated Fault Duty B Ph V	.05	%
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Accumulated Fault Duty A Ph V	.05	%
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	9 Month Operations	26	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	BCH000131	Charger	OR-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	BCH000131	Charger	OR-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	BCH000131	Charger	OR-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Operations A Ø	0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Operations B Ø	0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Operations C Ø	0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Operations Ground	0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Follow-up Action Required?	n	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Patrol Inspection	General Comments		
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	General Comments		
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Maintenance Operations	0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Operations Counter AF	197	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Operations Counter AL	197	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Operations This Read AM	0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Switching Operations	0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Unknown Operations	0	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	Percent Thermal Load C Ø Max	-60	%
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.6	VDC
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.6	VDC
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	120.0	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	PN50	WithLTC	OR-TRANS 1	LTC Transformer Readings	Percent Thermal Load B Ø Max	-60	%
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	1.00	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	1.00	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	1.00	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	.05	%
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	.05	%
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	.05	%
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	24	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Unknown Operations	0	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Switching Operations	0	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Operations This Read Vac	0	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Operations Counter AL	107	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Operations Counter AF	107	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Maintenance Operations	0	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	General Comments		
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Follow-up Action Required?	n	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Fault Operations Ground	0	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Fault Operations C Ø	0	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Fault Operations B Ø	0	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Fault Operations A Ø	0	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Amps C Ø	11.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Amps B Ø	12.0	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Amps A Ø	16.0	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Accumulated Fault Duty C Ph V	0	%
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Accumulated Fault Duty B Ph V	0	%
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Accumulated Fault Duty A Ph V	0	%
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	9 Month Operations	15	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Unknown Operations	0	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Switching Operations	0	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Operations This Read Vac	0	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Operations Counter AL	170	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Operations Counter AF	170	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Maintenance Operations	0	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	General Comments		
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Follow-up Action Required?	n	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Fault Operations Ground	0	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Fault Operations C Ø	0	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	BAT001436	Battery	OR-Battery Bank	Battery Patrol Inspection	General Comments		
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	BAT001436	Battery	OR-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	BAT001436	Battery	OR-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	BAT001436	Battery	OR-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	BAT001436	Battery	OR-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	BAT001436	Battery	OR-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	BAT001436	Battery	OR-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	BAT001436	Battery	OR-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	BAT001436	Battery	OR-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	35	°F
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	BAT001436	Battery	OR-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	9 Months Operations	0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Amps A Ø	0.0	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Amps B Ø	0.0	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Amps C Ø	100.0	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	General Comments		
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	6	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	150.0	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	150.0	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	100.0	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	226	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Min Tap Position	4L	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	General Comments		
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BCH001343	Charger	690-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BCH001343	Charger	690-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BCH001343	Charger	690-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BCH001343	Charger	690-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BCH001343	Charger	690-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BCH001343	Charger	690-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BCH001343	Charger	690-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	General Comments		
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	LTC As Found Counter	273621	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	LTC As Left Counter	273621	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	LTC Max Tap Position	8L	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	LTC Min Tap Position	10L	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	42	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	BAT001436	Battery	OR-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	BAT001436	Battery	OR-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	BAT001436	Battery	OR-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	BAT001436	Battery	OR-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	General Comments		
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	36	*F
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	CH000460	ControlHouse	OR-Battery Control House	Control House Patrol Inspection	Broom on Site?	y	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	CH000460	ControlHouse	OR-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	CH000460	ControlHouse	OR-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	CH000460	ControlHouse	OR-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	CH000460	ControlHouse	OR-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	CH000460	ControlHouse	OR-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	CH000460	ControlHouse	OR-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	CH000460	ControlHouse	OR-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	CH000460	ControlHouse	OR-Battery Control House	Control House Patrol Inspection	General Comments		
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	CH000460	ControlHouse	OR-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	297	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	297	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	2	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	2	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Fault Operations A Ø	0	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Fault Operations B Ø	0	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Fault Operations C Ø	0	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Fault Operations Ground	0	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Follow-up Action Required?	n	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Patrol Inspection	General Comments		
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	General Comments		
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Operations Counter AF	315	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Operations Counter AL	315	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Operations This Read AM	0	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Switching Operations	0	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	LB0706	BreakerAirMagnetic	OR-2	AMCB Readings	Unknown Operations	0	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	General Comments		
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	Percent Thermal Load C Ø Max	-60	%
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	Percent Thermal Load B Ø Max	-60	%
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	Percent Thermal Load A Ø Max	-60	%
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	Oil Temp Present	14	°C
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	Oil Temp Max	28	°C
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0	psi
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	General Comments	Needs Nitro	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	General Comments		
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	General Comments		
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	Follow-up Action Required?	n	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	Totalizer Meter Reading	.7410	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	Percent Thermal Load C Ø Max	-60	%
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	Percent Thermal Load B Ø Max	-60	%
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	Percent Thermal Load A Ø Max	-60	%
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	Oil Temp Present	18	°C
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	Oil Temp Max	30	°C
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0	psi
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	General Comments	Needs Nitro	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	General Comments		
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Min Tap Position	5L	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Regulator As Left Counter	10810	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	General Comments		
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	LTC Totalizer Reading	7113.60	kw
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	Oil Temp Max	50	°C
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	Oil Temp Present	45	°C
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	SWG000092	Switchgear	OR-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	226	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	2	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	General Comments		
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	100.0	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	60.0	
12/17/2020 13:32	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
12/17/2020 11:00	Distribution	Ormsby Quarterly Inspection	PN50	LTCMechanism	OR-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	180.0	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Regulator As Left Counter	14281	
12/17/2020 14:37	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	576	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	576	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	6	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	180.0	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	175.0	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	180.0	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	381	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	381	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	110.0	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	12	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	LTCC000911	LTCControl	667-1	LTC Control Insp	All Connections OK?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	LTCC000911	LTCControl	667-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	LTCC000911	LTCControl	667-1	LTC Control Insp	Follow-up Action Required?	n	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	LTCC000911	LTCControl	667-1	LTC Control Insp	General Comments		
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	LTCC000911	LTCControl	667-1	LTC Control Insp	LTC Operation Checked?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	LTCC000911	LTCControl	667-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	LTCC000911	LTCControl	667-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	LTCC000911	LTCControl	667-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	LTC As Found Counter	94227	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	General Comments		
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	Follow-up Action Required?	n	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	LTC As Left Counter	94227	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	LTC Current Tap Position	1L	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	LTC Max Tap Position	2R	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	LTC Min Tap Position	11L	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	LTC Operations Since Last Insp	627	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Mechanism Patrol Inspection	General Comments		
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	Totalizer Meter Reading	.9423	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	Oil Temp Present	30	°C
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	Oil Temp Max	40	°C
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	LTC Totalizer Reading	9046.08	kw
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	General Comments		
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	General Comments		
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	LTCC000912	LTCControl	656-1	LTC Control Insp	Follow-up Action Required?	n	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	LTCC000912	LTCControl	656-1	LTC Control Insp	All Connections OK?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	General Comments		
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Foundation Condition	Good	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Follow-up Action Required?	n	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	LTCC000912	LTCControl	656-1	LTC Control Insp	General Comments		
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	LTCC000912	LTCControl	656-1	LTC Control Insp	LTC Operation Checked?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	General Comments		
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Grounds in Place?	y	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Fault Operations Ground	0	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Fault Operations C Ø	0	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	General Comments		
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Fault Operations B Ø	0	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Fault Operations A Ø	0	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LTCC000567	LTCControl	SP-TRANS 2	LTC Control Insp	General Comments	ok	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	General Comments		
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	Totalizer Meter Reading	.6138	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	General Comments		
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Vegetation	None	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Yard Lights Working?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	PF000334	PowerFuse	SP-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	PF000334	PowerFuse	SP-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	PF000333	PowerFuse	SP-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	PF000333	PowerFuse	SP-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	General Comments		
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	General Comments		
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	LTCC000912	LTCControl	656-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	LTCC000912	LTCControl	656-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	LTCC000912	LTCControl	656-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LTCC000567	LTCControl	SP-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Maintenance Operations	0	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Operations Counter AF	218	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Operations Counter AL	218	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Operations This Read Vac	1	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Switching Operations	1	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Tank Paint Condition	Good	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Unknown Operations	0	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	LTCC000912	LTCControl	656-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations A Ø	0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations B Ø	0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations C Ø	0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations Ground	0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Follow-up Action Required?	n	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Patrol Inspection	General Comments		
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	General Comments		
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Maintenance Operations	0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AF	81	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AL	81	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Operations This Read AM	0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Switching Operations	0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Unknown Operations	0	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	General Comments		
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	General Comments		
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	LTC Totalizer Reading	5892.48	kw
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	Oil Temp Max	60	°C
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	Oil Temp Present	19	°C
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	9 Month Operations	4	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Amps A Ø	180.0	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Amps B Ø	180.0	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Amps C Ø	130.0	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Bushing Condition	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Fault Operations A Ø	0	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Fault Operations B Ø	0	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Fault Operations C Ø	0	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Fault Operations Ground	0	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Follow-up Action Required?	n	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Foundation Condition	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	General Comments		
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	General Comments		
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Grounds in Place?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Maintenance Operations	0	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Operations Counter AF	187	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Operations Counter AL	187	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Operations This Read Vac	1	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Switching Operations	1	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Tank Paint Condition	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Unknown Operations	0	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Vegetation	None	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	General Comments		
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Ambient Temp	37	°F
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Unknown Operations	0	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Tank Paint Condition	Good	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Switching Operations	0	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	Follow-up Action Required?	n	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	General Comments		
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Mechanism Patrol Inspection	General Comments		
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	LTC As Found Counter	200636	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	LTC As Left Counter	200636	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	LTC Current Tap Position	4L	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	General Comments		
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	LTC Max Tap Position	2L	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	LTC Min Tap Position	9L	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?		
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Readings	General Comments		
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.8	psi
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	15.00	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	10.00	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	LTC Operations Since Last Insp	631	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	General Comments		
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Vegetation	None	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Ambient Temp	35	°F
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	General Comments		
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	General Comments		
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	General Comments		
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Foundation Condition	Good	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Follow-up Action Required?	n	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Fault Operations Ground	0	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Fault Operations C ∅	0	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Fault Operations B ∅	0	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Fault Operations A ∅	0	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	9 Months Operations	0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Clear of Obstacles?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Clear of Trash?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Amps A ∅	0.0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Amps B ∅	0.0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Amps C ∅	0.0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Operations This Read Vac	0	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Operations Counter AL	163	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Operations Counter AF	163	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Maintenance Operations	0	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Grounds in Place?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	General Comments		
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	General Comments		
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Foundation Condition	Good	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Follow-up Action Required?	n	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Fault Operations Ground	0	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Fault Operations C ∅	0	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Fault Operations B ∅	0	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Fault Operations A ∅	0	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Bushing Condition	Good	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Amps C Ø	55.0	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Amps B Ø	65.0	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Amps A Ø	85.0	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	9 Month Operations	4	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Unknown Operations	0	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Tank Paint Condition	Good	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Switching Operations	0	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Operations This Read Vac	0	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Operations Counter AL	164	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Operations Counter AF	164	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Maintenance Operations	0	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Grounds in Place?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	General Comments		
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Readings	Oil Temp Max	33	°C
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Readings	Oil Temp Present	15	°C
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	LTCC000620	LTCControl	527-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	LTCC000620	LTCControl	527-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	LTCC000620	LTCControl	527-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	LTCC000620	LTCControl	527-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	LTCC000620	LTCControl	527-1	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	LTCC000620	LTCControl	527-1	LTC Control Insp	LTC Operation Checked?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	LTCC000620	LTCControl	527-1	LTC Control Insp	General Comments		
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	LTCC000620	LTCControl	527-1	LTC Control Insp	Follow-up Action Required?	n	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	LTCC000620	LTCControl	527-1	LTC Control Insp	All Connections OK?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	Oil Temp Present	40	°C
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	Oil Temp Max	50	°C
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	LTC Totalizer Reading	9129.60	kw
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	General Comments		
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	General Comments		
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	24	°C
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	63	°C
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	25	°C
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	63	°C
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	22	°C
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	BCH000475	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	BCH000475	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	BCH000475	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	BCH000475	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	BCH000475	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	BCH000475	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	58	°C
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	Oil Temp Present	22	°C
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	Oil Temp Max	58	°C
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	General Comments		
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	General Comments		
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	LTC Totalizer Reading	6864.00	kw
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Low	If low,note cell #~'s
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	General Comments	LOW BATTERY WATER	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	36	°F
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Low	If low,note cell #~'s
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	y	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	General Comments	LOW BATTERY WATER	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Ambient Temp	36	°F
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	4	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	65.0	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	65.0	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	105.0	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	35	*F
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	55.00	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	Totalizer Meter Reading	.9510	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Readings	Oil Temp Present	5	°C
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Readings	Oil Temp Max	30	°C
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	220.00	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	225.00	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.8	psi
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	General Comments	ok	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Readings	General Comments		
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Fault Operations Ground	0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Patrol Inspection	General Comments		
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	General Comments		
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Maintenance Operations	0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Operations Counter AF	424	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Operations Counter AL	424	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Operations This Read AM	0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Switching Operations	0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Unknown Operations	0	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Vegetation	None	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	General Comments		
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	0	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	478	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	478	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Ambient Temp	35	*F
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	Oil Temp Max	30	°C
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	Oil Temp Present	30	°C
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	Totalizer Meter Reading	.7150	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	General Comments		
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	9 Months Operations	7	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Amps A Ø	400.0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Amps B Ø	450.0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Amps C Ø	250.0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	General Comments	Needs Nitro	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Vegetation	None	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	General Comments		
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Ambient Temp	38	*F
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	General Comments		
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Fault Operations A Ø	0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Fault Operations B Ø	0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Fault Operations C Ø	0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.1	amps
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	Follow-up Action Required?	n	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	9 Month Operations	4	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	General Comments		
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Mechanism Patrol Inspection	General Comments		
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	LTC As Found Counter	7619	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	LTC As Left Counter	7619	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	LTC Max Tap Position	5R	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	LTC Min Tap Position	10L	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	LTC Operations Since Last Insp	712	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Bushing Condition	Good	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Amps C Ø	80.0	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Amps B Ø	50.0	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Amps A Ø	60.0	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	9 Month Operations	4	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Unknown Operations	0	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Tank Paint Condition	Good	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Switching Operations	0	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Operations This Read Vac	0	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Operations Counter AL	209	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Operations Counter AF	209	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Maintenance Operations	0	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Grounds in Place?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	General Comments		
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Foundation Condition	Good	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Follow-up Action Required?	n	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Fault Operations Ground	0	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Fault Operations C Ø	0	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Fault Operations B Ø	0	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Fault Operations A Ø	0	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Bushing Condition	Good	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Amps C Ø	205.0	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Amps B Ø	180.0	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Amps A Ø	195.0	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	9 Month Operations	3	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Bushing Condition	Good	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Amps C Ø	130.0	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Amps B Ø	110.0	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Amps A Ø	125.0	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	9 Month Operations	5	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	54	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	54	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	16	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	General Comments		
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Fault Operations A Ø	0	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Fault Operations B Ø	0	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Fault Operations C Ø	0	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Fault Operations Ground	0	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	LTCC000769	LTCControl	569-1	LTC Control Insp	General Comments		
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	LTCC000769	LTCControl	569-1	LTC Control Insp	Follow-up Action Required?	n	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	LTCC000769	LTCControl	569-1	LTC Control Insp	All Connections OK?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Foundation Condition	Good	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	General Comments		
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	General Comments		
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Grounds in Place?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Operations Counter AF	229	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Operations Counter AL	229	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Operations This Read Vac	0	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Switching Operations	0	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Tank Paint Condition	Good	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Unknown Operations	0	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	10.0	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	10.0	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	10.0	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Vegetation	None	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	General Comments		
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	35	*F
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Amps A Ø	10.0	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	General Comments		
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	General Comments		
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	General Comments		
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	LTC Operations Since Last Insp	161	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	LTC Min Tap Position	11L	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	LTC Max Tap Position	5L	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	LTC Current Tap Position	8L	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	LTC As Left Counter	21553	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	LTC As Found Counter	21553	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Mechanism Patrol Inspection	General Comments		
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	General Comments		
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	Follow-up Action Required?	n	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	LTCC000769	LTCControl	569-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	LTCC000769	LTCControl	569-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	LTCC000769	LTCControl	569-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	LTCC000769	LTCControl	569-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	LTCC000769	LTCControl	569-1	LTC Control Insp	LTC Operation Checked?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Amps B Ø	10.0	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Amps C Ø	10.0	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Bushing Condition	Good	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	General Comments		
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Readings	Oil Temp Present	22	°C
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Readings	Oil Temp Max	39	°C
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	30.00	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	General Comments		
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Vegetation	None	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Unknown Operations	0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Switching Operations	0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Operations This Read AM	0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Operations Counter AL	104	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Operations Counter AF	104	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Maintenance Operations	0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	General Comments		
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Patrol Inspection	General Comments		
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Follow-up Action Required?	n	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Unknown Operations	0	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Tank Paint Condition	Good	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Switching Operations	0	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Operations This Read Vac	0	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Operations Counter AL	243	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Operations Counter AF	243	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Maintenance Operations	0	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Grounds in Place?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	General Comments		
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	General Comments		
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Foundation Condition	Good	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Follow-up Action Required?	n	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BAT001499	Battery	694-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BAT001499	Battery	694-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BAT001499	Battery	694-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BAT001499	Battery	694-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BAT001499	Battery	694-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BAT001499	Battery	694-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BAT001499	Battery	694-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	36	*F
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Fault Operations B Ø	0	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Fault Operations C Ø	0	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Fault Operations A Ø	0	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	General Comments		
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Amps A Ø	30.0	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	9 Month Operations	8	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Unknown Operations	0	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Tank Paint Condition	Good	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Bushing Condition	Good	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Amps C Ø	120.0	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Amps B Ø	130.0	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Amps A Ø	150.0	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BAT001499	Battery	694-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Unknown Operations	0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Switching Operations	0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Operations This Read AM	0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Operations Counter AL	145	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Operations Counter AF	145	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Maintenance Operations	0	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Switching Operations	0	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Operations This Read Vac	0	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Operations Counter AL	144	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Operations Counter AF	144	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Maintenance Operations	0	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	General Comments		
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Patrol Inspection	General Comments		
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	9 Month Operations	8	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Amps C Ø	391.0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Amps B Ø	492.0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Amps A Ø	402.0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	9 Months Operations	0	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	9 Months Operations	0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Amps A Ø	100.0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	General Comments		
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	Totalizer Meter Reading	.3990	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	Oil Temp Present	45	°C
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	Oil Temp Max	50	°C
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	LTC Totalizer Reading	3830.40	kw
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	General Comments		
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	General Comments		
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Grounds in Place?	y	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Maintenance Operations	0	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Operations Counter AF	262	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Operations Counter AL	262	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Operations This Read Vac	0	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Fault Operations Ground	0	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Fault Operations C Ø	0	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Fault Operations B Ø	0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Fault Operations Ground	0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Fault Operations C Ø	0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Fault Operations B Ø	0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Fault Operations A Ø	0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Amps C Ø	50.0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Amps B Ø	75.0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Amps A Ø	50.0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	LTCC000250	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	LTCC000250	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	LTCC000250	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	LTCC000250	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	LTCC000250	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	LTCC000250	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	LTCC000250	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	LTCC000250	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	LTCC000250	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	45.00	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Amps B Ø	140.0	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Amps A Ø	180.0	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	9 Month Operations	6	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Readings	General Comments		
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	9 Months Operations	0	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Fault Operations A Ø	0	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Bushing Condition	Good	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Amps C Ø	120.0	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Amps B Ø	130.0	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Amps A Ø	110.0	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	9 Month Operations	3	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	LTC Min Tap Position	13L	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	LTC Max Tap Position	2L	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	LTC Current Tap Position	10L	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	LTC As Left Counter	226721	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	LTC As Found Counter	226721	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	9 Months Operations	2	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	General Comments		
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Fault Operations A Ø	0	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Fault Operations B Ø	0	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Fault Operations C Ø	0	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Fault Operations Ground	0	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Follow-up Action Required?	n	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Foundation Condition	Good	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	General Comments		
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	General Comments		
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Amps A Ø	320.0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Amps B Ø	300.0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Amps C Ø	280.0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Fault Operations C Ø	0	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Fault Operations Ground	0	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	General Comments		
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Amps B Ø	150.0	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Amps C Ø	180.0	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Switching Operations	0	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Tank Paint Condition	Good	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Unknown Operations	0	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Maintenance Operations	0	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Grounds in Place?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	General Comments		
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	General Comments		
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Foundation Condition	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Follow-up Action Required?	n	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Fault Operations Ground	0	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Fault Operations C Ø	0	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Fault Operations B Ø	0	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Fault Operations A Ø	0	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	General Comments		
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	General Comments		
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Readings	General Comments		
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Amps A Ø	120.0	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Operations This Read Vac	0	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Operations Counter AL	273	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Operations Counter AF	200	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	Oil Temp Present	40	°C
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	Oil Temp Max	50	°C
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	LTC Totalizer Reading	2872.80	kw
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	General Comments		
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	General Comments		
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Operations Counter AL	200	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Operations This Read Vac	4	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Switching Operations	4	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Tank Paint Condition	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Unknown Operations	0	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Mechanism Patrol Inspection	General Comments		
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	LTC As Found Counter	73706	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	LTC As Left Counter	73706	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	LTC Current Tap Position	7L	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	9 Month Operations	9	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	LTC Max Tap Position	4L	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	LTC Min Tap Position	11L	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	LTC Operations Since Last Insp	314	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Fault Operations A Ø	0	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Fault Operations B Ø	0	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	628	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	LTC Operations Since Last Insp	661	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	LTC Min Tap Position	14L	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	LTC Current Tap Position	4L	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	LTC As Left Counter	8497	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	LTC As Found Counter	8497	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Mechanism Patrol Inspection	General Comments		
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	General Comments		
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	Follow-up Action Required?	n	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Bushing Condition	Good	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Amps C Ø	49.0	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Amps B Ø	32.0	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Readings	Oil Temp Present	22	°C
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Readings	Oil Temp Max	37	°C
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	75.00	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	80.00	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Readings	General Comments		
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BAT001499	Battery	694-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BAT001499	Battery	694-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BAT001499	Battery	694-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Operations Counter AF	273	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Maintenance Operations	0	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Grounds in Place?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	General Comments		
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	General Comments		
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Foundation Condition	Good	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Follow-up Action Required?	n	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Fault Operations Ground	0	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BAT001499	Battery	694-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BAT001499	Battery	694-Battery Bank	Battery Patrol Inspection	General Comments	L	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BAT001499	Battery	694-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BAT001499	Battery	694-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	221.67	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	200.00	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	Follow-up Action Required?	n	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Readings	Oil Temp Max	36	°C
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Fault Operations A Ø	1	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Fault Operations B Ø	1	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Fault Operations C Ø	0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Fault Operations Ground	0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Follow-up Action Required?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Patrol Inspection	General Comments		
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	General Comments	No VC Change	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Maintenance Operations	0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Operations Counter AF	2467	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Operations Counter AL	2467	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Operations This Read AM	2	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Switching Operations	0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Unknown Operations	0	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Readings	Oil Temp Present	20	°C
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Follow-up Action Required?	n	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Foundation Condition	Good	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	General Comments		
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	General Comments		
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Grounds in Place?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Maintenance Operations	0	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Operations Counter AF	165	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Operations Counter AL	165	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Operations This Read Vac	0	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Switching Operations	0	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Tank Paint Condition	Good	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Unknown Operations	0	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Bushing Condition	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Amps C Ø	145.0	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	9 Month Operations	3	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Unknown Operations	0	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Tank Paint Condition	Good	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Switching Operations	0	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Operations This Read Vac	0	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Operations Counter AL	163	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Operations Counter AF	163	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	General Comments		
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Grounds in Place?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	General Comments		
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	General Comments		
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Foundation Condition	Good	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Follow-up Action Required?	n	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Fault Operations Ground	0	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Fault Operations C Ø	0	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Fault Operations B Ø	0	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Fault Operations A Ø	0	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Bushing Condition	Good	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Amps C Ø	67.0	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Amps B Ø	65.0	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Amps A Ø	55.0	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	9 Month Operations	4	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Bushing Condition	Good	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	General Comments	LOW WATER	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	y	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Low	If low,note cell #'s
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	35	°F
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	General Comments		
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	General Comments		
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Grounds in Place?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Maintenance Operations	0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Operations Counter AF	717	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Operations Counter AL	717	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Operations This Read Vac	0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Switching Operations	0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Tank Paint Condition	Good	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Unknown Operations	0	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	General Comments		
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	38	*F
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Bushing Condition	Good	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	35	*F
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	General Comments		
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Amps C Ø	34.0	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Amps B Ø	48.0	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Amps A Ø	58.0	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Switching Operations	1	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	LTCC000841	LTCControl	885-1	LTC Control Insp	All Connections OK?	y	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	LTCC000841	LTCControl	885-1	LTC Control Insp	Follow-up Action Required?	n	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Tank Paint Condition	Good	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Unknown Operations	0	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	General Comments		
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	General Comments		
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	LTC Totalizer Reading	5207.04	kw
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	Oil Temp Max	40	°C
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	Oil Temp Present	20	°C
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	Totalizer Meter Reading	1.0848	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	Winding Temp Max	30	°C
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	Winding Temp Present	20	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	Follow-up Action Required?	n	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	9 Month Operations	3	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	General Comments		
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	General Comments		
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	LTC As Found Counter	12731	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	LTC As Left Counter	12731	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	LTC Max Tap Position	2R	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	LTC Min Tap Position	4L	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	35	°C
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	18	°C
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	LTC Operations Since Last Insp	239	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Amps A Ø	58.0	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Amps B Ø	48.0	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Amps C Ø	45.0	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Bushing Condition	Good	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Fault Operations A Ø	0	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	LTCC000648	LTCControl	824-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	LTCC000648	LTCControl	824-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	LTCC000648	LTCControl	824-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	LTCC000648	LTCControl	824-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	LTCC000648	LTCControl	824-1	LTC Control Insp	LTC Operation Checked?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	LTCC000648	LTCControl	824-1	LTC Control Insp	General Comments		
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	LTCC000648	LTCControl	824-1	LTC Control Insp	Follow-up Action Required?	n	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	LTCC000648	LTCControl	824-1	LTC Control Insp	All Connections OK?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Fault Operations B Ø	0	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Fault Operations C Ø	0	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Fault Operations Ground	0	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Follow-up Action Required?	n	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Foundation Condition	Good	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	General Comments		
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	General Comments		
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	132.0	VDC
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	132.0	VDC
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Grounds in Place?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Maintenance Operations	0	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	Totalizer Meter Reading	.3990	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Operations Counter AF	189	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Operations Counter AL	189	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	LTCC000841	LTCControl	885-1	LTC Control Insp	VRR Time Delay	30	Seconds

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	LTCC000841	LTCControl	885-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	LTCC000841	LTCControl	885-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	LTCC000841	LTCControl	885-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	LTCC000841	LTCControl	885-1	LTC Control Insp	LTC Output Voltage Level	1254.0	VAC
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	LTCC000841	LTCControl	885-1	LTC Control Insp	LTC Operation Checked?	y	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	LTCC000841	LTCControl	885-1	LTC Control Insp	General Comments		
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Operations This Read Vac	1	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Bushings Connection/Risers	Good	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Cabinet Paint Condition	Good	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Equipment Properly Labeled?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Fault Operations	0	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Follow-up Action Required?	n	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Foundation Condition	Good	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Gauge(s) Condition	Good	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	General Comments		
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	General Comments		
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Grounds in Place?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Heaters (All) Functioning?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Maintenance Operations	0	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Moisture and Leak Free?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Number of Ops last 9 Months	0	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Operations Counter AF	426	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Operations Counter AL	426	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Operations This Read Oil	0	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Fault Operations Ground	0	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Fault Operations C Ø	0	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Fault Operations B Ø	0	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Fault Operations A Ø	0	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	BCH001089	Charger	SP-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	BCH001089	Charger	SP-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	BCH001089	Charger	SP-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	BCH001089	Charger	SP-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.8	amps
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	BCH001089	Charger	SP-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	BCH001089	Charger	SP-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	BCH001089	Charger	SP-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	9 Month Operations	12	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Amps A Ø	20.0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Amps B Ø	20.0	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	General Comments		
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/18/2020 6:51	Distribution	Middletown Quarterly Inspection	PF000235	PowerFuse	MT-STA SER NO 4 LINE	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/18/2020 6:51	Distribution	Middletown Quarterly Inspection	PF000235	PowerFuse	MT-STA SER NO 4 LINE	Disconnect Powerfuse Inspection	General Comments	ok	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/16/2020 14:39	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Switching Operations	0	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Tank Paint Condition	Good	
12/16/2020 14:28	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Unknown Operations	0	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Amps B Ø	100.0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Amps C Ø	100.0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Fault Operations A Ø	0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Fault Operations B Ø	0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Fault Operations C Ø	0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Fault Operations Ground	0	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Air Compressor Oil Status	Good	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Air Leaks	None	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Air Pressure OK?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Follow-up Action Required?	n	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Patrol Inspection	General Comments		
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	General Comments		
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Maintenance Operations	0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Operations Counter AF	240	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Operations Counter AL	240	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Operations This Read AM	0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Switching Operations	0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Unknown Operations	0	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Grounds in Place?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	General Comments		
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	General Comments		
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Foundation Condition	Good	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Follow-up Action Required?	n	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Bushing Condition	Good	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Bushing Oil Level	Good	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BCH001314	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BCH001314	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BCH001314	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Battery Charger Current	2.0	amps
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BCH001314	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BCH001314	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BCH001314	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	General Comments		
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BCH001314	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Ground Lights	None	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BCH001315	Charger	737-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BCH001315	Charger	737-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	General Comments		
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Vegetation	None	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BCH001315	Charger	737-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BCH001315	Charger	737-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BCH001315	Charger	737-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BCH001315	Charger	737-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/16/2020 8:36	Distribution	Mount Sterling Quarterly Inspection	BCH001315	Charger	737-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	General Comments		
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Amps C Ø	20.0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Bushing Condition	Good	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Fault Operations A Ø	0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Fault Operations B Ø	0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Fault Operations C Ø	0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Fault Operations Ground	0	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Follow-up Action Required?	n	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Follow-up Action Required?	n	
12/16/2020 9:45	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Foundation Condition	Good	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Unknown Operations	0	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Pop-off Valve Tested Date	2020-04-08 00:00:00.000000	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Pressure Vessel Condition	Good	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/16/2020 11:05	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Ambient Temp	34	*F
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Switching Operations	0	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Tank 1 Oil Level	Good	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Tank 2 Oil level	Good	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Tank 3 Oil Level	Good	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Tank Leaks	None	
12/16/2020 11:05	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Tank Paint Condition	Good	
12/16/2020 8:21	Distribution	Camargo Quarterly Inspection	BCH001314	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/16/2020 11:55	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	82	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	73.0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	82	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	74.0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	48.0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	7.97	%
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	14.62	%
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	11.96	%
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	3	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Operations This Read Vac	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Unknown Operations	0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	Winding Temp Present	40	°C
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	9 Month Operations	1	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Amps A Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Amps B Ø	0.0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Maintenance Operations	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Operations Counter AF	145	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Operations Counter AL	145	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Operations This Read Vac	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Switching Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Unknown Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Switching Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Operations This Read Oil	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Operations Counter AL	363	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Operations Counter AF	363	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Number of Ops last 9 Months	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Maintenance Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Fault Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Amps C Ø	0.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Amps B Ø	0.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Amps A Ø	0.0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	PF001201	PowerFuse	MK-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	PF001201	PowerFuse	MK-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	PF001202	PowerFuse	MK-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	PF001202	PowerFuse	MK-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Unknown Operations	0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Amps C Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Fault Operations C Ø	0	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Fault Operations B Ø	0	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Fault Operations A Ø	0	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	General Comments		
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	55	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Amps C Ø	233.0	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Amps B Ø	123.0	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Amps A Ø	221.0	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	9 Month Operations	1	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	General Comments		
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Operations Counter AF	71	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	35	*F
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Operations Counter AL	71	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Operations This Read Vac	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Switching Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Unknown Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Unknown Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Switching Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Operations This Read Vac	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Operations Counter AL	151	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Operations Counter AF	151	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Maintenance Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Fault Operations Ground	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Fault Operations C Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Fault Operations B Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Fault Operations A Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Amps C Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Amps B Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Amps A Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	9 Month Operations	1	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #''s
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	General Comments		
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Fault Operations A Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Fault Operations B Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Fault Operations C Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Fault Operations Ground	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0313	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0313	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0313	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0313	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0313	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0313	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Operations Counter AL	178	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Operations This Read Vac	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Switching Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Unknown Operations	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Amps A Ø	480.0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Amps B Ø	480.0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Amps C Ø	480.0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Bushing Condition	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Fault Operations A Ø	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Fault Operations B Ø	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Fault Operations C Ø	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Fault Operations Ground	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Follow-up Action Required?	n	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	General Comments		
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	General Comments		
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Bushing Condition	Good	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Maintenance Operations	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Operations Counter AF	64	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Operations Counter AL	64	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Fault Operations Ground	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Fault Operations C Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Fault Operations B Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Fault Operations A Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Amps C Ø	50.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Amps B Ø	60.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Amps A Ø	60.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	9 Month Operations	18	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Operations Counter AF	289	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Maintenance Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	General Comments		
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Vegetation	None	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	General Comments		
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Fault Operations Ground	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Fault Operations C Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Fault Operations B Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Fault Operations A Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Amps C Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Amps B Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Amps A Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	9 Month Operations	10	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	General Comments		
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Ambient Temp	32	°F
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Bushing Condition	Good	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Amps C Ø	71.0	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Amps B Ø	68.0	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Amps A Ø	58.0	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Fault Operations A Ø	0	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Fault Operations B Ø	0	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Fault Operations C Ø	0	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Fault Operations Ground	0	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Follow-up Action Required?	n	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	General Comments		
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	General Comments		
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Maintenance Operations	0	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Operations Counter AF	173	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Operations Counter AL	173	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	PN8	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Operations This Read Vac	0	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Switching Operations	0	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	9 Month Operations	6	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	PN8	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	PN8	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	PN8	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	PN8	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	PN8	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments		
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	PN8	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	General Comments		
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	PN8	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	PN8	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	PN8	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	PN8	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Unknown Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Switching Operations	1	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Operations This Read Vac	1	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Operations Counter AL	289	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Unknown Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Switching Operations	0	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Operations This Read Vac	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Operations Counter AL	243	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Operations Counter AF	243	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Maintenance Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Fault Operations C Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Fault Operations B Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Fault Operations A Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Amps C Ø	110.0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Maintenance Operations	0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Operations Counter AF	182	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Operations Counter AL	185	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Operations This Read Vac	0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Switching Operations	0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	Winding Temp Present	15	°C
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	Winding Temp Max	32	°C
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	Totalizer Meter Reading	.7590	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	Oil Temp Present	17	°C
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	Oil Temp Max	34	°C
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	LTC Totalizer Reading	5464.80	kw
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	General Comments		
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Unknown Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Switching Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Operations This Read Vac	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Operations Counter AL	90	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Operations Counter AF	90	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Maintenance Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Fault Operations Ground	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Fault Operations C Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Fault Operations B Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Fault Operations A Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Unknown Operations	0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	LTC Totalizer Reading	12618.00	kw
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	General Comments		
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	General Comments		
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	General Comments		
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Patrol Inspection	General Comments		
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Follow-up Action Required?	n	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Fault Operations Ground	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Operations Counter AL	149	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Operations Counter AF	149	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	Winding Temp Max	70	°C
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Maintenance Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Fault Operations Ground	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Fault Operations C Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Fault Operations B Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Fault Operations A Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	Totalizer Meter Reading	.7010	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	Oil Temp Present	35	°C
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	Oil Temp Max	65	°C
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1800	psi
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	9 Month Operations	12	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Amps A Ø	60.0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Amps B Ø	65.0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Amps C Ø	60.0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Bushing Condition	Good	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Fault Operations A Ø	0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Fault Operations B Ø	0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Fault Operations C Ø	0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Fault Operations Ground	0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Follow-up Action Required?	n	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	General Comments		
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	General Comments		
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Amps C Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Amps B Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Amps A Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	9 Month Operations	0	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Unknown Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Switching Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Operations This Read Vac	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Operations Counter AL	147	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Operations Counter AF	147	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Maintenance Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Fault Operations Ground	0	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Vegetation	None	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Ambient Temp	36	*F
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Amps C Ø	77.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Amps B Ø	74.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Amps A Ø	75.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	9 Month Operations	1	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	General Comments		
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Vegetation	None	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Yard Lights Working?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	9 Month Operations	1	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Amps A Ø	50.0	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Amps B Ø	50.0	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Amps C Ø	50.0	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	General Comments		
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Operations Counter	1451	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	General Comments		
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Ambient Temp	36	*F
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	General Comments		
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	PF000228	PowerFuse	MK-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Warning Signs OK?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Tank Leaks	None	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Grounds in Place?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Foundation Condition	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Unknown Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Switching Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Operations This Read Vac	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Operations Counter AL	50	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Operations Counter AF	50	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Maintenance Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Fault Operations Ground	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Fault Operations C Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Fault Operations B Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Fault Operations A Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Fault Operations C Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Fault Operations B Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Fault Operations A Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	General Comments		
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Amps C Ø	90.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Amps B Ø	93.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Amps A Ø	95.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	9 Month Operations	3	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Ambient Temp	20	*F
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	General Comments		
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Fault Operations A Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Fault Operations B Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Fault Operations C Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Fault Operations Ground	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	9 Month Operations	1	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Maintenance Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Operations Counter AF	82	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Operations Counter AL	82	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Operations This Read Vac	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Switching Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Unknown Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Bushing Condition	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	All Connections OK?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Vegetation	None	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	General Comments		
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Unknown Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Switching Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Operations This Read Vac	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Operations Counter AL	81	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Operations Counter AF	81	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Maintenance Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Fault Operations Ground	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Fault Operations C Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Fault Operations B Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Fault Operations A Ø	0	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Operations This Read Vac	0	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Operations Counter AL	172	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Operations Counter AF	172	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Maintenance Operations	0	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	General Comments		
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	General Comments		
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Follow-up Action Required?	n	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Fault Operations Ground	0	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Fault Operations C Ø	0	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Fault Operations B Ø	0	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Unknown Operations	0	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Switching Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	PF000413	PowerFuse	WS-1472 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	PF000413	PowerFuse	WS-1472 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	PF000412	PowerFuse	WS-1473 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	PF000412	PowerFuse	WS-1473 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	PF000411	PowerFuse	WS-1474 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	PF000411	PowerFuse	WS-1474 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	PF000409	PowerFuse	WS-1303 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	PF000409	PowerFuse	WS-1303 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	PF000408	PowerFuse	WS-1304 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	PF000408	PowerFuse	WS-1304 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	PF000407	PowerFuse	WS-1331 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	PF000407	PowerFuse	WS-1331 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	PF000405	PowerFuse	WS-1333 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	PF000405	PowerFuse	WS-1333 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	PF000404	PowerFuse	WS-1334 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	PF000404	PowerFuse	WS-1334 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	PF000403	PowerFuse	WS-1335 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	PF000403	PowerFuse	WS-1335 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Operations This Read Vac	0	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Operations Counter AL	338	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Operations Counter AF	338	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Maintenance Operations	0	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	General Comments		
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	General Comments		
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Follow-up Action Required?	n	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Fault Operations Ground	0	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Fault Operations C Ø	0	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Fault Operations B Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	PF000389	PowerFuse	WS-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	PF000388	PowerFuse	WS-14KV BUS SEC 4 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Maintenance Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	PF000388	PowerFuse	WS-14KV BUS SEC 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	PF000386	PowerFuse	WS-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	PF000386	PowerFuse	WS-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	PF000385	PowerFuse	WS-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	PF000385	PowerFuse	WS-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	9 Month Operations	16	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Amps A Ø	12.0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Amps B Ø	10.0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Amps C Ø	8.0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Bushing Condition	Good	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Fault Operations A Ø	0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Fault Operations B Ø	0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Fault Operations C Ø	0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Fault Operations Ground	0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Follow-up Action Required?	n	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	General Comments		
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	General Comments		
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Maintenance Operations	0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Operations Counter AF	259	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Operations Counter AL	259	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Operations This Read Vac	0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Switching Operations	0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Unknown Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Operations Counter AF	171	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Operations Counter AL	171	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Operations This Read Vac	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Switching Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Unknown Operations	0	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Unknown Operations	0	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Switching Operations	0	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Warning Signs OK?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Tank Leaks	None	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Grounds in Place?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Foundation Condition	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Grounds in Place?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Amps B Ø	144.0	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Amps A Ø	138.0	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Foundation Condition	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Capacitor Condition	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Bushing Condition	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	All Connections OK?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Fault Operations C Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Fault Operations Ground	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Maintenance Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Operations Counter AF	146	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Operations Counter AL	146	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Operations This Read Vac	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Switching Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Unknown Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Operations This Read Vac	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Switching Operations	0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	General Comments		
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Unknown Operations	1	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Switching Operations	0	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Operations This Read Vac	1	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Operations Counter AL	277	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Operations Counter AF	277	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Maintenance Operations	0	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	General Comments		
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Unknown Operations	0	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	9 Month Operations	0	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Follow-up Action Required?	n	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Fault Operations Ground	0	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Fault Operations C Ø	0	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Fault Operations B Ø	0	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Fault Operations A Ø	0	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Fault Adjusted Amps C Phase V	6.41	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Fault Adjusted Amps B Phase V	6.41	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Fault Adjusted Amps A Phase V	6.41	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	General Comments		
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Bushing Condition	Good	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Amps C Ø	235.0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Amps B Ø	215.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Amps A Ø	210.0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	9 Month Operations	15	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	9 Month Operations	1	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Amps A Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Amps B Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Amps C Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Fault Operations A Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Fault Operations B Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Fault Operations C Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Fault Operations Ground	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Maintenance Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Operations Counter AF	45	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Operations Counter AL	45	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000161	LTCControl	809-2	LTC Control Insp	VRR Time Delay	30	Seconds
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000161	LTCControl	809-2	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000161	LTCControl	809-2	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000161	LTCControl	809-2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000161	LTCControl	809-2	LTC Control Insp	LTC Output Voltage Level	125.2	VAC
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000161	LTCControl	809-2	LTC Control Insp	LTC Operation Checked?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000161	LTCControl	809-2	LTC Control Insp	General Comments		
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000161	LTCControl	809-2	LTC Control Insp	Follow-up Action Required?	n	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000161	LTCControl	809-2	LTC Control Insp	All Connections OK?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	9 Month Operations	1	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Amps A Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Amps B Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Amps C Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Fault Operations A Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Fault Operations B Ø	0	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Amps C Ø	144.0	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Amps B Ø	150.0	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Amps A Ø	136.0	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	9 Month Operations	3	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Amps B Ø	175.0	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Amps C Ø	194.0	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Bushing Condition	Good	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Unknown Operations	0	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Switching Operations	0	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Operations This Read Vac	0	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Operations Counter AL	80	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Operations Counter AF	80	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Maintenance Operations	0	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	General Comments		
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	General Comments		
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Follow-up Action Required?	n	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Fault Operations Ground	0	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Fault Operations C Ø	0	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Fault Operations B Ø	0	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Fault Operations A Ø	0	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Bushing Condition	Good	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	General Comments		
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	General Comments		
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	LTC Totalizer Reading	13482.00	kw
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	Oil Temp Max	60	°C
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Amps A Ø	179.0	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	Oil Temp Present	27	°C
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	Totalizer Meter Reading	.7490	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	Winding Temp Max	50	°C
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	Winding Temp Present	46	°C
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	110.00	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	General Comments		
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Vegetation	None	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	General Comments		
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	Follow-up Action Required?	n	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	General Comments		
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	General Comments		
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	LTC Totalizer Reading	12236.40	kw
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	Oil Temp Max	35	°C
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	Oil Temp Present	35	°C
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	TX000206	WithLTC	SW-B TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Vegetation	None	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Ambient Temp	33	°F
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Amps A Ø	95.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	9 Month Operations	1	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	General Comments		
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	LTC As Found Counter	26954	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	LTC As Left Counter	26954	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	LTC Current Tap Position	1L	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	LTC Max Tap Position	Neutral	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	LTC Min Tap Position	4L	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	45	°C
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	328	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	General Comments		
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0181	NonLTC	SSC-PORT TRANS 5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Unknown Operations	0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Switching Operations	0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Operations This Read Vac	0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Operations Counter AL	217	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Operations Counter AF	217	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Maintenance Operations	0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	General Comments		
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	General Comments		
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Follow-up Action Required?	n	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Fault Operations Ground	0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Fault Operations C Ø	0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Fault Operations B Ø	0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Fault Operations A Ø	0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	Totalizer Meter Reading	.6798	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	Winding Temp Max	59	°C
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	Winding Temp Present	35	°C
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	General Comments		
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	LTC Totalizer Reading	910.08	kw
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Oil Temp Max	48	°C
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Oil Temp Present	29	°C
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Totalizer Meter Reading	.1896	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Ambient Temp	32	°F
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Amps C Ø	310.0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Bushing Condition	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Fault Operations A Ø	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Fault Operations B Ø	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Fault Operations C Ø	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Fault Operations Ground	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Follow-up Action Required?	n	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	General Comments		
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	General Comments		
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Maintenance Operations	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Operations Counter AF	280	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Operations Counter AL	280	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Operations This Read Vac	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Switching Operations	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Unknown Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	9 Month Operations	2	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Amps A Ø	420.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Amps B Ø	413.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Amps C Ø	416.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Fault Operations A Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Fault Operations B Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Fault Operations C Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Fault Operations Ground	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	General Comments	checked vc	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Maintenance Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Operations Counter AF	188	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	General Comments		
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	415	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	LTC Min Tap Position	8L	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1R	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6L	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	LTC As Left Counter	116407	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	LTC As Found Counter	116407	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	General Comments		
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	41	*F
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	9 Month Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Amps A Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Amps B Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Amps C Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Unknown Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Unknown Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Switching Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Operations This Read Vac	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Operations Counter AL	96	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Operations Counter AF	96	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Maintenance Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Fault Operations Ground	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Fault Operations C Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Fault Operations B Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Fault Operations A Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Amps C Ø	84.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Amps B Ø	85.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Amps A Ø	88.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	9 Month Operations	1	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.1	amps
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Ambient Temp	35	*F
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	BCH001256	Charger	552-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	BCH001256	Charger	552-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	BCH001256	Charger	552-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	BCH001256	Charger	552-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.1	amps
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	BCH001256	Charger	552-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	BCH001256	Charger	552-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	BCH001257	Charger	636-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	BCH001257	Charger	636-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	BCH001257	Charger	636-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	BCH001257	Charger	636-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.8	amps
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	BCH001257	Charger	636-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	9 Month Operations	1	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Amps C Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Fault Operations A Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Fault Operations B Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Fault Operations C Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Fault Operations Ground	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Maintenance Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Operations Counter AF	170	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Operations Counter AL	170	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Operations This Read Vac	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Switching Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Unknown Operations	0	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	9 Month Operations	0	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Amps A Ø	355.0	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Amps B Ø	330.0	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Amps C Ø	350.0	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Bushing Condition	Good	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Fault Operations A Ø	0	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Fault Operations B Ø	0	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Fault Operations C Ø	0	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Fault Operations Ground	0	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Follow-up Action Required?	n	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	General Comments		
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	General Comments		
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Maintenance Operations	0	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Fault Operations Ground	0	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Follow-up Action Required?	n	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	General Comments		
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	General Comments		
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Maintenance Operations	0	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Operations Counter AF	180	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Operations Counter AL	180	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Operations This Read Vac	0	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Switching Operations	0	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Unknown Operations	0	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	9 Month Operations	1	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Amps A Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Amps B Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Unknown Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Switching Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Operations This Read Vac	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Operations Counter AL	57	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Operations Counter AF	57	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Maintenance Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Fault Operations Ground	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Fault Operations C Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Fault Operations B Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Fault Operations A Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Amps C Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Amps B Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Amps A Ø	0.0	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Counter Readings	LTC Min Tap Position	6L	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Counter Readings	LTC Operations Since Last Insp	354	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	LTC As Found Counter	22814	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	LTC As Left Counter	22814	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	LTC Current Tap Position	1L	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	LTC Max Tap Position	3R	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	LTC Min Tap Position	4L	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	47	°C
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	334	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Unknown Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Switching Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Operations This Read Vac	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Operations Counter AL	176	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Operations Counter AF	176	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Maintenance Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Fault Operations Ground	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Fault Operations C Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Fault Operations B Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Fault Operations A Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Amps C Ø	44.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Amps B Ø	41.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Amps A Ø	43.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	9 Month Operations	1	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	9 Month Operations	3	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Operations Counter AF	168	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Operations Counter AL	168	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Operations This Read Vac	0	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Switching Operations	0	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Unknown Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	9 Month Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Amps A Ø	120.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Amps B Ø	120.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Amps C Ø	120.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Fault Operations A Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Fault Operations B Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Fault Operations C Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Fault Operations Ground	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Maintenance Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Operations Counter AF	513	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Operations Counter AL	513	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Operations This Read Vac	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Switching Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Unknown Operations	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	n	If no, which cells in comments
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	all post bulging and leaking. Cleaned and added water. Work order will be written to replace batteries.	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	n	If no, which cells in comments
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	n	If no, which cells in comments
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	n	If no, which cells in comments
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	n	If no, which cells in comments
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Poor	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	32	*F
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Counter Readings	Follow-up Action Required?	n	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Counter Readings	General Comments		
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Mechanism Patrol Inspection	General Comments		
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Counter Readings	LTC As Found Counter	34261	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Counter Readings	LTC As Left Counter	34261	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Counter Readings	LTC Current Tap Position	4L	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Maintenance Operations	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1349	CircuitSwitcher	WS-Vista Switchgear	Circuit Switcher Inspection	Ambient Temp	70	*F
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1349	CircuitSwitcher	WS-Vista Switchgear	Circuit Switcher Inspection	Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1349	CircuitSwitcher	WS-Vista Switchgear	Circuit Switcher Inspection	Equipment Properly Labeled?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1349	CircuitSwitcher	WS-Vista Switchgear	Circuit Switcher Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1349	CircuitSwitcher	WS-Vista Switchgear	Circuit Switcher Inspection	SF6 Indicator Zone	OK	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Bushing Condition	Good	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Amps C Ø	580.0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Amps B Ø	565.0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Amps A Ø	550.0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	9 Month Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	9 Month Operations	1	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	148	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	148	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Operations Counter AF	896	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Operations Counter AL	896	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Operations This Read Vac	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Switching Operations	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Unknown Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	PF000395	PowerFuse	WS-1428 POT	Disconnect PowerFuse Inspection	General Comments	ok	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	PF000395	PowerFuse	WS-1428 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	PF000406	PowerFuse	WS-1332 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	PF000406	PowerFuse	WS-1332 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	9 Month Operations	1	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Amps A Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Amps B Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Amps C Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Operations This Read Vac	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Switching Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Unknown Operations	0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Unknown Operations	0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Switching Operations	0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Operations This Read Vac	0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Operations Counter AL	207	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Operations Counter AF	207	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Maintenance Operations	0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	General Comments		
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	General Comments		
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Follow-up Action Required?	n	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Fault Operations Ground	0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Fault Operations C Ø	0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Fault Operations B Ø	0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Fault Operations A Ø	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	9 Month Operations	3	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Amps A Ø	61.0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Amps B Ø	47.0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Amps C Ø	56.0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Bushing Condition	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Fault Operations A Ø	0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Fault Operations B Ø	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Fault Operations C Ø	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Fault Operations A Ø	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Follow-up Action Required?	n	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	General Comments		
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Amps A Ø	106.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Amps B Ø	104.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Amps C Ø	105.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Amps C Ø	123.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Fault Operations A Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Fault Operations B Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Fault Operations C Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Fault Operations Ground	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Maintenance Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Operations Counter AF	126	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Operations Counter AL	126	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Operations This Read Vac	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Switching Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Unknown Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Fault Operations A Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Fault Operations B Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Fault Operations C Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Fault Operations Ground	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Maintenance Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Operations Counter AF	107	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Operations Counter AL	107	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Operations This Read Vac	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Switching Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Unknown Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	9 Month Operations	1	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Amps A Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Amps B Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Amps C Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Fault Operations A Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Fault Operations B Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Fault Operations C Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Fault Operations Ground	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Unknown Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Switching Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Operations This Read Vac	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	General Comments		
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Fault Operations Ground	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Vegetation	None	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	General Comments		
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Ambient Temp	32	°F
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	General Comments		
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Maintenance Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Operations Counter AF	190	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Operations Counter AL	190	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Maintenance Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Operations Counter AF	102	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Operations Counter AL	102	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Operations This Read Vac	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Switching Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Unknown Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	9 Month Operations	1	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Amps A Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Amps B Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Amps C Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Operations This Read Vac	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Operations Counter AL	175	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Operations Counter AF	175	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Fault Operations A Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Fault Operations B Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Fault Operations C Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Maintenance Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Fault Operations Ground	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Fault Operations C Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Fault Operations B Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Fault Operations A Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Amps C Ø	111.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Amps B Ø	104.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Amps A Ø	107.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	9 Month Operations	1	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	LTCC000697	LTCControl	636-1	LTC Control Insp	All Connections OK?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	LTCC000697	LTCControl	636-1	LTC Control Insp	Follow-up Action Required?	n	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	LTCC000697	LTCControl	636-1	LTC Control Insp	General Comments		
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	LTCC000697	LTCControl	636-1	LTC Control Insp	LTC Operation Checked?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	LTCC000697	LTCControl	636-1	LTC Control Insp	LTC Output Voltage Level	124.9	VAC
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	LTCC000697	LTCControl	636-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	LTCC000697	LTCControl	636-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	LTCC000697	LTCControl	636-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	9 Month Operations	1	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Amps A Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Amps B Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Amps C Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Fault Operations A Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Fault Operations B Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Fault Operations C Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Fault Operations Ground	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Maintenance Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Operations Counter AF	79	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Operations Counter AL	79	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Operations This Read Vac	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Switching Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Unknown Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Unknown Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Switching Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Operations This Read Vac	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Operations Counter AL	40	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Operations Counter AF	40	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Maintenance Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Fault Operations Ground	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Fault Operations C Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Fault Operations B Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Fault Operations A Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Amps C Ø	118.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Amps B Ø	120.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Amps A Ø	124.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	9 Month Operations	4	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000639	LTCControl	767-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000639	LTCControl	767-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000639	LTCControl	767-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000639	LTCControl	767-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000639	LTCControl	767-1	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000639	LTCControl	767-1	LTC Control Insp	LTC Operation Checked?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000639	LTCControl	767-1	LTC Control Insp	General Comments		
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000639	LTCControl	767-1	LTC Control Insp	Follow-up Action Required?	n	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000639	LTCControl	767-1	LTC Control Insp	All Connections OK?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Unknown Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Operations This Read Vac	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Operations Counter AL	37	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Operations Counter AF	37	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Maintenance Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Fault Operations Ground	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1300	psi
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	Oil Temp Max	54	°C
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	Oil Temp Present	27	°C
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	55	°C
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	28	°C
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	55	°C
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	28	°C
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	55	°C
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	28	°C
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments	THIS XMER IS AT THE SHOP....SER#787	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	PN29	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments	NEED NITRO	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0218	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	General Comments		
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000313	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000313	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	122.0	VAC
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000313	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	122.0	VAC
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000313	LTCControl	920-Offline-Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000313	LTCControl	920-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	122.3	VAC
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000313	LTCControl	920-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000313	LTCControl	920-Offline-Distribution	LTC Control Insp	General Comments		
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000313	LTCControl	920-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000313	LTCControl	920-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Mechanism Patrol Inspection	General Comments	Ltc tank oil level is high pic sent to Stinson	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	LTC As Found Counter	24548	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	LTC As Left Counter	24548	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	LTC Current Tap Position	2L	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	LTC Max Tap Position	3R	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	LTC Min Tap Position	4L	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	44	°C
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	343	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Radiator Leaks	None	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Grounds in Place?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Foundation Condition	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Cleaned Mechanism Cabinet?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Unknown Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Switching Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Operations This Read Vac	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Operations Counter AL	88	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Operations Counter AF	88	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Maintenance Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Fault Operations Ground	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Fault Operations C Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Fault Operations B Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Fault Operations A Ø	0	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Amps C Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Amps B Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Amps A Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	9 Month Operations	1	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LTCC000231	LTCControl	WS-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LTCC000231	LTCControl	WS-TRANS 1	LTC Control Insp	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LTCC000231	LTCControl	WS-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	paralleIPAR	Position
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	BAT001117	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Battery Overall Condition	Good	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	BAT001117	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	BAT001117	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #""s
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	BAT001117	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	BAT001117	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	General Comments		
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	BAT001118	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Battery Overall Condition	Good	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	BAT001118	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	BAT001118	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #""s
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	BAT001118	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	BAT001118	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	General Comments		
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	y	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	General Comments	NEED NITRO	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	17.50	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0178	NonLTC	SSC-PORT TRANS 1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Amps A Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Amps B Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Amps C Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BCH001368	Charger	456-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Tank Leaks	None	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Current Tap Position	3R	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	General Comments		
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Max Tap Position	7R	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Min Tap Position	5L	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Regulator As Left Counter	118138	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Tank Leaks	None	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Fault Operations Ground	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Fault Operations C Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Fault Operations B Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Fault Operations A Ø	0	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Current Tap Position	1L	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Unknown Operations	0	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Switching Operations	0	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Operations This Read Vac	0	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Operations Counter AL	280	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Operations Counter AF	280	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Maintenance Operations	0	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	General Comments		
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	General Comments		
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Follow-up Action Required?	n	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Fault Operations Ground	0	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Fault Operations C Ø	0	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Fault Operations B Ø	0	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Fault Operations A Ø	0	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Bushing Condition	Good	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Amps C Ø	207.0	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Amps B Ø	205.0	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Readings	Totalizer Meter Multiplier	4000	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Readings	Totalizer Meter Reading	.0377	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Readings	Winding Temp Max	0	°C
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Readings	Winding Temp Present	0	°C
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Patrol Inspection	General Comments		
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BCH001358	Charger	809-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BCH001358	Charger	809-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BCH001358	Charger	809-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BCH001358	Charger	809-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BCH001358	Charger	809-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BCH001358	Charger	809-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BCH001358	Charger	809-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BCH001358	Charger	809-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Maintenance Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Operations Counter AF	100	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Operations Counter AL	100	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Operations This Read Vac	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Switching Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Unknown Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	9 Month Operations	1	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BCH001355	Charger	539-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BCH001355	Charger	539-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BCH001355	Charger	539-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BCH001355	Charger	539-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BCH001355	Charger	539-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.4	amps
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BCH001355	Charger	539-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BCH001355	Charger	539-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BCH001355	Charger	539-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Amps A Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Amps B Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Amps C Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Fault Operations A Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Fault Operations B Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Fault Operations C Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Fault Operations Ground	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	General Comments		
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	LTCC000347	LTCControl	539-2	LTC Control Insp	VRR Time Delay	30	Seconds
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	LTCC000347	LTCControl	539-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	LTCC000347	LTCControl	539-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	LTCC000347	LTCControl	539-2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	LTCC000347	LTCControl	539-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	LTCC000347	LTCControl	539-2	LTC Control Insp	LTC Operation Checked?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	LTCC000347	LTCControl	539-2	LTC Control Insp	General Comments		
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	LTCC000347	LTCControl	539-2	LTC Control Insp	Follow-up Action Required?	n	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	LTCC000347	LTCControl	539-2	LTC Control Insp	All Connections OK?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Operations Counter AF	107	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Operations Counter AL	107	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Operations This Read Vac	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Switching Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Unknown Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BCH001368	Charger	456-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BCH001368	Charger	456-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BCH001368	Charger	456-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BCH001368	Charger	456-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BCH001368	Charger	456-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BCH001368	Charger	456-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BCH001368	Charger	456-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Fault Operations A Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Fault Operations B Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Fault Operations C Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Fault Operations Ground	0	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Maintenance Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Operations Counter AF	230	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Operations Counter AL	230	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Operations This Read Vac	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Switching Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Unknown Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Fault Operations A Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Fault Operations B Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Fault Operations C Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Fault Operations Ground	0	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	9 Month Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Amps A Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Amps B Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Amps C Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Fault Operations A Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Fault Operations B Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Fault Operations C Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Fault Operations Ground	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Maintenance Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Operations Counter AF	72	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Operations Counter AL	72	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Operations This Read Vac	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Switching Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Unknown Operations	0	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Readings	General Comments		
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Readings	LTC Totalizer Reading	150.80	kw
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Readings	Oil Temp Max	40	°C
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Readings	Oil Temp Present	18	°C
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Amps C Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Fault Operations A Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Fault Operations B Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Fault Operations C Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Fault Operations Ground	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Maintenance Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Operations Counter AF	71	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Operations Counter AL	71	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Operations This Read Vac	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Switching Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Unknown Operations	0	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	LTCC000627	LTCControl	552-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	LTCC000627	LTCControl	552-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	LTCC000627	LTCControl	552-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	LTCC000627	LTCControl	552-1	LTC Control Insp	LTC Output Voltage Level	123.8	VAC
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	LTCC000627	LTCControl	552-1	LTC Control Insp	LTC Operation Checked?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	LTCC000627	LTCControl	552-1	LTC Control Insp	General Comments		
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	LTCC000627	LTCControl	552-1	LTC Control Insp	Follow-up Action Required?	n	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	LTCC000627	LTCControl	552-1	LTC Control Insp	All Connections OK?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	General Comments		
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	General Comments		
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Readings	Switching Operations	0	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	SF6 Pressure	87	psi
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	SF6 Bushing Condition	Good	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Readings	Operations This Read SF6	0	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Readings	Operations Counter AL	54	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Readings	Operations Counter AF	54	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Readings	Num Operations Last 9 Months	7	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Readings	Maintenance Operations	0	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Heaters (All) Functioning?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Grounds in Place?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	LTCM000024	LTCMechanism	636-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	LTCM000024	LTCMechanism	636-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	LTCM000024	LTCMechanism	636-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	LTCM000024	LTCMechanism	636-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	LTCM000024	LTCMechanism	636-1	LTC Counter Readings	LTC Operations Since Last Insp	397	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	LTCM000024	LTCMechanism	636-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	LTCM000024	LTCMechanism	636-1	LTC Counter Readings	LTC Min Tap Position	11L	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	LTCM000024	LTCMechanism	636-1	LTC Counter Readings	LTC Max Tap Position	10R	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	LTCM000024	LTCMechanism	636-1	LTC Counter Readings	LTC Current Tap Position	7L	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	LTCM000024	LTCMechanism	636-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Mechanism Patrol Inspection	General Comments		
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	General Comments		
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	Follow-up Action Required?	n	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	LTCM000024	LTCMechanism	636-1	LTC Counter Readings	LTC As Left Counter	19397	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	LTCM000024	LTCMechanism	636-1	LTC Counter Readings	LTC As Found Counter	19397	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	LTCM000024	LTCMechanism	636-1	LTC Mechanism Patrol Inspection	General Comments		
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	LTCM000024	LTCMechanism	636-1	LTC Counter Readings	General Comments		
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	LTCM000024	LTCMechanism	636-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	LTCM000024	LTCMechanism	636-1	LTC Counter Readings	Follow-up Action Required?	n	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	LTC Operations Since Last Insp	362	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	LTC Min Tap Position	11L	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	LTC Current Tap Position	7L	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	LTC As Left Counter	10379	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	LTC As Found Counter	10379	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Mechanism Patrol Inspection	General Comments		
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	General Comments		
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	Follow-up Action Required?	n	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	9 Month Operations	1	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Amps A Ø	379.0	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Amps B Ø	353.0	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Amps C Ø	362.0	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Bushing Condition	Good	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Fault Operations A Ø	0	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Fault Operations B Ø	0	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Fault Operations C Ø	0	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Fault Operations Ground	0	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Follow-up Action Required?	n	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	General Comments		
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	General Comments		
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Maintenance Operations	0	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Operations Counter AF	164	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Operations Counter AL	164	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Operations This Read Vac	0	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Switching Operations	0	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Unknown Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	9 Month Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Amps A Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Amps B Ø	0.0	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Readings	Operations Counter AL	206	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Readings	Operations Counter AF	206	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Readings	Maintenance Operations	0	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Readings	General Comments		
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	General Comments		
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	43	°C
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	LTC Min Tap Position	10L	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Readings	9 Month Operations	2	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	LTC Max Tap Position	3L	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	LTC Current Tap Position	7L	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	LTC As Left Counter	52853	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	LTC As Found Counter	52853	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	General Comments		
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	General Comments		
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	Follow-up Action Required?	n	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BCH000955	Charger	455-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BCH000955	Charger	455-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BCH000955	Charger	455-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BCH000955	Charger	455-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.7	amps
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BCH000955	Charger	455-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	134.0	VDC
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BCH000955	Charger	455-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	134.0	VDC
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BCH000955	Charger	455-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	General Comments		
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	BAT001154	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Battery Overall Condition	Good	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	BAT001154	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	BAT001154	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	BAT001154	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	BAT001154	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	General Comments		
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	BAT001155	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Battery Overall Condition	Good	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	BAT001155	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	BAT001155	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	BAT001155	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Readings	General Comments		
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	General Comments		
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Gauge(s) Condition	Good	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Foundation Condition	Good	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Readings	Follow-up Action Required?	n	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Readings	Fault Operations	0	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Ambient Temperature	32	*F
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	General Comments		
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	LTC Operations Since Last Insp	514	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	15	*C
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BK001429	BreakerVacuum	920-Offline-Distribution	VCB Readings	Unknown Operations	0	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BK001429	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BK001429	BreakerVacuum	920-Offline-Distribution	VCB Readings	Switching Operations	0	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BK001429	BreakerVacuum	920-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BK001429	BreakerVacuum	920-Offline-Distribution	VCB Readings	Operations Counter AL	172	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BK001429	BreakerVacuum	920-Offline-Distribution	VCB Readings	Operations Counter AF	172	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BK001429	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BK001429	BreakerVacuum	920-Offline-Distribution	VCB Readings	Maintenance Operations	0	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BK001429	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BK001429	BreakerVacuum	920-Offline-Distribution	VCB Readings	General Comments		
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BK001429	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	General Comments		
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BK001429	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BK001429	BreakerVacuum	920-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BK001429	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BK001429	BreakerVacuum	920-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BK001429	BreakerVacuum	920-Offline-Distribution	VCB Readings	Fault Operations C ∅	0	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BK001429	BreakerVacuum	920-Offline-Distribution	VCB Readings	Fault Operations B ∅	0	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BK001429	BreakerVacuum	920-Offline-Distribution	VCB Readings	Fault Operations A ∅	0	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BK001429	BreakerVacuum	920-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BK001429	BreakerVacuum	920-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BK001429	BreakerVacuum	920-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	BK001429	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0183	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Operations Counter AL	183	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Operations This Read Vac	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Switching Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Unknown Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	9 Month Operations	1	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Vegetation	None	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	General Comments		
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	9 Month Operations	3	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Amps A Ø	550.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Amps B Ø	540.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Amps C Ø	544.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Fault Operations A Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Fault Operations B Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Fault Operations C Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Fault Operations Ground	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Maintenance Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Operations Counter AF	3	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Operations Counter AL	3	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Operations This Read Vac	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Switching Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Unknown Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	9 Month Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Amps A Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Amps B Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Amps C Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Fault Operations A Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Fault Operations B Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Fault Operations C Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Fault Operations Ground	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Maintenance Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Operations Counter AF	107	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Operations Counter AL	107	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Operations This Read Vac	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Switching Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Unknown Operations	0	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Ambient Temp	41	*F
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	9 Month Operations	1	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Maintenance Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Operations Counter AF	53	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Operations Counter AL	53	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Operations This Read Vac	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Switching Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Unknown Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	9 Month Operations	2	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Amps A Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Amps B Ø	0.0	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Counter Readings	LTC Operations Since Last Insp	156	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Counter Readings	LTC Min Tap Position	9L	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Counter Readings	LTC Max Tap Position	2L	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Counter Readings	LTC Current Tap Position	7L	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Counter Readings	LTC As Left Counter	47489	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Counter Readings	LTC As Found Counter	47489	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Mechanism Patrol Inspection	General Comments		
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Counter Readings	General Comments		
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Counter Readings	Follow-up Action Required?	n	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	460	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Min Tap Position	12L	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Max Tap Position	6L	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	9L	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	24438	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	24438	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	General Comments		
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Amps C Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Fault Operations A Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Fault Operations B Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Fault Operations C Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Fault Operations Ground	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Maintenance Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Operations Counter AF	151	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Operations Counter AL	151	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Operations This Read Vac	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Switching Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Unknown Operations	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	LTC Operations Since Last Insp	456	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	LTC Min Tap Position	11L	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	LTC Max Tap Position	2L	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	LTC Current Tap Position	6L	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	LTC As Left Counter	117929	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	LTC As Found Counter	117929	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Amps A Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Amps B Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Amps C Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Fault Operations A Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Fault Operations B Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Fault Operations C Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Fault Operations Ground	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Maintenance Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Operations Counter AF	183	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Operations Counter AL	183	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Operations This Read Vac	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Switching Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Unknown Operations	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	9 Month Operations	2	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Amps A Ø	2.0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Amps B Ø	1.0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Amps C Ø	0.0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Bushing Condition	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LTCC000273	LTCControl	MK-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LTCC000273	LTCControl	MK-TRANS 1	LTC Control Insp	General Comments		
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LTCC000273	LTCControl	MK-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Fault Operations A Ø	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Fault Operations B Ø	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Fault Operations C Ø	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Fault Operations Ground	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Follow-up Action Required?	n	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	General Comments		
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	General Comments		
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Maintenance Operations	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Operations Counter AF	990	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Operations Counter AL	990	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Operations This Read Vac	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Switching Operations	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Unknown Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	9 Month Operations	1	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Amps A Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Amps B Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Amps C Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Fault Operations A Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Fault Operations B Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Fault Operations C Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Fault Operations Ground	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LTO286	LTCMechanism	WS-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LTO286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LTO286	LTCMechanism	WS-TRANS 4	LTC Mechanism Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LTO286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	LTC As Found Counter	27069	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LTO286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	LTC As Left Counter	27069	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LTO286	LTCMechanism	WS-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LTO286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	LTC Current Tap Position	1L	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LTO286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	LTC Max Tap Position	16R	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LTO286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	LTC Min Tap Position	6L	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LTO286	LTCMechanism	WS-TRANS 4	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	47	°C
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LTO286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	LTC Operations Since Last Insp	630	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LTO286	LTCMechanism	WS-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LTO286	LTCMechanism	WS-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LTO286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LTO286	LTCMechanism	WS-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	Follow-up Action Required?	n	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	General Comments		
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	General Comments		
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	LTC As Found Counter	195265	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	LTC As Left Counter	195265	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	LTC Current Tap Position	3R	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	LTC Max Tap Position	4R	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	LTC Min Tap Position	10L	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	40	°C
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	°C
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	LTC Operations Since Last Insp	918	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	120.0	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	120.0	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	120.0	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	General Comments		
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	2	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	660	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	660	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Unknown Operations	0	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Switching Operations	0	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Operations This Read Vac	0	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Operations Counter AL	205	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Operations Counter AF	205	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Maintenance Operations	0	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	General Comments		
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	General Comments		
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Follow-up Action Required?	n	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Follow-up Action Required?	n	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Fault Operations Ground	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Fault Operations C Ø	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Fault Operations B Ø	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Fault Operations A Ø	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	9 Month Operations	3	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Amps A Ø	97.0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Amps B Ø	94.0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Amps C Ø	91.0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Bushing Condition	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Fault Operations A Ø	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Fault Operations B Ø	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Fault Operations C Ø	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Fault Operations Ground	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Follow-up Action Required?	n	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	General Comments		
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	General Comments		
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	36	°F
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	General Comments		
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Bushing Condition	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Amps C Ø	93.0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Amps B Ø	100.0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Amps A Ø	99.0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	9 Month Operations	17	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Maintenance Operations	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Operations Counter AF	314	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Operations Counter AL	314	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Operations This Read Vac	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Switching Operations	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Unknown Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LTC0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Amps A Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Amps B Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Amps C Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Fault Operations A Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Fault Operations B Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Fault Operations C Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Fault Operations Ground	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Maintenance Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Operations Counter AF	50	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Operations Counter AL	50	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Operations This Read Vac	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Switching Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Unknown Operations	0	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Winding Temp Present	20	°C
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Winding Temp Max	27	°C
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Totalizer Meter Reading	.7668	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Oil Temp Present	22	°C
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Oil Temp Max	31	°C
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	1840.32	kw
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	General Comments		
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Amps A Ø	91.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Amps B Ø	95.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Amps C Ø	98.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Fault Operations A Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Fault Operations B Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Fault Operations C Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Fault Operations Ground	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Maintenance Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Operations Counter AF	84	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Operations Counter AL	84	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Operations This Read Vac	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Switching Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Unknown Operations	0	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	9 Month Operations	1	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	Oil Temp Present	20	°C
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	Oil Temp Max	52	°C
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	850	psi
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	9 Month Operations	9	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Amps A Ø	20.0	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Amps B Ø	20.0	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Amps C Ø	25.0	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Bushing Condition	Good	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Fault Operations A Ø	0	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Fault Operations B Ø	0	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Fault Operations C Ø	0	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Fault Operations Ground	0	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Follow-up Action Required?	n	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Fault Operations A Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Fault Operations B Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Fault Operations C Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Fault Operations Ground	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Maintenance Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Operations Counter AF	223	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Operations Counter AL	223	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Operations This Read Vac	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Switching Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Unknown Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	X3 Winding Temp Present	21	°C
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	X3 Winding Temp Max	54	°C
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	X2 Winding Temp Present	21	°C
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	X2 Winding Temp Max	54	°C
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	X1 Winding Temp Present	21	°C
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	X1 Winding Temp Max	54	°C
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Switching Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Unknown Operations	0	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Unknown Operations	0	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Switching Operations	0	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Operations This Read Vac	0	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Operations Counter AL	175	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Operations Counter AF	175	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Maintenance Operations	0	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	General Comments		
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	General Comments		
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Follow-up Action Required?	n	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Fault Operations Ground	0	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Fault Operations C Ø	0	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Fault Operations B Ø	0	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Fault Operations A Ø	0	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Bushing Condition	Good	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Amps C Ø	58.0	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Amps B Ø	55.0	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Amps A Ø	63.0	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	9 Month Operations	2	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCControl	539-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCControl	539-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Operations Counter	0	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	General Comments		
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	289	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	B ∅ Operations Counter	258	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Amps C ∅	39.1	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Amps B ∅	33.5	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Amps A ∅	23.5	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	A ∅ Operations Counter	120	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCControl	539-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCControl	539-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleIND	Position
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCControl	539-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCControl	539-1	LTC Control Insp	LTC Operation Checked?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCControl	539-1	LTC Control Insp	General Comments		
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCControl	539-1	LTC Control Insp	Follow-up Action Required?	n	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCControl	539-1	LTC Control Insp	All Connections OK?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Unknown Operations	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Switching Operations	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Operations This Read Vac	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Operations Counter AL	195	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Operations Counter AF	195	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Maintenance Operations	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	General Comments		
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Fault Operations B ∅	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Fault Operations C ∅	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Fault Operations Ground	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	X3 Winding Temp Present	45	°C
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	X3 Winding Temp Max	45	°C
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	X2 Winding Temp Present	40	°C
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	X2 Winding Temp Max	70	°C
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	X1 Winding Temp Present	40	°C
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	Oil Temp Present	40	°C
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	Oil Temp Max	70	°C
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	General Comments		
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	Follow-up Action Required?	n	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Maintenance Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Operations Counter AF	81	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Operations Counter AL	81	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Operations This Read Vac	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Switching Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Unknown Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LTCC000265	LTCControl	WS-TRANS 4	LTC Control Insp	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LTCC000265	LTCControl	WS-TRANS 4	LTC Control Insp	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LTCC000265	LTCControl	WS-TRANS 4	LTC Control Insp	Parallel / Ind. Sw Position	paralleIPAR	Position
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	9 Month Operations	3	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Amps A ∅	74.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Amps B ∅	76.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Amps C ∅	77.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Fault Operations A ∅	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Fault Operations B ∅	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Fault Operations C ∅	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Fault Operations Ground	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Maintenance Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Operations Counter AF	98	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	624	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	624	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	9 Month Operations	1	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Amps A Ø	480.0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Amps B Ø	440.0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Amps C Ø	480.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Operations Counter AF	161	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Operations Counter AL	161	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Operations This Read Vac	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Switching Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Unknown Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Fault Operations B Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Fault Operations A Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Amps C Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Amps B Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Amps A Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	9 Month Operations	3	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	20.0	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	20.0	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	General Comments		
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	33	*F
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Maintenance Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Operations Counter AF	187	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Operations Counter AL	187	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Operations This Read Vac	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Switching Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Unknown Operations	0	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Current Tap Position	Neutral	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	General Comments		
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Max Tap Position	2R	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Min Tap Position	8L	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Regulator As Left Counter	115686	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Bushing Condition	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Fault Operations A Ø	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Fault Operations B Ø	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Fault Operations C Ø	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Fault Operations Ground	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Follow-up Action Required?	n	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	General Comments		
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	General Comments		
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Maintenance Operations	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Operations Counter AF	212	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Operations Counter AL	212	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Operations This Read Vac	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Switching Operations	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Unknown Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Unknown Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Switching Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Operations This Read Vac	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Operations Counter AL	58	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Operations Counter AF	58	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Maintenance Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	General Comments	checked vc	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Fault Operations Ground	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Fault Operations C Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Fault Operations B Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Fault Operations A Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Amps C Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Amps B Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Amps A Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	9 Month Operations	2	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	LTCC000385	LTCControl	738-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	LTCC000385	LTCControl	738-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	LTCC000385	LTCControl	738-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	LTCC000385	LTCControl	738-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	LTCC000385	LTCControl	738-1	LTC Control Insp	LTC Operation Checked?	y	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	LTCC000385	LTCControl	738-1	LTC Control Insp	General Comments		
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	LTCC000385	LTCControl	738-1	LTC Control Insp	Follow-up Action Required?	n	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	LTCC000385	LTCControl	738-1	LTC Control Insp	All Connections OK?	y	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	General Comments	NEED NITRO	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0182	WithLTC	BI-Yard	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	9 Month Operations	3	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	Oil Temp Present	50	°C
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	Oil Temp Max	53	°C
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	LTC Totalizer Reading	13104.00	kw
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	General Comments		
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	General Comments		
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	9 Month Operations	1	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Amps A Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Amps B Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Amps C Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Fault Operations A Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Fault Operations B Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Fault Operations C Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Fault Operations Ground	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Maintenance Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Operations Counter AF	61	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Operations Counter AL	61	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Operations This Read Vac	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Switching Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Unknown Operations	0	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	9 Month Operations	2	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Amps A Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Amps B Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Amps C Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Fault Operations A Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Fault Operations B Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Fault Operations C Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Fault Operations Ground	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Unknown Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Switching Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Operations This Read Vac	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Operations Counter AL	90	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Operations Counter AF	90	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Maintenance Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	85.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	Oil Temp Present	40	°C
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	Oil Temp Max	60	°C
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/15/2020 11:02	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Counter Readings	LTC Operations Since Last Insp	356	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Counter Readings	LTC Min Tap Position	11L	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Counter Readings	LTC Max Tap Position	4L	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Counter Readings	LTC Current Tap Position	7L	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Counter Readings	LTC As Left Counter	316086	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Counter Readings	LTC As Found Counter	316086	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Mechanism Patrol Inspection	General Comments		
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Counter Readings	General Comments		
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Counter Readings	Follow-up Action Required?	n	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	9 Month Operations	19	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Amps A Ø	450.0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Amps B Ø	475.0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Amps C Ø	490.0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Bushing Condition	Good	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Fault Operations A Ø	0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Fault Operations B Ø	0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Fault Operations C Ø	0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Fault Operations Ground	0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Follow-up Action Required?	n	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	General Comments		
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	General Comments		
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Maintenance Operations	0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Operations Counter AF	306	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Operations Counter AL	306	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Operations This Read Vac	0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Switching Operations	0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Unknown Operations	0	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	Winding Temp Present	70	°C
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	Winding Temp Max	70	°C
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	Totalizer Meter Reading	.7280	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Amps C Ø	79.0	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments	NEED NITRO	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	PN55	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Amps B Ø	78.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Amps A Ø	81.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1244	BreakerVacuum	WS-1335-4	VCB Readings	9 Month Operations	1	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Unknown Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Switching Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Operations This Read Vac	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Operations Counter AL	97	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Operations Counter AF	97	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Maintenance Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Fault Operations Ground	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Fault Operations C Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Fault Operations B Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Fault Operations A Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Amps C Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Amps B Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Amps A Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1175	BreakerVacuum	WS-1475-1	VCB Readings	9 Month Operations	2	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	Oil Temp Present	21	°C
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	Oil Temp Max	573	°C
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1800	psi
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	LTC Totalizer Reading	11940.48	kw
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Arching Horns Good Condition?	y	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Free of Audible Arching?	y	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	General Comments		
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Readings	Unknown Operations	0	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Readings	Switching Operations	0	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Readings	Operations This Read Vac	0	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Readings	Operations Counter AL	92	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Readings	Operations Counter AF	92	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Readings	Maintenance Operations	0	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Readings	General Comments		
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	General Comments		
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Readings	Amps B Ø	200.0	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Readings	Amps A Ø	200.0	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Readings	Accumulated Fault Duty C Ph V	0	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	68	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	68	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Operations This Read Vac	3	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Switching Operations	3	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Unknown Operations	0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	LTC Min Tap Position	12L	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	LTC Operations Since Last Insp	1282	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Readings	9 Month Operations	3	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	General Comments		
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	General Comments		
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Fault Operations A Ø	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Fault Operations B Ø	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Fault Operations C Ø	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Fault Operations Ground	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Follow-up Action Required?	n	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	General Comments		
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	Oil Temp Present	22	°C
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	Oil Temp Max	60	°C
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	LTC Totalizer Reading	10940.40	kw
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	General Comments		
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Maintenance Operations	0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Operations Counter AF	99991	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Operations Counter AL	99991	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	6	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	70.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	70.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	70.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	General Comments		
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	3	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	.05	%
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	.05	%
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	.05	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Unknown Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Switching Operations	1	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Operations This Read Vac	1	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Operations Counter AL	79	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Operations Counter AF	79	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Maintenance Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Fault Operations Ground	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Fault Operations C Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Fault Operations A Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	LTC Totalizer Reading	10929.60	kw
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	General Comments		
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	General Comments		
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Amps C Ø	120.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Amps B Ø	118.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Amps A Ø	111.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Mechanism Patrol Inspection	General Comments		
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	LTC As Found Counter	65760	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	9 Month Operations	6	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Switching Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Unknown Operations	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	General Comments	20 amps on N	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Follow-up Action Required?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Fault Operations Ground	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Fault Operations C Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Fault Operations B Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Fault Operations A Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Amps C Ø	130.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Amps B Ø	132.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Amps A Ø	129.0	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	Winding Temp Present	35	°C
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	9 Month Operations	1	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	General Comments		
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	Winding Temp Max	40	°C
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	Totalizer Meter Reading	.6072	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	Oil Temp Present	30	°C
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	Oil Temp Max	35	°C
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1200	psi
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	4.0	psi
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Maintenance Operations	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Operations Counter AF	58	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Operations Counter AL	58	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Operations This Read Vac	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Switching Operations	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Unknown Operations	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Amps C Ø	50.0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Amps B Ø	13.0	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0305	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Amps A Ø	69.0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Accumulated Fault Duty C Ph V	.32	%
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Accumulated Fault Duty B Ph V	.37	%
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	General Comments		
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	99	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	99	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	General Comments		
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Follow-up Action Required?	n	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Fault Operations Ground	0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	LTC As Left Counter	65760	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	LTC Current Tap Position	Neutral	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	LTC Max Tap Position	2R	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	9 Month Operations	5	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Amps A Ø	130.0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Amps B Ø	161.0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Amps C Ø	182.0	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Bushing Condition	Good	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Fault Operations C Ø	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Fault Operations B Ø	0	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	PN13	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0305	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0305	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0305	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0305	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0305	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0305	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	LT0305	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Fault Operations A Ø	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	General Comments		
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Vegetation	None	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	9 Month Operations	2	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Amps A Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Amps B Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Amps C Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Fault Operations A Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Fault Operations B Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Fault Operations C Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Fault Operations Ground	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	Yes_sprayed	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	LTC As Left Counter	24130	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	LTC As Found Counter	24130	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	General Comments		
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	General Comments		
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	Follow-up Action Required?	n	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	Winding Temp Present	21	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	Winding Temp Max	58	°C
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	Totalizer Meter Reading	.8292	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	9 Month Operations	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Accumulated Fault Duty A Ph V	.64	%
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Ambient Temp	32	°F
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	LTC Totalizer Reading	4798.08	kw
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	General Comments		
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	General Comments		
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	9 Month Operations	1	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Amps A Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Amps B Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Amps C Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Fault Operations A Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Fault Operations B Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Fault Operations C Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Fault Operations Ground	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Maintenance Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Operations Counter AF	159	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Operations Counter AL	159	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Operations This Read Vac	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Switching Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Unknown Operations	0	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	Follow-up Action Required?	n	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	32	°F
12/15/2020 13:46	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	54	°C
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	23	°C
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	54	°C
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	23	°C
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	545	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	23	°C
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	Winding Temp Present	13	°C
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	Winding Temp Max	27	°C
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	Totalizer Meter Reading	.4998	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	Oil Temp Present	22	°C
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	Oil Temp Max	30	°C
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	9 Month Operations	3	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Unknown Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Switching Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Operations This Read Vac	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	General Comments		
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/15/2020 12:56	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000009	LTCControl	767-2	LTC Control Insp	All Connections OK?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000009	LTCControl	767-2	LTC Control Insp	Follow-up Action Required?	n	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000009	LTCControl	767-2	LTC Control Insp	General Comments		
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000009	LTCControl	767-2	LTC Control Insp	LTC Operation Checked?	y	
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000009	LTCControl	767-2	LTC Control Insp	LTC Output Voltage Level	124.8	VAC
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000009	LTCControl	767-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000009	LTCControl	767-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/15/2020 15:58	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000009	LTCControl	767-2	LTC Control Insp	VRR Time Delay	30	Seconds
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Unknown Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Switching Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Operations This Read Vac	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Operations Counter AL	181	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Operations Counter AF	181	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Maintenance Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Fault Operations Ground	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Fault Operations C Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Fault Operations B Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Fault Operations A Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Amps C Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Amps B Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Amps A Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	52	°C
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	2.0	psi
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	LTC Min Tap Position	4L	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	LTC Max Tap Position	4R	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Operations Counter AL	71	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Operations Counter AF	71	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Maintenance Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Follow-up Action Required?	n	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	Oil Temp Max	55	°C
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	700	psi
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	Oil Temp Max	53	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	Oil Temp Present	22	°C
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	22	°C
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	59	°C
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	22	°C
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	59	°C
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	22	°C
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	59	°C
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 15:50	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	Oil Temp Present	21	°C
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCControl	455-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCControl	455-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCControl	455-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCControl	455-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCControl	455-1	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCControl	455-1	LTC Control Insp	LTC Operation Checked?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCControl	455-1	LTC Control Insp	General Comments		
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCControl	455-1	LTC Control Insp	Follow-up Action Required?	n	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCControl	455-1	LTC Control Insp	All Connections OK?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	LTC Operations Since Last Insp	1140	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	15	°C
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Maintenance Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Operations Counter AF	149	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Operations Counter AL	149	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Operations This Read Vac	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Switching Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Unknown Operations	0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Fault Operations A Ø	0	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Fault Operations B Ø	0	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Fault Operations C Ø	0	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Fault Operations Ground	0	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Follow-up Action Required?	n	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	General Comments		
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	General Comments		
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	General Comments		
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Maintenance Operations	0	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Operations Counter AF	178	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Operations Counter AL	178	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Operations This Read Vac	0	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Switching Operations	0	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	9 Month Operations	2	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	General Comments		
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	General Comments		
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Maintenance Operations	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Operations Counter AF	84	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Operations Counter AL	84	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Operations This Read Vac	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Switching Operations	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Unknown Operations	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	9 Month Operations	1	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Amps A Ø	160.0	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Amps B Ø	159.0	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Amps C Ø	161.0	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Bushing Condition	Good	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Amps A Ø	469.0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Amps B Ø	401.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Fault Operations A Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Fault Operations B Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Fault Operations C Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Fault Operations Ground	0	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	General Comments		
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Amps C Ø	394.0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	General Comments		
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	General Comments		
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Maintenance Operations	0	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Operations Counter AF	253	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Operations Counter AL	253	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Operations This Read Vac	0	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Switching Operations	0	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Unknown Operations	0	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	9 Month Operations	2	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Amps C Ø	166.0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Amps B Ø	187.0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Amps A Ø	176.0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Accumulated Fault Duty C Ph V	.16	%
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Accumulated Fault Duty B Ph V	.16	%
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Accumulated Fault Duty A Ph V	.16	%
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	9 Month Operations	1	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Unknown Operations	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Switching Operations	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Operations This Read Vac	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Operations Counter AL	74	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Operations Counter AF	74	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Maintenance Operations	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	General Comments		
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	General Comments		
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Follow-up Action Required?	n	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Unknown Operations	0	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	9 Month Operations	2	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Amps A Ø	83.0	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Amps B Ø	92.0	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Amps C Ø	69.0	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Bushing Condition	Good	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Fault Operations A Ø	0	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Fault Operations A Ø	0	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Fault Operations B Ø	0	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Fault Operations C Ø	0	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Fault Operations Ground	0	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Follow-up Action Required?	n	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Switching Operations	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Unknown Operations	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	9 Month Operations	2	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Accumulated Fault Duty A Ph V	.59	%
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Accumulated Fault Duty B Ph V	.37	%
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Accumulated Fault Duty C Ph V	.43	%
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Amps A Ø	42.0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Amps B Ø	0.0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Amps C Ø	4.0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Maintenance Operations	0	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	General Comments		
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	General Comments		
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Follow-up Action Required?	n	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Fault Operations Ground	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Fault Operations C Ø	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Fault Operations B Ø	0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Follow-up Action Required?	n	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	General Comments		
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	General Comments		
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Maintenance Operations	0	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Operations Counter AF	226	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	BAT001155	Battery	SSC-Distribution Maint.	Battery Patrol Inspection	General Comments		
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments	NITRO BOTTLE 700	
12/15/2020 16:14	Distribution	South Service Center Quarterly Inspection	TX000036	WithLTC	SSC-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	186	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	186	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	9 Month Operations	1	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Amps A Ø	570.0	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Amps B Ø	570.0	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Amps C Ø	570.0	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Bushing Condition	Good	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Fault Operations A Ø	0	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Fault Operations B Ø	0	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Fault Operations C Ø	0	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Fault Operations Ground	0	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Operations Counter AF	81	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Operations Counter AL	81	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Operations This Read Vac	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	50	°C
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	17	°C
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	50	°C
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	Oil Temp Present	16	°C
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	Oil Temp Max	49	°C
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	General Comments		
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	9 Month Operations	5	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Amps A Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Amps B Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Amps C Ø	0.0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Fault Operations A Ø	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Fault Operations B Ø	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Fault Operations C Ø	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Fault Operations Ground	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Follow-up Action Required?	n	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Ambient Temperature	33	°F
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Foundation Condition	Good	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	General Comments		
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Grounds in Place?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Bushing Condition	Good	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Indicator Zone	OK	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Operations Counter AL	226	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Operations This Read Vac	1	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	Totalizer Meter Reading	1.1748	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LTCC000622	LTCControl	MK-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	Oil Temp Present	30	°C
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	Oil Temp Max	30	°C
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	LTC Totalizer Reading	8458.56	kw
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Switching Operations	1	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 13:20	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Unknown Operations	0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	General Comments		
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	General Comments		
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LTCC000622	LTCControl	MK-TRANS 2	LTC Control Insp	General Comments		
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LTCC000622	LTCControl	MK-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	409	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	49	°C
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	16	°C
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	LTC Min Tap Position	6L	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	LTC Max Tap Position	1R	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	LTC Current Tap Position	3L	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	LTC As Left Counter	11612	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	LTC As Found Counter	11612	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	General Comments		
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	17	°C
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	50	°C
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	17	°C
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	9 Month Operations	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	30	°C
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	60	°C
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	30	°C
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	60	°C
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	25	°C
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	60	°C
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LTCC000409	LTCControl	WS-TRANS 2	LTC Control Insp	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LTCC000409	LTCControl	WS-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	9 Month Operations	1	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Amps A Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Amps B Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Amps C Ø	0.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	Oil Temp Present	25	°C
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	Oil Temp Max	50	°C
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Unknown Operations	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	9 Month Operations	1	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Fault Operations A Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Fault Operations B Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Fault Operations C Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Fault Operations Ground	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Follow-up Action Required?	n	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	LTC Max Tap Position	5L	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	LTC Current Tap Position	7L	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	LTC As Left Counter	31469	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	LTC As Found Counter	31469	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	General Comments		
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	General Comments		
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LTCC000405	LTCControl	WS-TRANS 3	LTC Control Insp	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LTCC000405	LTCControl	WS-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LTCC000409	LTCControl	WS-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Unknown Operations	0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Switching Operations	0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Operations This Read Vac	0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Operations Counter AL	163	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Operations Counter AF	163	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Maintenance Operations	0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	General Comments		
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	General Comments		
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Follow-up Action Required?	n	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Fault Operations Ground	0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Fault Operations C Ø	0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Fault Operations B Ø	0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Fault Operations A Ø	0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Bushing Condition	Good	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Amps C Ø	110.0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Amps B Ø	115.0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Amps A Ø	100.0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Maintenance Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	9 Month Operations	1	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Amps A Ø	90.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Amps B Ø	90.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Amps C Ø	90.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Fault Operations A Ø	0	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	General Comments		
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Fault Operations B Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Fault Operations C Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Fault Operations Ground	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Follow-up Action Required?	n	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	General Comments		
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Maintenance Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Operations Counter AF	157	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Operations Counter AL	157	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Operations This Read Vac	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Operations This Read Vac	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Operations Counter AL	53	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Operations Counter AF	53	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Maintenance Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Maintenance Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Operations Counter AF	89	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Operations Counter AL	89	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Operations This Read Vac	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Switching Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Unknown Operations	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Accumulated Fault Duty B Ph V	.05	%
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Amps A Ø	42.0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Amps B Ø	43.0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Amps C Ø	24.0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Fault Operations A Ø	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Fault Operations B Ø	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Fault Operations C Ø	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Fault Operations Ground	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Follow-up Action Required?	n	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Unknown Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Switching Operations	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Amps A Ø	145.0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Accumulated Fault Duty C Ph V	.11	%
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Accumulated Fault Duty B Ph V	.05	%
12/15/2020 7:54	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	Follow-up Action Required?	n	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Accumulated Fault Duty A Ph V	.11	%
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	9 Month Operations	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Unknown Operations	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Operations This Read Vac	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Operations Counter AL	85	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Operations Counter AF	85	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Operations Counter AL	85	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Operations Counter AF	85	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Maintenance Operations	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	General Comments		
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	General Comments		
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Foundation Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	9 Month Operations	26	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Amps A Ø	100.0	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	LTCC000864	LTCControl	886-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	LTCC000864	LTCControl	886-1	LTC Control Insp	VRR Base Voltage AL	120.0	VAC
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	LTCC000864	LTCControl	886-1	LTC Control Insp	VRR Base Voltage AF	120.0	VAC
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	LTCC000864	LTCControl	886-1	LTC Control Insp	LTC Output Voltage Level	119.9	VAC
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	LTCC000864	LTCControl	886-1	LTC Control Insp	LTC Operation Checked?	y	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	LTCC000864	LTCControl	886-1	LTC Control Insp	General Comments		
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	LTCC000864	LTCControl	886-1	LTC Control Insp	Follow-up Action Required?	n	
12/15/2020 13:49	Distribution	Gates Rubber Quarterly Inspection	LTCC000864	LTCControl	886-1	LTC Control Insp	All Connections OK?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Amps B Ø	205.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Amps B Ø	100.0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Amps C Ø	167.0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Amps C Ø	100.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Fault Operations A Ø	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Fault Operations B Ø	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Fault Operations C Ø	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Fault Operations Ground	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Fault Operations A Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Fault Operations B Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Fault Operations C Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Fault Operations Ground	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Maintenance Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Operations Counter AF	49	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Operations Counter AL	49	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Fault Operations C Ø	0	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Fault Operations B Ø	0	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Fault Operations A Ø	0	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Bushing Condition	Good	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Amps C Ø	459.0	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Amps B Ø	474.0	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Amps A Ø	462.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Operations This Read Vac	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Switching Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Unknown Operations	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Fault Operations Ground	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Follow-up Action Required?	n	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Foundation Condition	Good	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Fault Operations B Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Fault Operations C Ø	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Fault Operations Ground	0	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Fault Operations Ground	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Patrol Inspection	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Follow-up Action Required?	n	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	General Comments		
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	General Comments		
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Maintenance Operations	0	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	General Comments		
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Grounds in Place?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Maintenance Operations	0	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Operations Counter AF	151	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Operations Counter AL	151	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Operations This Read Vac	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	9 Month Operations	1	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Amps A Ø	80.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Amps B Ø	80.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Amps C Ø	80.0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Operations Counter AF	129	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Operations Counter AL	129	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Operations This Read Vac	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Switching Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Unknown Operations	0	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	LTCC000612	LTCControl	456-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	LTCC000612	LTCControl	456-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	LTCC000612	LTCControl	456-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	LTCC000612	LTCControl	456-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	LTCC000612	LTCControl	456-1	LTC Control Insp	LTC Operation Checked?	y	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Operations This Read Vac	0	
12/15/2020 13:19	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	LTC Min Tap Position	16L	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	LTCC000612	LTCControl	456-1	LTC Control Insp	General Comments		
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	LTCC000612	LTCControl	456-1	LTC Control Insp	Follow-up Action Required?	n	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	30	°C
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	°C
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	LTC Operations Since Last Insp	685	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LTCC000405	LTCControl	WS-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Unknown Operations	0	
12/15/2020 12:31	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Fault Operations A Ø	0	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	LTCC000612	LTCControl	456-1	LTC Control Insp	All Connections OK?	y	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/15/2020 7:38	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Switching Operations	0	
12/15/2020 14:32	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Tank Paint Condition	Good	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Switching Operations	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Operations This Read Vac	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Fault Operations A Ø	0	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Operations Counter AL	225	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Operations Counter AF	225	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Maintenance Operations	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	General Comments		
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Fault Operations B Ø	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Fault Operations C Ø	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Fault Operations Ground	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Follow-up Action Required?	n	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Patrol Inspection	General Comments		
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Unknown Operations	0	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	MegaWatt Demand Meter Min	.30	MegaWatts
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LTC000577	LTCControl	SV-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	LTC0000847	LTCControl	537-1	LTC Control Insp	All Connections OK?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	LTC0000847	LTCControl	537-1	LTC Control Insp	Follow-up Action Required?	n	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	LTC0000847	LTCControl	537-1	LTC Control Insp	General Comments		
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	LTC0000847	LTCControl	537-1	LTC Control Insp	LTC Operation Checked?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	LTC0000847	LTCControl	537-1	LTC Control Insp	LTC Output Voltage Level	123.4	VAC
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	LTC0000847	LTCControl	537-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	9 Month Operations	1	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Amps A Ø	0.0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Amps B Ø	0.0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Amps C Ø	0.0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	General Comments		
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	MegaVar Demand Meter Max	.10	MegaVars
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	MegaVar Demand Meter Min	-.10	MegaVars
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	MegaWatt Demand Meter Max	.70	MegaWatts
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	General Comments		
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	Oil Temp Max	35	°C
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	Oil Temp Present	25	°C
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	Percent Thermal Load B Ø Max	-60	%
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
12/18/2020 6:46	Distribution	Jeffersonstown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/18/2020 6:46	Distribution	Jeffersonstown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2020 6:46	Distribution	Jeffersonstown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Amps C Ø	68.0	
12/18/2020 6:46	Distribution	Jeffersonstown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Amps B Ø	28.0	
12/18/2020 6:46	Distribution	Jeffersonstown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Amps A Ø	48.0	
12/18/2020 6:46	Distribution	Jeffersonstown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LTCC000577	LTCControl	SV-TRANS 2	LTC Control Insp	General Comments		
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LTCC000577	LTCControl	SV-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/18/2020 6:46	Distribution	Jeffersonstown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/18/2020 6:46	Distribution	Jeffersonstown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/18/2020 6:46	Distribution	Jeffersonstown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	9 Month Operations	4	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	Oil Temp Max	35	°C
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	Oil Temp Present	25	°C
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	General Comments		
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Max	.10	MegaVars
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Min	0.00	MegaVars
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Max	1.50	MegaWatts
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Min	.70	MegaWatts
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	LTC As Left Counter	87615	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	LTC As Found Counter	87615	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	General Comments		
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Operations This Read AM	0	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Operations Counter AL	810	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Operations Counter AF	810	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Maintenance Operations	0	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	General Comments		
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Patrol Inspection	General Comments		
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Fault Operations A Ø	0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Fault Operations C Ø	0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Fault Operations B Ø	0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Fault Operations A Ø	0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Amps C Ø	200.0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Amps B Ø	200.0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Amps A Ø	50.0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	9 Months Operations	0	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Fault Operations B Ø	0	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Fault Operations C Ø	0	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Fault Operations Ground	0	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Follow-up Action Required?	n	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Foundation Condition	Good	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	General Comments		
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Grounds in Place?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Maintenance Operations	0	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Operations Counter AF	480	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Operations Counter AL	480	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Operations This Read Vac	1	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Switching Operations	1	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Tank Paint Condition	Good	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Unknown Operations	0	
12/18/2020 6:46	Distribution	Jeffersonstown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Unknown Operations	0	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	LTC Totalizer Reading	2922.00	kw
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	General Comments	Need to add nitrogen, bottle on truck was empty.	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	General Comments		
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	General Comments		
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Patrol Inspection	General Comments		
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Follow-up Action Required?	n	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Fault Operations Ground	0	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	9 Month Operations	33	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Amps A Ø	215.0	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Amps B Ø	289.0	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Amps C Ø	232.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Bushing Condition	Good	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	523	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	LTC Min Tap Position	8L	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	LTC Max Tap Position	2R	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6L	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LTCC000482	LTCControl	SV-TRANS 1	LTC Control Insp	General Comments		
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LTCC000482	LTCControl	SV-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	LTC As Left Counter	220382	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	LTC As Found Counter	220382	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	General Comments		
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	74	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	LTC Min Tap Position	10L	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	LTC Max Tap Position	7L	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	LTC Current Tap Position	8L	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	LTC As Left Counter	223646	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	LTC As Found Counter	223746	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	General Comments		
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	9 Months Operations	1	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0	%
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0	%
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0	%
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Amps A Ø	0	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Amps B Ø	0	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Amps C Ø	0	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Fault Operations A Ø	0	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Fault Operations B Ø	0	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Fault Operations C Ø	0	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Fault Operations Ground	0	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Follow-up Action Required?	n	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Patrol Inspection	General Comments		
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Switching Operations	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Operations This Read Vac	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Operations Counter AL	344	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Operations Counter AF	344	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Maintenance Operations	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	General Comments		
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Follow-up Action Required?	n	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Fault Operations Ground	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Fault Operations C Ø	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Fault Operations B Ø	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Fault Operations A Ø	0	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	LTC Min Tap Position	8L	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	LTC Max Tap Position	Neutral	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	LTC Current Tap Position	6L	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LTCC000482	LTCControl	SV-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	General Comments		
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	General Comments	TRANSFORMER OIL LEVEL IS LOW	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	Oil Temp Max	50	°C
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	Oil Temp Present	38	°C
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	Percent Thermal Load B Ø Max	-60	%
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	Percent Thermal Load C Ø Max	-60	%
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	LTC Operations Since Last Insp	0	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	LTC Min Tap Position	10L	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	LTC Max Tap Position	3L	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	LTC Current Tap Position	5L	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	LTC As Left Counter	71819	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	LTC As Found Counter	71819	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Mechanism Patrol Inspection	General Comments		
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	General Comments		
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	Follow-up Action Required?	n	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	Totalizer Meter Reading	.9678	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	Oil Temp Present	38	°C
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	Oil Temp Max	38	°C
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	LTC Totalizer Reading	9290.88	kw
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	General Comments		
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	General Comments		
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	22	°C
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	47	°C
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	22	°C
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	47	°C
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	22	°C
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	47	°C
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	Oil Temp Present	21	°C
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	Oil Temp Max	47	°C
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	400	psi
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	General Comments		
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.1	VDC
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	General Comments		
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Exp/Missing Not Repl	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Fault Operations B ∅	0	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Fault Operations C ∅	0	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Fault Operations Ground	0	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Follow-up Action Required?	n	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Foundation Condition	Good	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	General Comments		
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Grounds in Place?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Maintenance Operations	0	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Operations Counter AF	315	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Operations Counter AL	315	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Operations This Read Vac	0	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Switching Operations	0	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Tank Paint Condition	Good	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Unknown Operations	0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Unknown Operations	0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Switching Operations	0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Operations This Read AM	0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Operations Counter AL	99963	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Operations Counter AF	99963	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Maintenance Operations	0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Fault Operations B Ø	0	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Fault Operations C Ø	0	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Fault Operations Ground	0	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Follow-up Action Required?	n	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	General Comments		
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Maintenance Operations	0	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Operations Counter AF	262	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Operations Counter AL	271	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Operations This Read Vac	9	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Switching Operations	9	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Unknown Operations	0	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	Totalizer Meter Reading	.4870	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	Oil Temp Present	46	°C
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	Oil Temp Max	57	°C
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	9 Month Operations	17	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Amps A Ø	80.0	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Amps B Ø	60.0	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Amps C Ø	120.0	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	9 Month Operations	1	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Amps A Ø	12.0	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Amps B Ø	12.0	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Amps C Ø	12.0	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Bushing Condition	Good	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Fault Operations A Ø	0	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Fault Operations A Ø	0	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Fault Operations B Ø	0	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Fault Operations C Ø	0	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Fault Operations Ground	0	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Follow-up Action Required?	n	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Foundation Condition	Good	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	General Comments		
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	General Comments		
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Grounds in Place?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Maintenance Operations	0	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Operations Counter AF	333	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Operations Counter AL	333	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Operations This Read Vac	0	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Switching Operations	0	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Tank Paint Condition	Good	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Unknown Operations	0	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	LTCC000921	LTCControl	790-1	LTC Control Insp	VRR Time Delay	60	Seconds
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	LTCC000921	LTCControl	790-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	LTCC000921	LTCControl	790-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	LTCC000921	LTCControl	790-1	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	LTCC000921	LTCControl	790-1	LTC Control Insp	LTC Operation Checked?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	LTCC000921	LTCControl	790-1	LTC Control Insp	General Comments		
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	LTCC000921	LTCControl	790-1	LTC Control Insp	Follow-up Action Required?	n	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	LTCC000921	LTCControl	790-1	LTC Control Insp	All Connections OK?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Unknown Operations	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Switching Operations	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Operations This Read Vac	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Operations Counter AL	211	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Operations Counter AF	211	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Maintenance Operations	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	General Comments		
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Patrol Inspection	General Comments		
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Follow-up Action Required?	n	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Fault Operations Ground	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Fault Operations C Ø	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Fault Operations B Ø	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Fault Operations A Ø	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Amps C Ø	126.0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Amps B Ø	143.0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Amps A Ø	109.0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	9 Month Operations	28	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Amps A Ø	46.0	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Amps B Ø	78.0	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Amps C Ø	69.0	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #""s
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	General Comments		
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #""s
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	General Comments		
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Bushing Condition	Good	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	LTC Min Tap Position	9L	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	BCH001322	Charger	779-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	BCH001322	Charger	779-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	BCH001322	Charger	779-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	BCH001322	Charger	779-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	BCH001322	Charger	779-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	BCH001322	Charger	779-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	BCH001322	Charger	779-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	LTCC000847	LTCControl	537-1	LTC Control Insp	VRR Time Delay	60	Seconds
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	LTCC000847	LTCControl	537-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	BCH001322	Charger	779-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	LTC Operations Since Last Insp	1008	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	General Comments		
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Unknown Operations	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Switching Operations	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Operations This Read Vac	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Operations Counter AL	206	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	LTC As Found Counter	21127	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	LTC As Left Counter	21127	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	LTC Current Tap Position	9L	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1L	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	LTC Min Tap Position	11L	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	41	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	10	°C
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	282	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Operations Counter AF	206	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Maintenance Operations	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	General Comments		
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Patrol Inspection	General Comments		
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Follow-up Action Required?	n	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Fault Operations Ground	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Fault Operations C Ø	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Fault Operations B Ø	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Fault Operations A Ø	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	9 Month Operations	7	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Unknown Operations	0	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Tank Paint Condition	Good	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Switching Operations	0	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Operations This Read Vac	0	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Operations Counter AL	0	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Operations Counter AF	747	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Maintenance Operations	0	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Grounds in Place?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	General Comments		
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	General Comments		
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Foundation Condition	Good	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Follow-up Action Required?	n	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Fault Operations Ground	0	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Fault Operations C Ø	0	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Fault Operations B Ø	0	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Fault Operations A Ø	0	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Bushing Condition	Good	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Amps C Ø	20.0	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Amps B Ø	12.0	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Amps A Ø	60.0	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	9 Month Operations	1	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	Follow-up Action Required?	n	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	General Comments		
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Mechanism Patrol Inspection	General Comments		
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	LTC As Found Counter	6456	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	LTC As Left Counter	6465	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	LTC Current Tap Position	2L	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	LTC Max Tap Position	4R	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	General Comments		
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	General Comments	needs nitro	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0	psi
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	Oil Temp Max	55	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	67	°C
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	40	°C
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	General Comments		
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Vegetation	None	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	General Comments		
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/18/2020 6:46	Distribution	Jeffersonstown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/18/2020 6:46	Distribution	Jeffersonstown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2020 6:46	Distribution	Jeffersonstown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Amps C Ø	109.0	
12/18/2020 6:46	Distribution	Jeffersonstown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Amps B Ø	108.0	
12/18/2020 6:46	Distribution	Jeffersonstown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Amps A Ø	78.0	
12/18/2020 6:46	Distribution	Jeffersonstown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/18/2020 6:46	Distribution	Jeffersonstown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/18/2020 6:46	Distribution	Jeffersonstown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/18/2020 6:46	Distribution	Jeffersonstown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	9 Month Operations	1	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	General Comments		
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Maintenance Operations	0	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Operations Counter AF	578	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Operations Counter AL	578	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Operations This Read AM	0	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Switching Operations	0	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Amps C Ø	110	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Amps B Ø	140	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Amps A Ø	125	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0	%
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0	%
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0	%
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	9 Months Operations	2	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	General Comments		
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Exp/Missing Not Repl	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Readings	Oil Temp Present	30	*C
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Readings	Oil Temp Max	45	*C
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1600	psi
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.8	psi
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Readings	General Comments		
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Ambient Temp	38	*F
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	9 Months Operations	1	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Amps A Ø	130.0	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Amps B Ø	100.0	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Amps C Ø	135.0	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Fault Operations A Ø	0	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Fault Operations B Ø	0	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Fault Operations C Ø	0	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Fault Operations Ground	0	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Follow-up Action Required?	n	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Patrol Inspection	General Comments		
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	General Comments		
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Maintenance Operations	0	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Operations Counter AF	431	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Operations Counter AL	431	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Operations This Read AM	0	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Switching Operations	0	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Unknown Operations	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Arching Horns Good Condition?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Readings	General Comments		
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.8	psi
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Readings	Oil Temp Max	15	°C
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Readings	Oil Temp Present	0	°C
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Ambient Temp	40	*F
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Unknown Operations	0	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Switching Operations	0	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Operations This Read AM	0	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Operations Counter AL	523	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Operations Counter AF	523	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Accumulated Fault Duty C Ph AM	4.85	%
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Amps A Ø	125	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Amps B Ø	140	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Amps C Ø	110	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Fault Adjusted Amps A Phase AM	0	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Fault Adjusted Amps B Phase AM	0	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Fault Adjusted Amps C Phase AM	0	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Fault Operations A Ø	0	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Fault Operations B Ø	0	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Fault Operations C Ø	0	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Unknown Operations	0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Fault Operations Ground	0	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Follow-up Action Required?	n	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Patrol Inspection	General Comments		
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	General Comments		
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Maintenance Operations	0	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Operations Counter AF	1282	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Operations Counter AL	1282	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Operations This Read AM	0	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Switching Operations	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	General Comments		
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	General Comments		
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Amps B Ø	108	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Amps A Ø	94	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0	%
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	PF000185	PowerFuse	JT-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	PF000185	PowerFuse	JT-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	PF000186	PowerFuse	JT-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	PF000186	PowerFuse	JT-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Switching Operations	1	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Operations This Read AM	1	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Operations Counter AL	345	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Operations Counter AF	345	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Maintenance Operations	0	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	General Comments		
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Patrol Inspection	General Comments		
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Follow-up Action Required?	n	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Operations Ground	0	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Operations C Ø	0	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Operations B Ø	0	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Operations A Ø	0	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	General Comments		
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Maintenance Operations	0	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	General Comments		
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Patrol Inspection	General Comments		
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Follow-up Action Required?	n	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Fault Operations Ground	0	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Fault Operations C Ø	0	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Fault Operations B Ø	0	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Fault Operations A Ø	0	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	General Comments		
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition?	Good	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Vegetation	None	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	General Comments		
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Unknown Operations	0	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Amps C Ø	110	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	General Comments		
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	General Comments		
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	General Comments	Moisture in cabinet, card was soaking wet.	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	LTC Totalizer Reading	6727.68	kw
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	n	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	General Comments	Under Frequency box has been removed.	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Vegetation	None	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Fault Adjusted Amps C Phase V	22.36	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Fault Operations A Ø	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Fault Operations B Ø	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Fault Operations C Ø	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Fault Operations Ground	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Follow-up Action Required?	n	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Patrol Inspection	General Comments		
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	General Comments		
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Operations Counter AF	377	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Operations Counter AL	377	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	30	°C
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	40	°C
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	-7	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Operations This Read Vac	2	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Switching Operations	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Unknown Operations	2	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	General Comments		
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Vegetation	None	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	General Comments		
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Ambient Temp	34	°F
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	9 Month Operations	1	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Amps A Ø	380.0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Amps B Ø	366.0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Amps C Ø	459.0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Fault Operations Ground	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Patrol Inspection	General Comments		
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	General Comments		
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Maintenance Operations	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Operations Counter AF	244	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Operations Counter AL	244	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Operations This Read Vac	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Switching Operations	0	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	LTC As Found Counter	320040	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	LTC As Left Counter	320040	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	LTC Max Tap Position	7L	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	LTC Min Tap Position	10L	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	78	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	9 Months Operations	0	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Accumulated Fault Duty A Ph AM	2.43	%
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Accumulated Fault Duty B Ph AM	7.28	%
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	General Comments		
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Unknown Operations	0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Switching Operations	0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Operations This Read AM	0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Operations Counter AL	354	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Operations Counter AF	354	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Maintenance Operations	0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	General Comments		
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Patrol Inspection	General Comments		
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Follow-up Action Required?	n	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Fault Operations Ground	0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Fault Operations C Ø	0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Fault Operations B Ø	0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Fault Operations A Ø	0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Amps C Ø	250.0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Amps B Ø	250.0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Amps A Ø	200.0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	9 Months Operations	1	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	Oil Temp Max	35	°C
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	Oil Temp Present	25	°C
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	Totalizer Meter Reading	.7008	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	85.00	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	PF000327	PowerFuse	SV-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	PF000327	PowerFuse	SV-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Amps A Ø	180.0	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Amps B Ø	180.0	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Amps C Ø	140.0	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Bushing Condition	Good	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Fault Operations A Ø	0	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Fault Operations B Ø	0	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Fault Operations C Ø	0	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Fault Operations Ground	0	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Foundation Condition	Good	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	General Comments		
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	General Comments		
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Fault Operations C Ø	0	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Fault Operations B Ø	0	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Fault Operations A Ø	0	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	9 Months Operations	0	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	PF000328	PowerFuse	SV-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	PF000328	PowerFuse	SV-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	PF000329	PowerFuse	SV-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	PF000329	PowerFuse	SV-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	PF000330	PowerFuse	SV-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	PF000330	PowerFuse	SV-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments	Transformer is not in station. Remove from isp	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Follow-up Action Required?	n	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Patrol Inspection	General Comments		
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	General Comments		
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Operations Counter AF	99950	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Operations Counter AL	99950	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Operations This Read AM	0	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Bushing Condition	Good	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Amps C Ø	144.0	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Amps B Ø	180.0	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Amps A Ø	155.0	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	9 Month Operations	24	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	General Comments	Some brush growing on fence and also trees growing near fence.	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Interrupts/Puffrs Visual OK?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	General Comments		
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Ambient Temp	34	°F
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	General Comments		
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Exp Boom Corrected	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Vegetation	None	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Grounds in Place?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Maintenance Operations	0	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Operations Counter AF	719	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Operations Counter AL	719	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Operations This Read Vac	0	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Switching Operations	0	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Tank Paint Condition	Good	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Unknown Operations	0	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Unknown Operations	0	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Switching Operations	0	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Operations This Read AM	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Operations Counter AL	312	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Operations Counter AF	312	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Maintenance Operations	0	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	General Comments		
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Patrol Inspection	General Comments		
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Follow-up Action Required?	n	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Operations Ground	0	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Operations C Ø	0	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Operations B Ø	0	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Operations A Ø	0	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Trash Emptied?	n	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	General Comments	Heater is not working.	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	n	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Broom on Site?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	9 Months Operations	1	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Amps A Ø	190.0	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Amps B Ø	150.0	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Amps C Ø	120.0	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Accumulated Fault Duty A Ph AM	0	%
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Accumulated Fault Duty B Ph AM	2.41	%
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Accumulated Fault Duty C Ph AM	0	%
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Amps A Ø	94	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Amps B Ø	108	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Amps C Ø	110	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Fault Adjusted Amps A Phase AM	0	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Fault Adjusted Amps B Phase AM	0	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Fault Adjusted Amps C Phase AM	0	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Fault Operations A Ø	0	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Fault Operations B Ø	0	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Fault Operations C Ø	0	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Fault Operations Ground	0	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Follow-up Action Required?	n	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Patrol Inspection	General Comments		
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	General Comments		
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Maintenance Operations	0	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Operations Counter AF	204	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Operations Counter AL	204	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Operations This Read AM	0	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Switching Operations	0	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0	%
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0	%
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	9 Months Operations	0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	PF000270	PowerFuse	PI-4KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	PF000270	PowerFuse	PI-4KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	PF000271	PowerFuse	PI-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	PF000271	PowerFuse	PI-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	BCH001088	Charger	SV-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	BCH001088	Charger	SV-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	BCH001088	Charger	SV-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	BCH001088	Charger	SV-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.1	amps
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	BCH001088	Charger	SV-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	BCH001088	Charger	SV-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	BCH001088	Charger	SV-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Tank Paint Condition	Good	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Switching Operations	1	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Operations This Read Vac	1	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Operations Counter AL	0	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Operations Counter AF	181	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Maintenance Operations	0	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Grounds in Place?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	General Comments		
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	General Comments		
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Foundation Condition	Good	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	Oil Temp Max	44	°C
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	Oil Temp Present	24	°C
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	46	°C
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	25	°C
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	46	°C
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	24	°C
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	46	°C
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	24	°C
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	General Comments		
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	LTC As Found Counter	5578	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	LTC As Left Counter	5578	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	LTC Current Tap Position	9L	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	LTC Max Tap Position	2L	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	LTC Min Tap Position	11L	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	41	°C
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	12	°C
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	348	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Amps C Ø	240.0	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Amps B Ø	180.0	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Amps A Ø	160.0	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	9 Months Operations	44	
12/14/2020 11:40	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	9 Months Operations	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Bushing Condition	Good	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Amps C Ø	36.0	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Amps B Ø	40.0	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Amps A Ø	62.0	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	9 Month Operations	2	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	9 Month Operations	2	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Unknown Operations	0	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Tank Paint Condition	Good	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Switching Operations	2	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Operations This Read Vac	24	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Operations Counter AL	328	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Operations Counter AF	328	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Maintenance Operations	22	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Grounds in Place?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	General Comments		
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	General Comments		
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	PF000187	PowerFuse	JT-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	PF000187	PowerFuse	JT-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	PF000188	PowerFuse	JT-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	PF000188	PowerFuse	JT-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Foundation Condition	Good	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Follow-up Action Required?	n	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Fault Operations Ground	0	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Follow-up Action Required?	n	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Fault Operations Ground	0	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Fault Operations C Ø	0	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Fault Operations B Ø	0	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Fault Operations A Ø	0	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Bushing Condition	Good	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Amps C Ø	60.0	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Amps B Ø	50.0	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Amps A Ø	57.0	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	9 Month Operations	7	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Unknown Operations	0	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Tank Paint Condition	Good	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Switching Operations	1	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Operations This Read Vac	1	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Operations Counter AL	160	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Operations Counter AF	160	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Maintenance Operations	0	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Grounds in Place?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	General Comments		
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	General Comments		
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Foundation Condition	Good	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Follow-up Action Required?	n	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Fault Operations Ground	0	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Fault Operations C Ø	0	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Fault Operations A Ø	0	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	BCH001353	Charger	537-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.200	millivolts
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Unknown Operations	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Switching Operations	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Operations This Read Vac	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Operations Counter AL	139	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Operations Counter AF	139	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Maintenance Operations	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	General Comments		
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Patrol Inspection	General Comments		
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Follow-up Action Required?	n	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Fault Operations Ground	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Fault Operations C Ø	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Fault Operations B Ø	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Fault Operations A Ø	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Ambient Temp	37	°F
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Amps C Ø	18.0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Amps B Ø	17.0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Amps A Ø	20.0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	9 Month Operations	1	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	General Comments		
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	General Comments		
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	General Comments		
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	BCH001353	Charger	537-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	BCH001353	Charger	537-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	BCH001353	Charger	537-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	BCH001353	Charger	537-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	BCH001353	Charger	537-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	BCH001353	Charger	537-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	BCH001353	Charger	537-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Unknown Operations	0	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Operations This Read AM	0	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Operations Counter AL	18463	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Operations Counter AF	18463	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Follow-up Action Required?	n	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	General Comments		
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Patrol Inspection	General Comments		
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Follow-up Action Required?	n	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	9 Months Operations	0	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Patrol Inspection	General Comments		
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Unknown Operations	0	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Switching Operations	0	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Operations This Read Vac	0	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Operations Counter AL	409	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Operations Counter AF	409	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Maintenance Operations	0	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	General Comments		
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Patrol Inspection	General Comments		
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Follow-up Action Required?	n	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Fault Operations Ground	0	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Fault Operations C Ø	0	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Fault Operations B Ø	0	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Fault Operations A Ø	0	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	General Comments		
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Maintenance Operations	0	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Operations Counter AF	180	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Operations Counter AL	180	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Operations This Read Vac	0	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Unknown Operations	0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Switching Operations	0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Operations This Read Vac	0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Operations Counter AL	99849	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Operations Counter AF	99849	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Amps C Ø	0.0	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Amps B Ø	0.0	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Amps A Ø	0.0	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	9 Month Operations	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Vegetation	None	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	9 Month Operations	3	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Fault Operations A Ø	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Fault Operations B Ø	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Fault Operations C Ø	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Fault Operations Ground	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Amps A Ø	163.0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Amps B Ø	138.0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Amps C Ø	209.0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Fault Operations A Ø	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Fault Operations B Ø	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Fault Operations C Ø	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Fault Operations Ground	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Follow-up Action Required?	n	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Patrol Inspection	General Comments		
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	General Comments		
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Maintenance Operations	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Operations Counter AF	475	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Operations Counter AL	475	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Operations This Read Vac	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Switching Operations	0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	General Comments		
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Ambient Temp	40	*F
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Maintenance Operations	0	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Operations Counter AF	448	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Operations Counter AL	448	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Operations This Read AM	0	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Switching Operations	0	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Unknown Operations	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	General Comments		
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	CH000442	ControlHouse	PI-Battery Control House	Control House Patrol Inspection	Panel Lights OK?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	CH000442	ControlHouse	PI-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	CH000442	ControlHouse	PI-Battery Control House	Control House Patrol Inspection	General Comments		
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	CH000442	ControlHouse	PI-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	CH000442	ControlHouse	PI-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	CH000442	ControlHouse	PI-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	CH000442	ControlHouse	PI-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	9 Month Operations	1	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Control House Lighting OK?	n	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Door Alarms OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Follow-up Action Required?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Fault Operations Ground	0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Follow-up Action Required?	n	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Foundation Condition	Good	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	General Comments		
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	General Comments		
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Grounds in Place?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Maintenance Operations	0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Operations Counter AF	41	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Operations Counter AL	41	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Operations This Read Vac	0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Switching Operations	0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Unknown Operations	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Amps C Ø	74.0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Amps B Ø	49.0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Amps A Ø	36.0	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	9 Months Operations	40	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Amps A Ø	165.0	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Amps B Ø	130.0	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Amps C Ø	130.0	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Vegetation	None	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Fault Operations A Ø	0	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Fault Operations B Ø	0	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Fault Operations C Ø	0	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Fault Operations Ground	0	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Follow-up Action Required?	n	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Patrol Inspection	General Comments		
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	General Comments		
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	2538	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	LTC Min Tap Position	9L	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	LTC Max Tap Position	3L	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	LTC As Left Counter	393802	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	LTC As Found Counter	393802	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	General Comments		
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Trash Emptied?	n	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	General Comments		
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Floor Swept?	n	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Door Alarms OK?	n	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Broom on Site?	n	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	General Comments		1-8ft bulb is out
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Fault Operations C Ø	0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Fault Operations B Ø	0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Fault Operations A Ø	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Trash Emptied?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	9 Months Operations	0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Amps A Ø	0.0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Amps B Ø	0.0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Amps C Ø	0.0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Fault Operations A Ø	0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Fault Operations B Ø	0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Fault Operations C Ø	0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Fault Operations Ground	0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Follow-up Action Required?	n	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Patrol Inspection	General Comments		
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	General Comments		
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Maintenance Operations	0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Operations Counter AF	284	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Operations Counter AL	284	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Operations This Read AM	0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Switching Operations	0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Unknown Operations	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Doors and Locks Secure?	n	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Filters Condition OK?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Floor Swept?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	General Comments	lock was not latched on house.	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Fault Operations Ground	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	Follow-up Action Required?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	LTC As Found Counter	61978	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	LTC As Left Counter	61985	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	General Comments	VC will not change if I operate in Man.	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	LTC As Found Counter	162415	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	LTC As Left Counter	162415	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	LTC Current Tap Position	8L	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	LTC Max Tap Position	2L	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	LTC Min Tap Position	10L	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Amps A Ø	60.0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Amps B Ø	47.0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Amps C Ø	31.0	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	LTCC000701	LTCControl	779-1	LTC Control Insp	All Connections OK?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	LTCC000701	LTCControl	779-1	LTC Control Insp	Follow-up Action Required?	n	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	LTCC000701	LTCControl	779-1	LTC Control Insp	General Comments		
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	LTCC000701	LTCControl	779-1	LTC Control Insp	LTC Operation Checked?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	LTCC000701	LTCControl	779-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	LTCC000701	LTCControl	779-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Patrol Inspection	General Comments		
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	General Comments		
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Maintenance Operations	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Operations Counter AF	140	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Operations Counter AL	140	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Operations This Read Vac	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Switching Operations	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Unknown Operations	0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Battery Bank Amps	.7	AMPS
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	40	°F
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	LTCC000701	LTCControl	779-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/14/2020 12:08	Distribution	Somerset 2 Quarterly Inspection	LTCC000701	LTCControl	779-1	LTC Control Insp	VRR Time Delay	45	Seconds
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	LTC Current Tap Position	6L	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	LTC Min Tap Position	13L	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	BCH001229	Charger	SE-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	BCH001229	Charger	SE-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	BCH001229	Charger	SE-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.7	VDC
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	BCH001229	Charger	SE-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.7	VDC
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	BCH001229	Charger	SE-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Mechanism Patrol Inspection	General Comments		
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	General Comments		
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	Follow-up Action Required?	n	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BCH001390	Charger	790-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BCH001390	Charger	790-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BCH001390	Charger	790-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BCH001390	Charger	790-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BCH001390	Charger	790-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.3	amps
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BCH001390	Charger	790-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BCH001390	Charger	790-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	BCH001390	Charger	790-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.700	millivolts

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	BAT001286	Battery	SE-Battery Bank	Battery Patrol Inspection	General Comments		
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	BAT001286	Battery	SE-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	BAT001286	Battery	SE-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	BAT001286	Battery	SE-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	BAT001286	Battery	SE-Battery Bank	Battery Patrol Inspection	Battery Bank Volts	26.7	VDC
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	BAT001286	Battery	SE-Battery Bank	Battery Patrol Inspection	Battery Bank Amps	.2	AMPS
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.7	amps
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.7	VDC
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/14/2020 12:14	Distribution	Seventh Street Quarterly Inspection	BCH001229	Charger	SE-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	9 Month Operations	2	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.7	VDC
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	General Comments		
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/14/2020 13:32	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Dry Cell Battery Install Date	2020-12-14 00:00:00.000000	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Battery Bank Volts	26.6	VDC
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	9 Month Operations	2	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Amps A Ø	255.0	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Amps B Ø	275.0	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Amps C Ø	305.0	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Amps A Ø	25.0	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Amps B Ø	31.0	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Amps C Ø	56.0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Maintenance Operations	0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Grounds in Place?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	General Comments		
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	General Comments		
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Foundation Condition	Good	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Follow-up Action Required?	n	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Fault Operations Ground	0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Fault Operations C Ø	0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Fault Operations B Ø	0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Fault Operations A Ø	0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	9 Month Operations	1	
12/18/2020 6:46	Distribution	Jeffersonton Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Broom on Site?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Unknown Operations	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Switching Operations	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	9 Month Operations	0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Amps C Ø	120.0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Amps B Ø	90.0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Amps A Ø	80.0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Amps C Ø	85.0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Amps B Ø	95.0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Fault Adjusted Amps B Phase V	22.36	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Amps A Ø	113.0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Fault Adjusted Amps A Phase V	22.36	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	9 Month Operations	2	
12/14/2020 11:32	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	LTC Operations Since Last Insp	745	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Unknown Operations	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Switching Operations	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Operations This Read Vac	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Operations Counter AL	161	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Operations Counter AF	161	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Maintenance Operations	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	General Comments		
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Patrol Inspection	General Comments		
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Follow-up Action Required?	n	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Patrol Inspection	Follow-up Action Required?	n	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Fault Operations Ground	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Fault Operations C Ø	0	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Fault Operations A Ø	0	
12/14/2020 9:34	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/18/2020 6:46	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Fault Operations B Ø	0	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	General Comments	no P3	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Grounds in Place?	y	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Maintenance Operations	0	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Operations Counter AF	183	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Operations Counter AF	181	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Operations Counter AL	182	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Operations This Read Vac	1	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Switching Operations	1	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	99996	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Tank Paint Condition	Good	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Unknown Operations	0	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	9 Month Operations	2	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	99996	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Amps C Ø	0.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Amps B Ø	0.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Amps A Ø	0.0	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Operations Counter AL	184	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Operations This Read Vac	1	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Switching Operations	1	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Tank Paint Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	9 Month Operations	0	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Unknown Operations	0	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Mechanism Patrol Inspection	General Comments	Need to add oil.	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	LTC As Found Counter	16936	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	LTC As Left Counter	16939	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	General Comments		
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Trash Emptied?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	LTC Current Tap Position	5L	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	LTC Max Tap Position	2L	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	LTC Min Tap Position	10L	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	LTC Operations Since Last Insp	484	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Amps A Ø	100.0	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Amps B Ø	126.0	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Amps C Ø	129.0	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Bushing Condition	Good	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Fault Operations A Ø	0	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Fault Operations B Ø	0	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Fault Operations C Ø	0	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Fault Operations Ground	0	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Follow-up Action Required?	n	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Foundation Condition	Good	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	General Comments		
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	General Comments		
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Grounds in Place?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	General Comments		
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Maintenance Operations	0	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	00176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Low	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	00196	WithLTC	361-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	00196	WithLTC	361-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	00196	WithLTC	361-1	LTC Transformer Readings	Totalizer Meter Reading	1.2879	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	00196	WithLTC	361-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	00196	WithLTC	361-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	00196	WithLTC	361-1	LTC Transformer Patrol Inspection	Tank Oil Level	Low	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	00196	WithLTC	361-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	00196	WithLTC	361-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	00196	WithLTC	361-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	00196	WithLTC	361-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	00196	WithLTC	361-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	00176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	00176	NonLTC	323-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1600	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	00176	NonLTC	323-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.0638	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	00196	WithLTC	361-1	LTC Transformer Readings	Oil Temp Present	45	°C
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	00196	WithLTC	361-1	LTC Transformer Readings	Oil Temp Max	55	°C
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	00196	WithLTC	361-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	00196	WithLTC	361-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	00196	WithLTC	361-1	LTC Transformer Readings	LTC Totalizer Reading	9272.88	kw
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	00196	WithLTC	361-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	General Comments		
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	00196	WithLTC	361-1	LTC Transformer Readings	General Comments		
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	00196	WithLTC	361-1	LTC Transformer Patrol Inspection	General Comments		
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	00196	WithLTC	361-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	00196	WithLTC	361-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	00196	WithLTC	361-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	LTC Max Tap Position	4L	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	LTC Current Tap Position	10L	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	LTC As Left Counter	188523	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	LTC As Found Counter	188523	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Mechanism Patrol Inspection	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	LTC Min Tap Position	12L	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	LTC Operations Since Last Insp	806	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	00176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	00176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	00176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	00176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	00176	NonLTC	323-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	00176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	00176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	00176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	General Comments		
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	LTCC000675	LTCControl	843-1	LTC Control Insp	All Connections OK?	y	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	LTCC000675	LTCControl	843-1	LTC Control Insp	Follow-up Action Required?	n	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	LTCC000675	LTCControl	843-1	LTC Control Insp	General Comments		
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	LTCC000675	LTCControl	843-1	LTC Control Insp	LTC Operation Checked?	y	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	LTCC000675	LTCControl	843-1	LTC Control Insp	LTC Output Voltage Level	124.8	VAC
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	LTCC000675	LTCControl	843-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	LTCC000675	LTCControl	843-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	LTCC000675	LTCControl	843-1	LTC Control Insp	VRR Time Delay	60	Seconds
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	00176	NonLTC	323-1	NonLTC Transformer Readings	General Comments		
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	00176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	00176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	00176	NonLTC	323-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	00176	NonLTC	323-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1702.08	kw
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	00176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	00176	NonLTC	323-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	00176	NonLTC	323-1	NonLTC Transformer Readings	Oil Temp Max	42	°C
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	00176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	00176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	00176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	00176	NonLTC	323-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	00176	NonLTC	323-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	00176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	00176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	00176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Fault Operations A Ø	0	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Fault Operations B Ø	0	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Fault Operations C Ø	0	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Fault Operations Ground	0	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Follow-up Action Required?	n	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Foundation Condition	Good	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	00196	WithLTC	361-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	00196	WithLTC	361-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	00196	WithLTC	361-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	00196	WithLTC	361-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Bushing Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Foundation Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Grounds in Place?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	Follow-up Action Required?	n	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Tank Leaks	None	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Tank Oil Level	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Tank Paint Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	00196	WithLTC	361-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	00196	WithLTC	361-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	00196	WithLTC	361-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	00196	WithLTC	361-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	00196	WithLTC	361-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	00196	WithLTC	361-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	00196	WithLTC	361-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	00196	WithLTC	361-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	Oil Temp Max	60	°C
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	Oil Temp Present	40	°C
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	X1 Winding Temp Max	65	°C
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	X1 Winding Temp Present	35	°C
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	X2 Winding Temp Max	65	°C
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	X2 Winding Temp Present	35	°C
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	X3 Winding Temp Max	65	°C
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	X3 Winding Temp Present	35	°C
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	9 Month Operations	2	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Amps A Ø	26.0	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Amps B Ø	33.0	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Amps C Ø	26.0	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Bushing Condition	Good	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	Oil Temp Max	60	°C
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	Oil Temp Present	30	°C
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	40.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	50	°C
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	30	°C
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	45	°C
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	20	°C
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	65	°C
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	40	°C
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	LTCC000699	LTCControl	361-1	LTC Control Insp	LTC Operation Checked?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Fans Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	Oil Temp Present	38	°C
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	Tank Paint Condition	Good	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	Totalizer Meter Reading	.9282	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	LTCC000699	LTCControl	361-1	LTC Control Insp	All Connections OK?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	LTCC000699	LTCControl	361-1	LTC Control Insp	Follow-up Action Required?	n	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	LTCC000699	LTCControl	361-1	LTC Control Insp	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B ∅	0	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C ∅	0	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	159	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	0	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	8	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	8	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	LTCC000699	LTCCControl	361-1	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	LTCC000699	LTCCControl	361-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	LTCC000699	LTCCControl	361-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	LTCC000699	LTCCControl	361-1	LTC Control Insp	VRR Time Delay	45	Seconds
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	Oil Temp Present	30	°C
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	Top Oil Temperature Max	50	°C
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	WithLTC Trn Dynamic Health	30.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	X1 Winding Temp Max	45	°C
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	X1 Winding Temp Present	30	°C
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	X2 Winding Temp Max	50	°C
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Winding Temp Max	40	°C
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	X3 Winding Temp Present	30	°C
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	X3 Winding Temp Max	50	°C
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	X2 Winding Temp Present	30	°C
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	Oil Temp Max	50	°C
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Unknown Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Switching Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Operations This Read Vac	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Operations Counter AL	155	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Operations Counter AF	155	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Maintenance Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Fault Operations Ground	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Fault Operations C ∅	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Fault Operations B ∅	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Fault Operations A ∅	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Amps C ∅	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	150.0	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	190.0	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	110.0	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	General Comments		
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Floor Swept?	n	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Amps B Ø	0.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Amps A Ø	0.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	9 Month Operations	0	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	50.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	60.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	50.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LTCC000578	LTCControl	FV-TRANS 4	LTC Control Insp	Parallel / Ind. Sw Position	parallelIPAR	Position
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LTCC000578	LTCControl	FV-TRANS 4	LTC Control Insp	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LTCC000578	LTCControl	FV-TRANS 4	LTC Control Insp	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LTCC000578	LTCControl	FV-TRANS 4	LTC Control Insp	All Connections OK?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Unknown Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Switching Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Operations This Read Vac	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Operations Counter AL	174	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Operations Counter AF	174	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Maintenance Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Fault Operations Ground	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Fault Operations C Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Fault Operations B Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Fault Operations A Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Amps C Ø	0.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Amps B Ø	0.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Amps A Ø	0.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	Follow-up Action Required?	n	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	General Comments		
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Mechanism Patrol Inspection	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	9 Month Operations	1	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	LTC As Found Counter	406105	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	LTC As Left Counter	406118	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	LTC Current Tap Position	2R	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	LTC Max Tap Position	7R	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	LTC Min Tap Position	5L	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	LTC Operations Since Last Insp	1379	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	LTC Operations Since Last Insp	213	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Fault Operations A Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Fault Operations B Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Fault Operations C Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Fault Operations Ground	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Maintenance Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Operations Counter AF	185	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Operations Counter AL	185	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Operations This Read Vac	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Switching Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Unknown Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	21	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	21	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	General Comments	nitro 6 pack at 0 psi	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	LV Winding Temp Max	40	°C
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	LV Winding Temp Present	40	°C
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	Oil Temp Max	50	°C
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BCH001233	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BCH001233	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BCH001233	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BCH001233	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BCH001233	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	52.7	VDC
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BCH001233	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.7	VDC
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BCH001233	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.990	millivolts
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Positive DC Ground	13.0	VDC
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Negative DC Ground	13.0	VDC
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	General Comments		
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	50	*F
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	263	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	LTC Min Tap Position	16L	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	LTC Max Tap Position	3L	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	LTC Current Tap Position	12L	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	LTC As Left Counter	47553	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	LTC As Found Counter	47553	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	85	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	LTC Min Tap Position	8R	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	LTC Max Tap Position	13R	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	LTC Current Tap Position	9R	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	LTC As Left Counter	265822	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	LTC As Found Counter	265822	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	LTC Min Tap Position	12L	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	LTC Max Tap Position	4L	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	LTC Current Tap Position	6L	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	LTC As Left Counter	71155	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	LTC As Found Counter	71155	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Mechanism Patrol Inspection	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	529	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LTCC000607	LTCControl	FV-TRANS 8	LTC Control Insp	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LTCC000607	LTCControl	FV-TRANS 8	LTC Control Insp	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LTCC000607	LTCControl	FV-TRANS 8	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	LTC Min Tap Position	10L	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	LTC Max Tap Position	2L	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	LTC Current Tap Position	8L	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	LTC As Left Counter	17059	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	LTC As Found Counter	17059	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Mechanism Patrol Inspection	General Comments	SMALL LEAK IN LTC FILTER CABINET	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	General Comments		
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	General Comments		
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	LTC Totalizer Reading	4455.36	kw
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	Oil Temp Max	55	°C
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LTCC000436	LTCControl	FV-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LTCC000436	LTCControl	FV-TRANS 1	LTC Control Insp	General Comments	ok	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LTCC000437	LTCControl	FV-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LTCC000437	LTCControl	FV-TRANS 3	LTC Control Insp	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LTCC000437	LTCControl	FV-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LTCC000438	LTCControl	FV-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LTCC000438	LTCControl	FV-TRANS 2	LTC Control Insp	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LTCC000438	LTCControl	FV-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Operations Counter AF	313	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Operations Counter AL	313	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Operations This Read Vac	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Switching Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	Tank Paint Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Unknown Operations	0	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Vegetation	None	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	General Comments	Driveway is overgrown and needs to be cut.	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	9 Month Operations	8	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Amps A Ø	330.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Amps B Ø	340.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Amps C Ø	330.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Fault Operations A Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Fault Operations B Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Fault Operations C Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Fault Operations Ground	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Follow-up Action Required?	n	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Clear of Trash?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Ambient Temp	32	*F
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	BAT001475	Battery	323-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	BAT001475	Battery	323-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	BAT001475	Battery	323-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	BAT001475	Battery	323-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	BAT001475	Battery	323-Battery Bank	Battery Patrol Inspection	General Comments		
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	BAT001475	Battery	323-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	BAT001475	Battery	323-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	BAT001475	Battery	323-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	BAT001475	Battery	323-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	BAT001475	Battery	323-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Amps A Ø	0.0	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Amps B Ø	0.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Amps C Ø	0.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	BAT001475	Battery	323-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	BAT001475	Battery	323-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	BAT001475	Battery	323-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Fault Operations A Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Fault Operations B Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Fault Operations C Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Fault Operations Ground	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	550.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	540.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	560.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Maintenance Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Operations Counter AF	138	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Operations Counter AL	138	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Operations This Read Vac	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Switching Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Unknown Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Tank Paint Condition	Good	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Grounds in Place?	y	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	General Comments		
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Foundation Condition	Good	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Bushing Condition	Good	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	9	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	9	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	1687	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	1678	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	General Comments	We had to clean the contacts.	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Maintenance Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Operations Counter AF	298	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Operations Counter AL	298	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Operations This Read Vac	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Switching Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Unknown Operations	0	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	BCH001409	Charger	323-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	BCH001409	Charger	323-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	BCH001409	Charger	323-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	BCH001409	Charger	323-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	BCH001409	Charger	323-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	BCH001409	Charger	323-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.1	VDC
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	BCH001409	Charger	323-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.1	VDC
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	BCH001409	Charger	323-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.300	millivolts
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	9	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	9	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	General Comments		
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	General Comments		
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	9 Month Operations	0	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	9 Month Operations	-1	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Amps A Ø	0.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Amps B Ø	0.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Amps C Ø	0.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	Bushing Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Unknown Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Switching Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Operations This Read Vac	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Operations Counter AL	27	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Operations Counter AF	27	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Maintenance Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Fault Operations Ground	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Fault Operations C Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Fault Operations B Ø	0	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	ST000002	Structure	323-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Unknown Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Switching Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Operations This Read Vac	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AL	74	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AF	74	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Maintenance Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Fault Operations Ground	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Fault Operations C Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Fault Operations B Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Fault Operations A Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Regulator As Left Counter	68012	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Max Tap Position	4L	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	General Comments		
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Current Tap Position	8L	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Amps C Ø	0.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Amps B Ø	0.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Amps A Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Regulator As Left Counter	65554	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Fault Operations A Ø	0	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Fault Operations B Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Fault Operations C Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Fault Operations Ground	0	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	General Comments		
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	Foundation Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	General Comments		inservice next week
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	Grounds in Place?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Maintenance Operations	0	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	9 Month Operations	1	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		fence is rusty
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Fault Operations A Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Amps C Ø	470.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Amps B Ø	480.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Amps A Ø	500.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	9 Month Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001519	BreakerVacuum	FV-1471	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Current Tap Position	7L	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	General Comments		
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Max Tap Position	3L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	BCH001319	Charger	361-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	BCH001319	Charger	361-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	BCH001319	Charger	361-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	BCH001319	Charger	361-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	BCH001319	Charger	361-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	BCH001319	Charger	361-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.3	VDC
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	BCH001319	Charger	361-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.3	VDC
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	BCH001319	Charger	361-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.000	millivolts
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Unknown Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Switching Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Operations This Read Vac	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Operations Counter AL	344	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Operations Counter AF	344	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Maintenance Operations	0	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Max Tap Position	4L	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	General Comments		
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Fault Operations Ground	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Fault Operations C Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Fault Operations B Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Fault Operations A Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Amps C Ø	0.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Amps B Ø	0.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Amps A Ø	0.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Operations This Read Vac	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Switching Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Unknown Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Maintenance Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Operations Counter AF	301	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Operations Counter AL	301	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Operations This Read Vac	0	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Current Tap Position	8L	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Ambient Temp	60	*F
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Amps A Ø	40.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Amps B Ø	30.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Amps C Ø	30.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	9 Month Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Amps A Ø	50.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Fault Operations A Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Fault Operations B Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Fault Operations Ground	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	9 Month Operations	0	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Regulator As Left Counter	66379	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	General Comments	inserie today	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	General Comments		
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Maintenance Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Operations Counter AF	325	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Readings	Operations Counter AL	325	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Amps B Ø	60.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Amps C Ø	60.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Fault Operations A Ø	0	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Fault Operations B Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Fault Operations C Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Fault Operations Ground	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	General Comments		
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	170.0	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	9 Month Operations	20	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	150.0	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	100.0	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	19	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Switching Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Unknown Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Amps A Ø	360.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Amps B Ø	360.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Amps C Ø	360.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Fault Operations A Ø	0	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	General Comments		
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Fault Operations B Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Fault Operations C Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Fault Operations Ground	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Maintenance Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Operations Counter AF	338	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Operations Counter AL	338	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Operations This Read Vac	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Switching Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Unknown Operations	0	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/11/2020 11:23	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	9 Month Operations	6	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Ambient Temp	50	*F
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	General Comments		
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Vegetation	None	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Vegetation	None	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	General Comments		
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2020 8:25	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/11/2020 10:54	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Floor Swept?	n	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Grounds in Place?	y	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Evidence of Insects	Yes_needs_sprayed	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Follow-up Action Required?	n	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Patrol Inspection	General Comments		
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	General Comments		
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Filters Condition OK?	y	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Fault Operations B Ø	0	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	9 Month Operations	4	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Fault Operations C Ø	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Fault Operations A Ø	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Amps B Ø	0.0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Amps C Ø	0.0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Fault Operations Ground	0	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Negative DC Ground	29.2	VDC
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	General Comments		
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Fault Operations A Ø	0	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Fault Operations B Ø	0	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Fault Operations C Ø	0	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Fault Operations Ground	0	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Follow-up Action Required?	n	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Foundation Condition	Good	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	General Comments		
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	General Comments		
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Grounds in Place?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Maintenance Operations	0	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Maintenance Operations	0	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Operations Counter AF	212	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Operations Counter AL	212	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Operations This Read Vac	0	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Switching Operations	0	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Unknown Operations	0	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	64	°F
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Bushing Condition	Good	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Amps C Ø	63.0	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Amps B Ø	107.0	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Amps A Ø	103.0	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	LTC Operations Since Last Insp	344	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	LTC Min Tap Position	9L	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Unknown Operations	0	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Switching Operations	0	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Operations This Read Vac	0	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	LTC Max Tap Position	4L	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	LTC Current Tap Position	5L	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	LTC As Left Counter	253375	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	LTC As Found Counter	253370	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Mechanism Patrol Inspection	General Comments		
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	General Comments		
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	Follow-up Action Required?	n	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Operations Counter AL	104	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Operations Counter AF	104	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Maintenance Operations	0	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Grounds in Place?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	General Comments		
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	General Comments		
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Foundation Condition	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Follow-up Action Required?	n	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Vegetation	None	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Fault Operations Ground	0	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Fault Operations C Ø	0	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Fault Operations B Ø	0	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Fault Operations A Ø	0	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	General Comments		
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Ambient Temp	56	*F
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Switching Operations	0	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	SF6 Pressure	70	psi
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	SF6 Bushing Condition	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Operations This Read SF6	0	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Operations Counter AL	51	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Operations Counter AF	51	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Num Operations Last 9 Months	1	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Maintenance Operations	0	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Heaters (All) Functioning?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Grounds in Place?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	General Comments		
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Amps C Ø	0.0	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	General Comments	BLACK AND RED BUGS	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	PF000137	PowerFuse	FV-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	K	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	PF000137	PowerFuse	FV-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	PF000137	PowerFuse	FV-12KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Amps B Ø	0.0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Amps A Ø	0.0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Positive DC Ground	24.3	VDC
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Operations Counter AF	299	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Operations Counter AL	300	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Operations This Read Vac	1	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Switching Operations	1	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Unknown Operations	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BCH001091	Charger	FM-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BCH001091	Charger	FM-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BCH001091	Charger	FM-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BCH001091	Charger	FM-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	5.1	amps
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BCH001091	Charger	FM-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.6	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	9 Month Operations	1	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BCH001091	Charger	FM-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.6	VDC
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BCH001091	Charger	FM-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	7.400	millivolts
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	BCH001180	Charger	594-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	BCH001180	Charger	594-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	BCH001180	Charger	594-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Amps A Ø	0.0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	BCH001180	Charger	594-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	BCH001180	Charger	594-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	BCH001180	Charger	594-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	BCH001180	Charger	594-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	General Comments		
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	9 Month Operations	0	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	PF000066	PowerFuse	CR-14KV TR 1-A POT	Disconnect Powerfuse Inspection	General Comments	NA	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	PF000066	PowerFuse	CR-14KV TR 1-A POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Switching Operations	0	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Operations This Read Vac	0	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Operations Counter AL	232	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Operations Counter AF	232	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Maintenance Operations	0	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Grounds in Place?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	General Comments		
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	General Comments		
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Foundation Condition	Good	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Follow-up Action Required?	n	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Fault Operations Ground	0	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Fault Operations C Ø	0	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Fault Operations B Ø	0	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Fault Operations A Ø	0	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Amps C Ø	190.0	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Amps B Ø	160.0	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Amps A Ø	185.0	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	9 Month Operations	4	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Unknown Operations	0	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Switching Operations	0	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Operations This Read Vac	0	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Operations Counter AL	160	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Unknown Operations	0	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	General Comments		
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Vegetation	None	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	General Comments		
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	General Comments	fence and barb wire rusty, gaps under fence more than 4 inches	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Unknown Operations	0	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Operations Counter AL	171	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Operations This Read Vac	0	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Switching Operations	0	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Unknown Operations	0	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	n	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	9 Month Operations	1	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Amps A Ø	67.0	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Amps B Ø	86.0	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Amps C Ø	84.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Trash Emptied?	n	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	9 Month Operations	1	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Unknown Operations	0	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Switching Operations	0	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Operations This Read Vac	0	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Fault Operations A Ø	0	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Fault Operations B Ø	0	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Fault Operations C Ø	0	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Fault Operations Ground	0	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Follow-up Action Required?	n	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Patrol Inspection	Foundation Condition	Good	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Patrol Inspection	General Comments		
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	General Comments		
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Patrol Inspection	Grounds in Place?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Maintenance Operations	0	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Operations Counter AF	157	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Operations Counter AL	157	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Operations Counter AF	160	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Maintenance Operations	0	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	Grounds in Place?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	General Comments		
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	General Comments		
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	Foundation Condition	Good	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Follow-up Action Required?	n	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Fault Operations Ground	0	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Fault Operations C Ø	0	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Fault Operations B Ø	0	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Fault Operations A Ø	0	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	Bushing Condition	Good	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Amps C Ø	53.0	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Amps B Ø	84.0	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Amps A Ø	44.0	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	General Comments		
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Operations Counter AF	171	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Unknown Operations	0	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Fault Operations C Ø	0	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Fault Operations B Ø	0	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Fault Operations A Ø	0	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Bushing Condition	Good	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Amps C Ø	67.0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Switching Operations	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Unknown Operations	0	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	General Comments		
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	General Comments		
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Amps B Ø	35.0	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Amps A Ø	51.0	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	9 Month Operations	42	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Amps A Ø	85.0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	9 Month Operations	1	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	LTC Operations Since Last Insp	1126	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	LTC Min Tap Position	2L	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	6045.12	kw
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	General Comments		
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	General Comments		
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Maintenance Operations	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Operations Counter AF	152	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Operations Counter AL	152	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Operations This Read Vac	0	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BCH000203	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	3.820	millivolts
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BCH000203	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.1	VDC
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BCH000203	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.1	VDC
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BCH000203	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	2.1	amps
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Foundation Condition	Good	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Fault Operations A Ø	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Fault Operations B Ø	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Fault Operations C Ø	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Fault Operations Ground	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Follow-up Action Required?	n	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Patrol Inspection	General Comments		
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Follow-up Action Required?	n	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Fault Operations Ground	0	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BCH000203	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BCH000203	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	9 Month Operations	3	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	General Comments		
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Maintenance Operations	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Operations Counter AF	206	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Operations Counter AL	206	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Operations This Read Vac	0	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Amps A Ø	0.0	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Amps B Ø	0.0	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Amps C Ø	0.0	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Switching Operations	0	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Follow-up Action Required?	n	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	LTC Min Tap Position	8L	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	LTC Max Tap Position	5R	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	LTC Current Tap Position	2L	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Fault Operations A Ø	0	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Fault Operations B Ø	0	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Fault Operations C Ø	0	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Fault Operations Ground	0	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Follow-up Action Required?	n	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	General Comments		
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	General Comments		
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Maintenance Operations	0	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Operations Counter AF	452	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Patrol Inspection	Foundation Condition	Good	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Patrol Inspection	General Comments		
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	General Comments		
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Patrol Inspection	Grounds in Place?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Maintenance Operations	0	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Operations Counter AL	452	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Operations This Read Vac	0	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Switching Operations	0	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	LTC As Left Counter	64878	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	LTC As Found Counter	64874	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	General Comments		
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	General Comments		
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	Follow-up Action Required?	n	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.2594	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	9 Month Operations	2	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Amps A Ø	112.0	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Amps B Ø	119.0	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	LTC Max Tap Position	13R	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	LTC Current Tap Position	9R	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	LTC As Left Counter	42481	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	LTC As Found Counter	42472	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Mechanism Patrol Inspection	General Comments		
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	General Comments		
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	Follow-up Action Required?	n	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	LTC Operations Since Last Insp	920	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Amps C Ø	136.0	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Patrol Inspection	Bushing Condition	Good	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	28	°C
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	56	°C
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Fault Operations A Ø	0	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Fault Operations B Ø	0	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Fault Operations C Ø	0	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Fault Operations Ground	0	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	9 Month Operations	2	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Trash Emptied?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Restroom Clean & OK?	n	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	LTC Totalizer Reading	6652.80	kw
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	Oil Temp Max	60	°C
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	Oil Temp Present	40	°C
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	n	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	Totalizer Meter Reading	.9240	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	General Comments	1-8ft bulb out. Restroom is out of order. Need to be fixed	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Follow-up Action Required?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Basement Condition Acceptable	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Broom on Site?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	9 Month Operations	9	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Amps A Ø	90.0	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Amps B Ø	85.0	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Amps C Ø	102.0	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Bushing Condition	Good	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Fault Adjusted Amps B Phase V	4.44	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Fault Operations A Ø	0	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Fault Operations B Ø	1	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Fault Operations C Ø	0	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Fault Operations Ground	0	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Follow-up Action Required?	n	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Foundation Condition	Good	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	General Comments		
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	General Comments		
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Grounds in Place?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Maintenance Operations	0	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Operations Counter AF	156	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Operations Counter AL	156	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Operations This Read Vac	1	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Switching Operations	0	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Unknown Operations	0	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Bushing Condition	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Amps C Ø	0.0	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Amps B Ø	0.0	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Amps A Ø	0.0	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	General Comments		
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Vegetation	None	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	General Comments		
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	LTCC000061	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	LTCC000061	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	LTCC000061	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	LTCC000061	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	LTCC000061	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	125.6	VAC
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	LTCC000061	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	LTCC000061	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	LTCC000061	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	9 Month Operations	6	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Amps A Ø	51.0	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Amps B Ø	65.0	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Amps C Ø	56.0	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	General Comments		
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	n	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	General Comments	Some ruts and washout forming at the bottom of the hill as you turn up to sub.	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Vegetation	None	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Control House Lighting OK?	n	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Broom on Site?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Trash Emptied?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	LTCC000163	LTCControl	423-1	LTC Control Insp	All Connections OK?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	LTCC000163	LTCControl	423-1	LTC Control Insp	Follow-up Action Required?	n	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	LTCC000163	LTCControl	423-1	LTC Control Insp	General Comments		
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	LTCC000163	LTCControl	423-1	LTC Control Insp	LTC Operation Checked?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	LTCC000163	LTCControl	423-1	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	LTCC000163	LTCControl	423-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	LTCC000163	LTCControl	423-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	LTCC000163	LTCControl	423-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	General Comments		
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	General Comments		
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Tank Paint Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Grounds in Place?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Foundation Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Bushing Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Patrol Inspection	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Tank Paint Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Grounds in Place?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	General Comments		
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LTCC000883	LTCControl	CR-TRANS 1-A	LTC Control Insp	General Comments		
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LTCC000883	LTCControl	CR-TRANS 1-A	LTC Control Insp	Follow-up Action Required?	n	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LTCC000883	LTCControl	CR-TRANS 1-A	LTC Control Insp	All Connections OK?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Regulator As Left Counter	39273	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	General Comments	top rail rusty .bottom of alot of the fence has a large gap	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Max Tap Position	8R	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	General Comments		
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	General Comments		
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	General Comments		
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Tank Paint Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Grounds in Place?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Foundation Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Bushing Condition	Good	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Unknown Operations	0	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	PF000132	PowerFuse	FV-GND TR 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	PF000132	PowerFuse	FV-GND TR 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	PF000132	PowerFuse	FV-GND TR 1	Disconnect Powerfuse Inspection	General Comments	ok	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	PF000133	PowerFuse	FV-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	PF000133	PowerFuse	FV-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	PF000133	PowerFuse	FV-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	PF000134	PowerFuse	FV-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	PF000134	PowerFuse	FV-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	PF000134	PowerFuse	FV-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	0k	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	PF000135	PowerFuse	FV-14KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	PF000135	PowerFuse	FV-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	PF000135	PowerFuse	FV-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	PF000136	PowerFuse	FV-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	PF000136	PowerFuse	FV-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	PF000136	PowerFuse	FV-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	K	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Amps C Ø	99.0	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Amps B Ø	67.0	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Amps A Ø	81.0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	3	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Winding Temp Present	28	°C
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Winding Temp Max	37	°C
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.5156	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Amps B Ø	137.0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Amps A Ø	173.0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	9 Month Operations	2	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Unknown Operations	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Switching Operations	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Operations This Read Vac	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Operations Counter AL	214	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Operations Counter AF	214	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Maintenance Operations	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	General Comments		
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Patrol Inspection	General Comments		
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Follow-up Action Required?	n	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Fault Operations Ground	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Fault Operations C Ø	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Fault Operations B Ø	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Fault Operations A Ø	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Amps C Ø	59.0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Amps B Ø	66.0	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	General Comments		
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Negative DC Ground	13.0	VDC
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Positive DC Ground	12.0	VDC
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	234	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	234	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	General Comments		
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Operations Counter	11	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	LTCC000716	LTCControl	594-1	LTC Control Insp	LTC Operation Checked?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	LTCC000716	LTCControl	594-1	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	LTCC000716	LTCControl	594-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	LTCC000716	LTCControl	594-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	PF000143	PowerFuse	FV-STA SER NO 6	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	PF000143	PowerFuse	FV-STA SER NO 6	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	PF000143	PowerFuse	FV-STA SER NO 6	Disconnect Powerfuse Inspection	General Comments	k	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	PF000144	PowerFuse	FV-STA SER NO 8	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	PF000144	PowerFuse	FV-STA SER NO 8	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	PF000144	PowerFuse	FV-STA SER NO 8	Disconnect Powerfuse Inspection	General Comments	ok	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	LTCC000716	LTCControl	594-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Regulator As Left Counter	43264	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Max Tap Position	10R	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	General Comments		
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	LTCC000716	LTCControl	594-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	PF000145	PowerFuse	FV-14KV TR 8 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	PF000145	PowerFuse	FV-14KV TR 8 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	PF000145	PowerFuse	FV-14KV TR 8 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Current Tap Position	1R	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Ambient Temperature	60	°F
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Cabinet Paint Condition	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Fault Operations	0	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Follow-up Action Required?	n	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Foundation Condition	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Gauge(s) Condition	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	General Comments		
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	PF000139	PowerFuse	FV-STA SER NO 3	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	PF000139	PowerFuse	FV-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	PF000139	PowerFuse	FV-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	k	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	PF000140	PowerFuse	FV-12KV TR 3 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	PF000140	PowerFuse	FV-12KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	PF000140	PowerFuse	FV-12KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	k	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	PF000141	PowerFuse	FV-STA SER NO 4	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	PF000141	PowerFuse	FV-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	PF000141	PowerFuse	FV-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	k	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	PF000142	PowerFuse	FV-12KV TR 4 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	PF000142	PowerFuse	FV-12KV TR 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	PF000142	PowerFuse	FV-12KV TR 4 POT	Disconnect Powerfuse Inspection	General Comments	k	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Oil Temp Present	28	°C
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Oil Temp Max	35	°C
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	3637.44	kw
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	General Comments		
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	General Comments		
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	LTCC000716	LTCControl	594-1	LTC Control Insp	All Connections OK?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	LTCC000716	LTCControl	594-1	LTC Control Insp	Follow-up Action Required?	n	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	LTCC000716	LTCControl	594-1	LTC Control Insp	General Comments		
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	PF000124	PowerFuse	FM-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	PF000124	PowerFuse	FM-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	PF000125	PowerFuse	FM-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	PF000125	PowerFuse	FM-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	PF000126	PowerFuse	FM-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	PF000126	PowerFuse	FM-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	PF000127	PowerFuse	FM-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	PF000127	PowerFuse	FM-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Vegetation	None	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Maintenance Operations	0	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Operations Counter AF	217	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Operations Counter AL	217	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Operations This Read Vac	3	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Switching Operations	0	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Unknown Operations	3	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Ambient Temp	62	°F

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	General Comments		
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	General Comments		
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	General Comments		
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Bushing Condition	Good	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Fault Adjusted Amps A Phase V	15.20	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Fault Adjusted Amps B Phase V	15.20	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Fault Adjusted Amps C Phase V	15.20	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Fault Operations A Ø	0	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Fault Operations B Ø	0	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Fault Operations C Ø	0	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Fault Operations Ground	0	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Follow-up Action Required?	n	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Foundation Condition	Good	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	General Comments		
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	General Comments		
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Grounds in Place?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	General Comments	Fabric and top rails rusty.	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	General Comments		
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	Follow-up Action Required?	n	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	General Comments		
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Mechanism Patrol Inspection	General Comments		
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	LTC As Found Counter	4320	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	LTC As Left Counter	4320	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	LTC Current Tap Position	Neutral	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	LTC Max Tap Position	2R	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	LTC Min Tap Position	Neutral	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	LTC Operations Since Last Insp	3	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Operations Counter AF	209	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Maintenance Operations	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	General Comments		
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Patrol Inspection	General Comments		
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Follow-up Action Required?	n	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Fault Operations Ground	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Fault Operations C Ø	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Fault Operations B Ø	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Fault Operations A Ø	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Amps C Ø	123.0	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	General Comments	trees overhang on transforme side	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Ambient Temp	60	*F
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Unknown Operations	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Operations This Read Vac	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Operations Counter AL	209	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	General Comments		
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Vegetation	None	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Yard Lights Working?	n	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	General Comments		
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Amps A Ø	40.0	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Amps B Ø	40.0	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Amps C Ø	50.0	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Bushing Condition	Good	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	General Comments		
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	General Comments		
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	5164.80	kw
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	60.00	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	55.00	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	LTCC000457	LTCControl	423-2	LTC Control Insp	VRR Time Delay	30	Seconds
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	LTCC000457	LTCControl	423-2	LTC Control Insp	VRR Base Voltage AL	0.0	VAC
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Fault Operations A Ø	0	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Fault Operations B Ø	0	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Fault Operations C Ø	0	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Fault Operations Ground	0	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Follow-up Action Required?	n	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	LTCC000457	LTCControl	423-2	LTC Control Insp	VRR Base Voltage AF	0.0	VAC
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	LTCC000457	LTCControl	423-2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	LTCC000457	LTCControl	423-2	LTC Control Insp	LTC Output Voltage Level	0.0	VAC
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	LTCC000457	LTCControl	423-2	LTC Control Insp	LTC Operation Checked?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	LTCC000457	LTCControl	423-2	LTC Control Insp	General Comments		
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	LTCC000457	LTCControl	423-2	LTC Control Insp	Follow-up Action Required?	n	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	LTCC000457	LTCControl	423-2	LTC Control Insp	All Connections OK?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Readings	Oil Temp Max	30	°C
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Readings	General Comments	OUT OF SERVICE	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	General Comments	OUT OF SERVICE	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Readings	Follow-up Action Required?	n	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	9 Month Operations	0	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	BCH000930	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	BCH000930	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	BCH000930	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	BCH000930	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	BCH000930	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	BCH000930	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	9 Month Operations	2	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Unknown Operations	0	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Switching Operations	0	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Operations This Read Vac	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Operations Counter AL	217	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Operations Counter AF	217	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Maintenance Operations	0	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Grounds in Place?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	General Comments		
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	General Comments		
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Foundation Condition	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Follow-up Action Required?	n	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Fault Operations Ground	0	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Fault Operations C Ø	0	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Fault Operations B Ø	0	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Fault Operations A Ø	0	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Bushing Condition	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Amps C Ø	56.0	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Amps B Ø	55.0	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Amps A Ø	70.0	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	9 Month Operations	1	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	Follow-up Action Required?	n	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5380	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Vegetation	None	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Foundation Condition	Good	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	General Comments		
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	General Comments		
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Grounds in Place?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Maintenance Operations	0	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Operations Counter AF	282	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Operations Counter AL	282	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Operations This Read Vac	2	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Switching Operations	2	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Unknown Operations	0	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	Winding Temp Present	36	°C
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	Winding Temp Max	44	°C
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	Totalizer Meter Reading	1.2900	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	Oil Temp Present	32	°C
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	Oil Temp Max	48	°C
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	LTC Totalizer Reading	12384.00	kw
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	General Comments		
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	General Comments		
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	General Comments	1 thru 12 need water...made WO	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Exp/Missing Not Repl	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Broom on Site?	n	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Floor Swept?	n	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	General Comments		
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Trash Emptied?	n	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	BCH000934	Charger	452-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	BCH000934	Charger	452-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	BCH000934	Charger	452-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	BCH000934	Charger	452-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	BCH000934	Charger	452-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.1	VDC
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	BCH000934	Charger	452-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	General Comments		
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	8R	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	11L	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	BCH001323	Charger	494-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	BCH001323	Charger	494-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	BCH001323	Charger	494-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.7	amps
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	BCH001323	Charger	494-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	BCH001323	Charger	494-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	BCH001323	Charger	494-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	62	*F
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	General Comments		
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #-'s
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	General Comments		
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Ambient Temp	50	*F
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	General Comments		
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Vegetation	None	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Readings	Oil Temp Max	60	*C
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Readings	General Comments		
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	General Comments		
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Bushing Condition	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Amps C Ø	442.0	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Readings	Follow-up Action Required?	n	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Amps B Ø	450.0	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Amps A Ø	451.0	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Readings	Percent Thermal Load B Ø Max	0	%
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Readings	Oil Temp Present	10	°C
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	125.3	volts
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	354439	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	74	°F
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	General Comments		
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.2	VDC
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.1	VDC
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Unknown Operations	0	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Switching Operations	0	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Operations This Read Vac	0	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Operations Counter AL	73	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Operations Counter AF	73	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Maintenance Operations	0	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Grounds in Place?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	General Comments		
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Foundation Condition	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Follow-up Action Required?	n	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Fault Operations Ground	0	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Fault Operations C Ø	0	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Fault Operations B Ø	0	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Fault Operations A Ø	0	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Foundation Condition	Good	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Internal Condition?	Clean	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Heaters Functioning?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Ambient Temperature	64	°F
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	LTCC000848	LTCControl	868-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	LTCC000848	LTCControl	868-1	LTC Control Insp	VRR Time Delay	60	Seconds
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Unknown Operations	0	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Switching Operations	0	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Operations This Read Vac	0	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Operations Counter AL	213	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Regulator As Left Counter	8570	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BCH001285	Charger	850-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BCH001285	Charger	850-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Ambient Temp	64	°F
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	General Comments		
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Vegetation	None	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	General Comments		
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	LTCC000848	LTCControl	868-1	LTC Control Insp	All Connections OK?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	LTCC000848	LTCControl	868-1	LTC Control Insp	Follow-up Action Required?	n	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	LTCC000848	LTCControl	868-1	LTC Control Insp	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	LTCC000848	LTCControl	868-1	LTC Control Insp	LTC Operation Checked?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	LTCC000848	LTCControl	868-1	LTC Control Insp	LTC Output Voltage Level	125.4	VAC
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	LTCC000848	LTCControl	868-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Trip-energy Supply Verified	y	LED lights?
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Indicator Zone	OK	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Bushing Condition	Good	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Grounds in Place?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	General Comments		
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	General Comments		
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Patrol Inspection	General Comments		
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	General Comments		
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	General Comments		
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	General Comments		
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Operations Counter AF	213	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Maintenance Operations	0	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Grounds in Place?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	General Comments		
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Foundation Condition	Good	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Follow-up Action Required?	n	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Fault Operations Ground	0	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Fault Operations C Ø	0	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Fault Operations B Ø	0	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Fault Operations A Ø	0	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Bushing Condition	Good	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Amps C Ø	87.0	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Amps B Ø	85.0	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Amps A Ø	122.0	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	9 Month Operations	5	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Min Tap Position	4L	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Max Tap Position	3R	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	General Comments		
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Unknown Operations	0	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Switching Operations	0	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Operations This Read Vac	0	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Operations Counter AL	2034	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Operations Counter AF	2034	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Maintenance Operations	0	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Grounds in Place?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	General Comments		
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Foundation Condition	Good	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Follow-up Action Required?	n	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Regulator As Left Counter	24979	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.6	volts
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Fault Operations C Ø	0	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Fault Operations B Ø	0	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Fault Operations A Ø	0	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	General Comments		
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Mechanism Patrol Inspection	General Comments		
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	LTC As Found Counter	85683	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	LTC As Left Counter	85694	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	LTC Current Tap Position	6L	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	LTC Max Tap Position	4L	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	LTC Min Tap Position	8L	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	LTC Operations Since Last Insp	193	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	General Comments		
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LTCC000406	LTCControl	FM-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallellIND	Position
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LTCC000406	LTCControl	FM-TRANS 2	LTC Control Insp	General Comments		
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LTCC000406	LTCControl	FM-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Ambient Temp	59	*F
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Counter Readings	Follow-up Action Required?	n	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Mechanism Patrol Inspection	General Comments		
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Counter Readings	General Comments	OUT OF SERVICE	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Counter Readings	LTC As Found Counter	77072	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Counter Readings	LTC As Left Counter	77072	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Counter Readings	LTC Current Tap Position	14R	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Counter Readings	LTC Operations Since Last Insp	0	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Regulator As Left Counter	26691	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.4	volts
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	LTCC000375	LTCControl	698-1	LTC Control Insp	All Connections OK?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	LTCC000375	LTCControl	698-1	LTC Control Insp	Follow-up Action Required?	n	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	LTCC000375	LTCControl	698-1	LTC Control Insp	General Comments		
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	LTCC000375	LTCControl	698-1	LTC Control Insp	LTC Operation Checked?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	LTCC000375	LTCControl	698-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	LTCC000375	LTCControl	698-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	LTCC000375	LTCControl	698-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	LTCC000375	LTCControl	698-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	LTCC000375	LTCControl	698-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Broom on Site?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Winding Temp Present	51	°C
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Winding Temp Max	51	°C
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.0896	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Oil Temp Max	35	°C
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	10460.16	kw
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	General Comments		
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	General Comments		
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BCH001285	Charger	850-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.400	millivolts
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BCH001285	Charger	850-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.3	VDC
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BCH001285	Charger	850-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.3	VDC
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BCH001285	Charger	850-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BCH001285	Charger	850-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BCH001285	Charger	850-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Bushing Condition	Good	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Amps C Ø	110.0	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Amps B Ø	125.0	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Amps A Ø	120.0	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	9 Month Operations	5	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	General Comments		
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0037	LTCMechanism	CR-TRANS 2-B	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	Follow-up Action Required?	n	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	General Comments		
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Mechanism Patrol Inspection	General Comments		
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	LTC As Found Counter	121467	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	LTC As Left Counter	121467	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	LTC Current Tap Position	5R	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	LTC Max Tap Position	6R	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	LTC Min Tap Position	5R	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	LTC Operations Since Last Insp	2	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0045	LTCMechanism	CR-TRANS 1-A	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Trash Emptied?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	General Comments		
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	LTC Operations Since Last Insp	259	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	LTC Min Tap Position	9L	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	LTC Max Tap Position	4L	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	LTC Current Tap Position	7L	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	LTC As Left Counter	254661	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	LTC As Found Counter	254654	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Mechanism Patrol Inspection	General Comments		
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	General Comments		
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	Follow-up Action Required?	n	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Switching Operations	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Unknown Operations	2	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Operations This Read Vac	0	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Operations Counter AL	214	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Operations Counter AF	214	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Maintenance Operations	0	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Grounds in Place?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	General Comments		
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	General Comments		
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Foundation Condition	Good	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Follow-up Action Required?	n	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Fault Operations Ground	0	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Fault Operations C Ø	0	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Fault Operations B Ø	0	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Fault Operations A Ø	0	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Bushing Condition	Good	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Amps C Ø	46.0	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Amps B Ø	52.0	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Amps A Ø	37.0	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	9 Month Operations	5	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	53	°C
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	33	°C
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	35	°C
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	35	°C
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	50	°C
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	35	°C
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	9 Month Operations	6	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Amps A Ø	254.0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Amps B Ø	246.0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Amps C Ø	240.0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Fault Adjusted Amps A Phase V	22.36	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Fault Adjusted Amps B Phase V	22.36	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Fault Adjusted Amps C Phase V	22.36	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Fault Operations A Ø	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Fault Operations B Ø	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Fault Operations C Ø	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Fault Operations Ground	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Follow-up Action Required?	n	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Patrol Inspection	General Comments		
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	General Comments		
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Maintenance Operations	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Operations Counter AF	405	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Operations Counter AL	405	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Operations This Read Vac	2	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	50	°F
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #"'s
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	General Comments		
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.8	VDC
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Tank Paint Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Grounds in Place?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Foundation Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Bushing Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Tank Paint Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Grounds in Place?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Foundation Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	General Comments		
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	General Comments		
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	LTC Totalizer Reading	3415.68	kw
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	Oil Temp Max	60	°C
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	Oil Temp Present	28	°C
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	Totalizer Meter Reading	1.0674	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	Winding Temp Max	50	°C
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	Winding Temp Present	35	°C
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Patrol Inspection	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	General Comments		
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Patrol Inspection	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Bushing Condition	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Amps C Ø	204.0	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Amps B Ø	285.0	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Amps A Ø	247.0	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	9 Month Operations	1	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Unknown Operations	0	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Switching Operations	0	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Operations This Read Vac	0	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Operations Counter AL	208	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Operations Counter AF	208	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Maintenance Operations	0	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Grounds in Place?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	General Comments		
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	General Comments		
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Foundation Condition	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Follow-up Action Required?	n	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Fault Operations Ground	0	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Fault Operations C Ø	0	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Fault Operations B Ø	0	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Fault Operations A Ø	0	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Bushing Condition	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Amps C Ø	0.0	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Amps B Ø	0.0	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Amps A Ø	0.0	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	General Comments	tower leg foundations crumbling, as well as transformer	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	LTCC000616	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	LTCC000616	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	LTCC000616	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	LTCC000616	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	LTCC000616	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	LTCC000616	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Unknown Operations	0	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Switching Operations	0	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Operations This Read Vac	0	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	LTCC000616	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	LTCC000616	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Operations Counter AL	187	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Operations Counter AF	187	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Grounds in Place?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	General Comments		
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	General Comments		
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Foundation Condition	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Follow-up Action Required?	n	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Fault Operations Ground	0	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Fault Operations C Ø	0	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Fault Operations B Ø	0	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Fault Operations A Ø	0	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	General Comments		
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Max Tap Position	5R	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Min Tap Position	12L	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.3	volts
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Regulator As Left Counter	60509	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Unknown Operations	0	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Switching Operations	0	
12/10/2020 14:04	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	General Comments		
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	General Comments	Trans needs nitrogen	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	30	°C
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	30	°C
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	Oil Temp Max	50	°C
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	9 Month Operations	1	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Bushing Condition	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Amps C Ø	212.0	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Amps B Ø	274.0	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Amps A Ø	248.0	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	9 Month Operations	5	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	LTCC000731	LTCControl	570-1	LTC Control Insp	All Connections OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	LTCC000731	LTCControl	570-1	LTC Control Insp	Follow-up Action Required?	n	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	LTCC000731	LTCControl	570-1	LTC Control Insp	General Comments		
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	LTCC000731	LTCControl	570-1	LTC Control Insp	LTC Operation Checked?	n	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	LTCC000731	LTCControl	570-1	LTC Control Insp	LTC Output Voltage Level	124.6	VAC
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	LTCC000731	LTCControl	570-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	LTCC000731	LTCControl	570-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	LTCC000731	LTCControl	570-1	LTC Control Insp	VRR Time Delay	60	Seconds
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	General Comments		
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Max Tap Position	5R	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Regulator As Left Counter	35298	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	General Comments		
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Fault Operations A Ø	0	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Fault Operations B Ø	0	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Fault Operations C Ø	0	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Fault Operations Ground	0	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Follow-up Action Required?	n	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Foundation Condition	Good	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	General Comments		
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	General Comments		
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Grounds in Place?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Maintenance Operations	0	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Operations Counter AF	166	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Operations Counter AL	166	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Operations This Read Vac	0	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Switching Operations	0	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Unknown Operations	0	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	9 Month Operations	4	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Amps A Ø	100.0	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Amps B Ø	102.0	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Amps C Ø	87.0	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Bushing Condition	Good	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	82	°F
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Fault Operations C Ø	0	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Fault Operations Ground	0	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Follow-up Action Required?	n	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Foundation Condition	Good	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	General Comments		
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	General Comments		
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Grounds in Place?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Maintenance Operations	0	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Operations Counter AF	169	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Operations Counter AL	169	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Operations This Read Vac	0	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Switching Operations	0	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Unknown Operations	0	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	9 Month Operations	5	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Amps A Ø	23.0	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Amps B Ø	19.0	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Amps C Ø	10.0	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Bushing Condition	Good	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	22	°C
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	42	°C
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	22	°C
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	41	°C
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	22	°C
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	41	°C
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	Oil Temp Present	21	°C
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	Oil Temp Max	41	°C
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1650	psi
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	9 Month Operations	5	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Unknown Operations	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Tank Paint Condition	Good	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Switching Operations	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Operations This Read Vac	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Operations Counter AL	7	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Operations Counter AF	7	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Maintenance Operations	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Heaters (All) Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Grounds in Place?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	General Comments		
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	General Comments		
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Foundation Condition	Good	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Follow-up Action Required?	n	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Fault Operations Ground	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Fault Operations C Ø	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Fault Operations B Ø	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Fault Operations A Ø	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Bushing Condition	Good	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Amps C Ø	165.0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Amps B Ø	190.0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Amps A Ø	180.0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	9 Month Operations	0	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	Neutral	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	BCH001323	Charger	494-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	BCH001323	Charger	494-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Fault Operations A Ø	0	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Fault Operations B Ø	0	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Fault Operations C Ø	0	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Fault Operations Ground	0	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Follow-up Action Required?	n	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Foundation Condition	Good	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	General Comments		
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	General Comments		
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Grounds in Place?	y	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Maintenance Operations	0	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Operations Counter AF	170	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Operations Counter AL	170	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	General Comments		
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Positive DC Ground	22.6	VDC
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Operations This Read Vac	0	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Switching Operations	0	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Unknown Operations	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Bushing Condition	Good	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Amps C Ø	100.0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Amps B Ø	160.0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Amps A Ø	120.0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Amps B Ø	208.0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Amps A Ø	223.0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	9 Month Operations	14	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Tank Paint Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Grounds in Place?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Foundation Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Bushing Condition	Good	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	General Comments		
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Mechanism Patrol Inspection	General Comments	Replaced Desiccant	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	LTC As Found Counter	116022	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	LTC As Left Counter	116022	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	LTC Current Tap Position	11L	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Unknown Operations	0	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Switching Operations	0	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Operations This Read Vac	0	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Operations Counter AL	182	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Operations Counter AF	182	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Maintenance Operations	0	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Grounds in Place?	y	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	General Comments		
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	General Comments		
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Foundation Condition	Good	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Follow-up Action Required?	n	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Fault Operations Ground	0	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Fault Operations C Ø	0	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Fault Operations B Ø	0	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Fault Operations A Ø	0	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Bushing Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Tank Paint Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Grounds in Place?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Foundation Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Bushing Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Tank Paint Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Grounds in Place?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Foundation Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Patrol Inspection	Bushing Condition	Good	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Unknown Operations	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Switching Operations	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Operations This Read Vac	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Operations Counter AL	611	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Operations Counter AF	611	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Maintenance Operations	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	General Comments	Actual counter	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Patrol Inspection	General Comments		
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Follow-up Action Required?	n	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Fault Operations Ground	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Fault Operations C Ø	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Fault Operations B Ø	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Fault Operations A Ø	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Amps C Ø	217.0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Bushing Condition	Good	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Amps C Ø	459.0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Amps B Ø	533.0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Amps A Ø	513.0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	9 Month Operations	2	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Unknown Operations	1	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Tank Paint Condition	Good	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Switching Operations	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Operations This Read Vac	1	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Operations Counter AL	28	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Operations Counter AF	28	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Maintenance Operations	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Grounds in Place?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	General Comments	IOC C Phase	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	General Comments		
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Foundation Condition	Good	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Follow-up Action Required?	n	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Fault Operations Ground	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Fault Operations C Ø	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Fault Operations B Ø	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Fault Operations A Ø	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	9 Month Operations	4	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Amps A Ø	66.0	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Amps B Ø	92.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Amps C Ø	80.0	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Bushing Condition	Good	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Fault Operations A Ø	0	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Fault Operations B Ø	0	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Bushing Condition	Good	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Amps C Ø	137.0	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Amps B Ø	142.0	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Amps A Ø	130.0	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	9 Month Operations	1	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LTCC000533	LTCControl	CR-TRANS 2-B	LTC Control Insp	General Comments		
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LTCC000533	LTCControl	CR-TRANS 2-B	LTC Control Insp	Follow-up Action Required?	n	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LTCC000533	LTCControl	CR-TRANS 2-B	LTC Control Insp	All Connections OK?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Unknown Operations	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Tank Paint Condition	Good	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Switching Operations	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Operations This Read Vac	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Operations Counter AL	68	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Operations Counter AF	68	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Maintenance Operations	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Grounds in Place?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	LTC Max Tap Position	6L	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	LTC Min Tap Position	13L	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	577	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	General Comments	HSI C phase	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	General Comments		
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Foundation Condition	Good	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Fault Operations Ground	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Bushing Condition	Good	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Max Tap Position	6R	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.3	VDC
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.8	VDC
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	General Comments		
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	55	*F
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Regulator As Left Counter	62203	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	General Comments		
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Follow-up Action Required?	n	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	9 Month Operations	4	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Amps A Ø	391.0	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Amps B Ø	401.0	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Amps C Ø	389.0	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Bushing Condition	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Foundation Condition	Good	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Follow-up Action Required?	n	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Follow-up Action Required?	n	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Fault Operations Ground	0	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Fault Operations C Ø	0	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Fault Operations B Ø	0	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Fault Operations A Ø	0	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	9 Month Operations	2	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Amps A Ø	130.0	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Amps B Ø	150.0	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Amps C Ø	145.0	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Bushing Condition	Good	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Fault Operations A Ø	0	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Fault Operations B Ø	0	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Fault Operations Ground	0	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Regulator As Left Counter	48604	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	General Comments		
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	LTC Current Tap Position	7L	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	LTC Max Tap Position	4R	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	LTC Min Tap Position	16L	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	LTC Operations Since Last Insp	1384	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Fault Operations A Ø	0	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Fault Operations B Ø	0	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Fault Operations C Ø	0	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.3	volts
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Regulator As Left Counter	62576	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	9 Month Operations	16	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Amps A Ø	120.0	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Amps B Ø	122.0	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Amps C Ø	119.0	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Ambient Temp	64	*F
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	General Comments		
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Vegetation	None	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Fault Operations Ground	0	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Follow-up Action Required?	n	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Foundation Condition	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	General Comments		
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Foundation Condition	Good	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	General Comments		
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	General Comments	BFTC	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Grounds in Place?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Maintenance Operations	0	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Operations Counter AF	185	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Bushing Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Foundation Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Grounds in Place?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Operations Counter AL	186	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Operations This Read Vac	2	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Switching Operations	2	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Unknown Operations	0	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Max Tap Position	9R	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Tank Paint Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Bushing Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Foundation Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Grounds in Place?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	Follow-up Action Required?	n	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	General Comments		
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Mechanism Patrol Inspection	General Comments		
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	LTC As Found Counter	199221	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	LTC As Left Counter	199233	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	General Comments		
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Vegetation	None	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Evidence of Insects	None	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	General Comments		
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	9 Month Operations	4	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Amps A Ø	100.0	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Amps B Ø	125.0	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Amps C Ø	110.0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	General Comments		
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Operations Counter	25	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	BCH001421	Charger	423-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	BCH001421	Charger	423-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	BCH001421	Charger	423-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	BCH001421	Charger	423-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	BCH001421	Charger	423-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.0	amps
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	BCH001421	Charger	423-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	BCH001421	Charger	423-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	BCH001421	Charger	423-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Panels Dusted?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Evidence of Insects	None	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Operations This Read Vac	0	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Switching Operations	0	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Unknown Operations	0	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	General Comments		
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Max Tap Position	8R	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Min Tap Position	13L	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Regulator As Left Counter	63186	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	General Comments		
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Regulator As Left Counter	68864	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Unknown Operations	0	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Switching Operations	1	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Operations This Read Vac	6	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Operations Counter AL	245	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Operations Counter AF	245	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Maintenance Operations	5	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Grounds in Place?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	General Comments		
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	General Comments		
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Panels Dusted?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	General Comments		
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Interrupters/Puffrs Visual OK?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Bushing Condition	Good	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Fault Operations A Ø	0	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Fault Operations B Ø	0	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Fault Operations C Ø	0	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Fault Operations Ground	0	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Follow-up Action Required?	n	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Foundation Condition	Good	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	General Comments		
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	General Comments		
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Grounds in Place?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Maintenance Operations	0	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Operations Counter AF	221	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Operations Counter AL	221	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Unknown Operations	0	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Switching Operations	2	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Operations This Read Vac	2	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Operations Counter AL	208	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Operations Counter AF	207	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	General Comments		
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	General Comments		
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Maintenance Operations	0	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	LTC Totalizer Reading	9345.60	kw
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	Oil Temp Max	102	°C
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	Oil Temp Present	48	°C
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Grounds in Place?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	General Comments		
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	General Comments		
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Foundation Condition	Good	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Follow-up Action Required?	n	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Fault Operations Ground	0	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Fault Operations B Ø	0	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Fault Operations A Ø	0	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Bushing Condition	Good	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Amps C Ø	140.0	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Amps B Ø	136.0	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Amps A Ø	150.0	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	9 Month Operations	3	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Foundation Condition	Good	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Fault Operations A Ø	0	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Fault Operations B Ø	0	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Fault Operations C Ø	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Fault Operations Ground	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Amps C Ø	393.0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Amps B Ø	420.0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Amps A Ø	483.0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	9 Month Operations	2	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Fault Operations Ground	0	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	Follow-up Action Required?	n	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	General Comments		
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Mechanism Patrol Inspection	General Comments		
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	LTC As Found Counter	233695	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	LTC As Left Counter	233698	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	LTC Current Tap Position	1L	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	LTC Min Tap Position	4L	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	LTC Operations Since Last Insp	134	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Follow-up Action Required?	n	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Foundation Condition	Good	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	General Comments		
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	General Comments		
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Grounds in Place?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Maintenance Operations	0	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Trash Emptied?	n	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	General Comments	light switch in control house is not working	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Floor Swept?	n	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Control House Lighting OK?	n	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Broom on Site?	n	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Patrol Inspection	General Comments		
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	0	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	240.0	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	300.0	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	240.0	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Unknown Operations	0	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Switching Operations	0	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Operations This Read Vac	0	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Operations Counter AL	225	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Operations Counter AF	225	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Grounds in Place?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Radiator Leaks	None	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Tank Leaks	None	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	Totalizer Meter Reading	1.2980	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	245.00	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	702	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	702	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Patrol Inspection	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	General Comments		
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	Totalizer Meter Reading	.9606	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	Oil Temp Present	30	°C
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	Oil Temp Max	60	°C
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	LTC Totalizer Reading	4610.88	kw
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	General Comments		
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	General Comments		
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Grounds in Place?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Maintenance Operations	0	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	General Comments		
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Operations Counter AF	243	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Operations Counter AL	243	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Operations This Read Vac	0	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Switching Operations	0	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Unknown Operations	0	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	General Comments	A couple of trees are starting to have some limbs to grow over the top of the fence line at the back of the station.	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Ambient Temp	63	*F
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Bushing Condition	Good	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/10/2020 13:19	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	General Comments	2 blown LA on A and B phase....one structure leg foundation is crumbling and another is starting to	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	Winding Temp Present	30	*C
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	Winding Temp Max	45	*C
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	Totalizer Meter Reading	.5710	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	Oil Temp Present	25	°C
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	Oil Temp Max	35	°C
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	LTC Totalizer Reading	10278.00	kw
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	General Comments		
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	General Comments		
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Unknown Operations	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Switching Operations	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Operations This Read Vac	0	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Operations Counter AL	168	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Operations Counter AF	168	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Maintenance Operations	0	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	General Comments		
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Patrol Inspection	General Comments		
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Amps C Ø	100.0	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Amps B Ø	50.0	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Amps A Ø	100.0	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	9 Month Operations	8	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Bushing Condition	Good	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/10/2020 12:50	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	General Comments		
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Vegetation	None	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/10/2020 15:45	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	Oil Temp Present	30	°C
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	Oil Temp Max	60	°C
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	General Comments		
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Fault Operations Ground	0	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Fault Operations C Ø	0	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Fault Operations B Ø	0	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Fault Operations A Ø	0	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Bushing Condition	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Amps C Ø	0.0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	BCH001350	Charger	868-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	BCH001350	Charger	868-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	BCH001350	Charger	868-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	BCH001350	Charger	868-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	BCH001350	Charger	868-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	BCH001350	Charger	868-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	BCH001350	Charger	868-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Amps B Ø	0.0	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Amps A Ø	0.0	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Patrol Inspection	General Comments		
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Operations Counter	113	
12/10/2020 13:34	Distribution	Somerset 3 Quarterly Inspection	BCH001350	Charger	868-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.400	millivolts
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	General Comments	open	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	General Comments		
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Unknown Operations	0	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	Bushing Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	Foundation Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	Grounds in Place?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Switching Operations	0	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Operations This Read Vac	0	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Operations Counter AL	134	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Operations Counter AF	134	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Patrol Inspection	General Comments		
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Maintenance Operations	0	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001669	BreakerVacuum	FV-1474	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Grounds in Place?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	General Comments		
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	General Comments		
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Foundation Condition	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Follow-up Action Required?	n	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	General Comments		
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/10/2020 13:13	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	Winding Temp Present	35	°C
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	Winding Temp Max	45	°C
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	Totalizer Meter Reading	.3774	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C ∅	0	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	22	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	22	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Amps A Ø	73.0	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Amps A Ø	0.0	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Amps B Ø	0.0	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Amps C Ø	0.0	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Oil Temp Present	15	°C
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Oil Temp Max	15	°C
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2780.64	kw
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	General Comments		
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	General Comments		
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	9 Month Operations	2	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Winding Temp Present	20	°C
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Winding Temp Max	20	°C
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.1586	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	9 Month Operations	1	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	Winding Temp Present	10	°C
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	Winding Temp Max	22	°C
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	Totalizer Meter Multiplier	0	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	Oil Temp Present	12	°C
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	Oil Temp Max	28	°C
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BCH001363	Charger	698-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	General Comments		
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	General Comments		
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	Follow-up Action Required?	n	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	537	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	31	°C
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	LTC Min Tap Position	14L	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	LTC Max Tap Position	4L	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	LTC Current Tap Position	10L	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	LTC As Left Counter	57202	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Amps C Ø	30.0	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Amps B Ø	49.0	
12/10/2020 10:13	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Amps A Ø	41.0	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Bushing Condition	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Bushing Oil Level	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Foundation Condition	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	General Comments		
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Grounds in Place?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Oil Temp Max	60	°C
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Radiator Leaks	None	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Tank Leaks	None	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	LT0272	GroundTransformer	CR-GND TRANS 1-A	Ground Transformer Patrol Inspection	Winding Temp Max	60	°C
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Ambient Temp	53	°F
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Unknown Operations	0	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Switching Operations	0	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Operations This Read Vac	0	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Operations Counter AL	281	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Operations Counter AF	281	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Maintenance Operations	0	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	General Comments		
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Max Tap Position	2L	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Grounds in Place?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	General Comments		
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	General Comments		
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Foundation Condition	Good	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Follow-up Action Required?	n	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/10/2020 12:53	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Fault Operations Ground	0	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Fault Operations C Ø	0	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Fault Operations B Ø	0	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Fault Operations A Ø	0	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.2	volts
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Regulator As Left Counter	46739	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Vegetation	None	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	Follow-up Action Required?	n	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	Foundation Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	Grounds in Place?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	PF001259	PowerFuse	CR-GEN EMERG STA SER	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	General Comments		
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Vegetation	None	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LTCC000360	LTCControl	FM-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LTCC000360	LTCControl	FM-TRANS 1	LTC Control Insp	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LTC000360	LTCControl	FM-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	PF001259	PowerFuse	CR-GEN EMERG STA SER	Disconnect Powerfuse Inspection	General Comments	NA	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	PF001260	PowerFuse	CR-GEN STA SER NO 1-A	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	PF001260	PowerFuse	CR-GEN STA SER NO 1-A	Disconnect Powerfuse Inspection	General Comments	NA	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BCH001356	Charger	605-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/10/2020 14:29	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LTO292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	LTC As Found Counter	57202	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LTO292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BCH001363	Charger	698-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BCH001363	Charger	698-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BCH001363	Charger	698-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BCH001363	Charger	698-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BCH001363	Charger	698-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BCH001363	Charger	698-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
12/10/2020 11:10	Distribution	Radcliff Quarterly Inspection	BCH001363	Charger	698-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Regulator As Left Counter	54418	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/10/2020 12:07	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BCH001356	Charger	605-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BCH001356	Charger	605-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BCH001356	Charger	605-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BCH001356	Charger	605-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BCH001356	Charger	605-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.3	amps
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BCH001356	Charger	605-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
12/10/2020 11:40	Distribution	Rogersville City Quarterly Inspection	BCH001356	Charger	605-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/14/2020 6:46	Distribution	Fairmount Quarterly Inspection	LTO292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	General Comments		
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/11/2020 13:29	Distribution	Fern Valley Quarterly Inspection	BK001668	BreakerVacuum	FV-1473	VCB Patrol Inspection	Bushing Condition	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/10/2020 14:18	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	C ∅ Operations Counter	259	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	A ∅ Operations Counter	329	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps A ∅	14.0	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps B ∅	27.3	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps C ∅	15.7	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	B ∅ Operations Counter	256	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 9:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	General Comments	ok	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	General Comments	ok	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Grounds in Place?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Maintenance Operations	0	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Operations Counter AF	198	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Operations Counter AL	198	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Operations This Read Vac	0	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	General Comments		
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Min Tap Position	12L	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	Follow-up Action Required?	n	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Foundation Condition	Good	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Follow-up Action Required?	n	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	General Comments	ok	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Max Tap Position	3L	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	General Comments		
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Mechanism Patrol Inspection	General Comments		
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Fault Operations A Ø	0	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Regulator As Left Counter	8771	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Fault Operations B Ø	0	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Fault Operations C Ø	0	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Fault Operations Ground	0	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Operations Ground	0	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Unknown Operations	0	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Follow-up Action Required?	n	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Patrol Inspection	General Comments		
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	General Comments		
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Maintenance Operations	0	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Operations Counter AF	520	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Operations Counter AL	520	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Operations This Read AM	0	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Switching Operations	0	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Unknown Operations	0	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Regulator As Left Counter	95248	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	General Comments		
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Fault Operations A Ø	0	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Fault Operations B Ø	0	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Fault Operations C Ø	0	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Fault Operations Ground	0	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Follow-up Action Required?	n	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Foundation Condition	Good	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	General Comments		
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	General Comments		
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Grounds in Place?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Maintenance Operations	0	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Operations Counter AF	233	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Operations Counter AL	233	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Operations This Read Vac	0	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Switching Operations	0	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	9 Months Operations	10	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Amps A Ø	200.0	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Amps B Ø	230.0	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Amps C Ø	260.0	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Operations A Ø	0	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Operations B Ø	0	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Operations C Ø	0	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	LTC Operations Since Last Insp	258	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	General Comments		
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Regulator As Left Counter	12679	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	55	*F
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	General Comments		
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	Negative DC Ground	22.9	VDC
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Unknown Operations	0	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Switching Operations	0	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	LTC Operations Since Last Insp	1148	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	LTC Min Tap Position	10L	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	LTC Max Tap Position	3L	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	LTC Current Tap Position	2L	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	LTC As Left Counter	94579	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	LTC As Found Counter	94568	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Vegetation	None	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	General Comments		
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Ambient Temp	54	*F
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	General Comments		
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	Follow-up Action Required?	n	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Mechanism Patrol Inspection	General Comments		
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	General Comments	Lower hand sluggish to reset	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	LTC As Found Counter	9546	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	LTC As Left Counter	9557	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	LTC Current Tap Position	3L	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	LTC Max Tap Position	1L	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	LTC Min Tap Position	7L	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	9 Month Operations	204	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	Follow-up Action Required?	n	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	General Comments		
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Mechanism Patrol Inspection	General Comments		
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	LTC As Found Counter	7930	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	LTC As Left Counter	7939	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	LTC Current Tap Position	4L	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Fault Operations A Ø	0	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	LTC Max Tap Position	1R	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	LTC Min Tap Position	8L	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	LTC Operations Since Last Insp	503	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Regulator As Left Counter	97891	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Fault Operations B Ø	0	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Fault Operations C Ø	0	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Fault Operations Ground	0	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Follow-up Action Required?	n	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Foundation Condition	Good	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	General Comments		
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	General Comments		
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Grounds in Place?	y	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Maintenance Operations	1	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Operations Counter AF	264	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Operations Counter AL	164	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Operations This Read Vac	1	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Regulator As Left Counter	145388	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Switching Operations	0	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Unknown Operations	0	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	9 Month Operations	2	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/9/2020 9:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/9/2020 9:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/9/2020 9:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Amps A Ø	50.0	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Amps B Ø	50.0	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Operations This Read Vac	0	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Switching Operations	0	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Unknown Operations	0	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Operations Counter AL	302	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	General Comments	barb wire rusty	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Operations Counter AF	302	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Maintenance Operations	0	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Grounds in Place?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	General Comments		
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	9 Month Operations	6	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Amps A Ø	130.0	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Amps B Ø	180.0	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Amps C Ø	250.0	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	General Comments		
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Foundation Condition	Good	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Follow-up Action Required?	n	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Fault Operations Ground	0	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Fault Operations C Ø	0	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Fault Operations B Ø	0	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Fault Operations A Ø	0	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Bushing Condition	Good	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Bushing Condition	Good	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Amps C Ø	150.0	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Amps B Ø	180.0	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Amps A Ø	170.0	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	General Comments	ok	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Max Tap Position	2L	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	General Comments		
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Operations Counter	305	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Regulator As Left Counter	8457	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Amps A Ø	92.0	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Amps B Ø	129.0	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Amps C Ø	83.0	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	General Comments	ok	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Regulator As Left Counter	8801	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	General Comments	ok	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Operations Counter	112	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Amps C Ø	55.0	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Bushing Condition	Good	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Unknown Operations	0	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Switching Operations	0	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Operations This Read Vac	0	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Operations Counter AL	175	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Operations Counter AF	175	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Maintenance Operations	0	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Grounds in Place?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	General Comments		
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	General Comments		
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Foundation Condition	Good	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Follow-up Action Required?	n	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Fault Operations Ground	0	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Fault Operations C Ø	0	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Fault Operations A Ø	0	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Min Tap Position	11L	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Bushing Condition	Good	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Amps C Ø	10.0	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	General Comments		
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Amps B Ø	0.0	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Amps A Ø	10.0	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	9 Month Operations	5	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Amps A Ø	12.0	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Amps B Ø	25.0	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Amps C Ø	14.0	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	Oil Temp Present	25	°C
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	75.00	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	60	°C
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	30	°C
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	60	°C
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	30	°C
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	15008	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Unknown Operations	0	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Switching Operations	0	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Operations This Read Vac	0	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Operations Counter AL	182	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Operations Counter AF	182	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Maintenance Operations	0	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	General Comments		
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	General Comments		
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Foundation Condition	Good	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Follow-up Action Required?	n	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Fault Operations Ground	0	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Fault Operations C Ø	0	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Fault Operations B Ø	0	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Fault Operations A Ø	0	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Bushing Condition	Good	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Amps C Ø	14.0	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Amps B Ø	15.0	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Amps A Ø	16.0	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	9 Month Operations	2	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BCH001439	Charger	866-Battery Charger 1	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BCH001439	Charger	866-Battery Charger 1	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	Positive DC Ground	27.5	VDC
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	Negative DC Ground	27.5	VDC
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	General Comments		
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	Battery Overall Condition	Good	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	Battery Area Ambient Temp	50	*F
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	All Connections OK?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	9 Month Operations	2	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Amps A Ø	287.0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Amps B Ø	294.0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Amps C Ø	291.0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Bushing Condition	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	General Comments		
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Max	-20	MegaVars
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Min	-40	MegaVars
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Max	.80	MegaWatts
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Min	.30	MegaWatts
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	Oil Temp Max	50	°C
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Fault Operations A Ø	0	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Fault Operations B Ø	0	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Fault Operations C Ø	0	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Fault Operations Ground	0	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Follow-up Action Required?	n	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Foundation Condition	Good	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	General Comments		
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Grounds in Place?	y	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Maintenance Operations	0	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Operations Counter AF	163	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Operations Counter AL	163	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Operations This Read Vac	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	134	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	134	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Operations Counter AF	406	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Operations Counter AL	406	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Operations This Read Vac	0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Switching Operations	0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Unknown Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	.86	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	.86	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	.86	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	2	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Switching Operations	0	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Unknown Operations	0	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	7L	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	1L	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments		
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	3L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Fault Operations A Ø	0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Fault Operations B Ø	0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Fault Operations C Ø	0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Fault Operations Ground	0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Follow-up Action Required?	n	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	166	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	166	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	General Comments		
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	90.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	90.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	90.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	1.72	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	1.72	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	1.72	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	3	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	9 Month Operations	2	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Grounds in Place?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Maintenance Operations	0	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Amps A Ø	65.0	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Amps B Ø	105.0	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Amps C Ø	75.0	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Bushing Condition	Good	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Arching Horns Good Condition?	y	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Free of Audible Arching?	y	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	General Comments		
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	General Comments	Barbed wire needs grounding	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	General Comments		
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Readings	General Comments		
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	205.00	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	200.00	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Readings	Oil Temp Max	35	°C
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Readings	Oil Temp Present	25	°C
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	General Comments	There are three small washouts in back corner on same side as gate.	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Vegetation	None	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	General Comments	ok	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	General Comments		
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Ambient Temp	58	°F
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	General Comments	SPR no longer in station	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Vegetation	None	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	LTC Operations Since Last Insp	1163	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	LTC Min Tap Position	13L	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	LTC Current Tap Position	9L	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	LTC As Left Counter	199709	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	LTC As Found Counter	199701	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Mechanism Patrol Inspection	General Comments		
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	General Comments		
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	Follow-up Action Required?	n	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	General Comments		
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Vegetation	None	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BCH001439	Charger	866-Battery Charger 1	Battery Charger Patrol Insp	General Comments		
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BCH001439	Charger	866-Battery Charger 1	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	27.7	VDC
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	29.0	VDC
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	58	*F
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	General Comments		
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	BCH001143	Charger	410-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	BCH001143	Charger	410-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	BCH001143	Charger	410-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	BCH001143	Charger	410-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	56.7	VDC
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	BCH001143	Charger	410-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	56.7	VDC
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Ambient Temp	57	°F
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	General Comments	lightening arrestors have come lose at the chance clamp 4618 circuit	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Readings	Oil Temp Present	25	°C
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Readings	Oil Temp Max	42	°C
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Readings	General Comments		
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	General Comments		
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	General Comments	counter not working	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Reg Operation Checked?	n	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Regulator As Left Counter	426763	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	General Comments	Heater wasnt working. Has been fixed.	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Exp/Missing Not Repl	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	35	*F
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	General Comments		
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	9 Month Operations	0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Amps A Ø	480.0	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	9 Month Operations	2	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Amps B Ø	430.0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Amps C Ø	467.0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Bushing Condition	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Readings	Oil Temp Present	8	°C
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Readings	Oil Temp Max	25	°C
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	55.00	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	60.00	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Readings	General Comments		
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Patrol Inspection	General Comments		
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Operations Counter AL	159	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Operations This Read Vac	0	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Switching Operations	0	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Unknown Operations	0	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	9 Month Operations	2	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Unknown Operations	0	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Switching Operations	0	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Operations This Read Vac	0	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Operations Counter AL	166	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Operations Counter AF	166	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Maintenance Operations	0	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Grounds in Place?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	General Comments		
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	General Comments		
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Foundation Condition	Good	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Follow-up Action Required?	n	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Fault Operations Ground	0	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Fault Operations C Ø	0	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Fault Operations A Ø	0	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Bushing Condition	Good	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Amps C Ø	67.0	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Amps B Ø	38.0	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Amps A Ø	40.0	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Winding Temp Max	30	°C
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6018	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3600	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Oil Temp Max	28	°C
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2166.48	kw
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	General Comments	ok	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	General Comments		
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	9 Month Operations	0	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Amps A Ø	100.0	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Amps B Ø	70.0	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Amps C Ø	80.0	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Bushing Condition	Good	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Max Tap Position	4R	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Min Tap Position	4L	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Fault Operations A Ø	0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Fault Operations B Ø	0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Fault Operations C Ø	0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Fault Operations Ground	0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Follow-up Action Required?	n	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Foundation Condition	Good	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	LTCC000750	LTCControl	665-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	LTCC000750	LTCControl	665-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	LTCC000750	LTCControl	665-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	General Comments		
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	General Comments		
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Grounds in Place?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Maintenance Operations	0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Operations Counter AF	143	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Operations Counter AL	143	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Operations This Read Vac	0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Switching Operations	0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Unknown Operations	0	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	LTCC000750	LTCControl	665-1	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	LTCC000750	LTCControl	665-1	LTC Control Insp	LTC Operation Checked?	y	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	LTCC000750	LTCControl	665-1	LTC Control Insp	General Comments		
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	LTCC000750	LTCControl	665-1	LTC Control Insp	Follow-up Action Required?	n	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	LTCC000750	LTCControl	665-1	LTC Control Insp	All Connections OK?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Max Tap Position	8R	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Regulator As Left Counter	5649	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Winding Temp Present	21	°C
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Regulator As Left Counter	28489	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Current Tap Position	9L	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	General Comments	ok	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Max Tap Position	6R	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Min Tap Position	16L	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Regulator As Left Counter	28377	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Unknown Operations	0	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Switching Operations	0	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Operations This Read Vac	0	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Operations Counter AL	162	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Operations Counter AF	162	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Maintenance Operations	0	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Grounds in Place?	y	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	General Comments		
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	General Comments		
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Foundation Condition	Good	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Follow-up Action Required?	n	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Fault Operations Ground	0	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Fault Operations C ∅	0	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Fault Operations B ∅	0	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Fault Operations A ∅	0	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Current Tap Position	9L	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	155	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	155	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C ∅	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B ∅	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A ∅	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C ∅	40.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B ∅	50.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A ∅	50.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	1.72	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	1.72	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	1.72	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	3	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Unknown Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Switching Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Operations This Read AM	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Operations Counter AL	273	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Operations Counter AF	273	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Maintenance Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Fault Operations Ground	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Fault Operations C ∅	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Fault Operations B ∅	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Fault Operations A ∅	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Amps C ∅	200.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Amps B ∅	220.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Amps A ∅	210.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	.47	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	.47	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	.47	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	9 Months Operations	1	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	General Comments	ok	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Max Tap Position	8L	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Min Tap Position	16L	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Amps A ∅	38.0	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	9 Month Operations	4	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Amps A ∅	0.0	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Amps B ∅	0.0	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Amps C ∅	0.0	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Bushing Condition	Good	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Fault Operations A ∅	0	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Fault Operations B ∅	0	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Fault Operations A ∅	0	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Fault Operations B ∅	0	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Fault Operations C ∅	0	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Fault Operations Ground	0	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Follow-up Action Required?	n	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Foundation Condition	Good	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	General Comments		
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	General Comments		
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Grounds in Place?	y	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Maintenance Operations	0	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Operations Counter AF	178	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Operations Counter AL	178	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Operations This Read Vac	0	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Switching Operations	0	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Unknown Operations	0	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Fault Operations C ∅	0	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Fault Operations Ground	0	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Follow-up Action Required?	n	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Foundation Condition	Good	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	General Comments	breaker is open	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	General Comments	ok	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Grounds in Place?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Maintenance Operations	0	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Operations Counter AF	159	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Bushing Condition	Good	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Amps C Ø	71.0	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Amps B Ø	91.0	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Amps A Ø	73.0	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	9 Month Operations	2	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Amps A Ø	25.0	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Amps B Ø	35.0	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Amps C Ø	30.0	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Bushing Condition	Good	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	9 Month Operations	2	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Unknown Operations	0	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Switching Operations	0	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Operations This Read Vac	0	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Operations Counter AL	175	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Operations Counter AF	175	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Maintenance Operations	0	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Grounds in Place?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	General Comments		
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	General Comments		
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Foundation Condition	Good	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Follow-up Action Required?	n	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Fault Operations Ground	0	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Fault Operations C Ø	0	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Fault Operations B Ø	0	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Fault Operations A Ø	0	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Bushing Condition	Good	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Amps C Ø	33.0	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Amps B Ø	38.0	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments	Lower arm would not reset	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	Totalizer Meter Reading	.5406	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	Oil Temp Present	30	°C
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	Oil Temp Max	55	°C
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-5	psi
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	LTC Totalizer Reading	5189.76	kw
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	General Comments		
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	General Comments		
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Regulator As Left Counter	10002	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Max Tap Position	2L	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	General Comments		
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	LTC Operations Since Last Insp	993	
12/9/2020 11:28	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	LTC Min Tap Position	10L	
12/9/2020 11:28	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	LTC Max Tap Position	Neutral	
12/9/2020 11:28	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	LTC Current Tap Position	4L	
12/9/2020 11:28	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	LTC As Left Counter	300788	
12/9/2020 11:28	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	LTC As Found Counter	300779	
12/9/2020 11:28	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Mechanism Patrol Inspection	General Comments		
12/9/2020 11:28	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	General Comments		
12/9/2020 11:28	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 11:28	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	Follow-up Action Required?	n	
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Bushing Condition	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Amps C Ø	551.0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Amps B Ø	525.0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Amps A Ø	567.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	303	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	303	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	2	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	2.58	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	2.58	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	2.58	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments	Cascade is showing 1 more operation then breaker. Breaker reads 161.	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	161	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	161	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Regulator As Left Counter	10501	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	1244.0	volts
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Max Tap Position	1L	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	General Comments		
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	1L	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	5L	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	96075	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	2	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	15.46	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	17.18	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	18.9	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	120.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	115.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	113.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Regulator As Left Counter	178007	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	General Comments		
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	LTCC000877	LTCControl	721-1	LTC Control Insp	VRR Time Delay	60	Seconds
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Regulator As Left Counter	33581	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Max Tap Position	5L	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	General Comments		
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Current Tap Position	7L	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	Follow-up Action Required?	n	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	General Comments		
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Mechanism Patrol Inspection	General Comments		
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	LTC As Found Counter	24514	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	LTC As Left Counter	24514	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	LTC Current Tap Position	Neutral	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	LTC Max Tap Position	Neutral	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	LTC Min Tap Position	6L	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	LTC Operations Since Last Insp	476	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AF	1878	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AL	1878	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations This Read AM	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Switching Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Unknown Operations	0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Switching Operations	1	
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Operations This Read Vac	1	
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Operations Counter AL	253	
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Operations Counter AF	253	
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Unknown Operations	0	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Switching Operations	0	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Operations This Read AM	0	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Operations Counter AL	3	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Operations Counter AF	3	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Maintenance Operations	0	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	General Comments		
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Patrol Inspection	General Comments		
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Follow-up Action Required?	n	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	General Comments		
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	Follow-up Action Required?	n	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	LTC As Found Counter	8959	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	LTC As Left Counter	8971	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	LTC Current Tap Position	3L	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	LTC Min Tap Position	7L	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	LTC Operations Since Last Insp	380	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	5.43	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	5.43	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	5.43	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps A Ø	0.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps B Ø	0.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps C Ø	0.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	LTCC000893	LTCControl	566-1	LTC Control Insp	VRR Time Delay	60	Seconds
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	LTCC000893	LTCControl	566-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	LTCC000893	LTCControl	566-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	LTCC000893	LTCControl	566-1	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	LTCC000893	LTCControl	566-1	LTC Control Insp	LTC Operation Checked?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	LTCC000893	LTCControl	566-1	LTC Control Insp	General Comments		
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	LTCC000893	LTCControl	566-1	LTC Control Insp	Follow-up Action Required?	n	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	LTCC000893	LTCControl	566-1	LTC Control Insp	All Connections OK?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	LTCC000892	LTCControl	566-2	LTC Control Insp	VRR Time Delay	30	Seconds
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	LTCC000892	LTCControl	566-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Min Tap Position	12L	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Max Tap Position	6L	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	General Comments		
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Current Tap Position	8L	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	LTCC000877	LTCControl	721-1	LTC Control Insp	All Connections OK?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	LTCC000877	LTCControl	721-1	LTC Control Insp	Follow-up Action Required?	n	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	LTCC000877	LTCControl	721-1	LTC Control Insp	General Comments		
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	LTCC000892	LTCControl	566-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	LTCC000892	LTCControl	566-2	LTC Control Insp	LTC Output Voltage Level	124.3	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	LTCC000892	LTCControl	566-2	LTC Control Insp	LTC Operation Checked?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	LTCC000892	LTCControl	566-2	LTC Control Insp	General Comments		
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	LTCC000892	LTCControl	566-2	LTC Control Insp	Follow-up Action Required?	n	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	LTCC000892	LTCControl	566-2	LTC Control Insp	All Connections OK?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	LTCC000877	LTCControl	721-1	LTC Control Insp	LTC Operation Checked?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	LTCC000877	LTCControl	721-1	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	LTCC000877	LTCControl	721-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	LTCC000877	LTCControl	721-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	LTCC000877	LTCControl	721-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	LTCC000380	LTCControl	175-5	LTC Control Insp	LTC Operation Checked?	y	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	LTCC000380	LTCControl	175-5	LTC Control Insp	General Comments		
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	LTCC000380	LTCControl	175-5	LTC Control Insp	Follow-up Action Required?	n	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	LTCC000380	LTCControl	175-5	LTC Control Insp	All Connections OK?	y	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	RC000348	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	RC000348	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	45.0	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	RC000348	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	28.0	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	RC000348	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	40.0	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	156	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Amps A Ø	30.7	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Amps B Ø	36.1	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Amps C Ø	30.4	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	171	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	9 Months Operations	13	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Accumulated Fault Duty A Ph AM	2.24	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Accumulated Fault Duty B Ph AM	2.24	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Accumulated Fault Duty C Ph AM	2.24	%
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	9225.60	kw
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Oil Temp Max	53	°C
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Amps A Ø	90.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Amps B Ø	125.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Amps C Ø	120.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Fault Operations A Ø	0	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Oil Temp Present	48	°C
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9610	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Winding Temp Max	60	°C
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Winding Temp Present	60	°C
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Fault Operations B Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Fault Operations C Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Fault Operations Ground	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	General Comments	.	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Maintenance Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Operations Counter AF	594	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Operations Counter AL	594	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Operations This Read AM	1	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Switching Operations	1	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Unknown Operations	0	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	120	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	General Comments	recloser needs wildlife protection	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Adequate	
12/9/2020 11:28	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/9/2020 11:28	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Operations Ground	0	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Operations C Ø	0	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Operations B Ø	0	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Operations A Ø	0	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Amps C Ø	200.0	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Amps B Ø	230.0	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Amps A Ø	240.0	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	9 Months Operations	1	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	RC000348	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	RC000348	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	RC000348	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	233	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	RC000348	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	RC000348	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	RC000348	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	RC000348	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	General Comments		
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	General Comments		
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Maintenance Operations	0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Grounds in Place?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	General Comments		
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	General Comments		
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Foundation Condition	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Follow-up Action Required?	n	
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Fault Operations Ground	0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Fault Operations C Ø	0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Fault Operations B Ø	0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Fault Operations A Ø	0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	RC000348	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	RC000348	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	LTCC000380	LTCControl	175-5	LTC Control Insp	VRR Time Delay	30	Seconds
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	LTCC000380	LTCControl	175-5	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	LTCC000380	LTCControl	175-5	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	LTCC000380	LTCControl	175-5	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Broom on Site?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Floor Swept?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	General Comments		
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	MegaVar Demand Meter Max	0.00	MegaVars
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	MegaVar Demand Meter Min	-.20	MegaVars
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	MegaWatt Demand Meter Max	2.10	MegaWatts
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	MegaWatt Demand Meter Min	.20	MegaWatts
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	Oil Temp Max	45	°C
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	Oil Temp Present	20	°C
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	200.00	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	General Comments		
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Trash Emptied?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	General Comments		
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	General Comments		
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	General Comments		
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2108.16	kw
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	Oil Temp Max	35	°C
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4392	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	42	°F
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	General Comments		
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	9 Months Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Accumulated Fault Duty A Ph AM	2.41	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Accumulated Fault Duty B Ph AM	1.2	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Accumulated Fault Duty C Ph AM	20.48	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Amps A Ø	260.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Amps B Ø	245.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Amps C Ø	250.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Fault Operations A Ø	0	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Negative DC Ground	.1	VDC
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Positive DC Ground	.1	VDC
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Fault Operations B Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Fault Operations C Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Fault Operations Ground	0	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9660	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	Oil Temp Present	55	°C
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	Oil Temp Max	65	°C
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	70.00	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	9273.60	kw
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Readings	Oil Temp Max	55	°C
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Readings	Oil Temp Present	40	°C
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	9 Month Operations	6	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Acceptable Building Appearance?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Control House Lighting OK?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Evidence of Insects	None	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Floor Swept?	n	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	General Comments		
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Trash Emptied?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Amps A Ø	115.0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Unknown Operations	0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Switching Operations	1	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Operations This Read Vac	1	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Operations Counter AL	187	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Operations Counter AF	187	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Maintenance Operations	0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Grounds in Place?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	General Comments	BFTC	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	General Comments		
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Foundation Condition	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Follow-up Action Required?	n	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Fault Operations Ground	0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Fault Operations C Ø	0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Fault Operations B Ø	0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Fault Operations A Ø	0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Bushing Condition	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Amps C Ø	130.0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Amps B Ø	115.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Maintenance Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Operations Counter AF	314	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Operations Counter AL	314	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Operations This Read AM	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Switching Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Unknown Operations	0	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	General Comments		
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Readings	General Comments		
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	Totalizer Meter Reading	1.2080	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	Oil Temp Present	33	°C
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	Oil Temp Max	33	°C
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	LTC Totalizer Reading	11596.80	kw
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	General Comments		
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	General Comments		
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Fault Operations B Ø	0	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Fault Operations C Ø	0	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Fault Operations Ground	0	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	General Comments	ok	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Readings	General Comments	ok	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	117.50	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	110.00	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Readings	Oil Temp Max	52	°C
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Readings	Oil Temp Present	31	°C
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Follow-up Action Required?	n	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Foundation Condition	Good	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	General Comments		
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	General Comments		
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Grounds in Place?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Maintenance Operations	0	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Operations Counter AF	317	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Operations Counter AL	317	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Operations This Read Vac	0	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Switching Operations	0	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Unknown Operations	0	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	General Comments		
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	General Comments		
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	LTC Totalizer Reading	6243.84	kw
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	Oil Temp Max	50	°C
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	Oil Temp Present	45	°C
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	3	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	2.58	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	2.58	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	2.58	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	50.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	50.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	50.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	247	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	247	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	9 Months Operations	0	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Amps A Ø	0.0	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Amps B Ø	0.0	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Amps C Ø	0.0	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Fault Operations A Ø	0	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Fault Operations B Ø	0	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Fault Operations C Ø	0	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Fault Operations Ground	0	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Follow-up Action Required?	n	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Patrol Inspection	General Comments		
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	General Comments		
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Maintenance Operations	0	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Operations Counter AF	276	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Operations Counter AL	276	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Operations This Read AM	0	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Switching Operations	0	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Unknown Operations	0	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	9 Month Operations	5	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Amps A Ø	100.0	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Amps B Ø	175.0	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Amps C Ø	150.0	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Bushing Condition	Good	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Fault Operations A Ø	0	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Bushing Condition	Good	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Amps C Ø	60.0	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Amps B Ø	60.0	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BCH001348	Charger	566-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BCH001348	Charger	566-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BCH001348	Charger	566-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BCH001348	Charger	566-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BCH001348	Charger	566-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Amps A Ø	100.0	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	9 Month Operations	3	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BCH001348	Charger	566-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BCH001348	Charger	566-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BCH001348	Charger	566-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.900	millivolts
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Current Tap Position	1R	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	General Comments	ok	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BCH001344	Charger	370-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BCH001344	Charger	370-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BCH001344	Charger	370-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BCH001344	Charger	370-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.6	amps
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BCH001344	Charger	370-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BCH001344	Charger	370-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Mechanism Patrol Inspection	General Comments		
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	General Comments		
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	Follow-up Action Required?	n	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Regulator As Left Counter	63991	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	General Comments	ok	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	Totalizer Meter Reading	.6504	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	200.00	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	LTC Operations Since Last Insp	277	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	LTC Min Tap Position	5L	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	LTC Current Tap Position	2L	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	LTC As Left Counter	691147	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	LTC As Found Counter	691141	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Mechanism Patrol Inspection	General Comments		
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	General Comments		
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 11:28	Distribution	London Quarterly Inspection	LTCC000241	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
12/9/2020 11:28	Distribution	London Quarterly Inspection	LTCC000241	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/9/2020 11:28	Distribution	London Quarterly Inspection	LTCC000241	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/9/2020 11:28	Distribution	London Quarterly Inspection	LTCC000241	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
12/9/2020 11:28	Distribution	London Quarterly Inspection	LTCC000241	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	LTCC000241	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
12/9/2020 11:28	Distribution	London Quarterly Inspection	LTCC000241	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
12/9/2020 11:28	Distribution	London Quarterly Inspection	LTCC000241	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Unknown Operations	0	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Switching Operations	0	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Operations This Read Vac	0	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Operations Counter AL	220	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Operations Counter AF	220	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Maintenance Operations	0	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Grounds in Place?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	General Comments		
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	General Comments		
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Foundation Condition	Good	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Follow-up Action Required?	n	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Fault Operations Ground	0	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Fault Operations C Ø	0	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Fault Operations B Ø	0	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Fault Operations A Ø	0	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	Follow-up Action Required?	n	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	LTC Operations Since Last Insp	227	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	LTC Min Tap Position	10L	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	LTC Max Tap Position	4R	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	LTC Current Tap Position	2R	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	LTC As Left Counter	128164	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	LTC As Found Counter	128164	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	2L	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	10L	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	9 Month Operations	7	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	9 Month Operations	1	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Amps A Ø	12.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Amps B Ø	10.0	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Amps C Ø	10.0	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Bushing Condition	Good	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Fault Operations A Ø	0	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Fault Operations B Ø	0	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Fault Operations C Ø	0	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Fault Operations Ground	0	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	Totalizer Meter Reading	.4488	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	Oil Temp Present	25	°C
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	Oil Temp Max	60	°C
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	LTC Totalizer Reading	4308.48	kw
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	General Comments	top fan not working	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	General Comments	liquid temp wont reset	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Follow-up Action Required?	n	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Foundation Condition	Good	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	General Comments		
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-5	psi
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1447.20	kw
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6030	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Unknown Operations	0	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Switching Operations	0	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Operations This Read Vac	0	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Operations Counter AL	201	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Operations Counter AF	201	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Maintenance Operations	0	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Grounds in Place?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	General Comments		
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	General Comments		
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Foundation Condition	Good	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Follow-up Action Required?	n	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Fault Operations Ground	0	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Fault Operations C ∅	0	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Fault Operations B ∅	0	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Fault Operations A ∅	0	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Bushing Condition	Good	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Amps C ∅	81.0	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Amps B ∅	74.0	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Amps A ∅	78.0	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	9 Month Operations	2	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	6L	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	General Comments		
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	LTC000730	LTCControl	370-1	LTC Control Insp	All Connections OK?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	1.57	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	1.57	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	1.57	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A ∅	75.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B ∅	75.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C ∅	75.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A ∅	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B ∅	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C ∅	0	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	9 Month Operations	14	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Amps A ∅	360.0	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Amps B ∅	360.0	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Amps C ∅	360.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	General Comments		
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	General Comments		
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Maintenance Operations	0	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Operations Counter AF	258	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Operations Counter AL	270	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Operations This Read Vac	12	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Switching Operations	12	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Unknown Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	General Comments		
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	General Comments		
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Grounds in Place?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Maintenance Operations	0	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	LTCC000730	LTCControl	370-1	LTC Control Insp	VRR Time Delay	60	Seconds
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Operations Counter AF	201	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Operations Counter AL	201	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Operations This Read Vac	0	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Switching Operations	0	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Unknown Operations	0	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	LTCC000730	LTCControl	370-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	LTCC000730	LTCControl	370-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	72928	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Amps A Ø	10.0	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Amps B Ø	10.0	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Amps C Ø	10.0	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Bushing Condition	Good	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Fault Operations A Ø	0	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Fault Operations B Ø	0	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Fault Operations C Ø	0	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Follow-up Action Required?	n	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Foundation Condition	Good	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	General Comments		
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	General Comments	BFTC	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Grounds in Place?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Maintenance Operations	0	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Operations Counter AF	287	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Operations Counter AL	291	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Operations This Read Vac	4	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Switching Operations	4	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Unknown Operations	0	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	LTCC000730	LTCControl	370-1	LTC Control Insp	LTC Output Voltage Level	124.6	VAC
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	LTCC000730	LTCControl	370-1	LTC Control Insp	LTC Operation Checked?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	LTCC000730	LTCControl	370-1	LTC Control Insp	General Comments		
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	LTCC000730	LTCControl	370-1	LTC Control Insp	Follow-up Action Required?	n	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	General Comments		
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	40	*F
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	LTC Operations Since Last Insp	534	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	LTC Min Tap Position	12L	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	LTC Max Tap Position	4L	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	LTC Current Tap Position	7L	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	LTC As Left Counter	280053	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	LTC As Found Counter	280050	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Mechanism Patrol Inspection	General Comments		
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	Follow-up Action Required?	n	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	Follow-up Action Required?	n	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Unknown Operations	0	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Switching Operations	0	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Operations This Read Vac	0	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Operations Counter AL	190	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Operations Counter AF	190	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Maintenance Operations	0	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Grounds in Place?	y	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	General Comments		
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	General Comments		
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Foundation Condition	Good	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Follow-up Action Required?	n	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Fault Operations Ground	0	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Fault Operations C Ø	0	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Fault Operations B Ø	0	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Fault Operations A Ø	0	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Bushing Condition	Good	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Amps C Ø	72.0	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Amps B Ø	83.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Amps A Ø	78.0	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	9 Month Operations	2	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Unknown Operations	0	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Switching Operations	0	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Operations This Read Vac	0	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Operations Counter AL	174	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Operations Counter AF	174	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Maintenance Operations	0	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Grounds in Place?	y	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BCH001054	Charger	665-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.9	VDC
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BCH001054	Charger	665-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.9	VDC
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BCH001054	Charger	665-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BCH001054	Charger	665-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BCH001054	Charger	665-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BCH001054	Charger	665-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Regulator As Left Counter	11547	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	General Comments		
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	BCH001406	Charger	411-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	BCH001406	Charger	411-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	BCH001406	Charger	411-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	BCH001406	Charger	411-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	BCH001406	Charger	411-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	BCH001406	Charger	411-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	BCH001406	Charger	411-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	BCH001406	Charger	411-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.300	millivolts
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	58	*F
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	27.4	VDC
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	27.4	VDC
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	BCH001404	Charger	798-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	BCH001404	Charger	798-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	BCH001404	Charger	798-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	BCH001404	Charger	798-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	BCH001404	Charger	798-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	BCH001404	Charger	798-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	BCH001404	Charger	798-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	BCH001404	Charger	798-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	General Comments		
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Switching Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Unknown Operations	0	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Unknown Operations	0	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Switching Operations	0	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Operations This Read Vac	0	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Operations Counter AL	188	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Operations Counter AF	188	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Maintenance Operations	0	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Grounds in Place?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	General Comments		
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	General Comments		
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Foundation Condition	Good	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Follow-up Action Required?	n	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Fault Operations Ground	0	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Fault Operations C Ø	0	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Fault Operations B Ø	0	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Fault Operations A Ø	0	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Bushing Condition	Good	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Amps C Ø	117.0	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Amps B Ø	94.0	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Amps A Ø	69.0	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	9 Month Operations	2	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	General Comments		
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	General Comments		
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	General Comments		
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Foundation Condition	Good	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Follow-up Action Required?	n	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Fault Operations Ground	0	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Fault Operations C Ø	0	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Fault Operations B Ø	0	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Fault Operations A Ø	0	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Bushing Condition	Good	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Amps C Ø	76.0	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Amps B Ø	78.0	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Amps A Ø	65.0	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	9 Month Operations	2	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Regulator As Left Counter	11394	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	General Comments		
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	9 Months Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Accumulated Fault Duty B Ph AM	12.05	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Amps A Ø	135.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Amps B Ø	130.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Amps C Ø	130.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Fault Operations A Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Fault Operations B Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Fault Operations C Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Fault Operations Ground	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Maintenance Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Operations Counter AF	146	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Operations Counter AL	146	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Operations This Read AM	0	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Readings	Oil Temp Present	20	°C
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Readings	Oil Temp Max	20	°C
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Readings	General Comments	ok	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	General Comments	ok	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Regulator As Left Counter	201473	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	General Comments	ok	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	66111	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	14L	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	2L	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	General Comments		
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	6L	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Current Tap Position	7L	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	General Comments	ok	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Max Tap Position	6L	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Min Tap Position	12L	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Regulator As Left Counter	326262	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	9 Month Operations	1	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Amps A Ø	185.0	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Amps B Ø	202.0	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Amps C Ø	213.0	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Bushing Condition	Good	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Fault Operations A Ø	0	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Fault Operations B Ø	0	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Fault Operations C Ø	0	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Fault Operations Ground	0	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Follow-up Action Required?	n	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Foundation Condition	Good	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	General Comments		
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	General Comments	varmint guard hose has slipped down wire below line side disconnects	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Grounds in Place?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Maintenance Operations	0	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Operations Counter AF	251	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Operations Counter AL	251	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Operations This Read Vac	0	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Switching Operations	0	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Unknown Operations	0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 11:28	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	Follow-up Action Required?	n	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	LTC Operations Since Last Insp	1214	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	LTC Min Tap Position	9L	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Fault Operations A Ø	0	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Fault Operations B Ø	0	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Fault Operations C Ø	0	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Fault Operations Ground	0	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Follow-up Action Required?	n	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	LTC Max Tap Position	2R	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	LTC Current Tap Position	3L	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Foundation Condition	Good	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	General Comments		
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	General Comments		
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Grounds in Place?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Maintenance Operations	0	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Operations Counter AF	192	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Operations Counter AL	192	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Operations This Read Vac	1	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Switching Operations	1	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Unknown Operations	0	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Regulator As Left Counter	36086	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Max Tap Position	3L	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	General Comments		
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Current Tap Position	7L	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1322	Regulator	410-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Regulator As Left Counter	33039	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	Follow-up Action Required?	n	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	General Comments		
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Mechanism Patrol Inspection	General Comments		
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	LTC As Left Counter	167746	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	LTC As Found Counter	167736	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Mechanism Patrol Inspection	General Comments		
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	General Comments		
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	General Comments		
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	LTC Totalizer Reading	12441.60	kw
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	Oil Temp Max	55	°C
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	Oil Temp Present	50	°C
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	Totalizer Meter Reading	.8640	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	Winding Temp Max	42	°C
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	Winding Temp Present	31	°C
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	9 Month Operations	2	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Amps A Ø	377.0	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Amps B Ø	269.0	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Amps C Ø	272.0	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Bushing Condition	Good	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/9/2020 11:28	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	LTC Operations Since Last Insp	880	
12/9/2020 11:28	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	LTC Min Tap Position	7L	
12/9/2020 11:28	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	LTC Max Tap Position	9R	
12/9/2020 11:28	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	LTC Current Tap Position	Neutral	
12/9/2020 11:28	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	LTC As Left Counter	127245	
12/9/2020 11:28	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	LTC As Found Counter	127234	
12/9/2020 11:28	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Mechanism Patrol Inspection	General Comments		
12/9/2020 11:28	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	General Comments		
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Foundation Condition	Good	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	General Comments		
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	General Comments		
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Grounds in Place?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Maintenance Operations	0	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Operations Counter AF	175	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Operations Counter AL	175	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Operations This Read Vac	0	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Switching Operations	0	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Unknown Operations	0	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	9 Month Operations	5	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Amps A Ø	54.0	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Amps B Ø	50.0	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Amps C Ø	52.0	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Bushing Condition	Good	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Fault Operations A Ø	0	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Fault Operations B Ø	0	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Fault Operations C Ø	0	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Fault Operations Ground	0	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Follow-up Action Required?	n	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Foundation Condition	Good	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	General Comments		
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	General Comments		
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Grounds in Place?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Maintenance Operations	0	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	General Comments		
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	947.52	kw
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	71.00	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	Oil Temp Max	55	°C
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	Oil Temp Present	25	°C
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	573	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	573	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	9 Month Operations	4	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Amps A Ø	90.0	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Amps B Ø	95.0	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Amps C Ø	70.0	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Bushing Condition	Good	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Fault Operations A Ø	0	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Fault Operations B Ø	0	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Fault Operations C Ø	0	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Fault Operations Ground	0	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Follow-up Action Required?	n	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Foundation Condition	Good	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	General Comments	needs wildlife protection	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	General Comments	ok	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Grounds in Place?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Maintenance Operations	0	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Operations Counter AF	99956	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Operations Counter AL	99956	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Operations This Read Vac	0	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Switching Operations	0	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Unknown Operations	0	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	9 Month Operations	4	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Amps A Ø	57.0	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Amps B Ø	54.0	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Amps C Ø	60.0	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Bushing Condition	Good	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Fault Operations A Ø	0	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Fault Operations C Ø	0	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Fault Operations Ground	0	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Follow-up Action Required?	n	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.8	VDC
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	28.1	VDC
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	45	°F
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Bushing Condition	Good	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Amps C Ø	100.0	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Amps B Ø	12.0	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Amps A Ø	12.0	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	9 Month Operations	4	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	General Comments		
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Current Tap Position	1R	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	General Comments	ok	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Regulator As Left Counter	106171	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.7896	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Operations Counter AF	187	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Operations Counter AL	187	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Operations This Read Vac	0	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Switching Operations	0	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Unknown Operations	0	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	9 Month Operations	5	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Amps A Ø	66.0	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Amps B Ø	18.0	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Amps C Ø	39.0	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Bushing Condition	Good	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Fault Operations A Ø	0	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Fault Operations B Ø	0	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Fault Operations C Ø	0	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Fault Operations Ground	0	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Follow-up Action Required?	n	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Foundation Condition	Good	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	General Comments		
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	General Comments		
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Grounds in Place?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Maintenance Operations	0	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Operations Counter AF	185	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Operations Counter AL	185	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Operations This Read Vac	0	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Switching Operations	0	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Unknown Operations	0	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Unknown Operations	0	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Switching Operations	0	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Operations This Read Vac	0	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Operations Counter AL	259	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Operations Counter AF	259	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Maintenance Operations	0	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Grounds in Place?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	General Comments		
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	General Comments		
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Foundation Condition	Good	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Follow-up Action Required?	n	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Fault Operations Ground	0	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Fault Operations C Ø	0	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Fault Operations B Ø	0	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Fault Operations A Ø	0	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BCH001221	Charger	480-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BCH001221	Charger	480-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	57.1	VDC
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BCH001221	Charger	480-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	57.1	VDC
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	General Comments		
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	General Comments		
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Vegetation	None	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	General Comments		
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BCH001221	Charger	480-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.200	millivolts
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	9 Months Operations	3	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	Oil Temp Present	25	°C
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	Oil Temp Max	40	°C
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	9 Month Operations	3	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Amps A Ø	37.0	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Amps B Ø	20.0	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Amps C Ø	27.0	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Bushing Condition	Good	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Fault Operations A Ø	0	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Fault Operations B Ø	0	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Fault Operations C Ø	0	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Fault Operations Ground	0	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Follow-up Action Required?	n	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Foundation Condition	Good	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	General Comments		
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	General Comments	BFTC	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Grounds in Place?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Maintenance Operations	0	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Operations Counter AF	211	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Operations Counter AL	212	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Operations This Read Vac	1	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Switching Operations	1	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Unknown Operations	0	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BCH001221	Charger	480-Battery Charger	Battery Charger Patrol Insp	General Comments	Charger float 54.5	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BCH001221	Charger	480-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	General Comments		
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Ambient Temp	42	°F
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	BCH000257	Charger	576-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	BCH000257	Charger	576-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	BCH000257	Charger	576-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	BCH000257	Charger	576-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	BCH000257	Charger	576-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BCH000427	Charger	596-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BCH000427	Charger	596-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BCH000427	Charger	596-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BCH000427	Charger	596-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BCH000427	Charger	596-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5106	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/9/2020 9:50	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/9/2020 9:50	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/9/2020 9:50	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/9/2020 9:50	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Accumulated Fault Duty B Ph AM	21.68	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Accumulated Fault Duty C Ph AM	3.61	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Amps A Ø	169.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Amps B Ø	170.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Amps C Ø	158.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Fault Operations A Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Fault Operations B Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Fault Operations C Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Fault Operations Ground	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	General Comments		
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	General Comments		
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	General Comments		
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	36.36	kw
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	225.00	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	220.00	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	Oil Temp Max	35	°C
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	Oil Temp Present	20	°C
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	300	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.1212	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Maintenance Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Operations Counter AF	862	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Operations Counter AL	862	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Operations This Read AM	0	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Switching Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Unknown Operations	0	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Vegetation	None	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Unknown Operations	0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Switching Operations	1	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Operations This Read Vac	1	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Operations Counter AL	231	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Operations Counter AF	230	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Maintenance Operations	0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Grounds in Place?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	General Comments		
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	General Comments		
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Foundation Condition	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Follow-up Action Required?	n	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Fault Operations Ground	0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Fault Operations C Ø	0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Fault Operations B Ø	0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Fault Operations A Ø	0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Bushing Condition	Good	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Very Low	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Unknown Operations	0	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Switching Operations	1	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Operations This Read Vac	2	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Operations Counter AL	181	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Operations Counter AF	181	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Maintenance Operations	1	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Grounds in Place?	y	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	General Comments		
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	General Comments		
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Foundation Condition	Good	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Follow-up Action Required?	n	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Fault Operations Ground	0	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Fault Operations C Ø	0	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Fault Operations B Ø	0	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Fault Operations A Ø	0	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Bushing Condition	Good	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Amps C Ø	7.0	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Amps B Ø	0.0	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Amps A Ø	0.0	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	9 Month Operations	4	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Vegetation	None	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	General Comments		
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	Totalizer Meter Reading	.2970	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Operations This Read Vac	1	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Switching Operations	1	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Unknown Operations	0	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Vegetation	None	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Amps C Ø	73.0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Amps B Ø	68.0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Amps A Ø	75.0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	9 Month Operations	2	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	General Comments		
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Vegetation	None	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	General Comments	low spots in the station with standing water	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Regulator As Left Counter	101085	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	Totalizer Meter Reading	.5226	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	Oil Temp Present	44	°C
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	Oil Temp Max	51	°C
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	BCH001218	Charger	497-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.9	VDC
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	BCH001218	Charger	497-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.9	VDC
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	BCH001218	Charger	497-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	General Comments		
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Foundation Condition	Good	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Follow-up Action Required?	n	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Fault Operations Ground	0	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	LTC Totalizer Reading	5016.96	kw
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	General Comments		
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	General Comments		
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Fault Operations C ∅	1	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Fault Operations B ∅	1	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Fault Operations A ∅	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Fault Adjusted Amps C Phase V	16.19	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Fault Adjusted Amps B Phase V	16.19	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	45	*F
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Fault Operations Ground	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Fault Operations C Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Fault Operations B Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Fault Operations A Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Amps C Ø	480.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Amps B Ø	480.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Amps A Ø	480.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Accumulated Fault Duty C Ph AM	2.15	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Accumulated Fault Duty B Ph AM	2.15	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Accumulated Fault Duty A Ph AM	2.15	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	9 Months Operations	3	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	9 Months Operations	1	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Broom on Site?	n	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	BCH001218	Charger	497-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	BCH001218	Charger	497-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	BCH001218	Charger	497-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	BCH001218	Charger	497-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Vegetation	None	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	General Comments		
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	General Comments		
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	*F
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Maintenance Operations	0	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Ambient Temp	43	*F
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Grounds in Place?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	General Comments		
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	General Comments		
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Foundation Condition	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Follow-up Action Required?	n	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Fault Operations Ground	0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Fault Operations C Ø	0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Fault Operations B Ø	0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Fault Operations A Ø	0	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.5	VDC
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.8	VDC
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	General Comments		
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Bushing Condition	Good	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Amps C Ø	0.0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Unknown Operations	0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Switching Operations	1	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Ambient Temp	40	*F
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Operations This Read Vac	1	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Operations Counter AL	414	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Operations Counter AF	413	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.5	VDC
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.8	VDC
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/9/2020 11:22	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	General Comments		
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Maintenance Operations	0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Grounds in Place?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	General Comments	BFTC	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Operations Counter AF	186	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Maintenance Operations	0	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Grounds in Place?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	General Comments		
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Foundation Condition	Good	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Follow-up Action Required?	n	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Fault Operations Ground	0	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Fault Operations C Ø	0	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Fault Operations B Ø	0	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Fault Operations A Ø	0	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Bushing Condition	Good	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Amps C Ø	84.0	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Amps B Ø	118.0	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Amps A Ø	85.0	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	9 Month Operations	1	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	General Comments		
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	.1	VDC
12/9/2020 9:50	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	.1	VDC
12/9/2020 9:50	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/9/2020 9:50	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	Oil Temp Present	24	°C
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	Oil Temp Max	47	°C
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1225.44	kw
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	General Comments	ok	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Unknown Operations	0	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Switching Operations	0	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Operations This Read Vac	0	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Operations Counter AL	186	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	27.9	VDC
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	29.1	VDC
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	General Comments		
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Vegetation	None	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Trash Emptied?	n	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Unknown Operations	0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Switching Operations	1	
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Operations This Read Vac	1	
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Operations Counter AL	99981	
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Operations Counter AF	99980	
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Amps C Ø	0.0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Amps B Ø	0.0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Amps A Ø	0.0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	9 Month Operations	3	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Unknown Operations	0	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Switching Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Fault Operations Ground	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Fault Operations C Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Fault Operations B Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Fault Operations A Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Amps C Ø	140.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Amps B Ø	145.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Amps A Ø	130.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Accumulated Fault Duty C Ph AM	.56	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Unknown Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Switching Operations	2	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Operations This Read AM	2	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Operations Counter AL	112	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Operations Counter AF	112	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Operations This Read Vac	2	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Operations Counter AL	222	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Operations Counter AF	222	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Maintenance Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Maintenance Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	General Comments	.	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Grounds in Place?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	General Comments	b and c faults instant nuetral also had target	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.4	VDC
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	27.9	VDC
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Unknown Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Switching Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Operations This Read AM	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Operations Counter AL	728	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Operations Counter AF	728	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Readings	Maintenance Operations	0	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	55	*F

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	General Comments		
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Foundation Condition	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Follow-up Action Required?	n	
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Fault Operations Ground	0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Fault Operations C Ø	0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Fault Operations B Ø	0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Fault Operations A Ø	0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Bushing Condition	Good	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	General Comments		
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #"'s
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	21.2	VDC
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	LTCC000777	LTCControl	093-5	LTC Control Insp	VRR Time Delay	30	Seconds
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Ambient Temp	60	*F
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	General Comments	ok	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Ambient Temp	42	*F
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	General Comments	ok	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Vegetation	None	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	General Comments	ok	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	General Comments		
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Ambient Temp	35	*F
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.7920	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Vegetation	None	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	General Comments		
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	LTCC000771	LTCControl	727-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	LTCC000771	LTCControl	727-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	LTCC000771	LTCControl	727-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	LTCC000771	LTCControl	727-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	LTCC000771	LTCControl	727-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	LTCC000771	LTCControl	727-1	LTC Control Insp	LTC Operation Checked?	y	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	LTCC000771	LTCControl	727-1	LTC Control Insp	General Comments		
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	LTCC000771	LTCControl	727-1	LTC Control Insp	Follow-up Action Required?	n	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	LTCC000771	LTCControl	727-1	LTC Control Insp	All Connections OK?	y	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Ambient Temp	43	*F

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	LTCC000777	LTCControl	093-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/9/2020 11:28	Distribution	London Quarterly Inspection	LTCC000777	LTCControl	093-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/9/2020 11:28	Distribution	London Quarterly Inspection	LTCC000777	LTCControl	093-5	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
12/9/2020 11:28	Distribution	London Quarterly Inspection	LTCC000777	LTCControl	093-5	LTC Control Insp	LTC Operation Checked?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	LTCC000777	LTCControl	093-5	LTC Control Insp	General Comments		
12/9/2020 11:28	Distribution	London Quarterly Inspection	LTCC000777	LTCControl	093-5	LTC Control Insp	Follow-up Action Required?	n	
12/9/2020 11:28	Distribution	London Quarterly Inspection	LTCC000777	LTCControl	093-5	LTC Control Insp	All Connections OK?	y	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	General Comments		
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	General Comments		
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Operations This Read Vac	0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Switching Operations	0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Unknown Operations	0	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Operations This Read AM	0	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Switching Operations	0	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Unknown Operations	0	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	General Comments		
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	General Comments		
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	BCH000420	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	55.5	VDC
12/9/2020 9:50	Distribution	Island Quarterly Inspection	BCH000420	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	55.5	VDC
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Operations A Ø	0	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Operations B Ø	0	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Operations C Ø	0	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Operations Ground	0	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Follow-up Action Required?	n	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Patrol Inspection	General Comments		
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	General Comments		
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Maintenance Operations	0	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Operations Counter AF	376	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Operations Counter AL	376	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Amps C Ø	240.0	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Amps B Ø	200.0	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Amps A Ø	120.0	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	9 Months Operations	1	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Fault Operations A Ø	0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Fault Operations B Ø	0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Fault Operations C Ø	0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Fault Operations Ground	0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Follow-up Action Required?	n	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Foundation Condition	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	General Comments		
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	General Comments		
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Grounds in Place?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Maintenance Operations	0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Operations Counter AF	334	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Operations Counter AL	334	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	General Comments	ok	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Vegetation	None	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	General Comments	ok	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	General Comments		
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	BCH000420	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	BCH000420	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments	ok	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Bushing Condition	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Amps C Ø	302.0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Amps B Ø	275.0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Amps A Ø	318.0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	9 Month Operations	18	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	General Comments	ok	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	Oil Temp Max	51	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	27.50	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	950.40	kw
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	General Comments	ok	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	General Comments	ok	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	General Comments		
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Vegetation	None	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Ambient Temp	44	°F
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BCH000446	Charger	405-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.9	VDC
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BCH000446	Charger	405-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.9	VDC
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BCH000446	Charger	405-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.3	amps
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BCH000446	Charger	405-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	BCH000446	Charger	405-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	BCH000452	Charger	571-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.9	VDC
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	BCH000452	Charger	571-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.9	VDC
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	BCH000452	Charger	571-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	BCH000452	Charger	571-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	BCH000452	Charger	571-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	General Comments		
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Unknown Operations	0	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	9 Month Operations	2	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Amps A Ø	142.0	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Amps B Ø	152.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Amps C Ø	140.0	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Bushing Condition	Good	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	Oil Temp Present	26	°C
12/9/2020 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	Oil Temp Present	37	°C
12/9/2020 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	Oil Temp Max	45	°C
12/9/2020 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/9/2020 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	LTC Totalizer Reading	15672.96	kw
12/9/2020 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
12/9/2020 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	General Comments		
12/9/2020 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	General Comments		
12/9/2020 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	Follow-up Action Required?	n	
12/9/2020 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Operations Counter AF	175	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Operations Counter AL	176	
12/9/2020 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	General Comments		
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	General Comments	ok	
12/9/2020 9:08	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/9/2020 10:29	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Fault Operations A Ø	0	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Fault Operations B Ø	0	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Fault Operations C Ø	0	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Fault Operations Ground	0	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Follow-up Action Required?	n	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Foundation Condition	Good	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	General Comments		
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	General Comments	BFTC	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Grounds in Place?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Maintenance Operations	0	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Ambient Temp	40	*F
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	General Comments		
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/9/2020 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	100.00	
12/9/2020 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	Winding Temp Present	32	*C
12/9/2020 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	Winding Temp Max	35	*C
12/9/2020 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	Totalizer Meter Reading	1.6326	
12/9/2020 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/9/2020 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/9/2020 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Ambient Temp	47	*F
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	9 Month Operations	2	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Amps A Ø	108.0	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Amps B Ø	86.0	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Amps C Ø	116.0	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Bushing Condition	Good	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Fault Operations A Ø	0	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Fault Operations B Ø	0	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Fault Operations C Ø	0	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Fault Operations Ground	0	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Follow-up Action Required?	n	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Foundation Condition	Good	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	General Comments		
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	General Comments	BFTC	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Grounds in Place?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Maintenance Operations	0	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Operations Counter AF	174	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Operations Counter AL	175	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Operations This Read Vac	1	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Switching Operations	1	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Unknown Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Unknown Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Switching Operations	2	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Operations This Read AM	2	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Operations Counter AL	100	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	General Comments		
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Battery Overall Condition	Good	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Battery Bank Volts	26.6	VDC
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Battery Bank Amps	.1	AMPS
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	Ground Lights	None	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	General Comments		
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	As Left Float Voltage	26.6	VDC
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	As Found Float Voltage	26.6	VDC
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Vegetation	None	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	General Comments	ok	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	LTCC000782	LTCControl	576-1	LTC Control Insp	All Connections OK?	y	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	LTCC000782	LTCControl	576-1	LTC Control Insp	Follow-up Action Required?	n	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	LTCC000782	LTCControl	576-1	LTC Control Insp	General Comments		
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	LTCC000782	LTCControl	576-1	LTC Control Insp	LTC Operation Checked?	y	
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	LTCC000782	LTCControl	576-1	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	LTCC000782	LTCControl	576-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	LTCC000782	LTCControl	576-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/9/2020 8:24	Distribution	Greenville 12kV Quarterly Inspection	LTCC000782	LTCControl	576-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	LTC As Found Counter	7266	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	General Comments		
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	9 Month Operations	2	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Amps A Ø	78.0	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Amps B Ø	84.0	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Amps C Ø	74.0	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Bushing Condition	Good	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Fault Operations A Ø	0	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Fault Operations B Ø	0	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Fault Operations C Ø	0	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Fault Operations Ground	0	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Follow-up Action Required?	n	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Foundation Condition	Good	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	General Comments		
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	General Comments	BFTC	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Maintenance Operations	0	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Operations Counter AF	230	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Operations Counter AL	231	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Operations This Read Vac	1	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Switching Operations	1	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Vegetation	None	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Operations Counter AF	100	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Maintenance Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	General Comments	.	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Fault Operations Ground	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Fault Operations C Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Fault Operations B Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Fault Operations A Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	General Comments		
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	LTC As Found Counter	259754	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	LTC As Left Counter	259754	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	LTC Current Tap Position	5L	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	LTC Max Tap Position	5L	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	LTC Min Tap Position	9L	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	69	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Amps C Ø	0.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Amps B Ø	0.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Amps A Ø	0.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Accumulated Fault Duty C Ph AM	2.83	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Accumulated Fault Duty B Ph AM	2.83	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Accumulated Fault Duty A Ph AM	2.83	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	9 Months Operations	4	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	26	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	LTC Min Tap Position	9L	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	LTC Max Tap Position	5L	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	LTC Current Tap Position	9L	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	LTC As Left Counter	7266	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Switching Operations	0	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Unknown Operations	1	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	General Comments	ok	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	LTCC000819	LTCCControl	480-1	LTC Control Insp	All Connections OK?	y	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	LTCC000819	LTCCControl	480-1	LTC Control Insp	Follow-up Action Required?	n	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	LTCC000819	LTCCControl	480-1	LTC Control Insp	General Comments		
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	LTCC000819	LTCCControl	480-1	LTC Control Insp	LTC Operation Checked?	y	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	LTCC000819	LTCCControl	480-1	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	LTCC000819	LTCCControl	480-1	LTC Control Insp	VRR Base Voltage AF	1245.0	VAC
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	LTCC000819	LTCCControl	480-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	LTCC000819	LTCCControl	480-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	General Comments	ok	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	General Comments		
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Vegetation	None	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	General Comments		
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Vegetation	None	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	General Comments		
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Ambient Temp	50	*F
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Bushing Condition	Good	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Fault Adjusted Amps A Phase V	5.20	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Fault Adjusted Amps B Phase V	5.20	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Fault Adjusted Amps C Phase V	5.20	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Fault Operations A Ø	0	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Fault Operations B Ø	0	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Fault Operations C Ø	0	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Fault Operations Ground	0	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Follow-up Action Required?	n	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Foundation Condition	Good	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	General Comments		
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	General Comments	No target written up	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Grounds in Place?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Maintenance Operations	0	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Operations Counter AF	186	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Operations Counter AL	186	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Operations This Read Vac	1	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Oil Temp Present	15	°C
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Oil Temp Max	15	°C
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Ambient Temp	38	°F
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	General Comments		
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	3L	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	37843200.00	kw
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	General Comments		
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	Totalizer Meter Reading	0.0000	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Regulator As Left Counter	372268	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	General Comments		
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	77713	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	12L	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	2L	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	General Comments		
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	General Comments	no spare fuse barrels	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	LTCC000826	LTCControl	497-1	LTC Control Insp	All Connections OK?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	LTCC000826	LTCControl	497-1	LTC Control Insp	Follow-up Action Required?	n	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	LTCC000826	LTCControl	497-1	LTC Control Insp	General Comments		
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	LTCC000826	LTCControl	497-1	LTC Control Insp	LTC Operation Checked?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	LTCC000826	LTCControl	497-1	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	LTCC000826	LTCControl	497-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	LTCC000826	LTCControl	497-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	LTCC000826	LTCControl	497-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	General Comments		
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Regulator As Left Counter	100467	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Vegetation	None	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	General Comments		
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	9 Month Operations	5	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Amps A Ø	120.0	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Amps B Ø	100.0	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	505	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	505	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	1	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 10:17	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Amps C Ø	100.0	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Ambient Temp	55	*F
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	General Comments		
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	General Comments	-1.5 psi on nitrogen blanket liquid temp max 54 present 24 winding temp 40 max current 15	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 8:37	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BCH001284	Charger	721-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.100	millivolts
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BCH001284	Charger	721-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BCH001284	Charger	721-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BCH001284	Charger	721-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.8	amps
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BCH001284	Charger	721-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BCH001284	Charger	721-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BCH001284	Charger	721-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BCH001284	Charger	721-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	General Comments		
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	UG Pothead Condition Good?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Current Tap Position	1R	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	General Comments		
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	General Comments		
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	General Comments		
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Follow-up Action Required?	n	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Fault Operations Ground	0	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Fault Operations C ∅	0	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Fault Operations B ∅	0	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Fault Operations A ∅	0	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	Oil Temp Max	55	°C
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	Oil Temp Present	25	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	General Comments	ok	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Max Tap Position	7L	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Min Tap Position	16L	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Regulator As Left Counter	28573	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Bushing Condition	Good	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Amps C Ø	320.0	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Amps B Ø	320.0	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Amps A Ø	320.0	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	9 Month Operations	0	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	General Comments		
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/9/2020 9:54	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Winding Temp Present	17	°C
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	180.0	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	70.0	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	160.0	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	Follow-up Action Required?	n	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	General Comments		
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	General Comments		
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	LTC Totalizer Reading	5656.32	kw
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Unknown Operations	0	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Switching Operations	0	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Operations This Read Vac	0	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Operations Counter AL	162	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Operations Counter AF	162	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Current Tap Position	9L	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Maintenance Operations	0	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Grounds in Place?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	General Comments		
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	General Comments		
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Foundation Condition	Good	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Winding Temp Max	32	°C
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Totalizer Meter Reading	3942.0000	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.5	VDC
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.5	VDC
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	General Comments		
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	General Comments		
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	General Comments		
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	General Comments		
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	General Comments		
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	100.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	9 Months Operations	6	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Accumulated Fault Duty A Ph AM	1.12	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Accumulated Fault Duty B Ph AM	1.12	%
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F
12/9/2020 13:32	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	6222.24	kw
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	Oil Temp Max	15	*C
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	General Comments	no spare fuse	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
12/9/2020 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	Totalizer Meter Reading	.7764	
12/9/2020 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	Winding Temp Max	50	*C
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/9/2020 10:47	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	Winding Temp Present	20	*C
12/9/2020 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
12/9/2020 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	9 Month Operations	6	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Unknown Operations	0	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Switching Operations	0	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Operations This Read AM	0	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Operations Counter AL	419	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Operations Counter AF	419	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Maintenance Operations	0	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	General Comments		
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Follow-up Action Required?	n	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Operations Ground	0	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Operations C ∅	0	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Operations B ∅	0	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Operations A ∅	0	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Amps C Ø	110.0	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Amps B Ø	110.0	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Amps A Ø	350.0	
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/9/2020 12:13	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	9 Months Operations	0	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	General Comments	ok	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Vegetation	None	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	General Comments		
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/9/2020 12:39	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Fault Operations Ground	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Maintenance Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Operations Counter AF	432	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Operations Counter AL	432	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Operations This Read AM	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Switching Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Unknown Operations	0	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Trash Emptied?	n	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	General Comments		
12/9/2020 9:50	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	n	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	°F

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	LTC Totalizer Reading	2154.24	kw
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	General Comments		
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	General Comments		
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
12/9/2020 8:33	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	Totalizer Meter Reading	.8642	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	General Comments	ok	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Amps A Ø	10.0	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Amps B Ø	0.0	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	9 Month Operations	15	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Amps A Ø	290.0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Amps B Ø	230.0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Amps C Ø	285.0	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Bushing Condition	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Vegetation	None	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Accumulated Fault Duty C Ph AM	1.12	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Amps A Ø	55.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Amps B Ø	65.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Amps C Ø	55.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Fault Operations A Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Fault Operations B Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Fault Operations C Ø	0	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Ambient Temp	44	°F
12/9/2020 9:50	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Regulator As Left Counter	103997	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Max Tap Position	6R	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	General Comments		
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/9/2020 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/9/2020 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	Follow-up Action Required?	n	
12/9/2020 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	General Comments		
12/9/2020 9:13	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	9 Months Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Accumulated Fault Duty A Ph AM	1.33	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Accumulated Fault Duty B Ph AM	1.33	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Accumulated Fault Duty C Ph AM	1.33	%
12/9/2020 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	General Comments	Needs nitrogen	
12/9/2020 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Amps A Ø	25.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Amps B Ø	25.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Amps C Ø	25.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Fault Operations A Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Fault Operations B Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Fault Operations C Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Fault Operations Ground	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	General Comments		
12/9/2020 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	LTC Totalizer Reading	11180.16	kw
12/9/2020 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
12/9/2020 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	Oil Temp Max	80	°C
12/9/2020 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	Oil Temp Present	30	°C
12/9/2020 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Unknown Operations	0	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Switching Operations	0	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Operations This Read Vac	0	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Operations Counter AL	186	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Operations Counter AF	186	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Maintenance Operations	0	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Grounds in Place?	y	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	General Comments		
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Maintenance Operations	0	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/9/2020 14:32	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	Totalizer Meter Reading	.5892	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
12/9/2020 9:52	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/9/2020 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	General Comments		
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	General Comments		
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/9/2020 8:17	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	LTC Totalizer Reading	1425.60	kw
12/9/2020 9:50	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/9/2020 9:50	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	LTC Totalizer Reading	3136.32	kw
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	General Comments		
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	General Comments		
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	Follow-up Action Required?	n	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Bushing Condition	Good	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Amps C Ø	164.0	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Amps B Ø	161.0	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Amps A Ø	190.0	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	9 Month Operations	4	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/9/2020 13:35	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	110.00	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	117.50	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	0.00	kw
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	General Comments	metter showing err 0001	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	General Comments		
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/9/2020 9:10	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/9/2020 12:19	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 11:28	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Operations Counter AF	40	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Operations Counter AL	40	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Operations This Read AM	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Switching Operations	0	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Foundation Condition	Good	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Follow-up Action Required?	n	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Follow-up Action Required?	n	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Fault Operations Ground	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Unknown Operations	0	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Fault Operations C Ø	0	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Fault Operations B Ø	0	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Fault Operations A Ø	0	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	Totalizer Meter Reading	.4488	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	Oil Temp Present	30	°C
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	Oil Temp Max	40	°C
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/9/2020 9:42	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/9/2020 10:58	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	Totalizer Meter Reading	.4356	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	Oil Temp Present	40	°C
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	Oil Temp Max	50	°C
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/9/2020 8:07	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps A Ø	70.0	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps B Ø	46.0	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps C Ø	97.0	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	General Comments		
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Operations Counter	1497	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	227	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	227	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Unknown Operations	0	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Unknown Operations	0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Switching Operations	0	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Switching Operations	1	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Operations This Read Vac	12	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Operations Counter AL	166	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Operations Counter AF	166	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Maintenance Operations	11	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	General Comments		
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Operations This Read Vac	0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Operations Counter AL	197	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Operations Counter AF	197	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Maintenance Operations	0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	General Comments		
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Patrol Inspection	General Comments		
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Follow-up Action Required?	n	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Patrol Inspection	General Comments		
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Operations Ground	0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Operations C Ø	0	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Operations B Ø	0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Operations A Ø	0	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Operations Ground	0	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Amps C Ø	230.0	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Amps B Ø	267.0	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Amps A Ø	290.0	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	3.85	%
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	3.85	%
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	3.85	%
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	LTC000386	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	40	Seconds
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	General Comments		
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	9 Month Operations	13	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	General Comments		
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	Totalizer Meter Reading	.5916	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	LTCC000378	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	LTCC000378	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	LTCC000378	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	LTCC000378	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	LTCC000378	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	121.4	VAC
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	LTCC000378	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	120.5	VAC
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	LTCC000142	LTCControl	406-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	LTCC000142	LTCControl	406-1	LTC Control Insp	LTC Operation Checked?	y	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	LTCC000142	LTCControl	406-1	LTC Control Insp	General Comments		
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	LTCC000142	LTCControl	406-1	LTC Control Insp	Follow-up Action Required?	n	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	LTCC000142	LTCControl	406-1	LTC Control Insp	All Connections OK?	y	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	LTCC000141	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	LTCC000141	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	LTCC000141	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	LTCC000141	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallellIND	Position
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	LTCC000141	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	LTCC000378	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	120.5	VAC
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	LTCC000378	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	Oil Temp Present	20	°C
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	Oil Temp Max	50	°C
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	LTC Totalizer Reading	3549.60	kw
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	LTCC000386	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	LTCC000386	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	LTCC000386	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	LTCC000386	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	LTCC000386	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	LTCC000386	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	LTCC000386	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Switching Operations	1	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Operations This Read Vac	1	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	Totalizer Meter Reading	.6258	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	General Comments		
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	Oil Temp Present	20	°C
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	Oil Temp Max	60	°C
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.2	psi
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Ambient Temp	34	°F
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	General Comments		
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Vegetation	None	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	General Comments		
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Ambient Temp	33	°F
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	General Comments		
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Readings	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	General Comments		
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	LTCC000901	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	LTCC000901	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	LTCC000901	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	LTCC000901	LTCControl	920-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	LTCC000901	LTCControl	920-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	LTCC000901	LTCControl	920-Offline-Distribution	LTC Control Insp	General Comments		
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	LTCC000901	LTCControl	920-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	LTCC000901	LTCControl	920-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Unknown Operations	0	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	49	°C
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	General Comments		
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	BCH001231	Charger	142-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	BCH001231	Charger	142-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	BCH001231	Charger	142-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Unknown Operations	0	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Switching Operations	1	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Operations This Read SF6	4	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	11	°C
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	53	°C
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	13	°C
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	55	°C
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	13	°C
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	General Comments		
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Operations Counter AL	694	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Operations Counter AF	694	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Num Operations Last 9 Months	7	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	General Comments		
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Maintenance Operations	3	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	General Comments		
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Follow-up Action Required?	n	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Fault Operations	0	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	9 Month Operations	3	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2020 15:25	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0235	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Maintenance Operations	0	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Operations Counter AF	74	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Operations Counter AL	74	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Operations This Read Vac	6	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Switching Operations	6	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Unknown Operations	0	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	General Comments		
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	750	psi
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	Oil Temp Max	53	°C
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	Oil Temp Present	13	°C
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BCH001379	Charger	683-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BCH001379	Charger	683-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BCH001379	Charger	683-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BCH001379	Charger	683-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BCH001379	Charger	683-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BCH001379	Charger	683-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BCH001379	Charger	683-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BCH001379	Charger	683-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	BCH001231	Charger	142-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	BCH001231	Charger	142-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Fault Operations C Ø	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Fault Operations Ground	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Operations Counter AF	222	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Operations Counter AL	222	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Operations This Read Vac	1	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Switching Operations	1	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	General Comments		
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Operations Counter	882	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	General Comments		
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Vegetation	None	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	845	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	845	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	General Comments	fence is rusty with wash out spots on creek side mentioned in previous inspection. some gaps in wire and multiple bends on posts.	
12/8/2020 15:25	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0235	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/8/2020 15:25	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0235	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/8/2020 15:25	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0235	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
12/8/2020 15:25	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0235	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
12/8/2020 15:25	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0235	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Amps A Ø	61.0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Amps B Ø	48.0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Amps C Ø	67.0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Fault Operations A Ø	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Fault Operations B Ø	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Fault Operations C Ø	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Fault Operations Ground	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Follow-up Action Required?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	General Comments	The operation counter is showing less operations then cascade.	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Amps C Ø	100.0	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Amps B Ø	100.0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Maintenance Operations	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Operations Counter AF	224	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Operations Counter AL	224	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Operations This Read Vac	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Switching Operations	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	9 Month Operations	2	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Amps A Ø	20.0	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Amps A Ø	95.0	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Amps B Ø	22.0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Amps C Ø	20.0	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	LTCC000142	LTCControl	406-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	LTCC000142	LTCControl	406-1	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	LTCC000142	LTCControl	406-1	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Amps A Ø	0.0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Amps B Ø	0.0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Amps C Ø	0.0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	9 Month Operations	16	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Amps A Ø	160.0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Amps B Ø	159.0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Amps C Ø	158.0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Fault Operations A Ø	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Readings	Fault Operations B Ø	0	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	122.9	volts
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Min Tap Position	9L	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	54	°F
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	BCH001062	Charger	343-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	BCH001062	Charger	343-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	BCH001062	Charger	343-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	BCH001062	Charger	343-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	BCH001062	Charger	343-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Amps A Ø	67.0	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	BCH001062	Charger	343-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.400	millivolts
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Amps B Ø	67.0	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	General Comments		
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Amps C Ø	67.0	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	General Comments		
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Operations Counter	1454	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	General Comments		
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Fault Operations A Ø	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Fault Operations B Ø	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Fault Operations C Ø	0	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Max Tap Position	4L	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	Totalizer Meter Reading	.4970	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	Oil Temp Present	25	°C
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	Oil Temp Max	35	°C
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.3	psi
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Fault Operations Ground	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	General Comments		
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	LTC Totalizer Reading	4771.20	kw
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Maintenance Operations	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Operations Counter AF	208	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Operations Counter AL	208	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Operations This Read Vac	2	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Switching Operations	2	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	General Comments		
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	General Comments		
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Operations Since Last Insp	408	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Min Tap Position	8L	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Max Tap Position	2L	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Current Tap Position	4L	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Left Counter	59872	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Found Counter	59872	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Follow-up Action Required?	n	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Follow-up Action Required?	n	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Vegetation	None	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Current Tap Position	6L	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	BCH001351	Charger	546-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	BCH001351	Charger	546-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	BCH001351	Charger	546-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	BCH001351	Charger	546-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	BCH001351	Charger	546-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	BCH001351	Charger	546-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Patrol Inspection	General Comments		
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Tank Leaks	None	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	BCH001351	Charger	546-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	BCH001351	Charger	546-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9630	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Regulator As Left Counter	91878	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Readings	Oil Temp Present	0	°C
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	General Comments		
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Clear of Trash?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Max Tap Position	1L	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	General Comments		
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	LTC Totalizer Reading	6007.68	kw
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	General Comments		
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	General Comments		
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Readings	General Comments	unable to read oil temp gauge	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	General Comments		
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	General Comments		
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	83.0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	General Comments	yard light by Switch gear 3 is out. Need small bucket truck	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Vegetation	None	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Yard Lights Working?	n	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	73.0	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	55.0	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	11	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	General Comments		
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Vegetation	None	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Amps A Ø	90.0	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Amps B Ø	102.0	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Amps C Ø	90.0	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Vegetation	None	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	LTCC000141	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	LTCC000141	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	LTCC000141	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	LTCC000141	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	Follow-up Action Required?	n	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	General Comments		
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Mechanism Patrol Inspection	General Comments		
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	LTC As Found Counter	197089	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	LTC As Left Counter	197098	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	LTC Current Tap Position	3L	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	LTC Max Tap Position	4R	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	General Comments		
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Operations Counter AL	347	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Operations Counter AF	347	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Maintenance Operations	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Fault Operations Ground	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Fault Operations C Ø	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Fault Operations B Ø	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Fault Operations A Ø	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Amps C Ø	0.0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Amps B Ø	0.0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Amps A Ø	0.0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	9 Month Operations	17	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	General Comments		
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	General Comments		
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	540	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	540	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Accumulated Fault Duty A Ph V	5.58	%
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Accumulated Fault Duty B Ph V	5.58	%
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Accumulated Fault Duty C Ph V	5.58	%
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Amps A Ø	0.0	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	General Comments		
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	General Comments		
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Patrol Inspection	General Comments		
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Follow-up Action Required?	n	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Operations Ground	0	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Vegetation	None	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Readings	General Comments		
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Readings	Oil Temp Present	25	°C
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Amps B Ø	0.0	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Amps C Ø	0.0	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Operations A Ø	0	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Operations B Ø	0	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Operations C Ø	0	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	9 Month Operations	12	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Amps A Ø	0.0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Amps B Ø	0.0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Amps C Ø	0.0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	LTC Min Tap Position	10L	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	LTC Operations Since Last Insp	1130	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Ambient Temp	36	*F
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	General Comments		
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Unknown Operations	0	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2311.20	kw
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	General Comments		
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	27.50	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	Oil Temp Max	45	*C
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Regulator As Left Counter	898	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Operations Counter	1492	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Switching Operations	1	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Operations This Read Vac	7	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Operations Counter AL	140	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Operations Counter AF	140	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Maintenance Operations	6	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	General Comments		
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	9 Month Operations	9	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Operations Counter AL	335	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Operations Counter AF	335	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Maintenance Operations	0	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Grounds in Place?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	General Comments		
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	General Comments		
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Foundation Condition	Good	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Follow-up Action Required?	n	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Fault Operations Ground	0	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Fault Operations C Ø	0	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Fault Operations B Ø	0	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Fault Operations A Ø	0	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	100.0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	110.0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	90.0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	828	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	828	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Operations Counter	99992	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	General Comments		
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	LTCC000659	LTCControl	565-1	LTC Control Insp	Follow-up Action Required?	n	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	LTCC000659	LTCControl	565-1	LTC Control Insp	General Comments		
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	LTCC000659	LTCControl	565-1	LTC Control Insp	LTC Operation Checked?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	LTCC000659	LTCControl	565-1	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	LTCC000659	LTCControl	565-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	LTCC000659	LTCControl	565-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	LTCC000659	LTCControl	565-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	LTCC000659	LTCControl	565-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	LTCC000661	LTCControl	546-1	LTC Control Insp	All Connections OK?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	LTCC000661	LTCControl	546-1	LTC Control Insp	Follow-up Action Required?	n	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	LTCC000661	LTCControl	546-1	LTC Control Insp	General Comments		
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	LTCC000661	LTCControl	546-1	LTC Control Insp	LTC Operation Checked?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	LTCC000661	LTCControl	546-1	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	LTCC000661	LTCControl	546-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	LTCC000661	LTCControl	546-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	LTCC000661	LTCControl	546-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	LTCC000661	LTCControl	546-1	LTC Control Insp	VRR Time Delay	60	Seconds
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Foundation Condition	Good	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	General Comments		
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	General Comments		
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Grounds in Place?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Maintenance Operations	0	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Operations Counter AF	489	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Operations Counter AL	489	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Operations This Read Vac	0	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Switching Operations	0	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Unknown Operations	0	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Unknown Operations	0	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Switching Operations	0	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Operations This Read Vac	0	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	General Comments		
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	General Comments		
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	LTC Totalizer Reading	1102.80	kw
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	LTCC000830	LTCControl	100-6	LTC Control Insp	VRR Time Delay	30	Seconds
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	LTCC000830	LTCControl	100-6	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	LTCC000830	LTCControl	100-6	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	LTCC000830	LTCControl	100-6	LTC Control Insp	Parallel / Ind. Sw Position	parallellIND	Position
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	LTCC000830	LTCControl	100-6	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	LTCC000830	LTCControl	100-6	LTC Control Insp	LTC Operation Checked?	y	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	LTCC000830	LTCControl	100-6	LTC Control Insp	General Comments		
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	LTCC000830	LTCControl	100-6	LTC Control Insp	Follow-up Action Required?	n	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	LTCC000830	LTCControl	100-6	LTC Control Insp	All Connections OK?	y	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.9	psi
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	Oil Temp Max	60	°C
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	Oil Temp Present	20	°C
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	Totalizer Meter Reading	.1838	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	General Comments		
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Unknown Operations	0	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Switching Operations	0	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Operations This Read Vac	2	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Operations Counter AL	501	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Operations Counter AF	501	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Maintenance Operations	0	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Bushing Condition	Good	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Amps C Ø	12.0	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Amps B Ø	20.0	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Amps A Ø	12.0	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	9 Month Operations	0	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Current Tap Position	2R	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	General Comments		
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Regulator As Left Counter	156142	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	General Comments		
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Vegetation	None	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	21	°C
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	42	°C
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	21	°C
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	43	°C
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	21	°C
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	45	°C
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Readings	General Comments		
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	General Comments		middle fan on right of cabinet not working
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	General Comments		
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Readings	Oil Temp Present	45	°C
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Operations Counter AL	1421	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Operations Counter AF	1421	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Num Operations Last 9 Months	3	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Maintenance Operations	0	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	General Comments		
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Patrol Inspection	General Comments		
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Follow-up Action Required?	n	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Fault Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Amps C Ø	490.0	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Amps B Ø	510.0	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Amps A Ø	490.0	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Amps A Ø	40.0	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Amps B Ø	3.0	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Amps C Ø	30.0	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Battery Load Check OK?	n	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	General Comments		
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Operations Counter	99	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	65	°C
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	45	°C
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	Oil Temp Present	60	°C
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	Oil Temp Max	40	°C
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1200	psi
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	General Comments		
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	LTCC000176	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	60	Seconds
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	General Comments		
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	General Comments		
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	554.40	kw
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	Oil Temp Present	25	°C
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.4620	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Follow-up Action Required?	n	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	General Comments		
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	Oil Temp Present	20	°C
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	Oil Temp Max	40	°C
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-5	psi
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	General Comments	NEEDS NITRO	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	General Comments		
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	LTCC000659	LTCControl	565-1	LTC Control Insp	All Connections OK?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Readings	Winding Temp Present	50	°C
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	9 Month Operations	6	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Amps A Ø	0.0	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Amps B Ø	0.0	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Amps C Ø	0.0	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Bushing Condition	Good	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	Follow-up Action Required?	n	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	General Comments		
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Mechanism Patrol Inspection	General Comments		
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	LTC As Found Counter	14962	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	LTC As Left Counter	14962	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	LTC Current Tap Position	2L	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	LTC Max Tap Position	1R	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	LTC Min Tap Position	7L	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	LTC Operations Since Last Insp	801	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Fault Operations A Ø	0	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Fault Operations B Ø	0	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Fault Operations Ground	0	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	LTCC000176	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	LTCC000176	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	LTCC000176	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	LTCC000176	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	LTCC000176	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	LTCC000176	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	LTCC000176	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	General Comments		
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	General Comments		
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	LTC Totalizer Reading	6301.44	kw
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	Oil Temp Max	50	°C
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	Oil Temp Present	40	°C
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	20.0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	20.0	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	Totalizer Meter Reading	.6564	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	20.0	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	General Comments		
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	General Comments		
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.2	VDC
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.1	VDC
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	69	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	General Comments		
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Operations Counter	0	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	Totalizer Meter Reading	.1998	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	Follow-up Action Required?	n	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Fault Operations A Ø	0	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Unknown Operations	0	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Switching Operations	1	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Operations This Read SF6	2	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Operations Counter AL	779	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Bushing Condition	Good	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Amps C Ø	200.0	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Amps B Ø	120.0	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Amps A Ø	120.0	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	9 Month Operations	25	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Ambient Temp	40	*F
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	General Comments		
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	793	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	0	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Amps C Ø	35.9	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Amps B Ø	33.2	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Amps A Ø	39.5	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	0	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Amps A Ø	20.0	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Amps B Ø	20.0	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Amps C Ø	20.0	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Fault Operations	0	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Follow-up Action Required?	n	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Patrol Inspection	General Comments		
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	General Comments		
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Maintenance Operations	1	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Num Operations Last 9 Months	3	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Operations Counter AF	779	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	General Comments		
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	2	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	82	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	82	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	General Comments		
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Vegetation	None	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	General Comments	dirt and gravel piles need to be removed	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Unknown Operations	0	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Switching Operations	1	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Operations This Read Vac	2	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Operations Counter AL	211	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Operations Counter AF	211	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Maintenance Operations	1	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Grounds in Place?	y	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	General Comments	Switch load/TC	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	General Comments		
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Foundation Condition	Good	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Follow-up Action Required?	n	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Fault Operations Ground	0	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Fault Operations C Ø	0	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Fault Operations B Ø	0	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	Totalizer Meter Reading	.6702	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	Oil Temp Present	19	°C
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	Oil Temp Max	50	°C
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.5	psi
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	LTC Totalizer Reading	2144.64	kw
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	General Comments		
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	General Comments	missing door gasket	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Max Tap Position	2L	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9192	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Adequate	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Adequate	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	Oil Temp Present	22	°C
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Grounds in Place?	y	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	General Comments		
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	General Comments		
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Foundation Condition	Good	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Follow-up Action Required?	n	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Fault Operations Ground	1	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Fault Operations C Ø	1	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Fault Operations B Ø	0	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Fault Operations A Ø	0	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Fault Adjusted Amps C Phase V	9.62	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Fault Adjusted Amps B Phase V	4.81	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Fault Adjusted Amps A Phase V	4.81	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Amps C Ø	56.0	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Amps B Ø	67.0	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Amps A Ø	32.0	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Bushing Condition	Good	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Amps C Ø	180.0	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Amps B Ø	190.0	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Amps A Ø	144.0	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	9 Month Operations	28	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BAT001485	Battery	683-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BAT001485	Battery	683-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	35	*F
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BAT001485	Battery	683-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BAT001485	Battery	683-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BAT001485	Battery	683-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BAT001485	Battery	683-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BAT001485	Battery	683-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BAT001485	Battery	683-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BAT001485	Battery	683-Battery Bank	Battery Patrol Inspection	General Comments		
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BAT001485	Battery	683-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BAT001485	Battery	683-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BAT001485	Battery	683-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BAT001485	Battery	683-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	General Comments		
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	131	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Needs Replaced	check oil cup
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	General Comments		
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	LTC Totalizer Reading	1198.80	kw
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	Oil Temp Max	45	°C
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	Oil Temp Present	40	°C
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Regulator As Left Counter	68321	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	62	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Amps A Ø	8.8	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Amps B Ø	.5	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Amps C Ø	.2	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	6	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	*F
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	00173	NonLTC	346-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	00173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	72.50	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	00173	NonLTC	346-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1103.04	kw
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	00173	NonLTC	346-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	00173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	00173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	00173	NonLTC	346-1	NonLTC Transformer Readings	General Comments		
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	00173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	00173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	00173	NonLTC	346-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	00173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	00173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	00173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	00173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	00173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	00173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	00173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	00173	NonLTC	346-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	General Comments		
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	General Comments		
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Mechanism Patrol Inspection	General Comments	screw in desicant filter needs replaced we didn't have one with us	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	LTC As Found Counter	102709	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	LTC As Left Counter	102709	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	LTC Current Tap Position	3L	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	LTC Max Tap Position	Neutral	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	LTC Min Tap Position	8L	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	LTC Min Tap Position	9L	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	LTC Operations Since Last Insp	330	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	9	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	20.0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	20.0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	20.0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	Actual counter	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Unknown Operations	0	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Switching Operations	1	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Operations This Read Vac	7	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Operations Counter AL	220	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Operations Counter AF	220	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Maintenance Operations	6	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	General Comments		
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Patrol Inspection	General Comments		
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Follow-up Action Required?	n	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Operations Ground	0	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Operations C Ø	0	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Operations B Ø	0	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Operations A Ø	0	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Amps C Ø	93.0	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Amps B Ø	120.0	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Amps A Ø	109.0	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Accumulated Fault Duty C Ph V	19.93	%
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Accumulated Fault Duty B Ph V	32.68	%
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Accumulated Fault Duty A Ph V	22.32	%
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	9 Month Operations	11	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Operations Counter	50	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	9 Month Operations	7	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Amps A Ø	358.0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Amps B Ø	363.0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Amps C Ø	361.0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Fault Operations A Ø	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Fault Operations B Ø	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Fault Operations C Ø	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Fault Operations Ground	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Maintenance Operations	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Operations Counter AF	180	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Operations Counter AL	180	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Operations This Read Vac	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Switching Operations	0	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	Follow-up Action Required?	n	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	General Comments		
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Mechanism Patrol Inspection	General Comments		
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	LTC As Found Counter	98597	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	LTC As Left Counter	98597	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	LTC Current Tap Position	6L	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	LTC Max Tap Position	4L	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Operations Counter	205	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Operations Counter AL	168	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Operations This Read Vac	4	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Switching Operations	4	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Unknown Operations	0	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	9 Month Operations	13	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Amps A Ø	210.0	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Amps B Ø	230.0	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Amps C Ø	185.0	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Patrol Inspection	Bushing Condition	Good	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Fault Operations A Ø	0	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Fault Operations B Ø	0	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Fault Operations C Ø	0	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Follow-up Action Required?	n	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Patrol Inspection	Foundation Condition	Good	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Patrol Inspection	General Comments		
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	General Comments		
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Patrol Inspection	Grounds in Place?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Maintenance Operations	0	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Operations Counter AF	170	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Operations Counter AL	170	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Operations This Read Vac	5	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Switching Operations	5	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001575	BreakerVacuum	683-0780	VCB Readings	Unknown Operations	0	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	General Comments		
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1482	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1482	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	5	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	5	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Regulator As Left Counter	49156	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	9 Month Operations	4	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Amps A Ø	45.0	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Amps B Ø	40.0	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Amps C Ø	85.0	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Patrol Inspection	Bushing Condition	Good	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Fault Operations A Ø	0	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Fault Operations B Ø	0	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Fault Operations C Ø	0	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Fault Operations Ground	0	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Follow-up Action Required?	n	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Patrol Inspection	Foundation Condition	Good	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Patrol Inspection	General Comments		
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	General Comments		
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Patrol Inspection	Grounds in Place?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Maintenance Operations	0	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001574	BreakerVacuum	683-0779	VCB Readings	Operations Counter AF	168	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Max Tap Position	4L	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	General Comments		
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Current Tap Position	8L	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Regulator As Left Counter	80130	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Min Tap Position	14L	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Max Tap Position	8L	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	General Comments		
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Current Tap Position	8L	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Ambient Temp	35	*F
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	9 Month Operations	1	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Amps A Ø	10.0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Amps B Ø	10.0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Amps C Ø	10.0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Fault Operations A Ø	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Fault Operations B Ø	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Fault Operations C Ø	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Fault Operations Ground	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Maintenance Operations	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Operations Counter AF	214	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Operations Counter AL	214	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Operations This Read Vac	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Switching Operations	0	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	General Comments		
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	General Comments		
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	1630.80	kw
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	100.00	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	Oil Temp Max	50	°C
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	Oil Temp Present	45	°C
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	1800	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	Totalizer Meter Reading	.9060	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	General Comments		
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Regulator As Left Counter	84305	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Min Tap Position	14L	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Max Tap Position	8L	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	General Comments		
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Operations This Read Vac	1	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Switching Operations	1	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	General Comments		
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Amps B Ø	35.0	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Amps C Ø	38.0	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	3	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	3	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Unknown Operations	0	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Switching Operations	1	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Operations This Read Vac	7	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Operations Counter AL	190	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Operations Counter AF	190	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Maintenance Operations	6	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	General Comments		
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Patrol Inspection	General Comments		
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Follow-up Action Required?	n	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Operations Ground	0	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Operations C Ø	0	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Operations B Ø	0	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Operations A Ø	0	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Amps C Ø	136.0	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Amps B Ø	142.0	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Amps A Ø	144.0	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Accumulated Fault Duty C Ph V	17.54	%
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Accumulated Fault Duty B Ph V	26.31	%
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Accumulated Fault Duty A Ph V	23.12	%
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	9 Month Operations	8	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	General Comments		
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Vegetation	None	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Arching Horns Good Condition?	y	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	9 Month Operations	20	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Amps A Ø	0.0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Amps B Ø	0.0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Amps C Ø	0.0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Fault Operations A Ø	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Fault Operations B Ø	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Fault Operations C Ø	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Fault Operations Ground	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	General Comments	X	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Maintenance Operations	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Operations Counter AF	239	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Operations Counter AL	239	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Operations This Read Vac	18	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Switching Operations	18	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	9 Month Operations	2	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Amps A Ø	0.0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Amps B Ø	0.0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Amps C Ø	0.0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Fault Operations A Ø	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Fault Operations B Ø	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Fault Operations C Ø	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Fault Operations Ground	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Maintenance Operations	0	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Amps A Ø	40.0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Operations Counter AF	221	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Readings	Operations Counter AL	221	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	General Comments		
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Foundation Condition	Good	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Follow-up Action Required?	n	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Fault Operations Ground	0	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Fault Operations C Ø	0	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Fault Operations B Ø	0	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Fault Operations A Ø	0	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Bushing Condition	Good	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Amps C Ø	59.0	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Amps B Ø	79.0	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Amps A Ø	70.0	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	9 Month Operations	17	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Vegetation	None	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	General Comments		
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Ambient Temp	36	°F
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Unknown Operations	0	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Switching Operations	1	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Operations This Read Vac	7	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Operations Counter AL	204	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Operations Counter AF	204	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Maintenance Operations	6	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Regulator As Left Counter	211064	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Broom on Site?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Broom on Site?	n	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Door Alarms OK?	n	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Floor Swept?	n	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	General Comments		
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Panel Lights OK?	n	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Panels Dusted?	n	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Station Ground Set On Site?	n	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	n	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Trash Emptied?	n	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Unknown Operations	0	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Switching Operations	0	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Operations This Read Vac	0	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Operations Counter AL	269	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Operations Counter AF	269	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Maintenance Operations	0	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Grounds in Place?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	General Comments		
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	Follow-up Action Required?	n	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	General Comments		
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	General Comments		
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	LTC Totalizer Reading	4775.04	kw
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	Oil Temp Max	60	°C
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	Oil Temp Present	35	°C
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	Totalizer Meter Reading	.4974	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Amps A Ø	128.0	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Amps B Ø	141.0	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Amps C Ø	118.0	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	General Comments	counter read wrong last time	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Operations Counter	160	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Unknown Operations	0	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Switching Operations	0	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Operations This Read SF6	0	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	General Comments		
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	General Comments		
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2181.12	kw
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6816	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	General Comments		
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Patrol Inspection	General Comments		
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LTCC000522	LTCControl	CS-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LTCC000522	LTCControl	CS-TRANS 1	LTC Control Insp	General Comments	ok	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Follow-up Action Required?	n	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Operations Ground	0	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Operations C ∅	0	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Operations B ∅	0	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Operations A ∅	0	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Amps C ∅	11.0	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Amps B ∅	9.0	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Amps A ∅	45.0	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Accumulated Fault Duty C Ph V	30.29	%
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Accumulated Fault Duty B Ph V	8.77	%
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Accumulated Fault Duty A Ph V	8.77	%
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	9 Month Operations	9	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	General Comments		
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	Totalizer Meter Reading	.8712	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Operations Counter	356	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	General Comments		
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	Oil Temp Present	30	°C
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	Oil Temp Max	40	°C
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	LTC Totalizer Reading	8363.52	kw
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	General Comments	Added nitrogen	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	General Comments		
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Amps C Ø	109.0	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Amps C Ø	152.2	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Amps B Ø	159.2	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Amps A Ø	148.0	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Regulator As Left Counter	4712.1	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	General Comments		
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	LTCC000356	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	LTCC000356	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	LTCC000356	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	LTCC000356	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.1	VAC
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	LTCC000356	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	LTCC000356	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	LTCC000356	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	LTCC000356	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	LTC Operations Since Last Insp	236	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	LTC Min Tap Position	6L	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	LTC Max Tap Position	4L	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	LTC Current Tap Position	4L	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	LTC As Left Counter	2013	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	LTC As Found Counter	2009	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Mechanism Patrol Inspection	General Comments		
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	General Comments		
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	Follow-up Action Required?	n	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	General Comments		
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Trash Emptied?	n	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	General Comments		
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BAT001476	Battery	565-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BAT001476	Battery	565-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BAT001476	Battery	565-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BAT001476	Battery	565-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BAT001476	Battery	565-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BAT001476	Battery	565-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BAT001476	Battery	565-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BAT001476	Battery	565-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BAT001476	Battery	565-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Exp/Missing Not Repl	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BAT001476	Battery	565-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BAT001476	Battery	565-Battery Bank	Battery Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BAT001476	Battery	565-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.2	VDC
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BAT001476	Battery	565-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.1	VDC
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BAT001476	Battery	565-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BAT001476	Battery	565-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	General Comments		
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Amps B Ø	110.0	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Amps A Ø	116.0	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BCH001410	Charger	565-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BCH001410	Charger	565-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BCH001410	Charger	565-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BCH001410	Charger	565-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BCH001410	Charger	565-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BCH001410	Charger	565-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	General Comments		
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Trash Emptied?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	General Comments		
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	n	If Bkr is Closed
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Broom on Site?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	240.0	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	230.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	General Comments		
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Maintenance Operations	2	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Num Operations Last 9 Months	26	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Operations Counter AF	682	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Operations Counter AL	682	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Operations This Read SF6	3	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Switching Operations	1	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Unknown Operations	0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	General Comments		
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LTCC000531	LTCControl	CG-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LTCC000531	LTCControl	CG-TRANS 1	LTC Control Insp	General Comments	OK	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Switching Operations	0	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Operations This Read Vac	0	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Operations Counter AL	293	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Operations Counter AF	293	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Maintenance Operations	0	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Grounds in Place?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	General Comments		
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	General Comments		
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Foundation Condition	Good	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Follow-up Action Required?	n	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Fault Operations Ground	0	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Fault Operations C Ø	0	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	9 Month Operations	4	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Amps A Ø	200.0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Amps B Ø	193.0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Amps C Ø	195.0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Fault Operations A Ø	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Fault Operations B Ø	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Fault Operations C Ø	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Fault Operations Ground	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	General Comments		
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Unknown Operations	0	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Maintenance Operations	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Operations Counter AF	526	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Operations Counter AL	526	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Operations This Read Vac	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Switching Operations	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	9 Month Operations	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Amps A Ø	178.0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Amps B Ø	186.0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Amps C Ø	183.0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Fault Operations A Ø	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Fault Operations B Ø	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Fault Operations C Ø	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Fault Operations Ground	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Maintenance Operations	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Operations Counter AF	201	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Operations Counter AL	201	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Operations This Read Vac	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Switching Operations	0	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Amps A Ø	110.0	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Amps B Ø	105.0	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Amps C Ø	110.0	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BCH000518	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BCH000518	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	General Comments		
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	LTC Max Tap Position	Neutral	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	LTC Current Tap Position	3L	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	LTC As Left Counter	481	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	LTC As Found Counter	481	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Mechanism Patrol Inspection	General Comments		
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	Follow-up Action Required?	n	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	Follow-up Action Required?	n	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	General Comments		
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	909	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	909	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	LOC C Phase	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	60.0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	50.0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	220.0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	200.0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	200.0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	99956	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	99956	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	General Comments		
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Regulator As Left Counter	31446	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	LTC Operations Since Last Insp	182	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	LTC Min Tap Position	Neutral	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BCH000518	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BCH000518	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BCH000518	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BCH000518	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BCH000518	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	LTC Min Tap Position	Neutral	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	LTC As Left Counter	246538	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	LTC As Found Counter	246530	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Mechanism Patrol Inspection	General Comments		
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	General Comments		
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	Follow-up Action Required?	n	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	LTCC000202	LTCCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	LTCC000202	LTCCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	LTCC000202	LTCCControl	Retired Distribution	LTC Control Insp	General Comments		
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	LTCC000202	LTCCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	LTCC000202	LTCCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	LTCC000202	LTCCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	LTCC000202	LTCCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	LTCC000202	LTCCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Regulator As Left Counter	46125	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	General Comments		
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/8/2020 15:25	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0194	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Low	
12/8/2020 15:25	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0194	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/8/2020 15:25	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0194	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/8/2020 15:25	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0194	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
12/8/2020 15:25	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0194	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/8/2020 15:25	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0194	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
12/8/2020 15:25	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0194	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 15:25	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0162	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Very Low	
12/8/2020 15:25	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0162	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/8/2020 15:25	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0162	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/8/2020 15:25	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0162	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
12/8/2020 15:25	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0162	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/8/2020 15:25	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0162	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
12/8/2020 15:25	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0162	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Vegetation	None	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Fault Operations A Ø	0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Amps C Ø	0.0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Amps B Ø	0.0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Amps A Ø	0.0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	9 Month Operations	0	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	7	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	200.0	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	160.0	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	2.94	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	2.94	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	1	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	1	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	335	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	335	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	2	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	LTC Operations Since Last Insp	855	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Mechanism Patrol Inspection	General Comments		
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	General Comments		
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	Follow-up Action Required?	n	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Amps A Ø	133.0	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Amps B Ø	116.0	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Amps C Ø	137.0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Patrol Inspection	General Comments		
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	General Comments		
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Operations Counter	1426	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	4	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	20.0	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	21.0	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	20.0	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	746	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	746	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	General Comments		
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Ambient Temp	35	*F
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	General Comments	lightning arrester still blown 522	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	n	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	LTC Operations Since Last Insp	637	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	LTC Min Tap Position	14L	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	LTC Max Tap Position	2L	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	LTC Current Tap Position	8L	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	LTC As Left Counter	77582	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	LTC As Found Counter	77572	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Mechanism Patrol Inspection	General Comments		
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	General Comments		
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	Follow-up Action Required?	n	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	LTC Operations Since Last Insp	401	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	LTC Min Tap Position	6L	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	LTC Max Tap Position	1R	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	LTC Current Tap Position	2L	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	LTC As Left Counter	85895	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	LTC As Found Counter	85893	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	General Comments		
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Trash Emptied?	n	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	9 Month Operations	23	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Amps A Ø	90.0	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Amps B Ø	65.0	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Amps C Ø	85.0	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Bushing Condition	Good	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Fault Operations A Ø	0	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Fault Operations B Ø	0	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Fault Operations C Ø	0	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Fault Operations Ground	0	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Follow-up Action Required?	n	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Foundation Condition	Good	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	General Comments		
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	General Comments		
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Grounds in Place?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Maintenance Operations	0	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Operations Counter AF	165	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Operations Counter AL	165	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Operations This Read Vac	2	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Switching Operations	2	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.9	VDC
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.9	VDC
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Unknown Operations	0	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	9 Month Operations	25	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Maintenance Operations	0	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Fault Operations B Ø	0	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Fault Operations A Ø	0	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Operations Counter AF	368	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Operations Counter AL	368	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Operations This Read Vac	3	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Switching Operations	3	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Readings	Unknown Operations	0	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Fault Operations A Ø	0	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Fault Operations B Ø	0	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Fault Operations C Ø	0	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Fault Operations Ground	0	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Follow-up Action Required?	n	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Foundation Condition	Good	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	General Comments		
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Grounds in Place?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Maintenance Operations	0	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Operations Counter AF	187	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Operations Counter AL	187	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Operations This Read Vac	0	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Switching Operations	0	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Unknown Operations	0	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Broom on Site?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Bushing Condition	Good	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Amps C Ø	32.0	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Amps B Ø	43.0	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Amps A Ø	66.0	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	9 Month Operations	4	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.3	amps
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Door Alarms OK?	n	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Fault Operations B Ø	0	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	Follow-up Action Required?	n	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Mechanism Patrol Inspection	General Comments		
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	General Comments		
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Current Tap Position	3L	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	LTC As Found Counter	233229	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	LTC As Left Counter	233229	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	LTC Current Tap Position	5L	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	LTC Max Tap Position	2L	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	LTC Min Tap Position	6L	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	LTC Operations Since Last Insp	446	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	Follow-up Action Required?	n	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	General Comments		
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Mechanism Patrol Inspection	General Comments		
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	LTC As Found Counter	61109	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	General Comments		
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Patrol Inspection	General Comments		
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	LTC As Left Counter	61109	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	LTC Current Tap Position	2L	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	LTC Min Tap Position	4L	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	LTC Operations Since Last Insp	236	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Amps A Ø	130.0	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Amps B Ø	75.0	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Amps C Ø	70.0	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Bushing Condition	Good	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Fault Operations A Ø	0	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Fault Operations B Ø	0	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Fault Operations C Ø	0	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Fault Operations Ground	0	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Follow-up Action Required?	n	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Foundation Condition	Good	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	General Comments		
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	General Comments		
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Grounds in Place?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Maintenance Operations	0	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Operations Counter AF	155	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Operations Counter AL	155	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Operations This Read Vac	2	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Switching Operations	2	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Unknown Operations	0	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Tank Leaks	None	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Regulator As Left Counter	97338	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Min Tap Position	3L	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Max Tap Position	3L	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Unknown Operations	0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Switching Operations	0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Operations This Read Vac	0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Operations Counter AL	149	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Operations Counter AF	149	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Maintenance Operations	0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	General Comments	RACKED OUT no faults showing previous reading wong	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Patrol Inspection	General Comments		
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Follow-up Action Required?	n	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Fault Operations Ground	0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Fault Operations C Ø	0	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	397	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	397	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Unknown Operations	0	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Switching Operations	1	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Operations This Read Vac	2	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Operations Counter AL	185	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Operations Counter AF	185	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Maintenance Operations	1	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Grounds in Place?	y	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	General Comments	Switch load/TC	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	General Comments		
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Foundation Condition	Good	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Follow-up Action Required?	n	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Fault Operations Ground	0	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Fault Operations C Ø	0	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Fault Operations B Ø	0	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Fault Operations A Ø	0	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Bushing Condition	Good	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	9 Month Operations	3	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Amps A Ø	150.0	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Amps B Ø	100.0	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Amps C Ø	150.0	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Bushing Condition	Good	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Fault Operations A Ø	0	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Broom on Site?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Acceptable Building Appearance?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Fault Operations B Ø	0	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Fault Operations C Ø	0	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Fault Operations Ground	0	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Follow-up Action Required?	n	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Foundation Condition	Good	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	General Comments		
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	General Comments		
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Grounds in Place?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Maintenance Operations	1	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	BCH000851	Charger	100-Battery Charger 2	Battery Charger Patrol Insp	General Comments		
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	BCH000851	Charger	100-Battery Charger 2	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	BCH000851	Charger	100-Battery Charger 2	Battery Charger Patrol Insp	As Left Float Voltage	55.4	VDC
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	BCH000851	Charger	100-Battery Charger 2	Battery Charger Patrol Insp	As Found Float Voltage	55.4	VDC
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	0	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	80.0	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	70.0	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	112.0	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Switching Operations	0	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Unknown Operations	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	581	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	581	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Unknown Operations	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Switching Operations	1	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Operations This Read Vac	1	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Operations Counter AL	340	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Operations Counter AF	340	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Maintenance Operations	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Fault Operations Ground	0	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	9 Month Operations	3	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	432	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	432	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Fault Operations C Ø	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Fault Operations B Ø	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Fault Operations A Ø	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Amps C Ø	40.0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Amps B Ø	40.0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Amps A Ø	40.0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	9 Month Operations	1	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Unknown Operations	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Switching Operations	6	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Operations This Read Vac	6	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Operations Counter AL	360	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Operations Counter AF	360	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Maintenance Operations	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	General Comments	This breaker is now 14KV Bus Tie 1-2. Please change in Cascade.	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Follow-up Action Required?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Fault Operations Ground	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Fault Operations C Ø	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Fault Operations B Ø	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Fault Operations A Ø	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Amps A Ø	20.0	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Amps B Ø	50.0	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	General Comments		
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Max Tap Position	4L	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Min Tap Position	11L	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	12	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Regulator As Left Counter	28804	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	Actual Counter	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	General Comments		
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Max Tap Position	3L	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Min Tap Position	11L	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Regulator As Left Counter	30428	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Operations Counter AF	143	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Operations Counter AL	143	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Operations This Read Vac	1	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	General Comments		
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Min Tap Position	8L	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Regulator As Left Counter	94087	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Tank Leaks	None	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Reading	.6930	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Present	35	°C
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Max	60	°C
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	LTC Totalizer Reading	3326.40	kw
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	General Comments		
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Vegetation	None	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	General Comments		
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Current Tap Position	1L	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	General Comments		
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Max Tap Position	2R	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Min Tap Position	8L	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Regulator As Left Counter	120716	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Tank Leaks	None	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Tank Leaks	None	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Regulator As Left Counter	208725	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Min Tap Position	9L	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Max Tap Position	3L	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	General Comments		
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Current Tap Position	6L	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Current Tap Position	3L	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	General Comments		
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	BCH001293	Charger	802-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	BCH001293	Charger	802-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	BCH001293	Charger	802-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	BCH001293	Charger	802-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	BCH001293	Charger	802-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	BCH001293	Charger	802-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.3	VDC
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	BCH001293	Charger	802-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.3	VDC
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	BCH001293	Charger	802-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	General Comments	House needs new heater.	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Floor Swept?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	General Comments		
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	n	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Evidence of Insects	None	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Control House Lighting OK?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	9 Month Operations	4	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Ambient Temp	40	*F
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	General Comments		
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Ambient Temp	35	*F
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Vegetation	None	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	General Comments		
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Ambient Temp	45	*F
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	General Comments		
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Vegetation	None	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/8/2020 13:03	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	850	psi
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	Oil Temp Max	65	*C
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	Oil Temp Present	45	*C
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 15:25	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0236	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/8/2020 15:25	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0236	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/8/2020 15:25	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0236	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/8/2020 15:25	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0236	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
12/8/2020 15:25	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0236	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
12/8/2020 15:25	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0236	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	9 Month Operations	2	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	General Comments		
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	General Comments	will need nitrogen soon	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	65	°C
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	45	°C
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	General Comments		
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.1	VDC
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	All Identified and Legible?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	Totalizer Meter Reading	.5556	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	ANN000019	Annunciator	CG-Annunciator Panel	Annunciator Patrol Inspection	General Comments		
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	ANN000019	Annunciator	CG-Annunciator Panel	Annunciator Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	ANN000019	Annunciator	CG-Annunciator Panel	Annunciator Patrol Inspection	ESOC Received Alarm Test?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	ANN000019	Annunciator	CG-Annunciator Panel	Annunciator Patrol Inspection	Control House Alarm Audible?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	ANN000019	Annunciator	CG-Annunciator Panel	Annunciator Patrol Inspection	All Lights Functioning?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Radiator Leaks	Seeping	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	Oil Temp Present	18	°C
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	Oil Temp Max	64	°C
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	LTC Totalizer Reading	5333.76	kw
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	General Comments	Cleaned up old oil diapers and put down new.	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	General Comments		
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	LTC As Found Counter	39370	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	LTC As Left Counter	39370	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	LTC Current Tap Position	9L	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4L	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	LTC Min Tap Position	11L	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	48	°C
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1126	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Fault Operations A Ø	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Fault Operations B Ø	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Fault Operations C Ø	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Fault Operations Ground	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Follow-up Action Required?	n	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	General Comments	Actual counter	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Maintenance Operations	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Operations Counter AF	72	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Operations Counter AL	72	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Operations This Read Vac	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Readings	Switching Operations	0	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Patrol Inspection	General Comments		
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	General Comments		
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Maintenance Operations	2	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Num Operations Last 9 Months	7	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Operations Counter AF	85	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Operations Counter AL	85	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Operations This Read SF6	3	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Switching Operations	1	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Unknown Operations	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	9 Month Operations	5	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Amps A Ø	50.0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Amps B Ø	50.0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Amps C Ø	50.0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Fault Operations A Ø	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Fault Operations B Ø	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Fault Operations C Ø	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Fault Operations Ground	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Follow-up Action Required?	n	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	General Comments	IOC B and C phase	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Maintenance Operations	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Operations Counter AF	117	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Operations Counter AL	117	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Operations This Read Vac	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Readings	Switching Operations	0	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Wood Structures OK?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Ground Connections Intact?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	General Comments		
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Follow-up Action Required?	n	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	60.0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	10	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Unknown Operations	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Switching Operations	1	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Operations This Read Vac	24	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Operations Counter AL	376	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Operations Counter AF	376	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Maintenance Operations	23	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	General Comments	X	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Fault Operations Ground	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Fault Operations C Ø	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Fault Operations B Ø	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Fault Operations A Ø	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Amps C Ø	96.0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Amps B Ø	116.0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Amps A Ø	87.0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	9 Month Operations	26	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	9 Month Operations	11	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	214	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	LTC Min Tap Position	5L	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	LTC Max Tap Position	13L	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	LTC As Left Counter	2626	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	LTC As Found Counter	2626	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	General Comments		
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	335	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	LTC Min Tap Position	12L	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	LTC Max Tap Position	1R	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	LTC Current Tap Position	8L	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	LTC As Left Counter	86242	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	LTC As Found Counter	86242	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Amps C Ø	35.0	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Bushing Condition	Good	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Fault Operations A Ø	0	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Fault Operations B Ø	0	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Fault Operations C Ø	0	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Fault Operations Ground	0	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Follow-up Action Required?	n	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Foundation Condition	Good	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	General Comments		
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	General Comments		
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Grounds in Place?	y	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Maintenance Operations	0	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Operations Counter AF	215	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Operations Counter AL	215	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Amps C Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Amps B Ø	0.0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Amps A Ø	0.0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Readings	9 Month Operations	21	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Operations This Read Vac	0	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Switching Operations	0	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 8:42	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Unknown Operations	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	LTCC000400	LTCControl	683-1	LTC Control Insp	All Connections OK?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	LTCC000400	LTCControl	683-1	LTC Control Insp	Follow-up Action Required?	n	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	LTCC000400	LTCControl	683-1	LTC Control Insp	General Comments		
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	LTCC000400	LTCControl	683-1	LTC Control Insp	LTC Operation Checked?	y	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	LTCC000400	LTCControl	683-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	LTCC000400	LTCControl	683-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	LTCC000400	LTCControl	683-1	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	LTCC000400	LTCControl	683-1	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	LTCC000400	LTCControl	683-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	80.0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	60.0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Maintenance Operations	0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Operations Counter AF	222	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Operations Counter AL	222	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Operations This Read Vac	0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Switching Operations	0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Unknown Operations	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Unknown Operations	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Switching Operations	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Operations This Read Vac	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Operations Counter AL	347	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Operations Counter AF	347	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Maintenance Operations	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	General Comments		
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Switching Operations	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Operations This Read Vac	3	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Operations Counter AL	180	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Operations Counter AF	180	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Maintenance Operations	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	General Comments	IOC B phase, Actual counter	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Follow-up Action Required?	n	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Fault Operations Ground	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Fault Operations C Ø	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Fault Operations B Ø	3	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Fault Operations A Ø	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Fault Adjusted Amps B Phase V	33.54	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Fault Operations Ground	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Fault Operations C Ø	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Fault Operations B Ø	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Fault Operations A Ø	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Amps C Ø	650.0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Amps B Ø	650.0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Amps A Ø	650.0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	9 Month Operations	2	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Switching Operations	14	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Operations This Read Vac	14	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Amps C Ø	100.0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Amps B Ø	140.0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Amps A Ø	170.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Readings	9 Month Operations	12	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Operations Counter AL	363	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Operations Counter AF	363	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Maintenance Operations	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	General Comments	X	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Follow-up Action Required?	n	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	General Comments		
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	General Comments		
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2851.20	kw
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Oil Temp Max	34	°C
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Oil Temp Present	18	°C
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5940	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Winding Temp Max	30	°C
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Winding Temp Present	17	°C
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	General Comments		
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Amps A Ø	104.0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Amps B Ø	104.0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Amps C Ø	102.0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Fault Operations A Ø	0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Fault Operations B Ø	0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Fault Operations C Ø	0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Fault Operations Ground	0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	Follow-up Action Required?	n	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Patrol Inspection	General Comments		
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Readings	General Comments		
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	138.0	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	146.0	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	145.0	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	Totalizer Meter Reading	.0396	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	Oil Temp Present	22	°C
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	Oil Temp Max	84	°C
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	LTC Totalizer Reading	126.72	kw
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	General Comments		
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Vegetation	None	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	General Comments		
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	35	°F
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	General Comments		
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	LTCC000261	LTCControl	793-1	LTC Control Insp	All Connections OK?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	LTCC000261	LTCControl	793-1	LTC Control Insp	Follow-up Action Required?	n	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	LTCC000261	LTCControl	793-1	LTC Control Insp	General Comments		
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	LTCC000261	LTCControl	793-1	LTC Control Insp	LTC Operation Checked?	y	
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	LTCC000261	LTCControl	793-1	LTC Control Insp	LTC Output Voltage Level	123.4	VAC
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	LTCC000261	LTCControl	793-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	LTCC000261	LTCControl	793-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/8/2020 10:50	Distribution	Leitchfield City Quarterly Inspection	LTCC000261	LTCControl	793-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	Follow-up Action Required?	n	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	General Comments		
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	LTC As Found Counter	302449	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	LTC As Left Counter	302449	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	LTC Current Tap Position	9L	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	LTC Max Tap Position	2L	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	LTC Min Tap Position	13L	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	LTC Operations Since Last Insp	704	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	LTC Max Tap Position	2L	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	LTC Min Tap Position	9L	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	LTC Operations Since Last Insp	512	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	General Comments		
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Capacitor Condition	Good	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Bushing Condition	Good	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	All Connections OK?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?		
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	9 Month Operations	0	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Amps A Ø	60.0	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Amps B Ø	80.0	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Amps C Ø	60.0	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Bushing Condition	Good	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Switching Operations	0	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	General Comments		
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	Follow-up Action Required?	n	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Amps A Ø	95.0	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Warning Signs OK?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Amps B Ø	105.0	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Amps C Ø	100.0	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Fault Operations	0	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Follow-up Action Required?	n	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	General Comments		
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Tank Leaks	None	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Grounds in Place?	y	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	General Comments		
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Foundation Condition	Good	
12/8/2020 15:40	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Maintenance Operations	0	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Num Operations Last 9 Months	12	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Operations Counter AF	399	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Operations Counter AL	399	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Operations This Read SF6	1	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Switching Operations	1	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Unknown Operations	0	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	General Comments		
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Mechanism Patrol Inspection	General Comments		
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	LTC As Found Counter	5801	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	LTC As Left Counter	5801	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/8/2020 8:02	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	LTC Current Tap Position	5L	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Fault Operations A Ø	0	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Fault Operations B Ø	0	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Fault Operations C Ø	0	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Fault Operations Ground	0	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Follow-up Action Required?	n	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	General Comments		
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	General Comments		
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	Follow-up Action Required?	n	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	General Comments		
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Mechanism Patrol Inspection	General Comments		
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	LTC As Found Counter	20298	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	LTC As Left Counter	20298	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	LTC Current Tap Position	1L	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	LTC Max Tap Position	2R	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	LTC Min Tap Position	5L	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	LTC Operations Since Last Insp	586	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Foundation Condition	Good	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	9 Month Operations	31	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	General Comments		
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	General Comments		
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Grounds in Place?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Amps A Ø	114.0	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Amps B Ø	121.0	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Amps C Ø	114.0	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Bushing Condition	Good	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Fault Operations Ground	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Maintenance Operations	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Operations Counter AF	410	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Operations Counter AL	410	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Operations This Read Vac	4	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Switching Operations	4	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	9 Month Operations	6	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Amps A Ø	110.0	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Amps B Ø	90.0	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Amps C Ø	130.0	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Bushing Condition	Good	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	Totalizer Meter Reading	.9362	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	Oil Temp Present	30	°C
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	Oil Temp Max	50	°C
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	LTC Totalizer Reading	6740.64	kw
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Max Tap Position	8L	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Min Tap Position	14L	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Regulator As Left Counter	61933	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Fault Operations A Ø	0	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Fault Operations B Ø	0	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Fault Operations C Ø	0	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Fault Operations Ground	0	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Follow-up Action Required?	n	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Foundation Condition	Good	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	General Comments		
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	General Comments		
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Grounds in Place?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Maintenance Operations	0	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Operations Counter AF	168	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Operations Counter AL	168	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Operations This Read Vac	0	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Switching Operations	0	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Unknown Operations	0	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	99957	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	99957	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Maintenance Operations	1	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Bushing Condition	Good	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Amps C Ø	0.0	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Amps B Ø	0.0	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Amps A Ø	0.0	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	9 Month Operations	10	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Operations Counter AF	116	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Operations Counter AL	116	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Operations This Read Vac	1	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Switching Operations	0	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Unknown Operations	0	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	General Comments		
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Ambient Temp	45	*F
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Current Tap Position	8L	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	General Comments		
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	BCH001274	Charger	771-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.1	VDC
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	BCH001274	Charger	771-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	BCH001274	Charger	771-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	BCH001274	Charger	771-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	*F
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Fault Operations A Ø	0	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Fault Operations B Ø	0	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Fault Operations C Ø	0	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Fault Operations Ground	0	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Follow-up Action Required?	n	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Foundation Condition	Good	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	General Comments		
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	General Comments		
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Grounds in Place?	y	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Maintenance Operations	0	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Operations Counter AF	235	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Operations Counter AL	235	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Operations This Read Vac	0	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Switching Operations	0	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Operations Counter AF	174	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Maintenance Operations	0	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Grounds in Place?	y	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	General Comments		
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.1	VDC
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Positive DC Ground	29.0	VDC
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Winding Temp Max	45	°C
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Patrol Inspection	General Comments		
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	General Comments		
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Maintenance Operations	0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Operations Counter AF	150	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Operations Counter AL	150	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Operations This Read Vac	1	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Switching Operations	1	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Unknown Operations	0	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	PF000075	PowerFuse	CS-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	PF000075	PowerFuse	CS-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Oil Temp Max	35	°C
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
12/8/2020 15:25	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0217	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments	No longer here	
12/8/2020 15:25	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0217	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	y	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	LTCC000843	LTCControl	100-7	LTC Control Insp	All Connections OK?	y	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	LTCC000843	LTCControl	100-7	LTC Control Insp	Follow-up Action Required?	n	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	LTCC000843	LTCControl	100-7	LTC Control Insp	General Comments	Found at 126,7Vac	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	LTCC000843	LTCControl	100-7	LTC Control Insp	LTC Operation Checked?	y	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Unknown Operations	0	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Switching Operations	0	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	LTCC000843	LTCControl	100-7	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	LTCC000843	LTCControl	100-7	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	LTCC000843	LTCControl	100-7	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	LTCC000843	LTCControl	100-7	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	LTCC000843	LTCControl	100-7	LTC Control Insp	VRR Time Delay	30	Seconds
12/8/2020 14:03	Distribution	Livermore Quarterly Inspection	BCH001274	Charger	771-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.1	VDC
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Operations This Read Vac	0	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Operations Counter AL	174	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	9 Month Operations	4	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Amps A Ø	80.0	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Amps B Ø	75.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Amps C Ø	105.0	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Bushing Condition	Good	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Regulator As Left Counter	3414	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Fault Operations Ground	0	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Fault Operations C Ø	0	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Unknown Operations	0	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Fault Operations B Ø	0	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Fault Operations A Ø	0	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Bushing Condition	Good	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Amps C Ø	300.0	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Amps B Ø	300.0	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Amps A Ø	300.0	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	9 Month Operations	4	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Current Tap Position	1R	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	General Comments		
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	General Comments		
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	General Comments		
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Foundation Condition	Good	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Follow-up Action Required?	n	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Regulator As Left Counter	12063	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Min Tap Position	12L	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Max Tap Position	2L	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	General Comments		
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 12:29	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Fault Operations Ground	0	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Fault Operations A ∅	0	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Fault Operations B ∅	0	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Fault Operations C ∅	0	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Fault Operations Ground	0	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Follow-up Action Required?	n	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Foundation Condition	Good	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	General Comments		
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	General Comments		
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Grounds in Place?	y	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Maintenance Operations	0	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Fault Operations A ∅	0	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Fault Operations B ∅	0	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Fault Operations C ∅	0	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Fault Operations Ground	0	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Follow-up Action Required?	n	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Foundation Condition	Good	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	General Comments		
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	General Comments		
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Grounds in Place?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Maintenance Operations	0	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Operations Counter AF	196	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Operations Counter AL	196	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Operations This Read Vac	0	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Switching Operations	0	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Unknown Operations	0	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Radiator Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	Oil Temp Present	50	°C
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	Oil Temp Max	55	°C
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	General Comments		
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	General Comments		
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	Follow-up Action Required?	n	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/8/2020 12:51	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	9 Month Operations	0	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	PF000358	PowerFuse	SH-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	OK	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	PF000358	PowerFuse	SH-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	PF000357	PowerFuse	SH-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	PF000357	PowerFuse	SH-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Operations This Read Vac	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Operations Counter AL	324	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Amps A Ø	148.0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Operations Counter AF	324	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Maintenance Operations	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Follow-up Action Required?	n	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Amps B Ø	170.0	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Amps C Ø	132.0	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Bushing Condition	Good	
12/8/2020 13:26	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	General Comments		
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Vegetation	None	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Fault Operations A Ø	0	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Fault Operations B Ø	0	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	Oil Temp Present	35	°C
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	704.16	kw
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	General Comments	fans not hooked up	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	General Comments		
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 15:25	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0217	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/8/2020 15:25	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0217	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/8/2020 15:25	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0217	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/8/2020 15:25	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0217	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Fault Operations C Ø	0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Fault Operations Ground	0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Follow-up Action Required?	n	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Operations Counter AF	388	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Operations Counter AL	388	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Operations This Read Vac	0	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Switching Operations	0	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Unknown Operations	0	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	Totalizer Meter Reading	.8802	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Ambient Temp	34	°F
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Fault Operations C Ø	0	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	PF000076	PowerFuse	CS-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	PF000076	PowerFuse	CS-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	PF000076	PowerFuse	CS-12KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	PF000075	PowerFuse	CS-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Fault Operations B Ø	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Fault Operations A Ø	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Amps C Ø	550.0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Amps B Ø	567.0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Amps A Ø	539.0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	9 Month Operations	2	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	9 Month Operations	1	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Amps A Ø	0.0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Amps B Ø	0.0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Amps C Ø	0.0	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2020 14:42	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/8/2020 11:44	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Vegetation	None	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Fault Operations	0	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Ambient Temperature	36	*F
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	PF000359	PowerFuse	SH-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	PF000359	PowerFuse	SH-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	General Comments		
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	40	*F
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	BCH001181	Charger	556-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	BCH001181	Charger	556-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	BCH001181	Charger	556-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	BCH001181	Charger	556-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	BCH001181	Charger	556-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	BCH001181	Charger	556-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
12/8/2020 11:47	Distribution	Leitchfield East Quarterly Inspection	BCH001181	Charger	556-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Switching Operations	1	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	SF6 Pressure Indicator	good	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	SF6 Pressure	67	psi
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	SF6 Bushing Condition	Good	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Operations This Read SF6	1	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Operations Counter AL	45	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Operations Counter AF	45	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Num Operations Last 9 Months	3	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	General Comments		
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Vegetation	None	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Vegetation	None	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	All Identified and Legible?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/8/2020 14:10	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	General Comments		
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	PF000356	PowerFuse	SH-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Maintenance Operations	0	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Heaters (All) Functioning?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Grounds in Place?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	General Comments	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	General Comments		
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Gauge(s) Condition	Good	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Foundation Condition	Good	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Follow-up Action Required?	n	
12/8/2020 13:28	Distribution	Shively Quarterly Inspection	PF000356	PowerFuse	SH-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	General Comments		
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Follow-up Action Required?	n	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Foundation Condition	Good	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Tank Leaks	None	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Regulator As Left Counter	120164	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Min Tap Position	7L	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Max Tap Position	3L	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	°F
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	General Comments		
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Current Tap Position	4L	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	9 Month Operations	41	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Amps A Ø	0.0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Amps B Ø	0.0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Amps C Ø	0.0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Fault Operations A Ø	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Fault Operations B Ø	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Fault Operations C Ø	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Fault Operations Ground	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	General Comments	X	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Maintenance Operations	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Operations Counter AF	378	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Operations Counter AL	378	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Operations This Read Vac	2	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Switching Operations	2	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Unknown Operations	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	9 Month Operations	39	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Amps A Ø	0.0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Amps B Ø	0.0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Amps C Ø	0.0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Fault Operations A Ø	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Fault Operations B Ø	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Fault Operations C Ø	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Fault Operations Ground	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Maintenance Operations	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Operations Counter AF	367	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Operations Counter AL	367	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Operations This Read Vac	1	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Switching Operations	1	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Readings	Unknown Operations	0	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	General Comments		
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	General Comments		
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Grounds in Place?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Foundation Condition	Good	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	General Comments		
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Ground Connections Intact?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	General Comments		
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	General Comments		
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	35	*F
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Operating Linkage OK?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/8/2020 14:03	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Ambient Temp	36	*F
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/8/2020 8:13	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	9 Month Operations	14	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Amps A Ø	10.0	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Amps B Ø	10.0	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Amps C Ø	10.0	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Bushing Condition	Good	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.9	VDC
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.2	VDC
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	General Comments	heater not working	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Fault Operations A Ø	0	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Fault Operations B Ø	0	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Fault Operations C Ø	0	
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Fault Operations Ground	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	9 Month Operations	30	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Switching Operations	1	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Operations Counter AL	355	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Operations Counter AF	355	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Operations This Read Vac	21	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Maintenance Operations	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Fault Operations Ground	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Fault Operations C Ø	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Fault Operations B Ø	0	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Maintenance Operations	0	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Operations Counter AF	629	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Operations Counter AL	629	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Operations Counter AL	376	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Fault Operations A Ø	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Operations Counter AF	376	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	100.0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	100.0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	100.0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Maintenance Operations	20	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	General Comments	X	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Operations This Read Vac	0	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	12	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Fault Operations Ground	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Fault Operations C Ø	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Fault Operations B Ø	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Fault Operations A Ø	0	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Fault Operations A Ø	0	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Fault Operations B Ø	0	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Fault Operations C Ø	0	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Fault Operations A Ø	0	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1000	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1000	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Unknown Operations	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Switching Operations	1	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Fault Operations B Ø	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Fault Operations C Ø	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Fault Operations Ground	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	General Comments	X	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Fault Operations Ground	0	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Maintenance Operations	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Operations Counter AF	434	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Follow-up Action Required?	n	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Foundation Condition	Good	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	General Comments		
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	General Comments		
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Grounds in Place?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Operations Counter AL	434	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Operations This Read Vac	1	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Operations This Read Vac	1	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	9 Month Operations	6	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/8/2020 12:49	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	9 Month Operations	51	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Amps A Ø	260.0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Amps B Ø	280.0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Amps C Ø	290.0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Amps A Ø	60.0	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Switching Operations	0	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Tank Paint Condition	Good	
12/8/2020 7:45	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Unknown Operations	0	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	General Comments		
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	General Comments		
12/8/2020 13:41	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	9 Month Operations	30	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Fault Operations A Ø	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Fault Operations B Ø	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	General Comments		
12/8/2020 10:24	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Amps C Ø	90.0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Amps B Ø	89.0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Amps A Ø	107.0	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/8/2020 12:14	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	General Comments		
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Amps C Ø	190.0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Amps B Ø	190.0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Amps A Ø	190.0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/8/2020 15:15	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Amps C Ø	60.0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Readings	Amps B Ø	60.0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Readings	Switching Operations	1	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	19	°C
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	50	°C
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Battery Load Check OK?	n	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Min Tap Position	2L	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	19	°C
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	51	°C
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	19	°C
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	50	°C
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Max Tap Position	5R	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	Oil Temp Present	19	°C
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	Oil Temp Max	48	°C
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Regulator As Left Counter	203139	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	400	psi
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	General Comments	the Ann panel test and normal switch is backwards. Pic sent to Stinson	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	General Comments		
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	General Comments		
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Ambient Temp	36	*F
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	General Comments	n/a	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Mechanism Patrol Inspection	General Comments	n/a	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	LTC As Found Counter	178655	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	LTC As Left Counter	178655	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	LTC Current Tap Position	4R	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	LTC Max Tap Position	6R	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	LTC Min Tap Position	6L	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	LTC Operations Since Last Insp	294	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	General Comments		
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	48	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	48	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Amps C Ø	51.0	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Amps B Ø	50.0	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Amps A Ø	45.0	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Amps A Ø	50.0	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Amps B Ø	33.0	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Amps C Ø	41.0	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	General Comments		
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Operations Counter	452	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	Follow-up Action Required?	n	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Vegetation	None	
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	General Comments		
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Ambient Temp	33	°F
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Follow-up Action Required?	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	General Comments	Need more gravel on fence line. Address sign is missing from fence.	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Amps A Ø	105.0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	9 Month Operations	3	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Grounds in Place?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	General Comments	n/a	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	General Comments	n/a	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Follow-up Action Required?	n	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Fault Operations Ground	0	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Fault Operations C Ø	0	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Fault Operations B Ø	0	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Fault Operations A Ø	0	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Operations Counter	95	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Ambient Temp	35	*F
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Amps C Ø	265	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Amps B Ø	325	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Amps A Ø	325	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Accumulated Fault Duty C Ph V	0	%
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Accumulated Fault Duty B Ph V	0	%
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Accumulated Fault Duty A Ph V	0	%
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	9 Month Operations	0	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Amps C Ø	100.0	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Amps B Ø	120.0	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Amps A Ø	100.0	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0688	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	General Comments		
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Current Tap Position	5R	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Amps A Ø	0.0	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Amps B Ø	12.0	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Amps C Ø	0.0	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Battery Load Check OK?	n	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Vegetation	None	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	General Comments		
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Fault Operations Ground	0	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Fault Operations C Ø	0	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Follow-up Action Required?	n	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Fault Operations B Ø	0	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Fault Operations A Ø	0	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Fault Adjusted Amps C Phase V	0	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Unknown Operations	0	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Switching Operations	0	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Operations This Read Vac	0	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Operations Counter AL	157	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Operations Counter AF	157	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Maintenance Operations	0	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Fault Adjusted Amps B Phase V	0	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Fault Adjusted Amps A Phase V	0	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Unknown Operations	2	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Switching Operations	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Operations This Read Vac	2	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Operations Counter AL	285	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Operations Counter AF	285	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Maintenance Operations	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Patrol Inspection	General Comments		
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Follow-up Action Required?	n	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Fault Operations Ground	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Fault Operations C Ø	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Fault Operations B Ø	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Fault Operations A Ø	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Fault Adjusted Amps C Phase V	22.36	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Fault Adjusted Amps B Phase V	22.36	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Fault Adjusted Amps A Phase V	22.36	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Amps C Ø	113.0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Amps B Ø	124.0	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Fault Adjusted Amps A Phase V	0	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	General Comments		
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Amps C Ø	104.0	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Amps B Ø	76.0	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Amps A Ø	66.0	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Fault Adjusted Amps B Phase V	0	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Fault Adjusted Amps C Phase V	0	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Fault Operations A Ø	0	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Fault Operations B Ø	0	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Fault Operations C Ø	0	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Fault Operations Ground	0	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Follow-up Action Required?	n	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	General Comments		
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	General Comments		
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Grounds in Place?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Operations Counter	34	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Maintenance Operations	0	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Operations Counter AF	346	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Operations Counter AL	346	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Operations This Read Vac	0	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Switching Operations	0	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Unknown Operations	0	
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	9 Month Operations	34	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Accumulated Fault Duty A Ph V	1.83	%
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	144	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	144	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	9 Month Operations	4	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Accumulated Fault Duty B Ph V	1.83	%
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Accumulated Fault Duty C Ph V	0	%
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Amps A Ø	55	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Amps B Ø	80	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Amps C Ø	45	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	General Comments		
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Operations Counter	81	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	General Comments		
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	General Comments		
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	General Comments		
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Grounds in Place?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Maintenance Operations	0	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Operations Counter AF	227	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Operations Counter AL	227	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Operations This Read Vac	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Switching Operations	0	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Unknown Operations	0	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Vegetation	None	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	General Comments		
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Ambient Temp	34	°F
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	PF000260	PowerFuse	NA-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	PF000260	PowerFuse	NA-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	PF000259	PowerFuse	NA-12KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	PF000259	PowerFuse	NA-12KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	PF000257	PowerFuse	NA-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	PF000257	PowerFuse	NA-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	PF000256	PowerFuse	NA-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	PF000256	PowerFuse	NA-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	PF000255	PowerFuse	NA-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	PF000255	PowerFuse	NA-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	3	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	94.0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	101.0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	118.0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	130	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	130	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	7	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Max Tap Position	10R	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	General Comments		
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	General Comments	n/a	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Current Tap Position	Neutral	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	General Comments		
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Ambient Temp	36	*F
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	General Comments		
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	General Comments		
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	9 Month Operations	0	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	General Comments	N/A	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Current Tap Position	Neutral	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BCH000495	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BCH000495	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BCH000495	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BCH000495	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BCH000495	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BCH000495	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BCH000495	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments	N/A	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	General Comments		
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Max Tap Position	7R	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Regulator As Left Counter	46995	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	LTC Operations Since Last Insp	157	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	LTC Min Tap Position	5L	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	LTC Max Tap Position	5L	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	LTC Current Tap Position	5L	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	LTC As Left Counter	84582	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	BCH000136	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	8.500	millivolts
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	BCH000136	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	133.7	VDC
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	BCH000136	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	133.7	VDC
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	BCH000136	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	5.0	amps
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	BCH000136	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	BCH000136	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	BCH000136	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	BCH000136	Charger	Retired Distribution	Battery Charger Patrol Insp	Ground Lights	None	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	General Comments		
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	32	°C
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	74	°C
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	45	°C
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	70	°C
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	40	°C
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	60	°C
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	30.00	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	Oil Temp Max	55	°C
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	General Comments	2nd fan from bottom to the right of the Control cabinet making bad sound	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	General Comments		
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	n	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?		
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Regulator As Left Counter	79891	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Max Tap Position	6L	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	General Comments	Drag hand cable seems to be broke.	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Follow-up Action Required?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Regulator As Left Counter	76374	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Min Tap Position	Neutral	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Max Tap Position	8R	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	General Comments		
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Ambient Temp	44	°F
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Regulator As Left Counter	171712	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	General Comments		
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Vegetation	None	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	General Comments		
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Ambient Temp	35	°F
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	General Comments		
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	General Comments		
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	General Comments	N/A	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Operations Counter	96	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	General Comments		
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Amps C Ø	41.0	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Amps B Ø	37.0	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Amps A Ø	31.0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	PF000258	PowerFuse	NA-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	PF000258	PowerFuse	NA-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	General Comments	n/a	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Vegetation	None	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Regulator As Left Counter	51980	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.1	volts
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	General Comments		
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Current Tap Position	6R	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	General Comments		
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Vegetation	None	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	General Comments		
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	General Comments		
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	149	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	149	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	General Comments		
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Vegetation	None	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	General Comments		
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Ambient Temp	36	*F
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Trash Emptied?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	General Comments	1 8ft bulb not working by door, replaced bulb and still nothing	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Follow-up Action Required?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	General Comments		
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	11	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	83.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	122.0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	90.0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Regulator As Left Counter	64021	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Min Tap Position	6L	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Max Tap Position	2R	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	General Comments		
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Current Tap Position	2L	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	554	
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments	Reclosure is open	
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 12:26	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	B phase Trip	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	50	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	50	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Vegetation	None	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Regulator As Left Counter	207039	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Min Tap Position	Neutral	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Max Tap Position	7R	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	General Comments		
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Current Tap Position	6R	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	General Comments		
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	35	°C
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	55	°C
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	30	°C
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	55	°C
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	35	°C
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	55	°C
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	Oil Temp Present	30	°C
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	Oil Temp Max	50	°C
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-5	psi
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	General Comments	Trans needs nitrogen	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	278.0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	416.0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	390.0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Control House Lighting OK?	n	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	36	°F
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	N/A	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Broom on Site?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Max Tap Position	10R	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	122.8	volts
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Regulator As Left Counter	53745	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	424.0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	438.0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	373.0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Operations Counter AL	168	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Operations This Read Vac	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Switching Operations	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Unknown Operations	0	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Amps C Ø	47.0	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Amps B Ø	42.0	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Amps A Ø	43.0	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	General Comments		
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	General Comments		
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Tank Leaks	None	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Regulator As Left Counter	67652	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Min Tap Position	4L	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Max Tap Position	4R	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	General Comments		
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Regulator As Left Counter	298174	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Amps A Ø	270.0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Amps B Ø	268.0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Amps C Ø	250.0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Fault Operations A Ø	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Fault Operations B Ø	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Fault Operations C Ø	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Fault Operations Ground	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Follow-up Action Required?	n	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Patrol Inspection	General Comments		
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	9 Month Operations	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Amps A Ø	0.0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Amps B Ø	0.0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Amps C Ø	1.0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Fault Operations A Ø	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Fault Operations B Ø	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Fault Operations C Ø	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Fault Operations Ground	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Follow-up Action Required?	n	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Patrol Inspection	General Comments		
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	General Comments		
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Maintenance Operations	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Operations Counter AF	168	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	General Comments		
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Maintenance Operations	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Operations Counter AF	194	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Operations Counter AL	194	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Operations This Read Vac	0	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Switching Operations	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Unknown Operations	0	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Operations Counter	60	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	General Comments		
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?		
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	82.0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	108.0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	99.0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Ambient Temp	36	°F
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	ARC sense A phase	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	141	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	141	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Tank Leaks	None	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Current Tap Position	1R	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Tank Leaks	None	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Regulator As Left Counter	62613	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	LTC As Found Counter	84582	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	General Comments	drag hands are stuck	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Mechanism Patrol Inspection	General Comments		
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	Follow-up Action Required?	n	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Min Tap Position	8L	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Max Tap Position	2L	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	General Comments		
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Vegetation	None	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	General Comments	n/a	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	ARC Sense A, B, and C phase	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	219.0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	238.0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	131.0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	15	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	239.0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	240.0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	169.0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	ARC sense A and C Phase	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	97	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	97	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	9 Month Operations	34	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Accumulated Fault Duty A Ph V	0	%
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Accumulated Fault Duty B Ph V	0	%
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Accumulated Fault Duty C Ph V	0	%
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Amps A Ø	65	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Amps B Ø	35	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Amps C Ø	35	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BCH001399	Charger	697-Battery Bank	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BCH001399	Charger	697-Battery Bank	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Winding Temp Present	35	°C
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Winding Temp Max	36	°C
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.4870	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Oil Temp Max	43	°C
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	3568.80	kw
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	General Comments		
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	General Comments		
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	General Comments		
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	44	*F
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Retired Operations	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	161	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	161	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Switching Operations	0	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Operations This Read Vac	0	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Operations Counter AL	552	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Operations Counter AF	552	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Maintenance Operations	0	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Grounds in Place?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	General Comments		
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	General Comments		
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Follow-up Action Required?	n	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Fault Operations Ground	0	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Fault Operations C Ø	0	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Fault Operations B Ø	0	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Fault Operations A Ø	0	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	General Comments		
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Amps C Ø	20.0	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Amps B Ø	20.0	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	General Comments		
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Fault Adjusted Amps A Phase V	0	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Fault Adjusted Amps B Phase V	0	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Fault Adjusted Amps C Phase V	0	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Fault Operations A Ø	0	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	General Comments		
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Trash Emptied?	n	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	General Comments		
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Control House Lighting OK?	n	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Broom on Site?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
12/7/2020 10:53	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	n	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Fault Operations B Ø	0	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Fault Operations C Ø	0	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Follow-up Action Required?	n	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	General Comments		
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	General Comments		
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Grounds in Place?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Maintenance Operations	0	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Operations Counter AF	165	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Operations Counter AL	165	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Operations This Read Vac	0	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Switching Operations	0	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Unknown Operations	0	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Unknown Operations	0	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	LTCC000511	LTCControl	697-1	LTC Control Insp	LTC Operation Checked?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	LTCC000511	LTCControl	697-1	LTC Control Insp	General Comments	n/a	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	LTCC000511	LTCControl	697-1	LTC Control Insp	Follow-up Action Required?	n	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	LTCC000511	LTCControl	697-1	LTC Control Insp	All Connections OK?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AF	253	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AL	253	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Operations This Read Vac	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Unknown Operations	0	
12/7/2020 8:28	Distribution	Clark County Quarterly Inspection	BCH001032	Charger	475-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
12/7/2020 8:28	Distribution	Clark County Quarterly Inspection	BCH001032	Charger	475-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	131.8	VDC
12/7/2020 8:28	Distribution	Clark County Quarterly Inspection	BCH001032	Charger	475-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	131.8	VDC
12/7/2020 8:28	Distribution	Clark County Quarterly Inspection	BCH001032	Charger	475-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
12/7/2020 8:28	Distribution	Clark County Quarterly Inspection	BCH001032	Charger	475-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/7/2020 8:28	Distribution	Clark County Quarterly Inspection	BCH001032	Charger	475-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/7/2020 8:28	Distribution	Clark County Quarterly Inspection	BCH001032	Charger	475-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Ground Lights	None	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Switching Operations	1	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Tank Paint Condition	Good	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Unknown Operations	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Switching Operations	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Operations This Read Vac	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Operations Counter AL	332	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Operations Counter AF	332	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Maintenance Operations	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	General Comments		
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Patrol Inspection	General Comments		
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Follow-up Action Required?	n	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Fault Operations Ground	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Fault Operations C ∅	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Fault Operations B ∅	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Fault Operations A ∅	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Amps C ∅	126.0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Amps B ∅	122.0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Amps A ∅	114.0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	9 Month Operations	18	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Unknown Operations	0	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	9 Month Operations	3	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Amps A ∅	0.0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Amps B ∅	0.0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Amps C ∅	0.0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Fault Operations A ∅	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Fault Operations B ∅	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Fault Operations C ∅	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Fault Operations Ground	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Follow-up Action Required?	n	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Patrol Inspection	General Comments		
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	General Comments		
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Maintenance Operations	0	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	9 Month Operations	15	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Accumulated Fault Duty A Ph V	5.94	%
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Accumulated Fault Duty B Ph V	3.2	%
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Accumulated Fault Duty C Ph V	7.31	%
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Amps A ∅	215	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Amps B ∅	225	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Amps C Ø	195	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Fault Adjusted Amps A Phase V	0	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Fault Adjusted Amps B Phase V	0	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Fault Adjusted Amps C Phase V	0	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Fault Operations A Ø	0	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Fault Operations B Ø	0	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Fault Operations C Ø	0	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Fault Operations Ground	0	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Follow-up Action Required?	n	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	General Comments		
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	General Comments		
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Grounds in Place?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Maintenance Operations	0	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Operations Counter AF	367	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Operations Counter AL	367	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Operations This Read Vac	1	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	LTCC000511	LTCControl	697-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	LTCC000511	LTCControl	697-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	LTCC000511	LTCControl	697-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	LTCC000511	LTCControl	697-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Fault Operations A Ø	0	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Fault Operations B Ø	0	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Fault Operations C Ø	0	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Fault Operations Ground	0	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Follow-up Action Required?	n	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	General Comments	n/a	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	General Comments	n/a	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Grounds in Place?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Maintenance Operations	0	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Operations Counter AF	117	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Operations Counter AL	117	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Operations This Read Vac	0	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Switching Operations	0	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Unknown Operations	0	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Amps C Ø	50.0	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Amps B Ø	50.0	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Amps A Ø	50.0	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	9 Month Operations	4	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	General Comments	n/a	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	36	°F
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BCH001399	Charger	697-Battery Bank	Battery Charger Patrol Insp	Ground Lights	None	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BCH001399	Charger	697-Battery Bank	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BCH001399	Charger	697-Battery Bank	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BCH001399	Charger	697-Battery Bank	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	General Comments	N/A	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	General Comments	n/a	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	LTC Totalizer Reading	2520.00	kw
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.6	psi
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	Oil Temp Max	45	°C
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	Oil Temp Present	45	°C
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Unknown Operations	0	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Switching Operations	0	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Operations This Read Vac	0	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Operations Counter AL	416	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Operations Counter AF	416	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Maintenance Operations	0	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Grounds in Place?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	General Comments		
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Follow-up Action Required?	n	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Fault Operations Ground	0	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Fault Operations C ∅	0	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Fault Operations B ∅	0	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Fault Operations A ∅	0	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	Totalizer Meter Reading	.4200	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	9 Month Operations	4	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Amps A ∅	10.0	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Amps B ∅	10.0	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Amps C ∅	10.0	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Maintenance Operations	0	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Operations Counter AF	110	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Operations Counter AL	110	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Operations This Read Vac	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Switching Operations	0	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Unknown Operations	0	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BCH001373	Charger	416-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BCH001373	Charger	416-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	Totalizer Meter Reading	.3870	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BCH001373	Charger	416-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BCH001373	Charger	416-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	General Comments		
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	General Comments	Seeps at detc.	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	555.84	kw
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	Oil Temp Max	12	°C
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	Oil Temp Present	10	°C
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Tank Leaks	Seeping	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Low	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BCH001373	Charger	416-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BCH001373	Charger	416-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BCH001373	Charger	416-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	BCH001373	Charger	416-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BCH001372	Charger	531-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BCH001372	Charger	531-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BCH001372	Charger	531-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BCH001372	Charger	531-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BCH001372	Charger	531-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BCH001372	Charger	531-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BCH001372	Charger	531-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	9 Month Operations	2	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	Oil Temp Present	18	°C
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	Oil Temp Max	24	°C
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	LTC Totalizer Reading	9907.2	kw
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	General Comments		
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	General Comments		
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	9 Month Operations	4	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Amps A Ø	120.0	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Amps B Ø	120.0	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Amps C Ø	120.0	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Fault Operations A Ø	0	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Fault Operations B Ø	0	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Fault Operations C Ø	0	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Fault Operations Ground	0	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Follow-up Action Required?	n	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	General Comments	n/a	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	General Comments	n/a	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Grounds in Place?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	Oil Temp Present	30	°C
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	Oil Temp Max	45	°C
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	LTC Totalizer Reading	3177.60	kw
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	General Comments		
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	General Comments		
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.1868	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	400	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	474.72	kw
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.9	psi
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	General Comments		
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	General Comments		
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/7/2020 12:09	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1600	
12/7/2020 11:28	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3474	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Unknown Operations	1	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Switching Operations	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Operations This Read Vac	1	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Operations Counter AL	199	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Operations Counter AF	199	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Maintenance Operations	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	General Comments		
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Patrol Inspection	General Comments		
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Follow-up Action Required?	n	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Fault Operations Ground	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Fault Operations C Ø	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Fault Operations B Ø	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Fault Operations A Ø	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Amps C Ø	0.0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Amps B Ø	7.0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Amps A Ø	0.0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	Oil Temp Present	40	°C
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	9 Month Operations	1	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	Oil Temp Max	40	°C
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	LTC Totalizer Reading	3096.00	kw
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	General Comments	n/a	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	General Comments	n/a	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	220.00	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	Totalizer Meter Reading	.3972	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Current Tap Position	Neutral	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	General Comments		
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Regulator As Left Counter	2307	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	General Comments	FAN THERMOSTAT NOT WORKING . FANS STUCK ON	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	207.50	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	LTCC000851	LTCControl	692-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	LTCC000851	LTCControl	692-1	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	LTCC000851	LTCControl	692-1	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	LTCC000851	LTCControl	692-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	LTCC000851	LTCControl	692-1	LTC Control Insp	LTC Operation Checked?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	LTCC000851	LTCControl	692-1	LTC Control Insp	General Comments	n/a	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	LTCC000851	LTCControl	692-1	LTC Control Insp	Follow-up Action Required?	n	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	LTCC000851	LTCControl	692-1	LTC Control Insp	All Connections OK?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Unknown Operations	0	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	34	*F
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Amps A Ø	20.0	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	9 Month Operations	4	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	General Comments		
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Min Tap Position	3L	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Regulator As Left Counter	2222	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Current Tap Position	2R	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	General Comments		
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Max Tap Position	5R	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Regulator As Left Counter	2780	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/7/2020 15:38	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Operations Counter AF	27	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Operations Counter AL	27	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Operations This Read Vac	0	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Switching Operations	0	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Unknown Operations	0	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Amps A Ø	81.0	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	9 Month Operations	2	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Unknown Operations	0	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Switching Operations	0	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Operations This Read Vac	0	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Operations Counter AL	173	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Operations Counter AF	173	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Maintenance Operations	0	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Grounds in Place?	y	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	General Comments		
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	General Comments		
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Follow-up Action Required?	n	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Fault Operations Ground	0	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Fault Operations C Ø	0	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Fault Operations B Ø	0	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Fault Operations A Ø	0	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	Winding Temp Present	22	°C
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	Winding Temp Max	26	°C
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	Totalizer Meter Reading	.688	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Amps C Ø	31.0	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Amps B Ø	42.0	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Amps A Ø	43.0	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Switching Operations	0	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Operations This Read Vac	0	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Operations Counter AL	173	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Operations Counter AF	173	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Maintenance Operations	0	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Grounds in Place?	y	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	General Comments		
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	General Comments		
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Follow-up Action Required?	n	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Fault Operations Ground	0	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Fault Operations C Ø	0	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Fault Operations B Ø	0	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Fault Operations A Ø	0	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	9 Month Operations	4	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Amps C Ø	64.0	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Amps B Ø	113.0	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Amps A Ø	180.0	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Amps B Ø	60.0	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Amps C Ø	120.0	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Fault Operations A Ø	0	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Fault Operations B Ø	0	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Fault Operations C Ø	0	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Fault Operations Ground	0	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Follow-up Action Required?	n	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	General Comments	n/a	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	General Comments	n/a	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Grounds in Place?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Heaters (All) Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Maintenance Operations	0	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Operations This Read Vac	1	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Operations Counter AL	191	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	LTC Max Tap Position	2L	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	LTC Min Tap Position	12L	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	525	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Unknown Operations	0	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	9 Month Operations	2	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Amps A Ø	177.0	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Amps B Ø	190.0	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Amps C Ø	190.0	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	LTCC000871	LTCControl	416-1	LTC Control Insp	VRR Base Voltage AL	125	VAC
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	LTCC000871	LTCControl	416-1	LTC Control Insp	VRR Base Voltage AF	125	VAC
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	LTCC000871	LTCControl	416-1	LTC Control Insp	LTC Output Voltage Level	124.9	VAC
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	LTCC000871	LTCControl	416-1	LTC Control Insp	LTC Operation Checked?	y	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	LTCC000871	LTCControl	416-1	LTC Control Insp	General Comments		
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Operations Counter AF	191	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Maintenance Operations	0	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Grounds in Place?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	General Comments	n/a	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	General Comments	n/a	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Follow-up Action Required?	n	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Fault Operations Ground	0	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Fault Operations C Ø	0	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Fault Operations B Ø	0	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Fault Operations A Ø	0	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	LTCC000871	LTCControl	416-1	LTC Control Insp	Follow-up Action Required?	n	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	LTCC000871	LTCControl	416-1	LTC Control Insp	All Connections OK?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	LTC As Left Counter	81888	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	LTC As Found Counter	81888	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Mechanism Patrol Inspection	General Comments	n/a	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	General Comments	n/a	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	Follow-up Action Required?	n	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Fault Operations B Ø	0	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Fault Operations A Ø	0	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	9 Month Operations	3	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Fault Operations A Ø	0	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	LTCC000871	LTCControl	416-1	LTC Control Insp	VRR Time Delay	30	Seconds

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Fault Operations B Ø	0	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Fault Operations C Ø	0	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Fault Operations Ground	0	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	LTC Operations Since Last Insp	69	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	LTC Min Tap Position	13L	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	LTC Max Tap Position	8L	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	LTC Current Tap Position	8L	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	General Comments		
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		pic of oil level sent to Stinson
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	LTC As Found Counter	20448	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	LTC As Left Counter	20448	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	LTC Current Tap Position	9L	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Follow-up Action Required?	n	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	General Comments	n/a	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	General Comments	n/a	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Grounds in Place?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Maintenance Operations	0	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Operations Counter AF	199	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Operations Counter AL	199	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Operations This Read Vac	0	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Switching Operations	0	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	LTC Current Tap Position	3L	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	LTC Max Tap Position	1L	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Unknown Operations	1	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Switching Operations	0	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Amps A Ø	119.0	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Amps B Ø	205.0	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Amps C Ø	196.0	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Fault Adjusted Amps A Phase V	12.90	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LTCC000211	LTCControl	NA-TRANS 3	LTC Control Insp	General Comments		
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LTCC000211	LTCControl	NA-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Amps C Ø	45.0	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Amps B Ø	45.0	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Amps A Ø	45.0	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	386	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	42	°C
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	LTC Min Tap Position	10L	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	LTC Max Tap Position	1L	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	LTC Current Tap Position	7L	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	LTC As Left Counter	58589	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	LTC As Found Counter	58589	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Mechanism Patrol Inspection	General Comments	replaced Desiccant	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	General Comments		
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	1	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	1	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1405	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1405	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C ∅	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B ∅	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A ∅	0	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	General Comments	n/a	
12/7/2020 13:46	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Fault Adjusted Amps C Phase V	12.90	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	7	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A ∅	64.0	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Fault Adjusted Amps B Phase V	12.90	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B ∅	75.0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C ∅	72.0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	11.18	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	286	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	LTC Min Tap Position	8L	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	-.5	psi
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	LTC Operations Since Last Insp	646	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	LTC Min Tap Position	11L	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	LTC Max Tap Position	4L	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	LTC Current Tap Position	8L	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	LTC As Left Counter	76576	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	LTC As Found Counter	76576	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	General Comments		
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LTCC000213	LTCControl	NA-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LTCC000213	LTCControl	NA-TRANS 2	LTC Control Insp	General Comments		
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LTCC000213	LTCControl	NA-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LTCC000212	LTCControl	NA-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LTCC000212	LTCControl	NA-TRANS 1	LTC Control Insp	General Comments		
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LTCC000212	LTCControl	NA-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LTCC000211	LTCControl	NA-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	9 Month Operations	2	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	894	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Fault Operations C ∅	0	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Fault Operations B ∅	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Fault Operations A Ø	0	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	General Comments		
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	General Comments		
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Grounds in Place?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Maintenance Operations	0	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Operations Counter AF	116	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Operations Counter AL	116	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Operations This Read Vac	0	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Switching Operations	0	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Unknown Operations	0	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	LTCC000707	LTCControl	531-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	LTCC000707	LTCControl	531-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Winding Temp Present	30	°C
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Winding Temp Max	40	°C
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Totalizer Meter Reading	.7716	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	General Comments		
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	General Comments		
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-5	psi
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	3703.68	kw
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Oil Temp Max	35	°C
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Oil Temp Present	25	°C
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	Follow-up Action Required?	n	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	9 Month Operations	2	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	LTC As Left Counter	115654	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	LTC As Found Counter	115654	
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Mechanism Patrol Inspection	General Comments		
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2020 8:14	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Fault Operations A Ø	0	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Fault Operations B Ø	0	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Fault Operations C Ø	0	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Fault Operations Ground	0	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Follow-up Action Required?	n	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	General Comments		
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	General Comments		
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Grounds in Place?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Maintenance Operations	0	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Fault Operations Ground	0	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Follow-up Action Required?	n	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Unknown Operations	0	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Switching Operations	0	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Operations This Read Vac	0	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Operations Counter AL	205	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Operations Counter AF	205	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Unknown Operations	0	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Switching Operations	0	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Amps C Ø	70.0	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Operations This Read Vac	0	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Operations Counter AL	162	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Operations Counter AF	162	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Maintenance Operations	0	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Grounds in Place?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	General Comments	n/a	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	General Comments	n/a	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Foundation Condition	Good	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	894	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	LTCC000707	LTCControl	531-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	LTCC000707	LTCControl	531-1	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	LTCC000707	LTCControl	531-1	LTC Control Insp	LTC Operation Checked?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	LTCC000707	LTCControl	531-1	LTC Control Insp	General Comments		
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	LTCC000707	LTCControl	531-1	LTC Control Insp	Follow-up Action Required?	n	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	LTCC000707	LTCControl	531-1	LTC Control Insp	All Connections OK?	y	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Follow-up Action Required?	n	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Fault Operations Ground	0	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Fault Operations C Ø	0	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2020 11:29	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2020 13:24	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Amps A Ø	50.0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
12/14/2020 6:44	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	9 Month Operations	4	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Amps A Ø	60.0	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Amps B Ø	70.0	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Amps C Ø	60.0	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2020 15:05	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Foundation Condition	Good	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	General Comments		
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Grounds in Place?	y	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Heaters (All) Functioning?	y	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	SF6 Bushing Condition	Good	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Fault Operations	0	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Follow-up Action Required?	n	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	General Comments		
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Maintenance Operations	0	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Num Operations Last 9 Months	0	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Operations Counter AF	421	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Operations Counter AL	421	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Operations This Read SF6	0	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Switching Operations	0	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Foundation Condition	Good	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	General Comments		
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Grounds in Place?	y	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Heaters (All) Functioning?	y	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	SF6 Bushing Condition	Good	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LTCC000283	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LTCC000283	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LTCC000283	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Operations Since Last Insp	154	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Min Tap Position	2R	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Max Tap Position	14R	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Counter Readings	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Counter Readings	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Found Counter	10505	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Left Counter	10505	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Current Tap Position	5R	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Max	65	°C
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Present	25	°C
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Readings	X1 Winding Temp Max	70	°C
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Readings	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Readings	X1 Winding Temp Present	35	°C
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Operations Since Last Insp	204	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Min Tap Position	3R	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Max Tap Position	10R	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Current Tap Position	5R	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Found Counter	38203	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Counter Readings	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Left Counter	38203	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Counter Readings	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LTCC000597	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LTCC000597	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LTCC000597	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Max	0	°C
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Present	0	°C
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Readings	X1 Winding Temp Max	50	°C
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Readings	X1 Winding Temp Present	35	°C
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Readings	General Comments	Oil temperature gauge is still bad. Needs new gauge. Pic sent to Tom Goodner.	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Readings	Follow-up Action Required?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1200	psi
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	n	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	General Comments	Work order created to replace house heater	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCControl	728-1	LTC Control Insp	LTC Operation Checked?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCControl	728-1	LTC Control Insp	General Comments		
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCControl	728-1	LTC Control Insp	Follow-up Action Required?	n	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCControl	728-1	LTC Control Insp	All Connections OK?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Trash Emptied?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Unknown Operations	0	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	LTCC000727	LTCControl	301-3	LTC Control Insp	General Comments		
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	LTCC000727	LTCControl	301-3	LTC Control Insp	Follow-up Action Required?	n	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	LTCC000727	LTCControl	301-3	LTC Control Insp	All Connections OK?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	Offline	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Amps C Ø	5.0	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Amps B Ø	20.0	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Amps A Ø	12.0	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	9 Month Operations	3	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Unknown Operations	0	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Switching Operations	1	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Operations This Read Vac	1	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Operations Counter AL	195	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Operations Counter AF	195	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Maintenance Operations	0	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	General Comments		
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	General Comments		
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Follow-up Action Required?	n	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Fault Operations Ground	0	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Fault Operations C Ø	0	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Fault Operations B Ø	0	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Fault Operations A Ø	0	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	General Comments		
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	General Comments		
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	LTCC000727	LTCControl	301-3	LTC Control Insp	VRR Time Delay	45	Seconds
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	LTCC000727	LTCControl	301-3	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	LTCC000727	LTCControl	301-3	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	LTCC000727	LTCControl	301-3	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	LTCC000727	LTCControl	301-3	LTC Control Insp	LTC Output Voltage Level	124.8	VAC
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	LTCC000727	LTCControl	301-3	LTC Control Insp	LTC Operation Checked?	y	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Unknown Operations	0	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Switching Operations	1	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Operations This Read Vac	1	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Operations Counter AL	191	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Operations Counter AF	191	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Maintenance Operations	0	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	General Comments		
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Follow-up Action Required?	n	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Fault Operations Ground	0	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Fault Operations C Ø	0	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Fault Operations B Ø	0	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Fault Operations A Ø	0	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Amps C Ø	200	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Amps B Ø	200	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	BCH001099	Charger	008-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	BCH001099	Charger	008-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	9 Month Operations	2	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Amps A Ø	180	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Accumulated Fault Duty C Ph V	.45	%
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Accumulated Fault Duty B Ph V	.45	%
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Accumulated Fault Duty A Ph V	0	%
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	9 Month Operations	3	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCControl	728-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCControl	728-1	LTC Control Insp	VRR Base Voltage AL	124	VAC
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCControl	728-1	LTC Control Insp	VRR Base Voltage AF	124	VAC
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCControl	728-1	LTC Control Insp	LTC Output Voltage Level	123.8	VAC
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Amps C Ø	165.0	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	45	*F
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	BCH001099	Charger	008-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Amps B Ø	100.0	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Amps A Ø	145.0	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	9 Month Operations	5	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Unknown Operations	0	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Switching Operations	0	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Operations This Read Vac	0	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Operations Counter AL	160	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Operations Counter AF	160	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Maintenance Operations	0	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	General Comments		
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	General Comments		
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Follow-up Action Required?	n	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Fault Operations Ground	0	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Fault Operations C Ø	0	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Fault Operations B Ø	0	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Fault Operations A Ø	0	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Fault Adjusted Amps C Phase V	0	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Fault Adjusted Amps B Phase V	0	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Fault Adjusted Amps A Phase V	0	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	General Comments	high sewer level alarm	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Follow-up Action Required?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Broom on Site?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Readings	Winding Temp Present	25	°C
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Readings	Winding Temp Max	50	°C
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Readings	Oil Temp Present	22	°C
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Readings	Oil Temp Max	50	°C
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	105	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	105	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	4	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	310.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	310.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	320.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	8.33	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	144	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	144	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	1	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	General Comments		
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	Oil Temp Max	40	°C
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	Oil Temp Present	29	°C
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Trash Emptied?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Restroom Clean & OK?	n	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	28.33	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Readings	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	3	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps A Ø	0.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps B Ø	0.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps C Ø	0.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	114	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	114	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AF	695	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AL	695	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations This Read AM	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Switching Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Unknown Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Readings	Winding Temp Present	22	°C
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Readings	Winding Temp Max	48	°C
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	119	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	119	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	1	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	275.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	250.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	250.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Readings	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Readings	Winding Temp Present	25	°C
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Readings	Winding Temp Max	50	°C
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Readings	Oil Temp Present	20	°C
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Readings	Oil Temp Max	50	°C
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	LTC Operations Since Last Insp	448	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	66.6	VDC
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	69.6	VDC
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	68	°F
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	Totalizer Meter Reading	.7974	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	97.50	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1913.76	kw
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.5	psi
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Unknown Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Switching Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations This Read AM	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AL	485	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AF	485	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps C Ø	0.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps B Ø	0.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps A Ø	0.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	0	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Patrol Inspection	General Comments		
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Switching Operations	0	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Operations This Read Vac	0	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Operations Counter AL	176	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Operations Counter AF	176	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Maintenance Operations	0	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	General Comments		
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	General Comments		
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Follow-up Action Required?	n	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Fault Operations Ground	0	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Fault Operations C Ø	0	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Fault Operations B Ø	0	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Fault Operations A Ø	0	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Amps C Ø	15.0	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Amps B Ø	15.0	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Amps A Ø	15.0	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	9 Month Operations	4	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	Follow-up Action Required?	n	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	General Comments		
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Mechanism Patrol Inspection	General Comments		
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	General Comments	BRKR Gone	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	General Comments	BRKR is Gone, Sub being rebuilt	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Maintenance Operations	0	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations Counter AF	221	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations Counter AL	0	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Switching Operations	0	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Unknown Operations	0	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	BCH001099	Charger	008-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.7	amps
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	BCH001099	Charger	008-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	136.3	VDC
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	BCH001099	Charger	008-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	136.3	VDC
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	BCH001099	Charger	008-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.500	millivolts
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	LTC As Found Counter	18058	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	LTC As Left Counter	18060	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	LTC Current Tap Position	6L	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	LTC Max Tap Position	2L	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	LTC Min Tap Position	11L	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	General Comments		
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Follow-up Action Required?	n	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	120	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	120	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Fault Operations Ground	0	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Fault Operations C Ø	0	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Fault Operations B Ø	0	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Fault Operations A Ø	0	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Amps C Ø	450.0	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Amps B Ø	450.0	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Amps A Ø	380.0	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	9 Month Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	2	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	2	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	General Comments		
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Unknown Operations	0	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	General Comments		
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	LTC Totalizer Reading	5667.84	kw
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Switching Operations	0	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Operations This Read Vac	0	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Operations Counter AL	19	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Operations Counter AF	19	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Maintenance Operations	0	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	General Comments		
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Amps A Ø	320.0	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Amps B Ø	320.0	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Amps C Ø	320.0	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Operations C Ø	0	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Operations B Ø	0	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Operations A Ø	0	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Adjusted Amps C Phase V	.93	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Adjusted Amps B Phase V	.93	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Adjusted Amps A Phase V	.93	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Fault Operations A Ø	0	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Fault Operations B Ø	0	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Fault Operations C Ø	0	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Fault Operations Ground	0	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Follow-up Action Required?	n	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	General Comments		
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	General Comments		
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Maintenance Operations	0	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Operations Counter AF	171	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Operations Counter AL	171	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Operations This Read Vac	0	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Switching Operations	0	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Unknown Operations	0	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Fault Operations Ground	0	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Follow-up Action Required?	n	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Unknown Operations	1	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Switching Operations	1	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Operations This Read Vac	2	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Operations Counter AL	234	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Operations Counter AF	234	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Maintenance Operations	0	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	General Comments	ok	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	General Comments	1 unknown op	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Follow-up Action Required?	n	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Operations Ground	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	238	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	238	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	9 Month Operations	0	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	General Comments		
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000030	LTCControl	593-2	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000030	LTCControl	593-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000030	LTCControl	593-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000030	LTCControl	593-2	LTC Control Insp	VRR Time Delay	30	Seconds
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	9 Month Operations	4	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Amps A Ø	100.0	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Amps B Ø	130.0	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Amps C Ø	110.0	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Fault Operations A Ø	0	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Fault Operations B Ø	0	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Fault Operations C Ø	0	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Follow-up Action Required?	n	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	General Comments		
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	General Comments	TC	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Maintenance Operations	1	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Operations Counter AF	148	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Operations Counter AL	148	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Operations This Read Vac	1	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Switching Operations	0	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Unknown Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushing Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	General Comments	Transformer needs nitrogen	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	General Comments	TC	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	9 Month Operations	14	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Maintenance Operations	1	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Operations Counter AF	140	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Operations Counter AL	140	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Operations This Read Vac	1	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Switching Operations	0	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Unknown Operations	0	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Counter Readings	General Comments		
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Counter Readings	LTC As Found Counter	7129	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Counter Readings	LTC As Left Counter	7129	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Counter Readings	LTC Current Tap Position	7L	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Counter Readings	LTC Max Tap Position	4L	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Counter Readings	LTC Min Tap Position	7L	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	9	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000030	LTCControl	593-2	LTC Control Insp	All Connections OK?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000030	LTCControl	593-2	LTC Control Insp	Follow-up Action Required?	n	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000030	LTCControl	593-2	LTC Control Insp	General Comments		
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000030	LTCControl	593-2	LTC Control Insp	LTC Operation Checked?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	147	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	147	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	General Comments	Substation is De-Energized. Sub is being rebuilt	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Vegetation	None	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	General Comments	Substation is De-Energized and being rebuilt.	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BCH001316	Charger	766-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	4	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	20.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	20.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	20.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BCH001316	Charger	766-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BCH001316	Charger	766-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BCH001316	Charger	766-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BCH001316	Charger	766-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BCH001316	Charger	766-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BCH001316	Charger	766-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	147	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	147	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	LTC Operations Since Last Insp	291	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	49	°C
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	20	°C
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	LTC Min Tap Position	4L	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	LTC Max Tap Position	14L	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	LTC Current Tap Position	11L	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	2	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	LTC As Left Counter	11028	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	LTC As Found Counter	11028	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	SWG000050	Switchgear	MG-4KV Sec 1 Swgr	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	SWG000050	Switchgear	MG-4KV Sec 1 Swgr	Switchgear Patrol Inspection	Panels Dusted?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	SWG000050	Switchgear	MG-4KV Sec 1 Swgr	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	SWG000050	Switchgear	MG-4KV Sec 1 Swgr	Switchgear Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	SWG000050	Switchgear	MG-4KV Sec 1 Swgr	Switchgear Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	SWG000050	Switchgear	MG-4KV Sec 1 Swgr	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	9 Month Operations	3	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Amps A Ø	100.0	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Amps B Ø	100.0	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Amps C Ø	130.0	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Fault Operations A Ø	0	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Fault Operations B Ø	0	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Fault Operations C Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	2	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	General Comments	Any parts left blank means there is no part on transformer.	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	General Comments		
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Panels Dusted?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	General Comments		
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Floor Swept?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Evidence of Insects	None	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Control House Lighting OK?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Acceptable Building Appearance?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Surge Arrester Counter C Ø	0	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Surge Arrester Counter B Ø	0	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Surge Arrester Counter A Ø	0	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	LTCC000199	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	LTCC000199	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	LTCC000199	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	LTCC000199	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	LTCC000199	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	LTCC000199	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	LTCC000199	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	LTCC000199	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Percent Thermal Load C Ø Max	0	%
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Percent Thermal Load B Ø Max	0	%
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Percent Thermal Load A Ø Max	0	%
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Oil Temp Present	28	°C
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Oil Temp Max	44	°C
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	4150.08	kw
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	LV Winding Temp Present	0	°C
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	LV Winding Temp Max	0	°C
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	HV Winding Temp Present	0	°C
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	HV Winding Temp Max	0	°C
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	H3 Winding Temp Present	0	°C
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	H3 Winding Temp Max	0	°C
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	H2 Winding Temp Present	0	°C
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	H2 Winding Temp Max	0	°C
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	H1 Winding Temp Present	0	°C
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	H1 Winding Temp Max	0	°C
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	Oil Temp Present	20	°C
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	Oil Temp Max	30	°C
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	72.50	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	1234.56	kw
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	General Comments		
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	General Comments		
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	Winding Temp Present	35	°C
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	Winding Temp Max	53	°C
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	Totalizer Meter Reading	.5045	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	Oil Temp Present	35	°C
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	Oil Temp Max	53	°C
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	LTC Totalizer Reading	9081.00	kw
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps A Ø	0.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps B Ø	0.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps C Ø	0.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AF	685	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AL	685	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations This Read AM	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Switching Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Unknown Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Readings	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	General Comments	Oil level is on the low side	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	Totalizer Meter Reading	.3858	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	225.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	220.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Readings	Oil Temp Max	60	°C
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Readings	Oil Temp Present	20	°C
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Tank Oil Level	Low	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	Oil Temp Present	34	°C
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Amps C Ø	39.0	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Amps B Ø	42.0	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Amps A Ø	41.0	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	9 Month Operations	0	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Unknown Operations	2	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Switching Operations	0	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Operations This Read Vac	2	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Operations Counter AL	210	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Operations Counter AF	210	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Maintenance Operations	0	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	General Comments		
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	General Comments		
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Follow-up Action Required?	n	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Fault Operations C Ø	0	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Fault Operations B Ø	0	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Fault Operations A Ø	0	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Fault Adjusted Amps C Phase V	2.00	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Fault Adjusted Amps B Phase V	2.00	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Fault Adjusted Amps A Phase V	2.00	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Amps C Ø	72.0	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Amps B Ø	100.0	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Amps A Ø	80.0	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Bushing Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Unknown Operations	0	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Switching Operations	0	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Operations This Read Vac	0	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Operations Counter AL	189	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Operations Counter AF	189	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Maintenance Operations	0	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	General Comments		
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	General Comments		
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Follow-up Action Required?	n	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Fault Operations Ground	0	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Fault Operations C Ø	0	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Fault Operations B Ø	0	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Fault Operations A Ø	0	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	Totalizer Meter Reading	.9492	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	65	°C
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	40	°C
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	60	°C
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	40	°C
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Y3 Winding Temp Present	0	°C
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	Oil Temp Max	45	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	LTC Totalizer Reading	6834.24	kw
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	General Comments		
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	General Comments		
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	Follow-up Action Required?	n	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Y3 Winding Temp Max	0	°C
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Y2 Winding Temp Present	0	°C
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Y2 Winding Temp Max	0	°C
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Y1 Winding Temp Present	0	°C
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Y1 Winding Temp Max	0	°C
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	X3 Winding Temp Present	0	°C
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	X3 Winding Temp Max	0	°C
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	X2 Winding Temp Present	0	°C
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	X2 Winding Temp Max	0	°C
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	X1 Winding Temp Present	0	°C
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	X1 Winding Temp Max	0	°C
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Winding Temp Present	28	°C
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Winding Temp Max	44	°C
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	TV Winding Temp Present	0	°C
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	TV Winding Temp Max	0	°C
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.7292	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Top Oil Temperature Present	0	°C
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Top Oil Temperature Max	0	°C
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	9 Month Operations	13	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Unknown Operations	0	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Switching Operations	0	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Operations This Read Vac	0	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Operations Counter AL	179	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Operations Counter AF	179	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Maintenance Operations	0	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	General Comments		
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	General Comments		
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Follow-up Action Required?	n	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Fault Operations Ground	0	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Fault Operations C ∅	0	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Fault Operations B ∅	0	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Fault Operations A ∅	0	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	Oil Temp Max	55	°C
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	Oil Temp Present	35	°C
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Amps C Ø	24.0	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Amps B Ø	13.0	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Amps A Ø	42.0	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	9 Month Operations	2	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	40	°C
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	30	°C
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	General Comments		
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	43	°F
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	General Comments		
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	General Comments		
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Ambient Temp	43	*F
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Readings	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	General Comments	Oil level is low. It can't even be seen in the gauge.	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	415.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	400.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Readings	Oil Temp Max	50	°C
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Readings	Oil Temp Present	20	°C
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Radiator Leaks	Seeping	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Tank Oil Level	Very Low	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	General Comments	.	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.8	amps
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	LTC Operations Since Last Insp	334	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	LTC Min Tap Position	12L	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	LTC Max Tap Position	4L	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	LTC Current Tap Position	6L	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	LTC As Left Counter	58926	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	LTC As Found Counter	58926	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Mechanism Patrol Inspection	General Comments		
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	General Comments		
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	Follow-up Action Required?	n	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	General Comments		
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	43	*F
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	General Comments	Raise hand hanging on caution sticker, will not reset fully	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Max Tap Position	3R	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Regulator As Left Counter	311931	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	SWG000136	Switchgear	MG-14KV Sec C Swgr	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	SWG000136	Switchgear	MG-14KV Sec C Swgr	Switchgear Patrol Inspection	Panels Dusted?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	SWG000136	Switchgear	MG-14KV Sec C Swgr	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	SWG000136	Switchgear	MG-14KV Sec C Swgr	Switchgear Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	SWG000136	Switchgear	MG-14KV Sec C Swgr	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	SWG000136	Switchgear	MG-14KV Sec C Swgr	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Panels Dusted?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	LTC Operations Since Last Insp	791	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	°C
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	30	°C
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	LTC Min Tap Position	11L	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	LTC Max Tap Position	1L	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	LTC Current Tap Position	2L	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	LTC As Left Counter	67922	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	LTC As Found Counter	67922	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	General Comments		
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	General Comments		
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Unknown Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Switching Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Operations This Read AM	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Operations Counter AL	242	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Operations Counter AF	242	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Maintenance Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Fault Operations Ground	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Fault Operations C Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Fault Operations B Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Fault Operations A Ø	0	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	General Comments		
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	General Comments		
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Unknown Operations	0	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	9 Month Operations	0	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Accumulated Fault Duty A Ph V	0	%
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Accumulated Fault Duty B Ph V	0	%
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Accumulated Fault Duty C Ph V	0	%
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Amps A Ø	480	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Amps B Ø	480	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Amps C Ø	480	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Fault Adjusted Amps A Phase V	0	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Fault Adjusted Amps B Phase V	0	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Fault Adjusted Amps C Phase V	0	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Fault Operations A Ø	0	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Fault Operations B Ø	0	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Fault Operations C Ø	0	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Fault Operations Ground	0	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Follow-up Action Required?	n	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	General Comments		
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	General Comments		
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Maintenance Operations	0	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Operations Counter AF	158	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Operations Counter AL	158	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Operations This Read Vac	0	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Switching Operations	0	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Unknown Operations	0	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	General Comments		
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Ambient Temp	45	*F
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Amps A Ø	0.0	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Amps B Ø	0.0	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Amps C Ø	0.0	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Fault Operations A Ø	0	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Fault Operations B Ø	0	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Fault Operations C Ø	0	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	General Comments		
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Interrupts/Puffrs Visual OK?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Switching Operations	0	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Unknown Operations	0	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Fault Operations Ground	0	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Follow-up Action Required?	n	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	General Comments		
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	General Comments	Breaker out of service	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Maintenance Operations	0	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Operations Counter AF	185	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Operations Counter AL	185	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Operations This Read Vac	0	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Switching Operations	0	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	General Comments		
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Vegetation	None	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	General Comments		
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	General Comments		
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Vegetation	None	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	General Comments		
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	General Comments	Stand alone under-frequency relay has been removed from this station	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	PF000215	PowerFuse	MG-451 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	PF000215	PowerFuse	MG-451 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	PF000214	PowerFuse	MG-4KV TFR POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	PF000214	PowerFuse	MG-4KV TFR POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	PF000213	PowerFuse	MG-4KV REA TIE POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	PF000213	PowerFuse	MG-4KV REA TIE POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	PF000210	PowerFuse	MG-411 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	PF000210	PowerFuse	MG-411 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	PF000209	PowerFuse	MG-464 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	PF000209	PowerFuse	MG-464 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	PF000208	PowerFuse	MG-454 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	PF000208	PowerFuse	MG-454 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Vegetation	None	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments	Gone	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments	XFMR is Gone	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	0	°C
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	General Comments		
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Ambient Temp	46	°F
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Readings	Operations Counter AL	95	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Readings	Operations This Read SF6	0	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	SF6 Bushing Condition	Good	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	SF6 Pressure Indicator	good	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Readings	Switching Operations	0	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Operations This Read Vac	0	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Switching Operations	0	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	General Comments		
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Unknown Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Switching Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Operations This Read AM	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Operations Counter AL	348	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Operations Counter AF	348	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Maintenance Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Fault Operations Ground	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Fault Operations C Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Fault Operations B Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Fault Operations A Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Amps C Ø	0.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Amps B Ø	0.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Amps A Ø	0.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	9 Month Operations	2	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Accumulated Fault Duty A Ph V	0	%
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Accumulated Fault Duty B Ph V	0	%
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Accumulated Fault Duty C Ph V	0	%
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Amps A Ø	640	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Amps B Ø	640	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Amps C Ø	640	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Fault Adjusted Amps A Phase V	0	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Fault Adjusted Amps B Phase V	0	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Fault Adjusted Amps C Phase V	0	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Fault Operations A Ø	0	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Fault Operations B Ø	0	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Fault Operations C Ø	0	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Fault Operations Ground	0	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Follow-up Action Required?	n	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	General Comments		
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	General Comments		
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Maintenance Operations	0	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Operations Counter AF	203	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Operations Counter AL	203	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Ambient Temperature	43	*F
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Readings	Fault Operations	0	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Readings	Follow-up Action Required?	n	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Foundation Condition	Good	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Gauge(s) Condition	Good	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Readings	General Comments		
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	General Comments	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Grounds in Place?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Readings	Maintenance Operations	0	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Readings	Num Operations Last 9 Months	0	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Readings	Operations Counter AF	95	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	General Comments		
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Readings	General Comments		
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Readings	LTC Totalizer Reading	4003.20	kw
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Readings	Oil Temp Max	32	°C
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Readings	Oil Temp Present	24	°C
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Readings	Totalizer Meter Reading	.2780	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Readings	Winding Temp Max	32	°C
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Readings	Winding Temp Present	24	°C
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	LTCC000808	LTCControl	828-1	LTC Control Insp	All Connections OK?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	LTCC000808	LTCControl	828-1	LTC Control Insp	Follow-up Action Required?	n	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	LTCC000808	LTCControl	828-1	LTC Control Insp	General Comments		
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	LTCC000808	LTCControl	828-1	LTC Control Insp	LTC Operation Checked?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	LTCC000808	LTCControl	828-1	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	LTCC000808	LTCControl	828-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	LTCC000808	LTCControl	828-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	LTCC000808	LTCControl	828-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	LTCC000808	LTCControl	828-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Counter Readings	Follow-up Action Required?	n	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Counter Readings	General Comments		
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	General Comments		
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Counter Readings	LTC As Found Counter	3974	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Counter Readings	LTC As Left Counter	3974	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Counter Readings	LTC Current Tap Position	3L	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Counter Readings	LTC Max Tap Position	2L	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Counter Readings	LTC Min Tap Position	11L	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	20	°C
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	18	°C
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Counter Readings	LTC Operations Since Last Insp	536	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	9 Months Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0632	BreakerAirMagnetic	MG-452	AMCB Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps A Ø	0.0	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps B Ø	0.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps C Ø	0.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AF	1432	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AL	1432	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations This Read AM	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Switching Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Unknown Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushing Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	General Comments	needs nitrogen	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Ambient Temp	44	*F
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	General Comments		
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	General Comments		
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	General Comments		
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Vegetation	None	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Switch Stick Next Test Date	2021-03-15 00:00:00.000000	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	General Comments		
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Amps C ∅	220.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Amps B Ø	220.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Amps A Ø	225.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	9 Months Operations	0	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	LTCC000135	LTCControl	663-2	LTC Control Insp	VRR Time Delay	30	Seconds
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	LTCC000135	LTCControl	663-2	LTC Control Insp	VRR Base Voltage AL	124	VAC
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	LTCC000135	LTCControl	663-2	LTC Control Insp	VRR Base Voltage AF	124	VAC
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	LTCC000135	LTCControl	663-2	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	LTCC000135	LTCControl	663-2	LTC Control Insp	LTC Operation Checked?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	LTCC000135	LTCControl	663-2	LTC Control Insp	General Comments		
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	LTCC000135	LTCControl	663-2	LTC Control Insp	Follow-up Action Required?	n	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	LTCC000135	LTCControl	663-2	LTC Control Insp	All Connections OK?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	General Comments		
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Readings	General Comments		
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	52.50	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Vegetation	None	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	General Comments		
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	240	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	Winding Temp Present	50	°C
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	Winding Temp Max	65	°C
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	Totalizer Meter Reading	.89	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	General Comments		
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	Oil Temp Present	50	°C
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	Oil Temp Max	65	°C
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-5	psi
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	LTC Totalizer Reading	12816	kw
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	General Comments		
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	General Comments		
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Ambient Temp	43	°F
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	General Comments		
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	General Comments		
12/4/2020 13:58	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	Winding Temp Present	30	°C
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	Winding Temp Max	40	°C
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	Totalizer Meter Reading	.8118	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	Oil Temp Present	30	°C
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	Oil Temp Max	40	°C
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	LTC Totalizer Reading	7793.28	kw
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	General Comments		
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	General Comments		
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	Follow-up Action Required?	n	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	VRR X Compensation AL	0	Position
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	VRR X Compensation AF	0	Position
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	VRR Time Delay	0	Seconds
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	VRR R Compensation AL	0	Position
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	VRR R Compensation AF	0	Position
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	VRR Base Voltage AL	0.0	VAC
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	VRR Base Voltage AF	0.0	VAC
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	VRR Bandwidth AL	0.0	VAC
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	VRR Bandwidth AF	0.0	VAC
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	Parallel / Ind. Sw Position	parallelIND	Position
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	Megger Trans Annum Pos.	0.0	Meg Ohms
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	Megger Trans Annum Neg.	0.0	Meg Ohms
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Unknown Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Switching Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations This Read AM	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AL	504	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AF	504	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations C ∅	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations B ∅	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations A ∅	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps C ∅	0.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps B ∅	0.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps A ∅	0.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	0	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	General Comments		
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	Follow-up Action Required?	n	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	FCP Lower AL	0.0	VAC
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	FCP Lower AF	0.0	VAC
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	FCP Block Raise AL	0.0	VAC
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	FCP Block Raise AF	0.0	VAC
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	Fault Pressure Sw Position	In	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	Fault Pressure Relay Info	NA	Model
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	Back Up Relay Block Raise AL	0.0	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	Back Up Relay Block Raise AF	0.0	VAC
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	Back Up Relay Block Low AL	0.0	VAC
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	Back Up Relay Block Low AF	0.0	VAC
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	All Connections OK?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Amps A \emptyset	2.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	9 Months Operations	0	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	BCH000462	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	General Comments	Offline	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	BCH000462	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	BCH000462	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	BCH000462	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	0.0	VDC
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	BCH000462	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	0.0	VDC
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	BCH000458	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	BCH000458	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	BCH000458	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	55.2	VDC
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Regulator As Left Counter	2821	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	General Comments		
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Regulator As Left Counter	2845	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	General Comments		
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	43	°F
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Patrol Inspection	General Comments		
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Reading	0.0000	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Multiplier	0	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	0	°C
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Readings	Non LTC Totalizer Reading	0.00	kw
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments	XFMR is Gone	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments	Gone	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	9 Months Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Amps A Ø	0.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Amps B Ø	0.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Amps C Ø	0.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Fault Operations A Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Fault Operations B Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Fault Operations C Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Fault Operations Ground	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Maintenance Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Operations Counter AF	424	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Operations Counter AL	424	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Operations This Read AM	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Switching Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Unknown Operations	0	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	General Comments		
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Vegetation	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	General Comments		
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Ambient Temp	43	*F
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BCH000134	Charger	MG-Battery Charger-Distribution	Battery Charger Patrol Insp	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BCH000134	Charger	MG-Battery Charger-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BCH000134	Charger	MG-Battery Charger-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BCH000134	Charger	MG-Battery Charger-Distribution	Battery Charger Patrol Insp	Battery Charger Current	4.5	amps
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BCH000134	Charger	MG-Battery Charger-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	133.5	VDC
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BCH000134	Charger	MG-Battery Charger-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	133.5	VDC
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BCH000134	Charger	MG-Battery Charger-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	4.500	millivolts
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	LTCC000842	LTCControl	433-2	LTC Control Insp	VRR Time Delay	30	Seconds
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	LTCC000842	LTCControl	433-2	LTC Control Insp	VRR Base Voltage AL	124	VAC
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	LTCC000842	LTCControl	433-2	LTC Control Insp	VRR Base Voltage AF	124	VAC
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	LTCC000842	LTCControl	433-2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	LTCC000842	LTCControl	433-2	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	LTCC000842	LTCControl	433-2	LTC Control Insp	LTC Operation Checked?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	LTCC000842	LTCControl	433-2	LTC Control Insp	General Comments		
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	LTCC000842	LTCControl	433-2	LTC Control Insp	Follow-up Action Required?	n	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	LTCC000842	LTCControl	433-2	LTC Control Insp	All Connections OK?	y	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	43	*F
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	General Comments	Oil level is low. The level can't even be seen in gauge.	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Readings	General Comments	ok	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	415.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	400.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Readings	Oil Temp Max	50	°C
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Readings	Oil Temp Present	20	°C
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Radiator Leaks	Seeping	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Tank Oil Level	Very Low	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps A Ø	312.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps B Ø	307.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps C Ø	310.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	.5	VDC
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	.2	VDC
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	45	*F
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AF	486	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AL	486	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations This Read AM	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Switching Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Unknown Operations	0	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Readings	Oil Temp Present	22	°C
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Readings	Oil Temp Max	48	°C
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	8.33	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Readings	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	1	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	Oil Temp Max	63	°C
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	Oil Temp Present	42	°C
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	X1 Winding Temp Max	70	°C
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	X1 Winding Temp Present	45	°C
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	X2 Winding Temp Max	70	°C
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	X2 Winding Temp Present	50	°C
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	X3 Winding Temp Max	70	°C
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	X3 Winding Temp Present	45	°C
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	BCH000512	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	BCH000512	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	BCH000512	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	BCH000512	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	BCH000512	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53	VDC
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	BCH000512	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53	VDC
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	BCH000512	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Amps C Ø	245	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Amps B Ø	185	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Amps A Ø	185	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Accumulated Fault Duty C Ph V	2.95	%
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Accumulated Fault Duty B Ph V	0	%
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Accumulated Fault Duty A Ph V	3.93	%
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	9 Month Operations	4	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	BCH000600	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	BCH000600	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	BCH000600	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	BCH000600	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	BCH000600	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.7	VDC
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	BCH000600	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.7	VDC
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	BCH000600	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	All Connections OK?	y	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	BCH000559	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	BCH000559	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	BCH000559	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	BCH000559	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	51.5	VDC
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	BCH000559	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	51.5	VDC
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	BCH000559	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Unknown Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Switching Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Operations This Read AM	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Operations Counter AL	370	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Operations Counter AF	370	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Maintenance Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Fault Operations Ground	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Fault Operations C Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Fault Operations A Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Amps C Ø	2.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Amps B Ø	2.0	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	General Comments		
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	General Comments		
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Unknown Operations	0	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Switching Operations	0	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Operations This Read Vac	0	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Operations Counter AL	282	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Operations Counter AF	282	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Maintenance Operations	0	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	General Comments		
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	General Comments		
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Follow-up Action Required?	n	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Fault Operations Ground	0	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Fault Operations C Ø	0	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Fault Operations B Ø	0	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Fault Operations A Ø	0	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Fault Adjusted Amps C Phase V	0	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Fault Adjusted Amps B Phase V	0	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Fault Adjusted Amps A Phase V	0	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	9 Month Operations	3	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Unknown Operations	0	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Switching Operations	5	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Operations This Read Vac	5	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	PF000310	PowerFuse	PL-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	PF000310	PowerFuse	PL-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	PF000309	PowerFuse	PL-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	PF000309	PowerFuse	PL-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Operations Counter AL	281	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Operations Counter AF	281	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Maintenance Operations	0	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	General Comments		
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	General Comments		
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Follow-up Action Required?	n	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Fault Operations Ground	0	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Fault Operations C ∅	0	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Fault Operations B ∅	0	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Fault Operations A ∅	0	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	General Comments		
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Ambient Temp	45	*F
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Amps C ∅	140.0	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Amps B ∅	120.0	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Amps A ∅	130.0	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	General Comments		
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	General Comments		
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Follow-up Action Required?	n	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Fault Operations Ground	0	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Fault Operations C ∅	0	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Fault Operations B ∅	0	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Fault Operations A ∅	0	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Amps C ∅	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	PF000226	PowerFuse	MG-STA SER NO 5	Disconnect Powerfuse Inspection	General Comments	ok	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	PF000226	PowerFuse	MG-STA SER NO 5	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	PF000225	PowerFuse	MG-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	ok	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	PF000225	PowerFuse	MG-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	PF000224	PowerFuse	MG-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	PF000224	PowerFuse	MG-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	PF000221	PowerFuse	MG-14KV BUS SEC A POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	PF000221	PowerFuse	MG-14KV BUS SEC A POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	PF000220	PowerFuse	MG-1322 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	PF000220	PowerFuse	MG-1322 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	General Comments	BRKR is Gone	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	General Comments	BRKR is Gone. Sub being rebuilt	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Maintenance Operations	0	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations Counter AF	212	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations Counter AL	0	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	9 Month Operations	0	
12/4/2020 14:48	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	9 Month Operations	9	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	23	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0	%
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0	%
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0	%
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	20	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	20	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	20	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	65	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	65	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	0	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	General Comments		
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Vegetation	None	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Yard Lights Working?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	PF000219	PowerFuse	MG-1330 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	PF000219	PowerFuse	MG-1330 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	PF000218	PowerFuse	MG-452 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	PF000218	PowerFuse	MG-452 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	PF000217	PowerFuse	MG-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	PF000217	PowerFuse	MG-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	9 Month Operations	2	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Follow-up Action Required?	n	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	General Comments		
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	General Comments		
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Maintenance Operations	0	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Operations Counter AF	388	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Operations Counter AL	388	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Operations This Read Vac	0	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Switching Operations	0	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Unknown Operations	0	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Ambient Temp	43	°F
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	General Comments		
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Vegetation	None	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	Follow-up Action Required?	n	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	General Comments		
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	General Comments		
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	LTC Totalizer Reading	9599.40	kw
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	Oil Temp Max	35	°C
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	Oil Temp Present	30	°C
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	Follow-up Action Required?	n	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	General Comments		
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	General Comments		
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	LTC Totalizer Reading	12159.00	kw
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	Oil Temp Max	47	°C
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	Oil Temp Present	31	°C
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	Totalizer Meter Reading	.6755	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	Winding Temp Max	80	°C
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	Winding Temp Present	35	°C
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	9 Month Operations	4	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Accumulated Fault Duty A Ph V	1.37	%
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Accumulated Fault Duty B Ph V	.46	%
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Accumulated Fault Duty C Ph V	1.83	%
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Amps A Ø	280	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Amps B Ø	280	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Amps C Ø	280	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Fault Adjusted Amps A Phase V	0	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Fault Adjusted Amps B Phase V	0	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Fault Adjusted Amps C Phase V	0	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Fault Operations A Ø	0	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Fault Operations B Ø	0	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Fault Operations C Ø	0	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Fault Operations Ground	0	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Operations This Read Vac	0	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Switching Operations	0	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Unknown Operations	0	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000114	LTCControl	PL-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000114	LTCControl	PL-TRANS 1	LTC Control Insp	General Comments	OK	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Unknown Operations	0	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Switching Operations	0	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Operations This Read Vac	0	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Operations Counter AL	151	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Operations Counter AF	151	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Maintenance Operations	0	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	PF000216	PowerFuse	MG-407 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	PF000216	PowerFuse	MG-407 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	PF000223	PowerFuse	MG-14KV BUS SEC C POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	PF000223	PowerFuse	MG-14KV BUS SEC C POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	PF000211	PowerFuse	MG-4KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	PF000211	PowerFuse	MG-4KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	General Comments		
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Follow-up Action Required?	n	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Fault Operations Ground	0	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Fault Operations C Ø	0	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Fault Operations B Ø	0	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Fault Operations A Ø	0	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	PF000227	PowerFuse	MG-14KV TR 5 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	PF000227	PowerFuse	MG-14KV TR 5 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Amps C Ø	176.0	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Amps B Ø	192.0	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Amps A Ø	183.0	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	9 Month Operations	0	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Unknown Operations	0	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Switching Operations	0	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Operations This Read Vac	0	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Operations Counter AL	185	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Operations Counter AF	185	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Maintenance Operations	0	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	General Comments		
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	Totalizer Meter Reading	.5333	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	Winding Temp Max	35	°C
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	Winding Temp Present	35	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	PF000222	PowerFuse	MG-14KV BUS SEC B POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	PF000222	PowerFuse	MG-14KV BUS SEC B POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	PF000212	PowerFuse	MG-417 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	PF000212	PowerFuse	MG-417 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	9 Month Operations	19	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Fault Operations A Ø	0	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Fault Operations B Ø	0	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Fault Operations C Ø	0	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Fault Operations Ground	0	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Follow-up Action Required?	n	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	General Comments		
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	General Comments		
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Maintenance Operations	0	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Operations Counter AF	135	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Operations Counter AL	135	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Acceptable Building Appearance?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Broom on Site?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Control House Lighting OK?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Amps A Ø	0.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Amps B Ø	0.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Amps C Ø	0.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Fault Operations A Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Fault Operations B Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Fault Operations C Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Fault Operations Ground	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Maintenance Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Door Alarms OK?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Evidence of Insects	None	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	9 Month Operations	4	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Accumulated Fault Duty A Ph V	0	%
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Accumulated Fault Duty B Ph V	0	%
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Accumulated Fault Duty C Ph V	0	%
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Amps A Ø	200	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Amps B Ø	265	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Amps C Ø	245	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Floor Swept?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Unknown Operations	0	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Switching Operations	0	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Operations This Read Vac	0	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Operations Counter AL	290	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Operations Counter AF	290	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Maintenance Operations	0	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	General Comments		
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Patrol Inspection	General Comments		
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Fault Operations Ground	0	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	General Comments		
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	General Comments		
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	LTC Totalizer Reading	5555.52	kw
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	Oil Temp Max	55	°C
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	Oil Temp Present	36	°C
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Amps C Ø	64.0	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Amps B Ø	67.0	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Amps A Ø	76.0	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	9 Month Operations	27	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	9 Months Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Amps C Ø	65.0	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Amps B Ø	24.0	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Amps A Ø	46.0	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Operations Counter AL	171	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Unknown Operations	0	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Switching Operations	2	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Operations This Read Vac	4	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Operations Counter AL	252	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Operations Counter AF	252	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Maintenance Operations	2	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	General Comments		
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	General Comments		
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Follow-up Action Required?	n	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Fault Operations Ground	0	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Fault Operations C Ø	0	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Fault Operations A Ø	0	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Amps C Ø	199.0	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Amps B Ø	158.0	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Amps A Ø	155.0	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	9 Month Operations	7	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Panel Lights OK?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Panels Dusted?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Restroom Clean & OK?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Station Ground Set On Site?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Trash Emptied?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Fault Adjusted Amps A Phase V	0	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Fault Adjusted Amps B Phase V	0	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Fault Adjusted Amps C Phase V	0	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Fault Operations A Ø	0	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Fault Operations B Ø	0	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Fault Operations C Ø	0	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Fault Operations Ground	0	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Follow-up Action Required?	n	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Patrol Inspection	General Comments		
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	General Comments		
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Maintenance Operations	0	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Operations Counter AF	171	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Operations Counter	7	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Operations Counter AF	42	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Operations Counter AL	42	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Operations This Read AM	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Switching Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Unknown Operations	0	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	General Comments		
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Counter Readings	LTC Operations Since Last Insp	0	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	0	°C
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	0	°C
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1	psi
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Counter Readings	LTC Min Tap Position	Neutral	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Counter Readings	LTC As Left Counter	1855	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Counter Readings	LTC As Found Counter	1855	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Mechanism Patrol Inspection	General Comments		
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Counter Readings	General Comments		
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Counter Readings	Follow-up Action Required?	n	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	Winding Temp Present	0	°C
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	Winding Temp Max	0	°C
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	Totalizer Meter Reading	0	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	Totalizer Meter Multiplier	0	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	Oil Temp Present	0	°C
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	Oil Temp Max	0	°C
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1700	psi
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	LTC Totalizer Reading	0	kw
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	General Comments		
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	General Comments		
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Vegetation	None	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	General Comments		
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	General Comments		
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
12/4/2020 8:28	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	LTCC000882	LTCControl	663-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	LTCC000882	LTCControl	663-1	LTC Control Insp	VRR Base Voltage AL	124	VAC
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	LTCC000882	LTCControl	663-1	LTC Control Insp	VRR Base Voltage AF	124	VAC
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	LTCC000882	LTCControl	663-1	LTC Control Insp	LTC Output Voltage Level	0	VAC
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	LTCC000882	LTCControl	663-1	LTC Control Insp	LTC Operation Checked?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	LTCC000882	LTCControl	663-1	LTC Control Insp	General Comments		
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	LTCC000882	LTCControl	663-1	LTC Control Insp	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	LTCC000882	LTCControl	663-1	LTC Control Insp	All Connections OK?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Fault Operations B Ø	0	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	Follow-up Action Required?	n	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Fault Operations A Ø	0	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Amps C Ø	56.0	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Amps B Ø	55.0	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Amps A Ø	58.0	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	9 Month Operations	15	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Patrol Inspection	General Comments		
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	26.00	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	General Comments		
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Patrol Inspection	General Comments		
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000645	LTCControl	593-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000645	LTCControl	593-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000645	LTCControl	593-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000645	LTCControl	593-1	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000645	LTCControl	593-1	LTC Control Insp	LTC Operation Checked?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000645	LTCControl	593-1	LTC Control Insp	General Comments		
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000645	LTCControl	593-1	LTC Control Insp	Follow-up Action Required?	n	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000645	LTCControl	593-1	LTC Control Insp	All Connections OK?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Unknown Operations	0	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Switching Operations	1	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Operations This Read Vac	1	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Operations Counter AL	109	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Operations Counter AF	108	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Maintenance Operations	0	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	General Comments		
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Patrol Inspection	General Comments		
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Follow-up Action Required?	n	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Fault Operations Ground	0	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Fault Operations C Ø	0	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Fault Operations A Ø	0	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Fault Operations B Ø	0	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Fault Operations C Ø	0	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Fault Operations Ground	0	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Follow-up Action Required?	n	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	General Comments		
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	General Comments		
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Maintenance Operations	0	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Operations Counter AF	168	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Operations Counter AL	168	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Operations This Read Vac	1	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Switching Operations	1	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Unknown Operations	0	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	LTCC000279	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	LTCC000279	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	LTCC000279	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	LTCC000279	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	LTCC000279	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.8	VAC
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	LTCC000279	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	BCH001408	Charger	778-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	BCH001408	Charger	778-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	BCH001408	Charger	778-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	BCH001408	Charger	778-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	BCH001408	Charger	778-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	BCH001408	Charger	778-Battery Charger	Battery Charger Patrol Insp	General Comments	.	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	BCH001408	Charger	778-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	9 Month Operations	2	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Amps A Ø	364.0	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Amps B Ø	370.0	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Amps C Ø	382.0	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Amps A Ø	77.0	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Amps B Ø	126.0	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Amps C Ø	124.0	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Fault Adjusted Amps A Phase V	27.36	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Fault Adjusted Amps B Phase V	27.36	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Fault Operations A Ø	6	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Fault Operations B Ø	6	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Fault Operations C Ø	0	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Fault Operations Ground	0	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Follow-up Action Required?	n	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	General Comments		
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	General Comments		
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Maintenance Operations	0	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Operations Counter AF	177	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Operations Counter AL	177	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Operations This Read Vac	12	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Switching Operations	0	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Unknown Operations	0	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	9 Month Operations	21	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Amps A Ø	90.0	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Amps B Ø	76.0	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Amps C Ø	84.0	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	General Comments		
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	LTCC000286	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	LTCC000286	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	LTCC000286	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	LTCC000286	LTCControl	920-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	LTCC000286	LTCControl	920-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	LTCC000286	LTCControl	920-Offline-Distribution	LTC Control Insp	General Comments		
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	LTCC000286	LTCControl	920-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	LTCC000286	LTCControl	920-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	LTC Operations Since Last Insp	335	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	LTC Min Tap Position	6L	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	LTC Max Tap Position	2R	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	LTC Current Tap Position	2L	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	LTC As Left Counter	73796	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	LTC As Found Counter	73793	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Mechanism Patrol Inspection	General Comments		
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	General Comments		
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	Follow-up Action Required?	n	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	LTCC000279	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	LTCC000279	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	40	Seconds
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Fault Operations A Ø	0	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Fault Operations B Ø	0	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Fault Operations C Ø	0	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Fault Operations Ground	0	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Follow-up Action Required?	n	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	General Comments		
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	General Comments		
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Maintenance Operations	0	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Operations Counter AF	211	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Operations Counter AL	211	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Operations This Read Vac	0	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Switching Operations	0	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Unknown Operations	0	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #"'s
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	General Comments		
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Fault Operations Ground	0	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Fault Operations C Ø	0	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Fault Operations B Ø	0	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Fault Operations A Ø	0	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Amps C Ø	120.0	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Unknown Operations	0	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Switching Operations	0	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Operations This Read Vac	0	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Operations Counter AL	165	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Operations Counter AF	165	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Maintenance Operations	0	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Unknown Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Operations This Read AM	0	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Amps B Ø	120.0	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Amps A Ø	120.0	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	9 Month Operations	7	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	LTCC000922	LTCControl	778-1	LTC Control Insp	All Connections OK?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	LTCC000922	LTCControl	778-1	LTC Control Insp	Follow-up Action Required?	n	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	LTCC000922	LTCControl	778-1	LTC Control Insp	General Comments		
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	LTCC000922	LTCControl	778-1	LTC Control Insp	LTC Operation Checked?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	LTCC000922	LTCControl	778-1	LTC Control Insp	LTC Output Voltage Level	124.8	VAC
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	LTCC000922	LTCControl	778-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Operations This Read Vac	2	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Switching Operations	2	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001565	BreakerVacuum	433-0628	VCB Readings	Unknown Operations	0	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Unknown Operations	0	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	Totalizer Meter Reading	.7716	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Switching Operations	0	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Operations This Read Vac	0	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Operations Counter AL	151	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Operations Counter AF	151	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Maintenance Operations	0	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Grounds in Place?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	General Comments		
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	General Comments		
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	SWG000170	Switchgear	MG-14KV Sec A Swgr	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	SWG000170	Switchgear	MG-14KV Sec A Swgr	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	SWG000170	Switchgear	MG-14KV Sec A Swgr	Switchgear Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	SWG000170	Switchgear	MG-14KV Sec A Swgr	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	SWG000170	Switchgear	MG-14KV Sec A Swgr	Switchgear Patrol Inspection	Panels Dusted?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	SWG000170	Switchgear	MG-14KV Sec A Swgr	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Evidence of Insects	None	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Panels Dusted?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Fault Adjusted Amps A Phase V	0	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Amps C Ø	50	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Amps B Ø	80	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Amps A Ø	75	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Accumulated Fault Duty C Ph V	0	%
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Accumulated Fault Duty B Ph V	0	%
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Accumulated Fault Duty A Ph V	0	%
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	9 Month Operations	29	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	9 Months Operations	0	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Regulator As Left Counter	122690	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Max Tap Position	2L	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	General Comments		
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	9 Month Operations	36	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	LTCC000922	LTCControl	778-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	LTCC000922	LTCControl	778-1	LTC Control Insp	VRR Time Delay	60	Seconds
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Operations Counter AL	246	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Operations Counter AF	246	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Maintenance Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Patrol Inspection	General Comments		
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	General Comments		
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Follow-up Action Required?	n	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	44	*F
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Fault Operations Ground	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Fault Operations C Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Fault Operations B Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Fault Operations A Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Amps C Ø	13.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Amps B Ø	13.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Amps A Ø	13.0	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	General Comments		
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Fault Operations Ground	0	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Fault Operations C Ø	0	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Fault Operations B Ø	0	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Fault Operations A Ø	0	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Fault Adjusted Amps C Phase V	0	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Fault Adjusted Amps B Phase V	0	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	Percent Thermal Load B Ø Max	0	%
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments	Gone	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments	XFMR is Gone	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BCH001345	Charger	301-Battery Charger	Battery Charger Patrol Insp	General Comments	1.8 mv ripple. No place in form to fill in	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BCH001345	Charger	301-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	3.93	%
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	6.88	%
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	5.9	%
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	7	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	General Comments		
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	Follow-up Action Required?	n	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	General Comments		
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Mechanism Patrol Inspection	General Comments		
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	LTC As Found Counter	98266	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	LTC As Left Counter	98276	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	Oil Temp Max	40	°C
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1400	psi
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	MegaWatt Demand Meter Min	0.00	MegaWatts
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	MegaWatt Demand Meter Max	0.00	MegaWatts
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	MegaVar Demand Meter Min	0.00	MegaVars
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	MegaVar Demand Meter Max	0.00	MegaVars
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	LV Winding Temp Present	0	°C
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	LV Winding Temp Max	0	°C
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	Kwh Reading	0	kWh
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	HV Winding Temp Present	0	°C
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	HV Winding Temp Max	0	°C
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	H3 Winding Temp Present	0	°C
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	H3 Winding Temp Max	0	°C
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	H2 Winding Temp Present	25	°C
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	H2 Winding Temp Max	40	°C
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	H1 Winding Temp Present	0	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	H1 Winding Temp Max	0	°C
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	General Comments	readings with 0 needs to be removed from insp.	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BCH001345	Charger	301-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BCH001345	Charger	301-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BCH001345	Charger	301-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.5	amps
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BCH001345	Charger	301-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BCH001345	Charger	301-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Readings	Winding Temp Max	50	°C
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Readings	Winding Temp Present	50	°C
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	220	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Fault Operations A Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Fault Operations B Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Fault Operations C Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Fault Operations Ground	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Maintenance Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Operations Counter AF	318	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Operations Counter AL	318	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Operations This Read AM	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Switching Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Unknown Operations	0	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Regulator As Left Counter	0	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	0.0	volts
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Reg Operation Checked?	n	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Min Tap Position	Neutral	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	LTC Operations Since Last Insp	530	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	26	°C
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	46	°C
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	LTC Min Tap Position	10L	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	General Comments	Regulator removed from substation	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	9 Months Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Amps A Ø	200.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Amps B Ø	200.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Amps C Ø	200.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Readings	General Comments		
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Readings	LTC Totalizer Reading	15012	kw
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Max	60	°C
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Present	42	°C
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Readings	Totalizer Meter Reading	.834	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Maintenance Operations	0	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	General Comments		
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	General Comments		
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Follow-up Action Required?	n	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Fault Operations Ground	0	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Fault Operations C Ø	0	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Fault Operations B Ø	0	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Fault Operations A Ø	0	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Fault Adjusted Amps C Phase V	0	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Fault Adjusted Amps B Phase V	0	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Fault Adjusted Amps A Phase V	0	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Amps C Ø	475	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Amps B Ø	545	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Amps A Ø	435	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Accumulated Fault Duty C Ph V	0	%
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Accumulated Fault Duty B Ph V	0	%
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Accumulated Fault Duty A Ph V	0	%
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	9 Month Operations	0	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	General Comments		
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Vegetation	None	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Patrol Inspection	General Comments		
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	Y3 Winding Temp Present	0	°C
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	Y3 Winding Temp Max	0	°C
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Current Tap Position	Neutral	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Regulator As Left Counter	0	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	0.0	volts
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Reg Operation Checked?	n	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	LTC As Left Counter	160765	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	LTC As Found Counter	160765	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Mechanism Patrol Inspection	General Comments		
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	General Comments		
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	Follow-up Action Required?	n	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Min Tap Position	Neutral	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	General Comments	Regulator removed from substtion	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Current Tap Position	Neutral	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Unknown Operations	0	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Switching Operations	0	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Operations This Read Vac	0	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Operations Counter AL	145	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Operations Counter AF	145	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Ambient Temp	43	°F
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	General Comments		
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0	%
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0	%
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0	%
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	12	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	67	°F
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Battery Bank Amps	2.9	AMPS
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Battery Bank Volts	53.6	VDC
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.2	VDC
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Positive DC Ground	25.7	VDC
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BCH001392	Charger	468-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.6	VDC
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BCH001392	Charger	468-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.6	VDC
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BCH001392	Charger	468-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.9	amps
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BCH001392	Charger	468-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	BCH001392	Charger	468-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Current Tap Position	1L	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	General Comments		
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Max Tap Position	2R	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Min Tap Position	6L	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Amps C Ø	110.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Amps B Ø	95.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Amps A Ø	133.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	9 Months Operations	0	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	LTCC000698	LTCControl	301-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	LTCC000698	LTCControl	301-2	LTC Control Insp	VRR Time Delay	45	Seconds
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	450	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	450	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	450	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	363	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	LTC Min Tap Position	12L	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	LTC Max Tap Position	5L	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	LTC Current Tap Position	10L	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	LTC As Left Counter	23740	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	LTC As Found Counter	23740	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Min Tap Position	8L	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Regulator As Left Counter	15023	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Tank Leaks	None	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	43	°F
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Battery Bank Amps	1.5	AMPS
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Battery Bank Volts	53.0	VDC
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	General Comments		
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	Follow-up Action Required?	n	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	General Comments		
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Mechanism Patrol Inspection	General Comments		
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	LTC As Found Counter	123276	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	LTC As Left Counter	123276	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	LTC Current Tap Position	4L	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	LTC Min Tap Position	11L	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	LTC Operations Since Last Insp	916	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/4/2020 14:04	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Regulator As Left Counter	18785	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Tank Leaks	None	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Current Tap Position	4L	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	General Comments		
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Min Tap Position	4L	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Regulator As Left Counter	16454	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Tank Leaks	None	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Current Tap Position	6L	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	General Comments		
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	SWG000169	Switchgear	MG-14KV Sec B Swgr	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	SWG000169	Switchgear	MG-14KV Sec B Swgr	Switchgear Patrol Inspection	Panels Dusted?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	SWG000169	Switchgear	MG-14KV Sec B Swgr	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	SWG000169	Switchgear	MG-14KV Sec B Swgr	Switchgear Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	SWG000169	Switchgear	MG-14KV Sec B Swgr	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	SWG000169	Switchgear	MG-14KV Sec B Swgr	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Vegetation	None	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	General Comments		
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Fault Operations A Ø	0	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Fault Operations B Ø	0	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Fault Operations C Ø	0	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Fault Operations Ground	0	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Follow-up Action Required?	n	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	General Comments		
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	General Comments		
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	LTC Max Tap Position	4R	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	LTC Min Tap Position	6L	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	LTC Operations Since Last Insp	850	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	General Comments		
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Ambient Temp	45	°F

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	9 Month Operations	1	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Amps A Ø	320.0	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Amps B Ø	320.0	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Amps C Ø	320.0	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Fault Operations B Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Fault Operations A Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Amps C Ø	208.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Amps B Ø	212.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Amps A Ø	215.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	9 Months Operations	0	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	0	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	12	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	12	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	LTCC000698	LTCControl	301-2	LTC Control Insp	All Connections OK?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	LTCC000698	LTCControl	301-2	LTC Control Insp	Follow-up Action Required?	n	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Unknown Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Switching Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Operations This Read AM	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Operations Counter AL	444	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Operations Counter AF	444	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Maintenance Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	LTCC000698	LTCControl	301-2	LTC Control Insp	General Comments		
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	LTCC000698	LTCControl	301-2	LTC Control Insp	LTC Operation Checked?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	LTCC000698	LTCControl	301-2	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	LTCC000698	LTCControl	301-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Fault Operations Ground	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Fault Operations C Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Fault Operations B Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Fault Operations A Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Maintenance Operations	0	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Operations Counter AF	66	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Operations Counter AL	66	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Operations This Read Vac	0	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Switching Operations	0	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Unknown Operations	0	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BCH001380	Charger	828-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BCH001380	Charger	828-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BCH001380	Charger	828-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BCH001380	Charger	828-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.3	amps
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BCH001380	Charger	828-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BCH001380	Charger	828-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	°F
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	General Comments		
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Unknown Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Switching Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Operations This Read AM	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Operations Counter AL	476	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Operations Counter AF	476	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Maintenance Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Fault Operations Ground	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Fault Operations C Ø	0	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Reg Operation Checked?	n	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	0.0	volts
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Regulator As Left Counter	0	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Exp/Missing Not Repl	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	General Comments		
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	PF001256	PowerFuse	PL-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/4/2020 22:12	Distribution	Pleasure Ridge Quarterly Inspection	PF001256	PowerFuse	PL-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	Follow-up Action Required?	n	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	General Comments		
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	General Comments		
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	General Comments		
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Ambient Temp	43	*F
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	95	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Mechanism Patrol Inspection	General Comments		
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	LTC As Found Counter	131888	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	General Comments		
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	4	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0	%
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0	%
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0	%
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	90	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	90	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	90	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	General Comments	Regulator removed from substation	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Min Tap Position	Neutral	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	0	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	Totalizer Meter Reading	.6290	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	Oil Temp Present	40	*C
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	Oil Temp Max	50	*C
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	LTC Totalizer Reading	14688	kw
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	General Comments		
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	Oil Temp Present	30	°C
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Filters Condition OK?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Operations This Read AM	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Switching Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Unknown Operations	0	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	470	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	LTC As Left Counter	131888	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	LTC Current Tap Position	1R	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	LTC Max Tap Position	16R	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	LTC Min Tap Position	10L	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	LTC Operations Since Last Insp	1121	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	Winding Temp Present	50	°C
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	Winding Temp Max	75	°C
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	29	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	29	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	Totalizer Meter Reading	1.53	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	9 Months Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	General Comments		
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Amps C Ø	75.0	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Amps A Ø	40.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Amps B Ø	30.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Amps C Ø	30.0	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Vegetation	None	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/4/2020 8:45	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Fault Operations A Ø	0	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Fault Operations B Ø	0	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Fault Operations C Ø	0	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Fault Operations Ground	0	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Regulator As Left Counter	2634	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2020 9:57	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Follow-up Action Required?	n	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	General Comments		
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	General Comments		
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Operations Counter AF	190	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Operations Counter AL	190	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Vegetation	None	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Operations This Read Vac	1	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Switching Operations	1	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Unknown Operations	0	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Fault Operations A Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Fault Operations B Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Fault Operations C Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Fault Operations Ground	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Maintenance Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Operations Counter AF	358	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Operations Counter AL	358	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Trip Bkr Coil 2 or Aux Rly	na	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Trip Bkr Coil 1 or Aux Rly	n	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Relay Trip Targets OK?	na	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Prove All BFI DC Paths	na	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	General Comments	ok	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Follow-up Action Required?	n	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Alarm Operation Correct?	n	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	RLY027318	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Trip Bkr Coil 2 or Aux Rly	na	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	RLY027318	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Trip Bkr Coil 1 or Aux Rly	n	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	RLY027318	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Prove All BFI DC Paths	na	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	RLY027318	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	General Comments	ok	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	RLY027318	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Follow-up Action Required?	n	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	50	*F
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Amps B Ø	81.0	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Amps A Ø	63.0	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	9 Month Operations	9	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	General Comments		
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Ambient Temp	45	*F
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	General Comments		
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Regulator As Left Counter	116918	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	General Comments		
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
12/4/2020 9:02	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	General Comments		
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	10980	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	9 Month Operations	12	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Amps A Ø	190.0	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	General Comments		
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Amps B Ø	230.0	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Amps C Ø	190.0	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Fault Operations A Ø	0	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	BCH001438	Charger	663-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	General Comments	ok	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	General Comments	ok	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Amps C Ø	0.0	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	General Comments		
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/4/2020 14:54	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	850	psi
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	Totalizer Meter Reading	.5904	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	217.50	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	210.00	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	Oil Temp Max	50	°C
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	Oil Temp Present	18	°C
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Follow-up Action Required?	n	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	General Comments		
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	General Comments		
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Maintenance Operations	0	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Operations Counter AF	372	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Patrol Inspection	Bushing Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Amps C Ø	191.0	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Amps B Ø	110.0	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Amps A Ø	125.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Operations Counter AL	372	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Operations This Read Vac	0	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	9 Month Operations	2	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Unknown Operations	0	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Switching Operations	0	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	Oil Temp Max	35	°C
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	LTC Totalizer Reading	6038.40	kw
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	General Comments		
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	General Comments		
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/7/2020 7:18	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	Follow-up Action Required?	n	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	General Comments		
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Mechanism Patrol Inspection	General Comments		
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	LTC As Found Counter	15467	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	LTC As Left Counter	15471	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	LTC Current Tap Position	2L	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	LTC Max Tap Position	2R	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	LTC Min Tap Position	7L	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	LTC Operations Since Last Insp	507	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	Winding Temp Max	66	°C
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	Winding Temp Present	42	°C
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Fault Operations C ∅	0	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Fault Operations Ground	0	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Follow-up Action Required?	n	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	General Comments		
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	General Comments		
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Maintenance Operations	0	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Operations Counter AF	207	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Operations Counter AL	207	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Operations This Read Vac	7	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Switching Operations	7	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 13:15	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Unknown Operations	0	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	10980	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	5L	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Max Tap Position	4L	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Min Tap Position	12L	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	547	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/4/2020 15:01	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	Follow-up Action Required?	n	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	General Comments		
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Mechanism Patrol Inspection	General Comments		
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	LTC As Found Counter	77806	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	LTC As Left Counter	77806	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	LTC Current Tap Position	1L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	LTC Max Tap Position	16R	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	LTC Min Tap Position	9L	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	-5	psi
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	LTC Operations Since Last Insp	756	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/4/2020 15:16	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Fault Operations A Ø	0	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Fault Operations B Ø	0	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Fault Operations C Ø	0	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Fault Operations Ground	0	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Fault Operations Ground	0	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Fault Operations C Ø	0	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Fault Operations B Ø	0	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Fault Operations A Ø	0	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/4/2020 12:07	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Switch Stick Next Test Date	2021-03-08 00:00:00.000000	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Vegetation	None	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Ambient Temp	43	*F
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Amps B Ø	0.0	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Amps A Ø	0.0	
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/4/2020 15:27	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	9 Month Operations	4	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	General Comments		
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
12/4/2020 13:25	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Vegetation	None	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	General Comments		
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Unknown Operations	0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Patrol Inspection	Tank Paint Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Switching Operations	2	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	470	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Operations This Read Vac	2	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Operations Counter AL	191	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Operations Counter AF	191	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Maintenance Operations	0	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Patrol Inspection	Grounds in Place?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	General Comments		
12/4/2020 13:16	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Patrol Inspection	General Comments		
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	75.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	75.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	75.0	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	BCH001438	Charger	663-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	BCH001438	Charger	663-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	134	VDC
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	BCH001438	Charger	663-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	134	VDC
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	BCH001438	Charger	663-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0	amps
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	BCH001438	Charger	663-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/4/2020 15:51	Distribution	Corporate Drive Quarterly Inspection	BCH001438	Charger	663-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Patrol Inspection	Foundation Condition	Good	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Readings	Follow-up Action Required?	n	
12/4/2020 11:10	Distribution	Big Stone Gap Quarterly Inspection	BK001592	BreakerVacuum	301-4704	VCB Patrol Inspection	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
12/4/2020 15:00	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Current Tap Position	5R	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Maintenance Operations	0	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Grounds in Place?	y	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Min Tap Position	1R	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Max Tap Position	5R	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Fault Operations A Ø	0	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Fault Operations B Ø	0	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Fault Operations C Ø	0	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Fault Operations Ground	0	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	General Comments		
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	General Comments		
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	General Comments		
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Foundation Condition	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Follow-up Action Required?	n	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	0	°C
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	0	°C
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Fault Operations A Ø	0	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Fault Operations B Ø	0	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Fault Operations C Ø	0	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Fault Operations Ground	0	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Follow-up Action Required?	n	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Foundation Condition	Good	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Amps A Ø	40.0	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Amps B Ø	25.0	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Amps C Ø	22.0	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	General Comments		
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	9 Month Operations	0	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Operations Counter	15	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Unknown Operations	0	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Amps A Ø	175.0	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	0	°C
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	0	°C
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	0	°C
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	Oil Temp Present	0	°C
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	Oil Temp Max	0	°C
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	0	°C
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	0	°C
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Regulator As Left Counter	30296	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Tank Leaks	None	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Amps C Ø	19.0	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Amps B Ø	21.0	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Amps A Ø	22.0	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Bushing Condition	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Amps C Ø	240.0	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Amps B Ø	240.0	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Amps A Ø	240.0	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	9 Month Operations	2	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Grounds in Place?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	General Comments		
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Foundation Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	0	°C
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Amps A Ø	22.0	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Follow-up Action Required?	n	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 16:25	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Vegetation	None	
12/3/2020 16:25	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	General Comments		
12/3/2020 16:25	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 16:25	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/3/2020 16:25	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/3/2020 16:25	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/3/2020 16:25	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/3/2020 16:25	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/3/2020 16:25	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/3/2020 16:25	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/3/2020 16:25	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Ambient Temp	30	°F
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Counter Readings	General Comments		
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Fault Operations A Ø	0	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Fault Operations B Ø	0	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Fault Operations C Ø	0	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Fault Operations Ground	0	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Follow-up Action Required?	n	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Foundation Condition	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	General Comments		
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	General Comments		
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Grounds in Place?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Maintenance Operations	0	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Operations Counter AF	7	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Operations Counter AL	7	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Operations This Read Vac	0	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Found Counter	169990	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Left Counter	169995	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Current Tap Position	3L	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Max Tap Position	7L	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Min Tap Position	1R	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Operations Since Last Insp	602	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Switching Operations	0	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Amps B Ø	21.0	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Amps C Ø	19.0	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Unknown Operations	0	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Amps B Ø	165.0	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Amps C Ø	155.0	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Bushing Condition	Good	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	General Comments		
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	General Comments		
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Regulator As Left Counter	40135	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Min Tap Position	12L	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Max Tap Position	5L	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	General Comments		
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Current Tap Position	7L	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Operations Counter	3	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Operations Counter AF	245	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Operations Counter AL	245	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Operations This Read Vac	0	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Switching Operations	0	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Amps A Ø	150.0	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Ambient Temp	41	*F
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	General Comments		
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Amps B Ø	150.0	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Amps C Ø	150.0	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Bushing Condition	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	BCH001375	Charger	680-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	BCH001375	Charger	680-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	BCH001375	Charger	680-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	BCH001375	Charger	680-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	BCH001375	Charger	680-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	BCH001375	Charger	680-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	BCH001375	Charger	680-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	BCH001375	Charger	680-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Vegetation	None	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	General Comments		
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Operations Counter	13	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	9 Month Operations	23	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Amps A Ø	0.0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Amps B Ø	0.0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Amps C Ø	0.0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Bushing Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Fault Operations A Ø	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Fault Operations B Ø	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Fault Operations C Ø	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Fault Operations Ground	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Foundation Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	General Comments		
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Grounds in Place?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Operations Counter	1972	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	General Comments		
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Unknown Operations	0	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Switching Operations	0	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Operations This Read Vac	0	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Operations Counter AL	329	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Operations Counter AF	329	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Maintenance Operations	0	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Amps C Ø	5.0	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Amps B Ø	5.0	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Amps A Ø	5.0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Maintenance Operations	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Operations Counter AF	236	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Operations Counter AL	236	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Readings	Operations This Read Vac	0	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Grounds in Place?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	General Comments		
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	General Comments		
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Foundation Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Fault Operations B Ø	0	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Follow-up Action Required?	n	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Patrol Inspection	General Comments		
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	General Comments	Actual counter, offline	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Maintenance Operations	0	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Num Operations Last 9 Months	6	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Operations Counter AF	262	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Operations Counter AL	262	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Operations This Read SF6	0	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Switching Operations	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Fault Operations C Ø	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Fault Operations Ground	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Foundation Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	General Comments		
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	General Comments		
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Grounds in Place?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Maintenance Operations	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Operations Counter AF	503	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Operations Counter AL	503	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Operations This Read Vac	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Switching Operations	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Grounds in Place?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	General Comments		
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Bushing Condition	Good	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Bushing Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Foundation Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	General Comments		
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Grounds in Place?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	9 Month Operations	7	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	General Comments	Relay not working properly, P&C coming to replace today.	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Grounds in Place?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Maintenance Operations	0	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Operations Counter AF	164	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Operations Counter AL	167	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Operations This Read Vac	3	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	34	*F
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Amps C Ø	220.0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Bushing Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Fault Operations A Ø	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Fault Operations B Ø	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Fault Operations C Ø	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Fault Operations Ground	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Foundation Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	General Comments		
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	General Comments		
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	General Comments		
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	LTC Totalizer Reading	14299.20	kw
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	Oil Temp Max	55	°C
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	Oil Temp Present	45	°C
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	General Comments		
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Grounds in Place?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Maintenance Operations	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Operations Counter AF	182	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Operations Counter AL	182	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Operations This Read Vac	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Readings	Switching Operations	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	Totalizer Meter Reading	.9930	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	Winding Temp Max	100	°C
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	Winding Temp Present	50	°C
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Follow-up Action Required?	n	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Fault Operations Ground	0	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Fault Operations C ∅	0	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Fault Operations B ∅	0	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Fault Operations A ∅	0	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Bushing Condition	Good	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Amps C ∅	90.0	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Amps B ∅	70.0	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Amps A ∅	90.0	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	Winding Temp Present	30	°C
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	9 Month Operations	4	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	9 Month Operations	4	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Amps A ∅	113.0	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Amps B ∅	91.0	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Amps C ∅	72.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Amps B Ø	468.0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Amps C Ø	465.0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Bushing Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Fault Operations A Ø	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Fault Operations B Ø	0	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Operations Counter	2029	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Amps A Ø	97.0	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Amps B Ø	85.0	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Amps C Ø	80.0	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	Follow-up Action Required?	n	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	General Comments		
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Mechanism Patrol Inspection	General Comments		
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Fault Operations C Ø	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Fault Operations Ground	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Foundation Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	General Comments		
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	General Comments		
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Grounds in Place?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Maintenance Operations	0	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	General Comments	off line due to Switch gear getting updated	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	General Comments	no ac power due to sw gear 1 getting updated	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Bushing Condition	Good	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Battery Bank Volts	53.0	VDC
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	General Comments		
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Operations Counter	16	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	LTCC000325	LTCControl	920-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	LTCC000325	LTCControl	920-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	LTCC000325	LTCControl	920-Offline-Distribution	LTC Control Insp	General Comments		
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	LTCC000325	LTCControl	920-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	LTCC000325	LTCControl	920-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	BCH000405	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	BCH000405	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	BCH000405	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	BCH000405	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	BCH000405	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	BCH000405	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	LTCC000325	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	LTCC000325	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	LTCC000325	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Foundation Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	General Comments		
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Grounds in Place?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Tank Leaks	None	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Regulator As Left Counter	78247	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Min Tap Position	11L	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Max Tap Position	4L	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	General Comments		
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Operations Counter	17	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Amps A Ø	35.0	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Amps B Ø	18.0	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Amps C Ø	30.0	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0234	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0234	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0234	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0234	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	General Comments		
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0234	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0234	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Current Tap Position	9L	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	General Comments		
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Max Tap Position	4L	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Min Tap Position	10L	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Regulator As Left Counter	85098	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Tank Leaks	None	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Switching Operations	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	9 Month Operations	25	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Amps A Ø	0.0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Amps B Ø	0.0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Amps C Ø	0.0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Bushing Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Amps A Ø	0.0	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Amps B Ø	0.0	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Amps C Ø	0.0	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Fault Operations	0	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Fault Operations A Ø	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Operations Counter AF	332	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Operations Counter AL	332	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Operations This Read Vac	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Readings	Switching Operations	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	9 Month Operations	22	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Amps A Ø	50.0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Amps B Ø	49.0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Amps C Ø	48.0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Bushing Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	General Comments		
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Fault Operations A Ø	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Fault Operations B Ø	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Fault Operations C Ø	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Fault Operations Ground	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Foundation Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	General Comments		
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	General Comments		
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Grounds in Place?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Maintenance Operations	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Operations Counter AF	438	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Operations Counter AL	438	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Operations This Read Vac	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	LTC As Found Counter	69014	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	LTC As Left Counter	69017	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	LTC Current Tap Position	10L	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	LTC Max Tap Position	11L	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	LTC Min Tap Position	6L	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	LTC Operations Since Last Insp	275	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Unknown Operations	0	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Switching Operations	0	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Operations This Read Vac	0	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Operations Counter AL	201	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Operations Counter AF	201	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Maintenance Operations	0	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Grounds in Place?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	General Comments		
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	Follow-up Action Required?	n	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	General Comments		
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Mechanism Patrol Inspection	General Comments		
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	LTC As Found Counter	84458	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	LTC As Left Counter	84461	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Switching Operations	0	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Operations This Read Vac	0	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Operations Counter AL	247	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Operations Counter AF	247	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	Oil Temp Present	35	°C
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	Oil Temp Max	55	°C
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Maintenance Operations	0	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	General Comments	offline, actual counter	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Patrol Inspection	General Comments		
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Fault Operations Ground	0	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Amps C Ø	0.0	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Amps B Ø	0.0	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Amps A Ø	0.0	
12/3/2020 16:25	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	40	*F
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/3/2020 16:25	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/3/2020 16:25	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
12/3/2020 16:25	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/3/2020 16:25	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	All Connections OK?	y	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	Current Tap Position	9R	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	Follow-up Action Required?	n	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	General Comments		
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	Max Tap Position	11R	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	Min Tap Position	4R	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	Reset Tap Drag Hands	Reset	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR Bandwidth AF	3.0	VAC
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR Bandwidth AL	3.0	VAC
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR Base Voltage AF	124.0	VAC
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Switching Operations	0	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Operations This Read SF6	0	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Operations Counter AL	645	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Operations Counter AF	645	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Num Operations Last 9 Months	0	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Maintenance Operations	0	
12/3/2020 16:25	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	General Comments		
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Patrol Inspection	General Comments		
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Follow-up Action Required?	n	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Fault Operations	0	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Amps C Ø	0.0	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Amps B Ø	0.0	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Amps A Ø	0.0	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR Base Voltage AL	124.0	VAC
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR Counter AF	119703	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR Counter AL	119703	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR R Compensation AF	0	Position
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR R Compensation AL	0	Position

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR Time Delay	45	Seconds
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	45	°C
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	60	°C
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	39	°C
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	60	°C
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	50	°C
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	60	°C
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/3/2020 16:25	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/3/2020 16:25	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/3/2020 16:25	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 16:25	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/3/2020 16:25	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
12/3/2020 16:25	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
12/3/2020 16:25	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/3/2020 16:25	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	General Comments	two large gaps on side closest to the scrap yard. very rusty, one bayonet is broken	
12/3/2020 16:25	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Follow-up Action Required?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	General Comments	PNC has a bunch of old relay panels in the control house that need to be taken back to SSC.	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Panel Lights OK?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Panels Dusted?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Station Ground Set On Site?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Trash Emptied?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Present	40	°C
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Max	55	°C
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Readings	LTC Totalizer Reading	4462.56	kw
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Readings	General Comments		
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	Winding Temp Present	0	°C
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	Winding Temp Max	0	°C
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Amps C Ø	125.0	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Amps B Ø	140.0	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Amps A Ø	125.0	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	9 Month Operations	2	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	LTC Operations Since Last Insp	241	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	Totalizer Meter Reading	.5898	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Amps C Ø	0.0	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Amps B Ø	0.0	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Amps A Ø	0.0	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	9 Month Operations	4	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Ambient Temp	32	*F
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	General Comments		
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	LTC Current Tap Position	5L	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	LTC Max Tap Position	5L	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	LTC Min Tap Position	Neutral	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	General Comments		
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Foundation Condition	Good	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Follow-up Action Required?	n	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Fault Operations Ground	0	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Fault Operations C Ø	0	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Fault Operations B Ø	0	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Fault Operations A Ø	0	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Vegetation	None	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Bushing Condition	Good	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	200.00	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Reading	.6198	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Acceptable Building Appearance?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Broom on Site?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Control House Lighting OK?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Door Alarms OK?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Doors and Locks Secure?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Evidence of Insects	None	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Floor Swept?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Bushing Condition	Good	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Amps C Ø	95.0	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Amps B Ø	87.0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LTCC000472	LTCControl	AL-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallellIND	Position
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LTCC000472	LTCControl	AL-TRANS 3	LTC Control Insp	General Comments		
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LTCC000472	LTCControl	AL-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LTCC000471	LTCControl	AL-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallellIND	Position
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LTCC000471	LTCControl	AL-TRANS 2	LTC Control Insp	General Comments		
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LTCC000471	LTCControl	AL-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	General Comments		
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushing Condition	Good	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Amps A Ø	100.0	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Accumulated Fault Duty C Ph V	.46	%
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Accumulated Fault Duty B Ph V	.46	%
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Accumulated Fault Duty A Ph V	.46	%
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	9 Month Operations	1	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Operations Counter	3	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	General Comments		
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	LTCC000822	LTCControl	500-1	LTC Control Insp	All Connections OK?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	LTCC000822	LTCControl	500-1	LTC Control Insp	Follow-up Action Required?	n	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	LTCC000822	LTCControl	500-1	LTC Control Insp	General Comments		
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	LTCC000822	LTCControl	500-1	LTC Control Insp	LTC Operation Checked?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	LTCC000822	LTCControl	500-1	LTC Control Insp	LTC Output Voltage Level	123.8	VAC
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	LTCC000822	LTCControl	500-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	LTCC000822	LTCControl	500-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	LTCC000822	LTCControl	500-1	LTC Control Insp	VRR Time Delay	45	Seconds
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	n	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	n	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	General Comments	off line due to it getting updated	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Maintenance Operations	0	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Operations Counter AF	148	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Operations Counter AL	148	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Operations This Read Vac	0	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Switching Operations	0	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Unknown Operations	0	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	9 Month Operations	1	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Grounds in Place?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	General Comments		
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Foundation Condition	Good	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Follow-up Action Required?	n	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Amps A Ø	157.0	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Amps B Ø	161.0	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Amps C Ø	154.0	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Bushing Condition	Good	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Fault Operations A Ø	0	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Fault Operations B Ø	0	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Fault Operations C Ø	0	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Fault Operations Ground	0	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Follow-up Action Required?	n	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Foundation Condition	Good	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	General Comments		
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	General Comments		
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Grounds in Place?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Maintenance Operations	0	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Operations Counter AF	182	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Operations Counter AL	182	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Operations This Read Vac	0	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Switching Operations	0	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Unknown Operations	0	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	LTCC000562	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	LTCC000562	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	LTCC000562	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	LTCC000562	LTCControl	932-Offline Distribution	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	LTCC000562	LTCControl	932-Offline Distribution	LTC Control Insp	LTC Operation Checked?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	LTCC000562	LTCControl	932-Offline Distribution	LTC Control Insp	General Comments		
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	LTCC000562	LTCControl	932-Offline Distribution	LTC Control Insp	Follow-up Action Required?	n	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	LTCC000562	LTCControl	932-Offline Distribution	LTC Control Insp	All Connections OK?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Fault Operations Ground	0	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Fault Operations C Ø	0	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Fault Operations B Ø	0	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Fault Operations A Ø	0	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	General Comments		
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Amps C Ø	1.0	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Amps B Ø	2.0	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Amps A Ø	8.0	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BCH001400	Charger	633-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BCH001400	Charger	633-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BCH001400	Charger	633-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BCH001400	Charger	633-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BCH001400	Charger	633-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.0	amps
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BCH001400	Charger	633-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BCH001400	Charger	633-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BCH001400	Charger	633-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	General Comments		
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Vegetation	None	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	General Comments		
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Switching Operations	0	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Operations This Read SF6	0	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Operations Counter AL	902	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Operations Counter AF	902	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Num Operations Last 9 Months	7	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Maintenance Operations	0	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	General Comments	Offline, Actual counter	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Patrol Inspection	General Comments		
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Follow-up Action Required?	n	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Fault Operations	0	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?		
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	General Comments		
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Ambient Temp	32	*F
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	Follow-up Action Required?	n	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	General Comments		
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	LTC As Found Counter	23840	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	LTC As Left Counter	23840	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	LTC Current Tap Position	1R	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	LTC Max Tap Position	5R	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	LTC Min Tap Position	3L	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	LTC Operations Since Last Insp	376	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	BCH001014	Charger	839-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	BCH001014	Charger	839-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Vegetation	None	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	LTC As Found Counter	127864	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	LTC As Left Counter	127864	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4R	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	LTC Min Tap Position	9L	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	893	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Switching Operations	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	General Comments		
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Fault Operations Ground	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Fault Operations C ∅	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Fault Operations B ∅	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Fault Operations A ∅	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Bushing Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Amps C Ø	0.0	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Amps B Ø	0.0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Amps A Ø	0.0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	9 Month Operations	31	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	General Comments		
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Operations Counter	220	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Operations Counter	429	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	Oil Temp Present	40	°C
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	Oil Temp Max	67	°C
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	LTC Totalizer Reading	3136.00	kw
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	General Comments		
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	General Comments		
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Fault Operations Ground	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Foundation Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	General Comments		
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	General Comments		
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Grounds in Place?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Operations Counter AF	208	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Operations Counter AL	208	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Operations This Read Vac	0	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	General Comments		
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Amps C Ø	65.0	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Amps B Ø	65.0	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Amps A Ø	70.0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	BCH001014	Charger	839-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	BCH001014	Charger	839-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	General Comments		
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Mechanism Patrol Inspection	General Comments	Needs nitrogen.	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	LTC As Found Counter	18094	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	LTC As Left Counter	18094	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	PF000003	PowerFuse	AK-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	PF000003	PowerFuse	AK-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	LTC Current Tap Position	Neutral	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	LTC Max Tap Position	16R	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	LTC Min Tap Position	3L	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	163	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Unknown Operations	0	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Switching Operations	0	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Operations This Read Vac	0	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Operations Counter AL	309	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Operations Counter AF	309	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	Totalizer Meter Reading	.6810	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Maintenance Operations	0	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	Oil Temp Present	40	°C
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	Oil Temp Max	50	°C
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	LTC Totalizer Reading	2179.20	kw
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	General Comments		
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	General Comments		
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Grounds in Place?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	General Comments		
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Bushing Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	General Comments		
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Oil Status	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Vegetation	None	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	General Comments		
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Ambient Temp	36	°F
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Counter Readings	General Comments		
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Counter Readings	LTC As Found Counter	59736	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Counter Readings	LTC As Left Counter	59736	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Counter Readings	LTC Current Tap Position	7R	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	12	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	LV Winding Temp Max	40	°C
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	LV Winding Temp Present	40	°C
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1	psi
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	Oil Temp Max	40	°C
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	Oil Temp Present	40	°C
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	LTC Operations Since Last Insp	278	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	LTC Min Tap Position	10L	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	General Comments	ok	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	PF000001	PowerFuse	AK-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	PF000001	PowerFuse	AK-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	PF000001	PowerFuse	AK-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	PF000002	PowerFuse	AK-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	PF000002	PowerFuse	AK-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	PF000004	PowerFuse	AK-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	PF000004	PowerFuse	AK-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	PF000004	PowerFuse	AK-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	LTC Max Tap Position	2R	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	LTC Current Tap Position	3L	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	LTC As Left Counter	224728	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	LTC As Found Counter	224728	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	General Comments		
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Vegetation	None	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	General Comments		
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Ambient Temp	38	°F
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	Oil Temp Present	35	°C
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	Oil Temp Max	35	°C
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	LTC Totalizer Reading	5662.08	kw
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	General Comments		
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	General Comments		
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Bushing Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Foundation Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	General Comments		
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Grounds in Place?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Radiator Leaks	None	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Tank Leaks	None	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	General Comments		
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	General Comments	Nitrogen bottles needs nitrogen added.	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	240.0	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	LTCC000903	LTCControl	774-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	LTCC000903	LTCControl	774-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	LTCC000903	LTCControl	774-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	LTCC000903	LTCControl	774-1	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	LTCC000903	LTCControl	774-1	LTC Control Insp	LTC Operation Checked?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	LTCC000903	LTCControl	774-1	LTC Control Insp	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	LTCC000903	LTCControl	774-1	LTC Control Insp	Follow-up Action Required?	n	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	LTCC000903	LTCControl	774-1	LTC Control Insp	All Connections OK?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Unknown Operations	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Switching Operations	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Operations This Read Vac	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Operations Counter AL	361	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Operations Counter AF	361	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	Maintenance Operations	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Grounds in Place?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Readings	General Comments		
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	General Comments		
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	Totalizer Meter Reading	.9800	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	General Comments		
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	9 Month Operations	16	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Amps A Ø	128.0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Amps B Ø	126.0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Amps C Ø	135.0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Bushing Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Fault Operations A Ø	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Fault Operations B Ø	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Readings	Fault Operations C Ø	0	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Amps A Ø	27.0	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Amps B Ø	27.0	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Amps C Ø	30.0	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Mechanism Patrol Inspection	General Comments		
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	General Comments		
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	Follow-up Action Required?	n	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	221	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	221	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Switching Operations	0	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Operations This Read SF6	0	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Operations Counter AL	700	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Operations Counter AF	700	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Num Operations Last 9 Months	1	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Maintenance Operations	0	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Patrol Inspection	Grounds in Place?	y	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	General Comments	offline, actual counter	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Patrol Inspection	General Comments		
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Follow-up Action Required?	n	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Fault Operations	0	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Amps C Ø	0.0	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Amps B Ø	0.0	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Amps A Ø	0.0	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Vegetation	None	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	General Comments		
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Ambient Temp	40	*F
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	240.0	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	200.0	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	VRR Time Delay	45	Seconds
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	VRR R Compensation AL	0	Position
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	VRR R Compensation AF	0	Position
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	VRR Base Voltage AL	124.0	VAC
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	VRR Base Voltage AF	124.0	VAC
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	VRR Bandwidth AL	3.0	VAC
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	VRR Bandwidth AF	3.0	VAC
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	Reset Tap Drag Hands	Reset	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	Min Tap Position	1R	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	Max Tap Position	3R	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	General Comments		
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	Follow-up Action Required?	n	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	Current Tap Position	3R	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	All Connections OK?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	9 Month Operations	25	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Amps A Ø	610.0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Amps B Ø	600.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Amps C Ø	600.0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Bushing Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Fault Operations A Ø	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Fault Operations B Ø	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Fault Operations C Ø	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Fault Operations Ground	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Foundation Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	General Comments		
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	General Comments		
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Grounds in Place?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Maintenance Operations	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Operations Counter AF	372	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Operations Counter AL	372	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Operations This Read Vac	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Switching Operations	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Readings	Unknown Operations	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Bushing Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Foundation Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	General Comments		
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Grounds in Place?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Bushing Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	X2 Winding Temp Present	30	°C
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Regulator As Left Counter	35129	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Min Tap Position	1R	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Max Tap Position	9L	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	General Comments		
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Bushing Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Fault Operations A Ø	0	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Fault Operations B Ø	0	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Fault Operations C Ø	0	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Fault Operations Ground	0	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Follow-up Action Required?	n	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Foundation Condition	Good	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	General Comments		
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	General Comments		
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Grounds in Place?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Maintenance Operations	0	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Operations Counter AF	313	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Operations Counter AL	313	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Operations This Read Vac	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	General Comments		
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushing Condition	Good	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Switching Operations	0	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Unknown Operations	0	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Tank Leaks	None	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Regulator As Left Counter	36028	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Min Tap Position	10L	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Max Tap Position	4L	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	General Comments		
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Current Tap Position	9L	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Follow-up Action Required?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Foundation Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	General Comments	This breaker circuit number is 14KV Bus Tie 1-2. Please change in Cascade.	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Grounds in Place?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	General Comments		
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BCH001292	Charger	500-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.600	millivolts
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BCH001292	Charger	500-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BCH001292	Charger	500-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BCH001292	Charger	500-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.9	amps
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BCH001292	Charger	500-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BCH001292	Charger	500-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BCH001292	Charger	500-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BCH001292	Charger	500-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	LTC Operations Since Last Insp	1027	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	LTC Min Tap Position	8L	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	LTC Max Tap Position	10R	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	LTC Current Tap Position	1L	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	LTC As Left Counter	10009	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	LTC As Found Counter	10001	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Mechanism Patrol Inspection	General Comments		
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	General Comments		
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	Follow-up Action Required?	n	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	General Comments		
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushing Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	LTCC000695	LTCControl	513-1	LTC Control Insp	General Comments		
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	LTCC000695	LTCControl	513-1	LTC Control Insp	LTC Operation Checked?	y	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	LTCC000695	LTCControl	513-1	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	LTCC000695	LTCControl	513-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	LTCC000695	LTCControl	513-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	LTCC000695	LTCControl	513-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Amps A Ø	218.0	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Amps B Ø	234.0	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Amps C Ø	221.0	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Patrol I Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	General Comments		
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Vegetation	None	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	General Comments		
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Accumulated Fault Duty A Ph V	7.77	%
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	9 Month Operations	4	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	General Comments		
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	General Comments		
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	Oil Temp Max	60	°C
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	Oil Temp Present	30	°C
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	X2 Winding Temp Max	60	°C
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Switching Operations	0	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1041	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	LTC Min Tap Position	16L	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	LTC Max Tap Position	1R	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	LTC Current Tap Position	8L	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	LTC As Left Counter	169671	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	LTC As Found Counter	169671	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	General Comments		
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Unknown Operations	0	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Switching Operations	0	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Operations This Read Vac	0	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Operations Counter AL	189	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Operations Counter AF	189	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Maintenance Operations	0	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Grounds in Place?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	General Comments		
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	General Comments		
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Ambient Temp	32	*F
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/3/2020 15:48	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	General Comments		
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Foundation Condition	Good	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Follow-up Action Required?	n	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Fault Operations Ground	0	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Fault Operations C Ø	0	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Fault Operations B Ø	0	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Fault Operations A Ø	0	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	LTCC000247	LTCControl	839-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	LTCC000247	LTCControl	839-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	LTCC000247	LTCControl	839-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	LTCC000247	LTCControl	839-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	LTCC000247	LTCControl	839-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	LTCC000247	LTCControl	839-1	LTC Control Insp	LTC Operation Checked?	y	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	LTCC000247	LTCControl	839-1	LTC Control Insp	General Comments		
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	LTCC000247	LTCControl	839-1	LTC Control Insp	Follow-up Action Required?	n	
12/3/2020 16:10	Distribution	Winchester South Quarterly Inspection	LTCC000247	LTCControl	839-1	LTC Control Insp	All Connections OK?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Bushing Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Foundation Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	General Comments		
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Grounds in Place?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Bushing Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Foundation Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	General Comments		
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Grounds in Place?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Tank Leaks	None	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Regulator As Left Counter	0	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Min Tap Position	1R	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Max Tap Position	3R	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	General Comments		
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Current Tap Position	3R	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	9 Month Operations	22	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Amps A Ø	40.0	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Amps B Ø	70.0	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	Oil Temp Present	40	°C
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	Oil Temp Max	50	°C
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	7395.84	kw
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	General Comments		
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	General Comments		
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	LTC Operations Since Last Insp	421	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	LTC Min Tap Position	9L	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	General Comments		
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	LTC Current Tap Position	2L	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	LTC As Left Counter	12064	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	LTC As Found Counter	12064	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Mechanism Patrol Inspection	General Comments		
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	General Comments		
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	Follow-up Action Required?	n	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	40.0	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	40.0	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	General Comments		
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushing Condition	Good	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Switching Operations	0	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Operations This Read SF6	0	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Operations Counter AL	594	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Operations Counter AF	594	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Num Operations Last 9 Months	5	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Maintenance Operations	0	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	General Comments	offline, actual counter	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Patrol Inspection	General Comments		
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Follow-up Action Required?	n	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Fault Operations	0	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Amps C Ø	0.0	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Amps B Ø	0.0	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Amps A Ø	0.0	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Filters Condition OK?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Floor Swept?	n	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	General Comments	Floor not swept, no broom on site or on truck.	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	Winding Temp Present	20	°C
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	Winding Temp Max	20	°C
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	Totalizer Meter Reading	.8560	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	Oil Temp Max	30	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Follow-up Action Required?	n	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Foundation Condition	Good	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	General Comments		
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	General Comments		
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Grounds in Place?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Maintenance Operations	0	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Operations Counter AF	157	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Operations Counter AL	157	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Operations This Read Vac	0	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Switching Operations	0	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Unknown Operations	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	General Comments		
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Vegetation	None	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	General Comments		
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	LTCC000710	LTCControl	633-1	LTC Control Insp	All Connections OK?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	LTCC000710	LTCControl	633-1	LTC Control Insp	Follow-up Action Required?	n	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	LTCC000710	LTCControl	633-1	LTC Control Insp	General Comments		
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	LTCC000710	LTCControl	633-1	LTC Control Insp	LTC Operation Checked?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	LTCC000710	LTCControl	633-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	LTCC000710	LTCControl	633-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelloff	Position
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	LTCC000710	LTCControl	633-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	LTCC000710	LTCControl	633-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	LTCC000710	LTCControl	633-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	9 Month Operations	8	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Amps A Ø	60.0	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Amps B Ø	70.0	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Amps C Ø	65.0	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Bushing Condition	Good	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Fault Operations A Ø	0	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Fault Operations C Ø	0	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Fault Operations Ground	0	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Follow-up Action Required?	n	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Foundation Condition	Good	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	General Comments		
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	General Comments		
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Grounds in Place?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Maintenance Operations	0	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Operations Counter AF	271	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Operations Counter AL	271	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Operations This Read Vac	0	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Switching Operations	0	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Unknown Operations	0	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	32	*F
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Operations Counter	11	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	General Comments		
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Amps C Ø	202.0	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Amps B Ø	154.0	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Amps A Ø	160.0	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	General Comments		
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Negative DC Ground	24.0	VDC
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Positive DC Ground	22.0	VDC
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	*F
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Amps A Ø	0.0	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Amps B Ø	0.0	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Amps C Ø	0.0	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Fault Operations	0	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Follow-up Action Required?	n	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Patrol Inspection	General Comments		
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	General Comments	offline	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Maintenance Operations	0	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Num Operations Last 9 Months	4	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Operations Counter AF	1324	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Operations Counter AL	1324	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Operations This Read SF6	0	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Switching Operations	0	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	General Comments	top half fence rusty	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	General Comments		
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	General Comments		
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Ambient Temp	32	°F
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	General Comments		
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Vegetation	None	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	124	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	124	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	600.0	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	600.0	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	600.0	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	2	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	Totalizer Meter Reading	1.0272	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	General Comments		
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.1	VDC
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	General Comments		
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LTCC000494	LTCControl	AL-TRANS 4	LTC Control Insp	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LTCC000494	LTCControl	AL-TRANS 4	LTC Control Insp	General Comments		
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LTCC000494	LTCControl	AL-TRANS 4	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	General Comments		
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Mechanism Patrol Inspection	General Comments		
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	LTC As Found Counter	80039	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	LTC As Left Counter	80039	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	LTC Current Tap Position	7R	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	LTC Max Tap Position	8R	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	LTC Min Tap Position	4R	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	LTC Operations Since Last Insp	8	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Tank Leaks	None	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Regulator As Left Counter	119703	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Min Tap Position	4R	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Max Tap Position	11R	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	General Comments		
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Current Tap Position	9R	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/3/2020 15:59	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Amps B Ø	200.0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Amps A Ø	190.0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	9 Month Operations	2	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Switching Operations	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/3/2020 16:25	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	LTC Totalizer Reading	5460.48	kw
12/3/2020 16:25	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/3/2020 16:25	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Insulators In Good Condition?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Operations This Read Vac	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Operations Counter AL	530	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Operations Counter AF	530	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Maintenance Operations	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Grounds in Place?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	General Comments		
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	General Comments		
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Foundation Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Fault Operations Ground	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Fault Operations C Ø	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Fault Operations B Ø	0	
12/3/2020 16:25	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/3/2020 16:25	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	General Comments	one insulator is chipped	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 16:25	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/3/2020 16:25	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/3/2020 16:25	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/3/2020 16:25	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/3/2020 16:25	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/3/2020 16:25	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Regulator As Left Counter	86553	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Max Tap Position	12R	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Fault Operations B Ø	0	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	30	°C
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Fault Operations C Ø	0	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Fault Operations Ground	0	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Follow-up Action Required?	n	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Switching Operations	0	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Operations This Read Vac	0	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Operations Counter AL	200	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Operations Counter AF	200	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	General Comments		
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 16:25	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/3/2020 16:25	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/3/2020 16:25	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/3/2020 16:25	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Switching Operations	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Operations This Read Vac	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Operations Counter AL	203	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Operations Counter AF	203	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Maintenance Operations	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Grounds in Place?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	General Comments		
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	General Comments		
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Foundation Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Fault Operations Ground	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Fault Operations C Ø	0	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	General Comments		
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Fault Operations B Ø	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Fault Operations A Ø	0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Bushing Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Readings	Amps C Ø	200.0	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1749.60	kw
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	10.00	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	Oil Temp Present	36	°C
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	General Comments		
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1800	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9720	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	Totalizer Meter Reading	.7584	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Maintenance Operations	0	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	Oil Temp Present	35	°C
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	Oil Temp Max	35	°C
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Grounds in Place?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	General Comments		
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	General Comments		
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Foundation Condition	Good	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Operations Counter AF	183	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Operations Counter AL	183	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Operations This Read Vac	0	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Unknown Operations	0	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Switching Operations	0	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	General Comments		
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	General Comments		
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Fault Operations A Ø	0	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	Oil Temp Present	35	°C
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	Oil Temp Max	65	°C
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	2000	psi
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	General Comments		
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Bushing Condition	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Amps C Ø	220.0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Amps B Ø	220.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Amps A Ø	230.0	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Readings	9 Month Operations	8	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	General Comments		
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Max Tap Position	9L	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Min Tap Position	1L	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/3/2020 16:31	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Regulator As Left Counter	25372	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/3/2020 16:19	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/3/2020 15:58	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Maintenance Operations	0	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Fault Operations A Ø	0	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Fault Operations B Ø	0	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Fault Operations C Ø	0	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Fault Operations Ground	0	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Amps A Ø	460.0	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Amps B Ø	415.0	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Follow-up Action Required?	n	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Foundation Condition	Good	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	General Comments		
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	General Comments		
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Grounds in Place?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Maintenance Operations	0	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Operations Counter AF	210	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Operations Counter AL	210	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Operations This Read Vac	0	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Switching Operations	0	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Unknown Operations	0	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	Winding Temp Max	50	°C
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Amps C Ø	460.0	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Bushing Condition	Good	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	LTCC000695	LTCControl	513-1	LTC Control Insp	Follow-up Action Required?	n	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	LTCC000695	LTCControl	513-1	LTC Control Insp	All Connections OK?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	Totalizer Meter Reading	.7266	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Unknown Operations	0	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Bushing Condition	Good	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Fault Operations A Ø	0	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Fault Operations B Ø	0	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Fault Operations C Ø	0	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Fault Operations Ground	0	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Follow-up Action Required?	n	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
12/3/2020 11:03	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	General Comments		
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	General Comments		
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	General Comments		
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	9 Month Operations	0	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Switching Operations	3	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Unknown Operations	0	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	9 Month Operations	1	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Amps A Ø	157.0	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Amps B Ø	171.0	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Amps C Ø	149.0	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Bushing Condition	Good	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/3/2020 11:58	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/3/2020 14:34	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	65	°C
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	35	°C
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	40	°C
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	55	°C
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Amps A Ø	100.0	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Amps B Ø	97.0	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Amps C Ø	67.0	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	65	°C
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Accumulated Fault Duty C Ph V	1.83	%
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Accumulated Fault Duty B Ph V	2.28	%
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Accumulated Fault Duty A Ph V	3.2	%
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Tank Paint Condition	Good	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	9 Month Operations	5	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	General Comments		
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	General Comments		
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	LTC Totalizer Reading	13078.80	kw
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	Oil Temp Max	60	°C
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	Oil Temp Present	46	°C
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Fault Operations A Ø	0	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Foundation Condition	Good	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/3/2020 15:50	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	General Comments		
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	General Comments		
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/7/2020 6:47	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/3/2020 16:15	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Grounds in Place?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BCH000033	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	135.0	VDC
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BCH000033	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BCH000033	Charger	Retired Distribution	Battery Charger Patrol Insp	Ground Lights	None	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BCH000033	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BCH000033	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BCH000033	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BCH000033	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	4.0	amps
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BCH000033	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	135.0	VDC
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0964	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	631	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0964	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0964	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0964	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0964	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	120.0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	2.41	%
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	6.02	%
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	3.61	%
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	8	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	110.0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	90.0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	828	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	828	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0963	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	380.0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	430.0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	400.0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	505	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	505	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0973	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	LTCC000636	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	LTCC000636	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	126.0	VAC
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	LTCC000636	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	LTCC000636	LTCControl	930-Offline-Distribution	LTC Control Insp	General Comments		
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	LTCC000636	LTCControl	930-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	LTCC000636	LTCControl	930-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	LTCC000636	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	LTCC000636	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Oil Temp Max	15	°C
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Tank Leaks	None	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	General Comments		
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	General Comments	BFTC	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Unknown Operations	0	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Switching Operations	5	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Operations This Read Vac	5	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	General Comments		
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	General Comments		
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1100	psi
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Bushing Condition	Good	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Amps C Ø	30.0	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Amps B Ø	30.0	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Amps A Ø	30.0	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	9 Month Operations	4	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	1065.60	kw
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	122.3	volts
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Regulator As Left Counter	21331	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Max Tap Position	4L	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Max Tap Position	3R	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	Oil Temp Present	35	°C
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	Oil Temp Max	50	°C
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	239.04	kw
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Min Tap Position	9L	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	General Comments		
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	General Comments	fuses are badly frayed	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Maintenance Operations	0	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Tank Leaks	None	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Current Tap Position	4L	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	General Comments		
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	General Comments		
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Min Tap Position	2R	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Operations Counter AL	298	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	General Comments	secondary side needs wildlife protection	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	Follow-up Action Required?	n	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	General Comments		
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Mechanism Patrol Inspection	General Comments		
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	Totalizer Meter Reading	.2988	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	LTC As Found Counter	13936	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Operations Counter AF	293	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Current Tap Position	3R	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	LTC As Left Counter	13947	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	LTC Current Tap Position	2L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	LTC Max Tap Position	2R	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	LTC Min Tap Position	5L	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	LTC Operations Since Last Insp	535	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	General Comments		
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Unknown Operations	0	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Switching Operations	0	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Operations This Read Vac	0	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Operations Counter AL	142	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Operations Counter AF	142	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Maintenance Operations	0	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Grounds in Place?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	General Comments		
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	General Comments		
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Foundation Condition	Good	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Follow-up Action Required?	n	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Fault Operations Ground	0	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Fault Operations C ∅	0	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Fault Operations B ∅	0	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Fault Operations A ∅	0	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Fault Operations A ∅	0	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Fault Operations B ∅	0	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Fault Operations C ∅	0	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Fault Operations Ground	0	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Follow-up Action Required?	n	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Current Tap Position	1R	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	Oil Temp Max	32	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	LTC Totalizer Reading	9676.8	kw
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	General Comments		
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	General Comments		
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	Follow-up Action Required?	n	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	9 Month Operations	4	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Amps A Ø	185.0	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Amps B Ø	95.0	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Amps C Ø	120.0	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Bushing Condition	Good	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Bushing Condition	Good	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Amps C Ø	50.0	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Amps B Ø	80.0	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Amps A Ø	85.0	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Fault Operations A Ø	0	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Fault Operations B Ø	0	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Fault Operations C Ø	0	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Fault Operations Ground	0	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Follow-up Action Required?	n	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Foundation Condition	Good	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	General Comments		
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	General Comments		
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Grounds in Place?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Maintenance Operations	0	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Operations Counter AF	180	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Operations Counter AL	180	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Operations This Read Vac	1	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Switching Operations	1	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Unknown Operations	0	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	9 Month Operations	2	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Amps A Ø	60.0	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Amps B Ø	70.0	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Amps C Ø	65.0	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Bushing Condition	Good	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	40	*F
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Tank Leaks	None	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Bushing Condition	Good	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Amps C Ø	140.0	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Amps B Ø	100.0	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Amps A Ø	120.0	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	9 Month Operations	3	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Min Tap Position	2L	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Max Tap Position	4R	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	General Comments		
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	20.3	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	9 Month Operations	6	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Amps A Ø	120.0	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Amps B Ø	140.0	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Amps C Ø	150.0	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Bushing Condition	Good	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	General Comments		
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	General Comments		
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Grounds in Place?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Maintenance Operations	0	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Operations Counter AF	43	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Operations Counter AL	43	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Operations This Read Vac	0	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Switching Operations	0	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Tank Paint Condition	Good	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Unknown Operations	0	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Broom on Site?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Floor Swept?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	General Comments		
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Trash Emptied?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Fault Operations A Ø	0	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Fault Operations B Ø	0	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Fault Operations C Ø	0	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Fault Operations Ground	0	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Tank Leaks	None	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.2	volts
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	9 Month Operations	8	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Min Tap Position	2R	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Max Tap Position	4R	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Follow-up Action Required?	n	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Foundation Condition	Good	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	General Comments		
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	200	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	Winding Temp Present	26	°C
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	Winding Temp Max	34	°C
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	Totalizer Meter Reading	.5376	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	Oil Temp Present	26	°C
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Oil Temp Present	15	°C
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	18000	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Totalizer Meter Reading	.0592	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Winding Temp Max	25	°C
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Winding Temp Present	12	°C
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	General Comments		
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	Totalizer Meter Reading	.545	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	SWG000183	Switchgear	SW-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	9 Month Operations	1	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6312	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	General Comments		
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	ST000575	Structure	SW-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Ambient Temp	32	*F
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	General Comments		
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Regulator As Left Counter	51799	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Unknown Operations	0	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	General Comments		
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	General Comments		
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	100.00	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	6059.52	kw
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Switching Operations	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Operations This Read Vac	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Operations Counter AL	224	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Operations Counter AF	224	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Maintenance Operations	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	General Comments		
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Patrol Inspection	General Comments		
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Fault Operations Ground	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Fault Operations C ∅	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Fault Operations B ∅	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Fault Operations A ∅	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Amps C ∅	571.0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Amps B ∅	591.0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Amps A ∅	583.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	General Comments		
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Vegetation	None	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	General Comments		
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	Totalizer Meter Reading	.6216	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	LTCC000923	LTCControl	512-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	LTCC000923	LTCControl	512-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	LTCC000923	LTCControl	512-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	LTCC000923	LTCControl	512-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Vegetation	None	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	YD000573	Yard	SW-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Unknown Operations	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Switching Operations	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Operations This Read Vac	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Operations Counter AL	405	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Operations Counter AF	405	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Maintenance Operations	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	General Comments		
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Patrol Inspection	General Comments		
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Follow-up Action Required?	n	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Fault Operations Ground	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Fault Operations C ∅	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Fault Operations B ∅	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Fault Operations A ∅	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Amps C ∅	161.0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Amps B ∅	124.0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Amps A ∅	176.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	9 Month Operations	2	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	General Comments		
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Vegetation	None	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	General Comments		
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	General Comments		
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Ambient Temp	40	*F
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	2L	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Switching Operations	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Operations This Read AM	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AL	106	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AF	106	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Maintenance Operations	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	General Comments	Actual counter	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Patrol Inspection	General Comments		
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Follow-up Action Required?	n	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations Ground	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations C Ø	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations B Ø	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations A Ø	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Platform/Walkway/Railing OK?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	General Comments		
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Amps C Ø	0.0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Amps B Ø	0.0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Amps A Ø	0.0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0972	BreakerAirMagnetic	SW-12KV BUS TIE SEC 2	AMCB Readings	9 Months Operations	0	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	BAT001522	Battery	815-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	BAT001522	Battery	815-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	BAT001522	Battery	815-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	BAT001522	Battery	815-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	BAT001522	Battery	815-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	48	*F
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	BAT001522	Battery	815-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	LTC Totalizer Reading	6330.24	kw
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	General Comments		
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	General Comments		
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	Follow-up Action Required?	n	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	General Comments		
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	Neutral	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	4L	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	22213	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	PF001262	PowerFuse	SW-B 14KV GND RLY POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	PF001262	PowerFuse	SW-B 14KV GND RLY POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	BCH001449	Charger	815-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	BCH001449	Charger	815-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	BCH001449	Charger	815-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	BCH001449	Charger	815-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	BCH001449	Charger	815-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	BCH001449	Charger	815-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	BAT001522	Battery	815-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Regulator As Left Counter	50401	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	BAT001522	Battery	815-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	BAT001522	Battery	815-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.5	VDC
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	BAT001522	Battery	815-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.4	VDC
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	BAT001522	Battery	815-Battery Bank	Battery Patrol Inspection	General Comments		
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	BAT001522	Battery	815-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	Totalizer Meter Reading	.6594	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	Oil Temp Present	45	°C
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	Oil Temp Max	45	°C
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	BAT001522	Battery	815-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Operations Counter AF	194	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Operations Counter AL	194	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Operations This Read Vac	0	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Switching Operations	0	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Unknown Operations	0	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	General Comments		
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2150.00	kw
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	96.00	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Follow-up Action Required?	n	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Fault Operations Ground	0	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Fault Operations C ∅	0	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Fault Operations B ∅	0	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Fault Operations A ∅	0	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	80.0	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	100.0	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	50.0	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	General Comments	NEW COUNTER	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Fault Operations A Ø	0	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Maintenance Operations	0	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Grounds in Place?	y	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	General Comments		
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	General Comments		
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	Oil Temp Max	60	°C
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	Oil Temp Present	35	°C
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	Totalizer Meter Reading	1.3998	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	General Comments		
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Fault Operations B Ø	0	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Fault Operations C Ø	0	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Fault Operations Ground	0	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Follow-up Action Required?	n	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Foundation Condition	Good	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	General Comments	ok	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	General Comments	ok	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Grounds in Place?	y	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Maintenance Operations	0	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Fault Operations A Ø	0	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Fault Operations B Ø	0	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Fault Operations C Ø	0	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Fault Operations Ground	0	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Follow-up Action Required?	n	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Foundation Condition	Good	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	General Comments		
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	General Comments		
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Grounds in Place?	y	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Maintenance Operations	0	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	General Comments		
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1000	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	Totalizer Meter Reading	2.1500	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Operations Counter AF	194	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Operations Counter AL	194	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Operations This Read Vac	0	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Switching Operations	0	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Unknown Operations	0	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	10	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	86	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	86	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	8	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	8	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	9 Month Operations	4	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Amps A Ø	5.0	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Amps B Ø	5.0	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Amps C Ø	5.0	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Bushing Condition	Good	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	General Comments		
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Vegetation	None	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	9 Month Operations	2	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Amps A Ø	90.0	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Amps B Ø	85.0	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Amps C Ø	85.0	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Bushing Condition	Good	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Fault Operations A Ø	0	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Fault Operations B Ø	0	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Fault Operations C Ø	0	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Fault Operations Ground	0	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Follow-up Action Required?	n	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Foundation Condition	Good	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	General Comments		
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	General Comments		
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Grounds in Place?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Maintenance Operations	0	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Operations Counter AF	201	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	General Comments	ok	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	General Comments		
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Operations Counter AL	201	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Operations This Read Vac	0	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Switching Operations	0	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Ambient Temp	52	°F
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Vegetation	None	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	Oil Temp Present	40	°C
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	Oil Temp Max	66	°C
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	LTC Totalizer Reading	5967.36	kw
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	General Comments	ok	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	General Comments		
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	General Comments	gap under fence in back right hand corner. wire and some of the posts show rust.	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	General Comments		
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	General Comments		
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	LTC Totalizer Reading	6719.04	kw
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	9 Month Operations	2	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Amps A Ø	25.0	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Amps B Ø	61.0	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Amps C Ø	34.0	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Bushing Condition	Good	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Unknown Operations	0	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Switching Operations	0	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Operations This Read Vac	0	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Operations Counter AL	230	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Operations Counter AF	230	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Tank Paint Condition	Good	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Unknown Operations	0	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Ambient Temp	48	*F
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	General Comments		
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	LTCC000923	LTCControl	512-1	LTC Control Insp	LTC Operation Checked?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	LTCC000923	LTCControl	512-1	LTC Control Insp	General Comments		
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	LTCC000923	LTCControl	512-1	LTC Control Insp	Follow-up Action Required?	n	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	LTCC000923	LTCControl	512-1	LTC Control Insp	All Connections OK?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.4	VDC
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	General Comments		
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	*F
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	Follow-up Action Required?	n	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	General Comments		
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	General Comments		
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Vegetation	None	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	General Comments		
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Ambient Temp	35	*F
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	General Comments		
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	General Comments		
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Switching Operations	0	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Operations This Read Vac	8	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Operations Counter AL	464	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Operations Counter AF	464	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Maintenance Operations	0	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Grounds in Place?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	General Comments		
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	General Comments		
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Foundation Condition	Good	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Follow-up Action Required?	n	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Fault Operations Ground	0	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Fault Operations C Ø	4	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Fault Operations B Ø	4	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Fault Operations A Ø	0	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Fault Adjusted Amps C Phase V	5.93	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Fault Adjusted Amps B Phase V	5.93	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Bushing Condition	Good	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Amps C Ø	110.0	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Amps B Ø	120.0	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Amps A Ø	110.0	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	9 Month Operations	14	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	Totalizer Meter Reading	.6510	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	8	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Fault Operations A Ø	0	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Fault Operations B Ø	0	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Fault Operations C Ø	0	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Fault Operations Ground	0	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BCH001374	Charger	084-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BCH001374	Charger	084-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BCH001374	Charger	084-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BCH001374	Charger	084-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Follow-up Action Required?	n	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Foundation Condition	Good	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	General Comments		
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	General Comments		
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	LTC Operations Since Last Insp	226	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	LTC Min Tap Position	3R	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	LTC Max Tap Position	8R	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Grounds in Place?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Maintenance Operations	0	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Operations Counter AF	302	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Operations Counter AL	302	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Operations This Read Vac	0	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	8	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	293	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	286	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	General Comments	BFTC	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	36	*F
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Amps A Ø	0.0	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BCH001374	Charger	084-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BCH001374	Charger	084-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BCH001374	Charger	084-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BCH001374	Charger	084-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	General Comments		
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	General Comments		
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	LTC Totalizer Reading	3124.80	kw
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	Oil Temp Max	50	°C
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	Oil Temp Present	45	°C
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	9 Month Operations	4	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Amps A Ø	60.0	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Amps B Ø	60.0	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Amps C Ø	30.0	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Bushing Condition	Good	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	General Comments		
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	48	°F
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	General Comments	ok	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	BCH001273	Charger	641-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	BCH001273	Charger	641-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	BCH001273	Charger	641-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	BCH001273	Charger	641-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.9	VDC
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	BCH001273	Charger	641-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.9	VDC
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	Totalizer Meter Reading	.5756	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Totalizer Meter Multiplier	7200	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	BCH001273	Charger	641-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.430	millivolts
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Vegetation	None	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	General Comments	ok	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	9 Month Operations	4	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.9	VDC
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.1	VDC
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	General Comments	ok	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	26	*F
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	General Comments	ok	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Ambient Temp	27	*F
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Max	55	*C
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Present	35	*C
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Pumps Condition	Leaks	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Pumps Operational?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	X1 Winding Temp Max	70	*C
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	X1 Winding Temp Present	30	*C
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	X2 Winding Temp Max	70	*C
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	X2 Winding Temp Present	40	*C
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	X3 Winding Temp Max	75	*C
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	X3 Winding Temp Present	45	*C
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Positive DC Ground	28.8	VDC
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.1	VDC
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	General Comments		
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BCH001369	Charger	686-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BCH001369	Charger	686-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BCH001369	Charger	686-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BCH001369	Charger	686-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BCH001369	Charger	686-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BCH001369	Charger	686-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BCH001369	Charger	686-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BCH001369	Charger	686-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Unknown Operations	0	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BCH001271	Charger	736-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BCH001271	Charger	736-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BCH001271	Charger	736-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BCH001271	Charger	736-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BCH001271	Charger	736-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	Oil Temp Present	32	°C
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	Oil Temp Max	65	°C
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	LTC Totalizer Reading	4144.32	kw
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	General Comments		
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	General Comments		
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	Follow-up Action Required?	n	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	General Comments		
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	General Comments		
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Max Tap Position	1L	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	General Comments		
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	LTCC000887	LTCControl	478-2	LTC Control Insp	All Connections OK?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	LTCC000887	LTCControl	478-2	LTC Control Insp	Follow-up Action Required?	n	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	LTCC000887	LTCControl	478-2	LTC Control Insp	General Comments		
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	LTCC000887	LTCControl	478-2	LTC Control Insp	LTC Operation Checked?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	LTCC000887	LTCControl	478-2	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	LTCC000887	LTCControl	478-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Regulator As Left Counter	31475	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	General Comments		
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Fault Operations Ground	0	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Fault Operations C Ø	0	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Regulator As Left Counter	91022	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Grounds in Place?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	General Comments		
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	General Comments		
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Foundation Condition	Good	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Follow-up Action Required?	n	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	General Comments		
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	n	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Fault Operations A Ø	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Fault Operations B Ø	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Fault Operations C Ø	0	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Fault Operations Ground	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	LTCC000887	LTCControl	478-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	LTCC000887	LTCControl	478-2	LTC Control Insp	VRR Time Delay	45	Seconds
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	General Comments		
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Follow-up Action Required?	n	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Patrol Inspection	General Comments		
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Regulator As Left Counter	113638	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Switching Operations	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Operations This Read AM	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Operations Counter AL	419	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Operations Counter AF	419	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Maintenance Operations	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	General Comments		
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Fault Operations B Ø	0	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Fault Operations A Ø	0	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Regulator As Left Counter	29928	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	General Comments		
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	LTC Current Tap Position	3R	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	LTC As Left Counter	39077	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	LTC As Found Counter	39077	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Mechanism Patrol Inspection	General Comments		
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	General Comments		
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	Follow-up Action Required?	n	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Regulator As Left Counter	50198	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Amps B Ø	0.0	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Amps C Ø	120.0	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Bushing Condition	Good	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	9 Months Operations	3	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Accumulated Fault Duty B Ph AM	1.2	%
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Accumulated Fault Duty C Ph AM	2.41	%
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Amps A Ø	80.0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Amps B Ø	80.0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Amps C Ø	80.0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0970	BreakerAirMagnetic	SW-1191	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	General Comments		
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Door Alarms OK?	n	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Broom on Site?	n	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	General Comments		
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	FE000592	Fence	SW-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Trash Emptied?	n	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	n	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Station Ground Set On Site?	n	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Panel Lights OK?	n	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	General Comments		
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C ∅	0	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B ∅	0	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A ∅	0	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Amps C ∅	50.0	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Amps B ∅	90.0	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Amps A ∅	90.0	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	13	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Unknown Operations	0	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	General Comments	ok	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	General Comments		
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Mechanism Patrol Inspection	General Comments	replaced dessicant filter	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	LTC As Found Counter	77892	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	General Comments		
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	LTC As Left Counter	77892	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6L	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	LTC Max Tap Position	3R	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	LTC Min Tap Position	11L	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1246	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	Totalizer Meter Reading	.7668	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	Oil Temp Present	30	°C
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	Oil Temp Max	50	°C
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	LTC Totalizer Reading	3680.64	kw
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	General Comments		
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	General Comments		
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	General Comments	Ballast going out on light near to the transformer	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Switching Operations	0	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Tank Paint Condition	Good	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Unknown Operations	0	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BCH001389	Charger	478-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BCH001389	Charger	478-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BCH001389	Charger	478-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BCH001389	Charger	478-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BCH001389	Charger	478-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.1	amps
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BCH001389	Charger	478-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BCH001389	Charger	478-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BCH001389	Charger	478-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	3.200	millivolts
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Switching Operations	0	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Operations This Read Vac	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Operations Counter AL	220	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Operations Counter AF	220	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Maintenance Operations	0	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Trash Emptied?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	General Comments		
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Broom on Site?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	CH000191	ControlHouse	SW-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	SWG000073	Switchgear	SW-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0188	LTCMechanism	SW-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Fault Operations A Ø	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Amps C Ø	50.0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Amps B Ø	50.0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Amps A Ø	50.0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Accumulated Fault Duty C Ph AM	1.2	%
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	9 Months Operations	0	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Unknown Operations	0	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	General Comments		
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Ambient Temp	46	°F
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	General Comments		
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BCH001402	Charger	819-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1	amps
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BCH001402	Charger	819-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BCH001402	Charger	819-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BCH001402	Charger	819-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BAT001466	Battery	819-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BAT001466	Battery	819-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BAT001466	Battery	819-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BAT001466	Battery	819-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BAT001466	Battery	819-Battery Bank	Battery Patrol Inspection	General Comments		
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BAT001466	Battery	819-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BAT001466	Battery	819-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BAT001466	Battery	819-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BAT001466	Battery	819-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BAT001466	Battery	819-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BAT001466	Battery	819-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BAT001466	Battery	819-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	40	°F
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	Oil Temp Max	35	°C
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Switching Operations	0	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	General Comments		Wildlife protection needed
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BAT001466	Battery	819-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Maintenance Operations	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	General Comments		
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Patrol Inspection	General Comments		
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Follow-up Action Required?	n	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Fault Operations Ground	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Fault Operations C ∅	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Fault Operations B ∅	0	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Fault Operations A ∅	0	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Operations Counter	8	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	General Comments		
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Fault Operations B Ø	0	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Fault Operations C Ø	0	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Fault Operations Ground	0	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Follow-up Action Required?	n	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	Foundation Condition	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	General Comments		
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	General Comments	BFTC	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	Grounds in Place?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Maintenance Operations	0	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Fault Operations B Ø	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Fault Operations A Ø	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Amps C Ø	250.0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Amps B Ø	257.0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Amps A Ø	261.0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	9 Month Operations	0	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Operations Counter AF	197	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Operations Counter AL	197	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Operations This Read Vac	0	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Switching Operations	0	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Unknown Operations	0	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	9 Month Operations	53	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	General Comments		
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Vegetation	None	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Regulator As Left Counter	47930	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Unknown Operations	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Switching Operations	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Operations This Read Vac	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Operations Counter AL	363	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Operations Counter AF	363	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Maintenance Operations	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	General Comments		
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Patrol Inspection	General Comments		
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Follow-up Action Required?	n	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Fault Operations Ground	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Fault Operations C Ø	0	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	General Comments		
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	9 Month Operations	0	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Amps A Ø	106.0	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Amps B Ø	106.0	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Amps C Ø	76.0	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	Bushing Condition	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Min Tap Position	12L	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Max Tap Position	5L	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	General Comments		
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Current Tap Position	5L	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	General Comments		
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	LTC As Found Counter	36432	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	LTC As Left Counter	36432	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	LTC Current Tap Position	8L	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	LTC Max Tap Position	2R	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	LTC Min Tap Position	12L	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	545	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Foundation Condition	Good	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	General Comments		
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	General Comments	2 trip checks and 2 functional trip checks	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Grounds in Place?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Tank Leaks	None	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Regulator As Left Counter	31587	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.2	volts
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Min Tap Position	9L	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Max Tap Position	2L	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	General Comments		
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	10.5	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	6.4	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Fault Operations A Ø	0	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Fault Operations B Ø	0	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Fault Operations C Ø	0	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	608	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Fault Operations Ground	0	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Follow-up Action Required?	n	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Foundation Condition	Good	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	General Comments		
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	General Comments		
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Grounds in Place?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Maintenance Operations	0	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Operations Counter AF	172	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Operations Counter AL	172	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Operations This Read Vac	0	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Switching Operations	0	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Unknown Operations	0	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Tank Leaks	None	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Regulator As Left Counter	26707	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	122.2	volts
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Fault Operations C Ø	0	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Fault Operations Ground	0	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Follow-up Action Required?	n	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Foundation Condition	Good	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	General Comments		
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	General Comments		
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Grounds in Place?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Maintenance Operations	0	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Operations Counter AF	375	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Operations Counter AL	375	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Operations This Read Vac	3	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Switching Operations	0	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Tank Paint Condition	Good	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Unknown Operations	0	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	Oil Temp Present	35	°C
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	General Comments	Barbwire and top rail in need of upgrade grounding	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Ambient Temp	53	°F
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BCH001402	Charger	819-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BCH001402	Charger	819-Battery Charger	Battery Charger Patrol Insp	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BCH001402	Charger	819-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BCH001402	Charger	819-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Switching Operations	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Operations This Read AM	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Operations Counter AL	233	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0969	BreakerAirMagnetic	SW-1190	AMCB Readings	Operations Counter AF	233	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	General Comments		
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Vegetation	None	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Current Tap Position	2L	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Maintenance Operations	4	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Operations Counter AF	145	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Operations Counter AL	145	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Operations This Read Vac	4	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	9 Month Operations	2	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	9 Month Operations	7	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Amps A Ø	30.0	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Amps B Ø	30.0	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Amps C Ø	60.0	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Bushing Condition	Good	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Fault Adjusted Amps B Phase V	12.58	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Fault Operations A Ø	0	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Fault Operations B Ø	3	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Grounds in Place?	y	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	General Comments		
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	General Comments		
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Foundation Condition	Good	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Fault Operations Ground	0	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Fault Adjusted Amps C Phase V	2.83	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Fault Operations A Ø	0	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Fault Operations B Ø	0	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Fault Operations C Ø	0	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Fault Operations B Ø	0	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Fault Operations A Ø	0	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Bushing Condition	Good	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Amps C Ø	300.0	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Amps B Ø	300.0	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Fault Operations C Ø	1	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Fault Operations Ground	0	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Follow-up Action Required?	n	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Foundation Condition	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	General Comments		
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	General Comments		
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Grounds in Place?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Maintenance Operations	0	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Operations Counter AF	222	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Operations Counter AL	222	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Operations This Read Vac	4	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Switching Operations	3	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Unknown Operations	0	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	9 Month Operations	5	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Amps A Ø	275.0	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	LTCC000853	LTCControl	084-5	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	LTCC000853	LTCControl	084-5	LTC Control Insp	LTC Operation Checked?	y	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Bushing Condition	Good	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Amps C Ø	206.0	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Amps B Ø	191.0	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Amps A Ø	213.0	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	9 Month Operations	6	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Amps A Ø	140.0	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Amps B Ø	130.0	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Amps C Ø	90.0	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Bushing Condition	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	LTCC000853	LTCControl	084-5	LTC Control Insp	General Comments		
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	LTCC000853	LTCControl	084-5	LTC Control Insp	Follow-up Action Required?	n	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	LTCC000853	LTCControl	084-5	LTC Control Insp	All Connections OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Maintenance Operations	0	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Operations Counter AF	189	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Operations Counter AL	189	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Operations This Read Vac	0	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Switching Operations	0	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Unknown Operations	0	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	550	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Unknown Operations	0	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Switching Operations	0	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Operations This Read Vac	0	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Operations Counter AL	218	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Operations Counter AF	218	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Maintenance Operations	0	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Operations Counter AL	523	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Operations This Read Vac	1	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Switching Operations	1	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Unknown Operations	0	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Amps C Ø	12.0	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Amps B Ø	12.0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	General Comments		
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments	Trans needs nitrogen, oil pump under LTC seeping oil	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Amps A Ø	11.0	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-5	psi
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	General Comments		
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	9 Month Operations	3	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Readings	General Comments		
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	9 Month Operations	44	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	30.0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	30.0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	30.0	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Amps A Ø	133.0	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Amps B Ø	107.0	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Amps C Ø	129.0	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Bushing Condition	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Fault Operations A Ø	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0187	WithLTC	Retired Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Fault Operations B Ø	0	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Fault Operations C Ø	0	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Fault Operations Ground	0	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Follow-up Action Required?	n	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Foundation Condition	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	General Comments		
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	General Comments	BFTC	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Grounds in Place?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Maintenance Operations	0	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Operations Counter AF	522	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0975	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	550	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	LTC Totalizer Reading	5232	kw
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	2L	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	General Comments	oil in gauge	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	Neutral	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	4L	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	157539	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	1L	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	Neutral	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	4L	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Amps A Ø	64.0	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Amps B Ø	63.0	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Amps C Ø	64.0	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Bushing Condition	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Fault Operations A Ø	0	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Fault Operations B Ø	0	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Fault Operations C Ø	0	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Fault Operations Ground	0	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Follow-up Action Required?	n	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Foundation Condition	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	General Comments		
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	General Comments		
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Grounds in Place?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Vegetation	None	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	General Comments		
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Regulator As Left Counter	34874	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	General Comments		
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Current Tap Position	6L	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Grounds in Place?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Maintenance Operations	0	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Operations Counter AF	231	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Operations Counter AL	231	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Operations This Read Vac	0	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	General Comments		
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	LTCC000853	LTCCControl	084-5	LTC Control Insp	VRR Time Delay	30	Seconds
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Switching Operations	0	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Unknown Operations	0	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Fault Operations B Ø	0	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Fault Operations A Ø	0	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	LTCC000853	LTCCControl	084-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	LTCC000853	LTCCControl	084-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	General Comments		
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	218493	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Unknown Operations	0	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Switching Operations	0	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Operations This Read Vac	0	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Operations Counter AL	207	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Operations Counter AF	207	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Maintenance Operations	0	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Grounds in Place?	y	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	General Comments	ok	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	General Comments	ok	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Foundation Condition	Good	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Follow-up Action Required?	n	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Fault Operations Ground	0	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Fault Operations C Ø	0	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	9 Month Operations	10	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Amps A Ø	55.0	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Amps B Ø	40.0	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Amps C Ø	60.0	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Bushing Condition	Good	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Fault Operations A Ø	0	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Fault Operations B Ø	0	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Fault Operations C Ø	0	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Fault Operations Ground	0	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Follow-up Action Required?	n	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Foundation Condition	Good	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	General Comments		
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	General Comments		
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	General Comments		
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	General Comments		
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	LTCC000008	LTCControl	223-5	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	LTCC000008	LTCControl	223-5	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	LTCC000008	LTCControl	223-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	LTCC000008	LTCControl	223-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	LTCC000008	LTCControl	223-5	LTC Control Insp	VRR Time Delay	30	Seconds
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Unknown Operations	0	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Switching Operations	0	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Operations This Read Vac	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Switching Operations	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Operations This Read AM	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Operations Counter AL	225	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Operations Counter AF	225	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Maintenance Operations	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	General Comments	IOC A phase, Actual counter	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Patrol Inspection	General Comments		
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Follow-up Action Required?	n	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Fault Operations Ground	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Fault Operations C Ø	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Fault Operations B Ø	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Fault Operations A Ø	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Operations Counter	213	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	General Comments		
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Amps B Ø	16.5	
12/2/2020 13:31	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	General Comments	ok	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Ambient Temp	26	*F
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Fault Operations Ground	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Fault Operations C Ø	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Fault Operations B Ø	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Fault Operations A Ø	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Amps C Ø	0.0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Amps B Ø	0.0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Amps A Ø	0.0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	9 Months Operations	0	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	Totalizer Meter Reading	.8064	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	Winding Temp Max	45	°C
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	Winding Temp Present	30	°C
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	Follow-up Action Required?	n	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	General Comments		
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Mechanism Patrol Inspection	General Comments		
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	LTC As Found Counter	18572	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	LTC As Left Counter	18572	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	LTC Current Tap Position	5L	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	LTC Max Tap Position	3R	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	LTC Min Tap Position	8L	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	LTC Operations Since Last Insp	535	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	LTCC000008	LTCControl	223-5	LTC Control Insp	All Connections OK?	y	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	LTCC000008	LTCControl	223-5	LTC Control Insp	Follow-up Action Required?	n	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	LTCC000008	LTCControl	223-5	LTC Control Insp	General Comments		
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	LTCC000008	LTCControl	223-5	LTC Control Insp	LTC Operation Checked?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Operations Counter AL	225	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Operations Counter AF	225	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Maintenance Operations	0	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Grounds in Place?	y	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	General Comments		
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	General Comments		
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Foundation Condition	Good	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Follow-up Action Required?	n	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Fault Operations Ground	0	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Fault Operations C Ø	0	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Fault Operations B Ø	0	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Bushing Condition	Good	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Amps C Ø	130.0	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Amps B Ø	130.0	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Amps A Ø	140.0	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	9 Month Operations	2	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	9 Month Operations	12	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Amps A Ø	65.0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Amps B Ø	28.0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Amps C Ø	39.0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Fault Operations A Ø	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Fault Operations B Ø	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Fault Operations C Ø	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Fault Operations Ground	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Follow-up Action Required?	n	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Patrol Inspection	General Comments		
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	General Comments		
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	General Comments	ok	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Vegetation	None	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	LTC Totalizer Reading	7612.72	kw
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	Oil Temp Max	32	°C
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	Oil Temp Present	32	°C
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	Totalizer Meter Multiplier	8600	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	Totalizer Meter Reading	.8852	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Amps C Ø	50.0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Amps B Ø	50.0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Amps A Ø	50.0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	Accumulated Fault Duty A Ph AM	3.61	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0967	BreakerAirMagnetic	SW-1188	AMCB Readings	9 Months Operations	3	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	General Comments		
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	General Comments	Trans needs nitrogen	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	General Comments		
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LTCC000388	LTCControl	WO-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIPAR	Position
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LTCC000388	LTCControl	WO-TRANS 1	LTC Control Insp	General Comments		
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LTCC000388	LTCControl	WO-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	LTC Operations Since Last Insp	367	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	LTC Min Tap Position	10L	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	LTC Max Tap Position	7L	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	LTC Current Tap Position	8L	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Unknown Operations	0	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Switching Operations	0	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Operations This Read Vac	0	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Operations Counter AL	187	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Operations Counter AF	187	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Maintenance Operations	0	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Grounds in Place?	y	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	General Comments		
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	General Comments		
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Foundation Condition	Good	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Follow-up Action Required?	n	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	LTC As Left Counter	11566	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	LTC As Found Counter	11566	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Fault Operations Ground	0	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Fault Operations C ∅	0	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Fault Operations B ∅	0	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Fault Operations A ∅	0	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	General Comments	ok	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	General Comments	ok	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	LTC Totalizer Reading	4212.00	kw
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	Oil Temp Max	50	°C
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	Oil Temp Present	20	°C
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	Totalizer Meter Reading	.5850	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	15	°C
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	LTCC000565	LTCControl	743-2	LTC Control Insp	All Connections OK?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	LTCC000565	LTCControl	743-2	LTC Control Insp	Follow-up Action Required?	n	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	LTCC000565	LTCControl	743-2	LTC Control Insp	General Comments		
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	LTCC000565	LTCControl	743-2	LTC Control Insp	LTC Operation Checked?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	LTCC000565	LTCControl	743-2	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	LTCC000565	LTCControl	743-2	LTC Control Insp	Parallel / Ind. Sw Position	parallellIND	Position
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	LTCC000565	LTCControl	743-2	LTC Control Insp	VRR Base Voltage AF	124	VAC
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	LTCC000565	LTCControl	743-2	LTC Control Insp	VRR Base Voltage AL	124	VAC
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	LTCC000565	LTCControl	743-2	LTC Control Insp	VRR Time Delay	30	Seconds
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	60	°C
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	17	°C
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	71	°C
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	17	°C
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	71	°C
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	Oil Temp Present	15	°C
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0188	WithLTC	SW-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	General Comments		
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Mechanism Patrol Inspection	General Comments		
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	LTC As Found Counter	28036	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	LTC As Left Counter	28036	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	LTC Current Tap Position	8L	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	LTC Max Tap Position	3L	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	LTC Min Tap Position	12L	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	LTC Operations Since Last Insp	701	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Switching Operations	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Operations This Read AM	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Operations Counter AL	536	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Operations Counter AF	536	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Maintenance Operations	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	General Comments		
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Patrol Inspection	General Comments		
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Readings	Follow-up Action Required?	n	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0968	BreakerAirMagnetic	SW-1189	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	General Comments		
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	General Comments		
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	LTC Totalizer Reading	11612.16	kw
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	563	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	LTC Min Tap Position	12L	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4L	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	LTC Current Tap Position	7L	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	LTC As Left Counter	92983	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	LTC As Found Counter	92983	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1100	psi
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	Oil Temp Max	50	°C
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	Oil Temp Present	30	°C
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	General Comments		
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Mechanism Patrol Inspection	General Comments		
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	General Comments		
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	Follow-up Action Required?	n	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	LTC Operations Since Last Insp	900	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	LTC Min Tap Position	12L	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	LTC Max Tap Position	3R	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	LTC Current Tap Position	9L	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	LTC As Left Counter	30143	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	LTC As Found Counter	30132	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Bushing Condition	Good	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Amps C Ø	95.0	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Amps B Ø	105.0	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Amps A Ø	120.0	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	9 Month Operations	4	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Mechanism Patrol Inspection	General Comments		
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	General Comments		
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	Follow-up Action Required?	n	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	Follow-up Action Required?	n	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	Follow-up Action Required?	n	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	General Comments		
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Unknown Operations	0	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Tank Paint Condition	Good	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Switching Operations	0	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Operations This Read Vac	0	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Operations Counter AL	243	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Operations Counter AF	243	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Maintenance Operations	0	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	9 Month Operations	19	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Amps A Ø	180.0	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Amps B Ø	255.0	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Grounds in Place?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	General Comments		
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	General Comments		
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Foundation Condition	Good	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Follow-up Action Required?	n	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Fault Operations Ground	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments	ok	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Readings	General Comments		
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Fault Operations B Ø	0	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Fault Operations A Ø	0	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Bushing Condition	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Amps C Ø	12.0	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Amps B Ø	12.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Amps A Ø	11.0	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	9 Month Operations	0	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.0356	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	130.00	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	135.00	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1242.72	kw
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	General Comments		
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	General Comments		
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Vegetation	None	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	General Comments		
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Ambient Temp	50	*F
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Amps B Ø	190	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Amps C Ø	170	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Bushing Condition	Good	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Fault Adjusted Amps A Phase V	0	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Fault Adjusted Amps B Phase V	0	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Fault Adjusted Amps C Phase V	0	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Fault Operations A Ø	0	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Fault Operations B Ø	0	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Fault Operations C Ø	0	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Fault Operations Ground	0	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Fault Operations C Ø	0	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Amps C Ø	190.0	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Bushing Condition	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Fault Operations A Ø	0	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Fault Operations B Ø	0	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Fault Operations C Ø	0	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Fault Operations Ground	0	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Follow-up Action Required?	n	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Foundation Condition	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	General Comments		
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	General Comments		
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Grounds in Place?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Maintenance Operations	0	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Operations Counter AF	357	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Operations Counter AL	357	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Operations This Read Vac	0	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Switching Operations	0	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Unknown Operations	0	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	9 Month Operations	0	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Accumulated Fault Duty A Ph V	.64	%
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Accumulated Fault Duty B Ph V	0	%
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Accumulated Fault Duty C Ph V	0	%
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Amps A Ø	160	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	General Comments		
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Fault Operations B Ø	0	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Fault Operations A Ø	0	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Fault Operations B Ø	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Fault Operations C Ø	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Fault Operations Ground	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Follow-up Action Required?	n	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Patrol Inspection	General Comments		
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Fault Operations C Ø	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Fault Operations Ground	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Follow-up Action Required?	n	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Patrol Inspection	General Comments		
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	General Comments		
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Maintenance Operations	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Operations Counter AF	147	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Operations Counter AL	147	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Operations This Read Vac	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Switching Operations	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Unknown Operations	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	9 Month Operations	2	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Amps A Ø	193.0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Amps B Ø	191.0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Amps C Ø	212.0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Fault Operations A Ø	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Amps A Ø	605.0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Amps B Ø	561.0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Amps C Ø	629.0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Fault Operations Ground	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Switching Operations	0	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Operations This Read Vac	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Patrol Inspection	General Comments		
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	General Comments		
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Maintenance Operations	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Operations Counter AF	154	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Operations Counter AL	154	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Operations This Read Vac	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Switching Operations	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Unknown Operations	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Operations Counter AL	234	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Operations Counter AF	234	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Maintenance Operations	0	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Grounds in Place?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	General Comments		
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Foundation Condition	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Follow-up Action Required?	n	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Fault Operations Ground	0	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Fault Operations C Ø	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Present	30	°C
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	PN58	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Max	40	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	PNS8	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	PNS8	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	PNS8	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	Follow-up Action Required?	n	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Fault Operations A Ø	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Fault Operations B Ø	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Fault Operations C Ø	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Fault Operations Ground	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Follow-up Action Required?	n	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Patrol Inspection	General Comments		
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	General Comments		
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	LTCC000157	LTCControl	467-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Maintenance Operations	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Operations Counter AF	147	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Operations Counter AL	147	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Operations This Read Vac	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Switching Operations	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Unknown Operations	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	5	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	General Comments		
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	LTCC000157	LTCControl	467-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	LTCC000157	LTCControl	467-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	LTCC000157	LTCControl	467-1	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	LTCC000157	LTCControl	467-1	LTC Control Insp	LTC Operation Checked?	y	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	LTCC000157	LTCControl	467-1	LTC Control Insp	General Comments	ok	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	LTCC000157	LTCControl	467-1	LTC Control Insp	Follow-up Action Required?	n	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	LTCC000157	LTCControl	467-1	LTC Control Insp	All Connections OK?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Unknown Operations	0	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	146	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	146	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	4	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	4	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	9 Month Operations	1	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Operations Counter AF	184	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	1.6	VDC
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	.2	VDC
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	Totalizer Meter Reading	.4404	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	General Comments		
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Readings	General Comments		
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	General Comments		
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	60.00	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Ambient Temp	60	*F
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	General Comments		
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	55.00	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Readings	Oil Temp Max	35	*C
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Vegetation	None	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Ambient Temp	55	*F
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	9 Month Operations	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Amps A Ø	0.0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Amps B Ø	0.0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Amps C Ø	0.0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Fault Operations A Ø	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Fault Operations B Ø	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Fault Operations C Ø	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Fault Operations Ground	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Follow-up Action Required?	n	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Patrol Inspection	General Comments		
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	General Comments		
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Maintenance Operations	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Operations Counter AF	369	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Operations Counter AL	369	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Operations This Read Vac	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Switching Operations	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Unknown Operations	0	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LTCC000333	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LTCC000333	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LTCC000333	LTCControl	Retired Distribution	LTC Control Insp	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LTCC000333	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LTCC000334	LTCControl	SW-TRANS 1	LTC Control Insp	All Connections OK?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LTCC000334	LTCControl	SW-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LTCC000334	LTCControl	SW-TRANS 1	LTC Control Insp	General Comments		
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LTCC000334	LTCControl	SW-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Unknown Operations	0	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Switching Operations	0	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Operations This Read Vac	1	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Operations Counter AL	184	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Follow-up Action Required?	n	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Fault Operations Ground	0	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Fault Operations C Ø	0	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Fault Operations B Ø	1	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Fault Operations A Ø	0	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Fault Adjusted Amps B Phase V	5.07	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Bushing Condition	Good	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Amps C Ø	253.0	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Amps B Ø	158.0	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Amps A Ø	190.0	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	9 Month Operations	6	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Bushing Condition	Good	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Amps C Ø	30.0	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Amps B Ø	35.0	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Amps A Ø	30.0	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Unknown Operations	0	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Switching Operations	0	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	General Comments		
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	9 Month Operations	5	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	55	*F
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Readings	General Comments		
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	60.00	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	55.00	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Readings	Oil Temp Present	11	*C
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	General Comments		
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Switch Stick Next Test Date	2022-12-02 00:00:00.000000	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Vegetation	None	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	PF000429	PowerFuse	WO-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	PF000429	PowerFuse	WO-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Maintenance Operations	1	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Grounds in Place?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	General Comments	TC	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	General Comments		
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Foundation Condition	Good	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Follow-up Action Required?	n	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Fault Operations Ground	0	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Fault Operations C Ø	0	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Fault Operations B Ø	0	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Fault Operations A Ø	0	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Unknown Operations	0	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Switching Operations	0	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Operations This Read Vac	1	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Operations Counter AL	274	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Operations Counter AF	274	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Maintenance Operations	0	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Grounds in Place?	y	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	General Comments		
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	General Comments		
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Foundation Condition	Good	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	Winding Temp Present	25	°C
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	Totalizer Meter Reading	.3312	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	Oil Temp Present	25	°C
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	Oil Temp Max	70	°C
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-2.0	psi
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	LTC Totalizer Reading	3179.52	kw
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	General Comments		
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	General Comments		
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	9 Month Operations	3	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Amps A Ø	0.0	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Amps B Ø	54.0	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Amps C Ø	54.0	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Bushing Condition	Good	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Fault Operations A Ø	0	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Fault Operations B Ø	0	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Fault Operations C Ø	0	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Fault Operations Ground	0	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	General Comments		
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	General Comments		
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.5	psi
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	352.32	kw
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	15.00	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	10.00	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	Oil Temp Max	40	°C
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	Oil Temp Present	20	°C
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	BCH000096	Charger	Retired Distribution	Battery Charger Patrol Insp	Ground Lights	None	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	BCH000096	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	BCH000096	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	BCH000096	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	BCH000096	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	5.0	amps
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	BCH000096	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.3	VDC
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	BCH000096	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.3	VDC
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	BCH000096	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	22.500	millivolts
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BCH000539	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BCH000539	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BCH000539	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BCH000539	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BCH000539	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BCH000539	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	BCH000425	Charger	006-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	BCH000425	Charger	006-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	BCH000425	Charger	006-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	BCH000425	Charger	006-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	BCH000425	Charger	006-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BCH000528	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BCH000528	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	132.0	VDC
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BCH000528	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	132.0	VDC
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BCH000528	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	LTCC000068	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	45	Seconds
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	LTCC000068	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	LTCC000068	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	LTCC000068	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	LTCC000068	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	LTCC000068	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	LTCC000068	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	LTCC000068	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BCH000528	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Fault Operations A Ø	0	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Fault Operations B Ø	0	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Fault Operations C Ø	0	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Fault Operations Ground	0	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Follow-up Action Required?	n	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Foundation Condition	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	General Comments		
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	General Comments	BFTC	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Grounds in Place?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Maintenance Operations	0	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Operations Counter AF	211	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Operations Counter AL	212	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Operations This Read Vac	1	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Switching Operations	1	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Unknown Operations	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LTCC000098	LTCControl	WO-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LTCC000098	LTCControl	WO-TRANS 2	LTC Control Insp	General Comments		
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LTCC000098	LTCControl	WO-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	27	*F
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	28.8	VDC
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	27.6	VDC
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	BCH001052	Charger	467-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	BCH001052	Charger	467-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	BCH001052	Charger	467-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	BCH001052	Charger	467-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	BCH001052	Charger	467-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	BCH001052	Charger	467-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	55	*F
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Follow-up Action Required?	n	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Foundation Condition	Good	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	General Comments	ok	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	General Comments	ok	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Grounds in Place?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Maintenance Operations	0	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Operations Counter AF	227	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Operations Counter AL	227	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Operations This Read Vac	0	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Switching Operations	0	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Unknown Operations	0	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BCH000528	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Ambient Temperature	55	*F
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Heaters Functioning?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Internal Condition?	Clean	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Foundation Condition	Good	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	General Comments		
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Grounds in Place?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Moisture and Leak Free?	y	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Bushing Condition	Good	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Indicator Zone	OK	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Trip-energy Supply Verified	y	LED lights?
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	Follow-up Action Required?	n	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	General Comments		
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Mechanism Patrol Inspection	General Comments		
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	LTC As Found Counter	345317	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	LTC As Left Counter	345323	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	LTC Current Tap Position	12L	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	LTC Max Tap Position	2L	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	LTC Min Tap Position	15L	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	LTC Operations Since Last Insp	1209	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	9 Month Operations	27	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Amps A Ø	8.0	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Amps B Ø	2.0	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Amps C Ø	3.0	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Bushing Condition	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Grounds in Place?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	General Comments	BFTC	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	General Comments		
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Foundation Condition	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Follow-up Action Required?	n	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Fault Operations Ground	0	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Fault Operations C Ø	0	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Fault Operations B Ø	0	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Fault Operations A Ø	0	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Bushing Condition	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Amps C Ø	139.0	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Amps B Ø	135.0	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Amps A Ø	126.0	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	9 Month Operations	13	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	55	*F
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	General Comments		
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.4	VDC
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.1	VDC
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	General Comments		
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	LTC Current Tap Position	6L	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	LTC As Left Counter	8613	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	General Comments	ok	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	General Comments	ok	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Foundation Condition	Good	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Follow-up Action Required?	n	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Fault Operations Ground	0	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Fault Operations C Ø	0	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Fault Operations B Ø	0	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Fault Operations A Ø	0	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	LTC As Found Counter	8613	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Mechanism Patrol Inspection	General Comments		
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	General Comments		
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	Follow-up Action Required?	n	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Bushing Condition	Good	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Amps C Ø	68.0	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Amps B Ø	45.0	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Amps A Ø	45.0	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	9 Month Operations	3	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Unknown Operations	0	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Switching Operations	1	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Operations This Read Vac	1	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Operations Counter AL	179	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Operations Counter AF	178	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Maintenance Operations	0	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	BCH000300	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	54.8	VDC
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	BCH000300	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	BCH000300	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	BCH000487	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	BCH000487	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	BCH000487	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	BCH000487	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	BCH000487	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	BCH000487	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	BCH000487	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Broom on Site?	n	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	General Comments		
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Trash Emptied?	n	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	PF001153	PowerFuse	SW-B 14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	PF001153	PowerFuse	SW-B 14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	Follow-up Action Required?	n	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	General Comments		
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Mechanism Patrol Inspection	General Comments		
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	LTC As Found Counter	8085	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	LTC As Left Counter	8085	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	LTC Current Tap Position	9L	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	LTC Max Tap Position	4L	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	LTC Min Tap Position	13L	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	LTC Operations Since Last Insp	266	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	PF000347	PowerFuse	SW-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	PF000347	PowerFuse	SW-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	PF000346	PowerFuse	SW-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	PF000346	PowerFuse	SW-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	General Comments		
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	BAT000089	Battery	SW-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Unknown Operations	0	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Switching Operations	0	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Operations This Read Vac	0	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Operations Counter AL	202	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Operations Counter AF	202	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Maintenance Operations	0	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Grounds in Place?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	General Comments		
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	General Comments		
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Foundation Condition	Good	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Follow-up Action Required?	n	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	General Comments		
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Fault Operations Ground	0	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Fault Operations C Ø	0	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Fault Operations B Ø	0	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Fault Operations A Ø	0	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Fault Adjusted Amps C Phase V	0	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Fault Adjusted Amps B Phase V	0	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Fault Adjusted Amps A Phase V	0	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Bushing Condition	Good	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Amps C Ø	95	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Amps B Ø	105	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Amps A Ø	95	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Accumulated Fault Duty C Ph V	.32	%
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Accumulated Fault Duty B Ph V	0	%
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Accumulated Fault Duty A Ph V	.32	%
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	9 Month Operations	2	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Bushing Condition	Good	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Amps C Ø	80	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Amps B Ø	105	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Amps A Ø	100	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Accumulated Fault Duty C Ph V	2.5	%
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Accumulated Fault Duty B Ph V	4.17	%
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Accumulated Fault Duty A Ph V	4.17	%
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	9 Month Operations	10	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Foundation Condition	Good	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Follow-up Action Required?	n	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Fault Operations Ground	0	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Fault Operations C Ø	0	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Fault Operations B Ø	0	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Fault Operations A Ø	0	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	BCH000477	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	BCH000477	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	BCH000477	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	BCH000477	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	BCH000212	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.3	VDC
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	BCH000212	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	52.3	VDC
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	BCH000212	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	BCH000212	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	BCH000212	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Readings	Oil Temp Max	38	°C
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Readings	Oil Temp Present	20	°C
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Operations This Read Vac	1	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Operations Counter AL	191	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Operations Counter AF	191	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Unknown Operations	0	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Switching Operations	0	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Maintenance Operations	1	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Grounds in Place?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	General Comments	TC	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	General Comments		
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Operations This Read Vac	0	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Operations Counter AL	1054	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Operations Counter AF	1054	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Maintenance Operations	0	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Grounds in Place?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	General Comments		
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	General Comments		
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Foundation Condition	Good	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Follow-up Action Required?	n	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Fault Operations Ground	0	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Fault Operations C Ø	0	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Fault Operations B Ø	0	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Fault Operations A Ø	0	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Fault Adjusted Amps C Phase V	0	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Fault Adjusted Amps B Phase V	0	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Fault Adjusted Amps A Phase V	0	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	PF000349	PowerFuse	SW-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	PF000349	PowerFuse	SW-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	PF000348	PowerFuse	SW-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	PF000348	PowerFuse	SW-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	General Comments		
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Bushing Condition	Good	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Amps C Ø	76.0	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Amps B Ø	60.0	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	LTC Operations Since Last Insp	321	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	LTC Min Tap Position	6L	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	LTC Max Tap Position	5L	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Amps A Ø	60.0	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	9 Month Operations	7	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Unknown Operations	0	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Switching Operations	0	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Operations This Read Vac	0	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Operations Counter AL	196	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Operations Counter AF	196	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Maintenance Operations	0	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Grounds in Place?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	*F
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Bushing Condition	Good	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Amps C Ø	97.0	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Amps B Ø	133.0	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Amps A Ø	116.0	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	9 Month Operations	2	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Unknown Operations	0	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Switching Operations	0	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Operations This Read Vac	1	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Operations Counter AL	192	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Operations Counter AF	192	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Maintenance Operations	0	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Grounds in Place?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	General Comments	ok	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	General Comments	ok	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Foundation Condition	Good	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Follow-up Action Required?	n	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Fault Operations Ground	0	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Fault Operations C Ø	0	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Fault Operations B Ø	1	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Fault Operations A Ø	0	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Fault Adjusted Amps B Phase V	13.43	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	PF000428	PowerFuse	WO-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	PF000428	PowerFuse	WO-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Ambient Temp	41	*F
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	General Comments		
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Vegetation	None	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Amps C Ø	73.0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Amps B Ø	70.0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Amps A Ø	33.0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	9 Month Operations	8	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	40	°C
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	20	°C
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	65	°C
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	35	°C
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	35	°C
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	20	°C
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Unknown Operations	0	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1500	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1500	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	2	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	General Comments		
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	30.0	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	50.0	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	50.0	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	Follow-up Action Required?	n	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	General Comments		
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Ambient Temp	60	*F
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Unknown Operations	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Switching Operations	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Operations This Read Vac	6	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Operations Counter AL	461	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1400	psi
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	Oil Temp Max	55	°C
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	Oil Temp Present	40	°C
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Operations Counter AF	461	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Maintenance Operations	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	General Comments		
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Patrol Inspection	General Comments		
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Follow-up Action Required?	n	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Fault Operations Ground	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Fault Operations C Ø	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Fault Operations B Ø	6	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Fault Operations A Ø	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Fault Adjusted Amps B Phase V	67.08	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	Totalizer Meter Reading	.705	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	Oil Temp Present	38	°C
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	Oil Temp Max	38	°C
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	75	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	83.33	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	6768	kw
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	General Comments		
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	General Comments		
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	9 Month Operations	2	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Accumulated Fault Duty A Ph V	5.81	%
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Accumulated Fault Duty B Ph V	6.2	%
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Accumulated Fault Duty C Ph V	2.32	%
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Amps A Ø	215	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Amps B Ø	230	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Unknown Operations	0	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Switching Operations	0	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Operations This Read Vac	0	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Operations Counter AL	44	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Operations Counter AF	44	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Maintenance Operations	0	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Grounds in Place?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	General Comments		
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	General Comments		
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Foundation Condition	Good	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Amps C Ø	240	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Follow-up Action Required?	n	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Fault Operations Ground	0	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Fault Operations C Ø	0	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Fault Operations B Ø	0	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	General Comments		
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	General Comments		
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Mechanism Patrol Inspection	General Comments		
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Vegetation	None	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	General Comments		
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	LTC As Found Counter	4776	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	LTC As Left Counter	4789	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	48	°C
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	13	°C
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	61	°C
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	23	°C
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	61	°C
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	23	°C
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	LTC Current Tap Position	7L	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	LTC Min Tap Position	8L	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	LTC Operations Since Last Insp	983	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Fault Operations B Ø	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Fault Operations A Ø	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Amps C Ø	95.0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Amps B Ø	142.0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Amps A Ø	124.0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	9 Month Operations	0	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	General Comments		
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	General Comments		
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	5238.72	kw
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	26.00	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	Oil Temp Present	50	°C
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	Totalizer Meter Reading	2.1828	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Tank Leaks	None	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Unknown Operations	0	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Ambient Temp	36	°F
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	General Comments		
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	General Comments	added noitrogen found at -.5	LTC oil level is showing low at 35C
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	LTCC000681	LTCControl	686-2	LTC Control Insp	All Connections OK?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	LTC Totalizer Reading	2832.00	kw
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Tank 2 Oil level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Tank 3 Oil Level	Good	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	Oil Temp Max	59	°C
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	Oil Temp Present	34	°C
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Tank Oil Level	Low	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	Totalizer Meter Reading	.5900	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Unknown Operations	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Switching Operations	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Operations This Read Vac	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Operations Counter AL	343	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Operations Counter AF	343	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Maintenance Operations	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	General Comments		
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Patrol Inspection	General Comments		
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Follow-up Action Required?	n	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Fault Operations Ground	0	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Fault Operations C Ø	0	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	General Comments	nitro cyl at 0 psi needs refilling.	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	General Comments	X2 will not reset	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	70	°C
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	20	°C
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	General Comments		
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	Oil Temp Present	20	°C
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	General Comments		
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Vegetation	None	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Air Compressor Oil Status	Good	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Air Leaks	None	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Air Pressure OK?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Bushing Condition	Good	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Bushing Oil Level	Good	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Bushings Connection/Risers	Good	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	.3	VDC
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	.5	VDC
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	50	°F
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/2/2020 11:03	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/2/2020 10:00	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	General Comments		
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Follow-up Action Required?	n	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Fault Operations Ground	0	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	LTCC000807	LTCControl	418-1	LTC Control Insp	All Connections OK?	y	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	LTCC000807	LTCControl	418-1	LTC Control Insp	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	LTCC000807	LTCControl	418-1	LTC Control Insp	General Comments		
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	LTCC000807	LTCControl	418-1	LTC Control Insp	LTC Operation Checked?	y	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	LTCC000807	LTCControl	418-1	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	LTCC000807	LTCControl	418-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	LTCC000807	LTCControl	418-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	LTCC000807	LTCControl	418-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Fault Operations C Ø	0	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Fault Operations B Ø	0	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Fault Operations A Ø	0	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Bushing Condition	Good	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Amps C Ø	0.0	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Amps B Ø	0.0	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Amps A Ø	0.0	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Regulator As Left Counter	19815	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Tank Leaks	None	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Current Tap Position	4R	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	General Comments		
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Min Tap Position	1L	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Current Tap Position	3R	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Unknown Operations	0	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Switching Operations	0	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Operations This Read Vac	0	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Operations Counter AL	179	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Operations Counter AF	179	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Maintenance Operations	0	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Grounds in Place?	y	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	General Comments		
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	General Comments		
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Foundation Condition	Good	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Follow-up Action Required?	n	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Fault Operations Ground	0	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Fault Operations C Ø	0	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Fault Operations B Ø	0	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	General Comments		
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Max Tap Position	13R	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Min Tap Position	4L	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Bushing Condition	Good	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Amps C Ø	455.0	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Amps B Ø	480.0	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Amps A Ø	440.0	
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/2/2020 8:48	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	9 Month Operations	0	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Grounds in Place?	y	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	General Comments		
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	General Comments		
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Foundation Condition	Good	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Regulator As Left Counter	12238	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Tank Leaks	None	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	9 Month Operations	3	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Current Tap Position	7L	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	General Comments		
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Max Tap Position	3L	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Min Tap Position	12L	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Regulator As Left Counter	13853	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Tank Leaks	None	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Current Tap Position	8L	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	General Comments		
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Max Tap Position	5L	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Min Tap Position	13L	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.3	volts
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Regulator As Left Counter	12350	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Tank Leaks	None	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Regulator As Left Counter	21370	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Tank Leaks	None	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Current Tap Position	2R	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	General Comments		
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Min Tap Position	Neutral	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Regulator As Left Counter	17779	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Tank Leaks	None	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Current Tap Position	10L	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	General Comments		
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Max Tap Position	6L	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Min Tap Position	14L	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Amps A Ø	12.0	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	9 Month Operations	1	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Operations This Read Vac	0	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Switching Operations	0	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Unknown Operations	0	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Foundation Condition	Crumbling	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Fault Operations	0	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Follow-up Action Required?	n	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Foundation Condition	Good	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	General Comments	breaker 234,235 foundation crumbling	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Ambient Temp	38	*F
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	General Comments		
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Vegetation	None	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Fault Operations A Ø	0	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Bushing Condition	Good	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Fault Adjusted Amps A Phase V	0	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Fault Adjusted Amps B Phase V	0	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Fault Adjusted Amps C Phase V	0	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Fault Operations A Ø	0	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Fault Operations B Ø	0	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Fault Operations C Ø	0	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Fault Operations Ground	0	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Follow-up Action Required?	n	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Foundation Condition	Good	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	General Comments		
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	General Comments		
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Grounds in Place?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Maintenance Operations	0	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Operations Counter AF	215	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Operations Counter AL	215	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Ambient Temp	30	*F
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Clear of Trash?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	General Comments		
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Vegetation	None	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Bushing Condition	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Amps C Ø	12.0	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Amps B Ø	12.0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Amps C Ø	320.0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Amps B Ø	300.0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Amps A Ø	300.0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	9 Months Operations	0	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Fault Operations B Ø	0	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Fault Operations A Ø	0	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Fault Adjusted Amps C Phase V	0	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Fault Adjusted Amps B Phase V	0	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Fault Adjusted Amps A Phase V	0	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	General Comments		
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Bushing Condition	Good	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Amps C Ø	95	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Amps B Ø	90	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Amps A Ø	105	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Accumulated Fault Duty C Ph V	.64	%
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Accumulated Fault Duty B Ph V	.64	%
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Accumulated Fault Duty A Ph V	1.29	%
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	9 Month Operations	2	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Unknown Operations	0	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Switching Operations	0	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Operations This Read Vac	0	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Operations Counter AL	147	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Operations Counter AF	147	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Maintenance Operations	0	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	General Comments		
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/2/2020 14:09	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Gauge(s) Condition	Good	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	General Comments		
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	General Comments		
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Grounds in Place?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Heaters (All) Functioning?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Maintenance Operations	0	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Moisture and Leak Free?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Number of Ops last 9 Months	0	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Operations Counter AF	1091	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Operations Counter AL	1091	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Operations This Read Oil	0	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Pop-off Valve Tested Date	2020-03-19 00:00:00.000000	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Pressure Vessel Condition	Good	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Switching Operations	0	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Tank 1 Oil Level	Good	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Tank 2 Oil level	Good	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Tank 3 Oil Level	Good	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Tank Leaks	None	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Tank Paint Condition	Good	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Unknown Operations	0	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Unknown Operations	0	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Switching Operations	0	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Operations This Read Vac	0	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Operations Counter AL	191	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Operations Counter AF	191	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Maintenance Operations	0	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Grounds in Place?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	General Comments		
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Foundation Condition	Good	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Follow-up Action Required?	n	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Fault Operations Ground	0	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Fault Operations C Ø	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Switching Operations	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Operations This Read AM	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Operations Counter AL	76	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Operations Counter AF	76	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Maintenance Operations	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	General Comments		
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Patrol Inspection	General Comments		
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LB0974	BreakerAirMagnetic	SW-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Switching Operations	0	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Operations This Read Vac	0	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Operations Counter AL	472	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Operations Counter AF	472	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Maintenance Operations	0	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Grounds in Place?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	General Comments		
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	General Comments		
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Foundation Condition	Good	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Follow-up Action Required?	n	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Air Compressor Oil Status	Good	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Air Leaks	None	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Air Pressure OK?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Bushing Condition	Good	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Bushing Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	9 Month Operations	0	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Accumulated Fault Duty A Ph V	.94	%
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Accumulated Fault Duty B Ph V	.94	%
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Accumulated Fault Duty C Ph V	.94	%
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Amps A Ø	310	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Amps B Ø	320	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Amps C Ø	310	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Bushing Condition	Good	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Fault Adjusted Amps A Phase V	0	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Fault Adjusted Amps B Phase V	0	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Fault Adjusted Amps C Phase V	0	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Fault Operations Ground	0	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Fault Operations C Ø	0	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Fault Operations B Ø	0	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Fault Operations A Ø	0	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Readings	General Comments		
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Operations Counter	16	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	General Comments		
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Amps C Ø	14.0	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Amps B Ø	43.0	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Amps A Ø	26.0	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Indicator Zone	OK	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	General Comments		
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Ambient Temperature	40	*F
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Switching Operations	0	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Tank Paint Condition	Good	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Unknown Operations	0	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	5	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	187	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	187	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Unknown Operations	0	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Fans Operational?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Operations Counter AF	164	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Operations Counter AL	164	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Operations This Read Vac	0	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Switching Operations	0	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	LTCC000748	LTCControl	736-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	LTCC000748	LTCControl	736-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	LTCC000748	LTCControl	736-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	LTCC000748	LTCControl	736-1	LTC Control Insp	Parallel / Ind. Sw Position	parallellIND	Position
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	LTCC000748	LTCControl	736-1	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	LTCC000748	LTCControl	736-1	LTC Control Insp	LTC Operation Checked?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	LTCC000748	LTCControl	736-1	LTC Control Insp	General Comments	ok	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	LTCC000748	LTCControl	736-1	LTC Control Insp	Follow-up Action Required?	n	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	LTCC000748	LTCControl	736-1	LTC Control Insp	All Connections OK?	y	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	LTCC000746	LTCControl	641-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	LTCC000746	LTCControl	641-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	LTCC000746	LTCControl	641-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	LTCC000746	LTCControl	641-1	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	LTCC000746	LTCControl	641-1	LTC Control Insp	LTC Operation Checked?	y	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	LTCC000746	LTCControl	641-1	LTC Control Insp	General Comments		
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	LTCC000746	LTCControl	641-1	LTC Control Insp	Follow-up Action Required?	n	
12/2/2020 11:08	Distribution	Beaver Dam North Quarterly Inspection	LTCC000746	LTCControl	641-1	LTC Control Insp	All Connections OK?	y	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	Follow-up Action Required?	n	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	General Comments	ok	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Mechanism Patrol Inspection	General Comments	ok	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	LTC As Found Counter	10565	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	LTC As Left Counter	10571	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	LTC Current Tap Position	9L	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	LTC Max Tap Position	8L	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	LTC Min Tap Position	11L	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	LTC Operations Since Last Insp	370	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/2/2020 10:26	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Bushing Condition	Good	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Amps C Ø	0.0	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Amps B Ø	0.0	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Amps A Ø	0.0	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	9 Month Operations	5	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	Totalizer Meter Reading	.5382	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	Totalizer Meter Multiplier	2400	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	Oil Temp Present	35	°C
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	Oil Temp Max	50	°C
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	LTC Totalizer Reading	1291.68	kw
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	General Comments		
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Fault Operations A Ø	0	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Fault Operations B Ø	0	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Fault Operations C Ø	0	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Fault Operations Ground	0	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Follow-up Action Required?	n	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Foundation Condition	Good	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	General Comments		
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	General Comments		
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Grounds in Place?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Maintenance Operations	0	
12/2/2020 15:39	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	General Comments		
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Switching Operations	0	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Unknown Operations	0	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	General Comments		
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	General Comments		
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.3	psi
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	10540.80	kw
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	Oil Temp Present	45	°C
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	7	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	7	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	275	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	268	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	General Comments	BFTC	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Bushing Condition	Good	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Amps C Ø	100.0	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Amps B Ø	60.0	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Amps A Ø	80.0	
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/1/2020 8:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	9 Month Operations	4	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Floor Swept?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	General Comments		
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Follow-up Action Required?	n	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Foundation Condition	Good	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	General Comments		
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	General Comments		
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	LTC Operations Since Last Insp	0	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	LTC Min Tap Position	15L	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	LTC Max Tap Position	9L	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	LTC Current Tap Position	11L	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	LTC As Left Counter	610	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	LTC As Found Counter	610	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	General Comments	counter not working	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Mechanism Patrol Inspection	General Comments		
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 13:38	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	Follow-up Action Required?	n	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Grounds in Place?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Maintenance Operations	0	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Operations Counter AF	165	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Operations Counter AL	165	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Operations This Read Vac	0	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Amps A Ø	30.0	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Amps B Ø	30.0	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Amps C Ø	30.0	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Bushing Condition	Good	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Fault Operations A Ø	0	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Fault Operations B Ø	0	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Fault Operations C Ø	0	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Fault Operations Ground	0	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Follow-up Action Required?	n	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Foundation Condition	Good	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	General Comments		
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	General Comments		
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Grounds in Place?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Maintenance Operations	0	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Operations Counter AF	995	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Operations Counter AL	995	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Operations This Read Vac	0	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 15:05	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	250.0	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	340.0	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	300.0	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
12/2/2020 9:07	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	240.0	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	300.0	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	240.0	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	12	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.0980	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	General Comments		
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	General Comments		
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2100.48	kw
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	117.50	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	110.00	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1600	
12/2/2020 12:45	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.3128	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	9 Month Operations	46	
12/1/2020 8:03	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LTO187	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Pop-off Valve Tested Date	2020-03-24 00:00:00.000000	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Operations This Read Oil	0	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Operations Counter AL	351	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Operations Counter AF	351	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Number of Ops last 9 Months	0	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Maintenance Operations	0	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Heaters (All) Functioning?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Grounds in Place?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	General Comments		
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Gauge(s) Condition	Good	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Foundation Condition	Good	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	LTC Operations Since Last Insp	169	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	LTC Min Tap Position	11L	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	LTC Max Tap Position	7L	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	LTC Current Tap Position	9L	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	LTCC000702	LTCControl	536-1	LTC Control Insp	VRR Time Delay	45	Seconds
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	LTC As Left Counter	42217	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	LTC As Found Counter	42211	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Mechanism Patrol Inspection	General Comments	ok	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	General Comments	ok	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 11:47	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	Follow-up Action Required?	n	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	LTCC000702	LTCControl	536-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	LTCC000702	LTCControl	536-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	LTCC000702	LTCControl	536-1	LTC Control Insp	LTC Output Voltage Level	123.3	VAC
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	LTCC000702	LTCControl	536-1	LTC Control Insp	LTC Operation Checked?	y	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	LTCC000702	LTCControl	536-1	LTC Control Insp	General Comments		
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	LTCC000702	LTCControl	536-1	LTC Control Insp	Follow-up Action Required?	n	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	LTCC000702	LTCControl	536-1	LTC Control Insp	All Connections OK?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	LTCC000201	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	125	VAC
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	LTCC000201	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	125	VAC
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	LTCC000201	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	125	VAC
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	LTCC000201	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	LTCC000201	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	LTCC000201	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	LTCC000201	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
12/2/2020 15:29	Distribution	Paris 12kV Quarterly Inspection	LTCC000201	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	LTCC000681	LTCControl	686-2	LTC Control Insp	Follow-up Action Required?	n	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	LTCC000681	LTCControl	686-2	LTC Control Insp	General Comments		
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	LTCC000681	LTCControl	686-2	LTC Control Insp	LTC Operation Checked?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	LTCC000681	LTCControl	686-2	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	LTCC000681	LTCControl	686-2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	LTCC000681	LTCControl	686-2	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	LTCC000681	LTCControl	686-2	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
12/2/2020 15:18	Distribution	Carlisle Quarterly Inspection	LTCC000681	LTCControl	686-2	LTC Control Insp	VRR Time Delay	30	Seconds
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
12/2/2020 14:35	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Tank 1 Oil Level	Good	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	General Comments	Replaced Dessicant filter	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Counter Readings	General Comments		
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Switching Operations	0	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Follow-up Action Required?	n	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Follow-up Action Required?	n	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Fault Operations	0	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Equipment Properly Labeled?	y	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Cabinet Paint Condition	Good	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Counter Readings	Follow-up Action Required?	n	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Pressure Vessel Condition	Good	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BCH001209	Charger	439-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/2/2020 9:19	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Found Counter	139750	
12/2/2020 11:58	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BCH001209	Charger	439-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BCH001209	Charger	439-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Operations Since Last Insp	4	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Min Tap Position	6L	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Max Tap Position	5L	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Current Tap Position	7L	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BCH001209	Charger	439-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Left Counter	139750	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Left Counter	123875	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Found Counter	123875	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	General Comments	Replaced Desiccant filter	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Counter Readings	General Comments		
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	PN58	LTCMechanism	Retired Distribution	LTC Counter Readings	Follow-up Action Required?	n	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Operations Since Last Insp	1091	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Min Tap Position	10L	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Max Tap Position	2R	
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Current Tap Position	6L	
12/2/2020 12:55	Distribution	Shavers Chapel Quarterly Inspection	BCH001209	Charger	439-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
12/7/2020 6:43	Distribution	Stewart Quarterly Inspection	LT0187	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000206	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	9 Month Operations	2	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Amps A Ø	451.0	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	LTC Operations Since Last Insp	1091	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	32	*F
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	General Comments		
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Panels Dusted?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	General Comments		
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Floor Swept?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	LTC Min Tap Position	1L	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	40	°C
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	°C
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	Totalizer Meter Reading	.8196	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	Winding Temp Max	60	°C
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	Winding Temp Present	60	°C
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	7	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	7	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	163	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	163	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Amps A Ø	44.0	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Operations Counter AF	170	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Maintenance Operations	0	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Grounds in Place?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	General Comments		
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	General Comments		
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Amps B Ø	49.0	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Amps C Ø	50.0	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Foundation Condition	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Follow-up Action Required?	n	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Fault Operations Ground	0	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Fault Operations C Ø	0	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Bushing Condition	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Fault Operations B Ø	0	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Fault Operations A Ø	0	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Unknown Operations	0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Tank Paint Condition	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Switching Operations	0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Operations This Read Vac	0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Operations Counter AL	178	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Operations Counter AF	178	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	General Comments		
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Grounds in Place?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	10.0	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	10.0	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	10.0	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	11	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000206	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Amps B Ø	469.0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Amps C Ø	461.0	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	General Comments		
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	General Comments		
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	Follow-up Action Required?	n	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Bushing Condition	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	32	*F
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Unknown Operations	0	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Tank Paint Condition	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Switching Operations	1	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Operations This Read Vac	1	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Operations Counter AL	170	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Bushing Condition	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Amps C Ø	200.0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Amps B Ø	220.0	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Amps C Ø	84.0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Amps A Ø	220.0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	9 Month Operations	4	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	General Comments		
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	General Comments		
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	LTC As Found Counter	117690	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	LTC As Left Counter	117694	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Amps B Ø	94.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Amps A Ø	71.0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Operations Counter AF	269	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Operations Counter AL	269	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Operations This Read Vac	1	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Switching Operations	1	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Unknown Operations	0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	LTC Current Tap Position	11R	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	LTC Max Tap Position	14R	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	LTC Min Tap Position	8L	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	50	°C
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	50	°C
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	LTC Operations Since Last Insp	2277	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	LTCC000373	LTCControl	845-1	LTC Control Insp	Follow-up Action Required?	n	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	LTCC000373	LTCControl	845-1	LTC Control Insp	All Connections OK?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	General Comments		
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	BCH001362	Charger	681-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	BCH001362	Charger	681-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	BCH001362	Charger	681-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	BCH001362	Charger	681-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	BCH001362	Charger	681-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.7	amps
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	BCH001362	Charger	681-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	Follow-up Action Required?	n	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	9 Month Operations	3	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Amps A Ø	0.0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Amps B Ø	0.0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Amps C Ø	0.0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	General Comments		
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Mechanism Patrol Inspection	General Comments		
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	LTC As Found Counter	20960	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	LTC As Left Counter	20964	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Fault Operations A Ø	0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Fault Operations B Ø	0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Fault Operations C Ø	0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Fault Operations Ground	0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Follow-up Action Required?	n	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	General Comments		
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	General Comments		
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Maintenance Operations	0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Operations Counter	297	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	General Comments		
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	LTC Current Tap Position	2L	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	LTC Max Tap Position	9L	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	LTC Min Tap Position	Neutral	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	LTC Operations Since Last Insp	909	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	LTCC000373	LTCControl	845-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	LTCC000373	LTCControl	845-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	LTCC000373	LTCControl	845-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	LTCC000373	LTCControl	845-1	LTC Control Insp	LTC Output Voltage Level	123.7	VAC
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	LTCC000373	LTCControl	845-1	LTC Control Insp	LTC Operation Checked?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	LTCC000373	LTCControl	845-1	LTC Control Insp	General Comments		
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	Follow-up Action Required?	n	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000206	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Bushing Condition	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Amps C Ø	360.0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Amps B Ø	400.0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Amps A Ø	400.0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	Follow-up Action Required?	n	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	General Comments		
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	General Comments		
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	9 Month Operations	5	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	LTC Totalizer Reading	14752.80	kw
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	Oil Temp Max	55	°C
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	Oil Temp Present	55	°C
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	Positive DC Ground	20.0	VDC
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.0	VDC
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	General Comments		
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	32	°F
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.8	amps
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	General Comments		
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	BCH001362	Charger	681-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	BCH001362	Charger	681-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000206	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Fault Operations A Ø	0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Fault Operations B Ø	0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Fault Operations C Ø	0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Fault Operations Ground	0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Follow-up Action Required?	n	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Foundation Condition	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	General Comments		
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	General Comments		
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Grounds in Place?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Maintenance Operations	0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Operations Counter AF	204	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Operations Counter AL	204	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Operations This Read Vac	0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Switching Operations	0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Tank Paint Condition	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Unknown Operations	0	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000206	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000206	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000206	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000206	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000206	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Unknown Operations	0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Tank Paint Condition	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Switching Operations	0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Operations This Read Vac	0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Operations Counter AL	184	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Operations Counter AF	184	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Maintenance Operations	0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Grounds in Place?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	General Comments		
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	General Comments		
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Foundation Condition	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Follow-up Action Required?	n	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Fault Operations Ground	0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Fault Operations C Ø	0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Fault Operations B Ø	0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Fault Operations A Ø	0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Amps A Ø	100.0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Amps B Ø	0.0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Amps C Ø	100.0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Fault Operations A Ø	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Fault Operations B Ø	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Fault Operations C Ø	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Fault Operations Ground	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Follow-up Action Required?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	General Comments	IOC A, B and C phase. B phase current meter not reading correctly, Actual counter	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Maintenance Operations	0	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Operations Counter	73	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	General Comments		
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Amps C Ø	88.0	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Amps B Ø	81.0	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Amps A Ø	67.0	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Grounds in Place?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Maintenance Operations	0	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Operations Counter AF	168	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Operations Counter AL	168	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Operations This Read Vac	0	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Switching Operations	0	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Tank Paint Condition	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Unknown Operations	0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Maintenance Operations	0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Grounds in Place?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	General Comments		
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	General Comments		
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Foundation Condition	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Follow-up Action Required?	n	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Fault Operations Ground	0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Fault Operations C Ø	0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Fault Operations B Ø	0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Fault Operations A Ø	0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Bushing Condition	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Amps C Ø	620.0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Amps B Ø	640.0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Amps A Ø	620.0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	9 Month Operations	1	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	9 Months Operations	11	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	Totalizer Meter Reading	.4848	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	General Comments		
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	General Comments		
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Ambient Temp	32	*F
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	General Comments		
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Vegetation	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	General Comments		
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	9 Month Operations	2	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Amps A Ø	731.0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Amps B Ø	749.0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Amps C Ø	729.0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Bushing Condition	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Fault Operations A Ø	0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Fault Operations B Ø	0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Fault Operations C Ø	0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Fault Operations Ground	0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Follow-up Action Required?	n	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Foundation Condition	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	General Comments		
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	General Comments		
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Grounds in Place?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Maintenance Operations	0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Operations Counter AF	211	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Operations Counter AL	211	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Operations This Read Vac	1	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Switching Operations	1	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Tank Paint Condition	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Unknown Operations	0	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	General Comments		
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	General Comments		
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	LTC Totalizer Reading	4654.08	kw
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	Oil Temp Max	45	°C
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	Oil Temp Present	30	°C
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Fault Operations A Ø	0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Fault Operations B Ø	0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Fault Operations C Ø	0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Fault Operations Ground	0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Follow-up Action Required?	n	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Foundation Condition	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	General Comments		
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	General Comments		
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Grounds in Place?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Maintenance Operations	0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Unknown Operations	0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Switching Operations	1	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Operations This Read Vac	1	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Operations Counter AL	99947	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Operations Counter AF	99947	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Amps B Ø	111.0	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Amps C Ø	106.0	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Bushing Condition	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Operations Counter AF	267	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Operations Counter AL	267	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Operations This Read Vac	1	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Switching Operations	1	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Tank Paint Condition	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Unknown Operations	0	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	LTC Totalizer Reading	5765.76	kw
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	Oil Temp Max	48	°C
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	Oil Temp Present	30	°C
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	Totalizer Meter Reading	.6006	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	LTC Max Tap Position	11L	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	LTC Current Tap Position	1L	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	LTC As Left Counter	28728	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	LTC As Found Counter	28724	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	General Comments		
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	General Comments		
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	Follow-up Action Required?	n	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	9 Month Operations	2	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	General Comments		
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	LTCC000713	LTCControl	611-1	LTC Control Insp	All Connections OK?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	LTCC000713	LTCControl	611-1	LTC Control Insp	Follow-up Action Required?	n	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	LTCC000713	LTCControl	611-1	LTC Control Insp	General Comments		
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	LTCC000713	LTCControl	611-1	LTC Control Insp	LTC Operation Checked?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	LTCC000713	LTCControl	611-1	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	LTCC000713	LTCControl	611-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	LTCC000713	LTCControl	611-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	LTCC000713	LTCControl	611-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	LTCC000714	LTCControl	611-2	LTC Control Insp	All Connections OK?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	LTCC000714	LTCControl	611-2	LTC Control Insp	Follow-up Action Required?	n	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	LTCC000714	LTCControl	611-2	LTC Control Insp	General Comments		
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	LTCC000714	LTCControl	611-2	LTC Control Insp	LTC Operation Checked?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	LTCC000714	LTCControl	611-2	LTC Control Insp	LTC Output Voltage Level	123.7	VAC
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	LTCC000714	LTCControl	611-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	LTCC000714	LTCControl	611-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	LTCC000714	LTCControl	611-2	LTC Control Insp	VRR Time Delay	30	Seconds
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	9 Month Operations	1	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Amps A Ø	99.0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Follow-up Action Required?	n	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Fault Operations Ground	0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Fault Operations C Ø	0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Fault Operations B Ø	0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Fault Operations A Ø	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Unknown Operations	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Switching Operations	6	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Operations This Read AM	6	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Operations Counter AL	252	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Readings	Operations Counter AF	252	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BCH000580	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BCH000580	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BCH000580	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BCH000580	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.1	amps
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BCH000580	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BCH000580	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BCH000580	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	General Comments		
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	General Comments		
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	LTC Totalizer Reading	5227.20	kw
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Bushing Condition	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Amps C Ø	17.0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Amps B Ø	0.0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Amps A Ø	22.0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	9 Month Operations	1	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	Oil Temp Max	47	°C
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	Oil Temp Present	30	°C
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	Totalizer Meter Reading	.7260	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Fault Operations B Ø	0	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Fault Operations C Ø	0	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Fault Operations Ground	0	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Follow-up Action Required?	n	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Foundation Condition	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	General Comments		
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	General Comments		
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	9 Month Operations	22	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Amps A Ø	112.0	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Amps B Ø	99.0	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Amps C Ø	103.0	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Bushing Condition	Good	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Fault Operations A Ø	0	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Fault Operations A Ø	0	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Fault Operations B Ø	0	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Fault Operations C Ø	0	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Fault Operations Ground	0	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Follow-up Action Required?	n	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Foundation Condition	Good	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	General Comments		
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	General Comments		
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Grounds in Place?	y	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Maintenance Operations	0	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Operations Counter AF	367	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Operations Counter AL	367	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Operations This Read Vac	0	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Switching Operations	0	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Tank Paint Condition	Good	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Unknown Operations	0	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	40	°C
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	38	°C
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	LTC Min Tap Position	4L	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	LTC Max Tap Position	11L	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	LTC Current Tap Position	5L	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	LTC As Left Counter	129336	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	LTC As Found Counter	129332	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	General Comments		
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	Winding Temp Present	0	°C
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	Winding Temp Max	0	°C
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	Totalizer Meter Reading	.8807	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	Oil Temp Present	30	°C
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	38	°C
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	38	°C
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	LTC Operations Since Last Insp	1005	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	Oil Temp Max	65	°C
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	LTC Totalizer Reading	4227.36	kw
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	General Comments		
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	General Comments		
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Vegetation	None	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	General Comments		
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Operations Counter	92	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	Follow-up Action Required?	n	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	General Comments		
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	General Comments		
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	LTC As Found Counter	50830	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	LTC As Left Counter	50835	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	LTC Current Tap Position	3R	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	LTC Max Tap Position	5R	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	LTC Min Tap Position	10L	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	LTC Operations Since Last Insp	1046	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Fault Operations B Ø	0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Fault Operations C Ø	0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Fault Operations Ground	0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Follow-up Action Required?	n	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Foundation Condition	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	General Comments		
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	General Comments		
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Grounds in Place?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Maintenance Operations	0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Operations Counter AF	250	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Operations Counter AL	250	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Operations This Read Vac	0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Switching Operations	0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Tank Paint Condition	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Unknown Operations	0	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	General Comments		
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	Follow-up Action Required?	n	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	General Comments		
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	General Comments		
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	Follow-up Action Required?	n	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Mechanism Patrol Inspection	General Comments		
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	LTC As Found Counter	231355	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	LTC As Left Counter	231360	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	LTC Current Tap Position	1L	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	LTC Max Tap Position	7L	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	LTC Min Tap Position	Neutral	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	LTC Operations Since Last Insp	304	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	9 Month Operations	1	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Amps A Ø	274.0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Amps B Ø	260.0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Amps C Ø	265.0	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Bushing Condition	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	LTCC000788	LTCControl	681-1	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	LTCC000788	LTCControl	681-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	LTCC000788	LTCControl	681-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000266	LTCControl	799-2	LTC Control Insp	All Connections OK?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000266	LTCControl	799-2	LTC Control Insp	Follow-up Action Required?	n	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000266	LTCControl	799-2	LTC Control Insp	General Comments		
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000266	LTCControl	799-2	LTC Control Insp	LTC Operation Checked?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000266	LTCControl	799-2	LTC Control Insp	LTC Output Voltage Level	124.6	VAC
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000266	LTCControl	799-2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000266	LTCControl	799-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000266	LTCControl	799-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000266	LTCControl	799-2	LTC Control Insp	VRR Time Delay	30	Seconds
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	LTCC000788	LTCControl	681-1	LTC Control Insp	VRR Time Delay	30	Seconds
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	Winding Temp Present	38	°C
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	Winding Temp Max	38	°C
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	Totalizer Meter Reading	.7512	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Vegetation	None	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	General Comments		
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Amps B Ø	36.0	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Amps A Ø	53.0	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	140.0	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	General Comments		
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	4	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	140.0	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	140.0	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	133	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	133	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Amps C Ø	55.0	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	LTCC000788	LTCControl	681-1	LTC Control Insp	All Connections OK?	y	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	LTCC000788	LTCControl	681-1	LTC Control Insp	Follow-up Action Required?	n	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	LTCC000788	LTCControl	681-1	LTC Control Insp	General Comments		
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	LTCC000788	LTCControl	681-1	LTC Control Insp	LTC Operation Checked?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	General Comments		
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	General Comments		
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	General Comments		
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	General Comments		
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	Follow-up Action Required?	n	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	General Comments		
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Ambient Temp	32	°F
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	Oil Temp Present	38	°C
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	Oil Temp Max	38	°C
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	LTC Totalizer Reading	13521.60	kw
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	General Comments		
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Ambient Temp	32	*F
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Ambient Temp	32	*F
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Clear of Trash?	y	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	General Comments		
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Vegetation	None	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/1/2020 17:58	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Amps A Ø	115.0	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Amps B Ø	102.0	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Amps C Ø	101.0	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Fault Operations Ground	0	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	General Comments		
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Operations Counter	31	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	General Comments		
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Tank Leaks	None	
12/1/2020 17:41	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	9 Month Operations	20	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Amps A Ø	78.0	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Amps B Ø	75.0	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Amps C Ø	53.0	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Bushings Connection/Risers	Good	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Cabinet Paint Condition	Good	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Equipment Properly Labeled?	y	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Unknown Operations	0	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Tank Paint Condition	Good	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Follow-up Action Required?	n	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Foundation Condition	Good	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	General Comments		
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	General Comments		
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Grounds in Place?	y	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Heaters (All) Functioning?	y	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Maintenance Operations	0	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Moisture and Leak Free?	y	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Operations Counter AF	279	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Operations Counter AL	279	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Operations This Read Vac	0	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Switching Operations	0	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Fault Operations C Ø	0	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
12/1/2020 17:14	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Fault Operations B Ø	0	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
12/1/2020 17:26	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Fault Operations A Ø	0	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	General Comments		
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Switching Operations	0	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Operations This Read Vac	0	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Operations Counter AL	306	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Operations Counter AF	306	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Maintenance Operations	0	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Grounds in Place?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	General Comments		
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	General Comments		
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Foundation Condition	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Follow-up Action Required?	n	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Fault Operations Ground	0	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Fault Operations C Ø	0	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Fault Operations B Ø	0	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Fault Operations A Ø	0	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	General Comments		
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	CAP000015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	CAP000015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Current Tap Position	1L	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	CAP000015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	CAP000015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Capacitor Condition	Good	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Operations Counter AF	37	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Operations Counter AL	37	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Operations This Read Vac	0	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	CAP000015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	CAP000015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Bushing Condition	Good	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	CAP000015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	All Connections OK?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Max Tap Position	16R	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Min Tap Position	9L	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Switching Operations	0	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Unknown Operations	0	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Amps C Ø	12.0	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Bushing Condition	Good	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Unknown Operations	0	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Unknown Operations	0	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Switching Operations	0	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Maintenance Operations	0	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Counter Readings	General Comments		
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Mechanism Patrol Inspection	General Comments		
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Fault Operations B Ø	0	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Fault Operations A Ø	0	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	General Comments	barbwire rusty ,large gap in back of lot, and back right post is washed out. Limbs and weeds starting to grow through the fence.	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Counter Readings	LTC As Found Counter	253008	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Counter Readings	LTC As Left Counter	253019	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Counter Readings	LTC Current Tap Position	4L	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Bushing Condition	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Counter Readings	LTC Max Tap Position	6R	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Counter Readings	LTC Min Tap Position	12L	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	2.0	psi
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Counter Readings	LTC Operations Since Last Insp	814	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Counter Readings	Follow-up Action Required?	n	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Counter Readings	General Comments		
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Mechanism Patrol Inspection	General Comments		
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Counter Readings	LTC As Found Counter	718873	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Counter Readings	LTC As Left Counter	718885	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	9 Month Operations	0	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Amps C Ø	120.0	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Amps B Ø	120.0	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Counter Readings	LTC Current Tap Position	3L	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Counter Readings	LTC Max Tap Position	2L	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Counter Readings	LTC Min Tap Position	12L	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Counter Readings	LTC Operations Since Last Insp	986	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Amps A Ø	68.0	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Amps B Ø	84.0	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Amps C Ø	82.0	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Amps B Ø	12.0	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Amps A Ø	12.0	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Grounds in Place?	y	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	General Comments	amp gauges isnt working	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	General Comments		
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Foundation Condition	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	FE000081	Fence	314-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Follow-up Action Required?	n	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Fault Operations Ground	0	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Operations This Read Vac	0	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Operations Counter AL	46	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Operations Counter AF	46	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Fault Operations C Ø	0	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Fault Operations B Ø	0	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Fault Operations A Ø	0	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Maintenance Operations	0	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Grounds in Place?	y	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	General Comments		
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Foundation Condition	Good	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Follow-up Action Required?	n	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Fault Operations Ground	0	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Fault Operations C Ø	0	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Fault Operations A Ø	0	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Fault Operations B Ø	0	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Bushing Condition	Good	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Amps C Ø	5.0	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Counter Readings	Follow-up Action Required?	n	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	M0089	LTCMechanism	844-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Readings	Totalizer Meter Reading	.2664	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Readings	Oil Temp Max	32	°C
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	319.68	kw
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.8	psi
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Readings	General Comments		
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Maintenance Operations	0	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Operations Counter AF	192	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Operations Counter AL	193	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Operations This Read Vac	3	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Switching Operations	3	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Unknown Operations	0	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	General Comments		
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	LTCC000803	LTCControl	795-1	LTC Control Insp	VRR Time Delay	45	Seconds
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	LTCC000803	LTCControl	795-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	LTCC000803	LTCControl	795-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	LTCC000803	LTCControl	795-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	LTCC000803	LTCControl	795-1	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	LTCC000803	LTCControl	795-1	LTC Control Insp	LTC Operation Checked?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Min Tap Position	8L	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Regulator As Left Counter	12854	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Tank Leaks	None	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Fault Operations A Ø	0	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Fault Operations B Ø	0	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Fault Operations C Ø	0	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Fault Operations Ground	0	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Follow-up Action Required?	n	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Foundation Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	General Comments		
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	General Comments		
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Grounds in Place?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	General Comments		
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	FE000174	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	General Comments		
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	CAP000015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	CAP000015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Tank Leaks	None	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	CAP000015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	CAP000015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Grounds in Place?	y	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	CAP000015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	General Comments	not hooked up to anything	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	CAP000015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	CAP000015	CapacitorBank	503-Cap Bank	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	General Comments	Cross arm that holds the metering has termite damage	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	General Comments		
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	9 Month Operations	9	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Amps A Ø	180.0	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Amps B Ø	180.0	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Readings	Amps C Ø	120.0	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Bushing Condition	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0180	BreakerVacuum	844-0278	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	LTCC000803	LTCControl	795-1	LTC Control Insp	General Comments		
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	LTCC000803	LTCControl	795-1	LTC Control Insp	Follow-up Action Required?	n	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	LTCC000803	LTCControl	795-1	LTC Control Insp	All Connections OK?	y	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	LTCC000186	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	60	Seconds
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	LTCC000186	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	LTCC000186	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Trash Emptied?	y	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	General Comments		
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	CH000435	ControlHouse	795-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	LTCC000186	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	LTCC000186	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	LTCC000186	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	ST000180	Structure	844-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	n	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	General Comments		
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	LTCC000186	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	LTCC000186	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	BAT001472	Battery	844-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	BAT001472	Battery	844-Battery Bank	Battery Patrol Inspection	General Comments		
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	BAT001472	Battery	844-Battery Bank	Battery Patrol Inspection	Negative DC Ground	.3	VDC
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	BAT001472	Battery	844-Battery Bank	Battery Patrol Inspection	Positive DC Ground	1.0	VDC
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	BAT001472	Battery	844-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	BAT001472	Battery	844-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	BCH001413	Charger	844-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.500	millivolts

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	BCH001413	Charger	844-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	BCH001413	Charger	844-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	BCH001413	Charger	844-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	BCH001413	Charger	844-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Unknown Operations	0	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Switching Operations	1	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Operations This Read Vac	2	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Operations Counter AL	187	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Operations Counter AF	187	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Switching Operations	1	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Operations This Read Vac	3	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Operations Counter AL	229	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Operations Counter AF	229	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Maintenance Operations	2	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Grounds in Place?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	General Comments		
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	General Comments		
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Operations Counter	143	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Maintenance Operations	0	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Tank Leaks	None	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Readings	Oil Temp Present	58	°C
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	B0239	NonLTC	314-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Tank Leaks	None	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Readings	Oil Temp Max	79	°C
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	9 Month Operations	3	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Readings	Winding Temp Max	39	°C
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Readings	LTC Totalizer Reading	7908.48	kw
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Readings	General Comments		
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	General Comments		
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Readings	Winding Temp Present	26	°C
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	BAT001472	Battery	844-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	BAT001472	Battery	844-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	40	°F
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	BAT001472	Battery	844-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	BAT001472	Battery	844-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	BAT001472	Battery	844-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	BAT001472	Battery	844-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	BAT001472	Battery	844-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	BAT001472	Battery	844-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	346674	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	8L	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	5R	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	1R	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	General Comments		
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Fault Operations Ground	0	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Fault Operations C Ø	0	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Fault Operations B Ø	0	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Fault Operations A Ø	1	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Fault Adjusted Amps A Phase V	6.13	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Bushing Condition	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Amps C Ø	22.0	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Amps B Ø	79.0	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Amps A Ø	67.0	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	9 Month Operations	4	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Amps A Ø	180.0	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Amps B Ø	180.0	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Amps C Ø	180.0	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Bushing Condition	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Grounds in Place?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	General Comments	1 AG	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	General Comments		
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Foundation Condition	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Readings	Follow-up Action Required?	n	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	BK000735	BreakerVacuum	844-0276	VCB Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	General Comments		
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Foundation Condition	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Follow-up Action Required?	n	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Fault Operations Ground	0	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Fault Operations C Ø	0	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Fault Operations B Ø	0	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	BCH001413	Charger	844-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Fault Operations A Ø	0	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	BCH001413	Charger	844-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	BCH001413	Charger	844-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	313669	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	8L	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	3R	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	Neutral	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1163	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1162	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	5R	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Amps A Ø	120.0	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	9 Month Operations	1	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Readings	Totalizer Meter Reading	.4746	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	7L	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	321315	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	General Comments		
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Operations Counter AF	247	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	M0095	LTCMechanism	503-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	Acceptable Building Appearance?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	Control House Lighting OK?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	Evidence of Insects	None	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	Floor Swept?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	General Comments		
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	Trash Emptied?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	CH000240	ControlHouse	Retired Distribution	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	General Comments		
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	General Comments		
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Fault Operations C Ø	0	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Fault Operations Ground	0	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Follow-up Action Required?	n	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Foundation Condition	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	General Comments		
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	General Comments		
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	VCB Patrol Inspection	Grounds in Place?	y
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Maintenance Operations	0	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Readings	Oil Temp Present	25	°C
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1164	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	2R	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	9 Month Operations	1	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	LTCC000765	LTCControl	844-1	LTC Control Insp	VRR Time Delay	45	Seconds
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	LTCC000765	LTCControl	844-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	General Comments		
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	LTCC000765	LTCControl	844-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	LTCC000765	LTCControl	844-1	LTC Control Insp	LTC Output Voltage Level	123.3	VAC
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Operations Counter	15	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Regulator As Left Counter	11841	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Tank Leaks	None	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000153	Regulator	795-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Current Tap Position	1R	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	LTCC000765	LTCControl	844-1	LTC Control Insp	LTC Operation Checked?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	LTCC000765	LTCControl	844-1	LTC Control Insp	General Comments		
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	LTCC000765	LTCControl	844-1	LTC Control Insp	Follow-up Action Required?	n	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	LTCC000765	LTCControl	844-1	LTC Control Insp	All Connections OK?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	55.00	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	Totalizer Meter Reading	.0030	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Readings	Unknown Operations	0	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0148	BreakerVacuum	844-2	VCB Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	M0061	WithLTC	795-1	LTC Transformer Readings	Totalizer Meter Reading	.8238	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	General Comments		
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Max Tap Position	8R	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Min Tap Position	8L	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000154	Regulator	795-2 C	Regulator Patrol Inspection	Regulator As Left Counter	12854	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	Seeping	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	General Comments	leakage from radiator, nitrogen -1 psi. Both pumps impellers making noise bank 2 (closest to entrance gate) is worse more investigati	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Operations Counter AL	247	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Operations This Read Vac	0	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Switching Operations	0	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0178	BreakerVacuum	844-0279	VCB Readings	Unknown Operations	0	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	LTC Totalizer Reading	14.40	kw
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	Oil Temp Max	42	°C
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	Oil Temp Present	25	°C
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	General Comments		
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Recloser Heaters Functioning?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	RC000019	RecloserElectronic	314-0736	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	ST000111	Structure	795-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	FE000179	Fence	503-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Amps B Ø	5.0	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Amps A Ø	5.0	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Readings	Oil Temp Present	48	°C
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Readings	Oil Temp Max	63	°C
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Readings	LTC Totalizer Reading	4170.24	kw
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Readings	General Comments		
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	General Comments		
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?		
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	Totalizer Meter Reading	.8082	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	Winding Temp Max	55	°C
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	Winding Temp Present	20	°C
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	LTCC000663	LTCControl	704-1	LTC Control Insp	VRR Time Delay	60	Seconds
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	LTCC000663	LTCControl	704-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	LTCC000663	LTCControl	704-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	LTCC000663	LTCControl	704-1	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	LTCC000663	LTCControl	704-1	LTC Control Insp	LTC Operation Checked?	y	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	LTCC000663	LTCControl	704-1	LTC Control Insp	General Comments		
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	LTCC000663	LTCControl	704-1	LTC Control Insp	Follow-up Action Required?	n	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	LTCC000663	LTCControl	704-1	LTC Control Insp	All Connections OK?	y	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BCH001230	Charger	795-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.3	VDC
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BCH001230	Charger	795-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.200	millivolts
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Fault Operations A Ø	0	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Fault Operations B Ø	0	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Fault Operations C Ø	0	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Fault Operations Ground	0	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Follow-up Action Required?	n	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Foundation Condition	Good	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	General Comments	Bank on outside of fence starting to wash off.	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	YD000026	Yard	381-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	YD000026	Yard	381-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	YD000026	Yard	381-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	YD000026	Yard	381-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	YD000026	Yard	381-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	YD000026	Yard	381-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	YD000026	Yard	381-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	YD000026	Yard	381-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	YD000026	Yard	381-Yard	Yard Patrol Inspection	General Comments		
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	YD000026	Yard	381-Yard	Yard Patrol Inspection	Vegetation	None	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Fair	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	General Comments	Potholes coming into station , had water standing in them.	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Vegetation	None	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	General Comments		
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	General Comments		
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.1	psi
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1300	psi
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	7758.72	kw
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	Oil Temp Max	54	°C
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	Oil Temp Present	18	°C
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	General Comments		
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	General Comments		
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	15.84	kw
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	55.00	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Readings	Totalizer Meter Reading	.5792	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Readings	Switching Operations	0	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Current Tap Position	7L	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Switching Operations	0	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Unknown Operations	0	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	MX0464	RecloserHydraulic	381-0744	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	MX0464	RecloserHydraulic	381-0744	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	MX0464	RecloserHydraulic	381-0744	Recloser Hydraulic Patrol Inspection	Operations Counter	79	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	MX0464	RecloserHydraulic	381-0744	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	MX0464	RecloserHydraulic	381-0744	Recloser Hydraulic Patrol Inspection	General Comments		
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	MX0464	RecloserHydraulic	381-0744	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	MX0464	RecloserHydraulic	381-0744	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	MX0464	RecloserHydraulic	381-0744	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	Oil Temp Max	42	°C
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	Oil Temp Present	29	°C
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	Totalizer Meter Reading	.0066	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	MX0464	RecloserHydraulic	381-0744	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	MX0464	RecloserHydraulic	381-0744	Recloser Hydraulic Patrol Inspection	Amps A ∅	47.8	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	333	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	Vegetation	None	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	General Comments		
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	YD000106	Yard	795-Yard	Yard Patrol Inspection	Ambient Temp	32	*F
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	General Comments		
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	General Comments		
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Ambient Temperature	40	*F
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	BCH000222	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	BCH000222	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	BCH000222	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	BCH000222	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	BCH000222	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Readings	Fault Operations	0	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Readings	Follow-up Action Required?	n	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Foundation Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Readings	General Comments		
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	General Comments	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Grounds in Place?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Heaters (All) Functioning?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Readings	Maintenance Operations	0	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Readings	Num Operations Last 9 Months	1	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Readings	Operations Counter AF	78	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Readings	Operations Counter AL	78	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Readings	Operations This Read SF6	0	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	SF6 Pressure Pole 1	60	psi
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Grounds in Place?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Maintenance Operations	2	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Operations Counter AF	695	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Operations Counter AL	695	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Operations This Read Vac	2	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	SF6 Pressure Pole 2	60	psi
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	General Comments		
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	SF6 Pressure Pole 3	60	psi
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000805	BreakerSF6	795-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Counter Readings	LTC Operations Since Last Insp	1967	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Counter Readings	LTC Min Tap Position	4L	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Counter Readings	LTC Max Tap Position	15R	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Counter Readings	LTC Current Tap Position	8R	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Counter Readings	LTC As Left Counter	250730	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Counter Readings	LTC As Found Counter	250720	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Mechanism Patrol Inspection	General Comments		
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Counter Readings	General Comments		
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Counter Readings	Follow-up Action Required?	n	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	General Comments	Crossarm rotten and 2 poles rotten at the bottom	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Follow-up Action Required?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	General Comments		
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Readings	General Comments		
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	ST000087	Structure	314-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	189.12	kw
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	BAT000172	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	BAT000172	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	BAT000172	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	BAT000172	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	BAT000172	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	BAT000172	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	BAT000172	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	BAT000172	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	BAT000172	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	BAT000172	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	BAT000172	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	BAT000172	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	BAT000172	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	BAT000172	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Counter Readings	LTC Operations Since Last Insp	1638	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Counter Readings	LTC Min Tap Position	8L	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Counter Readings	LTC Max Tap Position	5R	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Counter Readings	LTC As Left Counter	55320	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Counter Readings	LTC As Found Counter	55309	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Mechanism Patrol Inspection	General Comments	has desicant filter	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Counter Readings	General Comments		
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Counter Readings	Follow-up Action Required?	n	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	General Comments		
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Trash Emptied?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	CH000027	ControlHouse	795-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	9 Month Operations	7	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Amps A Ø	40.0	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Amps B Ø	110.0	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Readings	Amps C Ø	110.0	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Bushing Condition	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0149	BreakerVacuum	844-0275	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	9 Month Operations	6	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	M0061	LTCMechanism	795-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Amps A Ø	20.0	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Amps B Ø	10.0	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Amps C Ø	30.0	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Bushing Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	General Comments		
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BCH001230	Charger	795-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BCH001230	Charger	795-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BCH001230	Charger	795-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BCH001230	Charger	795-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BCH001230	Charger	795-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.9	amps
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BCH001230	Charger	795-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.3	VDC
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Ambient Temp	37	*F
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	Ambient Temp	38	*F
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	TX000204	NonLTC	795-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Follow-up Action Required?	y	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	FE000031	Fence	381-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Readings	Oil Temp Max	42	°C
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Readings	Oil Temp Present	20	°C
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Fault Operations A Ø	0	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Fault Operations B Ø	0	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Fault Operations C Ø	0	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Fault Operations Ground	0	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Follow-up Action Required?	n	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Foundation Condition	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	General Comments		
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	General Comments		
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Grounds in Place?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Maintenance Operations	0	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Operations Counter AF	814	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	General Comments		
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	44	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	36	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	Amps C Ø	.8	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	48	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Operations Counter AL	814	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Operations This Read Vac	2	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Switching Operations	2	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	MB0150	BreakerVacuum	844-0277	VCB Readings	Unknown Operations	0	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Low	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	0929	NonLTC	381-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.2364	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	Vegetation	None	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	General Comments		
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	n	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	n	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	YD000081	Yard	314-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Bad	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.3	VDC
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BAT001287	Battery	795-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.0	VDC
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	12L	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	5R	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments	seals need fixed.	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	4L	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	n	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	General Comments		
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Current Tap Position	7L	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Amps A Ø	0.0	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	9 Month Operations	2	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Amps A Ø	296.0	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Amps B Ø	0.0	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Amps C Ø	0.0	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Amps B Ø	113.0	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Amps C Ø	372.0	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Fault Operations A Ø	0	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Fault Operations B Ø	0	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Fault Operations C Ø	0	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Fault Operations Ground	0	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Counter Readings	LTC Operations Since Last Insp	1455	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Counter Readings	LTC Min Tap Position	16R	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Counter Readings	LTC Max Tap Position	16R	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Counter Readings	LTC Current Tap Position	16R	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	General Comments		
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Max Tap Position	2L	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Min Tap Position	13L	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Regulator As Left Counter	406754	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R0862	Regulator	890-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	General Comments		
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Vegetation	None	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Current Tap Position	9L	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Counter Readings	LTC As Left Counter	224362	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Counter Readings	LTC As Found Counter	224354	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Mechanism Patrol Inspection	General Comments		
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Counter Readings	General Comments		
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Counter Readings	Follow-up Action Required?	n	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Switching Operations	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Unknown Operations	0	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	9 Month Operations	3	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R0649	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	227890	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Regulator As Left Counter	194951	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Panels Dusted?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Operations This Read Vac	1	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Switching Operations	1	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Unknown Operations	0	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	9 Month Operations	5	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	General Comments		
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	General Comments		
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Amps A Ø	14.0	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Amps B Ø	14.0	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Readings	Amps C Ø	16.0	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Bushing Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Readings	Follow-up Action Required?	n	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	General Comments		
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	FE000077	Fence	890-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Readings	General Comments		
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Readings	LTC Totalizer Reading	6834.24	kw
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Readings	Oil Temp Max	70	°C
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000926	BreakerVacuum	795-0289	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Current Tap Position	1R	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	General Comments		
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Max Tap Position	8R	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Follow-up Action Required?	n	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Operations Counter	270	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	General Comments		
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	General Comments	open	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Maintenance Operations	0	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Operations Counter AF	166	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Operations Counter AL	166	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Operations This Read Vac	1	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Switching Operations	1	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	M0089	WithLTC	844-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Fault Operations A Ø	0	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Fault Operations B Ø	0	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Fault Operations C Ø	0	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Fault Operations Ground	0	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Follow-up Action Required?	n	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Foundation Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	General Comments		
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000835	BreakerVacuum	795-BT1-2	VCB Readings	Unknown Operations	0	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	RG000152	Regulator	795-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	General Comments		
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	General Comments		
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Grounds in Place?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Maintenance Operations	0	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Operations Counter AF	188	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000925	BreakerVacuum	795-0288	VCB Readings	Operations Counter AL	188	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Readings	Totalizer Meter Reading	1.0308	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Readings	Oil Temp Present	30	°C
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Readings	Oil Temp Max	55	°C
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Readings	LTC Totalizer Reading	7421.76	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	B0362	WithLTC	844-1	LTC Transformer Readings	General Comments		
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Vegetation	None	
11/30/2020 13:55	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Max Tap Position	6L	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Min Tap Position	15L	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R0863	Regulator	890-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Current Tap Position	8L	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	General Comments		
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Max Tap Position	4L	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Min Tap Position	14L	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Regulator As Left Counter	364644	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/30/2020 14:18	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Amps A Ø	0.0	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Regulator As Left Counter	123092	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Max Tap Position	7L	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	General Comments		
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	FE000105	Fence	795-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1100	Regulator	314-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Amps B Ø	0.0	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Amps C Ø	0.0	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Bushing Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	191	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	333	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	7.6	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	10.4	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	10.6	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	MX0048	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	285	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	LTCC000878	LTCControl	844-2	LTC Control Insp	All Connections OK?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	LTCC000878	LTCControl	844-2	LTC Control Insp	Follow-up Action Required?	n	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	LTCC000878	LTCControl	844-2	LTC Control Insp	General Comments		
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	LTCC000878	LTCControl	844-2	LTC Control Insp	LTC Operation Checked?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	LTCC000878	LTCControl	844-2	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	LTCC000878	LTCControl	844-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	LTCC000878	LTCControl	844-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	LTCC000878	LTCControl	844-2	LTC Control Insp	VRR Time Delay	45	Seconds
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	General Comments		
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	9 Month Operations	2	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Amps A Ø	11.0	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Amps B Ø	12.0	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Amps C Ø	12.0	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Bushing Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Fault Operations A Ø	0	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Fault Operations B Ø	0	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Fault Operations C Ø	0	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Fault Operations Ground	0	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Follow-up Action Required?	n	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Foundation Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	General Comments		
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	General Comments		
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Grounds in Place?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Maintenance Operations	0	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Operations Counter AF	191	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Operations Counter AL	191	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Operations This Read Vac	0	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Switching Operations	0	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000833	BreakerVacuum	795-0290	VCB Readings	Unknown Operations	0	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	9 Month Operations	4	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/30/2020 11:00	Distribution	Roaring Fork Quarterly Inspection	ST000026	Structure	381-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Fault Operations A Ø	0	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Fault Operations B Ø	0	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Fault Operations C Ø	0	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Fault Operations Ground	0	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Follow-up Action Required?	n	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Foundation Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	General Comments		
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	General Comments	open	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Grounds in Place?	y	
11/30/2020 16:11	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Maintenance Operations	0	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Operations Counter AF	183	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Operations Counter AL	183	
11/30/2020 10:26	Distribution	Corbin US Steel Quarterly Inspection	BK000834	BreakerVacuum	795-0291	VCB Readings	Operations This Read Vac	1	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Ambient Temp	34	°F

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Readings	Totalizer Meter Reading	.7050	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Readings	Oil Temp Present	23	°C
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Readings	Oil Temp Max	38	°C
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	General Comments		
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Vegetation	None	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	YD000173	Yard	844-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
11/30/2020 11:30	Distribution	Corbin East Quarterly Inspection	B0362	LTCMechanism	844-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Readings	Non LTC Totalizer Reading	846.00	kw
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Readings	General Comments		
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	W0244	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	General Comments		
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Max Tap Position	1L	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Min Tap Position	11L	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/30/2020 12:00	Distribution	Hamer Quarterly Inspection	R1098	Regulator	314-1 C	Regulator Patrol Inspection	Regulator As Left Counter	293886	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Regulator As Left Counter	173008	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	General Comments		
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Readings	Amps C Ø	200.0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Readings	Amps B Ø	200.0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Readings	Amps A Ø	200.0	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Readings	9 Month Operations	19	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Amps C Ø	34.0	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Amps B Ø	39.0	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Amps A Ø	28.0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	General Comments	concrete foundation is crumbling in multiple places	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Foundation Condition	Crumbling	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Max Tap Position	5R	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	General Comments		
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Operations Counter	473	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	MX0492	RecloserHydraulic	881-0315	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Readings	Unknown Operations	0	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Current Tap Position	1R	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Readings	Switching Operations	1	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Readings	Operations This Read Vac	1	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	R0763	Regulator	881-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Readings	Fault Operations A Ø	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Readings	Fault Operations B Ø	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Readings	Fault Operations C Ø	0	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	ST000119	Structure	881-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Readings	Fault Operations Ground	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Readings	Follow-up Action Required?	n	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Readings	General Comments		
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Readings	Maintenance Operations	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Readings	Operations Counter AF	344	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Readings	Operations Counter AL	344	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Readings	Amps C Ø	0.0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Readings	Fault Adjusted Amps A Phase V	22.36	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Readings	Fault Adjusted Amps B Phase V	22.36	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Readings	Fault Adjusted Amps C Phase V	22.36	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Readings	Fault Operations A Ø	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Readings	Fault Operations B Ø	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Readings	Fault Operations C Ø	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Readings	Fault Operations Ground	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Readings	Follow-up Action Required?	n	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Readings	General Comments		
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Readings	Maintenance Operations	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Readings	Operations Counter AF	330	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Readings	Operations Counter AL	330	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Readings	Operations This Read Vac	2	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Readings	Switching Operations	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Readings	Unknown Operations	2	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Readings	9 Month Operations	3	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	ANN000107	Annunciator	FH-Annunciator Panel	Annunciator Patrol Inspection	Control House Alarm Audible?	y	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Readings	Amps A Ø	300.0	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Readings	Amps B Ø	300.0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Readings	Amps C Ø	300.0	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9700	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	9 Month Operations	12	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Unknown Operations	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Switching Operations	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Operations This Read Vac	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Operations Counter AL	329	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Operations Counter AF	329	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Maintenance Operations	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	General Comments		
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Follow-up Action Required?	n	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Fault Operations Ground	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Fault Operations C Ø	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Fault Operations B Ø	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Fault Operations A Ø	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	ANN000107	Annunciator	FH-Annunciator Panel	Annunciator Patrol Inspection	ESOC Received Alarm Test?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	ANN000107	Annunciator	FH-Annunciator Panel	Annunciator Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	ANN000107	Annunciator	FH-Annunciator Panel	Annunciator Patrol Inspection	General Comments		
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Amps C Ø	40.0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Amps B Ø	40.0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Amps A Ø	40.0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Ambient Temp	46	*F
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Current Tap Position	Neutral	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Readings	General Comments		
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	General Comments		
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	General Comments	fans are rusty, added 2 pounds of nitrogen	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2328.00	kw
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	96.00	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Readings	Oil Temp Max	51	°C
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	O0180	NonLTC	881-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Regulator As Left Counter	88208	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	ANN000107	Annunciator	FH-Annunciator Panel	Annunciator Patrol Inspection	All Lights Functioning?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Readings	9 Month Operations	7	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Readings	Amps A Ø	0.0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Readings	Amps B Ø	0.0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Amps C Ø	35.0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Amps B Ø	35.0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Amps A Ø	35.0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	9 Month Operations	3	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Operations Counter	6	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	General Comments		
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Unknown Operations	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Switching Operations	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Operations This Read Vac	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Operations Counter AL	172	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Operations Counter AF	172	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Maintenance Operations	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	General Comments		
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Follow-up Action Required?	n	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Fault Operations Ground	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Fault Operations C Ø	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Unknown Operations	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Switching Operations	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Operations This Read Vac	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Operations Counter AL	339	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Operations Counter AF	339	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Maintenance Operations	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	General Comments		
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Follow-up Action Required?	n	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Fault Operations Ground	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Fault Operations C Ø	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Fault Operations B Ø	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Fault Operations A Ø	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Amps C Ø	40.0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Amps B Ø	40.0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Amps A Ø	40.0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Readings	9 Month Operations	4	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Amps A Ø	33.0	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Amps B Ø	46.0	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Amps C Ø	49.0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Readings	9 Month Operations	1	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Amps A Ø	40.0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Amps B Ø	40.0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Amps C Ø	40.0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	FE000868	Fence	881-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	FE000868	Fence	881-Fence	Fence Patrol Inspection	General Comments	small tree has limbs overhanging fence in rear corner of station	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	FE000868	Fence	881-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	FE000868	Fence	881-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Readings	Fault Operations A Ø	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Readings	Fault Operations B Ø	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Readings	Fault Operations C Ø	0	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	FE000868	Fence	881-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	FE000868	Fence	881-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	FE000868	Fence	881-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	FE000868	Fence	881-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	FE000868	Fence	881-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	FE000868	Fence	881-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Readings	Fault Operations Ground	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Readings	Follow-up Action Required?	n	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Readings	General Comments		
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	FE000868	Fence	881-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	FE000868	Fence	881-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	FE000868	Fence	881-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	FE000868	Fence	881-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	FE000868	Fence	881-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Fault Operations A Ø	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Readings	Fault Operations B Ø	0	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	MX0313	RecloserElectronic	881-0316	Recloser Electronic Patrol Inspection	Tank Leaks	None	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Unknown Operations	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Switching Operations	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Readings	Maintenance Operations	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Readings	Operations Counter AF	334	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Readings	Operations Counter AL	334	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Readings	Operations This Read Vac	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Readings	Switching Operations	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Readings	Unknown Operations	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Operations This Read Vac	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Operations Counter AL	366	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Operations Counter AF	366	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Maintenance Operations	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	General Comments		
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Follow-up Action Required?	n	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Fault Operations Ground	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Fault Operations C Ø	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Fault Operations B Ø	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Fault Operations A Ø	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Switching Operations	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Amps A Ø	40.0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Amps B Ø	40.0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Amps A Ø	0.0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Amps B Ø	0.0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Amps C Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	General Comments		
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	9 Month Operations	2	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Unknown Operations	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Fault Operations A Ø	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Fault Operations B Ø	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Fault Operations C Ø	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Amps C Ø	40.0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Fault Operations Ground	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Follow-up Action Required?	n	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Fault Operations Ground	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Follow-up Action Required?	n	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	General Comments		
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Regulator As Left Counter	185068	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Fault Operations A Ø	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Fault Operations B Ø	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Fault Operations C Ø	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Fault Operations Ground	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Follow-up Action Required?	n	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	General Comments		
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Maintenance Operations	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Operations Counter AF	333	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Operations Counter AL	333	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Operations This Read Vac	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Switching Operations	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Unknown Operations	0	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Vegetation	None	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	General Comments		
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Maintenance Operations	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Operations Counter AF	175	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Operations Counter AL	175	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Operations This Read Vac	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Switching Operations	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Unknown Operations	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Amps A Ø	40.0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Amps B Ø	40.0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Amps C Ø	40.0	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	OR0051	Regulator	881-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Fault Operations A Ø	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	9 Month Operations	7	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Fault Operations B Ø	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Fault Operations C Ø	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Fault Operations Ground	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Readings	9 Month Operations	1	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	YD000115	Yard	881-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/25/2020 10:04	Distribution	Mill Creek KU Quarterly Inspection	OR0052	Regulator	881-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Follow-up Action Required?	n	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	General Comments		
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Maintenance Operations	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Operations Counter AF	352	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Operations Counter AL	352	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Readings	Operations This Read Vac	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	General Comments		
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LTCC000341	LTCControl	WT-TRANS 4	LTC Control Insp	Follow-up Action Required?	n	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LTCC000341	LTCControl	WT-TRANS 4	LTC Control Insp	General Comments		
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	9 Months Operations	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	PF000424	PowerFuse	WT-12KV TR 5 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	PF000424	PowerFuse	WT-12KV TR 5 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	General Comments	Fence fabric and some top rails are getting rusty. Fence is 6 foot tall.	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Gate Locks Functioning?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Panels Dusted?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Operations Counter AF	81	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Operations Counter AL	81	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Operations This Read AM	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Switching Operations	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Unknown Operations	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LTCC000341	LTCControl	WT-TRANS 4	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Tank Leaks	None	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Fault Operations B Ø	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Fault Operations A Ø	0	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Amps C Ø	154.0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Patrol Inspection	General Comments		
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	General Comments		
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Evidence of Insects	None	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Amps B Ø	106.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Amps A Ø	145.0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	General Comments		
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	9 Month Operations	2	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Amps A Ø	0.0	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Amps B Ø	0.0	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Amps C Ø	10.0	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Bushing Condition	Good	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Evidence of Insects	None	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Patrol Inspection	General Comments		
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	General Comments		
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Patrol Inspection	Grounds in Place?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Maintenance Operations	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Operations Counter AF	46	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Operations Counter AL	46	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Operations This Read Vac	1	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Switching Operations	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Unknown Operations	1	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	WLTCTr Dynamic Health	0.00	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	100.00	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	Totalizer Meter Reading	.6756	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	Oil Temp Present	36	°C
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	Oil Temp Max	72	°C
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	LTC Totalizer Reading	3242.88	kw
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	General Comments		
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	General Comments		
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	General Comments		
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Grounds in Place?	y	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Maintenance Operations	0	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Operations Counter AF	171	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	9 Month Operations	15	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Operations Counter AL	171	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Operations This Read Vac	0	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Switching Operations	0	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Tank Paint Condition	Good	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Panels Dusted?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Fault Adjusted Amps C Phase V	1.00	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Fault Adjusted Amps B Phase V	1.00	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Fault Adjusted Amps A Phase V	1.00	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Current Tap Position	Neutral	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	General Comments	station is offline	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Min Tap Position	8L	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Reg Operation Checked?	n	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	0.0	volts
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Regulator As Left Counter	158746	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Tank Leaks	None	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	R0958	Regulator	310-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	FE000082	Fence	715-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Fault Operations A Ø	0	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Fault Operations B Ø	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	PF000420	PowerFuse	WT-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Fault Operations C Ø	0	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Fault Operations Ground	0	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Follow-up Action Required?	n	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Readings	Follow-up Action Required?	n	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	PF000420	PowerFuse	WT-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	General Comments		
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	General Comments		
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	Foundation Condition	Good	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	PF000418	PowerFuse	WT-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	PF000418	PowerFuse	WT-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Patrol Inspection	Bushing Condition	Good	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Amps C Ø	191.0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Amps B Ø	189.0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Amps A Ø	173.0	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	BK000250	BreakerVacuum	534-0251	VCB Patrol Inspection	General Comments		
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	Follow-up Action Required?	n	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Fault Operations A Ø	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Fault Operations B Ø	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Fault Operations C Ø	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Fault Operations Ground	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	Follow-up Action Required?	n	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	General Comments		
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Mechanism Patrol Inspection	General Comments		
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	LTC As Found Counter	273285	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	General Comments		
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	Vegetation	None	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Follow-up Action Required?	n	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Patrol Inspection	General Comments		
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	General Comments		
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Maintenance Operations	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Operations Counter AF	914	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Operations Counter AL	914	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Operations This Read AM	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Switching Operations	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Unknown Operations	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	Oil Temp Present	35	°C
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	Oil Temp Max	65	°C
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	General Comments		
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	9 Month Operations	18	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Counter Readings	LTC Operations Since Last Insp	1508	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Counter Readings	LTC Min Tap Position	3L	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Counter Readings	LTC Max Tap Position	8R	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Counter Readings	LTC Current Tap Position	4R	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Counter Readings	LTC As Left Counter	43151	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Counter Readings	LTC As Found Counter	43143	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Mechanism Patrol Inspection	General Comments		
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Counter Readings	Follow-up Action Required?	n	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Counter Readings	Follow-up Action Required?	n	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	BAT000176	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	BAT000176	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	55	°F
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	BAT000176	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	BAT000176	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	9 Months Operations	7	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Amps A Ø	130.0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Amps B Ø	138.0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Amps C Ø	134.0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Fault Adjusted Amps C Phase AM	11.18	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Fault Operations A Ø	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Fault Operations B Ø	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Fault Operations C Ø	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Fault Operations Ground	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Follow-up Action Required?	n	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Patrol Inspection	General Comments		
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	General Comments	ARC sense A and C phase	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Maintenance Operations	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Operations Counter AF	882	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Operations Counter AL	882	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Unknown Operations	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Switching Operations	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Operations This Read AM	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Operations Counter AL	368	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Operations Counter AF	368	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Maintenance Operations	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	General Comments		
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Patrol Inspection	General Comments		
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Follow-up Action Required?	n	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Fault Operations Ground	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Fault Operations C Ø	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Fault Operations B Ø	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Fault Operations A Ø	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Amps C Ø	421.0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Amps B Ø	397.0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Amps A Ø	351.0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	9 Months Operations	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Operations This Read AM	1	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Switching Operations	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Unknown Operations	1	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	YD000083	Yard	715-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	X3 Winding Temp Present	40	°C
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	X3 Winding Temp Max	65	°C
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	X2 Winding Temp Present	32	°C
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	X2 Winding Temp Max	70	°C
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	X1 Winding Temp Present	35	°C
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	X1 Winding Temp Max	80	°C
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	9 Months Operations	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Amps A Ø	0.0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Amps B Ø	0.0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Amps C Ø	0.0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Fault Operations Ground	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Follow-up Action Required?	n	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Patrol Inspection	Foundation Condition	Good	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Ambient Temp	45	*F
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	General Comments		
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Vegetation	None	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	YD000084	Yard	534-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	Totalizer Meter Reading	0.0000	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	Totalizer Meter Multiplier	1800	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	General Comments		
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	Oil Temp Present	11	*C
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	Oil Temp Max	53	*C
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	Non LTC Totalizer Reading	0.00	kw
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	General Comments	station is offline	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	C0381	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	BCH000226	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	BCH000226	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	BCH000226	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	BCH000226	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	BCH000226	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	BAT000176	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	BAT000176	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	BAT000176	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	BAT000176	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	BAT000176	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	BAT000176	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	BAT000176	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	BAT000176	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	BAT000176	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	BAT000176	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	LTC As Left Counter	273285	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	LTC Current Tap Position	6L	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	LTC Max Tap Position	4R	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	LTC Min Tap Position	9L	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	LTC Operations Since Last Insp	669	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	ST000089	Structure	715-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	n	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	General Comments		
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	General Comments	Trans needs nitrogen	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	Oil Temp Max	60	°C
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	Oil Temp Present	30	°C
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	X1 Winding Temp Max	80	°C
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	X1 Winding Temp Present	30	°C
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	X2 Winding Temp Max	75	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	X2 Winding Temp Present	35	°C
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	X3 Winding Temp Max	70	°C
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	X3 Winding Temp Present	35	°C
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Amps A Ø	77.0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Amps B Ø	87.0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Amps C Ø	68.0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Patrol Inspection	Bushing Condition	Good	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Fault Adjusted Amps A Phase V	1.00	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Fault Adjusted Amps B Phase V	1.00	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Fault Adjusted Amps C Phase V	1.00	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Fault Operations A Ø	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Fault Operations B Ø	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001651	BreakerVacuum	WT-1153	VCB Readings	Fault Operations C Ø	0	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Regulator As Left Counter	77966	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Tank Leaks	None	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Unknown Operations	3	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Switching Operations	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Operations This Read AM	3	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Operations Counter AL	556	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Operations Counter AF	556	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Maintenance Operations	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	General Comments	ARC sense A and B phase	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Patrol Inspection	General Comments		
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Follow-up Action Required?	n	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Fault Operations Ground	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Fault Operations C Ø	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Fault Operations B Ø	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Fault Operations A Ø	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Fault Adjusted Amps C Phase AM	33.54	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Fault Adjusted Amps B Phase AM	33.54	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Fault Adjusted Amps A Phase AM	33.54	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Amps C Ø	151.0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Amps B Ø	179.0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Amps A Ø	150.0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Counter Readings	Follow-up Action Required?	n	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Counter Readings	General Comments		
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Mechanism Patrol Inspection	General Comments		
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Counter Readings	LTC As Found Counter	77360	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Counter Readings	LTC As Left Counter	77360	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	Fault Operations Ground	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	Follow-up Action Required?	n	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Patrol Inspection	Foundation Condition	Good	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Patrol Inspection	General Comments		
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	General Comments		
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Amps A Ø	77.0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Amps B Ø	87.0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Amps C Ø	68.0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Patrol Inspection	General Comments		
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	General Comments		
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Operations Counter AF	46	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Operations Counter AL	46	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Operations This Read AM	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Switching Operations	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Unknown Operations	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	9 Months Operations	3	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	General Comments	A few limbs starting to grow over the fence.	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	Operations This Read Vac	1	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	Operations Counter AL	55	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	Operations Counter AF	55	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	Maintenance Operations	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Patrol Inspection	Grounds in Place?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	98.0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	90.0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	89.0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	33	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	33	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	9 Months Operations	12	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Amps A Ø	84.0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Amps B Ø	89.0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Amps C Ø	133.0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Fault Adjusted Amps A Phase AM	55.90	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Fault Adjusted Amps B Phase AM	55.90	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Fault Adjusted Amps C Phase AM	55.90	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Fault Operations A Ø	0	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	0.0	volts
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Reg Operation Checked?	n	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Min Tap Position	8L	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Max Tap Position	2R	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	R0957	Regulator	310-2 B	Regulator Patrol Inspection	General Comments	station is offline	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Readings	Fault Operations A Ø	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Readings	Fault Adjusted Amps C Phase V	1.00	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Readings	Fault Adjusted Amps B Phase V	1.00	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Readings	Fault Adjusted Amps A Phase V	1.00	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Patrol Inspection	Bushing Condition	Good	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Readings	Amps C Ø	89.0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Readings	Amps B Ø	90.0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Readings	Amps A Ø	98.0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	55	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	55	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Tank Leaks	None	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001654	BreakerVacuum	WT-1209	VCB Readings	9 Month Operations	13	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	Unknown Operations	1	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	Switching Operations	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Operations Counter	55	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	General Comments		
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Patrol Inspection	Bushing Condition	Good	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	Amps C Ø	85.0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	Amps B Ø	92.0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	PF000423	PowerFuse	WT-STA SER NO 5	Disconnect Powerfuse Inspection	General Comments	ok	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	Amps A Ø	85.0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001653	BreakerVacuum	WT-1155	VCB Readings	9 Month Operations	16	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Unknown Operations	1	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Switching Operations	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Operations This Read Vac	1	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Operations Counter AL	33	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Operations Counter AF	33	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Maintenance Operations	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Patrol Inspection	Grounds in Place?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	General Comments		
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Patrol Inspection	General Comments		
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Follow-up Action Required?	n	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	119	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Fault Operations Ground	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	BK001652	BreakerVacuum	WT-1154	VCB Readings	Fault Operations C Ø	0	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	General Comments	station is offline	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Battery Load Check OK?	n	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps C Ø	0.0	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps A Ø	0.0	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps B Ø	0.0	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps C Ø	0.0	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Battery Load Check OK?	n	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps B Ø	0.0	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps A Ø	0.0	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Operations Counter	2681	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	General Comments	station is offline	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Operations Counter	5	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Tank Leaks	None	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	MX0303	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Unknown Operations	5	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Tank Leaks	None	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	MX0301	RecloserElectronic	951-Offline-Distribution	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Reg Operation Checked?	n	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	0.0	volts
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	PF000421	PowerFuse	WT-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	PF000421	PowerFuse	WT-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	ok	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	PF000422	PowerFuse	WT-12KV TR 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Regulator As Left Counter	125406	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	LTCC000656	LTCControl	534-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	LTCC000656	LTCControl	534-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	LTCC000656	LTCControl	534-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	LTCC000656	LTCControl	534-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	LTCC000656	LTCControl	534-1	LTC Control Insp	VRR Time Delay	60	Seconds
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	General Comments	Actual counter	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Maintenance Operations	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Operations Counter AF	751	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	PF000422	PowerFuse	WT-12KV TR 4 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	PF000423	PowerFuse	WT-STA SER NO 5	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Operations Counter AL	751	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Operations This Read AM	5	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Switching Operations	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LTO221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	583.0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	548.0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	573.0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	General Comments	station is offline	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	LTCC000656	LTCControl	534-1	LTC Control Insp	LTC Operation Checked?	y	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	LTCC000656	LTCControl	534-1	LTC Control Insp	General Comments		
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Min Tap Position	8L	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Fault Operations B Ø	0	
11/24/2020 14:59	Distribution	Gardner Quarterly Inspection	R0956	Regulator	310-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	LTCC000656	LTCControl	534-1	LTC Control Insp	Follow-up Action Required?	n	
11/24/2020 12:19	Distribution	Manchester Quarterly Inspection	LTCC000656	LTCControl	534-1	LTC Control Insp	All Connections OK?	y	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Patrol Inspection	General Comments		
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	119	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Fault Operations C Ø	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Fault Operations Ground	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Follow-up Action Required?	n	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	9	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	9	
11/30/2020 6:42	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Unknown Operations	1	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Switching Operations	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Operations This Read AM	1	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Operations Counter AL	99992	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Operations Counter AF	99992	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Maintenance Operations	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	General Comments		
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Amps A Ø	118.0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Amps B Ø	120.0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Amps C Ø	119.0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Fault Adjusted Amps A Phase AM	8.00	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Fault Adjusted Amps B Phase AM	8.00	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Fault Adjusted Amps C Phase AM	8.00	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Fault Operations A Ø	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Fault Operations B Ø	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Fault Operations C Ø	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Fault Operations Ground	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Readings	9 Months Operations	15	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0472	BreakerAirMagnetic	S-Offline Distribution Breakers	AMCB Patrol Inspection	General Comments		
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Operations Counter AF	797	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	General Comments		
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	General Comments	barbed wire on front half of station is rusty	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Maintenance Operations	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Unknown Operations	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Switching Operations	0	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	X0073	RecloserHydraulic	800-0322	Recloser Hydraulic Patrol Inspection	Amps A Ø	46.3	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	X0073	RecloserHydraulic	800-0322	Recloser Hydraulic Patrol Inspection	Amps B Ø	51.7	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	X0073	RecloserHydraulic	800-0322	Recloser Hydraulic Patrol Inspection	Amps C Ø	53.4	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	X0073	RecloserHydraulic	800-0322	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	X0073	RecloserHydraulic	800-0322	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	X0073	RecloserHydraulic	800-0322	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	X0073	RecloserHydraulic	800-0322	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	X0073	RecloserHydraulic	800-0322	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	X0073	RecloserHydraulic	800-0322	Recloser Hydraulic Patrol Inspection	General Comments		
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	X0073	RecloserHydraulic	800-0322	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	X0073	RecloserHydraulic	800-0322	Recloser Hydraulic Patrol Inspection	Operations Counter	538	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Regulator As Left Counter	288777	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.1	volts
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Min Tap Position	14L	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Max Tap Position	6L	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	General Comments		
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Unknown Operations	2	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Switching Operations	0	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Current Tap Position	10L	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Operations This Read AM	2	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Operations Counter AL	797	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	X0073	RecloserHydraulic	800-0322	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Amps A Ø	0.0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Amps B Ø	0.0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Amps C Ø	0.0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Fault Operations A Ø	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Fault Operations B Ø	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Fault Operations C Ø	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Fault Operations Ground	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Unknown Operations	1	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Switching Operations	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Operations This Read Vac	1	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Operations Counter AL	184	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Operations Counter AF	184	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Maintenance Operations	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	General Comments		
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Patrol Inspection	General Comments		
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Amps A Ø	77.0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Amps B Ø	78.0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Follow-up Action Required?	n	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Amps C Ø	91.0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Patrol Inspection	General Comments		
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	General Comments		
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Maintenance Operations	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Fault Operations A Ø	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Fault Operations B Ø	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Follow-up Action Required?	n	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Fault Operations Ground	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Fault Operations C Ø	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Operations This Read AM	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Operations Counter AL	308	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Operations Counter AF	308	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	X0073	RecloserHydraulic	800-0322	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Amps B Ø	68.0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Amps A Ø	78.0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Accumulated Fault Duty C Ph V	2.15	%
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Accumulated Fault Duty B Ph V	2.87	%
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Accumulated Fault Duty A Ph V	2.15	%
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	9 Month Operations	15	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4824	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	9 Month Operations	123	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Amps A Ø	426.0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Amps B Ø	432.0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Amps C Ø	463.0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	9 Month Operations	3	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Accumulated Fault Duty A Ph V	.72	%
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0466	BreakerVacuum	HI-1103	VCB Readings	Accumulated Fault Duty B Ph V	2.15	%
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	9 Months Operations	6	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0476	BreakerAirMagnetic	HI-GND TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Fault Operations C Ø	0	
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	General Comments		
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Fault Operations Ground	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Follow-up Action Required?	n	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Patrol Inspection	General Comments		
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	General Comments	Actual counter	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Maintenance Operations	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Operations Counter AF	872	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Operations Counter AL	872	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Operations This Read Vac	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Switching Operations	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Unknown Operations	0	
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Amps C Ø	65.0	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Operations Counter	139	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	General Comments		
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Amps C Ø	2.1	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Amps B Ø	8.3	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Amps A Ø	.6	
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	BCH001092	Charger	HI-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	BCH001092	Charger	HI-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	80	°C
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	30	°C
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	55	°C
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	40	°C
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	65	°C
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	40	°C
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0259	GroundTransformer	HI-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0259	GroundTransformer	HI-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0259	GroundTransformer	HI-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0259	GroundTransformer	HI-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0259	GroundTransformer	HI-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0259	GroundTransformer	HI-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0259	GroundTransformer	HI-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0259	GroundTransformer	HI-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0259	GroundTransformer	HI-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	BCH001092	Charger	HI-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	BCH001092	Charger	HI-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	BCH001092	Charger	HI-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	7.8	amps
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	BCH001092	Charger	HI-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.6	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	BCH001092	Charger	HI-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.6	VDC
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Amps C Ø	5.0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Amps B Ø	4.0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Amps A Ø	4.0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	9 Months Operations	2	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Fault Operations B Ø	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Fault Operations A Ø	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Fault Operations B Ø	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Fault Operations C Ø	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Fault Operations Ground	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Follow-up Action Required?	n	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Patrol Inspection	General Comments		
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	General Comments		
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Maintenance Operations	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Operations Counter AF	767	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Operations Counter AL	767	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Operations This Read AM	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Switching Operations	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0473	BreakerAirMagnetic	HI-1474	AMCB Readings	Unknown Operations	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	General Comments		
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	General Comments	Trans needs nitrogen	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	H2 Winding Temp Max	75	°C
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	H2 Winding Temp Present	30	°C
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-5	psi
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	Oil Temp Max	55	°C
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	Oil Temp Present	30	°C
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Fault Operations A Ø	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0091	WithLTC	HI-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0465	BreakerVacuum	HI-1102	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	RC000166	RecloserHydraulic	800-0321	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Accumulated Fault Duty A Ph V	68.87	%
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	9 Month Operations	14	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	9 Months Operations	25	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Accumulated Fault Duty A Ph AM	3.8	%
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Amps A Ø	61.0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Amps B Ø	60.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Amps C Ø	57.0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Fault Adjusted Amps A Phase AM	16.00	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Fault Adjusted Amps B Phase AM	16.00	
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Follow-up Action Required?	y	
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Unknown Operations	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Switching Operations	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Operations This Read Vac	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Operations Counter AL	269	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Operations Counter AF	269	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Maintenance Operations	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	General Comments	Actual counter	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Patrol Inspection	General Comments		
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Fault Adjusted Amps C Phase AM	16.00	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Fault Operations A Ø	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Fault Operations B Ø	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Fault Operations C Ø	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Fault Operations Ground	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	Follow-up Action Required?	n	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Patrol Inspection	General Comments		
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Fault Operations Ground	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0470	BreakerVacuum	HI-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Ambient Temp	44	*F
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	General Comments		
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Vegetation	None	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	FE000567	Fence	HI-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	SWG000012	Switchgear	Hi Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0474	BreakerAirMagnetic	HI-1475	AMCB Readings	General Comments		
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	BCH001092	Charger	HI-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	3.200	millivolts
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	Vegetation	Needs Attention	
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	General Comments		
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	n	
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	n	
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	n	
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Bad	
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	Clear of Trash?	n	
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	General Comments		
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	General Comments		
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	ST000083	Structure	644-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	5.0	psi
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	Ambient Temp	38	°F
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1157.76	kw
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	217.50	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	200.00	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	Oil Temp Max	104	°C
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	Oil Temp Present	25	°C
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	General Comments	Fence is old, and looks rough	Large rock has rolled off the mountain and into the fence pushing it in toward the transformer
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Unknown Operations	2	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Switching Operations	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Operations This Read Vac	2	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Operations Counter AL	679	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Operations Counter AF	679	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Maintenance Operations	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	General Comments		
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Patrol Inspection	General Comments		
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Follow-up Action Required?	n	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Fault Operations Ground	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Fault Operations C Ø	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Fault Operations B Ø	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Fault Operations A Ø	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Fault Adjusted Amps C Phase V	22.36	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Fault Adjusted Amps B Phase V	22.36	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Fault Adjusted Amps A Phase V	22.36	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Amps C Ø	103.0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Amps B Ø	100.0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Amps A Ø	105.0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Accumulated Fault Duty C Ph V	57.39	%
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0468	BreakerVacuum	HI-1105	VCB Readings	Accumulated Fault Duty B Ph V	76.76	%
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	General Comments		
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Current Tap Position	6L	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	General Comments		
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	BAT000126	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	ST000576	Structure	HI-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	BAT000126	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	BAT000126	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	BAT000126	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	BAT000126	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	BAT000126	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	BAT000126	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	BAT000126	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	BAT000126	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	BAT000126	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	BAT000126	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	BAT000126	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	PF000164	PowerFuse	HI-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	PF000164	PowerFuse	HI-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	PF000163	PowerFuse	HI-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	PF000163	PowerFuse	HI-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	PF000162	PowerFuse	HI-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	PF000162	PowerFuse	HI-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	9 Months Operations	8	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Accumulated Fault Duty A Ph AM	1.9	%
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Accumulated Fault Duty B Ph AM	1.9	%
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Accumulated Fault Duty C Ph AM	2.85	%
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Amps A Ø	50.0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Operations Counter AF	215	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Operations Counter AL	215	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Operations This Read Vac	3	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Switching Operations	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	65	°C
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	45	°C
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Regulator As Left Counter	35756	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	122.8	volts
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Unknown Operations	3	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Counter Readings	LTC As Found Counter	191117	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Mechanism Patrol Inspection	General Comments	oil level low ltc	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Counter Readings	General Comments		
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	670	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Counter Readings	LTC Min Tap Position	13L	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Counter Readings	LTC Max Tap Position	3R	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Counter Readings	LTC Current Tap Position	11L	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Counter Readings	LTC As Left Counter	28615	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Counter Readings	LTC As Found Counter	28615	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Counter Readings	General Comments		
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0091	LTCMechanism	HI-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LTCC000432	LTCControl	HI-TRANS 1	LTC Control Insp	General Comments	ok	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LTCC000432	LTCControl	HI-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LTCC000598	LTCControl	HI-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LTCC000598	LTCControl	HI-TRANS 2	LTC Control Insp	General Comments	ok	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Min Tap Position	11L	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Regulator As Left Counter	305212	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.6	volts
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	13.20	kw
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Min Tap Position	14L	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Max Tap Position	5L	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	General Comments		
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Current Tap Position	10L	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	SWG000077	Switchgear	Hi Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	General Comments		
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Amps B Ø	46.0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Amps C Ø	51.0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Unknown Operations	3	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Switching Operations	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Operations This Read Vac	3	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Operations Counter AL	883	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Operations Counter AF	883	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Maintenance Operations	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	General Comments	Actual counter	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Patrol Inspection	General Comments		
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Follow-up Action Required?	n	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Fault Operations Ground	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Fault Operations C Ø	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Fault Operations B Ø	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Fault Operations A Ø	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Fault Adjusted Amps C Phase V	33.54	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Fault Adjusted Amps B Phase V	33.54	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Fault Adjusted Amps A Phase V	33.54	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Amps C Ø	97.0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Amps B Ø	92.0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Amps A Ø	80.0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Accumulated Fault Duty C Ph V	57.39	%
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Accumulated Fault Duty B Ph V	77.48	%
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	Accumulated Fault Duty A Ph V	89.68	%
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0467	BreakerVacuum	HI-1104	VCB Readings	9 Month Operations	12	
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Readings	Totalizer Meter Reading	.0330	
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	400	
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	PF000165	PowerFuse	HI-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	PF000165	PowerFuse	HI-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Chipped	
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Crumbling	
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	General Comments		
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Readings	General Comments		
11/23/2020 10:58	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Amps C Ø	103.0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Amps B Ø	104.0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Amps A Ø	90.0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Accumulated Fault Duty B Ph V	.72	%
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Accumulated Fault Duty A Ph V	2.15	%
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	9 Month Operations	8	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Counter Readings	LTC As Left Counter	191117	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Counter Readings	LTC Current Tap Position	5L	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4R	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Counter Readings	LTC Min Tap Position	7L	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Unknown Operations	0	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	General Comments		
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	557	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0092	LTCMechanism	HI-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	9 Months Operations	9	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Amps A Ø	226.0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Amps B Ø	278.0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Amps C Ø	227.0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Fault Operations B Ø	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Fault Operations C Ø	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Fault Operations Ground	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Follow-up Action Required?	n	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Patrol Inspection	General Comments		
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	General Comments		
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Maintenance Operations	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Operations Counter AF	431	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Operations Counter AL	431	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Operations This Read AM	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Switching Operations	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0475	BreakerAirMagnetic	HI-14KV TR 1	AMCB Readings	Unknown Operations	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Switching Operations	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Operations This Read AM	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Vegetation	None	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Operations Counter AL	793	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Operations Counter AF	793	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Maintenance Operations	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	General Comments		
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Patrol Inspection	General Comments		
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Follow-up Action Required?	n	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Fault Operations Ground	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Fault Operations C Ø	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Fault Operations B Ø	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Fault Operations A Ø	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0471	BreakerAirMagnetic	HI-1472	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	YD000576	Yard	HI-Yard	Yard Patrol Inspection	Ambient Temp	40	*F
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Readings	General Comments		
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	General Comments	Trans needs nitrogen	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Readings	Oil Temp Max	65	°C
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Readings	Oil Temp Present	45	°C
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/23/2020 12:55	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LT0092	WithLTC	HI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Fault Adjusted Amps B Phase V	33.54	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Fault Adjusted Amps C Phase V	33.54	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Fault Operations A Ø	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Fault Operations B Ø	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Fault Operations C Ø	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Fault Operations Ground	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Patrol Inspection	Follow-up Action Required?	n	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Follow-up Action Required?	n	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Patrol Inspection	General Comments		
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	General Comments	Arc Sense C Phase	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Maintenance Operations	0	
11/30/2020 6:39	Distribution	Highland Quarterly Inspection	LB0464	BreakerVacuum	HI-1101	VCB Readings	Fault Adjusted Amps A Phase V	33.54	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	LTCC000544	LTCControl	MC-Offline-Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallellIND	Position
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	LTCC000544	LTCControl	MC-Offline-Distribution	LTC Control Insp	General Comments		
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	LTCC000544	LTCControl	MC-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	PF000246	PowerFuse	MC-12KV TR 9 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	PF000246	PowerFuse	MC-12KV TR 9 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	PF000246	PowerFuse	MC-12KV TR 9 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	PF000342	PowerFuse	S-4KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	PF000342	PowerFuse	S-4KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LTCC000331	LTCControl	S-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallellIND	Position
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LTCC000331	LTCControl	S-TRANS 1	LTC Control Insp	General Comments		
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LTCC000331	LTCControl	S-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LTCC000330	LTCControl	S-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallellIND	Position
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LTCC000330	LTCControl	S-TRANS 2	LTC Control Insp	General Comments		
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LTCC000330	LTCControl	S-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Patrol Inspection	Equipment Properly Labeled?	y	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Patrol Inspection	Follow-up Action Required?	n	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LB0700	BreakerSF6	OK-1273	GCB Patrol Inspection	General Comments		
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Operations Counter AL	929	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Operations Counter AF	929	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Maintenance Operations	2	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	General Comments		
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Patrol Inspection	General Comments		
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Follow-up Action Required?	n	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Fault Operations Ground	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Fault Operations C Ø	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Fault Operations B Ø	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Fault Operations A Ø	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Amps C Ø Max	0.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Amps C Ø	0.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Amps B Ø Max	0.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	General Comments		
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Panels Dusted?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Trash Emptied?	n	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Panels Dusted?	y	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	General Comments		
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Evidence of Insects	None	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	General Comments		
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	9 Months Operations	3	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Ambient Temp	60	*F
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	SWG000108	Switchgear	MC-Swgr Sec 9	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	General Comments		
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	9 Months Operations	2	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	85	°C
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	PF000245	PowerFuse	MC-STA SER NO 9	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	PF000245	PowerFuse	MC-STA SER NO 9	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	PF000245	PowerFuse	MC-STA SER NO 9	Disconnect Powerfuse Inspection	General Comments	ok	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Patrol Inspection	Equipment Properly Labeled?	y	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Patrol Inspection	Follow-up Action Required?	n	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LB0699	BreakerSF6	OK-1272	GCB Patrol Inspection	General Comments		
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Amps A Ø	95.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Amps A Ø Max	0.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Amps B Ø	98.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Amps B Ø Max	0.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Amps C Ø	91.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Amps C Ø Max	0.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Fault Operations A Ø	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Fault Operations B Ø	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Fault Operations A Ø	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Fault Operations B Ø	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Fault Operations C Ø	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Fault Operations Ground	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Follow-up Action Required?	n	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Patrol Inspection	General Comments		
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	General Comments		
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Maintenance Operations	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Operations Counter AF	1130	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Operations Counter AL	1130	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Operations This Read AM	1	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Switching Operations	1	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	General Comments	cleaned up some trash in front of door,	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Unknown Operations	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Vegetation	None	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Amps C Ø Max	0.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Amps C Ø	60.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Amps B Ø Max	0.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Amps B Ø	40.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Amps A Ø Max	0.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Amps A Ø	60.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	65.0	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	66.0	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	64.0	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	3.96	%
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	11.87	%
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	32	°C
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	48	°C
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	29	°C
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	48	°C
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	29	°C
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	48	°C
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	14.5	%
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	3	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	General Comments		
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	300	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	Oil Temp Present	26	°C
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	Oil Temp Max	53	°C
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	25	°C
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	49	°C
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	General Comments	need nitrogen	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Readings	General Comments		
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LT0139	WithLTC	OK-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	300	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Fault Operations C Ø	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Fault Operations Ground	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Amps B Ø	0.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Amps A Ø Max	0.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Amps A Ø	0.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	9 Months Operations	6	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	40	°C
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	18.0	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	20.0	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	17.0	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	1.32	%
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	1.32	%
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	2.64	%
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0266	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	2	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Follow-up Action Required?	n	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Patrol Inspection	General Comments		
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	BAT001014	Battery	DE-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	1	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0268	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Fault Operations B Ø	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Fault Operations A Ø	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Amps C Ø Max	0.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Amps C Ø	84.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Amps B Ø Max	0.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	PF000341	PowerFuse	S-STA SER	Disconnect Powerfuse Inspection	General Comments	ok	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	PF000343	PowerFuse	S-4KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	PF000343	PowerFuse	S-4KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Amps B Ø	62.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Amps A Ø Max	0.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Amps A Ø	80.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	9 Months Operations	1	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	BCH001090	Charger	DE-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	BCH001090	Charger	DE-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	BCH001090	Charger	DE-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	BCH001090	Charger	DE-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	BCH001090	Charger	DE-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	4.4	amps
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	BCH001090	Charger	DE-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	BCH001090	Charger	DE-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	BCH001090	Charger	DE-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.400	millivolts
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	1	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	365	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	365	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0267	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Fault Operations Ground	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Fault Operations C Ø	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Fault Operations B Ø	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Fault Operations A Ø	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Amps C Ø Max	0.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Amps C Ø	113.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Amps B Ø Max	0.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Amps B Ø	98.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Amps A Ø Max	0.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Amps A Ø	34.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	9 Months Operations	4	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	PF000098	PowerFuse	DE-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	PF000098	PowerFuse	DE-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	PF000099	PowerFuse	DE-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	PF000099	PowerFuse	DE-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	ST000630	Structure	S-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	ST000630	Structure	S-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	ST000630	Structure	S-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	ST000630	Structure	S-Structure	Structure Patrol Inspection	General Comments		
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	ST000630	Structure	S-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	ST000630	Structure	S-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	General Comments		
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Follow-up Action Required?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	General Comments		
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Foundation Condition	Good	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	FE000650	Fence	OK-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	FE000650	Fence	OK-Fence	Fence Patrol Inspection	General Comments		
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	FE000650	Fence	OK-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	FE000650	Fence	OK-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	FE000650	Fence	OK-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	FE000650	Fence	OK-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	FE000650	Fence	OK-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	FE000650	Fence	OK-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	FE000650	Fence	OK-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Unknown Operations	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Switching Operations	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Unknown Operations	0	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Vegetation	None	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	General Comments		
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	YD000617	Yard	DE-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Unknown Operations	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Switching Operations	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Operations This Read AM	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Operations Counter AL	4991	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Operations Counter AF	4991	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Maintenance Operations	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	General Comments		
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Patrol Inspection	General Comments		
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Follow-up Action Required?	n	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Follow-up Action Required?	n	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Amps A Ø	93.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Amps A Ø Max	0.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Amps B Ø	86.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Amps B Ø Max	0.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Amps C Ø	61.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Amps C Ø Max	0.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Switching Operations	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Operations This Read AM	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Operations Counter AL	2559	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Operations Counter AF	2559	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Maintenance Operations	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	General Comments		
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Patrol Inspection	General Comments		
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Follow-up Action Required?	n	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Fault Operations Ground	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Fault Operations C Ø	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Fault Operations B Ø	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Fault Operations A Ø	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Amps C Ø Max	0.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Amps C Ø	0.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Amps B Ø Max	0.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Amps B Ø	0.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Amps A Ø Max	0.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Amps A Ø	0.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	9 Months Operations	1	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Fault Operations A Ø	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Fault Operations B Ø	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Fault Operations C Ø	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Fault Operations Ground	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Fault Operations C Ø	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Fault Operations B Ø	0	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	WithLTC	MC-TRANS 9	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	436	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	LTC Min Tap Position	15L	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1L	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	LTC Current Tap Position	5L	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	PF000337	PowerFuse	S-1378 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	PF000337	PowerFuse	S-1378 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Broom on Site?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Vegetation	None	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	General Comments		
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	LTC As Left Counter	97068	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	LTC As Found Counter	97068	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	General Comments		
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	9 Months Operations	8	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Unknown Operations	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Switching Operations	1	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Operations This Read AM	1	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Operations Counter AL	842	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Operations Counter AF	842	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Maintenance Operations	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	General Comments		
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Patrol Inspection	General Comments		
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	3159	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Fault Operations Ground	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	PF000336	PowerFuse	S-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	PF000335	PowerFuse	S-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	PF000335	PowerFuse	S-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	PF000263	PowerFuse	OK-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	PF000263	PowerFuse	OK-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	PF000263	PowerFuse	OK-12KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	PF000262	PowerFuse	OK-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	PF000262	PowerFuse	OK-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	PF000262	PowerFuse	OK-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Follow-up Action Required?	n	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Patrol Inspection	General Comments		
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	General Comments		
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Maintenance Operations	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Operations Counter AF	4506	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Operations Counter AL	4506	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Unknown Operations	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Switching Operations	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Operations This Read AM	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Operations Counter AL	391	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Operations Counter AF	391	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Maintenance Operations	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	General Comments		
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Patrol Inspection	General Comments		
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Follow-up Action Required?	n	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	PF000339	PowerFuse	S-1372 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	PF000339	PowerFuse	S-1372 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	PF000340	PowerFuse	S-1496 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	PF000340	PowerFuse	S-1496 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	PF000341	PowerFuse	S-STA SER	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Fault Operations Ground	0	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	YD000655	Yard	OK-Yard	Yard Patrol Inspection	Ambient Temp	54	*F
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	ST000634	Structure	OK-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Fault Operations A Ø	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Amps C Ø Max	0.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Amps C Ø	40.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Amps B Ø Max	0.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Amps B Ø	60.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Amps A Ø Max	0.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Amps A Ø	25.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	9 Months Operations	2	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	PF000338	PowerFuse	S-1308 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	PF000338	PowerFuse	S-1308 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	PF000336	PowerFuse	S-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	ANN000027	Annunciator	DE-Annunciator Panel	Annunciator Patrol Inspection	General Comments		
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	ANN000027	Annunciator	DE-Annunciator Panel	Annunciator Patrol Inspection	Follow-up Action Required?	n	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	ANN000027	Annunciator	DE-Annunciator Panel	Annunciator Patrol Inspection	Control House Alarm Audible?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	ANN000027	Annunciator	DE-Annunciator Panel	Annunciator Patrol Inspection	All Lights Functioning?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Counter Readings	General Comments		
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Counter Readings	LTC As Found Counter	415912	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Counter Readings	LTC As Left Counter	415912	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Counter Readings	LTC Current Tap Position	7L	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4R	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Counter Readings	LTC Min Tap Position	11L	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LTCM000068	LTCMechanism	DE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	General Comments	gutter is still on the fence	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Follow-up Action Required?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	n	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	FE000599	Fence	DE-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Fault Operations A Ø	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Fault Operations B Ø	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Fault Operations C Ø	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Fault Operations Ground	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Follow-up Action Required?	n	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Patrol Inspection	General Comments		
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	General Comments		
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Maintenance Operations	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	30	°C
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	9 Months Operations	0	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	1	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	1	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	657	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	657	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Operations Counter AF	354	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Operations Counter AL	354	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Operations This Read AM	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Switching Operations	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Unknown Operations	0	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Broom on Site?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	CH000182	ControlHouse	DE-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0262	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	LB0659	BreakerAirMagnetic	MC-Offline-Distribution	AMCB Readings	Amps A Ø	0.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Unknown Operations	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Switching Operations	1	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Operations This Read AM	1	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Operations Counter AL	527	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Operations Counter AF	527	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Maintenance Operations	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	General Comments		
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Patrol Inspection	General Comments		
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Follow-up Action Required?	n	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Fault Operations Ground	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Fault Operations C Ø	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Fault Operations B Ø	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Fault Operations A Ø	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Operations Counter AL	745	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Operations Counter AF	745	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Maintenance Operations	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	General Comments		
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Patrol Inspection	General Comments		
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Follow-up Action Required?	n	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Fault Operations Ground	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Fault Operations C Ø	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Fault Operations B Ø	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Fault Operations A Ø	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Amps C Ø Max	0.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Amps C Ø	0.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Amps B Ø Max	0.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Amps B Ø	0.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Amps A Ø Max	0.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Amps A Ø	0.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	9 Months Operations	2	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Operations This Read AM	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Switching Operations	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Unknown Operations	0	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Patrol Inspection	Equipment Properly Labeled?	y	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Patrol Inspection	Follow-up Action Required?	n	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LB0702	BreakerSF6	OK-1275	GCB Patrol Inspection	General Comments		
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	911	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Counter Readings	LTC Min Tap Position	10L	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1R	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Counter Readings	LTC Current Tap Position	9L	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Counter Readings	Follow-up Action Required?	n	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Counter Readings	General Comments		
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Mechanism Patrol Inspection	General Comments		
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Counter Readings	LTC As Found Counter	236206	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Counter Readings	LTC As Left Counter	236206	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Counter Readings	LTC Current Tap Position	7L	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Counter Readings	LTC Max Tap Position	5L	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	9 Months Operations	6	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Evidence of Insects	None	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Broom on Site?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	Oil Temp Max	60	°C
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	Oil Temp Present	35	°C
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Unknown Operations	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Switching Operations	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Operations This Read AM	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	60	°C
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	4	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	6.59	%
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	15.82	%
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0264	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	3.96	%
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Counter Readings	LTC Min Tap Position	7L	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Counter Readings	LTC Operations Since Last Insp	5677	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Counter Readings	LTC Tank Oil Level	Good	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	LT0132	LTCMechanism	MC-TRANS 9	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Counter Readings	LTC As Left Counter	108479	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Counter Readings	LTC As Found Counter	108479	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Counter Readings	General Comments		
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LT0139	LTCMechanism	OK-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	General Comments		
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	General Comments	tr needs nitro	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	SWG000088	Switchgear	OK-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Fault Operations A ∅	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Fault Operations B ∅	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Fault Operations C ∅	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Fault Operations Ground	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	507	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Counter Readings	LTC Min Tap Position	13L	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Counter Readings	LTC Max Tap Position	2L	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Counter Readings	LTC Current Tap Position	8L	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Counter Readings	LTC As Left Counter	10121	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Counter Readings	LTC As Found Counter	10121	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Counter Readings	General Comments		
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Follow-up Action Required?	n	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Patrol Inspection	General Comments		
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Readings	Fault Operations A Ø	0	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Readings	Fault Operations B Ø	0	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Readings	Fault Operations C Ø	0	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Readings	Fault Operations Ground	0	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Patrol Inspection	Follow-up Action Required?	n	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Readings	Follow-up Action Required?	n	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Patrol Inspection	General Comments		
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	BK001356	BreakerVacuum	MC-12KV TR 9	VCB Readings	General Comments		
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Operations This Read AM	2	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Switching Operations	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Unknown Operations	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	Amps A Ø	400.0	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	Amps B Ø	400.0	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	Amps C Ø	400.0	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Patrol Inspection	Equipment Properly Labeled?	y	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	Fault Operations	0	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Patrol Inspection	Follow-up Action Required?	n	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	Follow-up Action Required?	n	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Patrol Inspection	Gauge(s) Condition	Good	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Patrol Inspection	General Comments		
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	General Comments		
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	Maintenance Operations	0	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	Num Operations Last 9 Months	4	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	Operations Counter AF	318	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	Operations Counter AL	318	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	Operations This Read SF6	0	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	Switching Operations	0	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LB0704	BreakerSF6	OK-12KV TR 1	GCB Readings	Unknown Operations	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Readings	Oil Temp Max	50	°C
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	ST000604	Structure	DE-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	n	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	1.32	%
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	124.0	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	121.0	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	119.0	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	574	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	574	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	2	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	2	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0263	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Amps C Ø Max	0.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Fault Operations A Ø	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Fault Operations B Ø	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Fault Operations C Ø	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Fault Operations Ground	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Follow-up Action Required?	n	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Patrol Inspection	General Comments		
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	General Comments		
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Maintenance Operations	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Operations Counter AF	917	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Operations Counter AL	917	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Operations This Read AM	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Switching Operations	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Unknown Operations	0	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Patrol Inspection	Grounds in Place?	y	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Patrol Inspection	General Comments		
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Patrol Inspection	Follow-up Action Required?	n	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	9 Months Operations	1	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Operations Counter AL	398	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Operations This Read AM	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Switching Operations	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Unknown Operations	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Amps A Ø	90.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Amps A Ø Max	0.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Amps B Ø	72.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Amps B Ø Max	0.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Amps C Ø	0.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Amps B Ø Max	0.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Readings	General Comments		
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Unknown Operations	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Switching Operations	1	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Amps B Ø	0.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Amps A Ø Max	0.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Amps A Ø	0.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Operations This Read AM	1	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Operations Counter AL	418	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Operations Counter AF	418	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Maintenance Operations	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	General Comments		
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Patrol Inspection	General Comments		
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Follow-up Action Required?	n	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Amps C Ø	98.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Amps C Ø Max	0.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Operations Counter AF	11589	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Maintenance Operations	0	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	BK001354	BreakerVacuum	MC-1262	VCB Patrol Inspection	Bushing Condition	Good	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Patrol Inspection	Grounds in Place?	y	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Patrol Inspection	General Comments		
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Patrol Inspection	Follow-up Action Required?	n	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	9 Months Operations	1	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	BK001353	BreakerVacuum	MC-1261	VCB Patrol Inspection	Bushing Condition	Good	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	General Comments	tr needs nitro	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Fault Operations A Ø	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Fault Operations B Ø	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Fault Operations C Ø	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Fault Operations Ground	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	BCH001073	Charger	S-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.9	VDC
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	BCH001073	Charger	S-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.9	VDC
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	BCH001073	Charger	S-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.9	amps
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	BCH001073	Charger	S-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	BCH001073	Charger	S-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	BCH001073	Charger	S-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	BCH001073	Charger	S-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	BCH001073	Charger	S-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	CH000193	ControlHouse	OK-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Patrol Inspection	Follow-up Action Required?	n	
12/20/2020 15:21	Distribution	Okolona Quarterly Inspection	LB0701	BreakerSF6	OK-1274	GCB Patrol Inspection	General Comments		
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	SWG000080	Switchgear	DE-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Unknown Operations	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Switching Operations	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Operations This Read AM	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Operations Counter AL	11589	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	1	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	1	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	734	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LB0265	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	734	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Amps C Ø Max	0.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Fault Operations A Ø	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Fault Operations B Ø	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Fault Operations C Ø	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Fault Operations Ground	0	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Follow-up Action Required?	n	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Patrol Inspection	Bushing Condition	Good	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Readings	Amps C Ø	20.0	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Readings	Amps B Ø	20.0	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Readings	Amps A Ø	20.0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Patrol Inspection	General Comments		
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Readings	9 Month Operations	1	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Readings	Accumulated Fault Duty A Ph V	0	%
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Readings	Accumulated Fault Duty B Ph V	0	%
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	General Comments		
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Maintenance Operations	0	
11/20/2020 14:12	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Operations Counter AF	398	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	BK001355	BreakerVacuum	MC-1264	VCB Readings	Accumulated Fault Duty C Ph V	0	%
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Readings	9 Month Operations	8	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Readings	Amps A Ø	219.0	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Readings	Amps B Ø	169.0	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Readings	Amps C Ø	186.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Readings	Fault Operations A Ø	0	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Readings	Fault Operations B Ø	0	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Readings	Fault Operations C Ø	0	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Readings	Fault Operations Ground	0	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Readings	Follow-up Action Required?	n	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Readings	General Comments		
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Readings	Maintenance Operations	0	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Readings	Operations Counter AF	196	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Readings	Operations Counter AL	196	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Readings	Operations This Read Vac	2	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Readings	Switching Operations	2	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Readings	Unknown Operations	0	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Patrol Inspection	Bushing Condition	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Patrol Inspection	Foundation Condition	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Patrol Inspection	General Comments		
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Patrol Inspection	Grounds in Place?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001282	BreakerVacuum	496-1759	VCB Patrol Inspection	Tank Paint Condition	Good	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	BCH001035	Charger	HE-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Current Tap Position	9L	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	General Comments		
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Min Tap Position	15L	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	310	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Unknown Operations	0	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Counter Readings	LTC Current Tap Position	5L	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4L	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	11	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Counter Readings	LTC Min Tap Position	6L	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	2136	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.5	volts
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Regulator As Left Counter	124260	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	19	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	5	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Counter Readings	LTC Min Tap Position	11L	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	99985	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Counter Readings	LTC Max Tap Position	6L	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Counter Readings	LTC Current Tap Position	6L	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Counter Readings	LTC As Left Counter	440758	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Counter Readings	LTC As Found Counter	440758	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	99985	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	140.0	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Counter Readings	General Comments		
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	160.0	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	19	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN46	LTCMechanism	HE-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	167	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	BCH001035	Charger	HE-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	BCH001035	Charger	HE-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Counter Readings	General Comments	Counter not working	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Mechanism Patrol Inspection	General Comments		
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Switching Operations	0	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Operations This Read AM	0	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Operations Counter AL	392	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Operations Counter AF	392	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	15	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	6	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	6	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Maintenance Operations	0	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	General Comments		
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	316	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	9 Months Operations	0	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Counter Readings	Follow-up Action Required?	n	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Patrol Inspection	General Comments		
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Follow-up Action Required?	n	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	Amps C \emptyset	120.0	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	Amps B \emptyset	120.0	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	Amps A \emptyset	120.0	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Fault Operations Ground	0	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Fault Operations C \emptyset	0	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Fault Operations B \emptyset	0	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Fault Operations A \emptyset	0	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0463	BreakerAirMagnetic	HE-SEC 2 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	BCH000978	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	BCH000978	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	BCH000978	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	BCH000978	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	BCH000978	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.1	VDC
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	BCH000978	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.1	VDC
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	BCH000978	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C \emptyset	0	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B \emptyset	0	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A \emptyset	0	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Fault Operations A \emptyset	0	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Fault Operations B \emptyset	0	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Fault Operations C \emptyset	0	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Fault Operations Ground	0	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Counter Readings	General Comments		
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Counter Readings	LTC As Found Counter	394574	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Counter Readings	LTC As Left Counter	394574	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Counter Readings	LTC Current Tap Position	4L	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Counter Readings	LTC Max Tap Position	Neutral	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Counter Readings	LTC Min Tap Position	9L	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN54	LTCMechanism	HE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Follow-up Action Required?	n	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	General Comments		
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	General Comments		
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Grounds in Place?	y	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Maintenance Operations	0	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Operations Counter AF	281	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Operations Counter AL	281	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Operations This Read Vac	2	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Counter Readings	LTC As Found Counter	272000	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	BCH001035	Charger	HE-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	BCH001035	Charger	HE-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.8	VDC
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Switching Operations	2	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Tank Paint Condition	Good	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Unknown Operations	0	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	BCH001035	Charger	HE-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.8	VDC
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	BCH001035	Charger	HE-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Counter Readings	LTC As Left Counter	323351	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Counter Readings	LTC As Found Counter	323351	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	MB0117	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0157	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	12.0	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	24.0	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Counter Readings	General Comments		
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	PN45	LTCMechanism	HA-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	13	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Counter Readings	LTC As Left Counter	272000	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Counter Readings	LTC Max Tap Position	6R	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Counter Readings	LTC Min Tap Position	12L	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Counter Readings	LTC Operations Since Last Insp	0	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	M0082	LTCMechanism	597-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	24.0	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	591	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	103	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	11	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	General Comments		
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	9 Months Operations	0	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Amps A Ø	90.0	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Amps B Ø	50.0	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Amps C Ø	130.0	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Fault Operations A Ø	0	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Fault Operations B Ø	0	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Fault Operations C Ø	0	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Follow-up Action Required?	n	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Patrol Inspection	General Comments		
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	General Comments		
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Maintenance Operations	0	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Operations Counter AF	380	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Operations Counter AL	380	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Operations This Read AM	0	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Switching Operations	0	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0460	BreakerAirMagnetic	HE-4	AMCB Readings	Unknown Operations	0	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	Totalizer Meter Reading	.0042	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Operations Counter AL	582	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Operations This Read AM	0	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Switching Operations	0	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Unknown Operations	0	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	Oil Temp Present	35	°C
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C ∅	0	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B ∅	0	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A ∅	0	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	Amps C ∅	200.0	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	Amps B ∅	200.0	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	Amps A ∅	120.0	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	Totalizer Meter Reading	.8570	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	A ∅ Operations Counter	142	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Amps A ∅	0.0	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Amps B ∅	0.0	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Amps C ∅	0.0	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Unknown Operations	0	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	General Comments		
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	°F

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Tank Paint Condition	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Switching Operations	1	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Operations This Read Vac	1	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Operations Counter AL	439	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Operations Counter AF	439	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Counter Readings	LTC Operations Since Last Insp	819	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Counter Readings	LTC Min Tap Position	13L	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Maintenance Operations	0	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Grounds in Place?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	General Comments		
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	General Comments		
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Foundation Condition	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Follow-up Action Required?	n	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Fault Operations Ground	0	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Fault Operations C Ø	0	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Fault Operations B Ø	0	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Fault Operations A Ø	0	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	Oil Temp Present	22	°C
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	Oil Temp Max	44	°C
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	71.00	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	5.04	kw
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	General Comments		
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	General Comments		
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Fans Operational?	n	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Counter Readings	Follow-up Action Required?	n	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Counter Readings	General Comments		
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Mechanism Patrol Inspection	General Comments		
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Counter Readings	LTC As Found Counter	12867	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Counter Readings	LTC As Left Counter	12876	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	BCH001061	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	BCH001061	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	BCH001061	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	BCH001061	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	BCH001061	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	BCH001061	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.120	millivolts
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Counter Readings	LTC Current Tap Position	3L	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Counter Readings	LTC Max Tap Position	5R	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Counter Readings	LTC Min Tap Position	10L	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Counter Readings	LTC Operations Since Last Insp	1329	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	M0096	LTCMechanism	780-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	BAT001100	Battery	350-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Fault Operations Ground	0	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Follow-up Action Required?	n	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Foundation Condition	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	General Comments		
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	General Comments		
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Grounds in Place?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Maintenance Operations	0	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Operations Counter AF	64	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Operations Counter AL	64	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Operations This Read Vac	2	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Switching Operations	2	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Tank Paint Condition	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Unknown Operations	0	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	General Comments		
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Readings	Totalizer Meter Reading	.6156	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.9	volts
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Regulator As Left Counter	50258	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000172	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	9 Month Operations	13	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Amps A Ø	240.0	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Amps B Ø	260.0	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	General Comments		
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	122.7	volts
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Regulator As Left Counter	43790	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0068	Regulator	350-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0069	Regulator	350-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Amps C Ø	260.0	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Bushing Condition	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Fault Operations A Ø	0	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Fault Operations B Ø	0	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0075	BreakerVacuum	020-2543	VCB Readings	Fault Operations C Ø	0	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	LTC000172	LTCControl	932-Offline Distribution	LTC Control Insp	All Connections OK?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Amps A Ø	110.0	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Amps B Ø	150.0	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Amps C Ø	100.0	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	304	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	299	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Fault Operations A Ø	0	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Fault Operations B Ø	0	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Fault Operations C Ø	0	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Fault Operations Ground	0	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Follow-up Action Required?	n	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Patrol Inspection	General Comments		
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	General Comments		
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	General Comments		
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	General Comments		
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	LTC Totalizer Reading	6170.40	kw
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	Oil Temp Max	66	°C
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Maintenance Operations	0	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Operations Counter AF	582	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Readings	Oil Temp Present	48	°C
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Readings	Oil Temp Max	48	°C
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Readings	LTC Totalizer Reading	5909.76	kw
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Readings	General Comments		
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	General Comments		
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Readings	Follow-up Action Required?	n	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	M0082	WithLTC	597-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	9 Months Operations	0	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	M0096	WithLTC	780-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	5	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0158	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	5	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000172	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000172	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0457	BreakerAirMagnetic	HE-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000172	LTCControl	932-Offline Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000172	LTCControl	932-Offline Distribution	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000172	LTCControl	932-Offline Distribution	LTC Control Insp	LTC Operation Checked?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000172	LTCControl	932-Offline Distribution	LTC Control Insp	General Comments		
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000172	LTCControl	932-Offline Distribution	LTC Control Insp	Follow-up Action Required?	n	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	Ambient Temp	56	*F
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	General Comments		
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	Vegetation	None	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	YD000002	Yard	602-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	General Comments		
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	LTCC000674	LTCControl	602-1	LTC Control Insp	General Comments		
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	LTCC000674	LTCControl	602-1	LTC Control Insp	Follow-up Action Required?	n	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	LTCC000674	LTCControl	602-1	LTC Control Insp	All Connections OK?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	General Comments		
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	ST000001	Structure	350-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	Totalizer Meter Reading	.7974	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	Oil Temp Present	48	°C
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	Oil Temp Max	48	°C
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	Non LTC Totalizer Reading	3827.52	kw
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Readings	General Comments		
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	C0388	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	General Comments	barbed wire is rusty and fence post	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0048	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	General Comments	added nitrogen from -1psi to 1psi	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Readings	General Comments		
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	n	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	ST000005	Structure	602-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.1802	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	General Comments		
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	FE000006	Fence	602-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Readings	Oil Temp Present	37	°C
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Readings	Oil Temp Max	59	°C
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	O0190	NonLTC	350-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	5664.96	kw
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	9 Month Operations	18	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Amps A Ø	86.0	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Amps B Ø	76.0	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Readings	Amps C Ø	107.0	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Bushing Condition	Good	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	KB0078	BreakerVacuum	602-0308	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Vegetation	None	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	General Comments		
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	9 Month Operations	20	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Regulator As Left Counter	40032	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Counter Readings	LTC Max Tap Position	5L	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Counter Readings	LTC Current Tap Position	9L	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Counter Readings	LTC As Left Counter	82567	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Counter Readings	LTC As Found Counter	82567	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Counter Readings	General Comments		
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Counter Readings	Follow-up Action Required?	n	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	4R	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	151	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	151	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	Vegetation	None	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	General Comments		
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	YD000572	Yard	HE-Yard	Yard Patrol Inspection	Ambient Temp	50	*F
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	General Comments		
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	FE000563	Fence	HE-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	General Comments		
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	KR0070	Regulator	350-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Patrol Inspection	Bushing Condition	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Amps C Ø	140.0	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Amps B Ø	80.0	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	K0076	BreakerVacuum	020-2504	VCB Readings	Amps A Ø	120.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	237849	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	ST000850	Structure	124-Structure Distribution	Structure Patrol Inspection	All Identified and Legible?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	ST000850	Structure	124-Structure Distribution	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	ST000850	Structure	124-Structure Distribution	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	ST000850	Structure	124-Structure Distribution	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	ST000850	Structure	124-Structure Distribution	Structure Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	ST000850	Structure	124-Structure Distribution	Structure Patrol Inspection	Foundation Condition	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	ST000850	Structure	124-Structure Distribution	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	ST000850	Structure	124-Structure Distribution	Structure Patrol Inspection	General Comments		
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	ST000850	Structure	124-Structure Distribution	Structure Patrol Inspection	Ground Connections Intact?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	ST000850	Structure	124-Structure Distribution	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	ST000850	Structure	124-Structure Distribution	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	ST000850	Structure	124-Structure Distribution	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	ST000850	Structure	124-Structure Distribution	Structure Patrol Inspection	Operating Linkage OK?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	ST000850	Structure	124-Structure Distribution	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	ST000850	Structure	124-Structure Distribution	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	ST000850	Structure	124-Structure Distribution	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	ST000850	Structure	124-Structure Distribution	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	ST000850	Structure	124-Structure Distribution	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	ST000850	Structure	124-Structure Distribution	Structure Patrol Inspection	Wood Structures OK?	y	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	BCH001391	Charger	602-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.760	millivolts
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	BCH001391	Charger	602-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.3	VDC
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	BCH001391	Charger	602-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.3	VDC
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	BCH001391	Charger	602-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	BCH001391	Charger	602-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	BCH001391	Charger	602-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	BCH001391	Charger	602-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	BCH001391	Charger	602-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	SWG000071	Switchgear	HE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	LTCC000674	LTCControl	602-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	LTCC000674	LTCControl	602-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	LTCC000674	LTCControl	602-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	LTCC000674	LTCControl	602-1	LTC Control Insp	LTC Output Voltage Level	124.9	VAC
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	LTCC000674	LTCControl	602-1	LTC Control Insp	LTC Operation Checked?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	80.0	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	80.0	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	100.0	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	BAT001435	Battery	HA-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	BAT001435	Battery	HA-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	71	*F

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	BAT001435	Battery	HA-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	BAT001435	Battery	HA-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	BAT001435	Battery	HA-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	BAT001435	Battery	HA-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	BAT001435	Battery	HA-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	BAT001435	Battery	HA-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	DB0047	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	13	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	BAT001435	Battery	HA-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	BAT001435	Battery	HA-Battery Bank	Battery Patrol Inspection	General Comments		
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	BAT001435	Battery	HA-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	BAT001435	Battery	HA-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0877	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Fault Operations Ground	0	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Fault Operations C Ø	0	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Fault Operations B Ø	0	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Fault Operations A Ø	0	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Patrol Inspection	Bushing Condition	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Amps C Ø	243.0	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Amps B Ø	200.0	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Amps A Ø	215.0	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Amps B Ø	32.0	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Amps A Ø	19.0	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	9 Month Operations	12	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	9 Month Operations	48	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Unknown Operations	0	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Tank Paint Condition	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Switching Operations	1	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Operations This Read Vac	1	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Operations Counter AL	199	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Operations Counter AF	199	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Maintenance Operations	0	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Grounds in Place?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	General Comments		
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Patrol Inspection	General Comments		
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Patrol Inspection	Foundation Condition	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Follow-up Action Required?	n	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Amps C Ø	15.0	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	Ambient Temp	33	*F
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	9 Months Operations	1	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Amps A Ø	110.0	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Amps B Ø	180.0	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Amps C Ø	110.0	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Fault Operations A Ø	0	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Fault Operations B Ø	0	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Fault Operations C Ø	0	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Fault Operations Ground	0	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Follow-up Action Required?	n	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Patrol Inspection	General Comments		
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	General Comments		
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Maintenance Operations	0	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Operations Counter AF	397	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Operations Counter AL	397	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Operations This Read AM	0	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Switching Operations	0	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0428	BreakerAirMagnetic	HA-1	AMCB Readings	Unknown Operations	0	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	General Comments		
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	YD000001	Yard	350-Yard	Yard Patrol Inspection	Vegetation	None	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BCH000491	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.8	VDC
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BCH000491	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	52.8	VDC
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BCH000491	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.9	amps
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BCH000491	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BCH000491	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BCH000491	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	S0043	LTCMechanism	951-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	S0043	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	S0043	LTCMechanism	951-Offline-Distribution	LTC Counter Readings	General Comments		
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	S0043	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	S0043	LTCMechanism	951-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	21723	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	S0043	LTCMechanism	951-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	21733	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	S0043	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	S0043	LTCMechanism	951-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	Neutral	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	S0043	LTCMechanism	951-Offline-Distribution	LTC Counter Readings	LTC Max Tap Position	6R	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	S0043	LTCMechanism	951-Offline-Distribution	LTC Counter Readings	LTC Min Tap Position	12L	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	S0043	LTCMechanism	951-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	10	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	S0043	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	S0043	LTCMechanism	951-Offline-Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	S0043	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	50	°F
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Exp/Missing Not Repl	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	12.0	VDC
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	12.0	VDC
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BAT000377	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000591	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000591	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000591	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000591	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000591	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.3	VAC
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	General Comments		
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Foundation Condition	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Follow-up Action Required?	n	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Fault Operations Ground	0	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Fault Operations B Ø	0	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Fault Operations A Ø	0	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	CH000445	ControlHouse	HE-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	CH000445	ControlHouse	HE-Battery Control House	Control House Patrol Inspection	General Comments		
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	CH000445	ControlHouse	HE-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	CH000445	ControlHouse	HE-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	CH000445	ControlHouse	HE-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	CH000445	ControlHouse	HE-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	CH000445	ControlHouse	HE-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	CH000445	ControlHouse	HE-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	CH000445	ControlHouse	HE-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	CH000445	ControlHouse	HE-Battery Control House	Control House Patrol Inspection	Broom on Site?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Patrol Inspection	Bushing Condition	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Amps C Ø	150.0	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Amps B Ø	153.0	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Amps A Ø	140.0	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	KB0063	BreakerVacuum	197-BT5-6	VCB Readings	9 Month Operations	7	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000569	LTCControl	951-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000569	LTCControl	951-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000569	LTCControl	951-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000569	LTCControl	951-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000569	LTCControl	951-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000569	LTCControl	951-Offline-Distribution	LTC Control Insp	General Comments		
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000569	LTCControl	951-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000569	LTCControl	951-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	20.0	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	20.0	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	General Comments	counter not working	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	233	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	234	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	General Comments	Fence fabric and some barb wire a little rusty	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	*F
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	General Comments		
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	BAT001240	Battery	602-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Unknown Operations	0	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Tank Paint Condition	Good	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Switching Operations	2	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	BCH000026	Charger	HA-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	BCH000026	Charger	HA-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.8	VDC
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	BCH000026	Charger	HA-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.8	VDC
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	BCH000026	Charger	HA-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	BCH000026	Charger	HA-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	BCH000026	Charger	HA-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	BCH000026	Charger	HA-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Operations This Read Vac	2	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Counter Readings	Follow-up Action Required?	n	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0118	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	20.0	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Foundation Condition	Good	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Follow-up Action Required?	n	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Fault Operations Ground	0	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Fault Operations C Ø	0	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Fault Operations B Ø	0	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Fault Operations A Ø	0	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	SWG000008	Switchgear	HA-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Bushing Condition	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Unknown Operations	0	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Patrol Inspection	Tank Paint Condition	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Switching Operations	8	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Operations This Read Vac	8	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Operations Counter AL	201	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Operations Counter AF	201	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	Maintenance Operations	0	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Patrol Inspection	Grounds in Place?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	BK001336	BreakerVacuum	780-0355	VCB Readings	General Comments		
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Structure Patrol Inspection	General Comments	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Counter Readings	General Comments		
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Mechanism Patrol Inspection	General Comments		
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Counter Readings	LTC As Found Counter	19564	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Counter Readings	LTC As Left Counter	19572	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Counter Readings	LTC Current Tap Position	3L	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Counter Readings	LTC Max Tap Position	4R	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Counter Readings	LTC Min Tap Position	9L	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Counter Readings	LTC Operations Since Last Insp	1073	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	B0387	LTCMechanism	602-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Counter Readings	Follow-up Action Required?	n	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Counter Readings	General Comments		
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Mechanism Patrol Inspection	General Comments		
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Counter Readings	LTC As Found Counter	41725	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Counter Readings	LTC As Left Counter	41733	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Counter Readings	LTC Current Tap Position	7L	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Counter Readings	LTC Max Tap Position	2R	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Counter Readings	LTC Min Tap Position	13L	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Counter Readings	LTC Operations Since Last Insp	932	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	S0044	LTCMechanism	780-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Operations Counter AL	191	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Operations Counter AF	191	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	Maintenance Operations	0	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	Grounds in Place?	y	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Readings	General Comments		
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	BK001145	BreakerVacuum	602-0390	VCB Patrol Inspection	General Comments		
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Fault Operations C ∅	0	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Fault Operations Ground	0	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Follow-up Action Required?	n	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Patrol Inspection	General Comments		
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	General Comments	AB Phase IOC	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Maintenance Operations	0	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Operations Counter AF	517	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Operations Counter AL	517	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Operations This Read AM	2	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Switching Operations	0	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Unknown Operations	0	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	FE000561	Fence	HA-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Readings	Totalizer Meter Reading	.8750	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Readings	Oil Temp Present	33	°C
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Readings	Oil Temp Max	54	°C
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	B0387	WithLTC	602-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	Ambient Temp	46	°F
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	General Comments		
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	General Comments		
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Foundation Condition	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Follow-up Action Required?	n	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Fault Operations Ground	0	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Fault Operations C Ø	0	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Fault Operations B Ø	0	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Fault Operations A Ø	0	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Bushing Condition	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Amps C Ø	23.0	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Amps B Ø	39.0	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Amps A Ø	44.0	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	9 Month Operations	4	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	9 Months Operations	4	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Amps A Ø	170.0	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Amps B Ø	120.0	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Amps C Ø	130.0	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Fault Adjusted Amps A Phase AM	9.55	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Fault Adjusted Amps B Phase AM	9.55	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Fault Operations A Ø	1	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0429	BreakerAirMagnetic	HA-2	AMCB Readings	Fault Operations B Ø	1	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Readings	Oil Temp Present	26	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	CH000232	ControlHouse	350-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Readings	Totalizer Meter Reading	.2532	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	S0044	WithLTC	780-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Evidence of Insects	None	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Control House Lighting OK?	y	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Broom on Site?	n	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Acceptable Building Appearance?	y	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Current Tap Position	11L	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	General Comments	Counter not working	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Max Tap Position	8L	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Min Tap Position	15L	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Regulator As Left Counter	272822	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	9 Months Operations	0	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Amps A Ø	200.0	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Amps B Ø	250.0	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Amps C Ø	220.0	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000591	LTCCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	4L	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Panels Dusted?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	General Comments		
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	CH000371	ControlHouse	466-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000591	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000591	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	232121	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0878	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	General Comments		
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 13:59	Distribution	Meldrum Quarterly Inspection	CH000334	ControlHouse	602-Control house	Control House Patrol Inspection	Floor Swept?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	General Comments		
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	Vegetation	None	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	General Comments		
11/19/2020 10:11	Distribution	Rose Hill Quarterly Inspection	FE000001	Fence	350-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	PF001248	PowerFuse	MC-STA SER B 440V	Disconnect Powerfuse Inspection	General Comments	ok	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	PF001248	PowerFuse	MC-STA SER B 440V	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	PF001248	PowerFuse	MC-STA SER B 440V	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	PF001247	PowerFuse	MC-208/120 STA SER B	Disconnect Powerfuse Inspection	General Comments	ok	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	PF001247	PowerFuse	MC-208/120 STA SER B	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	PF001247	PowerFuse	MC-208/120 STA SER B	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	General Comments		
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	YD000570	Yard	HA-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Fault Operations A ∅	0	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Fault Operations B ∅	0	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Fault Operations C ∅	0	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Fault Operations Ground	0	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Follow-up Action Required?	n	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Patrol Inspection	General Comments		
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	General Comments		
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Maintenance Operations	0	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Operations Counter AF	854	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Operations Counter AL	854	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Operations This Read AM	0	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Switching Operations	0	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0459	BreakerAirMagnetic	HE-3	AMCB Readings	Unknown Operations	0	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000821	LTCControl	780-3	LTC Control Insp	VRR Time Delay	30	Seconds
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000821	LTCControl	780-3	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Unknown Operations	0	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Tank Paint Condition	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Switching Operations	1	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Operations This Read Vac	1	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Operations Counter AL	192	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Operations Counter AF	191	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Readings	Maintenance Operations	0	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	BK000891	BreakerVacuum	780-0360	VCB Patrol Inspection	Grounds in Place?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000821	LTCControl	780-3	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000821	LTCControl	780-3	LTC Control Insp	LTC Output Voltage Level	123.8	VAC
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000821	LTCControl	780-3	LTC Control Insp	LTC Operation Checked?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000821	LTCControl	780-3	LTC Control Insp	General Comments		
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000821	LTCControl	780-3	LTC Control Insp	Follow-up Action Required?	n	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	LTCC000821	LTCControl	780-3	LTC Control Insp	All Connections OK?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	ST000048	Structure	780-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Maintenance Operations	0	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Operations Counter AF	361	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Operations Counter AL	361	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Operations This Read AM	0	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Switching Operations	0	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Unknown Operations	0	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Readings	General Comments		
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Readings	LTC Totalizer Reading	8363.52	kw
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Readings	Oil Temp Max	51	*C
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Readings	Oil Temp Present	39	*C
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Readings	Totalizer Meter Reading	.8712	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	30.00	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	S0043	WithLTC	951-Offline-Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	General Comments		
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	CH000459	ControlHouse	HA-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	CH000459	ControlHouse	HA-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	CH000459	ControlHouse	HA-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	Ambient Temp	51	*F
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	CH000459	ControlHouse	HA-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	CH000459	ControlHouse	HA-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	CH000459	ControlHouse	HA-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	PF000244	PowerFuse	MC-STA SER A 440V	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	PF000244	PowerFuse	MC-STA SER A 440V	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	PF000244	PowerFuse	MC-STA SER A 440V	Disconnect Powerfuse Inspection	General Comments	ok	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	PF000247	PowerFuse	MC-208/120 STA SER A	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	PF000247	PowerFuse	MC-208/120 STA SER A	Disconnect Powerfuse Inspection	General Comments	ok	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	SWG000011	Switchgear	HE-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	9 Month Operations	9	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	Amps A Ø	180.0	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	Amps B Ø	160.0	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	Amps C Ø	120.0	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	40.0	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	9 Months Operations	1	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Amps A Ø	250.0	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Amps B Ø	50.0	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Amps C Ø	200.0	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Fault Operations A Ø	0	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Fault Operations C Ø	0	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Fault Operations Ground	0	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	Follow-up Action Required?	n	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Patrol Inspection	General Comments		
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	LB0430	BreakerAirMagnetic	HA-3	AMCB Readings	General Comments		
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	BAT001290	Battery	HE-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Fault Operations B Ø	0	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Fault Operations A Ø	0	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	General Comments		
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	General Comments		
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	Maintenance Operations	0	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	Operations Counter AF	669	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	9 Months Operations	0	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	Operations Counter AL	673	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	Operations This Read Vac	4	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	Switching Operations	4	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Readings	Unknown Operations	0	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	78	°C
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	78	°C
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	72	°C
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Readings	Oil Temp Max	63	°C
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Readings	General Comments		
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	PN45	WithLTC	HA-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	CH000459	ControlHouse	HA-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	CH000459	ControlHouse	HA-Battery Control House	Control House Patrol Inspection	General Comments		
11/19/2020 20:03	Distribution	Hale Quarterly Inspection	CH000459	ControlHouse	HA-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0153	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	General Comments		
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	General Comments		
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	Vegetation	None	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	YD000045	Yard	780-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	Oil Temp Present	26	°C
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	-60	°C
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	-60	°C
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	-60	°C
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	-60	°C
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	-60	°C
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN54	WithLTC	HE-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	-60	°C
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Unknown Operations	0	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Switching Operations	0	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Operations This Read AM	0	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Operations Counter AL	383	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Operations Counter AF	383	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Maintenance Operations	0	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	General Comments		
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Patrol Inspection	General Comments		
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Follow-up Action Required?	n	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Fault Operations Ground	0	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	BK000263	BreakerAirMagnetic	HE-SEC 1 SPARE	AMCB Readings	Fault Operations C ∅	0	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Readings	Winding Temp Max	36	°C
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Reading	1.1990	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Present	26	°C
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Max	39	°C
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Readings	LTC Totalizer Reading	3836.80	kw
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Switching Operations	0	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Unknown Operations	0	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000735	LTCCControl	597-1	LTC Control Insp	All Connections OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000735	LTCControl	597-1	LTC Control Insp	Follow-up Action Required?	n	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000735	LTCControl	597-1	LTC Control Insp	General Comments		
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000735	LTCControl	597-1	LTC Control Insp	LTC Operation Checked?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Readings	General Comments		
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000735	LTCControl	597-1	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000735	LTCControl	597-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000735	LTCControl	597-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	LTCC000735	LTCControl	597-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	3R	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	General Comments		
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	FE000048	Fence	780-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Max Tap Position	3L	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Min Tap Position	15L	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Regulator As Left Counter	131704	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	174	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	170	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Amps C Ø	120.0	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Amps B Ø	140.0	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Amps A Ø	160.0	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	9 Months Operations	0	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	3R	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	3R	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	199950	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	R0879	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	O0182	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	O0182	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	O0182	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	O0182	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Operations Since Last Insp	502	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	O0182	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	O0182	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Min Tap Position	7L	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	O0182	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Max Tap Position	7L	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	O0182	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Current Tap Position	Neutral	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Fault Operations A Ø	0	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Fault Operations B Ø	0	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Fault Operations C Ø	0	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Fault Operations Ground	0	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Follow-up Action Required?	n	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Patrol Inspection	General Comments		
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	General Comments		
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Maintenance Operations	0	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	O0182	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	O0182	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Left Counter	415235	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Operations Counter AF	404	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Operations Counter AL	404	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	LB0458	BreakerAirMagnetic	HE-2	AMCB Readings	Operations This Read AM	0	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Current Tap Position	9L	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	O0182	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Found Counter	415225	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	O0182	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	O0182	LTCMechanism	932-Offline Distribution	LTC Counter Readings	General Comments		
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	O0182	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	O0182	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Follow-up Action Required?	n	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	30	°C
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	73	°C
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
11/19/2020 10:58	Distribution	Middlesboro 1 Quarterly Inspection	O0182	WithLTC	932-Offline Distribution	LTC Transformer Readings	Winding Temp Present	24	°C
11/20/2020 10:05	Distribution	Mill Creek Switching Quarterly Inspection	PF000247	PowerFuse	MC-208/120 STA SER A	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	25	°C
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	47	°C
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	26	°C
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	65	°C
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	Oil Temp Max	47	°C
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	General Comments		
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/19/2020 14:31	Distribution	Herman Quarterly Inspection	PN46	WithLTC	HE-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
11/19/2020 13:06	Distribution	Middlesboro 2 Quarterly Inspection	MB0130	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
11/19/2020 13:51	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Counter Readings	LTC Current Tap Position	9L	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Counter Readings	LTC Max Tap Position	1L	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Counter Readings	LTC Min Tap Position	13L	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Counter Readings	Follow-up Action Required?	n	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Counter Readings	General Comments		
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	827	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Counter Readings	LTC As Found Counter	114900	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Counter Readings	LTC As Left Counter	114900	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Counter Readings	LTC Current Tap Position	7L	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Counter Readings	LTC Max Tap Position	3L	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Counter Readings	LTC Min Tap Position	10L	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Counter Readings	LTC Operations Since Last Insp	720	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Counter Readings	Follow-up Action Required?	n	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Counter Readings	LTC Operations Since Last Insp	797	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Amps C Ø	150.0	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Bushing Condition	Good	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Counter Readings	LTC Current Tap Position	4L	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Counter Readings	LTC As Left Counter	114180	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Counter Readings	LTC As Found Counter	114180	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Counter Readings	General Comments		
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Counter Readings	LTC As Left Counter	213738	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Counter Readings	LTC As Found Counter	213738	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BAT000773	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BAT000773	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Counter Readings	General Comments		
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	BCH000610	Charger	833-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	BCH000610	Charger	833-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	BCH000610	Charger	833-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.3	amps
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	BCH000610	Charger	833-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	BCH000610	Charger	833-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	BCH000610	Charger	833-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	9 Month Operations	3	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Amps A Ø	14.0	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Amps B Ø	15.0	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Amps C Ø	17.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Bushing Condition	Good	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Follow-up Action Required?	n	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Fault Operations A Ø	0	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Fault Operations B Ø	0	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Fault Operations C Ø	0	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Fault Operations Ground	0	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Follow-up Action Required?	n	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Counter Readings	LTC As Left Counter	14907	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Counter Readings	LTC As Left Counter	47383	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Counter Readings	LTC Current Tap Position	7L	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Counter Readings	LTC Max Tap Position	2R	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Counter Readings	LTC Min Tap Position	12L	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	9 Month Operations	13	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Counter Readings	LTC As Found Counter	47379	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Mechanism Patrol Inspection	General Comments		
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Counter Readings	General Comments		
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Counter Readings	Follow-up Action Required?	n	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Follow-up Action Required?	n	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Fault Operations Ground	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Counter Readings	LTC Operations Since Last Insp	1020	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Amps B Ø	141.0	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Amps A Ø	109.0	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Clear of Trash?	y	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Fault Operations C Ø	0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Fault Operations B Ø	0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Fault Operations A Ø	0	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Amps C Ø	58.0	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	PF000121	PowerFuse	ET-STA SER NO 6	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	PF000117	PowerFuse	ET-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0296	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	PF000116	PowerFuse	ET-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	PF000116	PowerFuse	ET-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	PF000117	PowerFuse	ET-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	37	°C
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	37	°C
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	General Comments		
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	PF000122	PowerFuse	ET-12KV TR 6 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	PF000122	PowerFuse	ET-12KV TR 6 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Counter Readings	LTC Max Tap Position	9L	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Counter Readings	LTC Min Tap Position	1L	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Counter Readings	LTC Operations Since Last Insp	1206	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	PF000121	PowerFuse	ET-STA SER NO 6	Disconnect Powerfuse Inspection	General Comments	ok	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Foundation Condition	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	General Comments		
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	General Comments		
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Grounds in Place?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Maintenance Operations	0	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Operations Counter AF	234	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Operations Counter AL	234	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Operations This Read Vac	4	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Switching Operations	4	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Tank Paint Condition	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Unknown Operations	0	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0067	LTCMechanism	ET-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Counter Readings	Follow-up Action Required?	n	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0295	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	LTCC000158	LTCControl	833-2	LTC Control Insp	All Connections OK?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	LTCC000158	LTCControl	833-2	LTC Control Insp	Follow-up Action Required?	n	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	LTCC000158	LTCControl	833-2	LTC Control Insp	General Comments		
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	LTCC000158	LTCControl	833-2	LTC Control Insp	LTC Operation Checked?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	LTCC000158	LTCControl	833-2	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Counter Readings	General Comments		
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Mechanism Patrol Inspection	General Comments		
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	LTCC000158	LTCControl	833-2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	LTCC000158	LTCControl	833-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	LTCC000158	LTCControl	833-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	LTCC000158	LTCControl	833-2	LTC Control Insp	VRR Time Delay	30	Seconds
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Counter Readings	LTC Min Tap Position	3L	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Counter Readings	LTC Max Tap Position	4R	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Counter Readings	LTC Current Tap Position	2L	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KT0031	LTCMechanism	833-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0068	LTCMechanism	ET-TRANS 6	LTC Counter Readings	LTC As Found Counter	14907	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Readings	General Comments		
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Operations This Read AM	0	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Switching Operations	0	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Unknown Operations	0	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2957.76	kw
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Follow-up Action Required?	n	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	71.00	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Bushing Condition	Good	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	9 Month Operations	3	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	10	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	10	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0298	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Readings	Oil Temp Max	80	°C
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Fault Operations B Ø	0	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Fault Operations A Ø	0	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Amps C Ø	100.0	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Amps B Ø	100.0	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Amps A Ø	100.0	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	9 Months Operations	0	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Amps A Ø	281.0	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Amps B Ø	315.0	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Amps C Ø	286.0	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Bushing Condition	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Fault Operations C Ø	0	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Fault Operations Ground	0	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Follow-up Action Required?	n	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Fault Operations A Ø	0	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Fault Operations B Ø	0	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Fault Operations C Ø	0	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Patrol Inspection	General Comments		
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	General Comments		
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Maintenance Operations	0	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	9 Month Operations	2	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Tank Paint Condition	Good	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Grounds in Place?	y	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	General Comments		
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000932	BreakerVacuum	094-2165	VCB Patrol Inspection	Foundation Condition	Good	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Operations Counter AF	622	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0424	BreakerAirMagnetic	GD-3	AMCB Readings	Operations Counter AL	622	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Fault Operations Ground	0	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	General Comments		
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Amps A Ø	114.0	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Amps B Ø	129.0	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	General Comments		
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Counter Readings	LTC Min Tap Position	5L	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	25	°C
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	40	°C
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Counter Readings	LTC Operations Since Last Insp	994	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Operations This Read Vac	1	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Switching Operations	1	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Tank Paint Condition	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Unknown Operations	0	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	General Comments		
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	ST000468	Structure	833-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Amps C Ø	133.0	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Bushing Condition	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Fault Operations A Ø	0	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Fault Operations B Ø	0	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Fault Operations C Ø	0	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Fault Operations Ground	0	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Patrol Inspection	Follow-up Action Required?	n	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0299	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Readings	Oil Temp Present	40	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	B0296	NonLTC	849-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.2324	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Counter Readings	Follow-up Action Required?	n	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Foundation Condition	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	General Comments		
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	General Comments		
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Grounds in Place?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Maintenance Operations	0	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Operations Counter AF	173	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0056	BreakerVacuum	833-2	VCB Readings	Operations Counter AL	173	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Counter Readings	General Comments		
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Mechanism Patrol Inspection	General Comments		
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Counter Readings	LTC As Found Counter	102602	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Counter Readings	LTC As Left Counter	102607	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	General Comments		
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Maintenance Operations	0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Operations Counter AF	204	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Operations Counter AL	204	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Operations This Read Vac	2	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Switching Operations	2	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Counter Readings	Follow-up Action Required?	n	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Counter Readings	General Comments		
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Counter Readings	LTC As Found Counter	98158	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Counter Readings	LTC As Left Counter	98162	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Counter Readings	LTC Current Tap Position	8L	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Counter Readings	LTC Max Tap Position	12L	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Counter Readings	LTC Min Tap Position	3L	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Counter Readings	LTC Operations Since Last Insp	578	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Counter Readings	LTC Current Tap Position	3L	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	S0068	LTCMechanism	833-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Unknown Operations	0	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	9 Month Operations	6	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0285	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0193	BreakerVacuum	833-2314	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	FE000459	Fence	833-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	310.00	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	60	°C
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	20	°C
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	60	°C
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	20	°C
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	60	°C
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	20	°C
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	PF000118	PowerFuse	ET-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	PF000118	PowerFuse	ET-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Fault Operations A Ø	0	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Fault Operations B Ø	0	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Fault Operations C Ø	0	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Fault Operations Ground	0	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Follow-up Action Required?	n	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	Foundation Condition	Good	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	0.0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	0.0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	0.0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	3.34	%
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	3.34	%
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	3.34	%
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Operations Counter AF	189	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Operations Counter AL	189	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Counter Readings	General Comments		
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Counter Readings	LTC As Found Counter	589166	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Counter Readings	LTC As Left Counter	589166	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Counter Readings	LTC Max Tap Position	2L	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Counter Readings	LTC Min Tap Position	5L	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	236	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6L	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Operations This Read Vac	0	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Switching Operations	0	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Unknown Operations	0	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	BCH000103	Charger	GD-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	BCH000103	Charger	GD-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.6	VDC
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	BCH000103	Charger	GD-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.6	VDC
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Counter Readings	LTC Max Tap Position	3L	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Counter Readings	LTC Min Tap Position	6L	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	231	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Switching Operations	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Unknown Operations	0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	9 Month Operations	6	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Fault Operations A Ø	0	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Fault Operations B Ø	0	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Fault Operations C Ø	0	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Fault Operations Ground	0	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Follow-up Action Required?	n	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	General Comments		
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	General Comments		
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Maintenance Operations	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	150	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	150	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LTCC000602	LTCControl	ET-TRANS 6	LTC Control Insp	Follow-up Action Required?	n	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LTCC000602	LTCControl	ET-TRANS 6	LTC Control Insp	General Comments		
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LTCC000602	LTCControl	ET-TRANS 6	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	PF000120	PowerFuse	ET-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	PF000120	PowerFuse	ET-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	ok	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Counter Readings	General Comments		
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Counter Readings	LTC As Found Counter	414545	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Counter Readings	LTC As Left Counter	414545	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	PF000119	PowerFuse	ET-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	PF000119	PowerFuse	ET-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LTCC000120	LTCControl	ET-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LTCC000120	LTCControl	ET-TRANS 2	LTC Control Insp	General Comments		
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LTCC000120	LTCControl	ET-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	Bushing Condition	Good	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	General Comments		
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	General Comments	needs nitro	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN25	LTCMechanism	GD-TRANS 2	LTC Counter Readings	LTC Current Tap Position	4L	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	Oil Temp Max	60	°C
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Readings	Oil Temp Present	20	°C
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN25	WithLTC	GD-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	45	°F
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	11	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	11	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	238	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	238	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	All Connections OK?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	0.0	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	0.0	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	0.0	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Ambient Temp	47	°F
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	General Comments		
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Vegetation	None	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	YD000465	Yard	833-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	6	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	3.08	%
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	20.0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	20.0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	20.0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	224	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	224	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Accumulated Fault Duty A Ph V	11.3	%
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Accumulated Fault Duty B Ph V	7.19	%
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	General Comments		
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Accumulated Fault Duty C Ph V	13.36	%
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Amps A Ø	110.0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Amps B Ø	110.0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Amps C Ø	110.0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Fault Operations A Ø	0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Fault Operations C Ø	0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Fault Operations Ground	0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Follow-up Action Required?	n	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	General Comments		
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Maintenance Operations	0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Operations Counter AF	293	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Operations Counter AL	293	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Operations This Read Vac	0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Switching Operations	0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Unknown Operations	0	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	13	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0106	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	BCH000103	Charger	GD-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	BCH000103	Charger	GD-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	BCH000103	Charger	GD-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	BCH000103	Charger	GD-Battery Charger	Battery Charger Patrol Insp	General Comments		
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	6	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	General Comments		
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	General Comments		
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	Grounds in Place?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Maintenance Operations	0	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	BAT000096	Battery	GD-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN21	LTCMechanism	GD-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Operations Counter AF	156	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Operations Counter AL	156	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Operations This Read Vac	0	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Switching Operations	0	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Patrol Inspection	Tank Paint Condition	Good	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Unknown Operations	0	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BCH001265	Charger	094-Battery Charger Distribution	Battery Charger Patrol Insp	Ground Lights	None	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BCH001265	Charger	094-Battery Charger Distribution	Battery Charger Patrol Insp	General Comments		
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BCH001265	Charger	094-Battery Charger Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BCH001265	Charger	094-Battery Charger Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BCH001265	Charger	094-Battery Charger Distribution	Battery Charger Patrol Insp	Battery Charger Current	6.5	amps
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BCH001265	Charger	094-Battery Charger Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BCH001265	Charger	094-Battery Charger Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BCH001265	Charger	094-Battery Charger Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Positive DC Ground	22.0	VDC
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Negative DC Ground	34.0	VDC
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	General Comments		
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BAT001323	Battery	094-Battery Bank Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Fault Operations A Ø	0	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Fault Operations B Ø	0	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Fault Operations C Ø	0	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Follow-up Action Required?	n	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Foundation Condition	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	General Comments		
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	General Comments		
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Grounds in Place?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Maintenance Operations	0	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Operations Counter AF	233	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	General Comments		
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Operations Counter AL	233	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Operations This Read Vac	11	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Switching Operations	11	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Tank Paint Condition	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Unknown Operations	0	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Vegetation	None	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	YD000438	Yard	592-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	General Comments		
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Readings	General Comments		
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	100.0	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Readings	LTC Totalizer Reading	8348.40	kw
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	9 Month Operations	6	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Accumulated Fault Duty A Ph V	10.28	%
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Readings	Oil Temp Max	45	°C
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Readings	Oil Temp Present	22	°C
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	SWG000076	Switchgear	GD-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	9 Month Operations	4	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Follow-up Action Required?	n	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Foundation Condition	Good	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	General Comments		
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	General Comments		
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Grounds in Place?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Maintenance Operations	0	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Fault Operations A Ø	0	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Fault Operations B Ø	0	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Fault Operations C Ø	0	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Fault Operations Ground	0	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Follow-up Action Required?	n	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Foundation Condition	Good	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	General Comments		
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Grounds in Place?	y	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Maintenance Operations	0	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Mechanism Patrol Inspection	General Comments		
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	C0438	LTCMechanism	592-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Operations Counter AF	187	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Operations Counter AL	187	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Operations This Read Vac	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	9 Month Operations	6	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Accumulated Fault Duty A Ph V	11.3	%
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Accumulated Fault Duty B Ph V	7.19	%
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Accumulated Fault Duty C Ph V	13.36	%
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Amps A Ø	110.0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Amps B Ø	110.0	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Switching Operations	0	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Patrol Inspection	Tank Paint Condition	Good	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000933	BreakerVacuum	094-2166	VCB Readings	Unknown Operations	0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	218	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	218	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Amps A Ø	160.0	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Amps B Ø	132.0	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Readings	Amps C Ø	123.0	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Bushing Condition	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	K0194	BreakerVacuum	833-2109	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Operations Counter AF	320	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Operations Counter AL	320	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Operations This Read Vac	1	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Switching Operations	1	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Patrol Inspection	Tank Paint Condition	Good	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0253	BreakerVacuum	589-2144	VCB Readings	Unknown Operations	0	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	LTCC000586	LTCControl	833-1	LTC Control Insp	All Connections OK?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	LTCC000586	LTCControl	833-1	LTC Control Insp	Follow-up Action Required?	n	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	LTCC000586	LTCControl	833-1	LTC Control Insp	General Comments		
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	LTCC000586	LTCControl	833-1	LTC Control Insp	LTC Operation Checked?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	LTCC000586	LTCControl	833-1	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	LTCC000586	LTCControl	833-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Amps A Ø	130.0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Amps B Ø	130.0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Amps C Ø	130.0	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Amps A Ø	105.0	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Amps B Ø	146.0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Fault Operations B Ø	0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Fault Operations C Ø	0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Fault Operations Ground	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	375.0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	350.0	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	Amps C Ø	1500.0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Amps C Ø	110.0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Fault Operations A Ø	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Fault Operations B Ø	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Fault Operations C Ø	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Fault Operations Ground	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	375.0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Follow-up Action Required?	n	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	General Comments		
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Maintenance Operations	0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Operations Counter AF	846	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Operations Counter AL	846	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Follow-up Action Required?	n	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Operations This Read Vac	0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Switching Operations	0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Unknown Operations	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	287	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	287	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0292	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	General Comments		
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Maintenance Operations	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Operations Counter AF	297	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Operations Counter AL	297	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Readings	Operations This Read Vac	0	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	SWG000002	Switchgear	GD-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Amps A Ø	0.0	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Amps B Ø	0.0	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Readings	Amps C Ø	0.0	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Readings	Totalizer Meter Reading	.4638	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Readings	Winding Temp Max	42	°C
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Readings	Winding Temp Present	22	°C
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KT0031	WithLTC	833-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	LTCC000586	LTCControl	833-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	LTCC000586	LTCControl	833-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	LTCC000586	LTCControl	833-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	KB0057	BreakerVacuum	833-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Accumulated Fault Duty B Ph V	10.28	%
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Accumulated Fault Duty C Ph V	16.44	%
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Amps A Ø	120.0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Amps B Ø	120.0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Amps C Ø	120.0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Fault Operations A Ø	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Fault Operations B Ø	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Fault Operations C Ø	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Fault Operations Ground	0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	100.0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	100.0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Follow-up Action Required?	n	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	General Comments		
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	3.08	%
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Maintenance Operations	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Operations Counter AF	852	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Operations Counter AL	852	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Operations This Read Vac	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Switching Operations	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Unknown Operations	0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	9 Month Operations	6	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Accumulated Fault Duty A Ph V	10.28	%
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Accumulated Fault Duty B Ph V	10.28	%
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Readings	Accumulated Fault Duty C Ph V	16.44	%
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	148	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	148	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	BK000934	BreakerVacuum	094-5	VCB Readings	9 Month Operations	0	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	FE000447	Fence	592-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	0.0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	0.0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	0.0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	3.34	%
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	3.34	%
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	3.34	%
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Readings	Totalizer Meter Reading	.6354	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Readings	Totalizer Meter Multiplier	2400	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Readings	Oil Temp Present	40	°C
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Readings	Oil Temp Max	50	°C
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1111.0	psi
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Readings	LTC Totalizer Reading	1524.96	kw
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Readings	General Comments		
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	C0438	WithLTC	592-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BCH001310	Charger	592-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BCH001310	Charger	592-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BCH001310	Charger	592-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BCH001310	Charger	592-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.3	amps
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Readings	Oil Temp Present	25	°C
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	506	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Readings	Oil Temp Max	35	°C
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	5279.04	kw
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Readings	General Comments		
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	General Comments		
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0294	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	506	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0300	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C ∅	0	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Fault Operations C ∅	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Fault Operations Ground	0	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Follow-up Action Required?	n	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Patrol Inspection	General Comments		
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	General Comments		
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Maintenance Operations	0	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Operations Counter AF	466	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Operations Counter AL	466	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Operations This Read AM	0	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Switching Operations	0	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Unknown Operations	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0066	LTCMechanism	ET-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0066	LTCMechanism	ET-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0066	LTCMechanism	ET-TRANS 1	LTC Counter Readings	General Comments		
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0066	LTCMechanism	ET-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0066	LTCMechanism	ET-TRANS 1	LTC Counter Readings	LTC As Found Counter	45362	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0066	LTCMechanism	ET-TRANS 1	LTC Counter Readings	LTC As Left Counter	45362	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0066	LTCMechanism	ET-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0066	LTCMechanism	ET-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6R	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0066	LTCMechanism	ET-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	253	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0066	LTCMechanism	ET-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0066	LTCMechanism	ET-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Unknown Operations	0	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	Tank Paint Condition	Good	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Switching Operations	0	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Operations This Read Vac	0	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Operations Counter AL	318	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Operations Counter AF	318	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Maintenance Operations	0	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	Grounds in Place?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	General Comments		
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	General Comments		
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	Foundation Condition	Good	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Follow-up Action Required?	n	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Fault Operations Ground	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0283	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Fault Operations C Ø	0	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	3	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BCH001310	Charger	592-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BCH001310	Charger	592-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BCH001310	Charger	592-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BCH001310	Charger	592-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BAT001382	Battery	592-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BAT001382	Battery	592-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	40	*F
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BAT001382	Battery	592-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BAT001382	Battery	592-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BAT001382	Battery	592-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BAT001382	Battery	592-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BAT001382	Battery	592-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BAT001382	Battery	592-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BAT001382	Battery	592-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BAT001382	Battery	592-Battery Bank	Battery Patrol Inspection	General Comments		
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BAT001382	Battery	592-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BAT001382	Battery	592-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BAT001382	Battery	592-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BAT001382	Battery	592-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Patrol Inspection	Tank Paint Condition	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Patrol Inspection	Grounds in Place?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Patrol Inspection	General Comments	Breaker Connected light not working. Replaced bulb and still the same	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Patrol Inspection	Foundation Condition	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Patrol Inspection	Follow-up Action Required?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000768	BreakerVacuum	ET-1173	VCB Patrol Inspection	Bushing Condition	Good	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	9 Months Operations	2	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Amps A Ø	220.0	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Amps B Ø	220.0	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Amps C Ø	250.0	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Fault Operations A Ø	0	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0422	BreakerAirMagnetic	GD-1	AMCB Readings	Fault Operations B Ø	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	General Comments	Trans needs nitrogen	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	SWG000007	Switchgear	ET-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1300	psi
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	General Comments		
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Readings	General Comments		
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	General Comments	Pumps seeping oil	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	LTCC000132	LTCControl	592-1	LTC Control Insp	LTC Output Voltage Level	123.3	VAC
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	LTCC000132	LTCControl	592-1	LTC Control Insp	LTC Operation Checked?	y	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	LTCC000132	LTCControl	592-1	LTC Control Insp	General Comments		
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	LTCC000132	LTCControl	592-1	LTC Control Insp	Follow-up Action Required?	n	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	LTCC000132	LTCControl	592-1	LTC Control Insp	All Connections OK?	y	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Counter Readings	LTC As Left Counter	9755	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Counter Readings	LTC Current Tap Position	11L	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Counter Readings	LTC Max Tap Position	6L	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Counter Readings	LTC Min Tap Position	15L	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Counter Readings	LTC Operations Since Last Insp	848	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0252	GroundTransformer	ET-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	Follow-up Action Required?	n	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	General Comments		
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	General Comments	Trans needs nitrogen	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1	psi
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	Oil Temp Max	60	°C
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	Oil Temp Present	20	°C
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	WithLTC Trn Dynamic Health	40.00	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	X1 Winding Temp Max	105	°C
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	X1 Winding Temp Present	50	°C
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	X2 Winding Temp Max	100	°C
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	X2 Winding Temp Present	40	°C
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	X3 Winding Temp Max	90	°C
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	X3 Winding Temp Present	40	°C
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	CH000444	ControlHouse	GD-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	CH000444	ControlHouse	GD-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	CH000444	ControlHouse	GD-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	CH000444	ControlHouse	GD-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	CH000444	ControlHouse	GD-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	CH000444	ControlHouse	GD-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	CH000444	ControlHouse	GD-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	CH000444	ControlHouse	GD-Battery Control House	Control House Patrol Inspection	General Comments		
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	CH000444	ControlHouse	GD-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Readings	Totalizer Meter Reading	.7332	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	110	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	C0519	NonLTC	589-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	General Comments		
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1300	psi
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	Oil Temp Max	60	°C
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	Oil Temp Present	35	°C
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Readings	Percent Thermal Load X2 Max	60	%
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Readings	Percent Thermal Load Y2 Max	60	%
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Leaks	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	80	°C
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	40	°C
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	80	°C
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	40	°C
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	80	°C
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0067	WithLTC	ET-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	35	°C
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0068	WithLTC	ET-TRANS 6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Readings	Oil Temp Max	42	°C
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Follow-up Action Required?	n	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Patrol Inspection	Follow-up Action Required?	n	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Fault Operations Ground	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Fault Operations C Ø	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Fault Operations B Ø	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Fault Operations A Ø	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Patrol Inspection	Bushing Condition	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Amps C Ø	0.0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Amps B Ø	0.0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Amps A Ø	0.0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	°F
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	General Comments		
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	9 Month Operations	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Patrol Inspection	Tank Paint Condition	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Switching Operations	0	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Readings	Oil Temp Present	34	°C
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	40.00	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Bushing Condition	Good	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Amps C Ø	53.0	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Amps B Ø	61.0	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Amps A Ø	53.0	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	9 Month Operations	3	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Patrol Inspection	Tank Paint Condition	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Switching Operations	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Operations This Read Vac	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Operations Counter AL	35	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Operations Counter AF	35	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	Maintenance Operations	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Patrol Inspection	Grounds in Place?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Readings	General Comments	Actual counter	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Patrol Inspection	General Comments		
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001055	BreakerVacuum	ET-12KV BUS TIE SEC 6	VCB Patrol Inspection	Foundation Condition	Good	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Readings	General Comments		
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	9 Month Operations	2	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	SWG000085	Switchgear	ET-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Unknown Operations	0	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Switching Operations	0	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Operations This Read AM	0	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Operations Counter AL	171	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Operations Counter AF	171	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Maintenance Operations	0	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	General Comments		
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Patrol Inspection	General Comments		
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Follow-up Action Required?	n	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Fault Operations Ground	0	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Fault Operations C Ø	0	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	9 Months Operations	0	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Amps A Ø	110.0	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Amps B Ø	70.0	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Amps C Ø	110.0	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Fault Operations A Ø	0	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0427	BreakerAirMagnetic	GD-2	AMCB Readings	Fault Operations B Ø	0	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	25	°C
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	PN21	WithLTC	GD-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	20	°C
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Operations This Read Vac	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Operations Counter AL	22	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Operations Counter AF	22	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Amps C Ø	63.0	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Amps B Ø	109.0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Maintenance Operations	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Patrol Inspection	Grounds in Place?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	General Comments		
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Patrol Inspection	General Comments		
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Patrol Inspection	Foundation Condition	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Follow-up Action Required?	n	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Patrol Inspection	Follow-up Action Required?	n	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Fault Operations Ground	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Fault Operations C Ø	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Fault Operations B Ø	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Fault Operations A Ø	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	BAT001113	Battery	833-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Patrol Inspection	Bushing Condition	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Amps C Ø	400.0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Amps B Ø	420.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Amps A Ø	500.0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK001054	BreakerVacuum	ET-12KV TR 6	VCB Readings	9 Month Operations	0	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Amps A Ø	71.0	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	General Comments		
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Regulator As Left Counter	106716	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	General Comments		
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Regulator As Left Counter	124046	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1155	Regulator	849-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	261.0	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	239.0	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	252.0	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Fault Operations B Ø	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0284	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Fault Operations A Ø	0	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0252	BreakerVacuum	589-2146	VCB Patrol Inspection	Bushing Condition	Good	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	General Comments		
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	FE000488	Fence	849-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1154	Regulator	849-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Follow-up Action Required?	n	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Patrol Inspection	General Comments		
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	General Comments		
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Maintenance Operations	0	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Operations Counter AF	486	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Operations Counter AL	486	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Operations This Read AM	0	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Switching Operations	0	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Unknown Operations	0	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	345	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	345	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Unknown Operations	0	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Tank Paint Condition	Good	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Switching Operations	1	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Operations This Read Vac	1	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Operations Counter AL	397	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Operations Counter AF	397	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Maintenance Operations	0	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Grounds in Place?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	General Comments		
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	General Comments		
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Foundation Condition	Good	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Follow-up Action Required?	n	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Fault Operations Ground	0	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Fault Operations C ∅	0	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Fault Operations B ∅	0	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Fault Operations A ∅	0	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	CB0251	BreakerVacuum	589-2145	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Current Tap Position	10L	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	General Comments		
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Max Tap Position	2L	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Min Tap Position	16L	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Regulator As Left Counter	0	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Tank Leaks	None	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1156	Regulator	589-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	9 Months Operations	0	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Amps A Ø	0.0	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Amps B Ø	0.0	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Amps C Ø	0.0	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	BB0345	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Fault Operations A Ø	0	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Fault Operations B Ø	0	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Fault Operations C Ø	0	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0425	BreakerAirMagnetic	GD-4	AMCB Readings	Fault Operations Ground	0	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	Ambient Temp	34	*F
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	General Comments		
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	FE000601	Fence	GD-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Amps B Ø	2.0	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Amps A Ø	10.0	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	9 Month Operations	8	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Unknown Operations	0	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Tank Paint Condition	Good	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Switching Operations	1	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Operations This Read Vac	1	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Operations Counter AL	231	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Operations Counter AF	231	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Maintenance Operations	0	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	General Comments		
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	General Comments		
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Foundation Condition	Good	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Follow-up Action Required?	n	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Fault Operations Ground	0	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Fault Operations C Ø	0	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Fault Operations B Ø	0	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Fault Operations A Ø	0	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Patrol Inspection	Follow-up Action Required?	n	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Patrol Inspection	Bushing Condition	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Operations This Read Vac	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Operations Counter AL	387	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Operations Counter AF	387	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Maintenance Operations	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	General Comments		
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Follow-up Action Required?	n	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Fault Operations Ground	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Fault Operations C Ø	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Fault Operations B Ø	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Fault Operations A Ø	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Amps C Ø	120.0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Amps B Ø	90.0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Amps A Ø	40.0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Accumulated Fault Duty B Ph V	2.06	%
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Accumulated Fault Duty A Ph V	3.08	%
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	9 Month Operations	5	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Bushing Condition	Good	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Amps C Ø	8.0	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	General Comments		
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Bushing Condition	Good	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Amps C Ø	29.0	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Amps B Ø	30.0	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Amps A Ø	42.0	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	9 Month Operations	3	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Tank Leaks	None	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Regulator As Left Counter	102613	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Min Tap Position	11L	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Max Tap Position	6L	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	General Comments		
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Current Tap Position	10L	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1306	Regulator	589-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Tank Leaks	None	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Regulator As Left Counter	71571	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Patrol Inspection	Bushing Condition	Good	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Amps C Ø	10.0	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Amps B Ø	0.0	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Amps A Ø	1.0	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001104	BreakerVacuum	592-2148	VCB Readings	9 Month Operations	3	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Unknown Operations	0	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Tank Paint Condition	Good	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Switching Operations	1	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Operations This Read Vac	1	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Operations Counter AL	206	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Operations Counter AF	206	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Maintenance Operations	0	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Grounds in Place?	y	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	General Comments		
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	General Comments		
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Foundation Condition	Good	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Follow-up Action Required?	n	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Fault Operations Ground	0	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Fault Operations C Ø	0	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Fault Operations B Ø	0	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Fault Operations A Ø	0	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001103	BreakerVacuum	592-2147	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Patrol Inspection	Grounds in Place?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Patrol Inspection	General Comments		
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Patrol Inspection	Foundation Condition	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Patrol Inspection	Follow-up Action Required?	n	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Patrol Inspection	Tank Paint Condition	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Patrol Inspection	Grounds in Place?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Patrol Inspection	General Comments		
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Patrol Inspection	Foundation Condition	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Amps A Ø	23.0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Accumulated Fault Duty B Ph V	.48	%
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Accumulated Fault Duty A Ph V	.48	%
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	9 Month Operations	2	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Unknown Operations	0	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Tank Paint Condition	Good	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Switching Operations	6	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Operations This Read Vac	6	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Operations Counter AL	206	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Operations Counter AF	206	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Maintenance Operations	0	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Operations Counter	4	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	General Comments		
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Amps B Ø	64.0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Amps A Ø	53.0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Accumulated Fault Duty B Ph V	.48	%
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Accumulated Fault Duty A Ph V	.48	%
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	9 Month Operations	2	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Unknown Operations	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Switching Operations	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Operations This Read Vac	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Operations Counter AL	205	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Operations Counter AF	205	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Maintenance Operations	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	General Comments		
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Follow-up Action Required?	n	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Fault Operations Ground	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BAT000773	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BAT000773	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BAT000773	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BAT000773	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Fault Operations C Ø	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Fault Operations B Ø	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Fault Operations A Ø	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Amps C Ø	24.0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Readings	Amps B Ø	28.0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BAT000773	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BAT000773	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BAT000773	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BAT000773	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BAT000773	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BAT000773	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BCH000761	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	3.000	millivolts
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BCH000761	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.8	VDC
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BCH000761	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.8	VDC
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BCH000761	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BCH000761	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BCH000761	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BCH000761	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BCH000761	Charger	Retired Distribution	Battery Charger Patrol Insp	Ground Lights	None	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Patrol Inspection	Tank Paint Condition	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000872	BreakerVacuum	ET-1172	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Amps C Ø	120.0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Amps B Ø	100.0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Panels Dusted?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	General Comments		
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Evidence of Insects	None	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	SWG000086	Switchgear	ET-Swgr Sec 6	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Amps A Ø	120.0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Accumulated Fault Duty B Ph V	2.06	%
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Accumulated Fault Duty A Ph V	3.08	%
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	9 Month Operations	5	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Unknown Operations	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Switching Operations	0	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000871	BreakerVacuum	ET-1171	VCB Patrol Inspection	Bushing Condition	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Patrol Inspection	Tank Paint Condition	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Patrol Inspection	Grounds in Place?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Patrol Inspection	General Comments		
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	BK000870	BreakerVacuum	ET-1170	VCB Patrol Inspection	Foundation Condition	Good	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Amps C Ø	98.0	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Amps B Ø	106.0	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	KX0028	RecloserElectronic	849-2103	Recloser Electronic Patrol Inspection	Amps A Ø	111.0	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Grounds in Place?	y	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	General Comments		
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	General Comments		
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Foundation Condition	Good	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Follow-up Action Required?	n	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Fault Operations Ground	0	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Fault Operations C Ø	0	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	Vegetation	None	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	YD000604	Yard	GD-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Fault Operations B Ø	0	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Fault Operations A Ø	0	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	BK001105	BreakerVacuum	592-2149	VCB Patrol Inspection	Cabinet Paint Condition	Good	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Unknown Operations	0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Switching Operations	0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Operations This Read Vac	0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Operations Counter AL	383	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Operations Counter AF	383	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Maintenance Operations	0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	General Comments		
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Fault Operations Ground	0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Fault Operations C Ø	0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Fault Operations B Ø	0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Fault Operations A Ø	0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	LTCC000792	LTCControl	094-5	LTC Control Insp	All Connections OK?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	LTCC000792	LTCControl	094-5	LTC Control Insp	Follow-up Action Required?	n	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	LTCC000792	LTCControl	094-5	LTC Control Insp	General Comments		
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	LTCC000792	LTCControl	094-5	LTC Control Insp	LTC Operation Checked?	y	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	LTCC000792	LTCControl	094-5	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	General Comments		
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Regulator As Left Counter	125551	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	General Comments		
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	General Comments		
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	ST000496	Structure	849-Structure	Structure Patrol Inspection	All Identified and Legible?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Vegetation	None	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	General Comments		
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	Oil Temp Present	20	°C
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	Oil Temp Max	40	°C
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	LTC Totalizer Reading	4089.60	kw
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	General Comments		
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	General Comments		
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	General Comments		
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Vegetation	None	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	General Comments		
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	BAT001374	Battery	589-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	BAT001374	Battery	589-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	BAT001374	Battery	589-Battery Bank	Battery Patrol Inspection	Positive DC Ground	30.0	VDC
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	BAT001374	Battery	589-Battery Bank	Battery Patrol Inspection	Negative DC Ground	33.0	VDC
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	BAT001374	Battery	589-Battery Bank	Battery Patrol Inspection	General Comments		
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	BAT001374	Battery	589-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	BAT001374	Battery	589-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	BAT001374	Battery	589-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	BAT001374	Battery	589-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	BAT001374	Battery	589-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	BAT001374	Battery	589-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	BAT001374	Battery	589-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	BAT001374	Battery	589-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	°F
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	BAT001374	Battery	589-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	BCH001289	Charger	589-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	BCH001289	Charger	589-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	BCH001289	Charger	589-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	BCH001289	Charger	589-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	BCH001289	Charger	589-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	BCH001289	Charger	589-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	Totalizer Meter Reading	.2840	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	Winding Temp Max	40	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	Winding Temp Present	22	°C
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	BCH001289	Charger	589-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	BCH001289	Charger	589-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LB0282	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	R1153	Regulator	849-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	YD000460	Yard	589-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	LTCC000792	LTCControl	094-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	LTCC000792	LTCControl	094-5	LTC Control Insp	VRR Time Delay	30	Seconds
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Counter Readings	Follow-up Action Required?	n	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Counter Readings	General Comments		
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Mechanism Patrol Inspection	General Comments		
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	LTCM000086	LTCMechanism	094-5	LTC Counter Readings	LTC As Found Counter	9750	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	LTCC000132	LTCControl	592-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	General Comments		
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	LTCC000132	LTCControl	592-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	LTCC000132	LTCControl	592-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	FE000454	Fence	589-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Unknown Operations	0	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Switching Operations	0	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Operations This Read AM	0	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Operations Counter AL	306	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Operations Counter AF	306	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Maintenance Operations	0	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Current Tap Position	11L	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Readings	Follow-up Action Required?	n	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	ST000463	Structure	589-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Ambient Temp	32	°F
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/19/2020 5:32	Distribution	Pine Hill Quarterly Inspection	ST000441	Structure	592-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	TX000215	WithLTC	094-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Min Tap Position	16L	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/23/2020 6:50	Distribution	Ethel Quarterly Inspection	LT0066	WithLTC	ET-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	9 Months Operations	0	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Fault Operations A Ø	0	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Fault Operations B Ø	0	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Fault Operations C Ø	0	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Fault Operations Ground	0	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	Follow-up Action Required?	n	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Patrol Inspection	General Comments		
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Readings	General Comments		
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	General Comments		
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	General Comments		
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	LTC Totalizer Reading	11815.20	kw
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	Oil Temp Max	50	°C
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	Oil Temp Present	28	°C
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	Totalizer Meter Reading	.6564	
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	Winding Temp Max	25	°C
11/18/2020 17:31	Distribution	Richmond 3 Quarterly Inspection	S0068	WithLTC	833-1	LTC Transformer Readings	Winding Temp Present	25	°C
11/19/2020 10:24	Distribution	Mount Vernon Tap Quarterly Inspection	LTCC000792	LTCControl	094-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/18/2020 10:43	Distribution	Brodhead Quarterly Inspection	YD000494	Yard	849-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/18/2020 13:29	Distribution	Mount Vernon Quarterly Inspection	R1305	Regulator	589-2 B	Regulator Patrol Inspection	Max Tap Position	6L	
11/18/2020 10:48	Distribution	Grand Quarterly Inspection	LB0426	BreakerAirMagnetic	GD-SEC 1 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	9 Month Operations	1	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	General Comments		
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Amps B Ø	24.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Amps C Ø	31.0	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Amps A Ø	49.0	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	General Comments	Tree at one corner has branches growing over fence	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	CH000458	ControlHouse	GA-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	CH000458	ControlHouse	GA-Battery Control House	Control House Patrol Inspection	General Comments		
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	CH000458	ControlHouse	GA-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	CH000458	ControlHouse	GA-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	CH000458	ControlHouse	GA-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	CH000458	ControlHouse	GA-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	CH000458	ControlHouse	GA-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	CH000458	ControlHouse	GA-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Tank Paint Condition	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Grounds in Place?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	General Comments		
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Foundation Condition	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001106	BreakerVacuum	069-2325	VCB Patrol Inspection	Bushing Condition	Good	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	CH000458	ControlHouse	GA-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Accumulated Fault Duty C Ph V	2.78	%
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Accumulated Fault Duty B Ph V	3.57	%
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Accumulated Fault Duty A Ph V	4.37	%
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	9 Month Operations	3	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Tank Paint Condition	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Grounds in Place?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	General Comments		
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Amps A Ø	200.0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Amps B Ø	200.0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Amps C Ø	200.0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Bushing Condition	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Fault Operations A Ø	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Fault Operations B Ø	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Fault Operations C Ø	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Fault Operations Ground	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Follow-up Action Required?	n	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Foundation Condition	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Foundation Condition	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Unknown Operations	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BB0374	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	Oil Temp Max	53	°C
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	Oil Temp Present	35	°C
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	Totalizer Meter Reading	.3200	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	Winding Temp Max	42	°C
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	Winding Temp Present	40	°C
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Unknown Operations	0	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Switching Operations	0	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Operations This Read AM	0	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Operations Counter AL	217	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Operations Counter AF	217	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Maintenance Operations	0	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	General Comments		
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Patrol Inspection	General Comments		
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Follow-up Action Required?	n	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Fault Operations Ground	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	LTC Totalizer Reading	5760.00	kw
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	General Comments		
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	General Comments		
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	Follow-up Action Required?	n	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0486	WithLTC	069-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Unknown Operations	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Tank Paint Condition	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Switching Operations	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Operations This Read Vac	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Operations Counter AL	45	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Operations Counter AF	45	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Maintenance Operations	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	Grounds in Place?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	General Comments		
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Patrol Inspection	General Comments		
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Fault Operations B Ø	0	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Fault Operations C Ø	0	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Fault Operations Ground	0	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Follow-up Action Required?	n	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	General Comments		
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Maintenance Operations	0	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Operations Counter AF	205	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Operations Counter AL	206	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Operations This Read Vac	1	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Readings	Switching Operations	1	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	General Comments		
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	General Comments		
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Foundation Condition	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Foundation Condition	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	General Comments		
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Follow-up Action Required?	n	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Fault Operations Ground	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Fault Operations C Ø	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Fault Operations B Ø	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Fault Operations A Ø	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Bushing Condition	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Amps C Ø	76.0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Amps B Ø	95.0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Amps A Ø	120.0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	9 Month Operations	1	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Grounds in Place?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Tank Paint Condition	Good	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	FE000010	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Fault Operations C Ø	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Bushing Condition	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	LTCC000679	LTCControl	069-6	LTC Control Insp	All Connections OK?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	LTCC000679	LTCControl	069-6	LTC Control Insp	Follow-up Action Required?	n	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	LTCC000679	LTCControl	069-6	LTC Control Insp	General Comments		
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	LTCC000679	LTCControl	069-6	LTC Control Insp	LTC Operation Checked?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Bushing Condition	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Fault Operations B Ø	0	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Fault Operations A Ø	0	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Amps C Ø	200.0	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Amps B Ø	180.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Amps A Ø	180.0	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0299	BreakerVacuum	069-2326	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	LTCC000679	LTCControl	069-6	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	LTCC000679	LTCControl	069-6	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	LTCC000679	LTCControl	069-6	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	LTCC000679	LTCControl	069-6	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	LTCC000679	LTCControl	069-6	LTC Control Insp	VRR Time Delay	30	Seconds
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	LTCC000664	LTCControl	855-1	LTC Control Insp	All Connections OK?	y	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	LTCC000664	LTCControl	855-1	LTC Control Insp	Follow-up Action Required?	n	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	LTCC000664	LTCControl	855-1	LTC Control Insp	General Comments		
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	LTCC000664	LTCControl	855-1	LTC Control Insp	LTC Operation Checked?	y	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	LTCC000664	LTCControl	855-1	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	LTCC000664	LTCControl	855-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	LTCC000664	LTCControl	855-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	LTCC000664	LTCControl	855-1	LTC Control Insp	VRR Time Delay	60	Seconds
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Unknown Operations	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Tank Paint Condition	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Switching Operations	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Operations This Read Vac	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Operations Counter AL	203	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Operations Counter AF	203	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Readings	Maintenance Operations	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	BK001107	BreakerVacuum	069-2328	VCB Patrol Inspection	Grounds in Place?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Maintenance Operations	0	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Grounds in Place?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	General Comments		
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Foundation Condition	Good	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Follow-up Action Required?	n	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Follow-up Action Required?	n	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Fault Operations Ground	0	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Fault Operations C Ø	0	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Fault Operations B Ø	0	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Fault Operations A Ø	0	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Bushing Condition	Good	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Amps C Ø	403.0	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Amps B Ø	389.0	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Amps A Ø	399.0	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	9 Month Operations	2	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Mechanism Patrol Inspection	General Comments		
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Readings	Oil Temp Present	20	°C
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Readings	Oil Temp Max	35	°C
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Mechanism Patrol Inspection	General Comments		
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Readings	LTC Totalizer Reading	2030.40	kw
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	General Comments		
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	BAT001431	Battery	GA-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	71	°F
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	BAT001431	Battery	GA-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	BAT001431	Battery	GA-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	BAT001431	Battery	GA-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	BAT001431	Battery	GA-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	BAT001431	Battery	GA-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	BAT001431	Battery	GA-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	General Comments		
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	General Comments		
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	LTC Totalizer Reading	9158.40	kw
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	Oil Temp Max	50	°C
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	Oil Temp Present	38	°C
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	BAT001431	Battery	GA-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	BAT001431	Battery	GA-Battery Bank	Battery Patrol Inspection	General Comments		
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	BAT001431	Battery	GA-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	BAT001431	Battery	GA-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	BAT001431	Battery	GA-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	BAT001431	Battery	GA-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	Totalizer Meter Reading	.5088	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	Winding Temp Max	42	°C
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	Winding Temp Present	28	°C
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Bushing Condition	Good	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Amps C Ø	438.0	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Amps B Ø	450.0	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Amps A Ø	447.0	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	9 Month Operations	2	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Unknown Operations	0	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Tank Paint Condition	Good	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Switching Operations	0	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Operations This Read Vac	0	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Operations Counter AL	188	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Operations Counter AF	188	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BCH000572	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BCH000572	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BCH000572	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BCH000572	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	LTCC000906	LTCControl	871-1	LTC Control Insp	All Connections OK?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	LTCC000906	LTCControl	871-1	LTC Control Insp	Follow-up Action Required?	n	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	LTCC000906	LTCControl	871-1	LTC Control Insp	General Comments		
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	LTCC000906	LTCControl	871-1	LTC Control Insp	LTC Operation Checked?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	LTCC000906	LTCControl	871-1	LTC Control Insp	LTC Output Voltage Level	123.7	VAC
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	LTCC000906	LTCControl	871-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	LTCC000906	LTCControl	871-1	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	LTCC000906	LTCControl	871-1	LTC Control Insp	VRR Base Voltage AL	123.0	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	LTCC000906	LTCControl	871-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	BAT001388	Battery	855-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	BAT001388	Battery	855-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	BAT001388	Battery	855-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	BAT001388	Battery	855-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	BAT001388	Battery	855-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	BAT001388	Battery	855-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	BAT001388	Battery	855-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	BAT001388	Battery	855-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	BAT001388	Battery	855-Battery Bank	Battery Patrol Inspection	General Comments		
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	BAT001388	Battery	855-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	BAT001388	Battery	855-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	BAT001388	Battery	855-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	BAT001388	Battery	855-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Readings	General Comments		
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	General Comments		
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	FE000608	Fence	GA-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	General Comments		
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Vegetation	None	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	General Comments		
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	50	*F
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BCH000572	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BCH000572	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Broom on Site?	n	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	General Comments		
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	100.0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	100.0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	100.0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	2	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Unknown Operations	0	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Switching Operations	0	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Operations This Read AM	0	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Operations Counter AL	381	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Operations Counter AF	381	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Maintenance Operations	0	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	General Comments		
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Patrol Inspection	General Comments		
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Follow-up Action Required?	n	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Fault Operations Ground	0	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Fault Operations C Ø	0	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Fault Operations B Ø	0	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Fault Operations A Ø	0	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Amps C Ø	120.0	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Amps B Ø	200.0	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Amps A Ø	240.0	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	BCH001294	Charger	855-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	BCH001294	Charger	855-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	24	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	BCH001294	Charger	855-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	BCH001294	Charger	855-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	BCH001294	Charger	855-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	BCH001294	Charger	855-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	BCH001294	Charger	855-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	BCH001294	Charger	855-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	24	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Trash Emptied?	n	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	n	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Station Ground Set On Site?	n	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Panels Dusted?	y	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	ST000032	Structure	855-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	General Comments	.	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	CH000478	ControlHouse	855-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	General Comments		
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Readings	General Comments		
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Readings	LTC Totalizer Reading	7104.00	kw
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Readings	Oil Temp Max	65	°C
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Readings	Oil Temp Present	45	°C
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Readings	Totalizer Meter Reading	1.4800	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Unknown Operations	0	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Tank Paint Condition	Good	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Switching Operations	0	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Operations This Read Vac	0	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Operations Counter AL	177	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Operations Counter AF	177	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Maintenance Operations	0	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Grounds in Place?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	General Comments		
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	General Comments		
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Foundation Condition	Good	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Follow-up Action Required?	n	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Follow-up Action Required?	n	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Fault Operations Ground	0	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Fault Operations C Ø	0	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Fault Operations B Ø	0	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Fault Operations A Ø	0	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Readings	Follow-up Action Required?	n	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	C0525	WithLTC	069-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	BAT001431	Battery	GA-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0383	BreakerAirMagnetic	GA-1	AMCB Readings	9 Months Operations	3	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Readings	Totalizer Meter Reading	.4230	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	9 Month Operations	19	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Accumulated Fault Duty A Ph V	43.57	%
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Accumulated Fault Duty B Ph V	43.57	%
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Accumulated Fault Duty C Ph V	44.42	%
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Amps A Ø	72.0	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Amps B Ø	84.0	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Amps C Ø	132.0	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Fault Operations A Ø	0	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Fault Operations B Ø	0	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Fault Operations C Ø	0	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Fault Operations Ground	0	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Follow-up Action Required?	n	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	General Comments		
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Maintenance Operations	0	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Operations Counter AF	52	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Operations Counter AL	61	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Operations This Read Vac	9	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Switching Operations	9	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Readings	Unknown Operations	0	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Ambient Temp	50	*F

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	M0043	WithLTC	855-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Bushing Condition	Good	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Amps C Ø	0.0	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	9 Month Operations	16	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Accumulated Fault Duty A Ph V	11.96	%
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Accumulated Fault Duty B Ph V	15.38	%
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Accumulated Fault Duty C Ph V	17.94	%
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Amps A Ø	96.0	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Amps B Ø	88.0	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Amps C Ø	88.0	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Fault Operations A Ø	0	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Fault Operations B Ø	0	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Fault Operations C Ø	0	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Fault Operations Ground	0	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Follow-up Action Required?	n	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	General Comments		
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Maintenance Operations	0	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Operations Counter AF	99933	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Operations Counter AL	99941	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Amps B Ø	0.0	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Amps A Ø	0.0	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	9 Month Operations	31	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Accumulated Fault Duty A Ph V	9.13	%
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Operations This Read Vac	8	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Switching Operations	8	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Readings	Unknown Operations	0	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Accumulated Fault Duty B Ph V	9.13	%
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Accumulated Fault Duty C Ph V	9.53	%
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Amps A Ø	15.0	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Amps B Ø	15.0	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Amps C Ø	15.0	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Fault Adjusted Amps A Phase V	58.59	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Fault Adjusted Amps B Phase V	58.59	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Fault Adjusted Amps C Phase V	58.59	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Fault Operations A Ø	0	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Fault Operations B Ø	0	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Fault Operations C Ø	0	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Fault Operations Ground	0	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Follow-up Action Required?	n	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	General Comments		
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Maintenance Operations	0	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Operations Counter AF	241	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Operations Counter AL	249	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Operations This Read Vac	19	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Switching Operations	8	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Readings	Unknown Operations	11	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Counter Readings	LTC Operations Since Last Insp	1369	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Counter Readings	LTC Min Tap Position	15L	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Unknown Operations	0	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Tank Paint Condition	Good	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Switching Operations	0	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Operations This Read Vac	0	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Operations Counter AL	305	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Operations Counter AF	305	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Maintenance Operations	0	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Grounds in Place?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	General Comments		
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	General Comments		
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Foundation Condition	Good	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Follow-up Action Required?	n	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Follow-up Action Required?	n	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Fault Operations Ground	0	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Fault Operations C Ø	0	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Fault Operations B Ø	0	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Counter Readings	LTC Operations Since Last Insp	397	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Counter Readings	LTC Min Tap Position	8L	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Counter Readings	LTC Max Tap Position	1R	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Counter Readings	LTC Current Tap Position	4L	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Counter Readings	LTC As Left Counter	83763	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Counter Readings	LTC As Found Counter	83760	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Mechanism Patrol Inspection	General Comments		
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Counter Readings	General Comments		
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Counter Readings	Follow-up Action Required?	n	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Fault Operations A Ø	0	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Operations This Read AM	0	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Switching Operations	0	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Unknown Operations	0	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	9 Month Operations	1	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Amps A Ø	49.0	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Amps B Ø	58.0	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Amps C Ø	42.0	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Patrol Inspection	Bushing Condition	Good	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Tank Paint Condition	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Grounds in Place?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	General Comments		
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Foundation Condition	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Follow-up Action Required?	n	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	K0031	BreakerVacuum	069-2237	VCB Patrol Inspection	Bushing Condition	Good	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Fault Operations A Ø	0	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Fault Operations B Ø	0	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Fault Operations C Ø	0	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	9 Months Operations	0	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0384	BreakerAirMagnetic	GA-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Fault Operations Ground	0	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Patrol Inspection	Follow-up Action Required?	n	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Follow-up Action Required?	n	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Patrol Inspection	Foundation Condition	Good	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Patrol Inspection	General Comments		
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	General Comments		
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Patrol Inspection	Grounds in Place?	y	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Maintenance Operations	0	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Operations Counter AF	188	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Operations Counter AL	189	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Operations This Read Vac	1	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Switching Operations	1	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Patrol Inspection	Tank Paint Condition	Good	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	BK001434	BreakerVacuum	855-0395	VCB Readings	Unknown Operations	0	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Counter Readings	LTC Max Tap Position	1R	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Counter Readings	LTC Current Tap Position	7L	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Counter Readings	LTC As Left Counter	35287	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Counter Readings	LTC As Found Counter	35275	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Mechanism Patrol Inspection	General Comments		
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Counter Readings	General Comments		
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	M0043	LTCMechanism	855-1	LTC Counter Readings	Follow-up Action Required?	n	
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/17/2020 15:37	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	9 Month Operations	4	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	Ambient Temp	50	*F
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	General Comments		
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	Vegetation	None	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	YD000618	Yard	GA-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	9 Months Operations	0	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	BCH000102	Charger	GA-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	BCH000102	Charger	GA-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	BCH000102	Charger	GA-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	BCH000102	Charger	GA-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	BCH000102	Charger	GA-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.8	VDC
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	BCH000102	Charger	GA-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.8	VDC
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	BCH000102	Charger	GA-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Amps A Ø	180.0	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Amps B Ø	200.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Amps C Ø	200.0	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Fault Operations A Ø	0	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Fault Operations B Ø	0	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Fault Operations C Ø	0	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Fault Operations Ground	0	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Follow-up Action Required?	n	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Patrol Inspection	General Comments		
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	General Comments		
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Maintenance Operations	0	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Operations Counter AF	99933	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	LB0385	BreakerAirMagnetic	GA-3	AMCB Readings	Operations Counter AL	99933	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	General Comments		
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	Vegetation	None	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	454	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Counter Readings	LTC Min Tap Position	9L	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Counter Readings	LTC Max Tap Position	6L	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Readings	Oil Temp Present	15	°C
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Readings	Oil Temp Max	32	°C
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/17/2020 16:38	Distribution	Harrogate Quarterly Inspection	YD000031	Yard	855-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Counter Readings	LTC As Left Counter	495449	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Counter Readings	LTC As Found Counter	495449	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Counter Readings	General Comments		
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	SWG000075	Switchgear	GA-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	PN68	LTCMechanism	GA-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
11/17/2020 10:39	Distribution	Gaulbert Quarterly Inspection	PN68	WithLTC	GA-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/18/2020 5:34	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Amps C Ø	8.6	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Amps B Ø	9.3	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Amps A Ø	7.4	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	General Comments		
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	General Comments		
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Readings	General Comments		
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Readings	Non LTC Totalizer Reading	617.04	kw
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Readings	Totalizer Meter Multiplier	3600	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Readings	Oil Temp Max	50	°C
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Readings	Oil Temp Present	28	°C
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Readings	Totalizer Meter Reading	.5142	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	General Comments		
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Operations Counter	286	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Bushing Condition	Good	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Follow-up Action Required?	n	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Foundation Condition	Good	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	General Comments		
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Grounds in Place?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0061	BreakerVacuum	379-4614	VCB Patrol Inspection	Tank Paint Condition	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Readings	Oil Temp Max	40	°C
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Readings	Oil Temp Present	21	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Readings	Oil Temp Max	39	°C
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Readings	LTC Totalizer Reading	2257.20	kw
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Readings	General Comments		
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	General Comments		
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	2854	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Counter Readings	LTC Min Tap Position	8L	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1R	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Counter Readings	LTC Current Tap Position	3L	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Counter Readings	LTC As Left Counter	19637	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Counter Readings	LTC As Found Counter	19637	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	45	°C
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	45	°C
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	45	°C
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	General Comments		
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Readings	General Comments		
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	71.00	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Readings	Oil Temp Max	62	°C
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Readings	Oil Temp Present	28	°C
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Adequate	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	M0010	NonLTC	880-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Adequate	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	B0468	WithLTC	380-1	LTC Transformer Readings	Totalizer Meter Reading	.6270	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Counter Readings	General Comments		
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	C0173	NonLTC	880-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	PN41	LTCMechanism	FO-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	MX0491	RecloserHydraulic	380-0766	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	General Comments	Added nitrogen.	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Readings	General Comments		
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	General Comments		
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	FE000659	Fence	GO-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	Ambient Temp	56	*F
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	General Comments		
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	Vegetation	None	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	YD000664	Yard	GO-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Unknown Operations	0	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	n	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	General Comments	some top rail and post showing signs of rust as well as fabric	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	FE000016	Fence	880-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Readings	Totalizer Meter Reading	.0288	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Readings	Oil Temp Present	22	*C
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Readings	Oil Temp Max	35	*C
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	34.56	kw
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	O0212	NonLTC	356-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	MX0491	RecloserHydraulic	380-0766	Recloser Hydraulic Patrol Inspection	Amps A Ø	.1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	MX0491	RecloserHydraulic	380-0766	Recloser Hydraulic Patrol Inspection	Amps B Ø	1.1	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	MX0491	RecloserHydraulic	380-0766	Recloser Hydraulic Patrol Inspection	Amps C Ø	3.3	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	MX0491	RecloserHydraulic	380-0766	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	MX0491	RecloserHydraulic	380-0766	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	MX0491	RecloserHydraulic	380-0766	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	MX0491	RecloserHydraulic	380-0766	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	MX0491	RecloserHydraulic	380-0766	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	MX0491	RecloserHydraulic	380-0766	Recloser Hydraulic Patrol Inspection	General Comments		
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	MX0491	RecloserHydraulic	380-0766	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	MX0491	RecloserHydraulic	380-0766	Recloser Hydraulic Patrol Inspection	Operations Counter	275	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	MX0491	RecloserHydraulic	380-0766	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Maintenance Operations	0	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Operations Counter AF	385	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Operations Counter AL	385	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Operations This Read AM	0	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Switching Operations	0	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Unknown Operations	0	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Counter Readings	Follow-up Action Required?	n	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Counter Readings	General Comments		
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Mechanism Patrol Inspection	General Comments		
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Counter Readings	LTC As Found Counter	374695	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	General Comments		
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	Vegetation	None	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Counter Readings	LTC As Left Counter	374702	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Counter Readings	LTC Current Tap Position	Neutral	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Counter Readings	LTC Max Tap Position	2R	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Counter Readings	LTC Min Tap Position	8L	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Counter Readings	LTC Operations Since Last Insp	820	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Readings	General Comments		
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	PN43	WithLTC	GO-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Switching Operations	0	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Operations This Read AM	0	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Operations Counter AL	288	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Operations Counter AF	288	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Maintenance Operations	0	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	General Comments		
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Patrol Inspection	General Comments		
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Follow-up Action Required?	n	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Fault Operations Ground	0	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Fault Operations C Ø	0	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Fault Operations B Ø	0	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Fault Operations A Ø	0	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Amps C Ø	20.0	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Amps B Ø	40.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Amps A Ø	20.0	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0368	BreakerAirMagnetic	FO-3	AMCB Readings	9 Months Operations	0	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	YD000168	Yard	380-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	9 Months Operations	1	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Amps A Ø	150.0	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Amps B Ø	210.0	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Amps C Ø	270.0	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Fault Operations A Ø	0	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Fault Operations B Ø	0	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Fault Operations C Ø	0	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Fault Operations Ground	0	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	Follow-up Action Required?	n	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Patrol Inspection	General Comments		
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0392	BreakerAirMagnetic	GO-2	AMCB Readings	General Comments		
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	General Comments		
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Grounds in Place?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Tank Paint Condition	Good	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Readings	General Comments		
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	General Comments	Added nitrogen	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Readings	LTC Totalizer Reading	8236.80	kw
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Readings	Oil Temp Max	31	°C
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Readings	Oil Temp Present	31	°C
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Readings	Totalizer Meter Reading	.8580	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Readings	Winding Temp Max	40	°C
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Readings	Winding Temp Present	23	°C
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Readings	Oil Temp Present	24	°C
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Readings	Oil Temp Max	48	°C
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Tank Paint Condition	Good	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Grounds in Place?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	General Comments		
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Foundation Condition	Good	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Follow-up Action Required?	n	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	DB0063	BreakerVacuum	379-4613	VCB Patrol Inspection	Bushing Condition	Good	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Grounds in Place?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	General Comments		
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Foundation Condition	Good	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Follow-up Action Required?	n	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Bushing Condition	Good	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	General Comments		
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Readings	General Comments		
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	M0012	NonLTC	880-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	General Comments		
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	FE000064	Fence	380-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	LTCC000354	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	LTCC000354	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	LTCC000354	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	LTCC000354	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	LTCC000354	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	LTCC000354	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	LTCC000354	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	LTCC000354	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	60	Seconds
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	40	°C
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Counter Readings	Follow-up Action Required?	n	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Counter Readings	General Comments		
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Mechanism Patrol Inspection	General Comments		
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Counter Readings	LTC As Found Counter	106587	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Foundation Condition	Good	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Follow-up Action Required?	n	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	KB0065	BreakerVacuum	379-4615	VCB Patrol Inspection	Bushing Condition	Good	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	O0238	WithLTC	379-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	Totalizer Meter Reading	.3290	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	Totalizer Meter Multiplier	2400	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	Oil Temp Present	16	°C
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	Oil Temp Max	50	°C
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	LTC Totalizer Reading	789.60	kw
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	General Comments		
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	General Comments		
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	Follow-up Action Required?	n	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	General Comments		
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	General Comments		
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	LTC Totalizer Reading	1371.60	kw
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	Oil Temp Max	47	°C
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	Oil Temp Present	27	°C
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	141	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Counter Readings	LTC Min Tap Position	12L	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Counter Readings	LTC Max Tap Position	5L	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6L	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Counter Readings	LTC As Left Counter	339414	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Counter Readings	LTC As Found Counter	339414	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Counter Readings	General Comments		
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	PN43	LTCMechanism	GO-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	Totalizer Meter Multiplier	1800	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	Totalizer Meter Reading	.7620	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	WLT Bushing Dynamic Health	0.00	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	General Comments	Vegetation needs cut. Growing inside of fence. Needs more gravel.	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	General Comments		
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Follow-up Action Required?	y	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	ST000063	Structure	356-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	FE000058	Fence	356-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	General Comments		
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Readings	General Comments		
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Readings	Non LTC Totalizer Reading	284.40	kw
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Readings	Oil Temp Max	40	°C
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Readings	Oil Temp Present	17	°C
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Readings	Totalizer Meter Reading	.2370	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	LTCC000078	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	LTCC000078	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	LTCC000078	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	LTCC000078	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	LTCC000078	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.8	VAC
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	LTCC000078	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	LTCC000078	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	LTCC000078	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	60	Seconds
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Tank Paint Condition	Good	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	K0012	BreakerVacuum	379-0772	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	General Comments		
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Readings	General Comments		
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	71.00	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Readings	Oil Temp Max	45	°C
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Readings	Oil Temp Present	19	°C
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	General Comments		
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Readings	General Comments		
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Readings	Oil Temp Max	45	°C
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Readings	Oil Temp Present	20	°C
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	M0008	NonLTC	519-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	General Comments	Vegetation needs to be cut.	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	General Comments	Barb wire, and fence fabric is looking rusty .	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	FE000176	Fence	519-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	Ambient Temp	37	*F
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	333	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Amps A Ø	1.4	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Amps B Ø	1.6	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Amps C Ø	.8	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	209	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	299	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Switching Operations	0	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Operations This Read Vac	0	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Operations Counter AL	123	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Operations Counter AF	123	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Maintenance Operations	0	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Grounds in Place?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	General Comments		
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	General Comments		
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Foundation Condition	Good	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Follow-up Action Required?	n	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Fault Operations Ground	0	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Fault Operations C Ø	0	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Fault Operations B Ø	0	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Fault Operations A Ø	0	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Bushing Condition	Good	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Amps C Ø	300.0	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Amps B Ø	300.0	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	Vegetation	None	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Amps A Ø	300.0	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	9 Month Operations	0	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Counter Readings	LTC Operations Since Last Insp	1111	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Counter Readings	LTC Min Tap Position	11L	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Counter Readings	LTC Current Tap Position	6L	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Counter Readings	LTC As Left Counter	154156	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Counter Readings	LTC As Found Counter	154151	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Mechanism Patrol Inspection	General Comments		
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Counter Readings	General Comments		
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	B0468	LTCMechanism	380-1	LTC Counter Readings	Follow-up Action Required?	n	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Counter Readings	LTC Operations Since Last Insp	872	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Counter Readings	LTC Min Tap Position	7L	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Counter Readings	LTC Max Tap Position	2R	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Counter Readings	LTC Current Tap Position	2L	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Counter Readings	LTC As Left Counter	103970	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Counter Readings	LTC As Found Counter	103962	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Mechanism Patrol Inspection	General Comments		
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Counter Readings	General Comments		
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Counter Readings	Follow-up Action Required?	n	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	General Comments		
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	Vegetation	None	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	General Comments		
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	YD000669	Yard	FO-Yard	Yard Patrol Inspection	Ambient Temp	45	*F
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	General Comments		
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	FE000662	Fence	FO-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	YD000174	Yard	519-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	ST000181	Structure	519-Structure	Structure Patrol Inspection	General Comments	recloser bypass fuses ok...highside fuse is frayed	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	All Identified and Legible?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	General Comments		
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	434	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	Amps A Ø	.4	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	Amps B Ø	.6	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	Amps C Ø	1.1	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	405	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	185	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	General Comments		
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	MX0371	RecloserHydraulic	356-4627	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Counter Readings	LTC As Left Counter	106589	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Counter Readings	LTC Current Tap Position	1L	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Counter Readings	LTC Max Tap Position	7R	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Counter Readings	LTC Min Tap Position	5L	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Counter Readings	LTC Operations Since Last Insp	767	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	O0238	LTCMechanism	379-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	45	°C
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	35	°C
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	55	°C
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	40	°C
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	45	°C
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Readings	Oil Temp Present	35	°C
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Readings	Oil Temp Max	45	°C
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	10.0	psi
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	General Comments	Nitro pressure gauge is at past 10 psi mark. Tried to bleed off but would not bleed off.	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Readings	General Comments		
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	PN41	WithLTC	FO-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	General Comments		
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	9 Months Operations	0	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Amps A Ø	120.0	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Amps B Ø	50.0	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Amps C Ø	100.0	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Fault Operations A Ø	0	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Fault Operations B Ø	0	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Fault Operations C Ø	0	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Fault Operations Ground	0	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Follow-up Action Required?	n	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Patrol Inspection	General Comments		
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	General Comments		
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Maintenance Operations	0	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Operations Counter AF	446	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Operations Counter AL	446	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Operations This Read AM	0	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Switching Operations	0	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0393	BreakerAirMagnetic	GO-3	AMCB Readings	Unknown Operations	0	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	FE000175	Fence	379-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Readings	Unknown Operations	0	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	MB0176	BreakerVacuum	379-1	VCB Patrol Inspection	Tank Paint Condition	Good	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	ST000123	Structure	379-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	General Comments	the back right corner of fence is a foot off ground....left corner post of station is washing out	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Ambient Temp	48	*F
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	General Comments		
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Vegetation	None	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	MX0302	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	MX0302	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	MX0302	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	24	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	MX0302	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	MX0302	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	MX0302	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	MX0302	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	MX0302	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Ambient Temp	55	*F
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	Vegetation	None	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	General Comments		
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	YD000019	Yard	880-Yard	Yard Patrol Inspection	Ambient Temp	53	*F
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	General Comments		
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Operations Counter	12	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Tank Leaks	None	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	General Comments	Vegetation needs to be cut. Growing inside of the substation.	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Regulator As Left Counter	111226	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	1124.3	volts
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Vegetation	Needs Attention	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	YD000058	Yard	356-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	MX0302	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	CH000475	ControlHouse	GO-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	BAT001437	Battery	FO-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	BAT001437	Battery	FO-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	72	*F
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	BAT001437	Battery	FO-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	BAT001437	Battery	FO-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	BAT001437	Battery	FO-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	BAT001437	Battery	FO-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	BAT001437	Battery	FO-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #"'s
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	9 Months Operations	0	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	Ambient Temp	50	*F
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	BAT001432	Battery	GO-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	BAT001432	Battery	GO-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	76	*F
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	BAT001432	Battery	GO-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	BAT001432	Battery	GO-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	BAT001432	Battery	GO-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	BAT001432	Battery	GO-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	BAT001432	Battery	GO-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #"'s
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	BAT001432	Battery	GO-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	BAT001432	Battery	GO-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	BAT001432	Battery	GO-Battery Bank	Battery Patrol Inspection	General Comments		
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	BAT001432	Battery	GO-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	BAT001432	Battery	GO-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	General Comments		
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Regulator As Left Counter	107668	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	LTCC000810	LTCControl	380-1	LTC Control Insp	All Connections OK?	y	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	LTCC000810	LTCControl	380-1	LTC Control Insp	Follow-up Action Required?	n	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	LTCC000810	LTCControl	380-1	LTC Control Insp	General Comments		
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	LTCC000810	LTCControl	380-1	LTC Control Insp	LTC Operation Checked?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Regulator As Left Counter	370644	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	LTCC000810	LTCControl	380-1	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	LTCC000810	LTCControl	380-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	LTCC000810	LTCControl	380-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	LTCC000810	LTCControl	380-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	122.9	volts
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	General Comments		
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1071	Regulator	356-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Amps A Ø	95.3	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Amps B Ø	98.0	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Amps C Ø	86.2	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	General Comments		
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Operations Counter	123	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	MX0474	RecloserHydraulic	380-4630	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	General Comments		
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Trash Emptied?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	General Comments		
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	CH000475	ControlHouse	GO-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	CH000475	ControlHouse	GO-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	CH000475	ControlHouse	GO-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	CH000475	ControlHouse	GO-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	CH000475	ControlHouse	GO-Battery Control House	Control House Patrol Inspection	General Comments		
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	CH000475	ControlHouse	GO-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	MX0302	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	MX0302	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	15.8	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	MX0302	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	16.1	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	MX0302	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	15.2	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	194	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	210	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	21.6	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	23.6	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	22.3	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	DX0160	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	145	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	9 Months Operations	0	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Current Tap Position	Neutral	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	General Comments		
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Min Tap Position	4L	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Regulator As Left Counter	296712	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Current Tap Position	2R	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0931	Regulator	880-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	BAT001437	Battery	FO-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	BAT001437	Battery	FO-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	BAT001437	Battery	FO-Battery Bank	Battery Patrol Inspection	General Comments		
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	BAT001437	Battery	FO-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	BAT001437	Battery	FO-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	CH000475	ControlHouse	GO-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	CH000475	ControlHouse	GO-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	General Comments		
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Current Tap Position	Neutral	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	SWG000069	Switchgear	GO-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Follow-up Action Required?	y	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	General Comments	Drag hands dont work.	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Max Tap Position	3L	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Min Tap Position	3L	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Regulator As Left Counter	85468	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1021	Regulator	356-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Regulator As Left Counter	128040	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	CH000213	ControlHouse	379-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	General Comments		
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	BAT001395	Battery	379-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	BAT001395	Battery	379-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	9 Months Operations	0	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Amps A Ø	30.0	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Amps B Ø	40.0	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Amps C Ø	30.0	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Fault Operations A Ø	0	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Fault Operations B Ø	0	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Fault Operations C Ø	0	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Fault Operations Ground	0	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Follow-up Action Required?	n	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Patrol Inspection	General Comments		
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	General Comments		
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Maintenance Operations	0	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Operations Counter AF	372	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Operations Counter AL	372	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Operations This Read AM	0	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Switching Operations	0	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0367	BreakerAirMagnetic	FO-2	AMCB Readings	Unknown Operations	0	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	BAT001395	Battery	379-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	BAT001395	Battery	379-Battery Bank	Battery Patrol Inspection	General Comments		
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	BAT001395	Battery	379-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	BAT001395	Battery	379-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	BAT001395	Battery	379-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	BAT001395	Battery	379-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	BAT001395	Battery	379-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	BAT001395	Battery	379-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	BAT001395	Battery	379-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	BAT001395	Battery	379-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	62	°F
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	BAT001395	Battery	379-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	BCH001339	Charger	FO-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	BCH001339	Charger	FO-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	BCH001339	Charger	FO-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	BCH001339	Charger	FO-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	BCH001339	Charger	FO-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	BCH000024	Charger	GO-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	BCH000024	Charger	GO-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.7	VDC
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	BCH000024	Charger	GO-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.7	VDC
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	BCH000024	Charger	GO-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	BCH000024	Charger	GO-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	BCH000024	Charger	GO-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	BCH001339	Charger	FO-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.7	VDC
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	BCH001339	Charger	FO-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.7	VDC
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	BCH001339	Charger	FO-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Tank Leaks	Seeping	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Regulator As Left Counter	167301	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.5	volts
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	General Comments		
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	ST000018	Structure	880-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Unknown Operations	0	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Switching Operations	0	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Operations This Read AM	0	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Operations Counter AL	472	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Operations Counter AF	472	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Maintenance Operations	0	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	General Comments		
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Patrol Inspection	General Comments		
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Follow-up Action Required?	n	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	SWG000034	Switchgear	FO-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Current Tap Position	1R	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	BCH001321	Charger	379-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	BCH001321	Charger	379-Battery Charger	Battery Charger Patrol Insp	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	BCH001321	Charger	379-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	BCH001321	Charger	379-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	BCH001321	Charger	379-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	BCH001321	Charger	379-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	BCH001321	Charger	379-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	BCH001321	Charger	379-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	General Comments		
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Regulator As Left Counter	252644	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	BAT001395	Battery	379-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0642	Regulator	880-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	CH000457	ControlHouse	FO-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Operations Counter AL	99955	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Operations Counter AF	99955	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Maintenance Operations	0	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	General Comments		
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Patrol Inspection	General Comments		
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Follow-up Action Required?	n	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Fault Operations Ground	0	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Fault Operations C Ø	0	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Fault Operations B Ø	0	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Fault Operations A Ø	0	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	LTCC000763	LTCControl	519-2	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Tank Leaks	None	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Operations Counter	24	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	General Comments		
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Amps C Ø	6.0	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Amps B Ø	8.0	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Amps A Ø	4.0	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	LTCC000763	LTCControl	519-2	LTC Control Insp	LTC Operation Checked?	y	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	LTCC000763	LTCControl	519-2	LTC Control Insp	General Comments		
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	LTCC000763	LTCControl	519-2	LTC Control Insp	Follow-up Action Required?	n	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	LTCC000763	LTCControl	519-2	LTC Control Insp	All Connections OK?	y	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Amps B Ø	25.0	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Amps A Ø	25.0	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	General Comments		
11/16/2020 10:35	Distribution	Bear Branch Quarterly Inspection	ST000175	Structure	380-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	Vegetation	None	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	General Comments		
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/17/2020 5:27	Distribution	Esserville Quarterly Inspection	YD000119	Yard	379-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Amps A Ø	23.0	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Amps B Ø	4.0	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Amps C Ø	16.0	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
11/16/2020 12:12	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Amps C Ø	20.0	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Amps B Ø	30.0	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Amps A Ø	40.0	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Regulator As Left Counter	30501	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/16/2020 13:37	Distribution	Straight Creek Quarterly Inspection	R0643	Regulator	880-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	General Comments		
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/16/2020 12:34	Distribution	Blackwood Quarterly Inspection	R1131	Regulator	356-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Fault Operations Ground	0	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Fault Operations C Ø	0	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Fault Operations B Ø	0	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Fault Operations A Ø	0	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	CH000457	ControlHouse	FO-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	CH000457	ControlHouse	FO-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	CH000457	ControlHouse	FO-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	CH000457	ControlHouse	FO-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	CH000457	ControlHouse	FO-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	CH000457	ControlHouse	FO-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	CH000457	ControlHouse	FO-Battery Control House	Control House Patrol Inspection	General Comments		
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	CH000457	ControlHouse	FO-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Operations This Read AM	0	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Switching Operations	0	
11/16/2020 11:04	Distribution	Forty Fourth Street Quarterly Inspection	LB0366	BreakerAirMagnetic	FO-1	AMCB Readings	Unknown Operations	0	
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	LTCC000763	LTCControl	519-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	LTCC000763	LTCControl	519-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/16/2020 10:58	Distribution	Crockett Quarterly Inspection	LTCC000763	LTCControl	519-2	LTC Control Insp	VRR Time Delay	60	Seconds
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Amps C Ø	25.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/16/2020 21:21	Distribution	Goss Quarterly Inspection	LB0391	BreakerAirMagnetic	GO-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	General Comments		
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Readings	General Comments		
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Readings	LTC Totalizer Reading	627.84	kw
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Readings	Oil Temp Max	52	°C
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Readings	Oil Temp Present	36	°C
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	Oil Temp Max	45	°C
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Readings	Totalizer Meter Reading	.2616	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Readings	Totalizer Meter Multiplier	2400	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	Oil Temp Present	25	°C
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	Winding Temp Present	25	°C
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	Winding Temp Max	40	°C
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	Totalizer Meter Reading	.7089	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	Totalizer Meter Multiplier	15240	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	LTC Totalizer Reading	10803.64	kw
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	General Comments		
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	Follow-up Action Required?	n	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	General Comments		
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	9 Month Operations	2	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Amps A Ø	339.0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Amps B Ø	359.0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Amps C Ø	417.0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Fault Operations B Ø	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Fault Operations C Ø	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Fault Operations Ground	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Follow-up Action Required?	n	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Patrol Inspection	General Comments		
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	General Comments		
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Maintenance Operations	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Operations Counter AF	249	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Operations Counter AL	249	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Operations This Read Vac	2	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Switching Operations	2	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0239	BreakerVacuum	CW-12KV BUS TIE SEC 1	VCB Readings	Unknown Operations	0	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	General Comments		
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	ST000038	Structure	386-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Vegetation	None	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	General Comments		
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	General Comments		
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	LTCC000548	LTCControl	220-3	LTC Control Insp	VRR Time Delay	30	Seconds
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	LTCC000548	LTCControl	220-3	LTC Control Insp	VRR Base Voltage AL	121.0	VAC
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	LTCC000548	LTCControl	220-3	LTC Control Insp	VRR Base Voltage AF	121.0	VAC
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	LTCC000548	LTCControl	220-3	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	LTCC000548	LTCControl	220-3	LTC Control Insp	LTC Output Voltage Level	120.0	VAC
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	LTCC000548	LTCControl	220-3	LTC Control Insp	LTC Operation Checked?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	LTCC000548	LTCControl	220-3	LTC Control Insp	General Comments		
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	LTCC000548	LTCControl	220-3	LTC Control Insp	Follow-up Action Required?	n	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	LTCC000548	LTCControl	220-3	LTC Control Insp	All Connections OK?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	General Comments		
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	9 Month Operations	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Amps A Ø	200.0	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Amps B Ø	200.0	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Amps C Ø	200.0	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Bushing Condition	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Fault Operations A Ø	0	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Fault Operations B Ø	0	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Fault Operations C Ø	0	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Fault Operations Ground	0	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Follow-up Action Required?	n	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Foundation Condition	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	General Comments		
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	General Comments		
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Grounds in Place?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Maintenance Operations	0	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Operations Counter AF	107	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Operations Counter AL	107	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Operations This Read Vac	0	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Switching Operations	0	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Tank Paint Condition	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Unknown Operations	0	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	ST000650	Structure	OH-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Operations Counter AF	365	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Maintenance Operations	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	General Comments		
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Patrol Inspection	General Comments		
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Follow-up Action Required?	n	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Fault Operations Ground	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Fault Operations C Ø	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Fault Operations B Ø	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Fault Operations A Ø	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Amps C Ø	132.0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Amps B Ø	150.0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Amps A Ø	150.0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	9 Months Operations	8	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	BCH001349	Charger	338-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	BCH001349	Charger	338-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	BCH001349	Charger	338-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	BCH001349	Charger	338-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	BCH001349	Charger	338-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	BCH001349	Charger	338-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	BCH001349	Charger	338-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	BCH001349	Charger	338-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	9 Month Operations	1	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Amps A Ø	100.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Amps B Ø	100.0	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Amps C Ø	100.0	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Bushing Condition	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Fault Operations A Ø	0	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Fault Operations B Ø	0	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Fault Operations C Ø	0	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Fault Operations Ground	0	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Follow-up Action Required?	n	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Foundation Condition	Good	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Fault Operations C Ø	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Fault Operations Ground	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Follow-up Action Required?	n	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Patrol Inspection	General Comments		
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	General Comments		
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Maintenance Operations	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Operations Counter AF	699	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Operations Counter AL	699	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Operations This Read Vac	2	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Switching Operations	2	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Unknown Operations	0	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Operations Counter	164	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	General Comments		
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	MX0171	RecloserHydraulic	386-4404	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Unknown Operations	3	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Switching Operations	0	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Operations This Read Vac	3	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Operations Counter AL	250	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Operations Counter AF	250	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Maintenance Operations	0	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	General Comments		
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Patrol Inspection	General Comments		
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Follow-up Action Required?	n	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Fault Operations Ground	0	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Fault Operations C Ø	0	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Fault Operations B Ø	0	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Fault Operations A Ø	0	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Fault Adjusted Amps C Phase V	33.54	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Fault Adjusted Amps B Phase V	33.54	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Fault Adjusted Amps A Phase V	33.54	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Amps C Ø	85.0	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Amps B Ø	105.0	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Amps A Ø	77.0	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1317	BreakerVacuum	OH-1174	VCB Readings	9 Month Operations	4	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Unknown Operations	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Switching Operations	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Operations This Read AM	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0233	BreakerAirMagnetic	CW-1224	AMCB Readings	Operations Counter AL	365	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Fans Operational?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	General Comments	Still needs updated numbering installed. More animal guard needs to be installed when we have a station outage	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	ST000185	Structure	376-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Vegetation	None	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	General Comments		
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	YD000179	Yard	376-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	General Comments	Brush growing through fence.	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Follow-up Action Required?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	General Comments		
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	General Comments		
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Grounds in Place?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Maintenance Operations	0	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Operations Counter AF	65	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Operations Counter AL	65	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Operations This Read Vac	0	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Switching Operations	0	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Tank Paint Condition	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Unknown Operations	0	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	75.00	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	Winding Temp Present	35	°C
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	General Comments		
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	FE000067	Fence	386-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	Winding Temp Max	50	°C
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	Totalizer Meter Reading	.8964	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	Totalizer Meter Multiplier	15240	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	Oil Temp Present	35	°C
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	Oil Temp Max	50	°C
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	LTC Totalizer Reading	13661.14	kw
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	General Comments		
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	General Comments		
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	Follow-up Action Required?	n	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Amps A Ø	19.0	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Amps B Ø	26.0	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Amps C Ø	28.0	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Bushing Condition	Good	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Fault Operations A Ø	0	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Fault Operations B Ø	0	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Fault Operations C Ø	0	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Fault Operations Ground	0	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Follow-up Action Required?	n	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Foundation Condition	Good	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	General Comments		
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	General Comments		
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Grounds in Place?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Maintenance Operations	0	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Operations Counter AF	185	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Operations Counter AL	186	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Operations This Read Vac	1	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Switching Operations	1	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Patrol Inspection	Tank Paint Condition	Good	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	Unknown Operations	0	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	Vegetation	None	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	General Comments		
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	YD000110	Yard	338-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	M0041	WithLTC	376-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	35	°C
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	58	°C
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	35	°C
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	58	°C
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	21	°C
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	46	°C
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	Oil Temp Present	33	°C
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	Oil Temp Max	56	°C
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1300	psi
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	General Comments		
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LT0310	WithLTC	OH-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	BK000911	BreakerVacuum	338-4609	VCB Readings	9 Month Operations	3	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	45	°C
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	45	°C
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	10	°C
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	10	°C
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	10	°C
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	10	°C
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Counter Readings	LTC Operations Since Last Insp	542	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	-1.0	psi
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Counter Readings	LTC Min Tap Position	10L	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Counter Readings	LTC Max Tap Position	1L	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Counter Readings	LTC Current Tap Position	5L	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Counter Readings	LTC As Left Counter	161722	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Counter Readings	LTC As Found Counter	161722	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Mechanism Patrol Inspection	General Comments		
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Counter Readings	General Comments		
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Counter Readings	Follow-up Action Required?	n	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	SWG000096	Switchgear	CW-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	9 Month Operations	5	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Amps A Ø	137.0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Amps B Ø	151.0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Amps C Ø	133.0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Fault Operations A Ø	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0231	BreakerVacuum	CW-1222	VCB Readings	Fault Operations B Ø	0	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	General Comments		
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Ambient Temp	47	*F
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	General Comments		
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Vegetation	None	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	General Comments		
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	Oil Temp Max	0	°C
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	Oil Temp Present	0	°C
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0061	WithLTC	CW-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Maintenance Operations	0	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Grounds in Place?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	General Comments		
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	General Comments		
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Foundation Condition	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Follow-up Action Required?	n	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Fault Operations Ground	0	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Fault Operations C Ø	0	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Fault Operations B Ø	0	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Fault Operations A Ø	0	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Bushing Condition	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Amps C Ø	0.0	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Amps B Ø	0.0	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Amps A Ø	0.0	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	9 Month Operations	1	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LTCC000543	LTCControl	CW-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LTCC000543	LTCControl	CW-TRANS 2	LTC Control Insp	General Comments		
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LTCC000543	LTCControl	CW-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	LTCC000862	LTCControl	221-3	LTC Control Insp	VRR Time Delay	30	Seconds
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	LTCC000862	LTCControl	221-3	LTC Control Insp	VRR Base Voltage AL	120.0	VAC
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	LTCC000862	LTCControl	221-3	LTC Control Insp	VRR Base Voltage AF	120.0	VAC
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	LTCC000862	LTCControl	221-3	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	LTCC000862	LTCControl	221-3	LTC Control Insp	LTC Output Voltage Level	120.0	VAC
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	LTCC000862	LTCControl	221-3	LTC Control Insp	LTC Operation Checked?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	LTCC000862	LTCControl	221-3	LTC Control Insp	General Comments		
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	LTCC000862	LTCControl	221-3	LTC Control Insp	Follow-up Action Required?	n	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	LTCC000862	LTCControl	221-3	LTC Control Insp	All Connections OK?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	LTCC000861	LTCControl	221-2	LTC Control Insp	VRR Time Delay	30	Seconds
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	LTCC000861	LTCControl	221-2	LTC Control Insp	VRR Base Voltage AL	120.0	VAC
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	LTCC000861	LTCControl	221-2	LTC Control Insp	VRR Base Voltage AF	120.0	VAC
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	LTCC000861	LTCControl	221-2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	LTCC000861	LTCControl	221-2	LTC Control Insp	LTC Output Voltage Level	119.0	VAC
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	LTCC000861	LTCControl	221-2	LTC Control Insp	LTC Operation Checked?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	LTCC000861	LTCControl	221-2	LTC Control Insp	General Comments		
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	LTCC000861	LTCControl	221-2	LTC Control Insp	Follow-up Action Required?	n	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	LTCC000861	LTCControl	221-2	LTC Control Insp	All Connections OK?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	LTCC000860	LTCControl	221-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	LTCC000860	LTCControl	221-1	LTC Control Insp	VRR Base Voltage AL	120.0	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	LTCC000860	LTCControl	221-1	LTC Control Insp	VRR Base Voltage AF	120.0	VAC
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	LTCC000860	LTCControl	221-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	LTCC000860	LTCControl	221-1	LTC Control Insp	LTC Output Voltage Level	120.0	VAC
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	LTCC000860	LTCControl	221-1	LTC Control Insp	LTC Operation Checked?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	9 Month Operations	1	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Amps A Ø	650.0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Amps B Ø	650.0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Amps C Ø	650.0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Fault Operations Ground	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Patrol Inspection	General Comments		
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	General Comments		
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Maintenance Operations	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Operations Counter AF	204	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Operations Counter AL	204	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Operations This Read Vac	1	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Switching Operations	1	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0241	BreakerVacuum	CW-12KV TR 1	VCB Readings	Unknown Operations	0	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	1313	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	1321	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	8	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	8	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	LTCC000700	LTCControl	338-1	LTC Control Insp	VRR Time Delay	60	Seconds
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	LTCC000700	LTCControl	338-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	LTCC000700	LTCControl	338-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	LTCC000700	LTCControl	338-1	LTC Control Insp	LTC Output Voltage Level	124.9	VAC
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	LTCC000700	LTCControl	338-1	LTC Control Insp	LTC Operation Checked?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	LTCC000700	LTCControl	338-1	LTC Control Insp	General Comments		
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	LTCC000700	LTCControl	338-1	LTC Control Insp	Follow-up Action Required?	n	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	LTCC000700	LTCControl	338-1	LTC Control Insp	All Connections OK?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Unknown Operations	0	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Tank Paint Condition	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Switching Operations	0	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Operations This Read Vac	0	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Operations Counter AL	99872	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Operations Counter AF	99872	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	LTCC000860	LTCControl	221-1	LTC Control Insp	General Comments		
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	LTCC000860	LTCControl	221-1	LTC Control Insp	Follow-up Action Required?	n	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	LTCC000860	LTCControl	221-1	LTC Control Insp	All Connections OK?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Unknown Operations	2	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Switching Operations	0	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Operations This Read Vac	2	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Operations Counter AL	184	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Operations Counter AF	184	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	General Comments		
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Patrol Inspection	General Comments		
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Follow-up Action Required?	n	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Fault Operations Ground	0	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Fault Operations C Ø	0	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Fault Operations B Ø	0	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Fault Operations A Ø	0	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Fault Adjusted Amps C Phase V	22.36	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Fault Adjusted Amps B Phase V	22.36	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Fault Adjusted Amps A Phase V	22.36	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Amps C Ø	317.0	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Amps B Ø	296.0	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Amps A Ø	319.0	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1316	BreakerVacuum	OH-1173	VCB Readings	9 Month Operations	5	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	9 Month Operations	2	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Amps A Ø	201.0	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Amps B Ø	208.0	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Amps C Ø	206.0	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Fault Operations A Ø	0	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Fault Operations B Ø	0	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Fault Operations C Ø	0	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Fault Operations Ground	0	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Follow-up Action Required?	n	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Patrol Inspection	General Comments		
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	General Comments		
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Maintenance Operations	0	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Operations Counter AF	189	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Operations Counter AL	189	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Unknown Operations	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Switching Operations	1	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Operations This Read AM	1	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Operations Counter AL	2063	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Operations Counter AF	2063	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Maintenance Operations	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	General Comments		
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Patrol Inspection	General Comments		
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Follow-up Action Required?	n	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Fault Operations Ground	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Fault Operations C Ø	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Fault Operations B Ø	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Fault Operations A Ø	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	General Comments		
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	UG Pothead Condition Good?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Amps C Ø	0.0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Amps B Ø	0.0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Amps A Ø	0.0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0238	BreakerAirMagnetic	CW-1229	AMCB Readings	9 Months Operations	1	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	General Comments		
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	PF000077	PowerFuse	CW-STA SET NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	LTCC000204	LTCControl	220-Offline-Distribution	LTC Control Insp	General Comments		
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	LTCC000204	LTCControl	220-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	LTCC000204	LTCControl	220-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	General Comments		
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Readings	General Comments		
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Readings	LTC Totalizer Reading	5846.40	kw
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Readings	Oil Temp Max	68	°C
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Readings	Oil Temp Present	40	°C
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Adequate	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Readings	Totalizer Meter Reading	.6090	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	220.00	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	B0413	WithLTC	338-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Unknown Operations	0	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Tank Paint Condition	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Switching Operations	0	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Operations This Read Vac	0	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Operations Counter AL	99919	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Operations Counter AF	99919	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Maintenance Operations	0	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	General Comments		
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	General Comments		
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Foundation Condition	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Follow-up Action Required?	n	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Fault Operations Ground	0	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Fault Operations C Ø	0	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Fault Operations B Ø	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	PF000079	PowerFuse	CW-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	PF000079	PowerFuse	CW-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	PF000078	PowerFuse	CW-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	PF000078	PowerFuse	CW-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	BCH000116	Charger	CW-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	BCH000116	Charger	CW-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	BCH000116	Charger	CW-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	BCH000116	Charger	CW-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	6.0	amps
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	BCH000116	Charger	CW-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	BCH000116	Charger	CW-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	BCH000116	Charger	CW-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	BCH000116	Charger	CW-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	General Comments		
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Vegetation	None	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	General Comments		
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Ambient Temp	54	*F
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	PF000265	PowerFuse	OH-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	PF000265	PowerFuse	OH-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	PF000264	PowerFuse	OH-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	PF000264	PowerFuse	OH-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	PF000080	PowerFuse	CW-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	PF000080	PowerFuse	CW-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	PF000077	PowerFuse	CW-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Counter Readings	General Comments		
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Mechanism Patrol Inspection	General Comments		
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Counter Readings	LTC As Found Counter	945960	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Counter Readings	LTC As Left Counter	945960	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Counter Readings	LTC Current Tap Position	3L	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Counter Readings	LTC Max Tap Position	2L	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Counter Readings	LTC Min Tap Position	10L	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Counter Readings	LTC Operations Since Last Insp	434	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	9 Month Operations	2	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Amps A Ø	160.0	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Amps B Ø	150.0	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Amps C Ø	139.0	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Fault Operations A Ø	0	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Fault Operations B Ø	0	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Fault Operations C Ø	0	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Fault Operations Ground	0	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Follow-up Action Required?	n	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Patrol Inspection	General Comments		
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	General Comments		
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Maintenance Operations	0	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Operations Counter AF	166	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Operations Counter AL	166	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Operations This Read Vac	1	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Switching Operations	0	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1313	BreakerVacuum	OH-1170	VCB Readings	Unknown Operations	1	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	16	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	0.0	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	0.0	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	0.0	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0038	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Bushing Condition	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Amps C Ø	200.0	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Amps B Ø	200.0	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Amps A Ø	200.0	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	9 Month Operations	1	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	30.00	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	Winding Temp Present	30	°C
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	Winding Temp Max	40	°C
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	Totalizer Meter Reading	5181.0000	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	Totalizer Meter Multiplier	15240	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	Oil Temp Present	25	°C
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	Oil Temp Max	45	°C
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	LTC Totalizer Reading	78958440.00	kw
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	General Comments		
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	General Comments		
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Counter Readings	Follow-up Action Required?	n	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	Totalizer Meter Multiplier	15240	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	Totalizer Meter Reading	.8520	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	Winding Temp Max	40	°C
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	Winding Temp Present	30	°C
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Counter Readings	Follow-up Action Required?	n	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Counter Readings	General Comments		
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Mechanism Patrol Inspection	General Comments		
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Counter Readings	LTC As Found Counter	131894	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Counter Readings	LTC As Left Counter	131894	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Counter Readings	LTC Current Tap Position	6L	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Counter Readings	LTC Max Tap Position	5L	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Counter Readings	LTC Min Tap Position	12L	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Counter Readings	LTC Operations Since Last Insp	269	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Counter Readings	Follow-up Action Required?	n	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Counter Readings	General Comments		
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Mechanism Patrol Inspection	General Comments		
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Counter Readings	LTC As Found Counter	95975	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Counter Readings	LTC As Left Counter	95975	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Counter Readings	LTC Current Tap Position	6L	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Counter Readings	LTC Max Tap Position	5L	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Counter Readings	LTC Min Tap Position	12L	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Counter Readings	LTC Operations Since Last Insp	407	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	General Comments		
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Unknown Operations	0	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3774	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	900	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Readings	Oil Temp Present	36	°C
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Readings	Oil Temp Max	43	°C
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	339.66	kw
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Readings	General Comments		
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	C0515	NonLTC	386-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	Follow-up Action Required?	n	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	General Comments		
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	General Comments		
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	LTC Totalizer Reading	12984.48	kw
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	2100	psi
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	Oil Temp Max	43	°C
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	Oil Temp Present	25	°C
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Fault Operations Ground	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Fault Operations C Ø	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Fault Operations B Ø	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Fault Operations A Ø	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Amps C Ø	104.0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Amps B Ø	92.0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Amps A Ø	144.0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	9 Month Operations	8	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	LTCC000686	LTCCControl	951-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	LTCC000686	LTCCControl	951-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	LTCC000686	LTCCControl	951-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	LTCC000686	LTCCControl	951-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	124.9	VAC
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	LTCC000686	LTCCControl	951-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	n	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	LTCC000686	LTCCControl	951-Offline-Distribution	LTC Control Insp	General Comments		
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	LTCC000686	LTCCControl	951-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	LTCC000686	LTCCControl	951-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Ambient Temp	50	*F
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	YD000677	Yard	OH-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	AC/Dist Panels Labeled?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Broom on Site?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	General Comments		
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Panels Dusted?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Trash Emptied?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	CH000210	ControlHouse	OH-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	FE000670	Fence	OH-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	ST000639	Structure	CW-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	General Comments		
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	FE000656	Fence	CW-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Counter Readings	Follow-up Action Required?	n	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Counter Readings	General Comments		
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Mechanism Patrol Inspection	General Comments		
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Counter Readings	LTC As Found Counter	9373	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Counter Readings	LTC As Left Counter	9373	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Counter Readings	LTC Current Tap Position	4L	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Counter Readings	LTC Max Tap Position	2L	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Counter Readings	LTC Min Tap Position	12L	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	40	°C
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	25	°C
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Counter Readings	LTC Operations Since Last Insp	755	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	LTCC000766	LTCControl	221-4	LTC Control Insp	All Connections OK?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	LTCC000766	LTCControl	221-4	LTC Control Insp	Follow-up Action Required?	n	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	LTCC000766	LTCControl	221-4	LTC Control Insp	General Comments		
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	LTCC000766	LTCControl	221-4	LTC Control Insp	LTC Operation Checked?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	LTCC000766	LTCControl	221-4	LTC Control Insp	LTC Output Voltage Level	119.0	VAC
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	LTCC000766	LTCControl	221-4	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	LTCC000766	LTCControl	221-4	LTC Control Insp	VRR Base Voltage AF	120.0	VAC
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	LTCC000766	LTCControl	221-4	LTC Control Insp	VRR Base Voltage AL	120.0	VAC
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	LTCC000766	LTCControl	221-4	LTC Control Insp	VRR Time Delay	30	Seconds
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Unknown Operations	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Switching Operations	1	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Operations This Read Vac	1	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Operations Counter AL	631	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Operations Counter AF	631	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Maintenance Operations	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	General Comments		
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Patrol Inspection	General Comments		
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Readings	Follow-up Action Required?	n	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0234	BreakerVacuum	CW-1225	VCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	LTCC000469	LTCControl	220-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	LTCC000469	LTCControl	220-1	LTC Control Insp	VRR Base Voltage AL	121.0	VAC
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	LTCC000469	LTCControl	220-1	LTC Control Insp	VRR Base Voltage AF	121.0	VAC
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	LTCC000469	LTCControl	220-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	LTCC000469	LTCControl	220-1	LTC Control Insp	LTC Output Voltage Level	120.0	VAC
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	LTCC000469	LTCControl	220-1	LTC Control Insp	LTC Operation Checked?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	LTCC000469	LTCControl	220-1	LTC Control Insp	General Comments		
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	LTCC000469	LTCControl	220-1	LTC Control Insp	Follow-up Action Required?	n	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	LTCC000469	LTCControl	220-1	LTC Control Insp	All Connections OK?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	LTCC000468	LTCControl	220-2	LTC Control Insp	VRR Time Delay	30	Seconds
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	LTCC000468	LTCControl	220-2	LTC Control Insp	VRR Base Voltage AL	121.0	VAC
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	LTCC000468	LTCControl	220-2	LTC Control Insp	VRR Base Voltage AF	121.0	VAC
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	LTCC000468	LTCControl	220-2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	LTCC000468	LTCControl	220-2	LTC Control Insp	LTC Output Voltage Level	120.0	VAC
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	LTCC000468	LTCControl	220-2	LTC Control Insp	LTC Operation Checked?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	LTCC000468	LTCControl	220-2	LTC Control Insp	General Comments		
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	LTCC000468	LTCControl	220-2	LTC Control Insp	Follow-up Action Required?	n	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	LTCC000468	LTCControl	220-2	LTC Control Insp	All Connections OK?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	53	°C
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	70	°C
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	52	°C
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	70	°C
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	46	°C
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	63	°C
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	Oil Temp Present	46	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	Oil Temp Max	63	°C
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	51	°C
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	70	°C
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	General Comments		
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0060	WithLTC	CW-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	Winding Temp Present	45	°C
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	Winding Temp Max	45	°C
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Operations This Read Vac	1	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Switching Operations	0	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1314	BreakerVacuum	OH-1171	VCB Readings	Unknown Operations	1	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1216	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Counter Readings	LTC Min Tap Position	15L	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1R	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Counter Readings	LTC Current Tap Position	10L	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Regulator As Left Counter	267568	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Max Tap Position	5R	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	General Comments		
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Counter Readings	LTC As Left Counter	107000	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Counter Readings	LTC As Found Counter	107000	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Counter Readings	General Comments		
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0060	LTCMechanism	CW-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LTCC000488	LTCControl	OH-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LTCC000488	LTCControl	OH-TRANS 1	LTC Control Insp	General Comments		
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LTCC000488	LTCControl	OH-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0781	Regulator	386-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Regulator As Left Counter	7083	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Max Tap Position	7R	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	General Comments		
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0780	Regulator	386-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	9 Month Operations	1	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	General Comments		
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	General Comments		
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Panels Dusted?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Unknown Operations	0	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Tank Paint Condition	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Switching Operations	0	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Operations This Read Vac	0	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Operations Counter AL	274	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Operations Counter AF	274	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	General Comments		
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	General Comments		
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Operations Counter	460	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	MX0406	RecloserHydraulic	977-Offline-Distribution	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	411	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	MX0406	RecloserHydraulic	977-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Unknown Operations	0	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Tank Paint Condition	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Switching Operations	0	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Operations This Read Vac	0	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Maintenance Operations	0	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Grounds in Place?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	General Comments		
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	General Comments		
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Foundation Condition	Good	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Counter Readings	LTC Max Tap Position	1L	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Counter Readings	LTC Current Tap Position	12L	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Counter Readings	LTC As Left Counter	12713	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Counter Readings	LTC As Found Counter	12713	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Counter Readings	General Comments		
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Bushing Condition	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Amps C Ø	200.0	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Amps B Ø	200.0	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Amps A Ø	200.0	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	9 Month Operations	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	MX0406	RecloserHydraulic	977-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	MX0406	RecloserHydraulic	977-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	MX0406	RecloserHydraulic	977-Offline-Distribution	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	431	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	MX0406	RecloserHydraulic	977-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	MX0406	RecloserHydraulic	977-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	MX0406	RecloserHydraulic	977-Offline-Distribution	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	408	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	MX0406	RecloserHydraulic	977-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	MX0406	RecloserHydraulic	977-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	MX0406	RecloserHydraulic	977-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	MX0406	RecloserHydraulic	977-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	MX0406	RecloserHydraulic	977-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	MX0406	RecloserHydraulic	977-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	FE000844	Fence	338-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	General Comments		
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	ST000115	Structure	338-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	9 Month Operations	1	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1252	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LT0061	LTCMechanism	CW-TRANS 2	LTC Counter Readings	LTC Min Tap Position	16L	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Switching Operations	0	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Tank Paint Condition	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Unknown Operations	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Unknown Operations	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Switching Operations	1	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Operations This Read AM	1	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Operations Counter AL	307	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Operations Counter AF	307	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Maintenance Operations	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	General Comments		
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Patrol Inspection	General Comments		
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Follow-up Action Required?	n	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Fault Operations Ground	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Fault Operations C Ø	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Fault Operations B Ø	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Fault Operations A Ø	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Amps C Ø	20.0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Amps B Ø	20.0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Amps A Ø	20.0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0235	BreakerAirMagnetic	CW-1226	AMCB Readings	9 Months Operations	3	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Unknown Operations	0	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Tank Paint Condition	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Switching Operations	0	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Operations This Read Vac	0	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Operations Counter AL	268	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Operations Counter AF	268	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Maintenance Operations	0	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Grounds in Place?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	General Comments		
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Foundation Condition	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Follow-up Action Required?	n	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Fault Operations C Ø	0	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Counter Readings	Follow-up Action Required?	n	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Counter Readings	General Comments		
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Mechanism Patrol Inspection	General Comments		
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Counter Readings	LTC As Found Counter	139300	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Counter Readings	LTC As Left Counter	139300	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Counter Readings	LTC Current Tap Position	4L	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Counter Readings	LTC Max Tap Position	3L	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	BAT001495	Battery	338-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	BAT001495	Battery	338-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	BAT001495	Battery	338-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	BAT001495	Battery	338-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	BAT001495	Battery	338-Battery Bank	Battery Patrol Inspection	General Comments		
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	BAT001495	Battery	338-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	BAT001495	Battery	338-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	BAT001495	Battery	338-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	BAT001495	Battery	338-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #"'s
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	BAT001495	Battery	338-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	BAT001495	Battery	338-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	BAT001495	Battery	338-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	BAT001495	Battery	338-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	BAT001495	Battery	338-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Counter Readings	LTC Min Tap Position	12L	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Counter Readings	LTC Operations Since Last Insp	396	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Fault Operations Ground	0	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Follow-up Action Required?	n	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Foundation Condition	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	General Comments		
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	General Comments		
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Grounds in Place?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Maintenance Operations	0	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Operations Counter AF	99896	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Operations Counter AL	99896	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Operations This Read Vac	0	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	General Comments		
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Patrol Inspection	General Comments		
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Patrol Inspection	General Comments		
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	General Comments		
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Maintenance Operations	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Operations Counter AF	473	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Operations Counter AL	473	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Operations This Read AM	8	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Switching Operations	8	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Unknown Operations	0	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Fault Operations Ground	0	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	27.00	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	27.00	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	27.00	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Amps C Ø	772.0	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Amps B Ø	801.0	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Amps A Ø	827.0	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	9 Month Operations	1	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Amps A Ø	38.6	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Amps B Ø	16.9	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Amps C Ø	8.6	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	MX0451	RecloserHydraulic	376-0650	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	40	*F
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	BAT001013	Battery	CW-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Fault Operations Ground	0	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Fault Operations C Ø	0	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Fault Operations B Ø	0	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Fault Operations A Ø	0	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Bushing Condition	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Amps C Ø	360.0	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Amps B Ø	360.0	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Amps A Ø	360.0	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Unknown Operations	1	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	CH000034	ControlHouse	338-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Switching Operations	0	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Operations This Read Vac	1	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Operations Counter AL	140	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1312	BreakerVacuum	OH-12KV TR 1	VCB Readings	Operations Counter AF	140	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	9 Months Operations	10	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Amps A Ø	100.0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Amps B Ø	130.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Amps C Ø	180.0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Fault Operations A Ø	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Fault Operations B Ø	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Fault Operations C Ø	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Fault Operations Ground	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0237	BreakerAirMagnetic	CW-1228	AMCB Readings	Follow-up Action Required?	n	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	Oil Temp Present	25	°C
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	Oil Temp Max	25	°C
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	LTC Totalizer Reading	7726.68	kw
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Panels Dusted?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	General Comments		
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	General Comments		
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	Follow-up Action Required?	n	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Fault Operations A Ø	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Fault Operations B Ø	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Fault Operations C Ø	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Fault Operations Ground	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Follow-up Action Required?	n	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Patrol Inspection	General Comments		
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	General Comments		
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Maintenance Operations	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Operations Counter AF	422	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Operations Counter AL	422	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Operations This Read Vac	2	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Switching Operations	2	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Unknown Operations	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	General Comments	heavy on going construction.	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	Winding Temp Present	30	°C
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	Winding Temp Max	30	°C
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	Totalizer Meter Reading	.5070	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	Totalizer Meter Multiplier	15240	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	9 Month Operations	14	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Amps A Ø	71.0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Amps B Ø	90.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Amps C Ø	104.0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0236	BreakerVacuum	CW-1227	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Vegetation	None	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Trash Emptied?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Fault Operations A Ø	0	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Fault Operations B Ø	0	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Fault Operations C Ø	0	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Fault Operations Ground	0	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Follow-up Action Required?	n	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Foundation Condition	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	General Comments		
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	General Comments		
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Grounds in Place?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Maintenance Operations	0	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Operations Counter AF	58	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Operations Counter AL	58	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Operations This Read Vac	0	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Switching Operations	0	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Tank Paint Condition	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Unknown Operations	0	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1049	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	19	°C
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	43	°C
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Counter Readings	LTC Min Tap Position	6L	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Counter Readings	LTC Max Tap Position	13R	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Counter Readings	LTC Current Tap Position	2L	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Counter Readings	LTC As Left Counter	41001	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Counter Readings	LTC As Found Counter	41001	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LT0310	LTCMechanism	OH-TRANS 1	LTC Counter Readings	General Comments		
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Broom on Site?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	CH000141	ControlHouse	CW-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	SWG000190	Switchgear	OH-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	9 Month Operations	1	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Amps A Ø	200.0	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Amps B Ø	200.0	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Amps C Ø	200.0	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Bushing Condition	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Counter Readings	General Comments		
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Mechanism Patrol Inspection	General Comments		
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Counter Readings	LTC As Found Counter	304607	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Counter Readings	LTC As Left Counter	304607	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Counter Readings	LTC Current Tap Position	4L	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Counter Readings	LTC Max Tap Position	2L	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Counter Readings	LTC Min Tap Position	10L	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Counter Readings	LTC Operations Since Last Insp	441	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	Totalizer Meter Multiplier	15240	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	Totalizer Meter Reading	.6944	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	Winding Temp Max	40	°C
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	Winding Temp Present	40	°C
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	LTCC000823	LTCControl	376-1	LTC Control Insp	All Connections OK?	y	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	LTCC000823	LTCControl	376-1	LTC Control Insp	Follow-up Action Required?	n	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	LTCC000823	LTCControl	376-1	LTC Control Insp	General Comments		
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	LTCC000823	LTCControl	376-1	LTC Control Insp	LTC Operation Checked?	y	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	LTCC000823	LTCControl	376-1	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	LTCC000823	LTCControl	376-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	9 Months Operations	5	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Amps A Ø	0.0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Amps B Ø	0.0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Amps C Ø	0.0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	General Comments		
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	General Comments		
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	LTC Totalizer Reading	10582.66	kw
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	Oil Temp Max	45	°C
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	Oil Temp Present	40	°C
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Regulator As Left Counter	341997	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Max Tap Position	5R	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	General Comments		
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Counter Readings	Follow-up Action Required?	n	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	LTCC000823	LTCControl	376-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	LTCC000823	LTCControl	376-1	LTC Control Insp	VRR Time Delay	60	Seconds
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	Winding Temp Present	12	°C
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	Winding Temp Max	20	°C
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	0	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	Oil Temp Present	12	°C
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	Oil Temp Max	24	°C
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	General Comments		
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	R0779	Regulator	386-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Patrol Inspection	General Comments		
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	General Comments		
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Maintenance Operations	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Operations Counter AF	129	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Operations Counter AL	129	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Counter Readings	Follow-up Action Required?	n	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Counter Readings	General Comments		
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Mechanism Patrol Inspection	General Comments		
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Counter Readings	LTC As Found Counter	84589	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Counter Readings	LTC As Left Counter	84590	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Counter Readings	LTC Current Tap Position	5L	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Counter Readings	LTC Max Tap Position	5R	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Counter Readings	LTC Min Tap Position	6L	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Counter Readings	LTC Operations Since Last Insp	193	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	M0041	LTCMechanism	376-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Operations This Read AM	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Switching Operations	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0242	BreakerAirMagnetic	CW-12KV TR 2	AMCB Readings	Unknown Operations	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Ambient Temp	40	°F
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	General Comments	On going construction.	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	YD000661	Yard	CW-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	SWG000120	Switchgear	CW-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	4.31	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	4.31	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Amps C Ø	0.0	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Amps B Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Amps A Ø	0.0	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Counter Readings	Follow-up Action Required?	n	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	4.31	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Counter Readings	General Comments		
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Mechanism Patrol Inspection	General Comments		
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Counter Readings	LTC As Found Counter	43883	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Counter Readings	LTC As Left Counter	43885	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Amps C Ø	0.0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Amps B Ø	0.0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Amps A Ø	0.0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LTCC000219	LTCControl	CW-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LTCC000219	LTCControl	CW-TRANS 1	LTC Control Insp	General Comments		
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LTCC000219	LTCControl	CW-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	9 Month Operations	1	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Counter Readings	LTC Current Tap Position	6L	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	Vegetation	None	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	General Comments	Tree limbs still reaching over fence on right side. Blackberry briars are getting thick on left side and are touching the fence	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/13/2020 13:46	Distribution	Laurel Grove Quarterly Inspection	YD000067	Yard	386-Yard	Yard Patrol Inspection	Ambient Temp	60	*F
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Tank Leaks	None	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Operations Counter	4	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	General Comments		
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	DX0129	RecloserElectronic	376-4649	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	42	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	96.0	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	96.0	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	96.0	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Unknown Operations	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Switching Operations	1	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Operations This Read Vac	1	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Operations Counter AL	247	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Operations Counter AF	247	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Maintenance Operations	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	General Comments		
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Patrol Inspection	General Comments		
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Fault Operations Ground	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Fault Operations C Ø	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Fault Operations B Ø	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Fault Operations A Ø	0	
11/13/2020 12:04	Distribution	Crestwood Quarterly Inspection	LB0232	BreakerVacuum	CW-1223	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Counter Readings	General Comments		
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Unknown Operations	1	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Switching Operations	0	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Operations This Read Vac	1	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Operations Counter AL	155	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Operations Counter AF	155	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Maintenance Operations	0	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	General Comments		
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Patrol Inspection	General Comments		
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Follow-up Action Required?	n	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Patrol Inspection	Follow-up Action Required?	n	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Fault Operations Ground	0	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Fault Operations C Ø	0	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Fault Operations B Ø	0	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	9 Month Operations	1	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Fault Operations A Ø	0	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Amps C Ø	59.0	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Amps B Ø	54.0	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Amps A Ø	59.0	
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/13/2020 8:57	Distribution	Old Henry Quarterly Inspection	LB1315	BreakerVacuum	OH-1172	VCB Readings	9 Month Operations	2	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	13386	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	13386	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	Neutral	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	0	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/13/2020 10:59	Distribution	Addington Quarterly Inspection	FE000180	Fence	376-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Counter Readings	LTC Min Tap Position	14L	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Counter Readings	LTC Operations Since Last Insp	868	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	B0413	LTCMechanism	338-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/13/2020 11:43	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	1007	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	1015	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	2	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
11/13/2020 12:59	Distribution	Norton East Quarterly Inspection	DB0037	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	1	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Unknown Operations	0	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Tank Paint Condition	Good	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Switching Operations	0	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/13/2020 11:13	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Operations This Read Vac	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	9 Month Operations	0	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Amps A Ø	21.0	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Amps B Ø	16.0	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Amps C Ø	24.0	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Bushing Condition	Good	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Fault Operations A Ø	0	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Fault Operations B Ø	0	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Fault Operations C Ø	0	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Fault Operations Ground	0	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Follow-up Action Required?	n	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Foundation Condition	Good	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	General Comments		
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	General Comments		
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Grounds in Place?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Maintenance Operations	6	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Operations Counter AF	187	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Operations Counter AL	188	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Operations This Read Vac	7	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Switching Operations	1	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Tank Paint Condition	Good	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Unknown Operations	0	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	9 Month Operations	1	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Amps A Ø	38.0	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Amps B Ø	34.0	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BCH001317	Charger	337-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Amps A Ø	57.0	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Amps B Ø	75.0	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	Amps C Ø	60.0	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Bushing Condition	Good	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Unknown Operations	0	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Tank Paint Condition	Good	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Switching Operations	0	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Operations This Read Vac	0	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Operations Counter AL	177	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Operations Counter AF	177	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Maintenance Operations	0	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Grounds in Place?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	General Comments		
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	General Comments		
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Foundation Condition	Good	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Follow-up Action Required?	n	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Fault Operations Ground	0	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Fault Operations C Ø	0	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Fault Operations B Ø	0	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Fault Operations A Ø	0	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BK000415	BreakerVacuum	182-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BAT001393	Battery	337-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BAT001393	Battery	337-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BAT001393	Battery	337-Battery Bank	Battery Patrol Inspection	General Comments		
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BAT001393	Battery	337-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BAT001393	Battery	337-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BAT001393	Battery	337-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BAT001393	Battery	337-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BAT001393	Battery	337-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BAT001393	Battery	337-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	CAP000017	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Bushing Condition	Good	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	CAP000017	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	All Connections OK?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BAT001393	Battery	337-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	*F
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BAT001393	Battery	337-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Grounds in Place?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Maintenance Operations	0	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Operations Counter AF	200	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Operations Counter AL	201	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Operations This Read Vac	1	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Amps C Ø	0.0	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Amps B Ø	0.0	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Amps A Ø	0.0	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	9 Month Operations	0	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Unknown Operations	0	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Switching Operations	0	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Operations This Read Vac	0	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Operations Counter AL	179	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Operations Counter AF	179	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Maintenance Operations	0	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Unknown Operations	0	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Patrol Inspection	Tank Paint Condition	Good	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Switching Operations	0	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Operations This Read Vac	0	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Operations Counter AL	249	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Operations Counter AF	249	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Maintenance Operations	0	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Patrol Inspection	Grounds in Place?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	General Comments		
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Patrol Inspection	General Comments		
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Patrol Inspection	Foundation Condition	Good	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Follow-up Action Required?	n	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Amps C Ø	54.0	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Bushing Condition	Good	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	748	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Counter Readings	LTC Min Tap Position	9L	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Counter Readings	LTC Max Tap Position	6R	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Counter Readings	LTC Current Tap Position	7L	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Counter Readings	LTC As Left Counter	53989	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Counter Readings	LTC As Found Counter	53989	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Counter Readings	General Comments		
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0020	LTCMechanism	BB-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Fault Operations A Ø	0	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Fault Operations B Ø	0	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BAT001393	Battery	337-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BAT001393	Battery	337-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Fault Operations C Ø	0	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Fault Operations Ground	0	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Follow-up Action Required?	n	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Foundation Condition	Good	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	General Comments		
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	General Comments		
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Unknown Operations	0	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Switching Operations	0	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Operations This Read Vac	0	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Operations Counter AL	162	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Operations Counter AF	162	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Maintenance Operations	0	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	General Comments	sec 1 is carded	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Patrol Inspection	General Comments		
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Follow-up Action Required?	n	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Fault Operations Ground	0	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Fault Operations C Ø	0	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Fault Operations B Ø	0	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Fault Operations A Ø	0	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000682	BreakerVacuum	BB-12KV TR1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	Winding Temp Present	22	°C
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Counter Readings	LTC Operations Since Last Insp	891	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Counter Readings	LTC Min Tap Position	10L	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Counter Readings	LTC Max Tap Position	2R	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Counter Readings	LTC Current Tap Position	4L	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Counter Readings	LTC As Left Counter	119162	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Counter Readings	LTC As Found Counter	119159	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Mechanism Patrol Inspection	General Comments		
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Counter Readings	General Comments		
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	S0003	LTCMechanism	312-1	LTC Counter Readings	Follow-up Action Required?	n	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Counter Readings	LTC Operations Since Last Insp	1538	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Counter Readings	LTC Min Tap Position	9L	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Counter Readings	LTC Max Tap Position	15R	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Counter Readings	LTC Current Tap Position	4L	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Counter Readings	LTC As Left Counter	135187	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Counter Readings	LTC As Found Counter	135183	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Mechanism Patrol Inspection	General Comments		
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Counter Readings	General Comments		
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	O0232	LTCMechanism	337-1	LTC Counter Readings	Follow-up Action Required?	n	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Fault Operations A Ø	0	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	PF000034	PowerFuse	BB-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	PF000034	PowerFuse	BB-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	PF000034	PowerFuse	BB-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	99995	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	99995	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1164	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	General Comments		
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	General Comments		
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	LTC Totalizer Reading	10500.48	kw
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	Oil Temp Max	40	°C
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	Oil Temp Present	30	°C
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	Totalizer Meter Reading	1.0938	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	S0003	WithLTC	312-1	LTC Transformer Readings	Winding Temp Max	30	°C
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	PF000431	PowerFuse	Retired Distribution	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	CAP000017	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Warning Signs OK?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	CAP000017	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	CAP000017	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Tank Leaks	None	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	CAP000017	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	CAP000017	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	CAP000017	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Grounds in Place?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	CAP000017	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	General Comments		
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	CAP000017	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	CAP000017	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	CAP000017	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Foundation Condition	Good	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	CAP000017	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	CAP000017	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	CAP000017	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	CAP000017	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Capacitor Condition	Good	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	CAP000017	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	CAP000017	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Cap bank CT in Good Condition?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Current Tap Position	1R	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	CAP000017	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	LTCC000920	LTCControl	312-1	LTC Control Insp	All Connections OK?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	LTCC000920	LTCControl	312-1	LTC Control Insp	Follow-up Action Required?	n	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	LTCC000920	LTCControl	312-1	LTC Control Insp	General Comments		
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	LTCC000920	LTCControl	312-1	LTC Control Insp	LTC Operation Checked?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	LTCC000920	LTCControl	312-1	LTC Control Insp	LTC Output Voltage Level	124.8	VAC
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	LTCC000920	LTCControl	312-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	LTCC000920	LTCControl	312-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	LTCC000920	LTCControl	312-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	LTCC000920	LTCControl	312-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000387	BreakerVacuum	337-4640	VCB Readings	9 Month Operations	7	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BCH001317	Charger	337-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BCH001317	Charger	337-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BCH001317	Charger	337-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BCH001317	Charger	337-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BCH001317	Charger	337-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.6	amps
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BCH001317	Charger	337-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	52.9	VDC
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BCH001317	Charger	337-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	52.9	VDC
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	Vegetation	None	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	General Comments		
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	YD000012	Yard	337-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	General Comments		
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	General Comments		
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Min Tap Position	2L	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	ST000011	Structure	337-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	General Comments		
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	General Comments		
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BAT000106	Battery	BB-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	PF000431	PowerFuse	Retired Distribution	Disconnect PowerFuse Inspection	General Comments	OK	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	General Comments		
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	CH000245	ControlHouse	Retired Distribution	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	CH000245	ControlHouse	Retired Distribution	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	CH000245	ControlHouse	Retired Distribution	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	CH000245	ControlHouse	Retired Distribution	Control House Patrol Inspection	General Comments		
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	CH000245	ControlHouse	Retired Distribution	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	CH000245	ControlHouse	Retired Distribution	Control House Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	CH000245	ControlHouse	Retired Distribution	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	CH000245	ControlHouse	Retired Distribution	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	CH000245	ControlHouse	Retired Distribution	Control House Patrol Inspection	Evidence of Insects	None	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	CH000245	ControlHouse	Retired Distribution	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	CH000245	ControlHouse	Retired Distribution	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	CH000245	ControlHouse	Retired Distribution	Control House Patrol Inspection	Control House Lighting OK?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	CH000245	ControlHouse	Retired Distribution	Control House Patrol Inspection	Acceptable Building Appearance?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	CH000245	ControlHouse	Retired Distribution	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Trash Emptied?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	General Comments		
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	9 Month Operations	0	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	PF000035	PowerFuse	BB-12KV TR 1 POT	Disconnect PowerFuse Inspection	Equipment Properly Labeled?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	PF000035	PowerFuse	BB-12KV TR 1 POT	Disconnect PowerFuse Inspection	Follow-up Action Required?	n	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	PF000035	PowerFuse	BB-12KV TR 1 POT	Disconnect PowerFuse Inspection	General Comments	ok	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	PF000430	PowerFuse	Retired Distribution	Disconnect PowerFuse Inspection	Follow-up Action Required?	n	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	PF000430	PowerFuse	Retired Distribution	Disconnect PowerFuse Inspection	General Comments	OK	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Foundation Condition	Good	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	General Comments		
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	General Comments		
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BCH001120	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BCH001120	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	52	*F
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	Ground Connections Intact?	y	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	General Comments		
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	Foundation Condition	Good	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Operations This Read Vac	0	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Operations Counter AL	123	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Operations Counter AF	123	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Maintenance Operations	0	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Grounds in Place?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	General Comments		
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	General Comments		
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Foundation Condition	Good	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Follow-up Action Required?	n	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Fault Operations Ground	0	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Fault Operations C Ø	0	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Fault Operations B Ø	0	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Fault Operations A Ø	0	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	All Identified and Legible?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	General Comments		
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	General Comments		
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	Foundation Condition	Good	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Follow-up Action Required?	n	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Fault Operations Ground	0	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Fault Operations C Ø	0	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Fault Operations B Ø	0	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Fault Operations A Ø	0	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	Bushing Condition	Good	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Amps C Ø	83.0	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Amps B Ø	95.0	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Amps A Ø	94.0	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	9 Month Operations	2	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Fault Operations A Ø	0	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Fault Operations B Ø	0	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	General Comments		
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Maintenance Operations	0	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Grounds in Place?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Fault Operations C Ø	0	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Fault Operations Ground	0	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Unknown Operations	0	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Tank Paint Condition	Good	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Switching Operations	1	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Operations This Read Vac	1	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Operations Counter AL	193	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Operations Counter AF	192	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Maintenance Operations	0	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Grounds in Place?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BAT001298	Battery	312-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Follow-up Action Required?	n	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Foundation Condition	Good	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	General Comments		
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	General Comments		
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Unknown Operations	0	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	ST000082	Structure	182-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Tank Paint Condition	Good	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Switching Operations	1	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Operations This Read Vac	1	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Broom on Site?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	CH000234	ControlHouse	337-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Operations Counter AL	337	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Operations Counter AF	336	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	ANN000008	Annunciator	BB-Annunciator Panel	Annunciator Patrol Inspection	General Comments		
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	ANN000008	Annunciator	BB-Annunciator Panel	Annunciator Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	ANN000008	Annunciator	BB-Annunciator Panel	Annunciator Patrol Inspection	ESOC Received Alarm Test?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	ANN000008	Annunciator	BB-Annunciator Panel	Annunciator Patrol Inspection	Control House Alarm Audible?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	ANN000008	Annunciator	BB-Annunciator Panel	Annunciator Patrol Inspection	All Lights Functioning?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Bushing Condition	Good	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Amps C Ø	160.0	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Amps B Ø	160.0	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Amps A Ø	160.0	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Amps A Ø	48.0	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Amps B Ø	50.0	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Amps C Ø	66.0	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Bushing Condition	Good	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BCH000113	Charger	BB-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BCH000113	Charger	BB-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BCH000113	Charger	BB-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BCH000113	Charger	BB-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BCH000113	Charger	BB-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BCH000113	Charger	BB-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.6	VDC
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BCH000113	Charger	BB-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.6	VDC
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BCH000113	Charger	BB-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Unknown Operations	0	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Patrol Inspection	Tank Paint Condition	Good	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Switching Operations	1	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Operations This Read Vac	1	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0064	BreakerVacuum	312-4645	VCB Readings	Operations Counter AL	163	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BAT001409	Battery	182-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BAT001409	Battery	182-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	58	*F
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BAT001409	Battery	182-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BAT001409	Battery	182-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BAT001409	Battery	182-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Amps B Ø	0.0	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Amps A Ø	0.0	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000681	BreakerVacuum	BB-1103	VCB Readings	9 Month Operations	1	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	9 Month Operations	2	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Unknown Operations	0	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Switching Operations	0	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Operations This Read Vac	0	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BAT001409	Battery	182-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BAT001409	Battery	182-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Operations Counter AL	235	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Operations Counter AF	235	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	Neutral	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BCH001120	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	4.500	millivolts
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Maintenance Operations	0	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	General Comments	checked vc, breaker is open	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Patrol Inspection	General Comments		
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Fault Operations Ground	0	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Fault Operations C Ø	0	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Fault Operations B Ø	0	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BK000005	BreakerVacuum	182-3403	VCB Readings	Fault Operations A Ø	0	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	4L	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	DX0096	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	122.7	volts
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	36377	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Unknown Operations	0	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Tank Paint Condition	Good	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Readings	Switching Operations	0	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	DB0064	BreakerVacuum	337-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	DX0096	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	DX0096	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	DX0096	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	DX0096	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments	Will need painted in the next year or so.	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	DX0096	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	9 Month Operations	16	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	KB0021	BreakerVacuum	312-4646	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BAT001409	Battery	182-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BAT001409	Battery	182-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BAT001409	Battery	182-Battery Bank	Battery Patrol Inspection	General Comments		
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BAT001409	Battery	182-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BAT001409	Battery	182-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BAT001409	Battery	182-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BAT001409	Battery	182-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BCH001328	Charger	182-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BCH001328	Charger	182-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	134.3	VDC
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BCH001328	Charger	182-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	134.3	VDC
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BCH001328	Charger	182-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BCH001328	Charger	182-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BCH001328	Charger	182-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BCH001328	Charger	182-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	DX0096	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	547	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	DX0096	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	DX0096	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Adequate	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Fault Operations B Ø	0	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Fault Operations C Ø	0	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Fault Operations Ground	0	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	Operating Linkage OK?	y	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Follow-up Action Required?	n	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Follow-up Action Required?	n	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Fault Operations Ground	0	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Fault Operations C Ø	0	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Fault Operations B Ø	0	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Fault Operations A Ø	0	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Amps C Ø	0.0	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Amps B Ø	0.0	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	BK000680	BreakerVacuum	BB-1102	VCB Readings	Amps A Ø	0.0	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Switching Operations	1	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Patrol Inspection	Tank Paint Condition	Good	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000388	BreakerVacuum	337-4641	VCB Readings	Unknown Operations	0	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	9 Month Operations	10	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Amps A Ø	70.0	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Amps B Ø	58.0	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Readings	Amps C Ø	51.0	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Bushing Condition	Good	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BCH001120	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.7	VDC
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BCH001120	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	52.7	VDC
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BCH001120	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	2.1	amps
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BCH001120	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	BK000389	BreakerVacuum	337-4642	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0125	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	2R	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	ST000811	Structure	Retired Distribution	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	LTCC000527	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	LTCC000527	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	LTCC000527	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	LTCC000527	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	LTCC000527	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	LTCC000527	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	LTCC000527	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	LTCC000527	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B \emptyset	0	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A \emptyset	0	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C \emptyset	0.0	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B \emptyset	0.0	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	General Comments		
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	ST000067	Structure	312-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Vegetation	None	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	General Comments		
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2595.60	kw
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BCH001059	Charger	182-603 MOS Battery and Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.0	VDC
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BCH001059	Charger	182-603 MOS Battery and Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	YD000613	Yard	Retired Distribution	Yard Patrol Inspection	Clear of Obstacles?	y	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	YD000613	Yard	Retired Distribution	Yard Patrol Inspection	Clear of Trash?	y	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	YD000613	Yard	Retired Distribution	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	YD000613	Yard	Retired Distribution	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	YD000613	Yard	Retired Distribution	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	General Comments		
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	General Comments		
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	YD000613	Yard	Retired Distribution	Yard Patrol Inspection	Ambient Temp	37	°F
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Readings	General Comments		
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	General Comments		internals around circuit breaker paint is flaking off and floor is rusting out
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	24.17	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	10.00	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Readings	Oil Temp Max	50	°C
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Readings	Oil Temp Present	20	°C
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Readings	Percent Thermal Load H2 Max	-60	%
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Readings	Percent Thermal Load X2 Max	-60	%
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Readings	Percent Thermal Load Y2 Max	-60	%
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	LTC Totalizer Reading	4412.16	kw
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	General Comments		
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	General Comments		
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0019	NonLTC	BB-PORT TRANS 4	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Patrol Inspection	Bushing Condition	Good	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Amps C Ø	61.0	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Amps B Ø	52.0	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Amps A Ø	48.0	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	21000	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	Totalizer Meter Reading	.1236	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	Winding Temp Max	38	°C
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	Winding Temp Present	31	°C
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	General Comments		
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Vegetation	None	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	General Comments		
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	YD000640	Yard	BB-Yard	Yard Patrol Inspection	Ambient Temp	37	°F
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Fault Operations A Ø	0	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Fault Operations B Ø	0	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	9 Month Operations	170	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Unknown Operations	0	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Patrol Inspection	Tank Paint Condition	Good	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Switching Operations	1	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Operations This Read Vac	1	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Operations Counter AL	146	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Operations Counter AF	145	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Maintenance Operations	0	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Patrol Inspection	Grounds in Place?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	General Comments		
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Patrol Inspection	General Comments		
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Patrol Inspection	Foundation Condition	Good	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Follow-up Action Required?	n	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Fault Operations A Ø	0	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Fault Operations C Ø	0	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	YD000613	Yard	Retired Distribution	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	YD000613	Yard	Retired Distribution	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	YD000613	Yard	Retired Distribution	Yard Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	YD000613	Yard	Retired Distribution	Yard Patrol Inspection	General Comments		
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	YD000613	Yard	Retired Distribution	Yard Patrol Inspection	Landscape Good Condition?	y	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	YD000613	Yard	Retired Distribution	Yard Patrol Inspection	Vegetation	None	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Clear of Trash?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	General Comments	TR-1 is carded	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	3	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	YD000613	Yard	Retired Distribution	Yard Patrol Inspection	Yard Lights Working?	y	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Evidence of Insects	None	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	n	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	ST000621	Structure	BB-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	General Comments		
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Panels Dusted?	y	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	SWG000055	Switchgear	Retired Distribution	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	9 Month Operations	2	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Amps A Ø	72.0	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Amps B Ø	71.0	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Amps C Ø	68.0	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Patrol Inspection	Bushing Condition	Good	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001250	BreakerVacuum	312-4643	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	YD000060	Yard	312-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	FE000061	Fence	312-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Fault Operations Ground	0	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Follow-up Action Required?	n	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Patrol Inspection	Foundation Condition	Good	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Patrol Inspection	General Comments		
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Patrol Inspection	Grounds in Place?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Maintenance Operations	0	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Operations Counter AF	169	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Operations Counter AL	170	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Operations This Read Vac	1	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Operations Counter AL	173	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Operations This Read Vac	0	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Panels Dusted?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Switching Operations	0	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Tank Paint Condition	Good	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Unknown Operations	0	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	Fault Operations	0	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Patrol Inspection	Equipment Properly Labeled?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	Amps C Ø	120.0	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	Amps B Ø	120.0	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	Amps A Ø	120.0	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BCH001059	Charger	182-603 MOS Battery and Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Current Tap Position	Neutral	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BCH001059	Charger	182-603 MOS Battery and Charger	Battery Charger Patrol Insp	General Comments		
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Fault Operations B Ø	0	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Fault Operations C Ø	0	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Fault Operations Ground	0	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Follow-up Action Required?	n	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Foundation Condition	Good	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	General Comments		
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Regulator As Left Counter	35667	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	122.8	volts
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Min Tap Position	Neutral	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	General Comments		
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Grounds in Place?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	General Comments		
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0127	Regulator	182-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Maintenance Operations	0	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Operations Counter AF	173	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Fault Operations A Ø	0	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Fault Operations C Ø	0	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	General Comments		
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Switching Operations	1	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1021	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1021	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1165	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Ground Lead 1 Resistance Set 1	0.0	Micro Ohms
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Ground Lead 2 Resistance Set 1	0.0	Micro Ohms
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Ground Lead 3 Resistance Set 1	0.0	Micro Ohms
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Patrol Inspection	Tank Paint Condition	Good	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK001251	BreakerVacuum	312-4644	VCB Readings	Unknown Operations	0	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	SWG000049	Switchgear	BB-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	General Comments		
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	FE000836	Fence	182-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Broom on Site?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	CH000064	ControlHouse	182-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	Ambient Temp	50	*F
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	General Comments		
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	All Connections OK?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	Vegetation	None	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	YD000177	Yard	182-Yard	Yard Patrol Inspection	Yard Lights Working?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Battery Overall Condition	Good	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	Winding Temp Max	36	°C
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	Winding Temp Present	30	°C
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BAT001099	Battery	182-603 MOS Battery and Charger	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Readings	General Comments		
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BCH001059	Charger	182-603 MOS Battery and Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	BCH001059	Charger	182-603 MOS Battery and Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.0	VDC
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	General Comments		
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	FE000636	Fence	BB-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Regulator As Left Counter	37768	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	KR0126	Regulator	182-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	Totalizer Meter Reading	.4596	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	Oil Temp Present	30	°C
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Readings	Oil Temp Max	38	°C
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	O0232	WithLTC	337-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	636	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	636	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
11/12/2020 11:23	Distribution	Zorn Generating Quarterly Inspection	LB1163	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Fault Operations A Ø	0	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Patrol Inspection	Bushing Condition	Good	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/12/2020 9:59	Distribution	Andover Quarterly Inspection	TX000076	NonLTC	182-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Amps C Ø	252.0	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Amps B Ø	256.0	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Amps A Ø	242.0	
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/12/2020 13:14	Distribution	Clinch Valley Quarterly Inspection	BK000498	BreakerVacuum	312-1	VCB Readings	9 Month Operations	0	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	Follow-up Action Required?	n	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Patrol Inspection	General Comments		
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	General Comments		
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	Maintenance Operations	0	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	Number of Ops last 9 Months	6	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	Operations Counter AF	523	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	Operations Counter AL	523	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	Operations This Read Oil	0	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	Switching Operations	0	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Readings	Oil Temp Present	15	°C
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	General Comments		
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/12/2020 14:11	Distribution	Wise Quarterly Inspection	FE000017	Fence	337-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	65	°C
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	15	°C
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Readings	Unknown Operations	0	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Patrol Inspection	Tank Oil Level	Good	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LT0020	WithLTC	BB-TRANS 1	LTC Transformer Patrol Inspection	General Comments	T.C. oil is low TR-1 is carded	
11/12/2020 8:48	Distribution	Brandenburg Quarterly Inspection	LB1281	BreakerOil	BB-1105	OCB Patrol Inspection	Tank Leaks	None	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Counter Readings	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Mechanism Patrol Inspection	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Counter Readings	LTC As Found Counter	40672	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Counter Readings	LTC As Left Counter	40672	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Counter Readings	LTC Current Tap Position	6L	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Counter Readings	LTC Max Tap Position	1R	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Counter Readings	LTC Min Tap Position	8L	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Counter Readings	LTC Min Tap Position	5R	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Counter Readings	LTC Max Tap Position	9R	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Counter Readings	LTC Current Tap Position	6R	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Counter Readings	LTC As Left Counter	9855	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Counter Readings	LTC As Found Counter	9855	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Counter Readings	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	9	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Counter Readings	LTC Operations Since Last Insp	514	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0167	LTCMechanism	SM-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	General Comments		
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Vegetation	None	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Ambient Temp	55	*F
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	General Comments		
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Tank Oil Level	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Tank Leaks	None	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	Switching Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	Operations This Read Oil	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	Operations Counter AL	512	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	Operations Counter AF	512	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	Number of Ops last 9 Months	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	Maintenance Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Grounds in Place?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Foundation Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	Fault Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	X1 Winding Temp Max	47	°C
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	X1 Winding Temp Present	24	°C
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	X2 Winding Temp Max	47	°C
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	X2 Winding Temp Present	24	°C
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	X3 Winding Temp Max	47	°C
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	X3 Winding Temp Present	24	°C
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Counter Readings	LTC Operations Since Last Insp	1038	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Counter Readings	LTC Min Tap Position	10L	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Counter Readings	LTC Max Tap Position	4R	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Counter Readings	LTC Current Tap Position	1L	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Counter Readings	LTC As Left Counter	224588	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Counter Readings	LTC As Found Counter	224584	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Counter Readings	General Comments		
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	C0539	LTCMechanism	542-1	LTC Counter Readings	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	9 Month Operations	2	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Amps A Ø	0.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Amps B Ø	0.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Amps C Ø	0.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Fault Operations A Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Fault Operations B Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Fault Operations C Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Fault Operations Ground	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Patrol Inspection	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	General Comments		
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	YD000458	Yard	542-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Readings	Totalizer Meter Reading	.5100	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Vegetation	None	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	YD000596	Yard	SK-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0164	LTCMechanism	SM-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0164	LTCMechanism	SM-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	Ambient Temp	65	*F
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Fault Operations C Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Fault Operations B Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Fault Operations A Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0164	LTCMechanism	SM-TRANS 2	LTC Counter Readings	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0164	LTCMechanism	SM-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0164	LTCMechanism	SM-TRANS 2	LTC Counter Readings	LTC As Found Counter	23181	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0164	LTCMechanism	SM-TRANS 2	LTC Counter Readings	LTC As Left Counter	23181	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0164	LTCMechanism	SM-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0164	LTCMechanism	SM-TRANS 2	LTC Counter Readings	LTC Current Tap Position	4R	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0164	LTCMechanism	SM-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	198	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0164	LTCMechanism	SM-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0164	LTCMechanism	SM-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0165	LTCMechanism	SM-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0165	LTCMechanism	SM-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0165	LTCMechanism	SM-TRANS 1	LTC Counter Readings	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0165	LTCMechanism	SM-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0165	LTCMechanism	SM-TRANS 1	LTC Counter Readings	LTC As Found Counter	82596	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0165	LTCMechanism	SM-TRANS 1	LTC Counter Readings	LTC As Left Counter	82596	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0165	LTCMechanism	SM-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0165	LTCMechanism	SM-TRANS 1	LTC Counter Readings	LTC Current Tap Position	4R	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0165	LTCMechanism	SM-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	222	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0165	LTCMechanism	SM-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0165	LTCMechanism	SM-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Counter Readings	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0166	LTCMechanism	SM-TRANS 6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Patrol Inspection	Bushing Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	Amps C Ø	0.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	Amps B Ø	0.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0833	BreakerOil	SM-GND TR 2	OCB Readings	Amps A Ø	0.0	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Switching Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Operations This Read Vac	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Operations Counter AL	361	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Operations Counter AF	361	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Maintenance Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Operations Counter AF	150	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Operations Counter AL	150	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Operations This Read Vac	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1269	BreakerVacuum	SM-1384	VCB Readings	Switching Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Maintenance Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	Grounds in Place?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	Foundation Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Readings	Follow-up Action Required?	n	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Fault Operations Ground	0	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	General Comments		
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	ST000460	Structure	542-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	General Comments		
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Readings	General Comments		
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Readings	LTC Totalizer Reading	4896.00	kw
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Readings	Oil Temp Max	35	°C
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Readings	Oil Temp Present	35	°C
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	S0001	WithLTC	358-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	LTCC000734	LTCControl	358-1	LTC Control Insp	VRR Time Delay	60	Seconds
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	LTCC000734	LTCControl	358-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	LTCC000734	LTCControl	358-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	LTCC000734	LTCControl	358-1	LTC Control Insp	LTC Output Voltage Level	123.2	VAC
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	LTCC000734	LTCControl	358-1	LTC Control Insp	LTC Operation Checked?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	LTCC000734	LTCControl	358-1	LTC Control Insp	General Comments		
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	LTCC000734	LTCControl	358-1	LTC Control Insp	Follow-up Action Required?	n	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	LTCC000734	LTCControl	358-1	LTC Control Insp	All Connections OK?	y	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	General Comments		
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	Vegetation	None	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	PF000312	PowerFuse	SM-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	PF000312	PowerFuse	SM-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	PF000312	PowerFuse	SM-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	PF000313	PowerFuse	SM-14KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	PF000313	PowerFuse	SM-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	PF000313	PowerFuse	SM-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	PF000314	PowerFuse	SM-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	PF000314	PowerFuse	SM-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	PF000315	PowerFuse	SM-GND TR 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	PF000315	PowerFuse	SM-GND TR 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	PF000315	PowerFuse	SM-GND TR 1	Disconnect Powerfuse Inspection	General Comments	ok	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	PF000317	PowerFuse	SM-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	PF000317	PowerFuse	SM-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	PF000317	PowerFuse	SM-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Readings	General Comments		
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Readings	Oil Temp Max	55	°C
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Readings	Oil Temp Present	42	°C
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	45	°C
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LT0064	WithLTC	DE-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	40	°C
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	General Comments		
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	General Comments		
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	BCH001318	Charger	358-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	BCH001318	Charger	358-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	BCH001318	Charger	358-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	BCH001318	Charger	358-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	BCH001318	Charger	358-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	BCH001318	Charger	358-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	BCH001318	Charger	358-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	General Comments		
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	YD000102	Yard	358-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	General Comments		
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	Vegetation	None	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	YD000064	Yard	321-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	YD000057	Yard	517-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	YD000057	Yard	517-Yard	Yard Patrol Inspection	Ambient Temp	63	°F
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	PF000303	PowerFuse	SK-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	PF000303	PowerFuse	SK-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	PF000319	PowerFuse	SM-STA SER NO 4	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	PF000319	PowerFuse	SM-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	PF000319	PowerFuse	SM-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	ok	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	PF000320	PowerFuse	SM-14KV TR 4 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	PF000320	PowerFuse	SM-14KV TR 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	PF000320	PowerFuse	SM-14KV TR 4 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	PF000322	PowerFuse	SM-14KV TR 6 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	PF000322	PowerFuse	SM-14KV TR 6 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	PF000322	PowerFuse	SM-14KV TR 6 POT	Disconnect Powerfuse Inspection	General Comments	ok	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	PF000323	PowerFuse	SM-STA SER NO 3	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	PF000323	PowerFuse	SM-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	PF000323	PowerFuse	SM-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	PF000324	PowerFuse	SM-STA SER NO 6	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	PF000324	PowerFuse	SM-STA SER NO 6	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	PF000324	PowerFuse	SM-STA SER NO 6	Disconnect Powerfuse Inspection	General Comments	ok	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	PF000325	PowerFuse	SM-STA SER NO 5	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	PF000325	PowerFuse	SM-STA SER NO 5	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	PF000325	PowerFuse	SM-STA SER NO 5	Disconnect Powerfuse Inspection	General Comments	ok	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	9 Month Operations	1	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Amps A Ø	0.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Amps B Ø	0.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Amps C Ø	0.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Fault Operations A Ø	0	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Fault Operations B Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Fault Operations C Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Fault Operations Ground	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Patrol Inspection	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Maintenance Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Operations Counter AF	171	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Operations Counter AL	171	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Operations This Read Vac	1	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0834	BreakerVacuum	SM-GND TR 3	VCB Readings	Switching Operations	1	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	9 Month Operations	2	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Amps A Ø	7.0	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	ST000072	Structure	321-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	General Comments		
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	ST000045	Structure	538-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	Vegetation	None	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	General Comments		
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	YD000043	Yard	538-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	General Comments		
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	FE000046	Fence	538-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	YD000057	Yard	517-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	YD000057	Yard	517-Yard	Yard Patrol Inspection	Vegetation	None	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	YD000057	Yard	517-Yard	Yard Patrol Inspection	General Comments		
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	ST000108	Structure	358-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	YD000057	Yard	517-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	YD000057	Yard	517-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	YD000057	Yard	517-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	YD000057	Yard	517-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	YD000057	Yard	517-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	YD000057	Yard	517-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	861	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	861	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Tank Leaks	None	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Operations Counter	11	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	General Comments		
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Amps C Ø	31.0	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Amps B Ø	25.0	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	MX0269	RecloserElectronic	538-0314	Recloser Electronic Patrol Inspection	Amps A Ø	27.0	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	200.0	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	210.0	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	200.0	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	8	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	General Comments		
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Patrol Inspection	Bushing Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Amps C Ø	41.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Amps B Ø	46.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Amps A Ø	47.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK001186	BreakerVacuum	SM-1364	VCB Readings	9 Month Operations	27	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	General Comments		
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	FE000452	Fence	542-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0206	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Current Tap Position	10L	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	General Comments		
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Max Tap Position	6L	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Min Tap Position	15L	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Fault Operations A Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Fault Operations B Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Fault Operations C Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Fault Operations Ground	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Patrol Inspection	General Comments		
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	ST000062	Structure	517-Structure	Structure Patrol Inspection	All Identified and Legible?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Maintenance Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Operations Counter AF	143	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Operations Counter AL	143	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Operations This Read Vac	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Switching Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	9 Month Operations	13	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Amps A Ø	10.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Amps B Ø	10.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Amps C Ø	10.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Fault Operations A Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Fault Operations B Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Fault Operations C Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Fault Operations Ground	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Patrol Inspection	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Maintenance Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Operations Counter AF	239	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Operations Counter AL	239	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Operations This Read Vac	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0819	BreakerVacuum	SM-1382	VCB Readings	Switching Operations	0	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	FE000065	Fence	321-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	2	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	2	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	935	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	935	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	5	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Readings	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	295.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	293.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	299.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0829	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	*F
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	General Comments		
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	BAT001390	Battery	358-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	9 Month Operations	2	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Amps A Ø	0.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Amps B Ø	0.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Amps C Ø	0.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0835	BreakerVacuum	SM-GND TR 6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Fault Operations A Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Fault Operations B Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Fault Operations C Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Fault Operations Ground	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	Foundation Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	Grounds in Place?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Maintenance Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Operations Counter AF	171	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Operations Counter AL	171	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Operations This Read Vac	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Switching Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	9 Month Operations	9	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	General Comments		
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Readings	General Comments		
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	672.48	kw
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Readings	Oil Temp Present	34	°C
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	C0331	NonLTC	321-1	NonLTC Transformer Readings	Totalizer Meter Reading	.2802	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	General Comments		
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Readings	Grounds in Place?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Readings	LTC Totalizer Reading	13521.60	kw
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Readings	Oil Temp Max	65	°C
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Readings	Oil Temp Present	40	°C
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Amps A Ø	70.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Amps B Ø	57.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	Amps C Ø	59.0	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Readings	Totalizer Meter Reading	.9390	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Readings	Winding Temp Max	60	°C
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Readings	Winding Temp Present	45	°C
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	Bushing Condition	Good	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	651	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Counter Readings	LTC Min Tap Position	14L	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Counter Readings	LTC Max Tap Position	8L	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Counter Readings	LTC Current Tap Position	13L	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Counter Readings	LTC As Left Counter	98767	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Counter Readings	LTC As Found Counter	98767	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Counter Readings	General Comments		
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LT0172	LTCMechanism	SK-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Amps C Ø	70.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	Bushing Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	23	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	78.0	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	110.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C ∅	87.0	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	11.18	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Fault Operations A ∅	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Fault Operations B ∅	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Fault Operations C ∅	0	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A ∅	0	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B ∅	0	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C ∅	1	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	VC is 28 C phase IOc	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	28	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	28	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	1	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LB0870	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Fault Operations Ground	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Current Tap Position	2L	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	General Comments		
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Max Tap Position	1R	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Min Tap Position	6L	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	Foundation Condition	Good	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	122.6	volts
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Regulator As Left Counter	23849	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	General Comments		
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Readings	General Comments		
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Readings	Oil Temp Max	40	°C
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Readings	Oil Temp Present	30	°C
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	General Comments		
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	FE000591	Fence	SK-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Amps A ∅	93.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Amps B ∅	100.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Amps C Ø	109.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	Bushing Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Fault Operations A Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Fault Operations B Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Fault Operations C Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Fault Operations Ground	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	Foundation Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	Grounds in Place?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Maintenance Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Operations Counter AF	148	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Operations Counter AL	148	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Operations This Read Vac	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Readings	Switching Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000868	BreakerVacuum	SM-1233	VCB Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	9 Month Operations	2	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Amps A Ø	77.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Amps B Ø	88.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Amps A Ø	142.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Amps B Ø	97.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Amps C Ø	108.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	Bushing Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Operations This Read Vac	0	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Switching Operations	0	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Unknown Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Fault Operations A Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Fault Operations B Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Fault Operations C Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Fault Operations Ground	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	Foundation Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	Grounds in Place?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Maintenance Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Operations Counter AF	115	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Operations Counter AL	115	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Operations This Read Vac	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Switching Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000867	BreakerVacuum	SM-1231	VCB Readings	9 Month Operations	5	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Follow-up Action Required?	n	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Readings	9 Month Operations	1	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Readings	Amps A Ø	23.0	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Readings	Amps B Ø	23.0	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Readings	Amps C Ø	23.0	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Patrol Inspection	Bushing Condition	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	BK001261	BreakerVacuum	540-0335	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LTO295	LTCMechanism	SM-TRANS 5	LTC Counter Readings	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LTO295	LTCMechanism	SM-TRANS 5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LTO295	LTCMechanism	SM-TRANS 5	LTC Counter Readings	General Comments		
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Fault Operations A Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Fault Operations B Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Fault Operations C Ø	0	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	SWG000064	Switchgear	SK-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	Bushing Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Amps C Ø	80.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Amps B Ø	88.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Amps A Ø	91.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	9 Month Operations	48	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Fault Operations Ground	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	Foundation Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	Grounds in Place?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Operations Counter AL	164	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Operations Counter AF	164	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Maintenance Operations	0	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	Grounds in Place?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	General Comments		
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	General Comments		
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Patrol Inspection	Foundation Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Maintenance Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Operations Counter AF	235	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Operations Counter AL	235	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Operations This Read Vac	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Readings	Switching Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000865	BreakerVacuum	SM-1234	VCB Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	9 Month Operations	14	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000866	BreakerVacuum	SM-1235	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Fault Operations A Ø	0	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Fault Operations B Ø	0	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Fault Operations C Ø	0	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Fault Operations Ground	0	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Follow-up Action Required?	n	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Patrol Inspection	Foundation Condition	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Patrol Inspection	General Comments		
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	General Comments		
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Patrol Inspection	Grounds in Place?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Maintenance Operations	0	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Operations Counter AF	201	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Operations Counter AL	201	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Operations This Read Vac	0	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Switching Operations	0	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	BK001262	BreakerVacuum	540-2307	VCB Readings	Unknown Operations	0	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Counter Readings	LTC Operations Since Last Insp	754	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Counter Readings	LTC Min Tap Position	4L	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Counter Readings	LTC Max Tap Position	11R	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Counter Readings	LTC Current Tap Position	7L	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Counter Readings	LTC As Left Counter	8314	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Counter Readings	LTC As Found Counter	8312	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Mechanism Patrol Inspection	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Counter Readings	LTC Current Tap Position	6L	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Counter Readings	LTC Max Tap Position	1R	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Counter Readings	LTC Min Tap Position	16L	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Counter Readings	LTC Operations Since Last Insp	452	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	9 Month Operations	2	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Counter Readings	General Comments		
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	B0329	LTCMechanism	358-1	LTC Counter Readings	Follow-up Action Required?	n	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Readings	Follow-up Action Required?	n	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KT0027	WithLTC	540-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Mechanism Patrol Inspection	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Counter Readings	LTC As Found Counter	17933	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Counter Readings	LTC As Left Counter	17933	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0295	LTCMechanism	SM-TRANS 5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Fault Operations Ground	0	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Fault Operations C Ø	0	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Fault Operations B Ø	0	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0054	BreakerVacuum	540-2	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	H2 Winding Temp Max	62	°C
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	H2 Winding Temp Present	32	°C
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	Oil Temp Max	65	°C
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	Oil Temp Present	35	°C
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	X1 Winding Temp Max	60	°C
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	X1 Winding Temp Present	30	°C
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	X2 Winding Temp Max	60	°C
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	X2 Winding Temp Present	32	°C
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	9 Month Operations	16	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0831	BreakerVacuum	SM-14KV TR 6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Min Tap Position	9L	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Max Tap Position	1R	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	General Comments	change control board 11/11/2020	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Current Tap Position	2L	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Vegetation	None	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	General Comments		
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.3	psi
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1850	psi
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	Oil Temp Max	47	°C
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Readings	Oil Temp Present	24	°C
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0295	WithLTC	SM-TRANS 5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	YD000466	Yard	540-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	MX0396	RecloserHydraulic	517-0323 C	Recloser Hydraulic Patrol Inspection	Amps A Ø	12.2	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	MX0396	RecloserHydraulic	517-0323 C	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	MX0396	RecloserHydraulic	517-0323 C	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	MX0396	RecloserHydraulic	517-0323 C	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	MX0396	RecloserHydraulic	517-0323 C	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	MX0396	RecloserHydraulic	517-0323 C	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	MX0396	RecloserHydraulic	517-0323 C	Recloser Hydraulic Patrol Inspection	General Comments		
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	MX0396	RecloserHydraulic	517-0323 C	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	MX0396	RecloserHydraulic	517-0323 C	Recloser Hydraulic Patrol Inspection	Operations Counter	486	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	MX0396	RecloserHydraulic	517-0323 C	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.5	psi
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Readings	Oil Temp Max	70	°C
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Readings	Oil Temp Present	40	°C
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0167	WithLTC	SM-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0267	GroundTransformer	SM-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LT0251	GroundTransformer	DE-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Tank Leaks	None	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Regulator As Left Counter	265	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	MX0396	RecloserHydraulic	517-0323 C	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	LTCC000032	LTCControl	540-2	LTC Control Insp	VRR Time Delay	30	Seconds
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	LTCC000032	LTCControl	540-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	LTCC000032	LTCControl	540-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	LTCC000032	LTCControl	540-2	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	LTCC000032	LTCControl	540-2	LTC Control Insp	LTC Operation Checked?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	LTCC000032	LTCControl	540-2	LTC Control Insp	General Comments		
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	LTCC000032	LTCControl	540-2	LTC Control Insp	Follow-up Action Required?	n	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	LTCC000032	LTCControl	540-2	LTC Control Insp	All Connections OK?	y	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0103	Regulator	027-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	General Comments		
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Fault Operations Ground	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Fault Operations C Ø	0	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	ST000469	Structure	540-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Fault Operations B Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Fault Operations A Ø	0	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	9 Month Operations	14	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Amps A Ø	353.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Amps B Ø	355.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Amps C Ø	350.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Fault Operations A Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Fault Operations B Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Fault Operations C Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Fault Operations Ground	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Patrol Inspection	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Maintenance Operations	13	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Operations Counter AF	258	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Operations Counter AL	258	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Tank Leaks	None	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0102	Regulator	027-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	Grounds in Place?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Maintenance Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Operations Counter AF	144	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Operations Counter AL	144	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Operations This Read Vac	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Readings	Switching Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000869	BreakerVacuum	SM-1232	VCB Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Counter Readings	Follow-up Action Required?	n	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Counter Readings	General Comments		
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Mechanism Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Counter Readings	LTC As Found Counter	56590	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Counter Readings	LTC As Left Counter	56592	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Counter Readings	LTC Current Tap Position	1L	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Counter Readings	LTC Max Tap Position	2R	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Counter Readings	LTC Min Tap Position	10L	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	45	°C
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Unknown Operations	0	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Switching Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Operations This Read Vac	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Operations Counter AL	209	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Operations Counter AF	209	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Maintenance Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Grounds in Place?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Switching Operations	0	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Operations This Read Vac	0	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Operations Counter AL	208	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Operations Counter AF	208	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Maintenance Operations	0	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Grounds in Place?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	General Comments		
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Foundation Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Foundation Condition	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Follow-up Action Required?	n	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Fault Operations Ground	0	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Fault Operations C Ø	0	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Fault Operations B Ø	0	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Fault Operations A Ø	0	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	General Comments	abric and fence posts are rusty, multiple spots with 4in gap at bottom of fence.	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0166	WithLTC	SM-TRANS 6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0825	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Switching Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Operations This Read Vac	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Operations Counter AL	216	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Operations Counter AF	216	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Maintenance Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Grounds in Place?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Foundation Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Fault Operations Ground	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Fault Operations C Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Fault Operations B Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Fault Operations A Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1273	BreakerVacuum	SM-1360	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Patrol Inspection	Bushing Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Amps C Ø	57.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Amps B Ø	56.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Amps A Ø	57.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Operations This Read Vac	14	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0830	BreakerVacuum	SM-14KV TR 3	VCB Readings	Switching Operations	1	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	FE000093	Fence	358-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Patrol Inspection	Bushing Condition	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Amps C Ø	158.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1274	BreakerVacuum	SM-1363	VCB Readings	9 Month Operations	26	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Amps B Ø	161.0	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Amps A Ø	156.0	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LTCC000491	LTCControl	DE-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LTCC000491	LTCControl	DE-TRANS 1	LTC Control Insp	General Comments		
11/20/2020 14:19	Distribution	Del Park Quarterly Inspection	LTCC000491	LTCControl	DE-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0052	BreakerVacuum	540-2238	VCB Readings	9 Month Operations	3	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	50	°C
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Counter Readings	LTC Operations Since Last Insp	1134	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KT0027	LTCMechanism	540-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	General Comments		
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	FE000840	Fence	540-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	FE000057	Fence	517-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Readings	General Comments		
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.4	psi
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	96.00	kw
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Readings	Oil Temp Max	29	°C
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Readings	Oil Temp Present	25	°C
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	Bushing Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	Foundation Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	Grounds in Place?	y	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	General Comments		
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Max Tap Position	3L	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	122.7	volts
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Regulator As Left Counter	162337	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Unknown Operations	0	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	9 Month Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Amps A Ø	75.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Amps B Ø	74.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Amps C Ø	80.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Fault Operations A Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Fault Operations B Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Fault Operations C Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Fault Operations Ground	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Patrol Inspection	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Maintenance Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Operations Counter AF	249	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Operations Counter AL	249	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Operations This Read Vac	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0821	BreakerVacuum	SM-1394	VCB Readings	Switching Operations	0	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	General Comments		
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Readings	Totalizer Meter Reading	.0200	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Readings	Winding Temp Max	34	°C
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Readings	Winding Temp Present	33	°C
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	Tank Leaks	None	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Regulator As Left Counter	49562	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	General Comments		
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Readings	General Comments		
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Readings	LTC Totalizer Reading	3274.56	kw
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Readings	Oil Temp Max	50	°C
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Readings	Oil Temp Present	42	°C
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0976	Regulator	321-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	General Comments		
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Max Tap Position	3R	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Min Tap Position	11L	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Regulator As Left Counter	120114	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0977	Regulator	321-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	General Comments		
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	R0978	Regulator	321-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0268	GroundTransformer	SM-GND TR 2	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KT0048	NonLTC	027-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Fault Operations C Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Fault Operations B Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Fault Operations A Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Amps C Ø	10.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Amps B Ø	10.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Amps A Ø	10.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	9 Month Operations	15	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Counter Readings	LTC Operations Since Last Insp	590	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Counter Readings	LTC Min Tap Position	4L	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Counter Readings	LTC Max Tap Position	13L	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Counter Readings	LTC Current Tap Position	6L	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Counter Readings	LTC As Left Counter	20187	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Counter Readings	LTC As Found Counter	20184	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Mechanism Patrol Inspection	General Comments		
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Counter Readings	General Comments		
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	C0513	LTCMechanism	540-1	LTC Counter Readings	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Tank Oil Level	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Tank Leaks	None	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Grounds in Place?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Foundation Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Amps A Ø	166.0	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Amps B Ø	170.0	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Amps C Ø	168.0	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Bushing Condition	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Fault Operations A Ø	0	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Fault Operations B Ø	0	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Fault Operations C Ø	0	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Fault Operations Ground	0	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Follow-up Action Required?	n	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Foundation Condition	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	General Comments		
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	General Comments		
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Grounds in Place?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Maintenance Operations	0	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Operations Counter AF	191	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Operations Counter AL	191	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Operations This Read Vac	0	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Switching Operations	0	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Unknown Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Switching Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Operations This Read Vac	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Operations Counter AL	243	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Operations Counter AF	243	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Maintenance Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Patrol Inspection	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0818	BreakerVacuum	SM-1381	VCB Readings	Fault Operations Ground	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Evidence of Insects	None	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Amps C Ø	85.0	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Bushing Condition	Good	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Fault Operations A Ø	0	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Fault Operations B Ø	0	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Fault Operations C Ø	0	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Fault Operations Ground	0	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Foundation Condition	Good	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	General Comments		
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	General Comments		
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Grounds in Place?	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Maintenance Operations	0	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Operations Counter AF	191	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Operations Counter AL	191	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Operations This Read Vac	0	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Switching Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0832	BreakerOil	SM-GND TR 1	OCB Patrol Inspection	Bushing Condition	Good	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	9 Month Operations	8	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Amps A Ø	40.0	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0298	BreakerVacuum	542-0342	VCB Readings	Amps B Ø	100.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Readings	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	General Comments	NEEDS NITROGEN	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Readings	Oil Temp Max	61	°C
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Readings	Oil Temp Present	52	°C
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0164	WithLTC	SM-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Panels Dusted?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000189	Switchgear	SM-Swgr Sec 5	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Amps B Ø	277.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Amps C Ø	268.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Fault Operations A Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Fault Operations B Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Fault Operations C Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Fault Operations Ground	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Patrol Inspection	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Maintenance Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Operations Counter AF	436	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Operations Counter AL	436	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Operations This Read Vac	1	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0823	BreakerVacuum	SM-1397	VCB Readings	Switching Operations	1	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	9 Month Operations	3	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Amps A Ø	114.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Amps B Ø	113.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Amps C Ø	114.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Bushing Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Fault Operations A Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Fault Operations B Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Fault Operations C Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Fault Operations Ground	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Foundation Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Grounds in Place?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Maintenance Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Operations Counter AF	315	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Operations Counter AL	315	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Operations This Read Vac	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Readings	Switching Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000556	BreakerVacuum	SM-1366	VCB Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	General Comments		
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	General Comments		
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Grounds in Place?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Maintenance Operations	0	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Operations Counter AF	171	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Operations Counter AL	172	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Operations This Read Vac	1	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Switching Operations	1	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	BK000544	BreakerVacuum	358-4721	VCB Readings	Unknown Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LTO163	WithLTC	SM-TRANS 4	LTC Transformer Readings	X3 Winding Temp Present	37	°C
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LTO163	WithLTC	SM-TRANS 4	LTC Transformer Readings	X3 Winding Temp Max	76	°C
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LTO163	WithLTC	SM-TRANS 4	LTC Transformer Readings	X2 Winding Temp Present	35	°C
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LTO163	WithLTC	SM-TRANS 4	LTC Transformer Readings	X2 Winding Temp Max	76	°C
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LTO163	WithLTC	SM-TRANS 4	LTC Transformer Readings	X1 Winding Temp Present	36	°C
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LTO163	WithLTC	SM-TRANS 4	LTC Transformer Readings	X1 Winding Temp Max	77	°C
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LTO163	WithLTC	SM-TRANS 4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LTO163	WithLTC	SM-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	30.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LTO163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LTO163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LTO163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LTO163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LTO163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LTO163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LTO163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LTO163	WithLTC	SM-TRANS 4	LTC Transformer Readings	Oil Temp Present	29	°C
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LTO163	WithLTC	SM-TRANS 4	LTC Transformer Readings	Oil Temp Max	66	°C
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LTO163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LTO163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LTO163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LTO163	WithLTC	SM-TRANS 4	LTC Transformer Readings	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LTO163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LTO163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LTO163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LTO163	WithLTC	SM-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LTO163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LTO163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LTO163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0163	WithLTC	SM-TRANS 4	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	Oil Temp Present	29	°C
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	Oil Temp Max	30	°C
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	3407.04	kw
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	General Comments		
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	General Comments		
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Switching Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Operations This Read Vac	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Operations Counter AL	131	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Operations Counter AF	131	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Maintenance Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Patrol Inspection	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Fault Operations Ground	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Fault Operations C Ø	0	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Readings	Totalizer Meter Reading	.4548	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	LTCC000528	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	LTCC000528	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	LTCC000528	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	LTCC000528	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.7	VAC
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	LTCC000528	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	LTCC000528	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	LTCC000528	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	LTCC000528	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	200.00	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	B0329	WithLTC	358-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	General Comments		
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	ST000589	Structure	SK-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	Winding Temp Present	32	°C
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	Winding Temp Max	35	°C
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	Totalizer Meter Reading	.7098	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	KT0013	NonLTC	538-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	General Comments		
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Readings	General Comments		
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Readings	LTC Totalizer Reading	4573.44	kw
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Readings	Oil Temp Max	45	°C
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Readings	Oil Temp Present	40	°C
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Readings	Totalizer Meter Reading	.4764	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0269	GroundTransformer	SM-GND TR 3	Ground Transformer Patrol Inspection	Bushing Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0269	GroundTransformer	SM-GND TR 3	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0269	GroundTransformer	SM-GND TR 3	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0269	GroundTransformer	SM-GND TR 3	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0269	GroundTransformer	SM-GND TR 3	Ground Transformer Patrol Inspection	Foundation Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0269	GroundTransformer	SM-GND TR 3	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0269	GroundTransformer	SM-GND TR 3	Ground Transformer Patrol Inspection	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0269	GroundTransformer	SM-GND TR 3	Ground Transformer Patrol Inspection	Grounds in Place?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0269	GroundTransformer	SM-GND TR 3	Ground Transformer Patrol Inspection	Tank Leaks	None	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0269	GroundTransformer	SM-GND TR 3	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0269	GroundTransformer	SM-GND TR 3	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1226	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1226	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	2	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0813	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Fault Operations B Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Fault Operations A Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Amps C Ø	0.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Amps B Ø	0.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Amps A Ø	0.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1271	BreakerVacuum	SM-1386	VCB Readings	9 Month Operations	0	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	General Comments		
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Min Tap Position	11L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Regulator As Left Counter	199378	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0791	Regulator	538-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	C0513	WithLTC	540-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Patrol Inspection	Bushing Condition	Good	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Amps C Ø	480.0	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Amps B Ø	480.0	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Amps A Ø	480.0	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Switching Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Operations This Read Vac	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Operations Counter AL	163	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Operations Counter AF	163	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Maintenance Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Patrol Inspection	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Fault Operations Ground	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Fault Operations C Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Fault Operations B Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Fault Operations A Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Amps C Ø	0.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Amps B Ø	0.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Amps A Ø	0.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1266	BreakerVacuum	SM-14KV TR 5	VCB Readings	9 Month Operations	2	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	CB0300	BreakerVacuum	542-1	VCB Readings	9 Month Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Panels Dusted?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Counter Readings	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Counter Readings	Follow-up Action Required?	n	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	DX0153	RecloserHydraulic	321-4733	Recloser Hydraulic Patrol Inspection	Amps A Ø	17.5	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	DX0153	RecloserHydraulic	321-4733	Recloser Hydraulic Patrol Inspection	Amps B Ø	1.2	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	DX0153	RecloserHydraulic	321-4733	Recloser Hydraulic Patrol Inspection	Amps C Ø	20.2	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	DX0153	RecloserHydraulic	321-4733	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	DX0153	RecloserHydraulic	321-4733	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 15:17	Distribution	Osaka East Quarterly Inspection	DX0153	RecloserHydraulic	321-4733	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Current Tap Position	1L	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Evidence of Insects	None	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000182	Switchgear	SM-Swgr Sec 6	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Switching Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Operations This Read Vac	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Operations Counter AL	138	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Operations Counter AF	138	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Maintenance Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Patrol Inspection	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Fault Operations Ground	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Fault Operations C Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Fault Operations B Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Fault Operations A Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Amps C Ø	0.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Amps B Ø	0.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Amps A Ø	0.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1270	BreakerVacuum	SM-1385	VCB Readings	9 Month Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Switching Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Operations This Read Vac	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Operations Counter AL	226	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Operations Counter AF	226	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Maintenance Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Patrol Inspection	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0820	BreakerVacuum	SM-1393	VCB Readings	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Readings	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Readings	Oil Temp Max	62	°C
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Readings	Oil Temp Present	41	°C
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	30.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0165	WithLTC	SM-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Amps A Ø	54.0	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Amps B Ø	51.0	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Amps C Ø	55.0	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	General Comments		
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Patrol Inspection	Grounds in Place?	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Maintenance Operations	0	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Operations Counter AF	349	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Operations Counter AL	349	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Operations This Read Vac	1	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Switching Operations	1	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Unknown Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Counter Readings	LTC Operations Since Last Insp	1036	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Counter Readings	LTC Min Tap Position	12L	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Counter Readings	LTC Max Tap Position	Neutral	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Counter Readings	LTC Current Tap Position	10L	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Counter Readings	LTC As Left Counter	32924	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Counter Readings	LTC As Found Counter	32924	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LTCM000030	LTCMechanism	SM-TRANS 4	LTC Mechanism Patrol Inspection	General Comments		
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Tank Leaks	None	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	MX0325	RecloserElectronic	538-0313	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Amps A Ø	8.2	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	General Comments		
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Operations Counter	140	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/11/2020 10:04	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Switching Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Operations This Read Vac	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Operations Counter AL	194	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Operations Counter AF	194	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Maintenance Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Patrol Inspection	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Fault Operations Ground	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Fault Operations C Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Fault Operations B Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Fault Operations A Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Amps C Ø	10.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Amps B Ø	10.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Amps A Ø	10.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0817	BreakerVacuum	SM-1380	VCB Readings	9 Month Operations	15	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	9 Month Operations	3	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	BK000411	BreakerVacuum	542-0343	VCB Readings	Amps A Ø	264.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	3	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	9 Month Operations	2	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Amps A Ø	0.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Amps B Ø	0.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Amps C Ø	0.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Fault Operations A Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Fault Operations B Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Fault Operations C Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Fault Operations Ground	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Patrol Inspection	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Maintenance Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Operations Counter AF	142	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Operations Counter AL	142	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Operations This Read Vac	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1268	BreakerVacuum	SM-GND TR 5	VCB Readings	Switching Operations	0	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	9 Month Operations	2	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	1	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	1	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1499	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1499	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Operations Counter	60	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Tank Leaks	None	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Bushing Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Amps C Ø	117.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Amps B Ø	112.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Amps A Ø	117.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	9 Month Operations	9	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Readings	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	3	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1622	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1622	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0826	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	3	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Current Tap Position	2R	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	General Comments		
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Min Tap Position	11L	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Regulator As Left Counter	136122	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0765	Regulator	538-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	310.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	304.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	318.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	9 Month Operations	1	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0051	BreakerVacuum	540-2308	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	1	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Readings	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0828	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Amps A Ø	0.0	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Amps B Ø	0.0	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Amps C Ø	0.0	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Fault Operations A Ø	0	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Fault Operations B Ø	0	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Fault Operations C Ø	0	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Fault Operations Ground	0	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Follow-up Action Required?	n	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	General Comments		
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	General Comments		
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Maintenance Operations	0	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Operations Counter AF	185	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Operations Counter AL	185	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Operations This Read Vac	0	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Switching Operations	0	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0055	BreakerVacuum	540-BT1-2	VCB Readings	Unknown Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Operations Counter AL	145	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Operations Counter AF	145	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Maintenance Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Patrol Inspection	Grounds in Place?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Patrol Inspection	Foundation Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Fault Operations Ground	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Fault Operations C Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Fault Operations B Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Fault Operations A Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Patrol Inspection	Bushing Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Amps C Ø	433.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Amps B Ø	438.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Amps A Ø	469.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	9 Month Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Switching Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Operations This Read Vac	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Operations Counter AL	285	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Operations Counter AF	285	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Maintenance Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Grounds in Place?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	General Comments		
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	9 Month Operations	2	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Amps A Ø	0.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Amps B Ø	0.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Amps C Ø	0.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	General Comments		
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Max Tap Position	3R	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Min Tap Position	6L	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Regulator As Left Counter	25879	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Tank Leaks	None	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KR0101	Regulator	027-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Fault Operations A Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Fault Operations B Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Fault Operations C Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Fault Operations Ground	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Patrol Inspection	General Comments	ok	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Maintenance Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Operations Counter AF	223	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Operations Counter AL	223	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Operations This Read Vac	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0822	BreakerVacuum	SM-1396	VCB Readings	Switching Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Switching Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000179	BreakerVacuum	SM-12KV TR 4	VCB Readings	Operations This Read Vac	0	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	General Comments	added 2.5 nitrogen	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	LTC Totalizer Reading	12636.00	kw
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	Oil Temp Max	67	°C
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	Oil Temp Present	55	°C
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	Totalizer Meter Reading	.7020	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	Winding Temp Max	65	°C
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	Winding Temp Present	55	°C
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Fault Operations A Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Amps A Ø	19.0	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Amps B Ø	15.0	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Amps C Ø	11.0	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	General Comments		
11/11/2020 14:20	Distribution	KU Park-Greasy Creek Quarterly Inspection	KX0166	RecloserElectronic	027-0309	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Foundation Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Fault Operations Ground	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Fault Operations C Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	BK000178	BreakerVacuum	SM-1361	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000082	Switchgear	SM-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	Gauge(s) Condition	Good	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	C0539	WithLTC	542-1	LTC Transformer Readings	General Comments		
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	85.0	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	79.0	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	81.0	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	BCH000401	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	BCH000401	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	BCH000401	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	BCH000401	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	BCH000401	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	BCH000401	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	9 Month Operations	1	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	General Comments		
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	BAT000122	Battery	SK-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0296	GroundTransformer	SM-GND TR 5	Ground Transformer Patrol Inspection	Bushing Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0296	GroundTransformer	SM-GND TR 5	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0296	GroundTransformer	SM-GND TR 5	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0296	GroundTransformer	SM-GND TR 5	Ground Transformer Patrol Inspection	Foundation Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0296	GroundTransformer	SM-GND TR 5	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0296	GroundTransformer	SM-GND TR 5	Ground Transformer Patrol Inspection	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0296	GroundTransformer	SM-GND TR 5	Ground Transformer Patrol Inspection	Grounds in Place?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0296	GroundTransformer	SM-GND TR 5	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0296	GroundTransformer	SM-GND TR 5	Ground Transformer Patrol Inspection	Tank Leaks	None	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0296	GroundTransformer	SM-GND TR 5	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0296	GroundTransformer	SM-GND TR 5	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	56	°F
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	45	°C
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	55	°C
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Readings	Oil Temp Present	45	°C
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Evidence of Insects	None	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Panels Dusted?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	SWG000181	Switchgear	SM-Swgr Sec 4	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Readings	Oil Temp Max	55	°C
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	89.0	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	89.0	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	67.0	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	30	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Amps C Ø	0.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Amps B Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Amps A Ø	0.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	9 Month Operations	5	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Operations This Read Vac	0	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Operations Counter AL	181	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Operations Counter AF	181	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Maintenance Operations	0	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Grounds in Place?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	General Comments		
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Foundation Condition	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Follow-up Action Required?	n	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	LTCC000693	LTCControl	540-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	LTCC000693	LTCControl	540-1	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	LTCC000693	LTCControl	540-1	LTC Control Insp	LTC Operation Checked?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	LTCC000693	LTCControl	540-1	LTC Control Insp	General Comments		
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	LTCC000693	LTCControl	540-1	LTC Control Insp	Follow-up Action Required?	n	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	LTCC000693	LTCControl	540-1	LTC Control Insp	All Connections OK?	y	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Fault Operations Ground	0	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Fault Operations C Ø	0	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Fault Operations B Ø	0	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Amps A Ø	15.0	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Amps B Ø	14.0	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Amps C Ø	13.0	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Bushing Condition	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Fault Operations A Ø	0	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Regulator As Left Counter	136590	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Min Tap Position	4L	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/11/2020 14:37	Distribution	Richmond Industrial Quarterly Inspection	BAT000559	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	PF000318	PowerFuse	SM-14KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	PF000318	PowerFuse	SM-14KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	PF000318	PowerFuse	SM-14KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	PF000321	PowerFuse	SM-14KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	PF000321	PowerFuse	SM-14KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	PF000321	PowerFuse	SM-14KV TR 3 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Switching Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Operations This Read Vac	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Operations Counter AL	143	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Operations Counter AF	143	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Maintenance Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Patrol Inspection	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Fault Operations Ground	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Fault Operations C Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Fault Operations B Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Fault Operations A Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Amps C Ø	0.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Amps B Ø	0.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Amps A Ø	0.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Readings	General Comments		
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LT0172	WithLTC	SK-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Current Tap Position	8L	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1272	BreakerVacuum	SM-1387	VCB Readings	9 Month Operations	0	
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	General Comments		
11/11/2020 9:16	Distribution	Stinking Creek Quarterly Inspection	R0934	Regulator	538-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Unknown Operations	0	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Readings	Switching Operations	0	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	KB0121	BreakerVacuum	540-2306	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	LTCC000693	LTCControl	540-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/11/2020 15:30	Distribution	Okonite Quarterly Inspection	LTCC000693	LTCControl	540-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Fault Operations Ground	0	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Fault Operations C Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	PF000311	PowerFuse	SM-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	PF000326	PowerFuse	SM-14KV TR 5 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	PF000326	PowerFuse	SM-14KV TR 5 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Switching Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	PF000326	PowerFuse	SM-14KV TR 5 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	PF000302	PowerFuse	SK-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	PF000302	PowerFuse	SK-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Trash Emptied?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	General Comments		
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Counter Readings	LTC Operations Since Last Insp	1715	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Counter Readings	LTC Min Tap Position	13L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	VC is 35	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	35	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	35	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	LB0869	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Fault Operations A Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Fault Operations B Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	PF000316	PowerFuse	SM-GND TR 2	Disconnect Powerfuse Inspection	General Comments	ok	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	PF000316	PowerFuse	SM-GND TR 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Acceptable Building Appearance?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Broom on Site?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Control House Lighting OK?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Counter Readings	Follow-up Action Required?	n	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	PF000311	PowerFuse	SM-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	PF000311	PowerFuse	SM-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Counter Readings	General Comments		
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Mechanism Patrol Inspection	LTC As Found Counter	6340	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Evidence of Insects	None	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	CH000211	ControlHouse	358-Control house	Control House Patrol Inspection	Floor Swept?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Counter Readings	LTC As Left Counter	6343	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Counter Readings	LTC Current Tap Position	7L	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Counter Readings	LTC Max Tap Position	3L	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Amps B Ø	7.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Amps C Ø	7.0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Fault Operations A Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Fault Operations B Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Fault Operations C Ø	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Fault Operations Ground	0	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	2	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	9	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	33	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	24	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	7	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Patrol Inspection	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Maintenance Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Operations Counter AF	372	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	DB0051	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Operations Counter AL	372	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB0824	BreakerVacuum	SM-1398	VCB Readings	Operations This Read Vac	0	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	BCH000014	Charger	SK-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	BCH000014	Charger	SK-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	BCH000014	Charger	SK-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	BCH000014	Charger	SK-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.1	amps
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	BCH000014	Charger	SK-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.9	VDC
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	BCH000014	Charger	SK-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.9	VDC
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	BCH000014	Charger	SK-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/11/2020 13:11	Distribution	Skylight Quarterly Inspection	BCH000014	Charger	SK-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/11/2020 11:31	Distribution	East Stone Gap Quarterly Inspection	S0001	LTCMechanism	358-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Operations Counter AF	175	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Maintenance Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Patrol Inspection	General Comments		
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Switching Operations	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Operations This Read Vac	0	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Operations Counter AL	175	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	Bushing Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Readings	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LB1267	BreakerVacuum	SM-14KV BUS TIE SEC 5	VCB Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	Follow-up Action Required?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	Foundation Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	General Comments	needs nitro	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	Grounds in Place?	y	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	Tank Leaks	None	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
11/11/2020 14:00	Distribution	Seminole Quarterly Inspection	LT0270	GroundTransformer	SM-GND TR 6	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	General Comments		
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	783	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	783	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	ST000513	Structure	729-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	BCH001378	Charger	895-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	BCH001378	Charger	895-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	8	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B ∅	0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C ∅	0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	213	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	221	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	8	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	8	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	LTC Operations Since Last Insp	77	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	LTC Min Tap Position	Neutral	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	LTC Max Tap Position	3R	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	LTC As Left Counter	10044	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	LTC As Found Counter	10044	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Mechanism Patrol Inspection	General Comments		
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	General Comments		
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	Follow-up Action Required?	n	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Vegetation	None	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	General Comments		
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	YD000510	Yard	729-Yard	Yard Patrol Inspection	Ambient Temp	77	°F
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	General Comments		
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	FE000505	Fence	729-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Ambient Temp	78	°F
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	General Comments		
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	General Comments		
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	LTC Totalizer Reading	9817.20	kw
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	Oil Temp Max	60	°C
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	Oil Temp Present	55	°C
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	Totalizer Meter Reading	.5454	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Unknown Operations	0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Switching Operations	0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Operations This Read Vac	0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Operations Counter AL	94	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Operations Counter AF	94	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Maintenance Operations	0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	General Comments		
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Follow-up Action Required?	n	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Fault Operations Ground	0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Fault Operations C ∅	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Fault Operations B Ø	0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Fault Operations A Ø	0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Amps C Ø	0.0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Amps B Ø	0.0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Amps A Ø	0.0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Accumulated Fault Duty C Ph V	3.77	%
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Accumulated Fault Duty B Ph V	1.67	%
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	Accumulated Fault Duty A Ph V	4.19	%
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Readings	9 Month Operations	1	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	BCH001378	Charger	895-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	BCH001378	Charger	895-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	FE000499	Fence	431-Fence	Fence Patrol Inspection	General Comments		
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	Winding Temp Present	46	°C
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Readings	Winding Temp Max	46	°C
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	C0499	WithLTC	829-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	BCH001378	Charger	895-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	BCH001378	Charger	895-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	BCH001378	Charger	895-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	BCH001378	Charger	895-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	40.0	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	40.0	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	40.0	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0209	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	8	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Counter Readings	LTC Operations Since Last Insp	109	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Counter Readings	LTC Min Tap Position	7L	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Counter Readings	LTC Max Tap Position	5L	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Counter Readings	LTC Current Tap Position	5L	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Counter Readings	LTC As Left Counter	478528	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Counter Readings	LTC As Found Counter	478528	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Mechanism Patrol Inspection	General Comments		
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Counter Readings	General Comments		
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	W0309	LTCMechanism	415-1	LTC Counter Readings	Follow-up Action Required?	n	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Vegetation	None	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	General Comments		
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	YD000506	Yard	431-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Foundation Condition	Good	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	General Comments		
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	General Comments		
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Grounds in Place?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Maintenance Operations	0	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Operations Counter AF	268	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Operations Counter AL	268	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Operations This Read Vac	0	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Switching Operations	0	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Unknown Operations	0	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	9 Month Operations	0	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Amps A Ø	14.0	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Amps B Ø	14.0	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Amps C Ø	14.0	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Bushing Condition	Good	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	9 Months Operations	2	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Amps A Ø	50.0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Amps B Ø	50.0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Amps C Ø	50.0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Fault Adjusted Amps A Phase AM	22.36	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Fault Adjusted Amps B Phase AM	22.36	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Fault Adjusted Amps C Phase AM	22.36	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Fault Operations A Ø	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Fault Operations B Ø	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Fault Operations C Ø	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Fault Operations Ground	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Follow-up Action Required?	n	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Patrol Inspection	General Comments		
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	General Comments	IOC A, B, and C phase	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Current Tap Position	10L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	BCH001182	Charger	429-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	BCH001182	Charger	429-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	BCH001182	Charger	429-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	BCH001182	Charger	429-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	BCH001182	Charger	429-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.2	amps
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	BCH001182	Charger	429-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	BCH001182	Charger	429-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	BCH001182	Charger	429-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	General Comments		
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Max Tap Position	14L	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Regulator As Left Counter	57512	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Amps A Ø	21.0	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Amps B Ø	26.0	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Amps C Ø	27.0	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Bushing Condition	Good	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Fault Operations A Ø	0	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Fault Operations B Ø	0	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Fault Operations C Ø	0	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Fault Operations Ground	0	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	Follow-up Action Required?	n	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	General Comments		
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Vegetation	None	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	General Comments		
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	YD000456	Yard	829-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Switching Operations	0	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Unknown Operations	0	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Fault Operations A Ø	0	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Fault Operations C Ø	0	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Fault Operations Ground	0	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Follow-up Action Required?	n	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Foundation Condition	Good	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	General Comments		
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	General Comments		
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Grounds in Place?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Maintenance Operations	0	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Maintenance Operations	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Operations Counter AF	34	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Operations Counter AL	34	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Operations This Read AM	2	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Switching Operations	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0794	BreakerAirMagnetic	PV-1254	AMCB Readings	Unknown Operations	2	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Fault Operations A Ø	0	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Fault Operations B Ø	0	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Fault Operations C Ø	0	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Fault Operations Ground	0	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Follow-up Action Required?	n	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Foundation Condition	Good	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	General Comments		
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	General Comments		
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Grounds in Place?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Maintenance Operations	0	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Operations Counter AF	183	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Operations Counter AL	183	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Readings	Operations This Read Vac	0	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000487	BreakerVacuum	KC-3323	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	ST000458	Structure	829-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Regulator As Left Counter	110335	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Min Tap Position	16L	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Max Tap Position	16R	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Current Tap Position	12L	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0523	Regulator	729-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	General Comments		
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Panels Dusted?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Trash Emptied?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Unknown Operations	0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Switching Operations	0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	91.0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	110.0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	88.0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	40.12	%
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	32.41	%
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	42.44	%
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	8	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	202	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	194	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	PF000236	PowerFuse	KC-STA SER NO 1	Disconnect PowerFuse Inspection	General Comments	ok	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	PF000236	PowerFuse	KC-STA SER NO 1	Disconnect PowerFuse Inspection	Follow-up Action Required?	n	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	2.7	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	17.8	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	16.0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	13.12	%
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	13.12	%
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	13.12	%
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	8	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Current Tap Position	12L	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	CH000204	ControlHouse	PV-Control House	Control House Patrol Inspection	Broom on Site?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Amps A Ø	202.0	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	9 Month Operations	2	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Fault Operations A Ø	0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Amps C Ø	27.0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Amps B Ø	27.0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Amps A Ø	28.0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Accumulated Fault Duty C Ph V	9.63	%
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Accumulated Fault Duty B Ph V	2.09	%
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Accumulated Fault Duty A Ph V	6.28	%
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	9 Month Operations	11	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Regulator As Left Counter	112022	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0525	Regulator	729-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	9 Month Operations	2	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Amps A Ø	0.0	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Amps B Ø	0.0	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Amps C Ø	0.0	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Bushing Condition	Good	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000486	BreakerVacuum	KC-3322	VCB Readings	9 Month Operations	13	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Operations This Read Vac	0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Operations Counter AL	214	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Operations Counter AF	214	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Maintenance Operations	0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	General Comments		
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Follow-up Action Required?	n	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Fault Operations Ground	0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Fault Operations C Ø	0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Readings	Fault Operations B Ø	0	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	General Comments		
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Max Tap Position	8L	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Min Tap Position	15L	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	R0524	Regulator	729-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Unknown Operations	0	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Tank Paint Condition	Good	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Switching Operations	1	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Operations This Read Vac	1	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Operations Counter AL	256	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Operations Counter AF	256	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Maintenance Operations	0	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Grounds in Place?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	General Comments		
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	General Comments		
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Foundation Condition	Good	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Follow-up Action Required?	n	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Fault Operations Ground	0	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Fault Operations B Ø	0	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Fault Operations A Ø	0	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Patrol Inspection	Bushing Condition	Good	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Amps C Ø	203.0	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0098	BreakerVacuum	429-2162	VCB Readings	Amps B Ø	210.0	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	General Comments		
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	General Comments		
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Grounds in Place?	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Maintenance Operations	0	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Operations Counter AF	213	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Operations Counter AL	213	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Operations This Read Vac	0	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Switching Operations	0	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Tank Paint Condition	Good	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Unknown Operations	0	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	BCH001245	Charger	829-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	BCH001245	Charger	829-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	BCH001245	Charger	829-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	BCH001245	Charger	829-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	BCH001245	Charger	829-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	BCH001245	Charger	829-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	BCH001245	Charger	829-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Fault Operations Ground	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	General Comments		
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.0	VDC
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Ambient Temp	78	*F
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	General Comments		
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Operations Counter AF	223	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Operations Counter AL	223	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Operations This Read Vac	0	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Switching Operations	0	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Tank Paint Condition	Good	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Unknown Operations	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	9.00	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	9.00	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	9.00	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	9	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Unknown Operations	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Switching Operations	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Operations This Read Vac	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Operations Counter AL	147	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Operations Counter AF	147	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Maintenance Operations	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	General Comments		
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Patrol Inspection	General Comments		
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	9 Month Operations	2	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Amps A Ø	0.0	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Amps B Ø	0.0	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Amps C Ø	0.0	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Bushing Condition	Good	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Fault Operations A Ø	0	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Fault Operations B Ø	0	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Fault Operations C Ø	0	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Fault Operations Ground	0	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Readings	Follow-up Action Required?	n	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001122	BreakerVacuum	415-0740	VCB Patrol Inspection	Foundation Condition	Good	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Fault Operations Ground	0	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Fault Operations C Ø	0	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Fault Operations B Ø	0	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Fault Operations A Ø	0	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	LTCC000234	LTCControl	895-1	LTC Control Insp	All Connections OK?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	LTCC000234	LTCControl	895-1	LTC Control Insp	Follow-up Action Required?	n	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	LTCC000234	LTCControl	895-1	LTC Control Insp	General Comments		
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	LTCC000234	LTCControl	895-1	LTC Control Insp	LTC Operation Checked?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	LTCC000234	LTCControl	895-1	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	LTCC000234	LTCControl	895-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	LTCC000234	LTCControl	895-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	LTCC000234	LTCControl	895-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.0	VDC
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	BAT001306	Battery	829-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Amps C Ø	193.0	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Vegetation	None	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	SWG000115	Switchgear	PV-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	9 Months Operations	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Amps A Ø	0.0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Amps B Ø	0.0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Amps C Ø	0.0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Vegetation	None	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	General Comments		
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Amps C Ø	128.0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Amps B Ø	138.0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Amps A Ø	151.0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001369	BreakerVacuum	PV-12KV TR 2	VCB Readings	9 Month Operations	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Unknown Operations	7	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Switching Operations	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Operations This Read Vac	7	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Operations Counter AL	100	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Unknown Operations	0	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Tank Paint Condition	Good	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Switching Operations	1	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Operations This Read Vac	1	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Operations Counter AL	235	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Operations Counter AF	235	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Maintenance Operations	0	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Grounds in Place?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	General Comments		
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Foundation Condition	Good	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Follow-up Action Required?	n	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	869	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	869	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	180.0	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	110.0	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	160.0	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0211	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	9 Month Operations	0	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Amps A Ø	267.0	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Amps B Ø	261.0	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Amps C Ø	292.0	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Bushing Condition	Good	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3997	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	Oil Temp Present	42	°C
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	959.28	kw
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	General Comments		
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	General Comments		
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	B0264	NonLTC	729-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Ambient Temperature	78	°F
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Bushings Connection/Risers	Good	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Cabinet Paint Condition	Good	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Equipment Properly Labeled?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	Fault Operations	0	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	Follow-up Action Required?	n	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Foundation Condition	Good	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Gauge(s) Condition	Good	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	General Comments		
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	General Comments		
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Grounds in Place?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Heaters (All) Functioning?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	Maintenance Operations	0	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Moisture and Leak Free?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	Num Operations Last 9 Months	0	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	Operations Counter AF	15	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	Operations Counter AL	15	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	Operations This Read SF6	0	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	SF6 Bushing Condition	Good	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	SF6 Pressure Indicator	good	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Readings	Switching Operations	0	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	TB0940	BreakerSF6	431-708	GCB Patrol Inspection	Tank Paint Condition	Good	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	General Comments		
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Fault Operations Ground	0	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Fault Operations C Ø	0	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Fault Operations B Ø	0	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	9 Month Operations	5	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Amps A Ø	80.0	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Amps B Ø	95.0	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Amps C Ø	85.0	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Bushing Condition	Good	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Fault Operations A Ø	0	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Fault Operations A Ø	0	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Fault Operations B Ø	0	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Fault Operations C Ø	0	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Fault Operations Ground	0	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Follow-up Action Required?	n	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	General Comments		
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	General Comments		
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Patrol Inspection	Grounds in Place?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Bushing Condition	Good	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Amps C Ø	77.0	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Amps B Ø	108.0	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Amps A Ø	73.0	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	9 Month Operations	3	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BK001093	BreakerVacuum	415-0717	VCB Readings	Maintenance Operations	0	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Fault Operations A Ø	0	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Fault Operations B Ø	0	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Fault Operations C Ø	0	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Fault Operations Ground	0	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Follow-up Action Required?	n	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Foundation Condition	Good	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	General Comments		
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	General Comments		
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Grounds in Place?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	161	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Amps A Ø	20.0	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Amps B Ø	15.0	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Amps C Ø	12.0	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	166	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	184	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	General Comments		
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	X0052	RecloserHydraulic	729-2310	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Maintenance Operations	0	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Operations Counter AF	149	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Operations Counter AL	149	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Operations This Read Vac	0	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Switching Operations	0	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Patrol Inspection	Tank Paint Condition	Good	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	KB0085	BreakerVacuum	829-1	VCB Readings	Unknown Operations	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	9	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	0	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Unknown Operations	0	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Tank Paint Condition	Good	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Switching Operations	0	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Operations This Read Vac	0	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Operations Counter AL	167	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Operations Counter AF	167	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	Maintenance Operations	0	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Grounds in Place?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Readings	General Comments		
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	General Comments		
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0099	BreakerVacuum	429-2154	VCB Patrol Inspection	Foundation Condition	Good	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	9	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	108	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	108	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001370	BreakerVacuum	PV-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Maintenance Operations	0	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Operations Counter AF	255	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Operations Counter AL	255	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Operations This Read Vac	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Switching Operations	0	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Unknown Operations	0	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	9 Month Operations	0	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Amps A Ø	36.0	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Amps B Ø	40.0	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Amps C Ø	42.0	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Bushing Condition	Good	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Fault Operations A Ø	0	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Fault Operations B Ø	0	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Fault Operations C Ø	0	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Fault Operations Ground	0	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Follow-up Action Required?	n	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Foundation Condition	Good	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	General Comments		
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	General Comments		
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Grounds in Place?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Maintenance Operations	0	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Operations Counter AF	185	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Operations Counter AL	185	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Operations This Read Vac	0	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Switching Operations	0	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000716	BreakerVacuum	KC-34KV TR 1	VCB Readings	Unknown Operations	0	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	PF000194	PowerFuse	KC-34KV WEST BUS POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	PF000194	PowerFuse	KC-34KV WEST BUS POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	BCH000566	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	BCH000566	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	BCH000566	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	BCH000566	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	BCH000566	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	BCH000566	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Counter Readings	LTC Operations Since Last Insp	608	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Counter Readings	LTC Min Tap Position	14L	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Counter Readings	LTC Max Tap Position	1L	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Counter Readings	LTC Current Tap Position	6L	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Counter Readings	LTC As Left Counter	19101	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Counter Readings	LTC As Found Counter	19098	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Mechanism Patrol Inspection	General Comments		
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Counter Readings	General Comments		
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	C0499	LTCMechanism	829-1	LTC Counter Readings	Follow-up Action Required?	n	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	9 Month Operations	0	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Amps A Ø	0.0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	PF000274	PowerFuse	PV-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	PF000274	PowerFuse	PV-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	PF000273	PowerFuse	PV-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	PF000273	PowerFuse	PV-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Amps B Ø	0.0	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Amps C Ø	0.0	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Bushing Condition	Good	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Fault Operations A Ø	0	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Fault Operations B Ø	0	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Fault Operations C Ø	0	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Fault Operations Ground	0	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	Follow-up Action Required?	n	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Foundation Condition	Good	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	General Comments		
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Readings	General Comments		
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Grounds in Place?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	BK000715	BreakerVacuum	KC-3321	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Counter Readings	General Comments		
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	General Comments		
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	FE000559	Fence	KC-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	General Comments		
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	General Comments	Transformer needs nitrogen in bottle	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	TX000035	WithLTC	PV-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	ST000573	Structure	KC-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	General Comments		
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Vegetation	None	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	YD000657	Yard	PV-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LTCC000623	LTCControl	PV-TRANS 2	LTC Control Insp	VRR Time Delay	30	Seconds
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LTCC000623	LTCControl	PV-TRANS 2	LTC Control Insp	VRR Base Voltage AL	122.5	VAC
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LTCC000623	LTCControl	PV-TRANS 2	LTC Control Insp	VRR Base Voltage AF	122.5	VAC
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LTCC000623	LTCControl	PV-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LTCC000623	LTCControl	PV-TRANS 2	LTC Control Insp	LTC Output Voltage Level	122.5	VAC
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LTCC000623	LTCControl	PV-TRANS 2	LTC Control Insp	LTC Operation Checked?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LTCC000623	LTCControl	PV-TRANS 2	LTC Control Insp	General Comments		
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LTCC000623	LTCControl	PV-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LTCC000623	LTCControl	PV-TRANS 2	LTC Control Insp	All Connections OK?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	415	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	25	°C
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	42	°C
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.5	psi
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Counter Readings	LTC Min Tap Position	11L	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Counter Readings	LTC Max Tap Position	2L	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Counter Readings	LTC Current Tap Position	10L	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Counter Readings	LTC As Left Counter	9090	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LTCM000019	LTCMechanism	PV-TRANS 2	LTC Counter Readings	LTC As Found Counter	9090	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Ambient Temp	71	°F
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	General Comments		
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	YD000569	Yard	KC-Yard	Yard Patrol Inspection	Vegetation	None	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Fault Operations Ground	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Fault Operations C ∅	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Fault Operations B ∅	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Fault Operations A ∅	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Amps C ∅	1.0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Amps B ∅	1.0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Amps A ∅	1.0	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	General Comments		
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	YD000386	Yard	415-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	9 Month Operations	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001366	BreakerVacuum	PV-1257	VCB Readings	Unknown Operations	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001366	BreakerVacuum	PV-1257	VCB Readings	Switching Operations	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001366	BreakerVacuum	PV-1257	VCB Readings	Operations This Read Vac	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001366	BreakerVacuum	PV-1257	VCB Readings	Operations Counter AL	101	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001366	BreakerVacuum	PV-1257	VCB Readings	Operations Counter AF	101	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001366	BreakerVacuum	PV-1257	VCB Readings	Maintenance Operations	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001366	BreakerVacuum	PV-1257	VCB Readings	General Comments		
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001366	BreakerVacuum	PV-1257	VCB Patrol Inspection	General Comments		
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001366	BreakerVacuum	PV-1257	VCB Readings	Follow-up Action Required?	n	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001366	BreakerVacuum	PV-1257	VCB Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001366	BreakerVacuum	PV-1257	VCB Readings	Fault Operations Ground	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001366	BreakerVacuum	PV-1257	VCB Readings	Fault Operations C Ø	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001366	BreakerVacuum	PV-1257	VCB Readings	Fault Operations B Ø	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001366	BreakerVacuum	PV-1257	VCB Readings	Fault Operations A Ø	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001366	BreakerVacuum	PV-1257	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001366	BreakerVacuum	PV-1257	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001366	BreakerVacuum	PV-1257	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001366	BreakerVacuum	PV-1257	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001366	BreakerVacuum	PV-1257	VCB Readings	Amps C Ø	65.0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001366	BreakerVacuum	PV-1257	VCB Readings	Amps B Ø	63.0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001366	BreakerVacuum	PV-1257	VCB Readings	Amps A Ø	64.0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Fault Operations A Ø	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Fault Operations B Ø	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Fault Operations C Ø	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Fault Operations Ground	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Follow-up Action Required?	n	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Patrol Inspection	General Comments		
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	General Comments		
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Maintenance Operations	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Operations Counter AF	747	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Operations Counter AL	747	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Operations This Read AM	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Switching Operations	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0792	BreakerAirMagnetic	PV-1252	AMCB Readings	Unknown Operations	0	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Amps B Ø	203.0	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Amps A Ø	183.0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Operations Counter AF	100	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Maintenance Operations	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	General Comments	Actual counter	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Patrol Inspection	General Comments		
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Follow-up Action Required?	n	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Fault Operations Ground	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Fault Operations C Ø	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Fault Operations B Ø	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Fault Operations A Ø	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Fault Adjusted Amps C Phase V	78.26	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Fault Adjusted Amps B Phase V	78.26	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Fault Adjusted Amps A Phase V	78.26	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Amps C Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Amps B Ø	0.0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Amps A Ø	0.0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001368	BreakerVacuum	PV-1259	VCB Readings	9 Month Operations	7	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Unknown Operations	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Switching Operations	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Operations This Read Vac	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Operations Counter AL	131	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0097	BreakerVacuum	429-2313	VCB Readings	9 Month Operations	1	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Operations Counter AF	131	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Maintenance Operations	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	General Comments	AST needs tuning	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Patrol Inspection	General Comments		
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001367	BreakerVacuum	PV-1258	VCB Readings	Follow-up Action Required?	n	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Ambient Temp	77	*F
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Switching Operations	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Operations This Read Vac	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Operations Counter AL	92	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Operations Counter AF	92	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Maintenance Operations	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	General Comments	AST needs tuning	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Patrol Inspection	General Comments		
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Follow-up Action Required?	n	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Fault Operations Ground	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Fault Operations C Ø	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Fault Operations B Ø	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Fault Operations A Ø	0	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	149	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Amps A Ø	33.0	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Amps B Ø	28.0	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Amps C Ø	19.0	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	149	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	199	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	General Comments		
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Operations Counter	0	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/10/2020 15:04	Distribution	Paint Lick Quarterly Inspection	CX0122	RecloserHydraulic	729-2309	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Amps C Ø	34.0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Amps B Ø	24.0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Amps A Ø	31.0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	9 Month Operations	4	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	General Comments		
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001366	BreakerVacuum	PV-1257	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001366	BreakerVacuum	PV-1257	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001366	BreakerVacuum	PV-1257	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001366	BreakerVacuum	PV-1257	VCB Readings	9 Month Operations	6	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001365	BreakerVacuum	PV-1256	VCB Readings	Unknown Operations	3	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001365	BreakerVacuum	PV-1256	VCB Readings	Switching Operations	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001365	BreakerVacuum	PV-1256	VCB Readings	Operations This Read Vac	3	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001365	BreakerVacuum	PV-1256	VCB Readings	Operations Counter AL	125	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001365	BreakerVacuum	PV-1256	VCB Readings	Operations Counter AF	125	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001365	BreakerVacuum	PV-1256	VCB Readings	Maintenance Operations	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001365	BreakerVacuum	PV-1256	VCB Readings	General Comments	ARC sense A phase, Actual counter	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001365	BreakerVacuum	PV-1256	VCB Patrol Inspection	General Comments		
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001365	BreakerVacuum	PV-1256	VCB Readings	Follow-up Action Required?	n	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001365	BreakerVacuum	PV-1256	VCB Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001365	BreakerVacuum	PV-1256	VCB Readings	Fault Operations Ground	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001365	BreakerVacuum	PV-1256	VCB Readings	Fault Operations C Ø	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001365	BreakerVacuum	PV-1256	VCB Readings	Fault Operations B Ø	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001365	BreakerVacuum	PV-1256	VCB Readings	Fault Operations A Ø	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001365	BreakerVacuum	PV-1256	VCB Readings	Fault Adjusted Amps C Phase V	33.54	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001365	BreakerVacuum	PV-1256	VCB Readings	Fault Adjusted Amps B Phase V	33.54	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001365	BreakerVacuum	PV-1256	VCB Readings	Fault Adjusted Amps A Phase V	33.54	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001365	BreakerVacuum	PV-1256	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001365	BreakerVacuum	PV-1256	VCB Readings	Amps C Ø	86.0	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	General Comments		
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	78	*F
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001365	BreakerVacuum	PV-1256	VCB Readings	Amps B Ø	50.0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001365	BreakerVacuum	PV-1256	VCB Readings	Amps A Ø	73.0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001365	BreakerVacuum	PV-1256	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001365	BreakerVacuum	PV-1256	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001365	BreakerVacuum	PV-1256	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001365	BreakerVacuum	PV-1256	VCB Readings	9 Month Operations	10	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	BK001363	BreakerVacuum	PV-1255	VCB Readings	Unknown Operations	0	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	78	*F
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	BAT000631	Battery	431-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Vegetation	None	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	General Comments		
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	YD000533	Yard	429-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Maintenance Operations	0	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Grounds in Place?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	General Comments		
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	General Comments		
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Foundation Condition	Good	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Follow-up Action Required?	n	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Fault Operations Ground	0	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Fault Operations C Ø	0	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Fault Operations B Ø	0	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Fault Operations A Ø	0	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	LTCC000027	LTCControl	415-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Maintenance Operations	0	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	LTCC000027	LTCControl	415-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	General Comments	IOC A phase	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Patrol Inspection	General Comments		
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Follow-up Action Required?	n	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Fault Operations Ground	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Fault Operations C Ø	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Fault Operations B Ø	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Fault Operations A Ø	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	LTCC000027	LTCControl	415-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	LTCC000027	LTCControl	415-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Counter Readings	LTC Max Tap Position	12L	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Counter Readings	LTC Min Tap Position	4L	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	35	°C
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	40	°C
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Counter Readings	LTC Operations Since Last Insp	826	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Broom on Site?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Amps C Ø	20.0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Amps B Ø	20.0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Amps A Ø	20.0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	9 Months Operations	3	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Amps A Ø	450.0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Amps B Ø	450.0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	75.62	%
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	88.73	%
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	22	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	General Comments		
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Tank Paint Condition	Good	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Unknown Operations	0	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Trash Emptied?	n	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	Oil Temp Max	70	°C
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	Oil Temp Present	50	°C
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Filters Condition OK?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	General Comments		
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	60	°C
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	30	°C
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	70	°C
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	40	°C
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	70	°C
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	40	°C
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	PT000660	PT	KC-34KV WEST BUS POT	PT Patrol Inspection	PT Free of Leaks?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	PT000660	PT	KC-34KV WEST BUS POT	PT Patrol Inspection	Tank Oil Level	Good	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	PT000660	PT	KC-34KV WEST BUS POT	PT Patrol Inspection	Tank Paint Condition	Good	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	Totalizer Meter Reading	.2984	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Panels Dusted?	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	LTCC000027	LTCControl	415-1	LTC Control Insp	All Connections OK?	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	LTCC000027	LTCControl	415-1	LTC Control Insp	Follow-up Action Required?	n	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	LTCC000027	LTCControl	415-1	LTC Control Insp	General Comments		
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	LTCC000027	LTCControl	415-1	LTC Control Insp	LTC Operation Checked?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Unknown Operations	0	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Tank Paint Condition	Good	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Switching Operations	0	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Operations This Read Vac	0	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Operations Counter AL	162	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Operations Counter AF	162	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	9 Months Operations	1	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Bushing Condition	Good	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	LTCC000694	LTCControl	829-1	LTC Control Insp	All Connections OK?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	LTCC000694	LTCControl	829-1	LTC Control Insp	Follow-up Action Required?	n	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	LTCC000694	LTCControl	829-1	LTC Control Insp	General Comments		
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	LTCC000694	LTCControl	829-1	LTC Control Insp	LTC Operation Checked?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Amps C Ø	0.0	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Amps B Ø	16.0	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Amps A Ø	16.0	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	9 Month Operations	0	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	LTCC000694	LTCControl	829-1	LTC Control Insp	LTC Output Voltage Level	123.1	VAC
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	LTCC000694	LTCControl	829-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	LTCC000694	LTCControl	829-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	LTCC000694	LTCControl	829-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Trash Emptied?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Panels Dusted?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	General Comments		
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Trip-energy Supply Verified	y	LED lights?
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Indicator Zone	OK	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Bushing Condition	Good	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	General Comments		
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	77	°F
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	BAT000569	Battery	429-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Amps C Ø	450.0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	27.00	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	27.00	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	27.00	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Fault Operations A Ø	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Fault Operations B Ø	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Fault Operations C Ø	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Fault Operations Ground	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Follow-up Action Required?	n	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Patrol Inspection	General Comments		
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	General Comments		
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Maintenance Operations	0	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	PT000660	PT	KC-34KV WEST BUS POT	PT Patrol Inspection	Grounds in Place?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	PT000660	PT	KC-34KV WEST BUS POT	PT Patrol Inspection	General Comments		
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	PT000660	PT	KC-34KV WEST BUS POT	PT Patrol Inspection	Foundation Condition	Good	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	PT000660	PT	KC-34KV WEST BUS POT	PT Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	PT000660	PT	KC-34KV WEST BUS POT	PT Patrol Inspection	Equipment Properly Labeled?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	9 Months Operations	9	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Amps A Ø	50.0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Amps B Ø	50.0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Amps C Ø	50.0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Fault Adjusted Amps A Phase AM	22.36	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Fault Adjusted Amps B Phase AM	22.36	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Fault Adjusted Amps C Phase AM	22.36	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Fault Operations A Ø	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Operations Counter AF	8	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Operations Counter AL	8	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Operations This Read AM	1	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Switching Operations	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0796	BreakerAirMagnetic	PV-12KV TR 1	AMCB Readings	Unknown Operations	1	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Fault Operations B Ø	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Fault Operations C Ø	0	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Panels Dusted?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KB0033	BreakerVacuum	431-4311	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	General Comments		
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	CH000332	ControlHouse	431-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Fault Operations Ground	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Follow-up Action Required?	n	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Patrol Inspection	General Comments		
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	General Comments	Actual counter, IOC B phase	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Maintenance Operations	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Operations Counter AF	121	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Operations Counter AL	121	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Operations This Read AM	2	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Switching Operations	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0793	BreakerAirMagnetic	PV-1253	AMCB Readings	Unknown Operations	2	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Readings	General Comments		
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	General Comments		
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Follow-up Action Required?	n	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Foundation Condition	Good	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	General Comments		
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	General Comments		
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Grounds in Place?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Maintenance Operations	0	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Operations Counter AF	154	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Operations Counter AL	154	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Operations This Read Vac	0	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Switching Operations	0	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Tank Paint Condition	Good	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Unknown Operations	0	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Counter Readings	LTC As Left Counter	38679	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Counter Readings	LTC As Found Counter	38675	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Mechanism Patrol Inspection	General Comments		
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Counter Readings	General Comments		
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Counter Readings	Follow-up Action Required?	n	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Fault Operations A Ø	0	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Fault Operations B Ø	0	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Fault Operations C Ø	0	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	LTC Totalizer Reading	9611.36	kw
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	General Comments		
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	General Comments		
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	General Comments		
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Fault Operations Ground	0	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Fault Operations C Ø	0	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Fault Operations B Ø	0	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	900	psi
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	Oil Temp Max	40	°C
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Readings	X2 Winding Temp Present	40	°C
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Readings	X2 Winding Temp Max	50	°C
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	887	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	887	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	Oil Temp Present	35	°C
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	9 Month Operations	4	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Amps A Ø	0.0	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Amps B Ø	0.0	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Amps C Ø	0.0	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Bushing Condition	Good	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	Totalizer Meter Multiplier	10160	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	Totalizer Meter Reading	.9460	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	Winding Temp Max	50	°C
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	Winding Temp Present	45	°C
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Readings	Oil Temp Present	39	°C
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Readings	Oil Temp Max	46	°C
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	71.00	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Readings	H2 Winding Temp Present	45	°C
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Readings	H2 Winding Temp Max	55	°C
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	8	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	8	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	356	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	348	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Operations This Read Vac	2	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Switching Operations	2	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LT0161	WithLTC	PV-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Unknown Operations	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Switching Operations	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Operations This Read AM	0	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Operations Counter AL	210	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0791	BreakerAirMagnetic	PV-1251	AMCB Readings	Operations Counter AF	210	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	87.0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	57.0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	55.0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	76.39	%
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Fault Operations A Ø	0	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	LT0103	NonLTC	KC-TRANS 1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Fault Operations Ground	0	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Follow-up Action Required?	n	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Foundation Condition	Good	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	General Comments		
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	General Comments		
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Grounds in Place?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	ST000537	Structure	429-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	LTCC000031	LTCControl	431-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	LTCC000031	LTCControl	431-1	LTC Control Insp	VRR Base Voltage AL	127.0	VAC
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	LTCC000031	LTCControl	431-1	LTC Control Insp	VRR Base Voltage AF	127.0	VAC
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	LTCC000031	LTCControl	431-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	LTCC000031	LTCControl	431-1	LTC Control Insp	LTC Output Voltage Level	126.0	VAC
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	LTCC000031	LTCControl	431-1	LTC Control Insp	LTC Operation Checked?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	LTCC000031	LTCControl	431-1	LTC Control Insp	General Comments		
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	LTCC000031	LTCControl	431-1	LTC Control Insp	Follow-up Action Required?	n	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	LTCC000031	LTCControl	431-1	LTC Control Insp	All Connections OK?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Patrol Inspection	Bushing Condition	Good	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Amps C Ø	464.0	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Amps B Ø	521.0	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Amps A Ø	472.0	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KB0122	BreakerVacuum	429-1	VCB Readings	9 Month Operations	0	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Maintenance Operations	0	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Operations Counter AF	228	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KT0042	LTCMechanism	429-1	LTC Counter Readings	LTC Current Tap Position	4L	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	CB0210	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Operations Counter AL	228	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	LTC Totalizer Reading	6552.00	kw
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	General Comments		
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	General Comments		
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	General Comments		
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BAT001324	Battery	415-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BCH001266	Charger	415-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BCH001266	Charger	415-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BCH001266	Charger	415-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BCH001266	Charger	415-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BCH001266	Charger	415-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.3	amps
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BCH001266	Charger	415-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BCH001266	Charger	415-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	BCH001266	Charger	415-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	General Comments		
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	General Comments		
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	General Comments		
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	LTC Totalizer Reading	777.60	kw
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	Oil Temp Max	60	°C
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	Oil Temp Present	40	°C
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Amps B Ø	3.5	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Amps A Ø	3.4	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Accumulated Fault Duty C Ph V	6.28	%
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Accumulated Fault Duty B Ph V	4.19	%
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Accumulated Fault Duty A Ph V	4.19	%
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KT0024	WithLTC	431-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	Winding Temp Present	40	°C
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	General Comments		
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	Winding Temp Max	42	°C
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	Totalizer Meter Reading	.4550	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	Oil Temp Present	40	°C
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Readings	Oil Temp Max	45	°C
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	700	psi
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	KT0042	WithLTC	429-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Fault Operations C Ø	0	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Fault Operations B Ø	0	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Fault Operations A Ø	0	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Bushing Condition	Good	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Amps C Ø	60.0	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Unknown Operations	0	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Tank Paint Condition	Good	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Switching Operations	0	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Operations This Read Vac	0	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Operations Counter AL	1584	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Operations Counter AF	1584	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Amps B Ø	20.0	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Amps A Ø	60.0	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Broom on Site?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
11/11/2020 7:54	Distribution	Knob Creek Quarterly Inspection	CH000170	ControlHouse	KC-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	9 Month Operations	4	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	9 Month Operations	3	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	CH000418	ControlHouse	429-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	General Comments		
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	ST000636	Structure	PV-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	FE000528	Fence	429-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	General Comments		
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	Totalizer Meter Reading	.1620	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	W0309	WithLTC	415-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Unknown Operations	0	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Tank Paint Condition	Good	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Switching Operations	0	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Counter Readings	General Comments		
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Counter Readings	LTC As Found Counter	151353	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Counter Readings	LTC As Left Counter	151353	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1R	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Counter Readings	LTC Min Tap Position	11L	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	704	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LT0161	LTCMechanism	PV-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	LTCC000570	LTCControl	429-1	LTC Control Insp	All Connections OK?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	LTCC000570	LTCControl	429-1	LTC Control Insp	Follow-up Action Required?	n	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	LTCC000570	LTCControl	429-1	LTC Control Insp	General Comments		
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	LTCC000570	LTCControl	429-1	LTC Control Insp	LTC Operation Checked?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	LTCC000570	LTCControl	429-1	LTC Control Insp	LTC Output Voltage Level	123.3	VAC
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	LTCC000570	LTCControl	429-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	LTCC000570	LTCControl	429-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	LTCC000570	LTCControl	429-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Operations This Read Vac	0	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Operations Counter AL	269	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Operations Counter AF	269	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	FE000652	Fence	PV-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Maintenance Operations	0	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Grounds in Place?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	General Comments		
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	General Comments		
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Foundation Condition	Good	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Follow-up Action Required?	n	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Fault Operations Ground	0	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	FE000848	Fence	415-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	FE000848	Fence	415-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	FE000848	Fence	415-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	FE000848	Fence	415-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	FE000848	Fence	415-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	FE000848	Fence	415-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	General Comments		
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Fault Operations Ground	0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Fault Operations C Ø	0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Fault Operations B Ø	0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Fault Operations A Ø	0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Operations This Read Vac	4	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Switching Operations	4	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Unknown Operations	0	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Ambient Temperature	77	°F
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Bushings Connection/Risers	Good	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Heaters Functioning?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Internal Condition?	Clean	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Foundation Condition	Good	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	General Comments		
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Grounds in Place?	y	
11/10/2020 13:59	Distribution	Richmond 2 Quarterly Inspection	CS000002	CircuitSwitcher	429-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Moisture and Leak Free?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	General Comments		
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	Oil Temp Present	45	°C
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	Oil Temp Max	50	°C
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	9 Month Operations	16	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Accumulated Fault Duty A Ph V	17.1	%
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Accumulated Fault Duty B Ph V	10.68	%
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Accumulated Fault Duty C Ph V	8.85	%
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Unknown Operations	0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Switching Operations	0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Operations This Read Vac	0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Operations Counter AL	127	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Operations Counter AF	127	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Maintenance Operations	0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	General Comments		
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Amps A Ø	0.0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Amps B Ø	0.0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Amps C Ø	0.0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Follow-up Action Required?	n	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	FE000848	Fence	415-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	FE000848	Fence	415-Fence	Fence Patrol Inspection	General Comments		
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	FE000848	Fence	415-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	FE000848	Fence	415-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Fault Operations A Ø	0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Fault Operations B Ø	0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Fault Operations C Ø	0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Fault Operations Ground	0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Follow-up Action Required?	n	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	General Comments		
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Maintenance Operations	0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Operations Counter AF	315	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Readings	Operations Counter AL	315	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	FE000848	Fence	415-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	FE000848	Fence	415-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	FE000848	Fence	415-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	FE000848	Fence	415-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	FE000848	Fence	415-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	Follow-up Action Required?	n	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	General Comments		
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	General Comments		
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	LTC As Found Counter	32762	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	LTC As Left Counter	32762	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	45	°C
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	LTC Min Tap Position	Neutral	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Patrol Inspection	General Comments		
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	LTC Max Tap Position	2R	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	General Comments		
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/12/2020 11:44	Distribution	Plainview Quarterly Inspection	LB0790	BreakerAirMagnetic	PV-1250	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 11:11	Distribution	Richmond East Quarterly Inspection	FE000451	Fence	829-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Counter Readings	LTC Operations Since Last Insp	487	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Amps C Ø	3.5	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	LTC Totalizer Reading	2864.64	kw
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/10/2020 11:58	Distribution	Ghent City Quarterly Inspection	ST000849	Structure	415-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	General Comments		
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	General Comments		
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/10/2020 16:49	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	ST000508	Structure	431-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/10/2020 13:45	Distribution	Airgas Quarterly Inspection	KT0024	LTCMechanism	431-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	35	°C
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BCH000194	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	134.5	VDC
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	40	°C
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BCH000194	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	134.5	VDC
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	35	°C
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BCH000194	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.8	amps
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BCH000194	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BCH000194	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BCH000194	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	4	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Tank Leaks	None	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Unknown Operations	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	175.0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	90.0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	90.0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	PF000130	PowerFuse	FA-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	PF000130	PowerFuse	FA-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	C0443	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	C0443	LTCMechanism	Retired Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	C0443	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	C0443	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	C0443	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Operations Since Last Insp	126	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	C0443	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Min Tap Position	3L	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	55	°C
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	45	°C
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	70	°C
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	1	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Air Pressure OK?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Bushing Condition	Good	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Bushing Oil Level	Good	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Fault Operations	0	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Air Leaks	None	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Air Compressor Oil Status	Good	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	250.0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	225.0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	225.0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Follow-up Action Required?	n	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Foundation Condition	Good	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	650	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Gauge(s) Condition	Good	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	General Comments		
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	General Comments		
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Grounds in Place?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	650	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Maintenance Operations	0	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Number of Ops last 9 Months	1	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Operations Counter AF	335	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Operations Counter AL	335	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Operations This Read Oil	0	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Pop-off Valve Tested Date	2020-02-12 00:00:00.000000	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Pressure Vessel Condition	Good	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Readings	Switching Operations	0	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Tank 1 Oil Level	Good	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Tank 2 Oil level	Good	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	TB0589	BreakerOil	818-708	OCB Patrol Inspection	Tank 3 Oil Level	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Maintenance Operations	0	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Operations Counter AF	269	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Operations Counter AL	269	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Operations This Read Vac	1	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	PF000377	PowerFuse	TE-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	PF000377	PowerFuse	TE-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	PF000377	PowerFuse	TE-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	PF000378	PowerFuse	TE-12KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	PF000378	PowerFuse	TE-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	PF000378	PowerFuse	TE-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Broom on Site?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Readings	Oil Temp Present	42	°C
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Readings	Oil Temp Max	45	°C
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	General Comments		
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	Negative DC Ground	10.8	VDC
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	Positive DC Ground	11.7	VDC
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Switching Operations	1	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	General Comments		
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Readings	LTC Totalizer Reading	5218.56	kw
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	125	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	125	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	General Comments		
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Unknown Operations	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1322	BreakerVacuum	FA-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	0	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BCH000194	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.500	millivolts
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0324	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Broom on Site?	n	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	9 Month Operations	15	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Amps A Ø	115.0	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Amps B Ø	140.0	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Amps C Ø	105.0	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Bushing Condition	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	C0443	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Max Tap Position	1L	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	C0443	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Current Tap Position	2L	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	C0443	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	General Comments		
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Follow-up Action Required?	n	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Fault Operations Ground	0	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Fault Operations C Ø	0	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Fault Operations B Ø	0	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0083	BreakerVacuum	067-0704	VCB Readings	Fault Operations A Ø	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	n	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	Oil Temp Present	55	°C
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	Oil Temp Max	70	°C
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	General Comments		
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	C0443	LTCMechanism	Retired Distribution	LTC Counter Readings	Follow-up Action Required?	n	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	C0443	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	C0443	LTCMechanism	Retired Distribution	LTC Counter Readings	General Comments		
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	General Comments		
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	CH000405	ControlHouse	882-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	C0443	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	General Comments		
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	C0443	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Found Counter	41323	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	C0443	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Left Counter	41323	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	H2 Winding Temp Max	72	°C
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	General Comments		
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Grounds in Place?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	General Comments		
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Foundation Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000006	BreakerVacuum	072-3406	VCB Patrol Inspection	Bushing Condition	Good	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0071	WithLTC	FA-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	25	°C
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	9 Month Operations	1	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Accumulated Fault Duty A Ph V	1.17	%
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Accumulated Fault Duty B Ph V	.94	%
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Accumulated Fault Duty C Ph V	.47	%
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Amps A Ø	94.0	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Amps B Ø	101.0	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Amps C Ø	108.0	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Fault Operations A Ø	0	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Fault Operations B Ø	0	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Fault Operations C Ø	0	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Fault Operations Ground	0	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Follow-up Action Required?	n	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	General Comments		
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Maintenance Operations	0	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Operations Counter AF	212	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Operations Counter AL	212	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Operations This Read Vac	0	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Switching Operations	0	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Unknown Operations	0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Acceptable Building Appearance?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Broom on Site?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	10	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	58	°C
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	91	°C
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	32	°C
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	65	°C
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	General Comments		
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	BAT001015	Battery	TE-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	Oil Temp Present	45	°C
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	Oil Temp Max	68	°C
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.3	psi
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	H2 Winding Temp Present	40	°C
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Tank Leaks	None	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Regulator As Left Counter	8985	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Min Tap Position	2L	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Max Tap Position	3R	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	General Comments		
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Current Tap Position	2R	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	RG000039	Regulator	072-3 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	65	°C
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	45	°C
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	65	°C
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	45	°C
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	70	°C
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	Oil Temp Present	40	°C
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	Oil Temp Max	55	°C
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.8	psi
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	PF000380	PowerFuse	TE-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	PF000380	PowerFuse	TE-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	PF000380	PowerFuse	TE-12KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	PF000131	PowerFuse	FA-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	PF000131	PowerFuse	FA-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LTCC000364	LTCControl	TE-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LTCC000364	LTCControl	TE-TRANS 2	LTC Control Insp	General Comments		
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LTCC000364	LTCControl	TE-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	General Comments	oil leak from pump, has porcelain arrester	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	General Comments		
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	PF000379	PowerFuse	TE-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	PF000379	PowerFuse	TE-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	PF000379	PowerFuse	TE-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Grounds in Place?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	General Comments		
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Foundation Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000560	BreakerVacuum	072-0282	VCB Patrol Inspection	Bushing Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Control House Lighting OK?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	572.0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	481.0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	501.0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	99790	
8/6/2020 5:31	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	9 Month Operations	2	
8/6/2020 5:31	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Accumulated Fault Duty A Ph V	1.17	%
8/6/2020 5:31	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Accumulated Fault Duty B Ph V	.94	%
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	99790	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0364	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Door Alarms OK?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Evidence of Insects	None	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Floor Swept?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	General Comments		
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Panel Lights OK?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Panels Dusted?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Trash Emptied?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	CH000272	ControlHouse	072-Control House Distribution	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
8/6/2020 5:31	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Accumulated Fault Duty C Ph V	.47	%
8/6/2020 5:31	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Amps A Ø	105.0	
8/6/2020 5:31	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Amps B Ø	108.0	
8/6/2020 5:31	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Amps C Ø	115.0	
8/6/2020 5:31	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/6/2020 5:31	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/6/2020 5:31	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/6/2020 5:31	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Fault Operations A Ø	0	
8/6/2020 5:31	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Fault Operations B Ø	0	
8/6/2020 5:31	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Fault Operations C Ø	0	
8/6/2020 5:31	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Fault Operations Ground	0	
8/6/2020 5:31	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Follow-up Action Required?	n	
8/6/2020 5:31	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	General Comments		
8/6/2020 5:31	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Maintenance Operations	0	
8/6/2020 5:31	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Operations Counter AF	211	
8/6/2020 5:31	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Operations Counter AL	212	
8/6/2020 5:31	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Operations This Read Vac	1	
8/6/2020 5:31	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Switching Operations	1	
8/6/2020 5:31	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Readings	Unknown Operations	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0072	WithLTC	FA-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	45	°C
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Operations Counter AL	649	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Operations Counter AF	649	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Maintenance Operations	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Patrol Inspection	General Comments		
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Follow-up Action Required?	n	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Fault Operations Ground	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Fault Operations C Ø	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Fault Operations B Ø	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Fault Operations A Ø	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Amps C Ø	90.0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Amps B Ø	87.0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Amps A Ø	106.0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	9 Months Operations	3	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	General Comments		
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Regulator As Left Counter	7015	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Counter Readings	General Comments		
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Counter Readings	LTC As Found Counter	4336	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Bushing Condition	Good	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Amps C Ø	58.0	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Amps B Ø	70.0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	A and B phase IOC	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1035	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1035	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	1	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0316	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Readings	General Comments	ok	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LTCC000435	LTCControl	FA-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LTCC000435	LTCControl	FA-TRANS 2	LTC Control Insp	General Comments		
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	LTCC000657	LTCControl	722-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	LTCC000657	LTCControl	722-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	LTCC000657	LTCControl	722-1	LTC Control Insp	VRR Base Voltage AF	123.3	VAC
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	LTCC000657	LTCControl	722-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	LTCC000657	LTCControl	722-1	LTC Control Insp	LTC Operation Checked?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Unknown Operations	0	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Switching Operations	1	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Operations This Read Vac	1	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Operations Counter AL	150	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Operations Counter AF	149	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Maintenance Operations	0	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	General Comments		
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	LTCC000657	LTCControl	722-1	LTC Control Insp	General Comments		
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	LTCC000657	LTCControl	722-1	LTC Control Insp	Follow-up Action Required?	n	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	LTCC000657	LTCControl	722-1	LTC Control Insp	All Connections OK?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	General Comments		
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Follow-up Action Required?	n	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Fault Operations Ground	0	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Fault Operations C ∅	0	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Fault Operations B ∅	0	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Fault Operations A ∅	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LTCC000435	LTCControl	FA-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LTCC000434	LTCControl	FA-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LTCC000434	LTCControl	FA-TRANS 1	LTC Control Insp	General Comments		
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LTCC000434	LTCControl	FA-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	RG000108	Regulator	504-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Unknown Operations	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Switching Operations	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0994	BreakerAirMagnetic	TE-1243	AMCB Readings	Operations This Read AM	0	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Ambient Temp	59	*F
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	922	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	922	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	45	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	55	*C
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	72	*C
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	55	*C
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	55	*C
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	47	*C
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	65	*C
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	Oil Temp Present	47	°C
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	Oil Temp Max	47	°C
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	General Comments		
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0193	WithLTC	TE-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	49	°C
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0192	WithLTC	TE-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	89	°C
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Retired Distribution	Follow-up Action Required?	n
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0315	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Amps A Ø	51.0	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK000797	BreakerVacuum	722-0300	VCB Readings	9 Month Operations	2	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Counter Readings	LTC As Left Counter	4336	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6L	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4R	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Counter Readings	LTC Min Tap Position	9L	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	27	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0078	LTCMechanism	FL-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	General Comments		
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	LTCC000228	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	LTCC000228	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	LTCC000228	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	LTCC000228	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	LTCC000228	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	LTCC000228	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	LTCC000228	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	LTCC000228	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BCH000219	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.3	VDC
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BCH000219	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.3	VDC
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BCH000219	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	2.1	amps
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BCH000219	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BCH000219	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	88.0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	89.0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	89.0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0362	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	45	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Vegetation	None	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	General Comments		
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	YD0000616	Yard	TE-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	YD0000616	Yard	TE-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	YD0000616	Yard	TE-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	YD0000616	Yard	TE-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	YD0000616	Yard	TE-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	YD0000616	Yard	TE-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	YD0000616	Yard	TE-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	YD0000616	Yard	TE-Yard	Yard Patrol Inspection	General Comments		
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	YD0000616	Yard	TE-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	YD0000616	Yard	TE-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	YD0000616	Yard	TE-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	YD0000616	Yard	TE-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
8/6/2020 5:31	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Counter Readings	General Comments		
8/6/2020 5:31	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Counter Readings	Follow-up Action Required?	n	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Counter Readings	General Comments		
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	560	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Counter Readings	LTC Min Tap Position	16L	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Counter Readings	LTC Max Tap Position	7L	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Counter Readings	LTC Current Tap Position	15L	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Counter Readings	LTC As Left Counter	12589	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Counter Readings	LTC As Found Counter	12589	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	PF000128	PowerFuse	FA-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	PF000128	PowerFuse	FA-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	PF000129	PowerFuse	FA-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	PF000129	PowerFuse	FA-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Counter Readings	LTC Operations Since Last Insp	6	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	YD0000616	Yard	TE-Yard	Yard Patrol Inspection	Vegetation	None	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	General Comments		
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	YD0000616	Yard	TE-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	YD0000616	Yard	TE-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Counter Readings	General Comments		
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0071	LTCMechanism	FA-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	General Comments		
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Counter Readings	LTC Min Tap Position	9L	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	582	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Counter Readings	LTC Min Tap Position	16L	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Counter Readings	LTC Max Tap Position	Neutral	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Counter Readings	LTC Current Tap Position	14L	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Counter Readings	LTC As Left Counter	12640	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Counter Readings	LTC As Found Counter	12640	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Follow-up Action Required?	n	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Fault Operations Ground	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Fault Operations C Ø	1	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Fault Operations B Ø	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Fault Operations A Ø	1	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Fault Adjusted Amps C Phase AM	11.18	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Amps C Ø	45.0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Amps B Ø	48.0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Amps A Ø	45.0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	9 Months Operations	4	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	38	°C
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	49	°C
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	38	°C
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	49	°C
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	38	°C
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	49	°C
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	Winding Temp Present	38	°C
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	Winding Temp Max	49	°C
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Maintenance Operations	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Operations Counter AF	765	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Operations Counter AL	765	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Operations This Read AM	3	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Switching Operations	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Unknown Operations	0	
8/6/2020 5:31	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/6/2020 5:31	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Counter Readings	LTC Operations Since Last Insp	87	
8/6/2020 5:31	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Counter Readings	LTC Min Tap Position	1R	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	Oil Temp Present	37	°C
8/6/2020 5:31	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Counter Readings	LTC Max Tap Position	8L	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Ambient Temp	76	°F
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	YD000616	Yard	TE-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
8/6/2020 5:31	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Counter Readings	LTC Current Tap Position	3L	
8/6/2020 5:31	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Counter Readings	LTC As Left Counter	299300	
8/6/2020 5:31	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Counter Readings	LTC As Found Counter	299300	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	Oil Temp Max	48	°C
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1400	psi
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	20.0	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	20.0	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	20.0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	25.0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	24.0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	26.0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	18	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	All Connections OK?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	General Comments		
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BAT001130	Battery	072-Battery Bank Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Readings	Oil Temp Present	28	°C
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Readings	Oil Temp Max	30	°C
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.8	psi
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Readings	LTC Totalizer Reading	4095.36	kw
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Readings	General Comments		
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	General Comments		
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Readings	Follow-up Action Required?	n	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	9 Month Operations	9	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	314	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	49	°C
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	36	°C
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Counter Readings	LTC Min Tap Position	13L	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Counter Readings	LTC Max Tap Position	2L	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Counter Readings	LTC Current Tap Position	10L	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Counter Readings	LTC As Left Counter	13658	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Counter Readings	LTC As Found Counter	13658	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Counter Readings	General Comments		
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Counter Readings	LTC Max Tap Position	1L	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Counter Readings	LTC Current Tap Position	7L	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Counter Readings	LTC As Left Counter	299306	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Counter Readings	LTC As Found Counter	299306	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Counter Readings	General Comments	Counter was verified and this is the correct reading	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Counter Readings	Follow-up Action Required?	n	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Readings	General Comments		
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Readings	LTC Totalizer Reading	4095.36	kw
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Readings	Oil Temp Max	60	°C
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Readings	Oil Temp Present	40	°C
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Readings	Totalizer Meter Reading	.5688	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	220.00	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	M0071	WithLTC	722-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	General Comments		
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	6	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	General Comments		
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	BAT000092	Battery	FL-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Readings	WLT Bushing Dynamic Health	0.00	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Readings	Totalizer Meter Reading	.5688	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	S0048	WithLTC	722-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	162	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	162	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0361	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	BCH001071	Charger	TE-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	BCH001071	Charger	TE-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	BCH001071	Charger	TE-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	BCH001071	Charger	TE-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.8	amps
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	BCH001071	Charger	TE-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.7	VDC
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	BCH001071	Charger	TE-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.7	VDC
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	BCH001071	Charger	TE-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Counter Readings	LTC Operations Since Last Insp	374	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Counter Readings	LTC Min Tap Position	6L	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Counter Readings	LTC Max Tap Position	1R	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Counter Readings	LTC As Left Counter	282814	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Counter Readings	LTC As Found Counter	282807	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Mechanism Patrol Inspection	General Comments		
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Counter Readings	General Comments		
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Counter Readings	Follow-up Action Required?	n	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	496	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	48	°C
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	37	°C
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Counter Readings	LTC Min Tap Position	13L	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Counter Readings	LTC Max Tap Position	2R	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Counter Readings	LTC Current Tap Position	9L	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Counter Readings	LTC As Left Counter	15087	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Counter Readings	LTC As Found Counter	15087	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	9 Months Operations	5	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Amps A Ø	216.0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Amps B Ø	210.0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Amps C Ø	208.0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Fault Adjusted Amps B Phase AM	33.54	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	9 Month Operations	2	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Amps A Ø	30.0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Amps B Ø	30.0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Amps C Ø	30.0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Bushing Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Fault Operations B Ø	3	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Fault Operations C Ø	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Fault Operations Ground	0	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Counter Readings	General Comments		
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Unknown Operations	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Switching Operations	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Operations This Read AM	2	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Operations Counter AL	1022	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	Follow-up Action Required?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Patrol Inspection	General Comments		
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0998	BreakerAirMagnetic	TE-1247	AMCB Readings	General Comments	A&B Phase IOC	Missing A Phase Fault Operations
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	LTCC000324	LTCControl	067-6	LTC Control Insp	All Connections OK?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	LTCC000324	LTCControl	067-6	LTC Control Insp	Follow-up Action Required?	n	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	LT0079	LTCMechanism	FD-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments	ok	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	LT0079	LTCMechanism	FD-Offline Distribution	LTC Counter Readings	General Comments	ok	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	LT0079	LTCMechanism	FD-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	LT0079	LTCMechanism	FD-Offline Distribution	LTC Counter Readings	Follow-up Action Required?	n	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Follow-up Action Required?	n	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Patrol Inspection	General Comments		
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	General Comments		
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Maintenance Operations	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Operations Counter AF	149	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Operations Counter AL	149	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Operations This Read Vac	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Switching Operations	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Unknown Operations	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Fault Operations Ground	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Fault Operations C Ø	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Fault Operations B Ø	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Fault Operations A Ø	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Amps C Ø	0.0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Amps B Ø	0.0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Amps A Ø	0.0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1004	BreakerVacuum	TE-SPARE-1	VCB Readings	9 Month Operations	0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	O0187	LTCMechanism	882-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	General Comments	need nitrogen	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0254	GroundTransformer	FL-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Counter Readings	General Comments		
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Mechanism Patrol Inspection	General Comments		
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Counter Readings	LTC As Found Counter	249541	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Counter Readings	LTC As Left Counter	249546	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Counter Readings	LTC Current Tap Position	5L	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Counter Readings	LTC Max Tap Position	2R	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Counter Readings	LTC Min Tap Position	15L	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Counter Readings	LTC Operations Since Last Insp	1037	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	LTCC000778	LTCControl	072-6	LTC Control Insp	VRR Time Delay	60	Seconds
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	LTCC000778	LTCControl	072-6	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	LTCC000778	LTCControl	072-6	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	LTCC000778	LTCControl	072-6	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	LTCC000778	LTCControl	072-6	LTC Control Insp	LTC Operation Checked?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	LTCC000778	LTCControl	072-6	LTC Control Insp	General Comments		
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	LTCC000778	LTCControl	072-6	LTC Control Insp	Follow-up Action Required?	n	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	LTCC000778	LTCControl	072-6	LTC Control Insp	All Connections OK?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Adequate	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LTCC000284	LTCControl	FL-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LTCC000284	LTCControl	FL-TRANS 1	LTC Control Insp	General Comments		
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LTCC000284	LTCControl	FL-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	BCH001074	Charger	FL-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	BCH001074	Charger	FL-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	BCH001074	Charger	FL-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	BCH001074	Charger	FL-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	BCH001074	Charger	FL-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.8	amps
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	BCH001074	Charger	FL-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.9	VDC
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	BCH001074	Charger	FL-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.9	VDC
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	BCH001074	Charger	FL-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	BCH001071	Charger	TE-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	LTCC000324	LTCControl	067-6	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	LTCC000324	LTCControl	067-6	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	LTCC000324	LTCControl	067-6	LTC Control Insp	VRR Time Delay	30	Seconds
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Counter Readings	Follow-up Action Required?	n	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Counter Readings	General Comments		
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Mechanism Patrol Inspection	General Comments		
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Counter Readings	LTC As Found Counter	33575	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Counter Readings	LTC As Left Counter	33598	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	SWG000029	Switchgear	FA-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Counter Readings	LTC Current Tap Position	4L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Counter Readings	LTC Min Tap Position	12L	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Counter Readings	LTC Operations Since Last Insp	999	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	S0048	LTCMechanism	722-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Operations Counter AF	1022	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	O0220	LTCMechanism	072-6	LTC Counter Readings	Follow-up Action Required?	n	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Readings	Oil Temp Present	50	°C
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Readings	Oil Temp Max	60	°C
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Readings	General Comments		
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	147	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	147	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C ∅	0	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B ∅	0	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A ∅	0	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0327	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	Maintenance Operations	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Readings	General Comments	A&C Phase IOC	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0993	BreakerAirMagnetic	TE-1242	AMCB Patrol Inspection	General Comments		
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LT0072	LTCMechanism	FA-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	LTCC000324	LTCControl	067-6	LTC Control Insp	General Comments		
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	LTCC000324	LTCControl	067-6	LTC Control Insp	LTC Operation Checked?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	LTCC000324	LTCControl	067-6	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Fault Operations A ∅	0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Fault Operations B ∅	0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Fault Operations C ∅	0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Fault Operations Ground	0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Follow-up Action Required?	n	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Foundation Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	General Comments		
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	9 Month Operations	2	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Amps A ∅	193.0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Amps B ∅	193.0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Amps C ∅	210.0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Fault Operations A ∅	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Fault Operations B ∅	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Fault Operations C ∅	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Fault Operations Ground	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Patrol Inspection	General Comments		
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	General Comments	B phase IOC High Side	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Maintenance Operations	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Operations Counter AF	52	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Operations Counter AL	52	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Operations This Read Vac	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Switching Operations	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1318	BreakerVacuum	FA-12KV TR 2	VCB Readings	Unknown Operations	0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	General Comments		
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Grounds in Place?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Maintenance Operations	0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	SWG000121	Switchgear	TE-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Operations Counter AF	277	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Operations Counter AL	277	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Operations This Read Vac	2	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Switching Operations	2	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000929	BreakerVacuum	072-2	VCB Readings	Unknown Operations	0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Bushing Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Foundation Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	General Comments		
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Grounds in Place?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000930	BreakerVacuum	072-0284	VCB Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Readings	Totalizer Meter Reading	.8100	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Trash Emptied?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Panels Dusted?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	General Comments		
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Filters Condition OK?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Broom on Site?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	CH000171	ControlHouse	FL-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Unknown Operations	0	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Switching Operations	0	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Operations This Read Vac	2	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Operations Counter AL	241	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Operations Counter AF	241	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Maintenance Operations	0	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	General Comments		
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Follow-up Action Required?	n	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Fault Operations Ground	0	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Fault Operations C Ø	0	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Fault Operations B Ø	1	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Fault Operations A Ø	1	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Fault Adjusted Amps B Phase V	3.15	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Fault Adjusted Amps A Phase V	3.15	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Amps C Ø	69.0	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Amps B Ø	57.0	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Amps A Ø	55.0	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Accumulated Fault Duty A Ph V	.94	%
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	9 Month Operations	3	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	9 Month Operations	15	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Amps A Ø	85.0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Readings	LTC Totalizer Reading	5832.00	kw
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Operations This Read Vac	1	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Switching Operations	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Unknown Operations	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Unknown Operations	0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	General Comments	two lightning arresters missing above circuit #302	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	General Comments		
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	2350	psi
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	T0341	NonLTC	072-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Adequate	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	LTC Operations Since Last Insp	32	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	LTC Min Tap Position	2R	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	LTC Max Tap Position	2R	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	LTC Current Tap Position	2R	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	LTC As Left Counter	4108	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	LTC As Found Counter	4108	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Mechanism Patrol Inspection	General Comments		
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BAT000169	Battery	722-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Readings	Oil Temp Max	48	°C
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Readings	Oil Temp Present	46	°C
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	General Comments		
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	B0410	LTCMechanism	818-1	LTC Counter Readings	Follow-up Action Required?	n	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Adequate	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Amps C Ø	334.0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Amps B Ø	338.0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Amps A Ø	348.0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	9 Months Operations	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Trash Emptied?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Fault Operations Ground	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Patrol Inspection	General Comments		
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	General Comments		
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Maintenance Operations	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Operations Counter AF	229	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Operations Counter AL	229	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Operations This Read Vac	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Switching Operations	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Unknown Operations	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Panels Dusted?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	General Comments		
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Broom on Site?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	CH000200	ControlHouse	TE-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	PF000146	PowerFuse	FL-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	PF000146	PowerFuse	FL-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	PF000147	PowerFuse	FL-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	PF000147	PowerFuse	FL-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Trash Emptied?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Panels Dusted?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	General Comments		
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Evidence of Insects	Yes_needs_sprayed	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	CH000429	ControlHouse	818-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Amps B Ø	100.0	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Amps C Ø	85.0	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Bushing Condition	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Fault Operations A Ø	0	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Fault Operations B Ø	0	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Fault Operations C Ø	0	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Fault Operations Ground	0	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Follow-up Action Required?	n	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	General Comments		
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	General Comments		
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Maintenance Operations	0	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Operations Counter AF	305	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Operations Counter AL	305	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Operations This Read Vac	1	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Switching Operations	1	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	K0084	BreakerVacuum	067-0705	VCB Readings	Unknown Operations	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0318	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	9 Month Operations	1	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Amps A Ø	969.0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Amps B Ø	959.0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1003	BreakerVacuum	TE-12KV TR 2	VCB Readings	Amps C Ø	962.0	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Readings	Totalizer Meter Reading	.5436	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Unknown Operations	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Switching Operations	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Operations This Read AM	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Operations Counter AL	99966	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Operations Counter AF	99966	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Maintenance Operations	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	General Comments		
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Patrol Inspection	General Comments		
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Follow-up Action Required?	n	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Fault Operations Ground	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Fault Operations C Ø	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Fault Operations B Ø	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Fault Operations A Ø	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	O0187	WithLTC	882-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	LTCC000732	LTCControl	882-1	LTC Control Insp	VRR Time Delay	60	Seconds
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	LTCC000732	LTCControl	882-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	LTCC000732	LTCControl	882-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	LTCC000732	LTCControl	882-1	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	LTCC000732	LTCControl	882-1	LTC Control Insp	LTC Operation Checked?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	LTCC000732	LTCControl	882-1	LTC Control Insp	General Comments		
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	LTCC000732	LTCControl	882-1	LTC Control Insp	Follow-up Action Required?	n	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	LTCC000732	LTCControl	882-1	LTC Control Insp	All Connections OK?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1002	BreakerAirMagnetic	TE-12KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/9/2020 10:05	Distribution	Foumle Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	51	°C
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	39	°C
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	51	°C
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	Winding Temp Present	36	°C
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	Winding Temp Max	49	°C
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
8/6/2020 5:31	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Unknown Operations	0	
8/6/2020 5:31	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Switching Operations	1	
8/6/2020 5:31	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Operations This Read Vac	1	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	Oil Temp Present	38	°C
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	Oil Temp Max	50	°C
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1200	psi
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	General Comments		
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
8/6/2020 5:31	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Operations Counter AL	240	
8/6/2020 5:31	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Operations Counter AF	239	
8/6/2020 5:31	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Maintenance Operations	0	
8/6/2020 5:31	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	General Comments		
8/6/2020 5:31	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Follow-up Action Required?	n	
8/6/2020 5:31	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Fault Operations Ground	0	
8/6/2020 5:31	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Fault Operations C Ø	0	
8/6/2020 5:31	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Fault Operations B Ø	0	
8/6/2020 5:31	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Fault Operations A Ø	0	
8/6/2020 5:31	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Counter Readings	Follow-up Action Required?	n	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Counter Readings	General Comments		
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Mechanism Patrol Inspection	General Comments		
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Counter Readings	LTC As Found Counter	236421	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Counter Readings	LTC As Left Counter	236435	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Counter Readings	LTC Current Tap Position	3L	
8/6/2020 5:31	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/6/2020 5:31	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/6/2020 5:31	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Amps C Ø	54.0	
8/6/2020 5:31	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Amps B Ø	49.0	
8/6/2020 5:31	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Amps A Ø	44.0	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	CH000007	ControlHouse	Retired Distribution	Control House Patrol Inspection	Acceptable Building Appearance?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	CH000007	ControlHouse	Retired Distribution	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	CH000007	ControlHouse	Retired Distribution	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	CH000007	ControlHouse	Retired Distribution	Control House Patrol Inspection	Evidence of Insects	None	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	CH000007	ControlHouse	Retired Distribution	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	CH000007	ControlHouse	Retired Distribution	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	CH000007	ControlHouse	Retired Distribution	Control House Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	General Comments		
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Foundation Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	9 Month Operations	3	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	Winding Temp Present	22	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	Winding Temp Max	30	°C
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	Totalizer Meter Reading	.1170	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	10500	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Amps A Ø	132.0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Amps B Ø	117.0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Amps C Ø	122.0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Amps A Ø	58.0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Amps B Ø	61.0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Amps C Ø	68.0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Fault Operations A Ø	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Fault Operations B Ø	1	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Fault Operations C Ø	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Fault Operations Ground	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Follow-up Action Required?	n	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Patrol Inspection	General Comments		
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	General Comments		
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Fault Operations A Ø	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Fault Operations B Ø	1	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Fault Operations C Ø	1	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Fault Operations Ground	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Follow-up Action Required?	n	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Patrol Inspection	General Comments		
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	General Comments	B and C phase IOC	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Maintenance Operations	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Operations Counter AF	165	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BK000482	BreakerVacuum	072-0283	VCB Patrol Inspection	Bushing Condition	Good	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	39	°C
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	51	°C
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	39	°C
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Operations Counter AL	165	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Operations This Read Vac	3	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1321	BreakerVacuum	FA-1216	VCB Readings	Switching Operations	1	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Maintenance Operations	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Operations Counter AF	404	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0996	BreakerVacuum	TE-1245	VCB Readings	Operations Counter AL	404	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	Oil Temp Present	25	°C
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	Oil Temp Max	35	°C
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1228.50	kw
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	General Comments		
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	General Comments		
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LTCC000576	LTCControl	TE-TRANS 1	LTC Control Insp	General Comments		
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LTCC000576	LTCControl	TE-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	General Comments		
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	60	°C
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	40	°C
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.1	volts
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Regulator As Left Counter	7924	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	SWG000101	Switchgear	TE-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Arching Horns Good Condition?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Positive DC Ground	13.5	VDC
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Negative DC Ground	13.7	VDC
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	General Comments		
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	ST000046	Structure	722-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	54	°F
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Readings	Follow-up Action Required?	n	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	General Comments		
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Readings	General Comments		
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	O0220	WithLTC	072-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	CH000007	ControlHouse	Retired Distribution	Control House Patrol Inspection	General Comments		
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	CH000007	ControlHouse	Retired Distribution	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	CH000007	ControlHouse	Retired Distribution	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	CH000007	ControlHouse	Retired Distribution	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	General Comments		
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	FE000043	Fence	722-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	Ambient Temp	75	*F
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	General Comments	cusdu has died off left corner	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	Vegetation	None	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	YD000041	Yard	722-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
8/6/2020 5:31	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/6/2020 5:31	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/6/2020 5:31	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	Accumulated Fault Duty A Ph V	.94	%
8/6/2020 5:31	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Readings	9 Month Operations	5	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Counter Readings	LTC Min Tap Position	11L	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Counter Readings	LTC Operations Since Last Insp	1085	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	M0071	LTCMechanism	722-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KT0009	NonLTC	072-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/10/2020 7:26	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Readings	General Comments		
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LT0078	WithLTC	FL-TRANS 1	LTC Transformer Patrol Inspection	General Comments	needs nitrogen and no oil flow alarm on bank 2, oil is flowing	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LTCC000576	LTCControl	TE-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Amps C Ø	314.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Amps B Ø	319.0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Amps A Ø	301.0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	9 Month Operations	0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Counter Readings	General Comments		
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Counter Readings	LTC As Found Counter	89145	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Counter Readings	LTC As Left Counter	89145	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Counter Readings	LTC Current Tap Position	5R	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	1008	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0042	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	General Comments		
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Readings	Follow-up Action Required?	n	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Counter Readings	LTC Current Tap Position	5L	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Counter Readings	LTC As Left Counter	189797	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Counter Readings	LTC As Found Counter	189797	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Counter Readings	General Comments		
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Amps C Ø	68.0	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Amps B Ø	48.0	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	3	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	General Comments		
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Amps A Ø	67.0	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	9 Month Operations	4	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Ambient Temp	72	°F
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	FE000375	Fence	818-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Switching Operations	1	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Unknown Operations	0	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Regulator As Left Counter	64	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Tank Leaks	None	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Operations Counter AF	118	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Operations Counter AL	118	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Operations This Read Vac	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Switching Operations	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Unknown Operations	0	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Amps B Ø	37.0	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Amps A Ø	43.0	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	9 Month Operations	6	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Readings	Oil Temp Present	40	°C
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	3	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	96.0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	90.0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	93.0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Fault Operations A Ø	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Fault Operations B Ø	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Fault Operations C Ø	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Fault Operations Ground	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Follow-up Action Required?	n	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Patrol Inspection	General Comments		
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	General Comments		
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Maintenance Operations	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Operations Counter AF	301	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Operations Counter AL	301	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Operations This Read Vac	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Switching Operations	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0999	BreakerVacuum	TE-1248	VCB Readings	Unknown Operations	0	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Readings	General Comments		
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Readings	LTC Totalizer Reading	7096.32	kw
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Readings	Oil Temp Max	50	°C
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	99978	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	99978	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0358	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	10.0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	10.0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	10.0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	4	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Counter Readings	LTC As Found Counter	206286	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Counter Readings	LTC As Left Counter	206286	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Counter Readings	LTC Max Tap Position	6R	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Counter Readings	LTC Min Tap Position	12L	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	2753	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Patrol Inspection	Bushing Condition	Good	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	9 Month Operations	1	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Amps A Ø	369.0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Amps B Ø	367.0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Amps C Ø	337.0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Fault Operations A Ø	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Fault Operations B Ø	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Fault Operations C Ø	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Fault Operations Ground	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Operations This Read Vac	1	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Switching Operations	1	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Unknown Operations	0	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Unknown Operations	0	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	9 Month Operations	10	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Unknown Operations	0	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Unknown Operations	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Switching Operations	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Operations This Read Vac	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Operations Counter AL	238	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Operations Counter AF	238	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Switching Operations	3	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Operations This Read Vac	3	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Operations Counter AL	0	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Operations Counter AF	193	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Maintenance Operations	0	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	General Comments		
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Patrol Inspection	General Comments		
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Follow-up Action Required?	n	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Fault Operations Ground	0	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Fault Operations C Ø	0	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Fault Operations B Ø	0	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Fault Operations A Ø	0	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Maintenance Operations	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	General Comments		
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Patrol Inspection	General Comments		
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0997	BreakerVacuum	TE-1246	VCB Readings	Follow-up Action Required?	n	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BCH001405	Charger	818-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BCH001405	Charger	818-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BCH001405	Charger	818-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BCH001405	Charger	818-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BCH001405	Charger	818-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BCH001405	Charger	818-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BCH001405	Charger	818-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BCH001405	Charger	818-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BAT001470	Battery	818-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BAT001470	Battery	818-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BAT001470	Battery	818-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BAT001470	Battery	818-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BAT001470	Battery	818-Battery Bank	Battery Patrol Inspection	General Comments		
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BAT001470	Battery	818-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BAT001470	Battery	818-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BAT001470	Battery	818-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BAT001470	Battery	818-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BAT001470	Battery	818-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BAT001470	Battery	818-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BAT001470	Battery	818-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BAT001470	Battery	818-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	78	*F
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BAT001470	Battery	818-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	C phase IOC	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	86	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	86	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Counter Readings	General Comments		
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0193	LTCMechanism	TE-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1359	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Counter Readings	LTC Min Tap Position	11L	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LT0192	LTCMechanism	TE-TRANS 2	LTC Counter Readings	LTC Max Tap Position	11R	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	7	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	177	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	177	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	BB0330	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	3	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB0317	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	15	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	15	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Amps C Ø	227.0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Amps B Ø	192.0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Amps A Ø	220.0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	9 Month Operations	17	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Amps C Ø	83.0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Amps B Ø	3.0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Amps A Ø	52.0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	9 Month Operations	3	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Tank Leaks	None	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Operations Counter	43	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	General Comments	tower leg foundation crumbling	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Foundation Condition	Crumbling	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	Vegetation	None	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	General Comments		
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	YD000052	Yard	882-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	General Comments	1BG	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	3	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	318.0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	223.0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	278.0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0360	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Readings	Totalizer Meter Reading	.7392	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Surge Arrester Counter C Ø	0	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Surge Arrester Counter B Ø	0	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Surge Arrester Counter A Ø	0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	9	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	63.0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	65.0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	59.0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	C0443	WithLTC	067-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Maintenance Operations	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	General Comments	B and C phase IOC. B phase amperage reading not reading correctly	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Patrol Inspection	General Comments		
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Follow-up Action Required?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Max Tap Position	2L	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Min Tap Position	3L	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	General Comments		
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Fault Adjusted Amps B Phase V	22.36	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Fault Adjusted Amps C Phase V	22.36	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Fault Operations A Ø	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Fault Operations B Ø	2	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Fault Operations C Ø	2	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Fault Operations Ground	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Follow-up Action Required?	n	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Patrol Inspection	General Comments		
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	General Comments	B&C Phase IOC	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Maintenance Operations	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Operations Counter AF	587	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Operations Counter AL	587	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Operations This Read Vac	4	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Switching Operations	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB0995	BreakerVacuum	TE-1244	VCB Readings	Unknown Operations	0	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Amps C Ø	69.0	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Amps B Ø	73.0	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Amps A Ø	26.8	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Regulator As Left Counter	87	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Fault Operations A Ø	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Fault Operations B Ø	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Fault Operations C Ø	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1319	BreakerVacuum	FA-1214	VCB Readings	Fault Operations Ground	0	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Current Tap Position	3L	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Fault Operations A Ø	1	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Fault Operations B Ø	1	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Fault Operations C Ø	0	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Fault Operations Ground	0	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Follow-up Action Required?	n	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Fault Adjusted Amps B Phase V	4.56	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Fault Adjusted Amps A Phase V	4.56	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	Bushing Condition	Good	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Amps C Ø	55.0	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	8	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	8	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Operations This Read Vac	3	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Operations Counter AL	187	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Operations Counter AF	186	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Maintenance Operations	0	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	General Comments	ABG	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	General Comments		
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Min Tap Position	3L	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Max Tap Position	3L	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	General Comments		
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	General Comments		
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Vegetation	None	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	YD000381	Yard	818-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Current Tap Position	3L	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	General Comments		
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	FE000056	Fence	882-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
11/9/2020 10:05	Distribution	Foumle Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/9/2020 10:05	Distribution	Foumle Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/9/2020 10:05	Distribution	Foumle Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/9/2020 10:05	Distribution	Foumle Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 10:05	Distribution	Foumle Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/9/2020 10:05	Distribution	Foumle Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4902	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001146	BreakerVacuum	722-0302	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	ST000057	Structure	882-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Tank Leaks	None	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000214	Regulator	067-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	General Comments		
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	General Comments		
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	588.24	kw
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	General Comments		
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	ST000385	Structure	818-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	25	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	25	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	LB0359	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	LTC000817	LTCControl	818-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	9 Month Operations	9	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Amps A Ø	70.0	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Amps B Ø	85.0	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Amps C Ø	55.0	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Bushing Condition	Good	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Current Tap Position	Neutral	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	General Comments		
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Regulator As Left Counter	7677	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	Operations Counter	0	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	General Comments		
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0041	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Tank Leaks	None	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Regulator As Left Counter	89841	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	General Comments		
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	General Comments		
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	General Comments		
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	LTCC000817	LTCControl	818-1	LTC Control Insp	All Connections OK?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	LTCC000817	LTCControl	818-1	LTC Control Insp	Follow-up Action Required?	n	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	LTCC000817	LTCControl	818-1	LTC Control Insp	General Comments		
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	LTCC000817	LTCControl	818-1	LTC Control Insp	LTC Operation Checked?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	LTCC000817	LTCControl	818-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	LTCC000817	LTCControl	818-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	LTCC000817	LTCControl	818-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Tank Leaks	None	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Fault Operations Ground	0	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Follow-up Action Required?	n	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Follow-up Action Required?	n	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	General Comments		
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	General Comments	BCG	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Maintenance Operations	0	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Operations Counter AF	203	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Operations Counter AL	204	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Operations This Read Vac	3	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Switching Operations	1	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Unknown Operations	0	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	9 Month Operations	6	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Amps A Ø	40.0	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Amps B Ø	30.0	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Amps C Ø	40.0	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Bushing Condition	Good	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BCH001346	Charger	882-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.800	millivolts
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BCH001346	Charger	882-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BCH001346	Charger	882-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BCH001346	Charger	882-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BCH001346	Charger	882-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BCH001346	Charger	882-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BCH001346	Charger	882-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BCH001346	Charger	882-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	439	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Fault Adjusted Amps B Phase V	8.63	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Fault Operations A Ø	0	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Fault Operations B Ø	2	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Fault Operations C Ø	0	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Readings	Fault Operations Ground	0	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001091	BreakerVacuum	722-0301	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	12	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	Amps C Ø	5.8	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	Amps B Ø	7.5	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	Amps A Ø	9.3	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	398	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/9/2020 10:05	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	LTC Totalizer Reading	2413.44	kw
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	Oil Temp Max	55	°C
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	Oil Temp Present	55	°C
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	Totalizer Meter Reading	.2514	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Regulator As Left Counter	69	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BCH001450	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	BCH001450	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	General Comments		
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	FE000613	Fence	TE-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	9 Month Operations	1	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Patrol Inspection	Bushing Condition	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Fault Operations A Ø	0	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Fault Operations B Ø	0	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Fault Operations C Ø	0	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	9 Months Operations	2	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Amps A Ø	0.0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Amps B Ø	0.0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Amps C Ø	0.0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	SWG000089	Switchgear	FA-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	General Comments		
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	ST000603	Structure	TE-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2020 17:21	Distribution	Dayton-Walther Quarterly Inspection	B0410	WithLTC	818-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Tank Leaks	None	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Regulator As Left Counter	52830	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Min Tap Position	1L	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Max Tap Position	4R	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	General Comments		
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Current Tap Position	4R	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Fault Operations A Ø	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Fault Operations B Ø	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Fault Operations C Ø	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Fault Operations Ground	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Follow-up Action Required?	n	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Patrol Inspection	General Comments		
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	General Comments		
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Maintenance Operations	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Operations Counter AF	102	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Operations Counter AL	102	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Operations This Read Vac	0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Unknown Operations	0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KR0022	Regulator	072-3 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Amps A Ø	74.0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Amps B Ø	66.0	
11/9/2020 12:15	Distribution	Farnsley Quarterly Inspection	LB1320	BreakerVacuum	FA-1215	VCB Readings	Amps C Ø	60.0	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Current Tap Position	2L	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	General Comments		
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Max Tap Position	2L	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000216	Regulator	067-5 A	Regulator Patrol Inspection	Min Tap Position	3L	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	General Comments		
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	ST000601	Structure	FL-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Vegetation	None	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	General Comments		
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	YD000614	Yard	FL-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	FE000610	Fence	FL-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Fault Operations A Ø	1	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Fault Adjusted Amps B Phase V	4.56	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Fault Adjusted Amps A Phase V	4.56	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	General Comments		
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	General Comments		
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	2138.88	kw
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Patrol Inspection	General Comments		
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	Oil Temp Max	50	°C
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	Oil Temp Present	40	°C
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	Totalizer Meter Reading	.6684	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Fault Adjusted Amps B Phase V	9.13	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Fault Operations A Ø	0	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Fault Operations B Ø	3	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Fault Operations C Ø	0	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Fault Operations Ground	0	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Follow-up Action Required?	n	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Patrol Inspection	General Comments		
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Operations Counter AL	161	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Operations Counter AF	160	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Maintenance Operations	0	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	General Comments		
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Patrol Inspection	General Comments		
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Follow-up Action Required?	n	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Fault Operations Ground	0	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Fault Operations C Ø	0	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Fault Operations B Ø	0	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Fault Operations A Ø	0	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Switching Operations	1	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Operations This Read Vac	3	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Operations Counter AL	205	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Patrol Inspection	Bushing Condition	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Amps C Ø	20.0	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Amps B Ø	20.0	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Amps A Ø	35.0	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001409	BreakerVacuum	067-0709	VCB Readings	9 Month Operations	1	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Unknown Operations	0	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Switching Operations	7	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Operations This Read Vac	7	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Operations Counter AL	177	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Operations Counter AF	177	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Maintenance Operations	0	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	General Comments		
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Amps A Ø	22.0	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Amps B Ø	20.0	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Amps C Ø	9.0	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Patrol Inspection	Bushing Condition	Good	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Operations Counter AF	204	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	RG000215	Regulator	067-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Maintenance Operations	0	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	General Comments	ABG	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	General Comments		
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Follow-up Action Required?	n	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Fault Operations Ground	0	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Fault Operations C Ø	0	
11/9/2020 13:55	Distribution	Pineville Quarterly Inspection	BK001092	BreakerVacuum	722-0303	VCB Readings	Fault Operations B Ø	1	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	0987	NonLTC	067-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Patrol Inspection	General Comments		
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	General Comments		
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Maintenance Operations	0	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Operations Counter AF	184	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Operations Counter AL	184	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Operations This Read Vac	1	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Switching Operations	1	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Unknown Operations	0	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	9 Month Operations	9	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	General Comments		
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Patrol Inspection	General Comments		
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Follow-up Action Required?	n	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Fault Operations Ground	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Fault Operations C Ø	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Fault Operations B Ø	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Fault Operations A Ø	0	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Amps A Ø	90.0	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Min Tap Position	2L	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Max Tap Position	2R	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Grounds in Place?	n	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	General Comments		
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Current Tap Position	2R	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	KR0021	Regulator	072-3 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 15:28	Distribution	Floyd Quarterly Inspection	SWG000013	Switchgear	FL-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Amps C Ø	95.0	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001408	BreakerVacuum	067-0708	VCB Readings	Amps B Ø	100.0	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	General Comments	3BG	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Maintenance Operations	0	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Operations Counter AF	195	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Unknown Operations	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Switching Operations	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Operations This Read AM	0	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Operations Counter AL	646	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Operations Counter AF	646	
11/9/2020 14:22	Distribution	Terry Quarterly Inspection	LB1000	BreakerAirMagnetic	TE-12KV BUS TIE SEC 1	AMCB Readings	Maintenance Operations	0	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Operations Counter AL	195	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Operations This Read Vac	3	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Switching Operations	0	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 11:09	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Unknown Operations	0	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	9 Month Operations	5	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Amps A Ø	115.0	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Amps B Ø	120.0	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Amps C Ø	110.0	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Patrol Inspection	Bushing Condition	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Follow-up Action Required?	n	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
11/11/2020 8:47	Distribution	Dorchester Quarterly Inspection	DB0044	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Fault Operations Ground	0	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Fault Operations C Ø	0	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Fault Operations B Ø	0	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Fault Operations A Ø	0	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2020 17:07	Distribution	Carrollton Quarterly Inspection	BK001407	BreakerVacuum	067-0707	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Readings	Follow-up Action Required?	n	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Readings	General Comments		
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Readings	Maintenance Operations	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Readings	Operations Counter AF	331	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Readings	9 Month Operations	3	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Readings	Amps A Ø	0.0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Readings	Amps B Ø	0.0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Readings	Amps C Ø	0.0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Readings	Fault Adjusted Amps A Phase V	22.36	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Readings	Fault Adjusted Amps B Phase V	22.36	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Readings	Fault Adjusted Amps C Phase V	22.36	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Readings	Fault Operations A Ø	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Readings	Unknown Operations	2	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Readings	Switching Operations	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Readings	Operations This Read Vac	2	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Readings	Operations Counter AL	331	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Readings	Fault Operations Ground	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Readings	Fault Operations B Ø	0	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Unknown Operations	0	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Switching Operations	2	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	9 Month Operations	7	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Accumulated Fault Duty A Ph V	10.05	%
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	General Comments		
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Fault Operations A Ø	0	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Maintenance Operations	0	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Operations Counter AF	397	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Operations Counter AL	399	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Operations This Read Vac	2	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Fault Operations B Ø	0	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Fault Operations C Ø	0	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Fault Operations Ground	0	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Follow-up Action Required?	n	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Amps C Ø	145	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Amps B Ø	155	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Amps A Ø	130	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Accumulated Fault Duty C Ph V	8.68	%
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Accumulated Fault Duty B Ph V	10.97	%
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Grounds in Place?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	General Comments		
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Foundation Condition	Good	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Bushing Condition	Good	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Readings	General Comments		
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	7	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	150	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	150	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	150	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	302	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	303	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	1	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	1	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Switching Operations	0	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Operations This Read Vac	0	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Operations Counter AL	278	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Operations Counter AF	278	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Maintenance Operations	0	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Follow-up Action Required?	n	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	General Comments		
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	General Comments		
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Readings	Oil Temp Present	20	°C
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Readings	Oil Temp Max	25	°C
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	General Comments		
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Readings	General Comments		
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Readings	LTC Totalizer Reading	3771.36	kw
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Bushing Condition	Good	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Amps C Ø	80.0	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Amps B Ø	65.0	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Amps A Ø	90.0	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	9 Month Operations	2	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LTCC000442	LTCControl	FH-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LTCC000442	LTCControl	FH-TRANS 2	LTC Control Insp	General Comments		
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LTCC000442	LTCControl	FH-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Bushing Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	General Comments		
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Grounds in Place?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Fault Operations A Ø	0	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	General Comments		
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	FE000846	Fence	461-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Fault Operations Ground	0	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Fault Operations C Ø	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Fault Operations B Ø	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001248	BreakerVacuum	C-1344	VCB Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Readings	Winding Temp Present	0	°C
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Readings	Winding Temp Max	0	°C
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Readings	Totalizer Meter Reading	.5238	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	C0448	WithLTC	432-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	General Comments		
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Bushing Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	General Comments		
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001183	BreakerVacuum	C-1340	VCB Patrol Inspection	Bushing Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	General Comments		
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	387	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	387	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	0	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BCH001186	Charger	666-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BCH001186	Charger	666-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BCH001186	Charger	666-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BCH001186	Charger	666-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BCH001186	Charger	666-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BCH001186	Charger	666-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BCH001186	Charger	666-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BCH001186	Charger	666-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	General Comments		
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001182	BreakerVacuum	C-1306	VCB Patrol Inspection	Bushing Condition	Good	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	9 Month Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Amps A Ø	41.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Amps B Ø	42.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Amps C Ø	45.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Fault Operations A Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Fault Operations B Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Fault Operations C Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Fault Operations Ground	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Patrol Inspection	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Maintenance Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Operations Counter AF	218	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Operations Counter AL	218	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Operations This Read Vac	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Mechanism Patrol Inspection	General Comments		
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	C0448	LTCMechanism	432-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	General Comments		
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	FE000448	Fence	545-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	YD000452	Yard	545-Yard	Yard Patrol Inspection	Ambient Temp	70	*F
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	YD000452	Yard	545-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	YD000452	Yard	545-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	YD000452	Yard	545-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	YD000452	Yard	545-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	YD000452	Yard	545-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	YD000452	Yard	545-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	YD000452	Yard	545-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	YD000452	Yard	545-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	YD000452	Yard	545-Yard	Yard Patrol Inspection	General Comments		
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	YD000452	Yard	545-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	YD000452	Yard	545-Yard	Yard Patrol Inspection	Vegetation	None	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	YD000452	Yard	545-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	General Comments		
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BAT001229	Battery	666-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Bushing Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Amps C Ø	40.0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Amps B Ø	40.0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Amps A Ø	40.0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	9 Month Operations	1	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001184	BreakerVacuum	C-1345	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	Winding Temp Max	40	°C
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Reading	.6498	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Present	30	°C
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Max	35	°C
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1125	psi
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2	psi
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	LTC Totalizer Reading	11696.4	kw
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	General Comments		
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	Bushing Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	General Comments		
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001480	BreakerVacuum	C-14KV TR 3	VCB Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	33	°C
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	52	°C
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	33	°C
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	52	°C
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0247	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushing Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0247	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0247	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0247	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0247	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	General Comments		
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0247	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0247	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0247	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0247	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0247	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0247	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0247	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	33	°C
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	52	°C
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Readings	Oil Temp Present	32	°C
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Readings	Oil Temp Max	51	°C
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	700	psi
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Switching Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Unknown Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Switching Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Operations This Read AM	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Operations Counter AL	368	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Operations Counter AF	368	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Maintenance Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Fault Operations Ground	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Fault Operations C ∅	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Fault Operations B ∅	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Fault Operations A ∅	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Amps C ∅	0.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Amps B ∅	0.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Amps A ∅	0.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0597	BreakerAirMagnetic	MD-GND TR 2	AMCB Readings	9 Months Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Unknown Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	9 Months Operations	1	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Amps A ∅	0.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Amps B ∅	0.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Amps C ∅	0.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Fault Operations A Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Fault Operations B Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Fault Operations C Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Fault Operations Ground	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Patrol Inspection	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Maintenance Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Operations Counter AF	570	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Operations Counter AL	570	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Operations This Read AM	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Switching Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0591	BreakerAirMagnetic	MD-14KV BUS TIE	AMCB Readings	Unknown Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1305	BreakerVacuum	MD-1457	VCB Readings	Unknown Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Switching Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Operations This Read AM	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Operations Counter AL	549	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Operations Counter AF	549	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Maintenance Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Patrol Inspection	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Fault Operations Ground	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Fault Operations C Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Fault Operations B Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Fault Operations A Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Amps C Ø	10.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Amps B Ø	10.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Amps A Ø	10.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0586	BreakerAirMagnetic	MD-1449-A	AMCB Readings	9 Months Operations	3	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	Winding Temp Present	40	°C
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Bushings Oil Level	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	71	°F
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BCH001261	Charger	461-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BCH001261	Charger	461-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BCH001261	Charger	461-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BCH001261	Charger	461-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	General Comments		
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	General Comments		
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	4884.48	kw
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	Oil Temp Max	30	°C
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	Oil Temp Present	30	°C
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	Totalizer Meter Reading	.5088	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	Winding Temp Max	30	°C
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	Winding Temp Present	30	°C
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LB0137	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Unknown Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Switching Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Operations This Read Vac	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Operations Counter AL	163	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Operations Counter AF	163	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Maintenance Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Patrol Inspection	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Fault Operations Ground	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Fault Operations A Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Fault Operations B Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Fault Operations A Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Amps C Ø	0.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Amps B Ø	0.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Amps A Ø	0.0	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	General Comments		
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	ST000848	Structure	461-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Positive DC Ground	65.3	VDC
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Negative DC Ground	68.4	VDC
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	General Comments		
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	475	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	51	°C
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	31	°C
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	2.0	psi
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Counter Readings	LTC Min Tap Position	2R	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Counter Readings	LTC Max Tap Position	12R	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Counter Readings	LTC Current Tap Position	5R	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Counter Readings	LTC As Left Counter	170073	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Counter Readings	LTC As Found Counter	170073	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Counter Readings	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0108	LTCMechanism	MD-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	356	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Counter Readings	LTC Min Tap Position	6R	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Counter Readings	LTC Max Tap Position	11R	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Counter Readings	LTC Current Tap Position	3R	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Counter Readings	LTC As Left Counter	8483	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Counter Readings	LTC As Found Counter	8483	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Counter Readings	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0107	LTCMechanism	MD-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Counter Readings	LTC Operations Since Last Insp	658	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	°C
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	32	°C
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Counter Readings	LTC Min Tap Position	10L	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Counter Readings	LTC Max Tap Position	4L	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Counter Readings	LTC Current Tap Position	7L	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Counter Readings	LTC As Left Counter	67445	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Counter Readings	LTC As Found Counter	67438	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Mechanism Patrol Inspection	General Comments		
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Counter Readings	General Comments		
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	S0054	LTCMechanism	687-1	LTC Counter Readings	Follow-up Action Required?	n	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BAT001321	Battery	461-Battery Bank	Battery Patrol Inspection	Battery Bank Volts	133.7	VDC
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KT0039	NonLTC	666-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	General Comments		
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	General Comments		
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001189	BreakerVacuum	C-1341	VCB Patrol Inspection	Bushing Condition	Good	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Panels Dusted?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Trash Emptied?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	LTCC000546	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	LTCC000546	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Unknown Operations	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Switching Operations	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Operations This Read Vac	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Operations Counter AL	328	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Operations Counter AF	328	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Maintenance Operations	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Grounds in Place?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	LTCC000546	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	LTCC000546	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	LTCC000546	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	General Comments		
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	General Comments		
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Follow-up Action Required?	n	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Fault Operations Ground	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Fault Operations C Ø	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Fault Operations B Ø	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Fault Operations A Ø	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001185	BreakerVacuum	C-1304	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	LTCC000546	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	LTCC000546	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	LTCC000546	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	SWG000083	Switchgear	FH-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	2	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0380	BreakerVacuum	FH-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1306	BreakerVacuum	MD-1458	VCB Readings	9 Month Operations	0	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BCH001261	Charger	461-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.7	amps
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BCH001261	Charger	461-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.7	VDC
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BCH001261	Charger	461-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.7	VDC
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BCH001261	Charger	461-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.023	millivolts
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Unknown Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Switching Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Operations This Read AM	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Operations Counter AL	610	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Operations Counter AF	610	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Maintenance Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Patrol Inspection	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Fault Operations Ground	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Fault Operations C Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Fault Operations B Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Fault Operations A Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Amps C Ø	0.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Amps B Ø	0.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Amps A Ø	0.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0587	BreakerAirMagnetic	MD-1451	AMCB Readings	9 Months Operations	4	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Unknown Operations	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	General Comments		
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001190	BreakerVacuum	C-14KV BUS TIE	VCB Patrol Inspection	Bushing Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Switching Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Operations This Read AM	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Operations Counter AL	436	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Operations Counter AF	436	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Maintenance Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Patrol Inspection	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Fault Operations Ground	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Fault Operations C Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Fault Operations B Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Fault Operations A Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Amps C Ø	0.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Amps B Ø	0.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Amps A Ø	0.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0584	BreakerAirMagnetic	MD-1450	AMCB Readings	9 Months Operations	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Broom on Site?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	CH000187	ControlHouse	FH-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0273	GroundTransformer	MD-GND TR 2	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0273	GroundTransformer	MD-GND TR 2	Ground Transformer Patrol Inspection	Tank Leaks	None	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0273	GroundTransformer	MD-GND TR 2	Ground Transformer Patrol Inspection	Radiator Leaks	None	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0273	GroundTransformer	MD-GND TR 2	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0273	GroundTransformer	MD-GND TR 2	Ground Transformer Patrol Inspection	Grounds in Place?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	PF000058	PowerFuse	C-GND TR 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	PF000058	PowerFuse	C-GND TR 3	Disconnect Powerfuse Inspection	General Comments	OK	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	PF000059	PowerFuse	C-GND TR 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	PF000059	PowerFuse	C-GND TR 4	Disconnect Powerfuse Inspection	General Comments	OK	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	PF000060	PowerFuse	C-14KV BUS SEC 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	PF000060	PowerFuse	C-14KV BUS SEC 3 POT	Disconnect Powerfuse Inspection	General Comments	OK	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	PF000061	PowerFuse	C-14KV BUS SEC 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	PF000061	PowerFuse	C-14KV BUS SEC 4 POT	Disconnect Powerfuse Inspection	General Comments	OK	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0273	GroundTransformer	MD-GND TR 2	Ground Transformer Patrol Inspection	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0273	GroundTransformer	MD-GND TR 2	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0273	GroundTransformer	MD-GND TR 2	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	General Comments		
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0	VDC
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0	VDC
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Readings	Follow-up Action Required?	n	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Readings	Fault Operations Ground	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Readings	Fault Operations C ∅	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Readings	Fault Operations B ∅	0	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	PF000203	PowerFuse	MD-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	PF000203	PowerFuse	MD-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	OK	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	PF000206	PowerFuse	MD-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	PF000206	PowerFuse	MD-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	OK	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	PF000207	PowerFuse	MD-14KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	PF000207	PowerFuse	MD-14KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	OK	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	General Comments		
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	ST000341	Structure	666-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	BCH001075	Charger	FH-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LTCC000285	LTCControl	FH-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallellIND	Position
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Readings	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	General Comments	pump gauge showed off when turned on	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Readings	H2 Winding Temp Max	70	°C
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Readings	H2 Winding Temp Present	46	°C
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Readings	Oil Temp Max	62	°C
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Readings	Oil Temp Present	43	°C
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LTCC000285	LTCControl	FH-TRANS 1	LTC Control Insp	General Comments		
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LTCC000285	LTCControl	FH-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Readings	Fault Operations A Ø	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	50	°C
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	32	°C
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	Oil Temp Max	48	°C
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	50	°C
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	23	°C
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	51	°C
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	23	°C
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	50	°C
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0107	WithLTC	MD-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	23	°C
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0108	WithLTC	MD-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	BCH001075	Charger	FH-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	BCH001075	Charger	FH-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.9	VDC
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	BCH001075	Charger	FH-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.9	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	BCH001075	Charger	FH-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.8	amps
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	BCH001075	Charger	FH-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	BCH001075	Charger	FH-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	BCH001075	Charger	FH-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Fault Operations A Ø	0	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Fault Operations B Ø	0	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Fault Operations C Ø	0	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Fault Operations Ground	0	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	General Comments		
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	General Comments		
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Grounds in Place?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Maintenance Operations	0	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Operations Counter AF	237	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Operations Counter AL	237	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Operations This Read Vac	0	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Switching Operations	0	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Unknown Operations	0	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	BCH001307	Charger	777-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	BCH001307	Charger	777-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	BCH001307	Charger	777-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	BCH001307	Charger	777-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	BCH001307	Charger	777-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	BCH001307	Charger	777-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	BCH001307	Charger	777-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	BCH001307	Charger	777-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Unknown Operations	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Counter Readings	LTC As Left Counter	109296	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Counter Readings	LTC Current Tap Position	6L	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Counter Readings	LTC Max Tap Position	2L	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Counter Readings	LTC Min Tap Position	9L	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	763	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0028	WithLTC	C-TRANS 3	LTC Transformer Patrol Inspection	General Comments	NEED NITROGEN	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	9 Month Operations	6	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Accumulated Fault Duty A Ph V	6.26	%
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Accumulated Fault Duty B Ph V	1.84	%
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Accumulated Fault Duty C Ph V	1.47	%
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Amps A Ø	195	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Amps B Ø	205	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Amps C Ø	185	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Bushing Condition	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KB0087	BreakerVacuum	666-0472	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0299	GroundTransformer	MD-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0299	GroundTransformer	MD-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0299	GroundTransformer	MD-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0299	GroundTransformer	MD-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0299	GroundTransformer	MD-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0299	GroundTransformer	MD-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0299	GroundTransformer	MD-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LTCC000023	LTCControl	MD-TRANS 1	LTC Control Insp	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LTCC000023	LTCControl	MD-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0299	GroundTransformer	MD-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0299	GroundTransformer	MD-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	General Comments		
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Counter Readings	LTC Operations Since Last Insp	862	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Counter Readings	LTC Min Tap Position	8L	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Counter Readings	LTC Max Tap Position	4L	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Counter Readings	LTC Current Tap Position	12L	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Counter Readings	LTC As Left Counter	50784	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Counter Readings	LTC As Found Counter	50780	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Mechanism Patrol Inspection	General Comments		
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Counter Readings	General Comments		
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	S0002	LTCMechanism	666-1	LTC Counter Readings	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Switching Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Operations This Read AM	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Operations Counter AL	645	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Operations Counter AF	645	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Maintenance Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Patrol Inspection	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Fault Operations Ground	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Fault Operations C Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Fault Operations B Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Fault Operations A Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Amps C Ø	30.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Amps B Ø	30.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Amps A Ø	30.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0577	BreakerAirMagnetic	MD-1445-B	AMCB Readings	9 Months Operations	1	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	356	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	46	°C
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	28	°C
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Counter Readings	LTC Min Tap Position	11L	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Counter Readings	LTC Max Tap Position	3L	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Counter Readings	LTC Current Tap Position	8L	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Counter Readings	LTC As Left Counter	19612	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Counter Readings	LTC As Found Counter	19612	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Counter Readings	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0304	LTCMechanism	MD-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LTCC000023	LTCControl	MD-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	LTC Totalizer Reading	11772.00	kw
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	Oil Temp Max	50	°C
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	PF000153	PowerFuse	FH-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	PF000153	PowerFuse	FH-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	PF000202	PowerFuse	MD-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	PF000202	PowerFuse	MD-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	PF000062	PowerFuse	C-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	PF000062	PowerFuse	C-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	OK	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	General Comments		
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Ambient Temp	70	°F
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Clear of Obstacles?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Clear of Trash?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	General Comments		
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	Oil Temp Present	44	°C
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	PF000204	PowerFuse	MD-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	PF000204	PowerFuse	MD-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Amps C Ø	20.0	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	General Comments		
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	FE000389	Fence	666-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Amps B Ø	20.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Amps A Ø	20.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	9 Months Operations	1	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	General Comments		
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	General Comments		
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Counter Readings	LTC Operations Since Last Insp	934	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	3.0	psi
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Counter Readings	LTC Min Tap Position	12L	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Counter Readings	LTC Max Tap Position	6L	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Counter Readings	LTC Current Tap Position	8L	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Counter Readings	LTC As Left Counter	13800	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Counter Readings	LTC As Found Counter	13794	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Mechanism Patrol Inspection	General Comments		
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Counter Readings	General Comments		
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Counter Readings	Follow-up Action Required?	n	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	BCH000567	Charger	432-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	BCH000567	Charger	432-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	BCH000567	Charger	432-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	BCH000567	Charger	432-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	BCH000567	Charger	432-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	BCH000567	Charger	432-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.020	millivolts
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	43	*F
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	General Comments		
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.2	VDC
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.4	VDC
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	BAT000632	Battery	432-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	Totalizer Meter Reading	.6540	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	Winding Temp Max	50	*C
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	Winding Temp Present	44	*C
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	PF000150	PowerFuse	FH-STA SER NO 1	Disconnect PowerFuse Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	PF000150	PowerFuse	FH-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	PF000205	PowerFuse	MD-14KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	PF000205	PowerFuse	MD-14KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	TX000129	WithLTC	545-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	LTCC000722	LTCCControl	545-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	LTCC000722	LTCCControl	545-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	LTCC000722	LTCCControl	545-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	LTCC000722	LTCCControl	545-1	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	LTCC000722	LTCCControl	545-1	LTC Control Insp	LTC Operation Checked?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	LTCC000722	LTCCControl	545-1	LTC Control Insp	General Comments		
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	LTCC000722	LTCCControl	545-1	LTC Control Insp	Follow-up Action Required?	n	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	LTCC000722	LTCCControl	545-1	LTC Control Insp	All Connections OK?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Vegetation	None	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Yard Lights Working?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	LTCM000061	LTCMechanism	545-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	General Comments		
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	LTCC000574	LTCCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	LTCC000574	LTCCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	LTCC000574	LTCCControl	Retired Distribution	LTC Control Insp	General Comments		
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	LTCC000574	LTCCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	LTCC000574	LTCCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	125	VAC
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	LTCC000574	LTCCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124	VAC
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	LTCC000574	LTCCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124	VAC
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	LTCC000574	LTCCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Readings	9 Month Operations	1	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	PF000152	PowerFuse	FH-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	PF000152	PowerFuse	FH-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BCH001330	Charger	545-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BCH001330	Charger	545-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BCH001330	Charger	545-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BCH001330	Charger	545-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	All Connections OK?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Bushing Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Capacitor Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BCH001330	Charger	545-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.1	amps
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BCH001330	Charger	545-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BCH001330	Charger	545-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BCH001330	Charger	545-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.024	millivolts
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BAT001411	Battery	545-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BAT001411	Battery	545-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BAT001411	Battery	545-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.3	VDC
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BAT001411	Battery	545-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.8	VDC
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BAT001411	Battery	545-Battery Bank	Battery Patrol Inspection	General Comments		
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BAT001411	Battery	545-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BAT001411	Battery	545-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BAT001411	Battery	545-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BAT001411	Battery	545-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BAT001411	Battery	545-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Foundation Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	General Comments		
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	General Comments		
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	LTC Totalizer Reading	4556.16	kw
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	Oil Temp Max	40	°C
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	Oil Temp Present	36	°C
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	Totalizer Meter Reading	.4746	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	Winding Temp Max	38	°C
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	Winding Temp Present	24	°C
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	S0054	WithLTC	687-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Patrol Inspection	Bushing Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Readings	Amps C Ø	40.0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Readings	Amps B Ø	40.0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Readings	Amps A Ø	40.0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Foundation Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	General Comments		
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Patrol Inspection	General Comments		
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	General Comments		
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Patrol Inspection	Grounds in Place?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Maintenance Operations	0	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Operations Counter AF	209	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Operations Counter AL	209	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Operations This Read Vac	0	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Switching Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Grounds in Place?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Tank Leaks	None	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Warning Signs OK?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Unknown Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Unknown Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Switching Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Operations This Read AM	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Operations Counter AL	493	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Operations Counter AF	493	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Maintenance Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	General Comments		
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	PF000151	PowerFuse	FH-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	PF000151	PowerFuse	FH-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Patrol Inspection	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Fault Operations Ground	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Fault Operations C Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Fault Operations B Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Fault Operations A Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0580	BreakerAirMagnetic	MD-1447-A	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Grounds in Place?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Tank Leaks	None	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	CAP000054	CapacitorBank	MD-Cap Bank 2	Capacitor Patrol Inspection	Warning Signs OK?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	All Connections OK?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Bushing Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	9 Month Operations	2	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Amps A Ø	48.0	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Amps B Ø	37.0	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Amps C Ø	47.0	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Patrol Inspection	Bushing Condition	Good	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BAT001411	Battery	545-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BAT001411	Battery	545-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BAT001411	Battery	545-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BAT001411	Battery	545-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Fault Operations A Ø	0	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Fault Operations B Ø	0	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Fault Operations C Ø	0	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Fault Operations Ground	0	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Readings	Follow-up Action Required?	n	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000650	BreakerVacuum	545-2323	VCB Patrol Inspection	Foundation Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Capacitor Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	CAP000055	CapacitorBank	MD-Cap Bank 1	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Vegetation	None	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	9 Months Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Amps A Ø	750.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Amps B Ø	750.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Amps C Ø	750.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Fault Operations A Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Fault Operations B Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Fault Operations C Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Fault Operations Ground	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Patrol Inspection	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Maintenance Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	9 Month Operations	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Amps A Ø	65.0	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	BCH000535	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53	VDC
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Amps A Ø	0.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Amps B Ø	0.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Amps C Ø	0.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Fault Adjusted Amps A Phase AM	33.54	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Fault Adjusted Amps B Phase AM	33.54	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Fault Adjusted Amps C Phase AM	33.54	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Fault Operations A Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Fault Operations B Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Fault Operations C Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Fault Operations Ground	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Patrol Inspection	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Maintenance Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Operations Counter AF	579	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Operations Counter AL	579	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Operations This Read AM	3	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Switching Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Unknown Operations	3	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	BCH000535	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0028	LTCMechanism	C-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	General Comments		
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	YD000621	Yard	FH-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	Bushing Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Patrol Inspection	General Comments		
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BCH000056	Charger	C-Battery Charger-Distribution	Battery Charger Patrol Insp	Ground Lights	None	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BCH000056	Charger	C-Battery Charger-Distribution	Battery Charger Patrol Insp	General Comments		
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BCH000056	Charger	C-Battery Charger-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BCH000056	Charger	C-Battery Charger-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BCH000056	Charger	C-Battery Charger-Distribution	Battery Charger Patrol Insp	Battery Charger Current	2.7	amps
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BCH000056	Charger	C-Battery Charger-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	134.0	VDC
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BCH000056	Charger	C-Battery Charger-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	134.0	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BCH000056	Charger	C-Battery Charger-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	75.0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	50.0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	50.0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Amps B Ø	58.0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Amps C Ø	59.0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Fault Operations A Ø	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Fault Operations B Ø	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Fault Operations C Ø	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Fault Operations Ground	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Follow-up Action Required?	n	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Patrol Inspection	General Comments		
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	General Comments		
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Maintenance Operations	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Operations Counter AF	285	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Operations Counter AL	285	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Operations This Read Vac	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Switching Operations	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0376	BreakerVacuum	FH-1215	VCB Readings	Unknown Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	SWG000130	Switchgear	MD-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Operations Counter AF	532	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Operations Counter AL	532	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Operations This Read AM	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Switching Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0593	BreakerAirMagnetic	MD-14KV TR 2	AMCB Readings	Unknown Operations	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	General Comments		
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001395	BreakerVacuum	C-14KV TR 4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Amps A Ø	60.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Amps B Ø	40.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Amps C Ø	40.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Fault Operations B Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Fault Operations C Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Fault Operations Ground	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Patrol Inspection	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Maintenance Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Operations Counter AF	933	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Operations Counter AL	933	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Operations This Read AM	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Switching Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	Unknown Operations	0	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Current Tap Position	5L	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	General Comments		
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Max Tap Position	1L	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Min Tap Position	9L	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	9 Month Operations	8	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Amps A Ø	143.0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Amps B Ø	187.0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Amps C Ø	188.0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Fault Operations A Ø	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Fault Operations B Ø	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Fault Operations C Ø	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Fault Operations Ground	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Follow-up Action Required?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Patrol Inspection	General Comments		
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	General Comments	needs counter changed, numbers worn off	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Maintenance Operations	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Operations Counter AF	478	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Operations Counter AL	478	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Operations This Read Vac	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Switching Operations	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0374	BreakerVacuum	FH-1213	VCB Readings	Unknown Operations	0	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	General Comments		
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	FE000326	Fence	687-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0588	BreakerAirMagnetic	MD-1452	AMCB Readings	9 Months Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Fault Operations C Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Fault Operations B Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Fault Operations A Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Amps C Ø	30.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Amps B Ø	30.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Amps A Ø	30.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	9 Months Operations	1	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	125	volts
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Regulator As Left Counter	33513	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Tank Leaks	None	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	General Comments		
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Ambient Temp	58	°F
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	9 Months Operations	15	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0581	BreakerAirMagnetic	MD-1447-B	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	BCH000535	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	BCH000535	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	BCH000535	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	BCH000535	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	BCH000535	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53	VDC
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	124	volts
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Regulator As Left Counter	33005	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Tank Leaks	None	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0088	Regulator	666-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Current Tap Position	5L	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	General Comments		
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Max Tap Position	1L	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Min Tap Position	9L	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0089	Regulator	666-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Unknown Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Switching Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Operations This Read AM	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Operations Counter AL	362	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Operations Counter AF	362	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Vegetation	None	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	YD000884	Yard	461-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Maintenance Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Patrol Inspection	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0576	BreakerAirMagnetic	MD-1445-A	AMCB Readings	Fault Operations Ground	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LTCC000588	LTCControl	MD-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Bushing Condition	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Amps C Ø	70	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Amps B Ø	75	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Amps A Ø	70	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Accumulated Fault Duty C Ph V	3.27	%
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Accumulated Fault Duty B Ph V	3.27	%
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Accumulated Fault Duty A Ph V	2.61	%
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	9 Month Operations	5	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	General Comments		
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	9 Month Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Amps A Ø	0.0	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Unknown Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Switching Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Operations This Read Vac	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Operations Counter AL	120	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Operations Counter AF	120	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Maintenance Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Patrol Inspection	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Fault Operations Ground	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Fault Operations C Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Fault Operations B Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Fault Operations A Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Amps C Ø	20.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Amps B Ø	20.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Amps A Ø	20.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	9 Months Operations	1	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Unknown Operations	0	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Switching Operations	0	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Operations This Read Vac	0	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Operations Counter AL	36	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Operations Counter AF	36	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Maintenance Operations	0	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Grounds in Place?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	General Comments	Line arrester on C phase over circuit 471 blown.	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	General Comments		
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Foundation Condition	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Follow-up Action Required?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Fault Operations Ground	0	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Fault Operations C Ø	0	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Fault Operations B Ø	0	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Fault Operations A Ø	0	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	YD000338	Yard	666-Yard	Yard Patrol Inspection	Vegetation	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0383	BreakerVacuum	666-0471	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LTCC000588	LTCCControl	MD-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LTCC000588	LTCCControl	MD-TRANS 3	LTC Control Insp	General Comments		
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Amps B Ø	0.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Amps C Ø	0.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Fault Operations A Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Fault Operations B Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Fault Operations C Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Fault Operations Ground	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Patrol Inspection	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Maintenance Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Operations Counter AF	180	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	LTCC000029	LTCCControl	932-Offline Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	LTCC000029	LTCCControl	932-Offline Distribution	LTC Control Insp	VRR Base Voltage AL	125	VAC
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	LTCC000029	LTCCControl	932-Offline Distribution	LTC Control Insp	VRR Base Voltage AF	125	VAC
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	LTCC000029	LTCCControl	932-Offline Distribution	LTC Control Insp	LTC Output Voltage Level	124	VAC
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	LTCC000029	LTCCControl	932-Offline Distribution	LTC Control Insp	LTC Operation Checked?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	LTCC000029	LTCCControl	932-Offline Distribution	LTC Control Insp	General Comments		
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	LTCC000029	LTCCControl	932-Offline Distribution	LTC Control Insp	Follow-up Action Required?	n	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	LTCC000029	LTCCControl	932-Offline Distribution	LTC Control Insp	All Connections OK?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Operations Counter AL	180	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Operations This Read Vac	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Switching Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1304	BreakerVacuum	MD-1459	VCB Readings	Unknown Operations	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LTCC000532	LTCCControl	C-TRANS 4	LTC Control Insp	Follow-up Action Required?	n	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LTCC000532	LTCCControl	C-TRANS 4	LTC Control Insp	General Comments		
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LTCC000532	LTCCControl	C-TRANS 4	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Counter Readings	General Comments		
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0082	LTCMechanism	FH-TRANS 2	LTC Counter Readings	LTC As Found Counter	109296	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Amps C Ø	0.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Amps B Ø	0.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Amps A Ø	0.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1307	BreakerVacuum	MD-GND TR 3	VCB Readings	9 Month Operations	0	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	General Comments		
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Vegetation	None	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Yard Lights Working?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	General Comments		
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Unknown Operations	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	710	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	710	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C \emptyset	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B \emptyset	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A \emptyset	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C \emptyset	354.0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B \emptyset	318.0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A \emptyset	328.0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	4	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LTCC000410	LTCControl	C-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LTCC000410	LTCControl	C-TRANS 3	LTC Control Insp	General Comments		
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LTCC000410	LTCControl	C-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	9 Month Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Amps A \emptyset	0.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Amps B \emptyset	0.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Amps C \emptyset	0.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Bushing Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Readings	Switching Operations	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Readings	Operations This Read Vac	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Readings	Operations Counter AL	321	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1321	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1321	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0373	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0381	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001394	BreakerVacuum	C-14KV REACTOR TIE	VCB Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Readings	Unknown Operations	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	9 Months Operations	1	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Amps A Ø	80.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Amps B Ø	80.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Amps C Ø	80.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Fault Operations A Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Fault Operations B Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Fault Operations C Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Fault Operations Ground	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Patrol Inspection	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Maintenance Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Operations Counter AF	491	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Operations Counter AL	491	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Operations This Read AM	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0578	BreakerAirMagnetic	MD-1446-A	AMCB Readings	Switching Operations	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	n	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Readings	General Comments		
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	General Comments	NEED NITROGEN	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Readings	Oil Temp Max	68	°C
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	110.00	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Patrol Inspection	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Fault Operations Ground	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Fault Operations C Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Fault Operations B Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Fault Operations A Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Readings	Operations Counter AF	321	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Readings	Maintenance Operations	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Readings	General Comments		
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Patrol Inspection	General Comments		
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001393	BreakerVacuum	C-1343	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Fault Operations A Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Fault Operations B Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Fault Operations C Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Fault Operations Ground	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Foundation Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Grounds in Place?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Maintenance Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Operations Counter AF	170	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Operations Counter AL	170	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Operations This Read Vac	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Switching Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0595	BreakerVacuum	MD-CAP BK 2	VCB Readings	Unknown Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Unknown Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Switching Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Operations This Read AM	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Operations Counter AL	499	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Operations Counter AF	499	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	Maintenance Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0583	BreakerAirMagnetic	MD-1448-B	AMCB Readings	General Comments		
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Ambient Temperature	58	*F
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Readings	Fault Operations	0	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Readings	Follow-up Action Required?	n	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Fault Operations Ground	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Fault Operations C Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Fault Operations B Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Fault Operations A Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Amps C Ø	0.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Amps B Ø	0.0	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Amps A Ø	0.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	9 Months Operations	0	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	450.0	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	450.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	460.0	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Unknown Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Switching Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Operations This Read AM	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Operations Counter AL	7	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Operations Counter AF	7	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Maintenance Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Patrol Inspection	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Fault Operations Ground	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Fault Operations C Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Fault Operations B Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Fault Operations A Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Amps C Ø	0.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Amps B Ø	0.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Amps A Ø	0.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Amps C Ø	80.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Amps B Ø	80.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Amps A Ø	80.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	9 Months Operations	1	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Operations This Read Vac	0	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Switching Operations	0	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Unknown Operations	0	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Amps A Ø	10.0	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Amps B Ø	10.0	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Amps C Ø	10.0	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	General Comments		
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Operations Counter	1786	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Tank Leaks	None	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	CX0109	RecloserElectronic	687-2311	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Unknown Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Switching Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Operations This Read AM	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Operations Counter AL	316	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Operations Counter AF	316	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	Maintenance Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0596	BreakerAirMagnetic	MD-GND TR 1	AMCB Patrol Inspection	General Comments		
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	General Comments		
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	BAT001031	Battery	FH-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	47	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	47	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	CB0167	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Amps B Ø	79.0	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Amps C Ø	60.0	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Bushing Condition	Good	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	General Comments		
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Amps C Ø	62.0	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Amps B Ø	60.0	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Amps A Ø	86.0	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	General Comments		
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Readings	General Comments		
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Readings	LTC Totalizer Reading	7037.28	kw
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Readings	Oil Temp Max	35	°C
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Readings	Oil Temp Present	35	°C
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Readings	Totalizer Meter Reading	.9774	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Fault Operations A Ø	0	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Fault Operations B Ø	0	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Fault Operations C Ø	0	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Fault Operations Ground	0	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Operations Since Last Insp	768	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	22	°C
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	50	°C
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Foundation Condition	Good	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Gauge(s) Condition	Good	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Readings	General Comments		
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	General Comments	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Unknown Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Switching Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Operations This Read Vac	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Operations Counter AL	224	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Operations Counter AF	224	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Maintenance Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Patrol Inspection	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Fault Operations Ground	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Fault Operations C Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Fault Operations B Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Fault Operations A Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Amps C Ø	0.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Amps B Ø	0.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Amps A Ø	0.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1308	BreakerVacuum	MD-14KV BUS TIE SEC 3	VCB Readings	9 Month Operations	4	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Grounds in Place?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Readings	Maintenance Operations	0	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Moisture and Leak Free?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Readings	Num Operations Last 9 Months	0	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Readings	Operations Counter AF	17	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Readings	Operations Counter AL	17	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Readings	Operations This Read SF6	0	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	SF6 Bushing Condition	Good	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	SF6 Pressure Pole 1	85	psi
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	SF6 Pressure Pole 2	85	psi
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	SF6 Pressure Pole 3	85	psi
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Readings	Switching Operations	0	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000983	BreakerSF6	461-708	GCB Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	9 Month Operations	10	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000986	BreakerVacuum	461-2170	VCB Readings	Amps A Ø	84.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0594	BreakerAirMagnetic	MD-14KV TEMP BUS TIE	AMCB Readings	9 Months Operations	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	All Connections OK?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	General Comments		
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BAT001035	Battery	C-Battery Bank-Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Tank Leaks	None	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	X0125	RecloserElectronic	687-2224	Recloser Electronic Patrol Inspection	Operations Counter	97	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Counter Readings	General Comments		
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Counter Readings	LTC As Found Counter	56024	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Counter Readings	LTC As Left Counter	56024	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6L	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	310	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	330	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	300	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0	%
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0	%
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0	%
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Unknown Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Switching Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Operations This Read AM	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Operations Counter AL	557	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Operations Counter AF	557	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Counter Readings	LTC Max Tap Position	8R	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Maintenance Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	General Comments	vc is correct	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Patrol Inspection	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Fault Operations Ground	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Fault Operations C Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Fault Operations B Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Fault Operations A Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Amps C Ø	0.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Amps B Ø	0.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Amps A Ø	0.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0589	BreakerAirMagnetic	MD-14KV BUS TIE SEC A	AMCB Readings	9 Months Operations	14	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Counter Readings	LTC Min Tap Position	10L	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	948	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	Bushing Condition	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	9 Month Operations	8	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Accumulated Fault Duty A Ph V	7.18	%
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	General Comments		
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Unknown Operations	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Switching Operations	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Operations This Read Vac	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Operations Counter AL	228	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Operations Counter AF	228	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Maintenance Operations	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	General Comments		
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Follow-up Action Required?	n	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Bushing Condition	Good	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0068	BreakerVacuum	432-0643	VCB Patrol Inspection	Bushing Condition	Good	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	0	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	161	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	161	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Fault Operations Ground	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Fault Operations C Ø	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Fault Operations B Ø	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Fault Operations A Ø	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LTCM000013	LTCMechanism	FH-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	General Comments		
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	KB0069	BreakerVacuum	432-0624	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	General Comments		
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	General Comments		
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	Oil Temp Max	55	°C
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	Oil Temp Present	35	°C
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	60	°C
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	35	°C
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	70	°C
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	40	°C
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	65	°C
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	25	°C
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Fault Operations A Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Fault Operations B Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Fault Operations C Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Fault Operations Ground	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Patrol Inspection	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Maintenance Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Operations Counter AF	600	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Operations Counter AL	600	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Operations This Read AM	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Switching Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Unknown Operations	0	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Foundation Condition	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	General Comments		
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	General Comments		
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Grounds in Place?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Unknown Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Switching Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Operations This Read AM	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Operations Counter AL	505	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Operations Counter AF	505	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Maintenance Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Patrol Inspection	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Maintenance Operations	0	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Operations Counter AF	295	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Operations Counter AL	295	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Fault Operations Ground	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Fault Operations C Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Fault Operations A Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0579	BreakerAirMagnetic	MD-1446-B	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Accumulated Fault Duty B Ph V	5.88	%
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Accumulated Fault Duty C Ph V	5.22	%
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Amps A Ø	100	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Amps B Ø	100	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Amps C Ø	110	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Bushing Condition	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Amps C Ø	69.0	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	General Comments		
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Amps B Ø	76.0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Amps A Ø	77.0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0377	BreakerVacuum	FH-1216	VCB Readings	9 Month Operations	4	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001044	BreakerVacuum	C-1342	VCB Patrol Inspection	Bushing Condition	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Fault Operations A Ø	0	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Fault Operations B Ø	0	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Fault Operations C Ø	0	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Fault Operations Ground	0	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	BB0382	BreakerVacuum	666-0470	VCB Readings	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	9 Months Operations	1	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Amps A Ø	100.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Amps B Ø	110.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Readings	Amps C Ø	110.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0585	BreakerAirMagnetic	MD-1449-B	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Amps C Ø	213.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Amps B Ø	216.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Amps A Ø	217.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	9 Month Operations	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0081	WithLTC	FH-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	General Comments		chg 1st quarter

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Foundation Condition	Good	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	40	°C
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Counter Readings	LTC Min Tap Position	11L	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Counter Readings	LTC Max Tap Position	6L	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Counter Readings	LTC Current Tap Position	8L	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Counter Readings	LTC As Left Counter	5613	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Counter Readings	LTC As Found Counter	5605	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	General Comments		
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Counter Readings	General Comments		
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Counter Readings	Follow-up Action Required?	n	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	LTCC000797	LTCControl	461-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Follow-up Action Required?	n	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Fault Operations Ground	0	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Fault Operations C ∅	0	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Fault Operations B ∅	0	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Fault Operations A ∅	0	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	LTCC000797	LTCControl	461-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	LTCC000797	LTCControl	461-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	LTCC000797	LTCControl	461-1	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	LTCC000797	LTCControl	461-1	LTC Control Insp	LTC Operation Checked?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	LTCC000797	LTCControl	461-1	LTC Control Insp	General Comments		
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	LTCC000797	LTCControl	461-1	LTC Control Insp	Follow-up Action Required?	n	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	LTCC000797	LTCControl	461-1	LTC Control Insp	All Connections OK?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	Winding Temp Present	30	°C
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Bushing Condition	Good	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Amps C ∅	201.0	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Amps B ∅	208.0	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Amps A ∅	181.0	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	9 Month Operations	1	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Unknown Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Switching Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Operations This Read Vac	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Operations Counter AL	165	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Operations Counter AF	165	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Maintenance Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	General Comments		
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	Winding Temp Max	41	°C
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	Totalizer Meter Reading	.2900	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Patrol Inspection	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Fault Operations Ground	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Fault Operations C ∅	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Fault Operations B ∅	0	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Fault Operations B ∅	0	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Fault Operations C ∅	0	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Fault Operations Ground	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Fault Operations A ∅	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Fault Operations Ground	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Patrol Inspection	General Comments		
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	General Comments		
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Maintenance Operations	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Operations Counter AF	187	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Operations Counter AL	187	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Operations This Read Vac	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Switching Operations	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Unknown Operations	0	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Counter Readings	LTC Operations Since Last Insp	386	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	LTCM000090	LTCMechanism	461-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	21	°C
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Follow-up Action Required?	n	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Foundation Condition	Good	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	General Comments		
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	General Comments		
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Grounds in Place?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Maintenance Operations	0	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Operations Counter AF	330	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Operations Counter AL	330	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Operations This Read Vac	0	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Switching Operations	0	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Unknown Operations	0	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	LTCC000130	LTCControl	432-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	LTCC000130	LTCControl	432-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	LTCC000130	LTCControl	432-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	LTCC000130	LTCControl	432-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	LTCC000130	LTCControl	432-1	LTC Control Insp	LTC Operation Checked?	y	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	LTCC000130	LTCControl	432-1	LTC Control Insp	General Comments		
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	LTCC000130	LTCControl	432-1	LTC Control Insp	Follow-up Action Required?	n	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	LTCC000130	LTCControl	432-1	LTC Control Insp	All Connections OK?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Trip-energy Supply Verified	y	LED lights?
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Indicator Zone	OK	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Bushing Condition	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Moisture and Leak Free?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Grounds in Place?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	General Comments		
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Foundation Condition	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KB0131	CircuitSwitcher	666-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Ambient Temperature	70	°F
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Unknown Operations	0	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Switching Operations	0	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Operations This Read Vac	0	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Operations Counter AL	197	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Operations Counter AF	197	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	Maintenance Operations	0	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Patrol Inspection	Grounds in Place?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	BK000424	BreakerVacuum	545-2321	VCB Readings	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Operations Counter AL	357	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Operations This Read AM	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Switching Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0582	BreakerAirMagnetic	MD-1448-A	AMCB Readings	Unknown Operations	0	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	Oil Temp Present	30	°C
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	Oil Temp Max	40	°C
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1300	psi
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	LTC Totalizer Reading	6960.00	kw
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Readings	General Comments		
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Readings	LTC Totalizer Reading	7866.72	kw
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Readings	Oil Temp Max	45	°C
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Readings	Oil Temp Present	35	°C
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Readings	Totalizer Meter Reading	1.0926	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	LTCC000355	LTCControl	687-1	LTC Control Insp	All Connections OK?	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	LTCC000355	LTCControl	687-1	LTC Control Insp	Follow-up Action Required?	n	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	LTCC000355	LTCControl	687-1	LTC Control Insp	General Comments		
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LB0138	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LB0138	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LB0138	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LB0138	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LB0138	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LB0138	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LB0138	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LB0138	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LB0138	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LB0138	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LB0138	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LB0138	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	General Comments		
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	General Comments		
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	LTCC000355	LTCControl	687-1	LTC Control Insp	LTC Operation Checked?	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	LTCC000355	LTCControl	687-1	LTC Control Insp	LTC Output Voltage Level	123.3	VAC
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	LTCC000355	LTCControl	687-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	LTCC000355	LTCControl	687-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	LTCC000355	LTCControl	687-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Fault Operations A Ø	0	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	S0002	WithLTC	666-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	TX000220	WithLTC	461-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Amps C Ø	407.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Amps B Ø	406.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Amps A Ø	412.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1301	BreakerVacuum	MD-14KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Operations Counter AF	182	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Operations Counter AL	182	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Operations This Read Vac	0	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Switching Operations	0	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000987	BreakerVacuum	461-2171	VCB Readings	Unknown Operations	0	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	9 Month Operations	0	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Amps A Ø	235.0	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Amps B Ø	211.0	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Amps C Ø	193.0	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Bushing Condition	Good	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Fault Operations A Ø	0	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Fault Operations B Ø	0	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Fault Operations C Ø	0	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Fault Operations Ground	0	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Follow-up Action Required?	n	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Foundation Condition	Good	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	General Comments		
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	General Comments		
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Grounds in Place?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Maintenance Operations	0	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Operations Counter AF	179	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Operations Counter AL	179	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Operations This Read Vac	0	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Switching Operations	0	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 10:19	Distribution	Richmond North Quarterly Inspection	BK000988	BreakerVacuum	461-1	VCB Readings	Unknown Operations	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Trash Emptied?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Switch Diagram Present/Current	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Station Ground Set On Site?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Panels Dusted?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Panel Lights OK?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	General Comments		
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Floor Swept?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Evidence of Insects	None	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Door Alarms OK?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Control House Lighting OK?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Broom on Site?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Basement Condition Acceptable	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	Acceptable Building Appearance?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	CH000161	ControlHouse	C-Control House-Distribution	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Min Tap Position	9L	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Max Tap Position	2L	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Current Tap Position	5L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	30	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	15	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	30	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	16	%
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	17.82	%
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	16	%
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	6	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	8	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	9 Month Operations	4	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Amps A Ø	414.0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Amps B Ø	456.0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Amps C Ø	464.0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0382	BreakerVacuum	FH-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Amps A Ø	140.0	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Amps B Ø	135.0	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Amps C Ø	120.0	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Bushing Condition	Good	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	K0091	BreakerVacuum	545-2322	VCB Readings	Fault Operations A Ø	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	General Comments		
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	FE000617	Fence	FH-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Unknown Operations	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Switching Operations	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Operations This Read Vac	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Operations Counter AL	651	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Operations Counter AF	651	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Maintenance Operations	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	General Comments		
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Patrol Inspection	General Comments		
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Follow-up Action Required?	n	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Fault Operations Ground	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Fault Operations C Ø	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Fault Operations B Ø	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Fault Operations A Ø	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Amps C Ø	68.0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Amps B Ø	67.0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Amps A Ø	57.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0375	BreakerVacuum	FH-1214	VCB Readings	9 Month Operations	6	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	General Comments		
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	ST000605	Structure	FH-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	1	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations This Read Vac	1	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	271	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	270	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
11/6/2020 15:48	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	CB0171	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Ambient Temp	39	°F
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0029	LTCMechanism	C-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0029	LTCMechanism	C-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0029	LTCMechanism	C-TRANS 4	LTC Counter Readings	LTC Operations Since Last Insp	806	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0029	LTCMechanism	C-TRANS 4	LTC Counter Readings	LTC Current Tap Position	5R	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0029	LTCMechanism	C-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0029	LTCMechanism	C-TRANS 4	LTC Counter Readings	LTC As Left Counter	78243	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0029	LTCMechanism	C-TRANS 4	LTC Counter Readings	LTC As Found Counter	78243	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0029	LTCMechanism	C-TRANS 4	LTC Mechanism Patrol Inspection	General Comments		
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0029	LTCMechanism	C-TRANS 4	LTC Counter Readings	General Comments		
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0029	LTCMechanism	C-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0029	LTCMechanism	C-TRANS 4	LTC Counter Readings	Follow-up Action Required?	n	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	57	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	57	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	9 Month Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Amps A Ø	158.0	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Patrol Inspection	Bushing Condition	Good	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	40	°C
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	25	°C
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	45	°C
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Amps C Ø	58.0	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Amps B Ø	31.0	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Amps A Ø	32.0	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	9 Month Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Tank Leaks	None	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	25	°C
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	40	°C
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	25	°C
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Counter Readings	Follow-up Action Required?	n	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Counter Readings	General Comments		
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Mechanism Patrol Inspection	General Comments		
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Counter Readings	LTC As Found Counter	104349	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Counter Readings	LTC As Left Counter	104358	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0246	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0246	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0246	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0246	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0246	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0246	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0246	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0246	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	General Comments	OIL LEVEL IS AT MIN.	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0246	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0246	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0246	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0246	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Counter Readings	LTC Current Tap Position	4L	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Counter Readings	LTC Max Tap Position	3R	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Counter Readings	LTC Min Tap Position	6L	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Counter Readings	LTC Operations Since Last Insp	585	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	450.0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	360.0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	430.0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0371	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Current Tap Position	6L	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Min Tap Position	13L	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Max Tap Position	6L	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	General Comments	Unable to reset drag hands	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Amps B Ø	158.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Amps C Ø	158.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Fault Operations A Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Fault Operations B Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Fault Operations C Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Fault Operations Ground	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Patrol Inspection	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Maintenance Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Operations Counter AF	141	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Operations Counter AL	141	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Operations This Read Vac	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Switching Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1303	BreakerVacuum	MD-1456	VCB Readings	Unknown Operations	0	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	General Comments		
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Vegetation	None	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	YD000331	Yard	687-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	General Comments		
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/6/2020 9:02	Distribution	Red House Quarterly Inspection	ST000335	Structure	687-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Evidence of Insects	None	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	SWG000091	Switchgear	FH-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Unknown Operations	0	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Switching Operations	0	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Operations This Read Vac	0	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Operations Counter AL	179	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Operations Counter AF	179	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Maintenance Operations	0	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Patrol Inspection	Grounds in Place?	y	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	General Comments		
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Patrol Inspection	General Comments		
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Patrol Inspection	Foundation Condition	Good	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Follow-up Action Required?	n	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Fault Operations Ground	0	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Fault Operations C ∅	0	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Vegetation	None	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	General Comments		
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	124	volts
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Regulator As Left Counter	30309	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Unknown Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Switching Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Operations This Read Vac	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Operations Counter AL	114	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Operations Counter AF	114	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Tank Leaks	None	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C ∅	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B ∅	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A ∅	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C ∅	0.0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B ∅	0.0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A ∅	0.0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Bushing Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Foundation Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Grounds in Place?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0303	GroundTransformer	MD-GND TR 3	Ground Transformer Patrol Inspection	Radiator Leaks	None	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Fault Operations B Ø	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Fault Operations A Ø	0	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	Grounds in Place?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	H2 Winding Temp Max	45	°C
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	H2 Winding Temp Present	25	°C
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Panels Dusted?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	SWG000038	Switchgear	MD-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	113	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	113	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	YD000507	Yard	432-Yard	Yard Patrol Inspection	Ambient Temp	43	°F
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	Oil Temp Max	50	°C
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Readings	Oil Temp Present	30	°C
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LT0082	WithLTC	FH-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0372	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Operations Counter AF	664	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Amps A Ø	86.0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Amps B Ø	89.0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Amps C Ø	91.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Amps C Ø	180.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Amps B Ø	80.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Amps A Ø	70.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Amps B Ø	180.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Amps A Ø	190.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Fault Operations A Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	9 Month Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Maintenance Operations	0	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	General Comments		
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	General Comments		
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Patrol Inspection	General Comments		
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Follow-up Action Required?	n	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Fault Operations Ground	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Fault Operations C Ø	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Fault Operations B Ø	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Maintenance Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Operations Counter AF	167	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Operations Counter AL	167	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Operations This Read Vac	0	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Switching Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Unknown Operations	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	9 Month Operations	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/6/2020 14:01	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Grounds in Place?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Patrol Inspection	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Fault Operations Ground	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Fault Operations C Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Fault Operations B Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Fault Operations A Ø	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0590	BreakerVacuum	MD-1454	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	All Identified and Legible?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	LT0246	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushing Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	General Comments		
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Foundation Condition	Good	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	54	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	54	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/9/2020 14:53	Distribution	Canal Quarterly Inspection	BK001045	BreakerVacuum	C-1346	VCB Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Unknown Operations	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Switching Operations	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Operations This Read Vac	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0378	BreakerVacuum	FH-1217	VCB Readings	Operations Counter AL	664	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C ∅	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B ∅	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Fault Operations C ∅	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Fault Operations Ground	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Follow-up Action Required?	n	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A ∅	0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Patrol Inspection	General Comments		
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Maintenance Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Amps C ∅	80.0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Fault Operations A ∅	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Fault Operations B ∅	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Fault Operations C ∅	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Fault Operations Ground	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Follow-up Action Required?	n	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Patrol Inspection	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Maintenance Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Operations Counter AF	628	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Operations Counter AL	628	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Operations This Read AM	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Switching Operations	0	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Unknown Operations	0	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	14	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A ∅	240.0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B ∅	100.0	
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C ∅	300.0	
11/6/2020 16:01	Distribution	Oxford Quarterly Inspection	KR0087	Regulator	666-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB0592	BreakerAirMagnetic	MD-14KV TR 1	AMCB Readings	9 Months Operations	2	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Readings	General Comments		
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LT0304	WithLTC	MD-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
11/6/2020 15:19	Distribution	Freys Hill Quarterly Inspection	LB0370	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	General Comments		
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	General Comments		
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	FE000500	Fence	432-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Fault Operations A Ø	0	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/6/2020 13:24	Distribution	Madison Quarterly Inspection	LB1302	BreakerVacuum	MD-1455	VCB Readings	Fault Operations B Ø	0	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/9/2020 5:34	Distribution	Boonesboro Park Quarterly Inspection	ST000509	Structure	432-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/6/2020 16:52	Distribution	Richmond South Quarterly Inspection	ST000454	Structure	545-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	60.0	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	70.0	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	183	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	183	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	0	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	59.0	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	2	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000494	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 12:07	Distribution	Walker Quarterly Inspection	BAT001420	Battery	191-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/5/2020 12:07	Distribution	Walker Quarterly Inspection	BAT001420	Battery	191-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/5/2020 12:07	Distribution	Walker Quarterly Inspection	BAT001420	Battery	191-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/5/2020 12:07	Distribution	Walker Quarterly Inspection	BAT001420	Battery	191-Battery Bank	Battery Patrol Inspection	Battery Bank Volts	134.1	VDC
11/5/2020 12:07	Distribution	Walker Quarterly Inspection	BAT001420	Battery	191-Battery Bank	Battery Patrol Inspection	Battery Bank Amps	.8	AMPS
11/5/2020 12:07	Distribution	Walker Quarterly Inspection	BAT001420	Battery	191-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
11/5/2020 12:07	Distribution	Walker Quarterly Inspection	BAT001420	Battery	191-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/5/2020 12:07	Distribution	Walker Quarterly Inspection	BAT001420	Battery	191-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/5/2020 12:07	Distribution	Walker Quarterly Inspection	BAT001420	Battery	191-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/5/2020 12:07	Distribution	Walker Quarterly Inspection	BAT001420	Battery	191-Battery Bank	Battery Patrol Inspection	General Comments		
11/5/2020 12:07	Distribution	Walker Quarterly Inspection	BAT001420	Battery	191-Battery Bank	Battery Patrol Inspection	Negative DC Ground	63.4	VDC
11/5/2020 12:07	Distribution	Walker Quarterly Inspection	BAT001420	Battery	191-Battery Bank	Battery Patrol Inspection	Positive DC Ground	70.0	VDC
11/5/2020 12:07	Distribution	Walker Quarterly Inspection	BAT001420	Battery	191-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/5/2020 12:07	Distribution	Walker Quarterly Inspection	BAT001420	Battery	191-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/5/2020 12:07	Distribution	Walker Quarterly Inspection	BAT001420	Battery	191-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/5/2020 12:07	Distribution	Walker Quarterly Inspection	BAT001420	Battery	191-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 12:07	Distribution	Walker Quarterly Inspection	BCH001340	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	134.1	VDC
11/5/2020 12:07	Distribution	Walker Quarterly Inspection	BCH001340	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	134.1	VDC
11/5/2020 12:07	Distribution	Walker Quarterly Inspection	BCH001340	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
11/5/2020 12:07	Distribution	Walker Quarterly Inspection	BCH001340	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/5/2020 12:07	Distribution	Walker Quarterly Inspection	BCH001340	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/5/2020 12:07	Distribution	Walker Quarterly Inspection	BCH001340	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	General Comments		
11/5/2020 12:07	Distribution	Walker Quarterly Inspection	BCH001340	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	Ground Lights	None	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	BCH000455	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	BCH000455	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	BCH000455	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	BCH000455	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	BCH000455	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	1.75	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	1.75	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	1.75	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps C Ø	10.0	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps B Ø	10.0	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps A Ø	20.0	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Readings	9 Month Operations	2	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Readings	General Comments		
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Readings	Maintenance Operations	0	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations Counter AF	555	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations Counter AL	0	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations This Read Vac	1	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Readings	Switching Operations	0	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Readings	Unknown Operations	1	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	General Comments		
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0149	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Readings	9 Month Operations	3	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Readings	General Comments		
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Readings	Maintenance Operations	0	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations Counter AF	517	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations Counter AL	517	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations This Read Vac	2	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps A Ø	10.0	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps B Ø	20.0	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	3.49	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	3.49	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	3.49	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps C Ø	20.0	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Readings	Switching Operations	0	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Readings	Unknown Operations	2	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	General Comments		
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	WB0150	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Operations This Read Vac	1	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Operations Counter AL	188	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Operations Counter AF	188	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Maintenance Operations	0	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Amps C Ø	180.0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Amps B Ø	200.0	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Amps A Ø	210.0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	9 Month Operations	0	
11/5/2020 10:44	Distribution	Lawrenceburg Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Unknown Operations	0	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	9 Month Operations	10	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	LTC Totalizer Reading	10836.00	kw
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	General Comments		
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	General Comments		
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Unknown Operations	0	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Switching Operations	1	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	Oil Temp Max	50	°C
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	Oil Temp Present	35	°C
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	General Comments		
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	General Comments		
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	LTC Totalizer Reading	9882.00	kw
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	Oil Temp Max	65	°C
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	Oil Temp Present	50	°C
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	General Comments		
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Patrol Inspection	General Comments		
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Follow-up Action Required?	n	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Fault Operations Ground	0	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Fault Operations C Ø	2	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Bushing Condition	Good	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	9 Month Operations	9	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Amps A Ø	183.0	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Amps B Ø	202.0	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Fault Operations B Ø	0	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Fault Operations A Ø	0	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Fault Adjusted Amps C Phase V	22.36	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Vegetation	None	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Amps C Ø	205.0	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	Totalizer Meter Reading	.5490	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Grounds in Place?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	General Comments		
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	9 Month Operations	1	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Accumulated Fault Duty A Ph V	1.2	%
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	General Comments		
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	General Comments		
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Foundation Condition	Good	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Follow-up Action Required?	n	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Accumulated Fault Duty B Ph V	1.2	%
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Accumulated Fault Duty C Ph V	1.2	%
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Amps A Ø	341.0	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Amps B Ø	288.0	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Amps C Ø	302.0	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	Totalizer Meter Reading	.6020	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	Winding Temp Max	55	°C
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	Winding Temp Present	40	°C
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0467	WithLTC	639-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Fault Operations Ground	0	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	ST000488	Structure	588-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Fault Operations C Ø	0	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Fault Operations B Ø	0	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Fault Operations A Ø	0	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	KB0088	BreakerVacuum	639-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Switching Operations	0	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Operations This Read Vac	2	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Operations Counter AL	656	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Operations Counter AF	656	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0560	BreakerVacuum	LY-1163	VCB Readings	Maintenance Operations	0	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Follow-up Action Required?	n	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Fault Operations Ground	0	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Fault Operations C Ø	3	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Fault Operations B Ø	0	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Fault Operations A Ø	0	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Fault Adjusted Amps C Phase V	18.81	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Bushing Condition	Good	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Amps C Ø	188.0	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Amps B Ø	199.0	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Amps A Ø	196.0	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	9 Month Operations	6	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	General Comments	source bushing needs wildlife protection installed.	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Regulator As Left Counter	50061	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Max Tap Position	5R	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	General Comments		
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	0	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	Amps A Ø	8.0	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	Amps B Ø	5.0	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Current Tap Position	7L	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	Amps C Ø	10.0	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	0	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	R1293	Regulator	457-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	0	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Fault Adjusted Amps B Phase AM	22.36	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Fault Operations A Ø	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Fault Operations B Ø	2	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Fault Operations C Ø	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Unknown Operations	2	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	9 Month Operations	4	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Amps C Ø	20.0	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Amps B Ø	200.0	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Amps A Ø	20.0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Amps A Ø	138.0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Amps B Ø	125.0	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	9 Months Operations	6	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Amps C Ø	130.0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Patrol Inspection	Bushing Condition	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Switching Operations	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Operations This Read Vac	2	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Operations Counter AL	83	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Fault Operations Ground	0	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Follow-up Action Required?	n	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Patrol Inspection	General Comments		
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	General Comments		A and B phase IOC
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Maintenance Operations	0	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Operations Counter AF	53	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Operations Counter AL	53	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Operations This Read AM	3	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Switching Operations	0	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0558	BreakerAirMagnetic	LY-1111	AMCB Readings	Unknown Operations	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Operations Counter AF	83	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Maintenance Operations	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Fault Operations A Ø	0	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Regulator As Left Counter	60658	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	R1294	Regulator	457-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Regulator As Left Counter	5445	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Maintenance Operations	0	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Grounds in Place?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	General Comments		
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	General Comments		
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Foundation Condition	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Fault Operations Ground	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Fault Operations C Ø	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Fault Operations B Ø	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Fault Operations A Ø	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Amps C Ø	0.0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Amps B Ø	0.0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Amps A Ø	0.0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	9 Month Operations	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Unknown Operations	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Switching Operations	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Operations This Read Vac	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Operations Counter AL	662	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Operations Counter AF	662	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Maintenance Operations	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	General Comments		
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Patrol Inspection	General Comments		
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Follow-up Action Required?	n	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Fault Operations Ground	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Fault Operations C Ø	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Fault Operations B Ø	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Fault Operations A Ø	0	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.3	psi
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Readings	General Comments		
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	General Comments		
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Max Tap Position	5L	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	General Comments		
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Current Tap Position	7L	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0078	BreakerVacuum	BY-1284	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Readings	Follow-up Action Required?	n	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	C0528	WithLTC	588-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	General Comments		
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	X0354	RecloserHydraulic	701-0720	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Fault Operations B Ø	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Fault Operations C Ø	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Patrol Inspection	Follow-up Action Required?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Follow-up Action Required?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Patrol Inspection	Foundation Condition	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Patrol Inspection	General Comments	The flag on the breaker is bent out of position. Pictures have been sent to Tom and Kevin. Jennifer has put in an outage request and c	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	General Comments	The flag on this breaker is bent out of position. Pictures have been sent to Tom & Kevin. Jennifer has put in outage request and create	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Patrol Inspection	Grounds in Place?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	BCH000141	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	BCH000141	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	134	VDC
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	BCH000141	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	133	VDC
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	BCH000141	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1	amps
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	BCH000141	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	BCH000141	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments	.	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Maintenance Operations	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Operations Counter AF	34	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Operations Counter AL	34	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Operations This Read Vac	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Switching Operations	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001383	BreakerVacuum	IN-1291	VCB Readings	Unknown Operations	0	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5800	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	600	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Readings	Totalizer Meter Reading	.6846	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Unknown Operations	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Switching Operations	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Operations This Read Vac	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Operations Counter AL	216	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Operations Counter AF	216	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Readings	Oil Temp Present	30	°C
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Readings	Oil Temp Max	50	°C
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	348.00	kw
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Readings	General Comments		
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	C0315	NonLTC	701-1	NonLTC Transformer Patrol Inspection	General Comments		
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	W0188	NonLTC	012-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	1643.04	kw
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Maintenance Operations	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	General Comments		
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Patrol Inspection	General Comments		
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0514	BreakerVacuum	IN-1299	VCB Readings	Follow-up Action Required?	n	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	VCB Readings	Follow-up Action Required?	n	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	General Comments		
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	52.50	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Foundation Condition	Good	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Follow-up Action Required?	n	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	Recloser Electronic Patrol Inspection	General Comments		
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	BCH000562	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	BCH000562	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	BCH000562	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	BCH000562	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	BCH000562	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	BCH000562	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	Recloser Electronic Patrol Inspection	Operations Counter	17	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	Recloser Electronic Patrol Inspection	Tank Leaks	None	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	110.00	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Foundation Condition	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Readings	Follow-up Action Required?	n	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Readings	Fault Operations	0	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Ambient Temperature	65	°F
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Readings	Switching Operations	0	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	SF6 Pressure Indicator	good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	SF6 Bushing Condition	Good	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	General Comments		
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BCH001423	Charger	724-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BCH001423	Charger	724-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	4.2	amps
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	General Comments		
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Readings	General Comments		
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	280.08	kw
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BCH001423	Charger	724-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BCH001423	Charger	724-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BCH001423	Charger	724-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BCH001423	Charger	724-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Unknown Operations	0	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	General Comments	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Switching Operations	2	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Operations This Read Vac	2	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Operations Counter AL	347	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Readings	General Comments		
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Operations Counter AF	347	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Maintenance Operations	0	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Grounds in Place?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	Recloser Electronic Patrol Inspection	Amps A Ø	0	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	Recloser Electronic Patrol Inspection	Amps B Ø	0	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	Recloser Electronic Patrol Inspection	Amps C Ø	0	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	Recloser Electronic Patrol Inspection	Battery Load Check OK?	n	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	General Comments		
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Counter Readings	LTC Operations Since Last Insp	638	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	45	°C
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	45	°C
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Counter Readings	LTC Min Tap Position	8L	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Counter Readings	LTC Max Tap Position	6L	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Counter Readings	LTC Current Tap Position	6L	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Counter Readings	LTC As Left Counter	222204	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Counter Readings	LTC As Found Counter	222200	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Mechanism Patrol Inspection	General Comments		
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Counter Readings	General Comments		
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Counter Readings	Follow-up Action Required?	n	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Amps C Ø	60.0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	General Comments		
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	BAT001029	Battery	BY-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Amps B Ø	99.0	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Amps A Ø	104.0	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	600	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4668	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Readings	Operations This Read SF6	0	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Readings	Operations Counter AL	29	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Readings	Operations Counter AF	29	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Readings	Num Operations Last 9 Months	2	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	BAT000379	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	RC000365	RecloserElectronic	029-0702	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Counter Readings	Follow-up Action Required?	n	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Counter Readings	General Comments		
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Mechanism Patrol Inspection	General Comments		
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Counter Readings	LTC As Found Counter	43257	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Counter Readings	LTC As Left Counter	43257	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Counter Readings	LTC Current Tap Position	3R	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Counter Readings	LTC Min Tap Position	6R	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	°C
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Counter Readings	LTC Operations Since Last Insp	881	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	S0052	LTCMechanism	400-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Operations Counter	68	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	General Comments		
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	X0335	RecloserElectronic	702-1450	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Readings	Maintenance Operations	0	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Heaters (All) Functioning?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Grounds in Place?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	General Comments	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Readings	General Comments		
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Gauge(s) Condition	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakerSF6	724-608	GCB Patrol Inspection	Foundation Condition	Good	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	LTCM000064	LTCMechanism	198-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Follow-up Action Required?	n	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Patrol Inspection	Foundation Condition	Good	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Patrol Inspection	General Comments		
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	General Comments		
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Patrol Inspection	Grounds in Place?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Maintenance Operations	30	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Operations Counter AF	172	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Operations Counter AL	172	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Operations This Read Vac	30	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Operations Counter	79	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	General Comments		
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Battery Load Check OK?	n	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Amps C Ø	45.0	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Amps B Ø	40.0	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	RC000611	RecloserElectronic	891-0719	Recloser Electronic Patrol Inspection	Amps A Ø	55.0	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Switching Operations	0	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	LTCC000288	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	LTCC000288	LTCControl	Retired Distribution	LTC Control Insp	General Comments	This bank bay should be C0528 and need base AF/AL, Time delay, operation checked and basic control checks for qtr added.	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	LTCC000288	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Unknown Operations	0	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	9 Month Operations	3	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Amps A Ø	200.0	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Amps B Ø	204.0	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Amps C Ø	201.0	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Bushing Condition	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	BCH000361	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	BCH000361	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	BCH000361	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	BCH000361	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	BCH000361	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	BCH000361	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Regulator As Left Counter	134881	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Max Tap Position	4L	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	General Comments		
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1146	Regulator	514-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Regulator As Left Counter	257057	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Patrol Inspection	Bushing Condition	Good	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Amps C Ø	67.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Amps B Ø	61.0	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Amps A Ø	48.0	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Fault Operations A Ø	0	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Fault Operations B Ø	0	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Fault Operations C Ø	0	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	Fault Operations Ground	0	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BAT001492	Battery	724-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BAT001492	Battery	724-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BAT001492	Battery	724-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Readings	Switching Operations	0	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	SF6 Pressure Indicator	good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Readings	Operations This Read SF6	0	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Readings	Operations Counter AL	42	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Readings	Operations Counter AF	42	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Readings	Num Operations Last 9 Months	2	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Readings	Maintenance Operations	0	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Heaters (All) Functioning?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000602	BreakerSF6	724-618	GCB Patrol Inspection	Grounds in Place?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BAT001492	Battery	724-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #""s
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	W0218	NonLTC	457-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BAT001492	Battery	724-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BAT001492	Battery	724-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BAT001492	Battery	724-Battery Bank	Battery Patrol Inspection	General Comments		
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BAT001492	Battery	724-Battery Bank	Battery Patrol Inspection	Negative DC Ground	25.0	VDC
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BAT001492	Battery	724-Battery Bank	Battery Patrol Inspection	Positive DC Ground	28.0	VDC
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BAT001492	Battery	724-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BAT001492	Battery	724-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BCH001423	Charger	724-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.020	millivolts
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BCH001423	Charger	724-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Maintenance Operations	0	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Operations Counter AF	196	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Operations Counter AL	196	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Operations This Read Vac	0	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Switching Operations	0	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Unknown Operations	0	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Max Tap Position	3L	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Max Tap Position	3L	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	General Comments		
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	BK001609	BreakerVacuum	400-2505	VCB Readings	9 Month Operations	30	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Fault Operations A Ø	0	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Fault Operations B Ø	0	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Fault Operations C Ø	0	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Fault Operations Ground	0	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	Follow-up Action Required?	n	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Foundation Condition	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	General Comments		
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Readings	General Comments		
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK000319	BreakerVacuum	588-2524	VCB Patrol Inspection	Grounds in Place?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BAT001492	Battery	724-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BAT001492	Battery	724-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1145	Regulator	514-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Regulator As Left Counter	201084	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	68	*F
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BCH001069	Charger	609-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BCH001069	Charger	609-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BCH001069	Charger	609-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BCH001069	Charger	609-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.3	amps
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BCH001069	Charger	609-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BCH001069	Charger	609-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	General Comments		
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Counter Readings	LTC Operations Since Last Insp	366	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BCH001069	Charger	609-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Counter Readings	LTC Min Tap Position	5L	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Counter Readings	LTC Current Tap Position	4L	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Panels Dusted?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	General Comments		
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Filters Condition OK?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	CH000412	ControlHouse	609-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Counter Readings	LTC As Left Counter	157413	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Counter Readings	LTC As Found Counter	157410	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Mechanism Patrol Inspection	General Comments		
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Counter Readings	General Comments		
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	W0299	LTCMechanism	655-1	LTC Counter Readings	Follow-up Action Required?	n	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Ambient Temp	51	*F
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	General Comments		
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	R1144	Regulator	514-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	BCH000516	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	BCH000516	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	BCH000516	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	BCH000516	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	BCH000516	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	BCH000516	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	BCH000523	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	BCH000523	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	BCH000523	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	BCH000523	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	General Comments		
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BAT001110	Battery	609-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BCH001069	Charger	609-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Counter Readings	LTC Max Tap Position	7L	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Counter Readings	LTC Current Tap Position	9L	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Counter Readings	LTC As Left Counter	6193	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Counter Readings	LTC As Found Counter	6185	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Mechanism Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Counter Readings	General Comments		
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Counter Readings	Follow-up Action Required?	n	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Bushing Condition	Good	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Amps C Ø	55.0	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Fault Operations Ground	0	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Fault Operations C Ø	0	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Fault Operations B Ø	0	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Fault Operations A Ø	0	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Fault Adjusted Amps C Phase AM	22.36	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Fault Adjusted Amps B Phase AM	22.36	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Fault Adjusted Amps A Phase AM	22.36	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Amps C Ø	280.0	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Amps B Ø	270.0	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Amps A Ø	330.0	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	9 Months Operations	2	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000061	Regulator	701-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Amps B Ø	60.0	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Amps A Ø	50.0	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	General Comments		
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	ST000402	Structure	772-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	General Comments		
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Unknown Operations	2	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Switching Operations	0	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Operations This Read AM	2	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Operations Counter AL	663	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Operations Counter AF	663	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Unknown Operations	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Switching Operations	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Operations This Read Vac	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Operations Counter AL	161	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Operations Counter AF	161	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Maintenance Operations	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	General Comments		
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Patrol Inspection	General Comments		
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Follow-up Action Required?	n	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Fault Operations C Ø	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Fault Operations B Ø	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Fault Operations A Ø	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Amps C Ø	0.0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Amps B Ø	0.0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Amps A Ø	0.0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0512	BreakerVacuum	IN-1297	VCB Readings	9 Month Operations	3	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	FE000629	Fence	BY-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Maintenance Operations	0	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	General Comments		
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Patrol Inspection	General Comments		
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0559	BreakerAirMagnetic	LY-1112	AMCB Readings	Follow-up Action Required?	n	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Counter Readings	LTC Operations Since Last Insp	467	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	C0510	LTCMechanism	496-1	LTC Counter Readings	LTC Min Tap Position	11L	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Switching Operations	0	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Operations This Read Vac	0	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	General Comments		
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Operations Counter AL	277	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Operations Counter AF	277	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Maintenance Operations	0	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Grounds in Place?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	General Comments		
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Foundation Condition	Good	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Follow-up Action Required?	n	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Fault Operations Ground	0	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Fault Operations C Ø	0	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Fault Operations B Ø	0	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Fault Operations A Ø	0	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	7L	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Patrol Inspection	Bushing Condition	Good	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Amps C Ø	150.0	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Amps B Ø	150.0	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Amps A Ø	150.0	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	Totalizer Meter Reading	.4690	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	Winding Temp Max	34	°C
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	Winding Temp Present	30	°C
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	Follow-up Action Required?	n	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	14314	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.1	volts
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakersSF6	724-608	GCB Readings	Follow-up Action Required?	n	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakersSF6	724-608	GCB Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakersSF6	724-608	GCB Readings	Fault Operations	0	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	General Comments		
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	General Comments		
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	LTC Totalizer Reading	8442.00	kw
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1600	psi
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	Oil Temp Max	34	°C
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	Oil Temp Present	30	°C
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakersSF6	724-608	GCB Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	8L	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	3L	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakersSF6	724-608	GCB Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakersSF6	724-608	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakersSF6	724-608	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakersSF6	724-608	GCB Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000601	BreakersSF6	724-608	GCB Patrol Inspection	Ambient Temperature	65	°F
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.3	VDC
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.2	VDC
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	General Comments		
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	59	°F
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BAT001114	Battery	588-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Unknown Operations	0	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	Oil Temp Present	45	°C
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	Oil Temp Max	50	°C
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	LTC Totalizer Reading	9312.00	kw
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Fault Operations Ground	0	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Fault Operations C ∅	0	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Fault Operations B ∅	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Fault Operations A Ø	0	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0185	BreakerVacuum	473-0722	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	ST000614	Structure	BY-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Vegetation	None	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	YD000631	Yard	BY-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	General Comments		
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	General Comments		
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	General Comments		
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	FE000482	Fence	588-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Ambient Temp	59	°F
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	YD000487	Yard	588-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	TX000128	WithLTC	724-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	RG000015	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	K0153	BreakerVacuum	473-0721	VCB Readings	9 Month Operations	10	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	Winding Temp Present	50	°C
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	Winding Temp Max	60	°C
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	Totalizer Meter Reading	.9700	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	64	°F
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	General Comments		
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	BAT000519	Battery	891-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	S0052	WithLTC	400-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	General Comments		
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Readings	General Comments		
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Readings	Oil Temp Max	35	°C
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Readings	Oil Temp Present	35	°C
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0176	NonLTC	891-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Counter Readings	General Comments		
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Counter Readings	LTC As Found Counter	40054	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Counter Readings	LTC As Left Counter	40054	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Counter Readings	LTC Current Tap Position	6L	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Counter Readings	LTC Max Tap Position	3R	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Counter Readings	LTC Min Tap Position	10L	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	47	°C
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	21	°C
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	857	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LTCC000521	LTCControl	BY-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LTCC000521	LTCControl	BY-TRANS 2	LTC Control Insp	General Comments		
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LTCC000521	LTCControl	BY-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Counter Readings	General Comments		
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Counter Readings	LTC As Found Counter	49405	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Counter Readings	LTC As Left Counter	49405	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Counter Readings	LTC Current Tap Position	2L	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Counter Readings	LTC Max Tap Position	1L	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Counter Readings	LTC Min Tap Position	6L	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	43	°C
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	22	°C
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	249	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0097	LTCMechanism	IN-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Counter Readings	General Comments		
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Counter Readings	General Comments	Tap changer found in manual position	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Counter Readings	LTC As Found Counter	58533	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Counter Readings	LTC As Left Counter	58533	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Counter Readings	LTC Current Tap Position	2L	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Counter Readings	LTC Max Tap Position	2L	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Counter Readings	LTC Min Tap Position	2L	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Unknown Operations	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Switching Operations	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Operations This Read Vac	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Operations Counter AL	47	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Operations Counter AF	47	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Maintenance Operations	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	General Comments		
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	9 Month Operations	5	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Amps A Ø	210.0	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Amps B Ø	180.0	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Amps C Ø	210.0	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Bushing Condition	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Fault Operations A Ø	0	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Fault Operations B Ø	0	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Fault Operations C Ø	0	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Fault Operations Ground	0	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Follow-up Action Required?	n	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Foundation Condition	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	General Comments		
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	General Comments		
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Grounds in Place?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Maintenance Operations	0	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	2R	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Operations Counter AF	49	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Operations Counter AL	49	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Operations This Read Vac	0	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Switching Operations	0	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0423	BreakerVacuum	609-0401	VCB Readings	Unknown Operations	0	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	LTCC000884	LTCControl	639-2	LTC Control Insp	VRR Time Delay	30	Seconds
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	LTCC000884	LTCControl	639-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	LTCC000884	LTCControl	639-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	LTCC000884	LTCControl	639-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	LTCC000884	LTCControl	639-2	LTC Control Insp	LTC Operation Checked?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	LTCC000884	LTCControl	639-2	LTC Control Insp	General Comments		
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	LTCC000884	LTCControl	639-2	LTC Control Insp	Follow-up Action Required?	n	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	LTCC000884	LTCControl	639-2	LTC Control Insp	All Connections OK?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	LTCMechanism	BY-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	Oil Temp Present	34	°C
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	Oil Temp Max	60	°C
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	General Comments		
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Bushing Condition	Good	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Fault Adjusted Amps A Phase V	12.58	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Fault Adjusted Amps B Phase V	12.58	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Fault Adjusted Amps C Phase V	12.58	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Fault Operations A Ø	0	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Fault Operations B Ø	0	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Fault Operations C Ø	0	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Fault Operations Ground	0	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Follow-up Action Required?	n	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Foundation Condition	Good	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	General Comments		
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	General Comments		
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Grounds in Place?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Counter Readings	Follow-up Action Required?	n	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Counter Readings	General Comments		
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Mechanism Patrol Inspection	General Comments		
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Counter Readings	LTC As Found Counter	53832	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Counter Readings	LTC As Left Counter	53832	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Maintenance Operations	0	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Operations Counter AF	57	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Operations Counter AL	57	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Operations This Read Vac	3	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Switching Operations	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Patrol Inspection	General Comments		
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Follow-up Action Required?	n	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Fault Operations Ground	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Fault Operations C Ø	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Fault Operations B Ø	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Fault Operations A Ø	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Amps C Ø	320.0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Amps B Ø	300.0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Amps A Ø	300.0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	35	°C
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	9 Month Operations	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Amps A Ø	0.0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Amps B Ø	0.0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Amps C Ø	0.0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Fault Operations A Ø	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Fault Operations B Ø	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Fault Operations C Ø	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0077	BreakerVacuum	BY-1283	VCB Readings	9 Month Operations	7	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0098	LTCMechanism	IN-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Fault Operations Ground	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Follow-up Action Required?	n	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Patrol Inspection	General Comments		
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	General Comments		
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Maintenance Operations	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Operations Counter AF	669	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	9 Month Operations	6	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Amps A Ø	22.0	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Amps B Ø	25.0	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Amps C Ø	24.0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	62	°C
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	35	°C
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	62	°C
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	35	°C
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	62	°C
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0294	WithLTC	BY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Amps C Ø	68	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Amps B Ø	70	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Amps A Ø	75	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Readings	General Comments		
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Gauge(s) Condition	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Foundation Condition	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Readings	Follow-up Action Required?	n	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Readings	Fault Operations	0	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Ambient Temperature	65	°F
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BCH001041	Charger	838-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BCH001041	Charger	838-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BCH001041	Charger	838-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BCH001041	Charger	838-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BCH001041	Charger	838-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.9	amps
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BCH001041	Charger	838-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BCH001383	Charger	588-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BCH001383	Charger	588-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BCH001383	Charger	588-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BCH001383	Charger	588-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BCH001383	Charger	588-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.2	amps
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BCH001383	Charger	588-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BCH001383	Charger	588-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BCH001383	Charger	588-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.020	millivolts
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BCH001041	Charger	838-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BCH001041	Charger	838-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	General Comments		
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	FE000861	Fence	473-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	Follow-up Action Required?	n	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Tank Leaks	None	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Regulator As Left Counter	69989	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	General Comments		
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Grounds in Place?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Maintenance Operations	0	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Operations Counter	56	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Operations Counter AF	213	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Operations Counter AL	213	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Operations This Read Vac	0	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Switching Operations	0	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Unknown Operations	0	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Tank Leaks	None	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Operations Counter	1453	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	General Comments		
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Counter Readings	Follow-up Action Required?	n	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Counter Readings	General Comments		
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Mechanism Patrol Inspection	General Comments		
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Counter Readings	LTC As Found Counter	51757	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Counter Readings	LTC As Left Counter	51757	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Counter Readings	LTC Current Tap Position	7L	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Counter Readings	LTC Max Tap Position	6L	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Counter Readings	LTC Min Tap Position	8L	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Counter Readings	LTC Operations Since Last Insp	535	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0371	LTCMechanism	838-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Readings	Switching Operations	0	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	SF6 Pressure Indicator	good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	SF6 Bushing Condition	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Readings	Operations This Read SF6	0	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Readings	Operations Counter AL	56	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Readings	Operations Counter AF	56	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Readings	Num Operations Last 9 Months	0	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Readings	Maintenance Operations	0	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Heaters (All) Functioning?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	Grounds in Place?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000517	BreakerSF6	609-608	GCB Patrol Inspection	General Comments	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	BX0733	RecloserElectronic	029-0701	Recloser Electronic Patrol Inspection	Battery Load Check OK?	n	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	General Comments		
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Panels Dusted?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Tank Leaks	None	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Regulator As Left Counter	75905	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Min Tap Position	5L	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Max Tap Position	1L	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	General Comments		
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Current Tap Position	5L	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R1134	Regulator	012-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	68558	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	2R	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	6R	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0790	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	General Comments		
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	General Comments		
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	LTC Totalizer Reading	12600.00	kw
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	Oil Temp Max	40	°C
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Min Tap Position	7L	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Max Tap Position	3L	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	Oil Temp Present	30	°C
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	Totalizer Meter Reading	.7000	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	Winding Temp Max	50	°C
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	Winding Temp Present	35	°C
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0522	WithLTC	639-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LTCC000040	LTCControl	IN-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	paralleIPAR	Position
11/5/2020 13:00	Distribution	International Quarterly Inspection	LTCC000040	LTCControl	IN-TRANS 1	LTC Control Insp	General Comments		
11/5/2020 13:00	Distribution	International Quarterly Inspection	LTCC000040	LTCControl	IN-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LTCC000039	LTCControl	IN-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	paralleIPAR	Position
11/5/2020 13:00	Distribution	International Quarterly Inspection	LTCC000039	LTCControl	IN-TRANS 2	LTC Control Insp	General Comments		
11/5/2020 13:00	Distribution	International Quarterly Inspection	LTCC000039	LTCControl	IN-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Amps A Ø	60.0	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Amps B Ø	55.0	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Amps C Ø	70.0	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	General Comments		
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Operations Counter	11	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Tank Leaks	None	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	General Comments		
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R1135	Regulator	012-5 C	Regulator Patrol Inspection	Current Tap Position	5L	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Bushing Condition	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Amps C Ø	0.0	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Amps B Ø	0.0	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Amps A Ø	0.0	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	9 Month Operations	3	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Readings	Oil Temp Present	40	°C
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Readings	Oil Temp Max	50	°C
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Readings	General Comments		
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	General Comments		
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Readings	Oil Temp Present	30	°C
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Readings	Oil Temp Max	0	°C
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Readings	General Comments	max temp hand not functional	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	General Comments		
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	WD0126	NonLTC	514-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.3156	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Fault Operations A Ø	0	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Fault Operations Ground	0	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Follow-up Action Required?	n	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Foundation Condition	Good	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	General Comments		
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	General Comments		
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Grounds in Place?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Maintenance Operations	0	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Operations Counter AF	226	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Operations Counter AL	226	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Operations This Read Vac	1	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Switching Operations	1	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Unknown Operations	0	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Bushing Condition	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Amps C Ø	380.0	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Amps B Ø	380.0	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Amps A Ø	375.0	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	9 Month Operations	4	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Unknown Operations	0	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Switching Operations	0	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	CD0186	NonLTC	514-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Operations This Read Vac	0	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Operations Counter AL	200	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Operations Counter AF	200	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Maintenance Operations	0	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Grounds in Place?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	General Comments		
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Foundation Condition	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Follow-up Action Required?	n	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Fault Operations Ground	0	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Fault Operations C Ø	0	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Fault Operations B Ø	0	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Fault Operations A Ø	0	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000504	BreakerVacuum	609-0408	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	General Comments		
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Readings	General Comments		
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	2200	psi
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	69.17	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	55.00	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Readings	Oil Temp Max	50	°C
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Readings	Oil Temp Present	30	°C
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Readings	Winding Temp Max	20	°C
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	T0117	NonLTC	005-2	NonLTC Transformer Readings	Winding Temp Present	10	°C
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	General Comments		
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Max Tap Position	1L	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.3	volts
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Regulator As Left Counter	423	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Readings	Oil Temp Present	30	°C
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Readings	Oil Temp Max	0	°C
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	Amps C Ø	598.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Patrol Inspection	Bushing Condition	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	Fault Operations Ground	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Patrol Inspection	Foundation Condition	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Patrol Inspection	General Comments		
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	General Comments		
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Patrol Inspection	Grounds in Place?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	Maintenance Operations	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	Operations Counter AF	47	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	Operations Counter AL	47	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	Operations This Read Vac	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	BCH001370	Charger	608-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	BCH001370	Charger	608-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	BCH001370	Charger	608-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	BCH001370	Charger	608-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	BCH001370	Charger	608-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	BCH001370	Charger	608-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	BCH001370	Charger	608-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	BCH001370	Charger	608-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0522	Regulator	702-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	378.72	kw
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Readings	General Comments	Max temp hand not functional	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	LTCC000682	LTCControl	422-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	LTCC000682	LTCControl	422-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	LTCC000682	LTCControl	422-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	LTCC000682	LTCControl	422-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	LTCC000682	LTCControl	422-1	LTC Control Insp	LTC Operation Checked?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	LTCC000682	LTCControl	422-1	LTC Control Insp	General Comments		
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	LTCC000682	LTCControl	422-1	LTC Control Insp	Follow-up Action Required?	n	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	LTCC000682	LTCControl	422-1	LTC Control Insp	All Connections OK?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	Switching Operations	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001466	BreakerVacuum	IN-12KV TR 1	VCB Readings	Unknown Operations	0	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	General Comments		
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	WD0124	NonLTC	514-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Counter Readings	LTC Current Tap Position	6L	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Counter Readings	LTC Max Tap Position	2L	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Counter Readings	LTC Min Tap Position	8L	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Counter Readings	LTC Operations Since Last Insp	772	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Fault Operations B Ø	0	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Fault Operations C Ø	0	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Fault Operations Ground	0	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Follow-up Action Required?	n	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Foundation Condition	Good	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	General Comments		
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	General Comments		
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Grounds in Place?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Maintenance Operations	0	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0467	LTCMechanism	639-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Operations Counter AF	50	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Operations Counter AL	50	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Operations This Read Vac	0	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Switching Operations	0	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Unknown Operations	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Operations Counter AL	669	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Operations This Read Vac	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Switching Operations	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0076	BreakerVacuum	BY-1282	VCB Readings	Unknown Operations	0	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Unknown Operations	0	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Switching Operations	0	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Operations This Read Vac	0	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Operations Counter AL	173	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Operations Counter AF	173	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Maintenance Operations	0	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Grounds in Place?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	General Comments		
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	General Comments		
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Foundation Condition	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Follow-up Action Required?	n	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Fault Operations Ground	0	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Fault Operations C Ø	0	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Fault Operations B Ø	0	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Fault Operations A Ø	0	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Patrol Inspection	Bushing Condition	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Amps C Ø	375.0	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Amps B Ø	380.0	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000484	BreakerVacuum	005-3410	VCB Readings	Unknown Operations	3	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	9 Month Operations	1	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Amps A Ø	9.0	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Amps B Ø	12.0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Readings	9 Month Operations	15	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Readings	Amps A Ø	167.0	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Amps C Ø	9.0	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Bushing Condition	Good	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000485	BreakerVacuum	005-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Readings	Amps B Ø	164.0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Readings	Amps C Ø	160.0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Patrol Inspection	Bushing Condition	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001463	BreakerVacuum	IN-1292	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Fault Operations A Ø	0	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Fault Operations B Ø	0	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	CB0243	BreakerVacuum	639-2	VCB Readings	Fault Operations C Ø	0	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Fault Operations B Ø	0	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Amps A Ø	390.0	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000506	BreakerVacuum	609-2	VCB Readings	9 Month Operations	1	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Unknown Operations	0	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Switching Operations	2	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Operations This Read Vac	2	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Operations Counter AL	197	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Operations Counter AF	197	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Maintenance Operations	0	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Grounds in Place?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	General Comments		
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	General Comments		
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Foundation Condition	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Follow-up Action Required?	n	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Fault Operations Ground	0	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BK000505	BreakerVacuum	609-0403	VCB Readings	Fault Operations C Ø	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	Amps A Ø	260.0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	Amps B Ø	277.0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	Amps C Ø	255.0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Patrol Inspection	Bushing Condition	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	Fault Operations A Ø	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	Fault Operations B Ø	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	Fault Operations C Ø	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	Fault Operations Ground	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	Follow-up Action Required?	n	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Patrol Inspection	Foundation Condition	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Patrol Inspection	General Comments		
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	General Comments		
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Patrol Inspection	Grounds in Place?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	Maintenance Operations	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	Operations Counter AF	24	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	Operations Counter AL	24	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	Operations This Read Vac	1	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	Switching Operations	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001464	BreakerVacuum	IN-1293	VCB Readings	Unknown Operations	1	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Readings	9 Month Operations	11	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001465	BreakerVacuum	IN-1294	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	ANN000013	Annunciator	BY-Annunciator Panel	Annunciator Patrol Inspection	All Lights Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	ANN000013	Annunciator	BY-Annunciator Panel	Annunciator Patrol Inspection	Control House Alarm Audible?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	ANN000013	Annunciator	BY-Annunciator Panel	Annunciator Patrol Inspection	ESOC Received Alarm Test?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	ANN000013	Annunciator	BY-Annunciator Panel	Annunciator Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	ANN000013	Annunciator	BY-Annunciator Panel	Annunciator Patrol Inspection	General Comments		
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Fault Operations Ground	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Amps C Ø	800.0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Amps B Ø	825.0	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	General Comments		
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	General Comments		
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	LTC Totalizer Reading	6566.40	kw
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	Oil Temp Max	75	°C
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	Oil Temp Present	45	°C
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	Totalizer Meter Reading	.6840	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Amps A Ø	800.0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	9 Month Operations	1	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	°F
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	75273	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	BAT000212	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	BAT000212	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	Terminals on batteries are corroded.	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	BAT000212	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0	VDC
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	BAT000212	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0	VDC
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	BAT000212	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	n	If no, which cells in comments
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	BAT000212	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Unknown Operations	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Switching Operations	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Operations This Read Vac	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Operations Counter AL	429	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Operations Counter AF	429	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	Maintenance Operations	0	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	General Comments		
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	General Comments		
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	Follow-up Action Required?	n	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Fans Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Readings	General Comments		
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0081	BreakerVacuum	BY-12KV TR 1	VCB Patrol Inspection	General Comments		
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Counter Readings	LTC Operations Since Last Insp	494	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	45	°C
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	45	°C
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Counter Readings	LTC Min Tap Position	11L	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Counter Readings	LTC Max Tap Position	4R	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Counter Readings	LTC Current Tap Position	9L	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Counter Readings	LTC As Left Counter	13489	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Counter Readings	LTC As Found Counter	13482	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Mechanism Patrol Inspection	General Comments		
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Counter Readings	General Comments		
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	LTCM000052	LTCMechanism	005-5	LTC Counter Readings	Follow-up Action Required?	n	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	B0273	WithLTC	588-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Readings	Follow-up Action Required?	n	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	General Comments		
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Readings	General Comments		
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Readings	LTC Totalizer Reading	7700.40	kw
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Unknown Operations	0	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Switching Operations	0	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Operations This Read Vac	0	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Operations Counter AL	210	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Operations Counter AF	210	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Maintenance Operations	0	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Grounds in Place?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	General Comments		
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	General Comments		
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Foundation Condition	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Follow-up Action Required?	n	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Fault Operations C Ø	0	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Fault Operations B Ø	0	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	General Comments		
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Vegetation	None	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	YD000418	Yard	609-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	General Comments		
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BAT001050	Battery	838-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	2R	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	6R	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	General Comments		
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	3R	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0894	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Amps A Ø	97.0	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	BAT001450	Battery	400-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	BAT001450	Battery	400-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	BAT001450	Battery	400-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	BAT001450	Battery	400-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	BAT001450	Battery	400-Battery Bank	Battery Patrol Inspection	General Comments		
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	BAT001450	Battery	400-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	BAT001450	Battery	400-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	BAT001450	Battery	400-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	BAT001450	Battery	400-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	BAT001450	Battery	400-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	BAT001450	Battery	400-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	BAT001450	Battery	400-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	58	°F
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	BAT001450	Battery	400-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	BAT000793	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	BAT000793	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	BAT000793	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	BAT000793	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	BAT000793	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	BAT000793	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	BAT000793	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	BAT000793	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	AC rip 14.0	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	BAT000793	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	BCH000780	Charger	514-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.8	VDC
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	BCH000780	Charger	514-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.8	VDC
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	BCH000780	Charger	514-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	BCH000780	Charger	514-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Current Tap Position	8L	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	LTCC000353	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	LTCC000353	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	LTCC000353	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	LTCC000353	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	LTCC000583	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	LTCC000583	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	LTCC000583	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	LTCC000583	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	LTCC000583	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	LTCC000583	LTCControl	930-Offline-Distribution	LTC Control Insp	General Comments		
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	LTCC000583	LTCControl	930-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	LTCC000583	LTCControl	930-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	LTCC000353	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	LTCC000353	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	LTCC000353	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	LTCC000353	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	General Comments		
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Max Tap Position	8L	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Regulator As Left Counter	3296	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Operations Counter AF	489	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Operations Counter AL	489	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Operations This Read Vac	3	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Switching Operations	0	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0433	BreakerVacuum	838-0508	VCB Readings	Unknown Operations	0	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	General Comments		
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Min Tap Position	9L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Regulator As Left Counter	4953	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000062	Regulator	701-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Unknown Operations	0	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Switching Operations	0	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Operations This Read Vac	0	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Operations Counter AL	155	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Operations Counter AF	155	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Maintenance Operations	0	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	General Comments		
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Patrol Inspection	General Comments		
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Follow-up Action Required?	n	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Fault Operations Ground	0	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Fault Operations C Ø	0	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Fault Operations B Ø	0	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Fault Operations A Ø	0	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Amps C Ø	2.0	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Amps B Ø	2.0	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Amps A Ø	3.0	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	BK000563	BreakerVacuum	LY-LS 12KV BUS TIE	VCB Readings	9 Month Operations	1	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Operations Counter	76	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	General Comments		
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	General Comments		
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	ST000372	Structure	891-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	RG000063	Regulator	701-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	BAT000212	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	BAT000212	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	BAT000212	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	BAT000212	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	BAT000212	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Patrol Inspection	General Comments		
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	General Comments	BU relay Trip	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Maintenance Operations	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Operations Counter AF	174	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Operations Counter AL	174	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Operations This Read Vac	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Switching Operations	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Unknown Operations	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	Oil Temp Present	45	°C
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	Oil Temp Max	50	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1675	psi
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	40	°C
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	45	°C
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	General Comments		
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	Oil Temp Present	36	°C
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	Oil Temp Max	47	°C
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	800	psi
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	4.0	psi
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	LTC Totalizer Reading	12847.32	kw
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	BAT000212	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	BAT000212	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Battery Load Check OK?	n	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Amps C Ø	35.0	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Amps B Ø	35.0	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	RC000515	RecloserElectronic	891-0718	Recloser Electronic Patrol Inspection	Amps A Ø	30.0	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Counter Readings	LTC Operations Since Last Insp	5345	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	33	°C
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	42	°C
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Counter Readings	LTC Min Tap Position	6L	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Counter Readings	LTC Current Tap Position	5L	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Counter Readings	LTC As Left Counter	116790	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Counter Readings	LTC As Found Counter	116783	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Mechanism Patrol Inspection	General Comments		
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Counter Readings	General Comments		
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	9 Month Operations	1	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Amps A Ø	615.0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Amps B Ø	575.0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Amps C Ø	545.0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1252	BreakerVacuum	BY-12KV TR 2	VCB Readings	Fault Operations Ground	0	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	LTCM000053	LTCMechanism	609-2	LTC Counter Readings	Follow-up Action Required?	n	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	40	°C
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	55	°C
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	35	°C
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	60	°C
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	35	°C
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	50	°C
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	WithLTC	BY-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	Winding Temp Present	38	°C
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	Winding Temp Max	47	°C
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	Totalizer Meter Reading	.8430	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	TX000120	WithLTC	609-2	LTC Transformer Readings	Totalizer Meter Multiplier	15240	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	BAT000212	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	BAT000212	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	72	°F
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Grounds in Place?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Maintenance Operations	0	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Operations Counter AF	229	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Operations Counter AL	229	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Operations This Read Vac	0	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Switching Operations	0	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Unknown Operations	0	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	General Comments	A-50,B-56, C-53 counters	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	9 Month Operations	9	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9720	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1600	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Amps A Ø	130.0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Amps B Ø	130.0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Amps C Ø	140.0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Fault Operations A Ø	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Fault Operations B Ø	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Fault Operations C Ø	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Fault Operations Ground	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Readings	Oil Temp Max	54	°C
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	27.50	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1555.20	kw
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Patrol Inspection	Bushing Condition	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Amps C Ø	86.0	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Amps B Ø	94.0	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Amps A Ø	86.0	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000547	BreakerVacuum	724-2533	VCB Readings	9 Month Operations	2	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	LTCC000870	LTCControl	838-2	LTC Control Insp	All Connections OK?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	LTCC000870	LTCControl	838-2	LTC Control Insp	Follow-up Action Required?	n	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	LTCC000870	LTCControl	838-2	LTC Control Insp	General Comments		
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	LTCC000870	LTCControl	838-2	LTC Control Insp	LTC Operation Checked?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	LTCC000870	LTCControl	838-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	LTCC000870	LTCControl	838-2	LTC Control Insp	Parallel / Ind. Sw Position	parallellIND	Position
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	LTCC000870	LTCControl	838-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	LTCC000870	LTCControl	838-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	LTCC000870	LTCControl	838-2	LTC Control Insp	VRR Time Delay	30	Seconds
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	9 Month Operations	2	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Accumulated Fault Duty B Ph V	.47	%
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Amps A Ø	103.0	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Amps B Ø	58.0	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Amps C Ø	62.0	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Bushing Condition	Good	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Regulator As Left Counter	100272	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.8	volts
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Fault Operations A Ø	0	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Fault Operations B Ø	0	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Fault Operations C Ø	0	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Fault Operations Ground	0	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	Follow-up Action Required?	n	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	Foundation Condition	Good	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Patrol Inspection	General Comments		
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0001	BreakerVacuum	639-0160	VCB Readings	General Comments		
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Max Tap Position	6R	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	General Comments		
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0520	Regulator	702-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Counter Readings	Follow-up Action Required?	n	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Counter Readings	General Comments		
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Mechanism Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Counter Readings	LTC As Found Counter	90086	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Counter Readings	LTC As Left Counter	90091	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Counter Readings	LTC Current Tap Position	5L	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Counter Readings	LTC Max Tap Position	5L	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Counter Readings	LTC Min Tap Position	8L	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Counter Readings	LTC Operations Since Last Insp	519	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	C0528	LTCMechanism	588-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Fault Operations B Ø	0	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Fault Operations C Ø	0	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Fault Operations Ground	0	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Unknown Operations	0	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Switching Operations	0	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Operations This Read Vac	0	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Operations Counter AL	222	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Operations Counter AF	222	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Maintenance Operations	0	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Grounds in Place?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	General Comments		
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	General Comments		
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Foundation Condition	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Follow-up Action Required?	n	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Fault Operations Ground	0	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Fault Operations C Ø	0	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Fault Operations B Ø	0	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Fault Operations A Ø	0	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Patrol Inspection	Bushing Condition	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Amps C Ø	275.0	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Amps B Ø	288.0	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Amps A Ø	297.0	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	KB0003	BreakerVacuum	724-1	VCB Readings	9 Month Operations	1	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Follow-up Action Required?	n	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Foundation Condition	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	General Comments		
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Readings	General Comments		
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	General Comments		
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	W0179	NonLTC	702-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Follow-up Action Required?	n	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Patrol Inspection	General Comments		
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	General Comments		
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Maintenance Operations	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Operations Counter AF	34	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Operations Counter AL	34	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Operations This Read Vac	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Switching Operations	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0079	BreakerVacuum	BY-1285	VCB Readings	Unknown Operations	0	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Amps A Ø	102.0	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Amps B Ø	125.0	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Amps C Ø	97.0	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Tank Leaks	None	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Regulator As Left Counter	36652	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Min Tap Position	6L	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Max Tap Position	3L	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	General Comments		
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Current Tap Position	5L	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	R0748	Regulator	012-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Bushing Condition	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Fault Operations A Ø	0	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	9 Month Operations	2	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Unknown Operations	0	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Switching Operations	1	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Operations This Read Vac	1	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Operations Counter AL	169	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Operations Counter AF	169	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Maintenance Operations	0	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	General Comments		
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	General Comments		
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Readings	General Comments		
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	General Comments	needs nitro, TR@0 and bottle @0	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Readings	Oil Temp Max	70	°C
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Readings	Oil Temp Present	45	°C
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	85.00	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	110	°C
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LT0105	WithLTC	LY-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	45	°C
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	9 Month Operations	3	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	K0010	BreakerVacuum	588-2526	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Amps B Ø	80.0	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Amps C Ø	83.0	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/5/2020 9:31	Distribution	Corydon Quarterly Inspection	RC000444	RecloserElectronic	012-1431	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000549	BreakerVacuum	724-BT1-2	VCB Readings	Follow-up Action Required?	n	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	General Comments		
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Max Tap Position	1R	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Min Tap Position	2L	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	124	volts
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Regulator As Left Counter	5455	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Tank Leaks	None	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	LR0019	Regulator	029-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	General Comments		
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	ST000420	Structure	609-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Readings	Oil Temp Max	80	°C
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Readings	Oil Temp Present	35	°C
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Fault Operations A Ø	0	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Patrol Inspection	Bushing Condition	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Amps C Ø	259.0	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Amps B Ø	257.0	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000550	BreakerVacuum	724-2	VCB Readings	Amps A Ø	243.0	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	C0480	WithLTC	198-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	General Comments		
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	Vegetation	None	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	YD000334	Yard	639-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	240	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BCH001272	Charger	653-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.9	VDC
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BCH001272	Charger	653-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.9	VDC
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BCH001272	Charger	653-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BCH001272	Charger	653-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BCH001272	Charger	653-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	240	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations This Read Vac	2	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	0	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	General Comments		
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	Negative DC Ground	12.8	VDC
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	CB0164	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	2	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	Positive DC Ground	12.8	VDC
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BAT001357	Battery	653-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Unknown Operations	1	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Switching Operations	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Operations This Read Vac	1	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Operations Counter AL	246	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Operations Counter AF	246	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Maintenance Operations	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	General Comments		
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Readings	Totalizer Meter Reading	.8862	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	LTCC000827	LTCControl	496-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	LTCC000827	LTCControl	496-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	LTCC000827	LTCControl	496-1	LTC Control Insp	LTC Operation Checked?	y	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	LTCC000827	LTCControl	496-1	LTC Control Insp	General Comments		
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	LTCC000827	LTCControl	496-1	LTC Control Insp	Follow-up Action Required?	n	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	LTCC000827	LTCControl	496-1	LTC Control Insp	All Connections OK?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Bushing Condition	Good	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Amps C Ø	31.0	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Amps B Ø	44.0	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Amps A Ø	42.0	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	LTCC000129	LTCControl	588-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	LTCC000129	LTCControl	588-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	LTCC000129	LTCControl	588-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	9 Month Operations	2	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	LTCC000129	LTCControl	588-1	LTC Control Insp	LTC Output Voltage Level	123.4	VAC
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	LTCC000129	LTCControl	588-1	LTC Control Insp	LTC Operation Checked?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	LTCC000129	LTCControl	588-1	LTC Control Insp	General Comments		
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	LTCC000129	LTCControl	588-1	LTC Control Insp	Follow-up Action Required?	n	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	LTCC000129	LTCControl	588-1	LTC Control Insp	All Connections OK?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Unknown Operations	0	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Switching Operations	0	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Operations This Read Vac	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Maintenance Operations	0	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Grounds in Place?	y	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	General Comments		
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	General Comments		
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Foundation Condition	Good	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Follow-up Action Required?	n	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Fault Operations Ground	0	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Fault Operations C Ø	0	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Fault Operations B Ø	0	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Fault Operations A Ø	0	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Patrol Inspection	Bushing Condition	Good	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Amps C Ø	46.0	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Amps B Ø	29.0	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Amps A Ø	29.0	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BK000896	BreakerVacuum	653-0816	VCB Readings	9 Month Operations	4	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Readings	Oil Temp Present	40	°C
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Readings	Oil Temp Max	50	°C
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Patrol Inspection	General Comments		
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Readings	LTC Totalizer Reading	8507.52	kw
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Readings	General Comments		
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	General Comments		
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	M0068	WithLTC	609-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Follow-up Action Required?	n	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Fault Operations Ground	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Fault Operations C Ø	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Fault Operations B Ø	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Fault Operations A Ø	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Amps C Ø	0.0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Amps B Ø	0.0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Amps A Ø	0.0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0513	BreakerVacuum	IN-1298	VCB Readings	9 Month Operations	1	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	30	°C
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	75	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	30	°C
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	70	°C
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	30	°C
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	45	°C
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Amps B Ø	28.0	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Amps A Ø	22.0	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	BK000904	BreakerVacuum	514-1764	VCB Readings	9 Month Operations	4	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Unknown Operations	0	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Switching Operations	0	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Operations This Read Vac	0	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Operations Counter AL	191	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Operations Counter AF	191	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Maintenance Operations	0	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Patrol Inspection	Grounds in Place?	y	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	General Comments		
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Patrol Inspection	General Comments		
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Patrol Inspection	Foundation Condition	Good	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	BK000897	BreakerVacuum	653-0815	VCB Readings	Follow-up Action Required?	n	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Readings	General Comments		
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	General Comments		
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Counter Readings	Follow-up Action Required?	n	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Counter Readings	General Comments		
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Mechanism Patrol Inspection	General Comments		
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Counter Readings	LTC As Found Counter	99592	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Counter Readings	LTC As Left Counter	99597	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Counter Readings	LTC Current Tap Position	9L	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Counter Readings	LTC Max Tap Position	5R	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Counter Readings	LTC Min Tap Position	12L	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Counter Readings	LTC Operations Since Last Insp	683	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	S0036	LTCMechanism	653-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Ambient Temp	52	°F
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Counter Readings	General Comments		
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Counter Readings	LTC As Found Counter	6949	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Counter Readings	LTC As Left Counter	6949	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Counter Readings	LTC Current Tap Position	13L	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Counter Readings	LTC Max Tap Position	3L	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	General Comments		
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Vegetation	None	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	YD000260	Yard	702-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Counter Readings	LTC Min Tap Position	16L	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1067	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LT0105	LTCMechanism	LY-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	Ambient Temp	58	*F
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Counter Readings	LTC Operations Since Last Insp	88	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Counter Readings	LTC Min Tap Position	4L	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Counter Readings	LTC Max Tap Position	3L	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Counter Readings	LTC Current Tap Position	3L	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Counter Readings	LTC As Left Counter	1885	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Counter Readings	LTC As Found Counter	1883	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Mechanism Patrol Inspection	General Comments		
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	LTCM000095	LTCMechanism	473-1	LTC Counter Readings	Follow-up Action Required?	n	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	LTCC000833	LTCControl	473-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	LTCC000833	LTCControl	473-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	LTCC000833	LTCControl	473-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	LTC Totalizer Reading	2304.54	kw
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	General Comments		
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	General Comments		
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	LTCC000833	LTCControl	473-1	LTC Control Insp	LTC Output Voltage Level	124.6	VAC
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	LTCC000833	LTCControl	473-1	LTC Control Insp	LTC Operation Checked?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	LTCC000833	LTCControl	473-1	LTC Control Insp	General Comments		
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	LTCC000833	LTCControl	473-1	LTC Control Insp	Follow-up Action Required?	n	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	LTCC000833	LTCControl	473-1	LTC Control Insp	All Connections OK?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Readings	Winding Temp Present	30	°C
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Readings	Winding Temp Max	30	°C
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Readings	Totalizer Meter Reading	.5568	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Readings	Oil Temp Present	30	°C
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Readings	Oil Temp Max	30	°C
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	TX000237	WithLTC	473-1	LTC Transformer Readings	LTC Totalizer Reading	5345.28	kw
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Maintenance Operations	0	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Grounds in Place?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	General Comments		
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	General Comments		
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Foundation Condition	Good	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Follow-up Action Required?	n	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Fault Operations Ground	0	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Fault Operations C Ø	0	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Fault Operations B Ø	0	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Fault Operations A Ø	0	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	General Comments		
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	FE000386	Fence	701-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	General Comments		
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	ST000481	Structure	724-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	LTCC000827	LTCControl	496-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	LTCC000133	LTCControl	198-5	LTC Control Insp	VRR Time Delay	30	Seconds
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	LTCC000133	LTCControl	198-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	LTCC000133	LTCControl	198-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	LTCC000133	LTCControl	198-5	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	LTCC000133	LTCControl	198-5	LTC Control Insp	LTC Operation Checked?	y	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	LTCC000133	LTCControl	198-5	LTC Control Insp	General Comments		
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	LTCC000133	LTCControl	198-5	LTC Control Insp	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	LTCC000133	LTCControl	198-5	LTC Control Insp	All Connections OK?	y	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	LTCC000827	LTCControl	496-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	General Comments		
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	ST000267	Structure	702-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Unknown Operations	0	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Switching Operations	0	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Operations This Read Vac	0	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Operations Counter AL	187	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Readings	Operations Counter AF	187	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BK000906	BreakerVacuum	005-1477	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	General Comments		
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	FE000257	Fence	702-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Ambient Temp	65	*F
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	General Comments		
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Vegetation	None	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	YD000479	Yard	724-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	FE000423	Fence	724-Fence	Fence Patrol Inspection	General Comments		
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Readings	Totalizer Meter Reading	.3534	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Readings	Oil Temp Present	40	°C
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Readings	Oil Temp Max	40	°C
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Unknown Operations	0	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	General Comments		
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Readings	LTC Totalizer Reading	1696.32	kw
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Readings	General Comments		
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	General Comments		
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	C0510	WithLTC	496-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Counter Readings	LTC Operations Since Last Insp	1076	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Counter Readings	LTC Min Tap Position	10L	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Counter Readings	LTC Max Tap Position	3L	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Counter Readings	LTC Current Tap Position	8L	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Counter Readings	LTC As Left Counter	208070	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Counter Readings	LTC As Found Counter	208070	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Mechanism Patrol Inspection	General Comments		
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Fault Operations C Ø	2	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Fault Operations Ground	0	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Follow-up Action Required?	n	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Foundation Condition	Good	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	General Comments		
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	General Comments	C-G ops 11-05/10-23	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Grounds in Place?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	General Comments		
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Vegetation	None	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	YD000344	Yard	655-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Maintenance Operations	0	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Operations Counter AF	196	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Operations Counter AL	196	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Operations This Read Vac	2	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Switching Operations	0	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Readings	Oil Temp Present	35	°C
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Readings	Oil Temp Max	40	°C
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Readings	General Comments		
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	General Comments		
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0177	NonLTC	891-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Follow-up Action Required?	n	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Patrol Inspection	Foundation Condition	Good	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Patrol Inspection	General Comments		
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	General Comments		
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Patrol Inspection	Grounds in Place?	y	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Maintenance Operations	0	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Operations Counter AF	137	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Operations Counter AL	137	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Operations This Read Vac	0	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Switching Operations	0	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Unknown Operations	0	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	BCH001283	Charger	655-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	BCH001283	Charger	655-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	BCH001283	Charger	655-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	BCH001283	Charger	655-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	BCH001283	Charger	655-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	BCH001283	Charger	655-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	BCH001283	Charger	655-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	BCH001283	Charger	655-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	BAT001369	Battery	655-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	BAT001369	Battery	655-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	55	*F
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	General Comments		
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	ST000238	Structure	457-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Vegetation	None	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	General Comments		
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	YD000231	Yard	457-Yard	Yard Patrol Inspection	Ambient Temp	56	*F
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	General Comments		
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	ST000347	Structure	655-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Counter Readings	General Comments		
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Counter Readings	Follow-up Action Required?	n	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	9 Month Operations	0	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	9 Month Operations	1	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Amps A Ø	227.0	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Amps B Ø	260.0	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Amps C Ø	237.0	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Patrol Inspection	Bushing Condition	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Panels Dusted?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	HVAC Filter Replaced?	n	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	General Comments		
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Amps A Ø	190.0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Amps B Ø	201.0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Amps C Ø	190.0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Floor Swept?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Fault Operations A Ø	0	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Fault Operations B Ø	0	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Fault Operations C Ø	0	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001265	BreakerVacuum	198-5	VCB Readings	Fault Operations Ground	0	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Filters Condition OK?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Vegetation	None	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	General Comments		
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	YD000383	Yard	473-Yard	Yard Patrol Inspection	Ambient Temp	65	*F
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Broom on Site?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	CH000425	ControlHouse	724-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	General Comments		
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	FE000144	Fence	514-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	General Comments		
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	ST000147	Structure	514-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	BAT001272	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	BAT001272	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	68	°F
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	BAT001272	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	BAT001272	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	BAT001272	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	BAT001272	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	BAT001272	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	BAT001272	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	General Comments		
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	FE000340	Fence	655-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	Oil Temp Max	30	°C
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	General Comments		
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0098	WithLTC	IN-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	25	°C
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	46	°C
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	25	°C
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	46	°C
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	25	°C
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	46	°C
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	40.00	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	Oil Temp Present	25	°C
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	Oil Temp Max	46	°C
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	200	psi
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Readings	General Comments		
11/5/2020 13:00	Distribution	International Quarterly Inspection	LT0097	WithLTC	IN-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Ambient Temp	62	°F
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	General Comments		
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Vegetation	None	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	General Comments		
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Readings	Totalizer Meter Reading	.5130	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Readings	Oil Temp Present	22	°C
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Readings	Oil Temp Max	34	°C
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Readings	LTC Totalizer Reading	2462.40	kw
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Readings	General Comments		
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	General Comments		
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	W0299	WithLTC	655-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	BAT001272	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	BAT001272	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	BAT001272	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	BAT001272	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	9 Month Operations	4	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Amps A Ø	56.0	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Amps B Ø	59.0	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Amps C Ø	73.0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
11/5/2020 13:00	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/5/2020 13:00	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 13:00	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
11/5/2020 13:00	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	SWG000191	Switchgear	IN-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Trash Emptied?	n	
11/5/2020 13:00	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Panels Dusted?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	General Comments		
11/5/2020 13:00	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/5/2020 13:00	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 13:00	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Bushing Condition	Good	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Fault Adjusted Amps C Phase V	10.92	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Fault Operations A Ø	0	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	KB0113	BreakerVacuum	005-1476	VCB Readings	Fault Operations B Ø	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/5/2020 13:00	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Broom on Site?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 13:00	Distribution	International Quarterly Inspection	CH000188	ControlHouse	IN-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	General Comments		
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	FE000396	Fence	772-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Follow-up Action Required?	n	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Patrol Inspection	Foundation Condition	Good	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Patrol Inspection	General Comments		
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	General Comments		
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Patrol Inspection	Grounds in Place?	y	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Maintenance Operations	0	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Operations Counter AF	176	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Operations Counter AL	176	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Operations This Read Vac	0	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Switching Operations	0	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
11/5/2020 13:00	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Fault Operations Ground	0	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Fault Operations C Ø	0	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Fault Operations B Ø	0	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	LTCC000165	LTCControl	609-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	LTCC000165	LTCControl	609-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	LTCC000165	LTCControl	609-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	LTCC000165	LTCControl	609-1	LTC Control Insp	Parallel / Ind. Sw Position	parallellIND	Position
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	LTCC000165	LTCControl	609-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	LTCC000165	LTCControl	609-1	LTC Control Insp	LTC Operation Checked?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	LTCC000165	LTCControl	609-1	LTC Control Insp	General Comments		
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	LTCC000165	LTCControl	609-1	LTC Control Insp	Follow-up Action Required?	n	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	LTCC000165	LTCControl	609-1	LTC Control Insp	All Connections OK?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	9 Month Operations	15	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1256	BreakerVacuum	BY-1278	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Unknown Operations	0	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	9 Month Operations	3	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Amps A Ø	211.0	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Amps B Ø	223.0	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Readings	Amps C Ø	197.0	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Patrol Inspection	Bushing Condition	Good	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	General Comments		
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Min Tap Position	4L	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.8	volts
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Regulator As Left Counter	126680	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	R0521	Regulator	702-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001164	BreakerVacuum	838-0507	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	General Comments		
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Fault Operations A Ø	0	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Fault Operations B Ø	0	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Fault Operations C Ø	0	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Fault Operations Ground	0	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Follow-up Action Required?	n	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Patrol Inspection	Foundation Condition	Good	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Patrol Inspection	General Comments		
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	General Comments		
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Patrol Inspection	Grounds in Place?	y	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Maintenance Operations	0	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Operations Counter AF	166	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Operations Counter AL	166	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Operations This Read Vac	0	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Switching Operations	0	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Unknown Operations	0	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	9 Month Operations	1	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Amps A Ø	62.0	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Amps B Ø	48.0	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Amps C Ø	51.0	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Patrol Inspection	Bushing Condition	Good	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	Ambient Temp	70	*F
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	General Comments		
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	Vegetation	None	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	YD000197	Yard	496-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Fault Operations A Ø	0	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Fault Operations B Ø	0	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Fault Operations C Ø	0	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Readings	Fault Operations Ground	0	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001163	BreakerVacuum	198-2521	VCB Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Unknown Operations	0	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Switching Operations	0	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Operations This Read Vac	0	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Operations Counter AL	171	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Operations Counter AF	171	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000193	Switchgear	BY-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Maintenance Operations	0	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Patrol Inspection	Grounds in Place?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	General Comments		
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Patrol Inspection	General Comments		
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Patrol Inspection	Foundation Condition	Good	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Follow-up Action Required?	n	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Fault Operations Ground	0	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Fault Operations C Ø	0	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Fault Operations B Ø	0	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Fault Operations A Ø	0	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Patrol Inspection	Bushing Condition	Good	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	General Comments		
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Broom on Site?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Panels Dusted?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Trash Emptied?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	CH000169	ControlHouse	BY-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	SWG000052	Switchgear	BY-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Patrol Inspection	Bushing Condition	Good	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Amps C Ø	25.0	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Amps B Ø	29.0	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Amps A Ø	25.0	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001162	BreakerVacuum	198-2520	VCB Readings	9 Month Operations	1	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Unknown Operations	0	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Switching Operations	0	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Operations This Read Vac	0	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Operations Counter AL	154	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Operations Counter AF	154	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Maintenance Operations	0	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Patrol Inspection	Grounds in Place?	y	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	General Comments		
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Patrol Inspection	General Comments		
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Patrol Inspection	Foundation Condition	Good	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Follow-up Action Required?	n	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Fault Operations Ground	0	
11/5/2020 12:07	Distribution	Shelbyville Quarterly Inspection	BK001161	BreakerVacuum	198-2519	VCB Readings	Fault Operations C Ø	0	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Readings	General Comments		
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	General Comments	One fan not working. Sudden pressure seeping due to high oil level.	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Readings	LTC Totalizer Reading	18489.60	kw
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Readings	Oil Temp Max	45	°C
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Readings	Oil Temp Present	40	°C
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	9 Month Operations	2	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Unknown Operations	0	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Switching Operations	1	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Tank Leaks	Seeping	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Readings	Totalizer Meter Reading	1.2840	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Readings	Winding Temp Max	58	°C
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Readings	Winding Temp Present	52	°C
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Operations This Read Vac	1	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Operations Counter AL	179	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Operations Counter AF	179	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Maintenance Operations	0	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Patrol Inspection	Grounds in Place?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	General Comments		
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Patrol Inspection	General Comments		
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Patrol Inspection	Foundation Condition	Good	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Readings	Follow-up Action Required?	n	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001155	BreakerVacuum	838-0509	VCB Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 13:00	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	n	
11/5/2020 13:00	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	General Comments	hold card on breaker	
11/5/2020 13:00	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/5/2020 13:00	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	SWG000054	Switchgear	IN-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	FE000328	Fence	639-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Amps C Ø	146.0	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Amps B Ø	198.0	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Amps A Ø	147.0	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001158	BreakerVacuum	639-2515	VCB Readings	9 Month Operations	3	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Unknown Operations	0	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Switching Operations	0	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Operations This Read Vac	0	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Operations Counter AL	182	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Operations Counter AF	182	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Maintenance Operations	0	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Patrol Inspection	Grounds in Place?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	General Comments		
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Patrol Inspection	General Comments		
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Patrol Inspection	Foundation Condition	Good	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Follow-up Action Required?	n	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Fault Operations Ground	0	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Fault Operations C Ø	0	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Fault Operations B Ø	0	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Fault Operations A Ø	0	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Patrol Inspection	Bushing Condition	Good	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Amps C Ø	186.0	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Amps B Ø	153.0	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Amps A Ø	136.0	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001157	BreakerVacuum	639-2516	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	All Identified and Legible?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	General Comments		
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	ST000337	Structure	639-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0371	WithLTC	838-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	7L	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	3L	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	General Comments		
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	6L	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C ∅	0	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B ∅	0	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A ∅	0	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	n	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	General Comments	Main Entrance has deep potholes	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Vegetation	None	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	Follow-up Action Required?	n	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	General Comments		
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Mechanism Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	LTC As Found Counter	272943	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	LTC As Left Counter	272940	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	LTC Current Tap Position	7L	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	LTC Max Tap Position	6L	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	LTC Min Tap Position	9L	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	LTC Operations Since Last Insp	573	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	240.0	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Vegetation	None	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Amps A Ø	104.0	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Amps B Ø	88.0	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Amps C Ø	66.0	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Bushing Condition	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Fault Operations A Ø	0	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Fault Operations B Ø	0	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Fault Operations C Ø	0	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Fault Operations Ground	0	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Follow-up Action Required?	n	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Foundation Condition	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	General Comments		
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	General Comments		
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Grounds in Place?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Maintenance Operations	0	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Operations Counter AF	70	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Operations Counter AL	70	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Operations This Read Vac	0	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Switching Operations	0	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	Unknown Operations	0	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	113162	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	714	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	714	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	R1084	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Accumulated Fault Duty A Ph V	.5	%
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	9 Month Operations	2	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	110.00	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	Totalizer Meter Reading	1.2803	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	Totalizer Meter Multiplier	1800	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	General Comments		
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	ST000305	Structure	400-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	Vegetation	None	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Counter Readings	Follow-up Action Required?	n	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Counter Readings	General Comments		
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Mechanism Patrol Inspection	General Comments		
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Counter Readings	LTC As Found Counter	72046	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Counter Readings	LTC As Left Counter	72051	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Counter Readings	LTC Current Tap Position	6L	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	Oil Temp Present	25	°C
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	Oil Temp Max	40	°C
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Counter Readings	LTC Max Tap Position	3L	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Counter Readings	LTC Min Tap Position	8L	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Counter Readings	LTC Operations Since Last Insp	439	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	B0382	LTCMechanism	724-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	General Comments		
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	YD000297	Yard	400-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	General Comments		
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Panels Dusted?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	General Comments		
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	YD000390	Yard	701-Yard	Yard Patrol Inspection	Ambient Temp	59	*F
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	240.0	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	230.0	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	CB0148	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	LTCC000836	LTCControl	639-1	LTC Control Insp	All Connections OK?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	LTCC000836	LTCControl	639-1	LTC Control Insp	Follow-up Action Required?	n	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	LTCC000836	LTCControl	639-1	LTC Control Insp	General Comments		
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	LTCC000836	LTCControl	639-1	LTC Control Insp	LTC Operation Checked?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	B0273	LTCMechanism	588-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	LTCC000836	LTCControl	639-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	LTCC000836	LTCControl	639-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	LTCC000836	LTCControl	639-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	LTCC000836	LTCControl	639-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	CH000069	ControlHouse	005-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	FE000364	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	SWG000047	Switchgear	LY-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Current Tap Position	3R	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	84223	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	7L	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	3L	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	General Comments		
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	6L	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	R0924	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	General Comments		
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	FE000414	Fence	609-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 13:00	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	General Comments		
11/5/2020 13:00	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
11/5/2020 13:00	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Vegetation	None	
11/5/2020 13:00	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Unknown Operations	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Switching Operations	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Operations This Read Vac	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Operations Counter AL	159	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Operations Counter AF	159	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Maintenance Operations	0	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BK001152	BreakerVacuum	639-2518	VCB Readings	9 Month Operations	3	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	FE000206	Fence	005-Fence	Fence Patrol Inspection	General Comments		
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Unknown Operations	0	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Switching Operations	0	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Operations This Read Vac	0	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Operations Counter AL	172	
11/5/2020 13:00	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 13:00	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 13:00	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	General Comments		
11/5/2020 13:00	Distribution	International Quarterly Inspection	FE000647	Fence	IN-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Ambient Temp	67	*F
11/5/2020 13:00	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Tank Leaks	None	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Regulator As Left Counter	149888	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	124	volts
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Min Tap Position	1L	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Max Tap Position	3R	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	General Comments		
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Current Tap Position	Neutral	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	R0813	Regulator	029-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Tank Leaks	None	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Regulator As Left Counter	132234	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	124	volts
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Min Tap Position	1R	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Max Tap Position	3R	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	General Comments		
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	R0787	Regulator	029-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	General Comments		
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Vegetation	None	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Bushing Condition	Good	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Amps C Ø	180.0	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	LTCC000071	LTCControl	838-1	LTC Control Insp	All Connections OK?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	LTCC000071	LTCControl	838-1	LTC Control Insp	Follow-up Action Required?	n	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	LTCC000071	LTCControl	838-1	LTC Control Insp	General Comments		
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	LTCC000071	LTCControl	838-1	LTC Control Insp	LTC Operation Checked?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	LTCC000071	LTCControl	838-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	LTCC000071	LTCControl	838-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	LTCC000071	LTCControl	838-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	LTCC000071	LTCControl	838-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Amps B Ø	181.0	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Amps A Ø	186.0	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	LTCC000071	LTCControl	838-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Counter Readings	Follow-up Action Required?	n	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Counter Readings	General Comments		
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Mechanism Patrol Inspection	General Comments		
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Counter Readings	LTC As Found Counter	97853	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Counter Readings	LTC As Left Counter	97853	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Counter Readings	LTC Current Tap Position	4L	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Ambient Temp	69	*F
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	9 Month Operations	2	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Amps A Ø	156.0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Amps B Ø	158.0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Amps C Ø	152.0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Fault Operations A Ø	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Fault Operations B Ø	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Fault Operations C Ø	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Fault Operations Ground	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Follow-up Action Required?	n	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Patrol Inspection	General Comments		
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	General Comments		
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Maintenance Operations	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Operations Counter AF	156	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Operations Counter AL	156	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Operations This Read Vac	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Switching Operations	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0510	BreakerVacuum	IN-1295	VCB Readings	Unknown Operations	0	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	YD000204	Yard	005-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Counter Readings	LTC Max Tap Position	16L	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Counter Readings	LTC Min Tap Position	6L	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Counter Readings	LTC Operations Since Last Insp	452	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0439	LTCMechanism	838-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	CB0279	BreakerVacuum	588-2534	VCB Readings	9 Month Operations	1	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	General Comments		
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Patrol Inspection	General Comments		
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Fault Operations Ground	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Amps C Ø	153.0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Amps B Ø	156.0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	YD000652	Yard	IN-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 13:00	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	General Comments		
11/5/2020 13:00	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 13:00	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/5/2020 13:00	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	ST000631	Structure	IN-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Operations Counter AF	172	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Maintenance Operations	0	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Amps A Ø	155.0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0518	BreakerVacuum	IN-12KV TR 2	VCB Readings	9 Month Operations	2	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Grounds in Place?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	General Comments		
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	General Comments		
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Foundation Condition	Good	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Follow-up Action Required?	n	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Fault Operations Ground	0	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Fault Operations C Ø	0	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Fault Operations B Ø	0	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Fault Operations A Ø	0	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	K0200	BreakerVacuum	639-2517	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Ambient Temp	64	*F
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	YD000370	Yard	891-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	9 Month Operations	0	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Amps A Ø	428.0	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Amps B Ø	460.0	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Amps C Ø	424.0	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Patrol Inspection	Bushing Condition	Good	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	General Comments		
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	R1295	Regulator	457-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	PF000193	PowerFuse	IN-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/5/2020 13:00	Distribution	International Quarterly Inspection	PF000193	PowerFuse	IN-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments)	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	9 Month Operations	3	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Amps A Ø	70.0	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Amps B Ø	70.0	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Amps C Ø	60.0	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Patrol Inspection	Bushing Condition	Good	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Amps C Ø	340.0	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Amps B Ø	360.0	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Amps A Ø	320.0	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	9 Month Operations	0	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Operations Counter AF	215	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Maintenance Operations	0	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Grounds in Place?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Readings	Totalizer Meter Reading	.4542	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	PF000197	PowerFuse	LY-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	PF000197	PowerFuse	LY-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	PF000198	PowerFuse	LY-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	PF000198	PowerFuse	LY-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	General Comments		
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	General Comments		
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Foundation Condition	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Follow-up Action Required?	n	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Fault Operations Ground	0	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Fault Operations C Ø	0	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Fault Operations B Ø	0	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Fault Operations A Ø	0	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Bushing Condition	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Amps C Ø	85.0	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Amps B Ø	98.0	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Amps A Ø	114.0	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	9 Month Operations	3	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Unknown Operations	0	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Switching Operations	1	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Operations This Read Vac	1	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Operations Counter AL	194	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Operations Counter AF	194	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Maintenance Operations	0	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Grounds in Place?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	General Comments		
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Fault Operations A Ø	0	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Fault Operations Ground	0	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Follow-up Action Required?	n	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Patrol Inspection	Foundation Condition	Good	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Patrol Inspection	General Comments		
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	General Comments		
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Patrol Inspection	Grounds in Place?	y	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Maintenance Operations	0	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Operations Counter AF	232	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Operations Counter AL	232	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Operations This Read Vac	0	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Switching Operations	0	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	BK001052	BreakerVacuum	655-0703	VCB Readings	Unknown Operations	0	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Fault Operations B Ø	0	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Fault Operations C Ø	0	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Fault Operations Ground	0	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Follow-up Action Required?	n	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Patrol Inspection	Foundation Condition	Good	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Patrol Inspection	General Comments		
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	General Comments		
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	Winding Temp Present	35	°C
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	Winding Temp Max	40	°C
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	Totalizer Meter Reading	.4280	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Unknown Operations	0	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Switching Operations	1	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Operations This Read Vac	1	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000718	BreakerVacuum	724-2542	VCB Readings	Operations Counter AL	215	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	Oil Temp Present	40	°C
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	Oil Temp Max	45	°C
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	LTC Totalizer Reading	7704.00	kw
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	General Comments		
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	General Comments		
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	B0382	WithLTC	724-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Readings	General Comments		
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	General Comments		
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	Ambient Temp	64	°F
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	General Comments		
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	Vegetation	None	
11/5/2020 10:08	Distribution	Waverly Quarterly Inspection	YD000142	Yard	514-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BCH001305	Charger	639-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BCH001305	Charger	639-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	52.0	VDC
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BCH001305	Charger	639-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BCH001305	Charger	639-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.3	amps
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BCH001305	Charger	639-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BCH001305	Charger	639-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BCH001305	Charger	639-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BCH001305	Charger	639-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	General Comments		
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Unknown Operations	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Switching Operations	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Operations This Read Vac	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Operations Counter AL	199	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Operations Counter AF	199	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Maintenance Operations	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	General Comments		
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Patrol Inspection	General Comments		
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Follow-up Action Required?	n	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Fault Operations Ground	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Fault Operations C Ø	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Fault Operations B Ø	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Fault Operations A Ø	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Counter Readings	General Comments		
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Counter Readings	LTC As Found Counter	134771	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Counter Readings	LTC As Left Counter	134771	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6L	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Counter Readings	LTC Max Tap Position	3R	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Counter Readings	LTC Min Tap Position	10L	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	938	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LT0018	LTCMechanism	BY-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Amps C Ø	165.0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Amps B Ø	171.0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Amps A Ø	175.0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1254	BreakerVacuum	BY-1276	VCB Readings	9 Month Operations	1	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Readings	Totalizer Meter Reading	.516	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	4900	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Readings	Oil Temp Present	30	°C
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Readings	Oil Temp Max	50	°C
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	2528.4	kw
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	B0211	NonLTC	029-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	General Comments		
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Amps A Ø	64.0	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Amps B Ø	62.0	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Amps C Ø	60.0	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	General Comments		
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Operations Counter	314	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/5/2020 8:08	Distribution	Manitou Quarterly Inspection	KX0080	RecloserElectronic	702-1451	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	0	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations This Read Vac	1	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	618	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Unknown Operations	0	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	618	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Switching Operations	0	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Operations This Read Vac	0	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Operations Counter AL	99956	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Operations Counter AF	99956	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	PF000032	PowerFuse	BY-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	PF000032	PowerFuse	BY-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	PF000033	PowerFuse	BY-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	PF000033	PowerFuse	BY-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Readings	Maintenance Operations	0	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	CB0274	BreakerVacuum	588-2	VCB Patrol Inspection	Grounds in Place?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	K0102	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/5/2020 10:44	Distribution	Lawrence Quarterly Inspection	ST000393	Structure	701-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LTCC000020	LTCControl	LY-TRANS 2	LTC Control Insp	General Comments	ok	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LTCC000020	LTCControl	LY-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	General Comments	fence is only grounded in one spot on every side	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	FE000198	Fence	496-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	LTCC000801	LTCControl	655-1	LTC Control Insp	All Connections OK?	y	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	LTCC000801	LTCControl	655-1	LTC Control Insp	Follow-up Action Required?	n	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	LTCC000801	LTCControl	655-1	LTC Control Insp	General Comments		
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	LTCC000801	LTCControl	655-1	LTC Control Insp	LTC Operation Checked?	y	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	LTCC000801	LTCControl	655-1	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	LTCC000801	LTCControl	655-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	LTCC000801	LTCControl	655-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	LTCC000801	LTCControl	655-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	General Comments		
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	ST000204	Structure	496-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/5/2020 13:38	Distribution	Metal And Thermit Quarterly Inspection	ST000375	Structure	473-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	378	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments	High side fuse blown.	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	1	
11/5/2020 13:00	Distribution	International Quarterly Inspection	PF000175	PowerFuse	IN-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	10.52	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	130.0	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	180.0	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	130.0	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	5	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	BAT001400	Battery	496-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	BAT001400	Battery	496-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	LTCC000721	LTCControl	724-2	LTC Control Insp	VRR Time Delay	30	Seconds
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	LTCC000721	LTCControl	724-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	LTCC000721	LTCControl	724-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	LTCC000721	LTCControl	724-2	LTC Control Insp	LTC Output Voltage Level	123.8	VAC
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	LTCC000721	LTCControl	724-2	LTC Control Insp	LTC Operation Checked?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	LTCC000721	LTCControl	724-2	LTC Control Insp	General Comments		
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	LTCC000721	LTCControl	724-2	LTC Control Insp	Follow-up Action Required?	n	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	LTCC000721	LTCControl	724-2	LTC Control Insp	All Connections OK?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	General Comments		
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	FE000293	Fence	400-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	General Comments		
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Unknown Operations	0	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Counter Readings	LTC Operations Since Last Insp	471	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Counter Readings	LTC Min Tap Position	4L	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Counter Readings	LTC Max Tap Position	4R	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Counter Readings	LTC Current Tap Position	2L	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Counter Readings	LTC As Left Counter	73900	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Counter Readings	LTC As Found Counter	73900	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Mechanism Patrol Inspection	General Comments		
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Counter Readings	General Comments		
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	C0522	LTCMechanism	639-2	LTC Counter Readings	Follow-up Action Required?	n	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Unknown Operations	0	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Switching Operations	0	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Operations This Read AM	0	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Operations Counter AL	50	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Operations Counter AF	50	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Maintenance Operations	0	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	General Comments		
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Patrol Inspection	General Comments		
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Amps C Ø	340.0	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Amps B Ø	320.0	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Amps A Ø	320.0	
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/5/2020 18:11	Distribution	Lyndon Quarterly Inspection	LB0562	BreakerAirMagnetic	LY-12KV TR 2	AMCB Readings	9 Months Operations	0	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	BAT001400	Battery	496-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	BAT001400	Battery	496-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	*F
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	BAT001400	Battery	496-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	BAT001400	Battery	496-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/5/2020 13:00	Distribution	International Quarterly Inspection	PF000176	PowerFuse	IN-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/5/2020 13:00	Distribution	International Quarterly Inspection	PF000176	PowerFuse	IN-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	*	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	0	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations This Read Vac	1	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	K0101	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	378	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	Ambient Temp	68	*F
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	General Comments		
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	Gate Locks Functioning?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	FE000289	Fence	838-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	26	*C
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	32	*C
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Counter Readings	LTC Min Tap Position	8L	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	9 Month Operations	6	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Amps A Ø	78.0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Amps B Ø	77.0	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Counter Readings	LTC Max Tap Position	6L	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Counter Readings	LTC Current Tap Position	10L	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Counter Readings	LTC As Left Counter	14395	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Counter Readings	LTC As Found Counter	14387	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Mechanism Patrol Inspection	General Comments		
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Counter Readings	General Comments		
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Amps C Ø	71.0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Patrol Inspection	Bushing Condition	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Fault Adjusted Amps A Phase V	22.36	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Fault Adjusted Amps B Phase V	22.36	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Fault Adjusted Amps C Phase V	22.36	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Fault Operations A Ø	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Fault Operations B Ø	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Fault Operations C Ø	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Fault Operations Ground	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	Follow-up Action Required?	n	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Patrol Inspection	Foundation Condition	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Patrol Inspection	General Comments		
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Readings	General Comments		
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 13:00	Distribution	International Quarterly Inspection	BK001382	BreakerVacuum	IN-1290	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Counter Readings	Follow-up Action Required?	n	
11/5/2020 13:00	Distribution	International Quarterly Inspection	PF000175	PowerFuse	IN-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	P	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	BAT001400	Battery	496-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	BAT001400	Battery	496-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	BAT001400	Battery	496-Battery Bank	Battery Patrol Inspection	General Comments		
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	BAT001400	Battery	496-Battery Bank	Battery Patrol Inspection	Negative DC Ground	1.4	VDC
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	BAT001400	Battery	496-Battery Bank	Battery Patrol Inspection	Positive DC Ground	2.5	VDC
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	BAT001400	Battery	496-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/5/2020 6:40	Distribution	Camp Breckinridge Quarterly Inspection	BAT001400	Battery	496-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	BCH000109	Charger	BY-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	3.200	millivolts
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	BCH000109	Charger	BY-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	134.2	VDC
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	BCH000109	Charger	BY-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	134.2	VDC
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	BCH000109	Charger	BY-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.0	amps
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	BCH000109	Charger	BY-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	BCH000109	Charger	BY-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	BCH000109	Charger	BY-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	BCH000109	Charger	BY-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	LTCM000060	LTCMechanism	724-2	LTC Counter Readings	LTC Operations Since Last Insp	676	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	General Comments		
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	ST000300	Structure	838-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	Vegetation	None	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	General Comments		
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	YD000292	Yard	838-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Amps C ∅	0.0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	27.00	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	27.00	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	27.00	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A ∅	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B ∅	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C ∅	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	General Comments	Actual counter	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	198	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	198	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	1	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	1	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	LTCC000728	LTCControl	400-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	LTCC000728	LTCControl	400-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	LTCC000728	LTCControl	400-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	LTCC000728	LTCControl	400-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	LTCC000728	LTCControl	400-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	LTCC000728	LTCControl	400-1	LTC Control Insp	LTC Operation Checked?	y	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	LTCC000728	LTCControl	400-1	LTC Control Insp	General Comments		
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	LTCC000728	LTCControl	400-1	LTC Control Insp	Follow-up Action Required?	n	
11/5/2020 10:22	Distribution	Florida Tile Quarterly Inspection	LTCC000728	LTCControl	400-1	LTC Control Insp	All Connections OK?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	9 Month Operations	8	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Amps A Ø	426.0	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Amps B Ø	426.0	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Amps C Ø	439.0	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Bushing Condition	Good	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Fault Operations A Ø	0	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Fault Operations B Ø	0	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Fault Operations C Ø	0	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Fault Operations Ground	0	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Follow-up Action Required?	n	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Foundation Condition	Good	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	General Comments		
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Patrol Inspection	Grounds in Place?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	General Comments		
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Foundation Condition	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Follow-up Action Required?	n	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Fault Operations Ground	0	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Fault Operations C Ø	0	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Fault Operations B Ø	0	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Fault Operations A Ø	0	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Patrol Inspection	Bushing Condition	Good	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Amps C Ø	182.0	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Amps B Ø	184.0	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Amps A Ø	171.0	
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/5/2020 12:56	Distribution	Shelbyville East Quarterly Inspection	BK000717	BreakerVacuum	724-2523	VCB Readings	9 Month Operations	1	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Readings	Oil Temp Present	40	°C
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Readings	Oil Temp Max	40	°C
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Readings	LTC Totalizer Reading	4360.32	kw
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Readings	General Comments		
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	General Comments		
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Readings	Follow-up Action Required?	n	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	W0338	WithLTC	005-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	2	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1253	BreakerVacuum	BY-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	General Comments		
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Readings	General Comments		
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Readings	LTC Totalizer Reading	3553.92	kw
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Counter Readings	Follow-up Action Required?	n	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Counter Readings	General Comments		
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Readings	Oil Temp Max	55	°C
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Readings	Oil Temp Present	40	°C
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Mechanism Patrol Inspection	General Comments		
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Counter Readings	LTC As Found Counter	60184	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Counter Readings	LTC As Left Counter	60187	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Counter Readings	LTC Current Tap Position	2L	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Counter Readings	LTC Min Tap Position	9L	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Readings	Totalizer Meter Reading	.7404	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Counter Readings	LTC Operations Since Last Insp	1177	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	M0068	LTCMechanism	609-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Switching Operations	0	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/5/2020 11:18	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Maintenance Operations	0	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Operations Counter AF	154	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Operations Counter AL	154	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Readings	Operations This Read Vac	0	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BK001349	BreakerVacuum	838-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	General Comments		
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Grounds in Place?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Maintenance Operations	0	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Operations Counter AF	417	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Operations Counter AL	417	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Operations This Read Vac	2	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Switching Operations	2	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0434	BreakerVacuum	838-0510	VCB Readings	Unknown Operations	0	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	9 Month Operations	7	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Amps A Ø	150.0	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Amps B Ø	150.0	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Amps C Ø	150.0	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Bushing Condition	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Fault Operations A Ø	0	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Fault Operations B Ø	0	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Fault Operations C Ø	0	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Fault Operations Ground	0	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Follow-up Action Required?	n	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Foundation Condition	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	General Comments		
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	General Comments		
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Grounds in Place?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Maintenance Operations	0	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Operations Counter AF	477	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Operations Counter AL	477	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Operations This Read Vac	0	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Switching Operations	0	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 14:22	Distribution	Delaplain Quarterly Inspection	BB0436	BreakerVacuum	609-0402	VCB Readings	Unknown Operations	0	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	S0036	WithLTC	653-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Readings	Totalizer Meter Reading	.7030	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Readings	Winding Temp Max	50	°C
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Readings	Winding Temp Present	45	°C
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	110.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Operations Counter AF	131	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Maintenance Operations	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	General Comments		
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Patrol Inspection	General Comments		
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Follow-up Action Required?	n	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Fault Operations Ground	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Fault Operations C ∅	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Fault Operations B ∅	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Fault Operations A ∅	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Amps C ∅	0.0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Amps B ∅	0.0	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	Neutral	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Unknown Operations	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Switching Operations	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	General Comments		
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Fault Operations A ∅	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Fault Operations B ∅	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Fault Operations C ∅	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Fault Operations Ground	0	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	9 Month Operations	2	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Amps A ∅	0.0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	9 Month Operations	0	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	9 Month Operations	2	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Operations This Read Vac	0	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Amps A ∅	320.0	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Amps B ∅	320.0	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Amps C ∅	320.0	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Bushing Condition	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Amps A ∅	49.0	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Amps B ∅	59.0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Amps C ∅	0.0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Amps B ∅	0.0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Amps A ∅	0.0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	4	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Operations Counter AL	151	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Operations Counter AF	151	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Maintenance Operations	0	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Grounds in Place?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	General Comments		
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	General Comments		
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Foundation Condition	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Follow-up Action Required?	n	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Fault Operations Ground	0	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Fault Operations C Ø	0	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Fault Operations B Ø	0	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Fault Operations A Ø	0	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Positive DC Ground	57.2	VDC
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Negative DC Ground	62.0	VDC
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	General Comments		
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	BAT001202	Battery	005-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	9 Month Operations	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Amps A Ø	0.0	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Readings	Oil Temp Max	45	°C
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Readings	Oil Temp Present	45	°C
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Amps B Ø	0.0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Amps C Ø	0.0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	LTCC000747	LTCControl	005-5	LTC Control Insp	Follow-up Action Required?	n	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	LTCC000747	LTCControl	005-5	LTC Control Insp	All Connections OK?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Unknown Operations	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Switching Operations	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Operations This Read Vac	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Operations Counter AL	800	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Operations Counter AF	800	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Maintenance Operations	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	General Comments		
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Patrol Inspection	General Comments		
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Unknown Operations	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Switching Operations	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Operations This Read Vac	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Operations Counter AL	266	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Operations Counter AF	266	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Maintenance Operations	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	General Comments		
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Patrol Inspection	General Comments		
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Follow-up Action Required?	n	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Fault Operations Ground	0	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Patrol Inspection	Foundation Condition	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Patrol Inspection	General Comments		
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	General Comments		
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Patrol Inspection	Grounds in Place?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Maintenance Operations	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Fault Operations A Ø	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Fault Operations B Ø	0	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Fault Operations C Ø	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Fault Operations C Ø	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Fault Operations Ground	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Follow-up Action Required?	n	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Fault Operations B Ø	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Fault Operations A Ø	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Operations Counter AF	147	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Operations Counter AL	147	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Operations This Read Vac	0	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Amps C Ø	112.0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Amps B Ø	104.0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Amps A Ø	155.0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1257	BreakerVacuum	BY-1279	VCB Readings	9 Month Operations	14	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Amps A Ø	160.0	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	9 Month Operations	1	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Unknown Operations	0	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Switching Operations	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Patrol Inspection	General Comments		
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Amps C Ø	54.0	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Patrol Inspection	Bushing Condition	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Operations Counter AL	151	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Operations Counter AF	151	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Maintenance Operations	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	General Comments		
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Fault Operations A Ø	0	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Fault Operations B Ø	0	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Fault Operations C Ø	0	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Fault Operations Ground	0	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Follow-up Action Required?	n	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Foundation Condition	Good	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	General Comments		
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	General Comments		
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Grounds in Place?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Maintenance Operations	0	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Fault Operations A Ø	0	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Operations Counter AF	253	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Operations Counter AL	253	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Operations This Read Vac	2	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Bushing Condition	Good	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Amps C Ø	169.0	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Amps B Ø	194.0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	9 Month Operations	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Switching Operations	2	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Patrol Inspection	Tank Paint Condition	Good	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Amps A Ø	200.0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Amps B Ø	200.0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Amps C Ø	180.0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB0075	BreakerVacuum	BY-1281	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Fault Operations B Ø	0	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	BB0368	BreakerVacuum	838-2	VCB Readings	Unknown Operations	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0511	BreakerVacuum	IN-1296	VCB Readings	Follow-up Action Required?	n	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	LTCC000747	LTCControl	005-5	LTC Control Insp	VRR Time Delay	30	Seconds
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Fault Operations C Ø	0	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Fault Operations Ground	0	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001279	BreakerVacuum	588-2525	VCB Readings	Follow-up Action Required?	n	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	LTCC000747	LTCControl	005-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	LTCC000747	LTCControl	005-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	LTCC000747	LTCControl	005-5	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	LTCC000747	LTCControl	005-5	LTC Control Insp	LTC Operation Checked?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	LTCC000747	LTCControl	005-5	LTC Control Insp	General Comments		
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	General Comments		
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	BAT001369	Battery	655-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	BAT001369	Battery	655-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	BAT001369	Battery	655-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	61781	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	General Comments	SPR no longer in Station	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Vegetation	None	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LTCC000404	LTCControl	BY-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LTCC000404	LTCControl	BY-TRANS 1	LTC Control Insp	General Comments	ok	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Readings	Follow-up Action Required?	n	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	General Comments		
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Readings	General Comments		
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/5/2020 15:15	Distribution	Versailles Bypass Quarterly Inspection	B0439	WithLTC	838-2	LTC Transformer Readings	LTC Totalizer Reading	10123.20	kw
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Unknown Operations	0	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	1.0362	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	General Comments		
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	Vegetation	None	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Unknown Operations	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Switching Operations	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Operations This Read Vac	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1258	BreakerVacuum	BY-1280	VCB Readings	Operations Counter AL	131	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	YD000399	Yard	772-Yard	Yard Patrol Inspection	Ambient Temp	68	*F
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	BAT001369	Battery	655-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	BAT001369	Battery	655-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	BAT001369	Battery	655-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	BAT001369	Battery	655-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Reading	.7230	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Unknown Operations	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Switching Operations	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Operations This Read Vac	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Operations Counter AL	151	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Operations Counter AF	151	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Maintenance Operations	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	General Comments		
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Patrol Inspection	General Comments		
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Follow-up Action Required?	n	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Patrol Inspection	Follow-up Action Required?	n	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Fault Operations Ground	0	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	BAT001369	Battery	655-Battery Bank	Battery Patrol Inspection	General Comments		
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	BAT001369	Battery	655-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	BAT001369	Battery	655-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Fault Operations C Ø	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Fault Operations B Ø	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Fault Operations A Ø	0	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/9/2020 6:40	Distribution	Bluegrass Parkway Quarterly Inspection	LB1255	BreakerVacuum	BY-1277	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	58	*F
11/6/2020 7:45	Distribution	Lawrenceburg Quarterly Inspection	BAT001210	Battery	639-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	General Comments		
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	FE000236	Fence	653-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Ambient Temp	70	*F
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	YD000234	Yard	653-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	0	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments	One fan not working	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	193	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	193	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	General Comments		
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/5/2020 13:01	Distribution	Earlington Quarterly Inspection	ST000213	Structure	005-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Readings	Oil Temp Present	35	°C
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Readings	Oil Temp Max	40	°C
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	2486.88	kw
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Readings	General Comments		
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	General Comments		
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	1L	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	R0710	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	6R	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/5/2020 12:41	Distribution	Hunters Bottom Quarterly Inspection	C0175	NonLTC	891-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
11/5/2020 13:00	Distribution	International Quarterly Inspection	LB0516	BreakerVacuum	IN-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	35	°C
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/5/2020 13:53	Distribution	Dozier Heights Quarterly Inspection	ST000242	Structure	653-Structure	Structure Patrol Inspection	General Comments		
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/5/2020 9:43	Distribution	Sentry Quarterly Inspection	FE000232	Fence	457-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/5/2020 9:49	Distribution	Campbellsburg Quarterly Inspection	BAT001369	Battery	655-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Readings	Non LTC Totalizer Reading	2313.60	kw
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Switching Operations	0	
11/5/2020 11:15	Distribution	Shelbyville South Quarterly Inspection	BK001280	BreakerVacuum	588-2537	VCB Readings	Operations This Read Vac	0	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	52.50	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/5/2020 12:59	Distribution	Versailles Quarterly Inspection	B0232	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	50	°C
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	BAT001143	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	BAT001143	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	BAT001143	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	1.4	VDC
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	BAT001143	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	.5	VDC
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	BAT001143	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	BAT001143	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	BAT001143	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	BAT001143	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	BAT001143	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	BAT001143	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	BAT001143	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	BAT001143	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	BAT001143	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	BCH000255	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	BCH000255	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	BCH000255	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	BCH000255	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Bushing Condition	Good	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Amps B Ø	0.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Amps A Ø	0.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	9 Month Operations	1	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001040	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001040	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	16.77	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	2	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	3	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001040	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Unknown Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Switching Operations	0	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Operations This Read Vac	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Operations Counter AL	233	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Operations Counter AF	233	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Maintenance Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Patrol Inspection	General Comments		
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Accumulated Fault Duty C Ph V	5.15	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Amps A Ø	88.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Follow-up Action Required?	n	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Fault Operations Ground	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Fault Operations C Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Fault Operations B Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Fault Operations A Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Amps B Ø	78.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Amps C Ø	87.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Fault Operations A Ø	0	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Fault Operations B Ø	0	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Regulator As Left Counter	15615	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Min Tap Position	7L	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Max Tap Position	3L	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	General Comments		
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Current Tap Position	4L	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001040	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	FE000862	Fence	694-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	FE000862	Fence	694-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	FE000862	Fence	694-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	FE000862	Fence	694-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	FE000862	Fence	694-Fence	Fence Patrol Inspection	General Comments		
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	FE000862	Fence	694-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Foundation Condition	Good	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Follow-up Action Required?	n	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Operations Counter AF	105	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Unknown Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Switching Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Operations This Read Vac	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Operations Counter AL	217	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Operations Counter AF	217	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Maintenance Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Patrol Inspection	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Fault Operations Ground	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Fault Operations C Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Fault Operations B Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Fault Operations A Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Amps C Ø	0.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Amps B Ø	0.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Amps A Ø	0.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Operations Counter AL	105	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Operations This Read Vac	0	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Switching Operations	0	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Unknown Operations	0	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Fault Operations Ground	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0397	BreakerVacuum	GL-1331-1	VCB Readings	9 Month Operations	26	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	120.0	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	120.0	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	120.0	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	9	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Amps C Ø	40.0	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Amps B Ø	20.0	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Amps A Ø	20.0	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	9 Month Operations	2	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001040	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	9 Month Operations	5	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Amps A Ø	126.0	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Amps B Ø	149.0	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Amps C Ø	138.0	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Bushing Condition	Good	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Readings	Totalizer Meter Reading	.0924	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Fault Adjusted Amps A Phase V	5.07	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001040	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Fault Adjusted Amps B Phase V	5.07	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Fault Operations A Ø	1	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Fault Operations B Ø	1	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Fault Operations C Ø	0	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001040	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001040	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001040	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #''s
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001040	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001040	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001040	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001040	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BAT001040	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	61	°F
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Tank Leaks	None	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	RG000094	Regulator	004-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Counter Readings	General Comments		
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Mechanism Patrol Inspection	General Comments		
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Counter Readings	LTC As Found Counter	259474	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Counter Readings	LTC As Left Counter	259476	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Fault Adjusted Amps A Phase V	6.98	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BAT001279	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BAT001279	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BAT001279	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BAT001279	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BAT001279	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BAT001279	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BAT001279	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #''s
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BAT001279	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Unknown Operations	4	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Switching Operations	0	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Operations This Read Vac	4	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Counter Readings	LTC Current Tap Position	2L	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Counter Readings	LTC Max Tap Position	16R	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Counter Readings	LTC Min Tap Position	7L	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Counter Readings	LTC Operations Since Last Insp	69	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Unknown Operations	0	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Operations Counter AL	1549	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Operations Counter AF	1549	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Maintenance Operations	0	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Grounds in Place?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BAT001279	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Fault Adjusted Amps B Phase V	6.98	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Fault Adjusted Amps C Phase V	6.98	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Fault Operations A Ø	0	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Fault Operations B Ø	0	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Fault Operations C Ø	0	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Fault Operations Ground	0	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Switching Operations	2	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Operations This Read Vac	2	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Operations Counter AL	197	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Operations Counter AF	197	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Maintenance Operations	0	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Bushing Condition	Good	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Amps C Ø	120.0	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Amps B Ø	120.0	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Amps A Ø	110.0	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Counter Readings	Follow-up Action Required?	n	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Counter Readings	General Comments		
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Mechanism Patrol Inspection	General Comments		
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Counter Readings	LTC As Found Counter	10278	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Counter Readings	LTC As Left Counter	10278	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Counter Readings	LTC Current Tap Position	5L	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	9 Month Operations	4	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	0	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Maintenance Operations	0	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	489	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Operations Counter AF	305	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Operations Counter AL	305	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Operations This Read Vac	2	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Switching Operations	0	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	Unknown Operations	0	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	9 Month Operations	6	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Amps A Ø	30.0	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Amps B Ø	5.0	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Amps C Ø	15.0	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Bushing Condition	Good	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	20.0	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	20.0	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	LTCM000034	LTCMechanism	559-1	LTC Counter Readings	Follow-up Action Required?	n	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCM000036	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Follow-up Action Required?	n	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCM000036	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCM000036	LTCMechanism	932-Offline Distribution	LTC Counter Readings	General Comments		
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCM000036	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCM000036	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Found Counter	16965	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCM000036	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Left Counter	16965	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCM000036	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCM000036	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Current Tap Position	3L	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCM000036	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Max Tap Position	3L	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCM000036	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Min Tap Position	7L	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCM000036	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Operations Since Last Insp	787	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCM000036	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCM000036	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCM000036	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCM000036	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Unknown Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Switching Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Operations This Read Vac	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Operations Counter AL	2233	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Operations Counter AF	223	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Maintenance Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Patrol Inspection	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Fault Operations Ground	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Fault Operations C Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Fault Operations B Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Fault Operations A Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Amps C Ø	261.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Amps B Ø	237.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Amps A Ø	265.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	2.39	%
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BCH001371	Charger	402-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BCH001371	Charger	402-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BCH001371	Charger	402-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	1.59	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	2.39	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0407	BreakerVacuum	GL-14KV TR 1	VCB Readings	9 Month Operations	23	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BCH001371	Charger	402-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0137	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	849	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Grounds in Place?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	General Comments		
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Counter Readings	LTC Max Tap Position	8L	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Counter Readings	LTC Min Tap Position	4L	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Counter Readings	LTC Operations Since Last Insp	259	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	General Comments		
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Foundation Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Follow-up Action Required?	n	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Fault Operations Ground	0	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Fault Operations C Ø	0	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Fault Operations B Ø	0	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Fault Operations A Ø	0	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Patrol Inspection	Bushing Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Amps C Ø	125.0	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Amps B Ø	112.0	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Amps A Ø	122.0	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Readings	Follow-up Action Required?	n	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	Foundation Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0146	BreakerVacuum	640-1467	VCB Patrol Inspection	General Comments		
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BAT001279	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BAT001279	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BAT001279	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	25.0	VDC
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BAT001279	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BAT001279	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BCH001220	Charger	508-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.000	millivolts
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BCH001220	Charger	508-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BCH001220	Charger	508-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BCH001220	Charger	508-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BCH001220	Charger	508-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BCH001220	Charger	508-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BCH001224	Charger	585-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BCH001224	Charger	585-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53	VDC
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	KB0080	BreakerVacuum	786-2540	VCB Readings	9 Month Operations	2	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BCH001224	Charger	585-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53	VDC
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BCH001224	Charger	585-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BCH001224	Charger	585-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BCH001224	Charger	585-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BCH001224	Charger	585-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BCH001224	Charger	585-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCC000811	LTCControl	670-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCC000811	LTCControl	670-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCC000811	LTCControl	670-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCC000811	LTCControl	670-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCC000811	LTCControl	670-1	LTC Control Insp	LTC Operation Checked?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCC000811	LTCControl	670-1	LTC Control Insp	General Comments		
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCC000811	LTCControl	670-1	LTC Control Insp	Follow-up Action Required?	n	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	LTCC000811	LTCControl	670-1	LTC Control Insp	All Connections OK?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	General Comments		
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Readings	General Comments		
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Grounds in Place?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KB0070	BreakerVacuum	634-2503	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Fault Operations A Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Fault Operations B Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Fault Operations C Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Fault Operations Ground	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Unknown Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Switching Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Operations This Read Vac	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Operations Counter AL	235	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Operations Counter AF	235	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Maintenance Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Patrol Inspection	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Fault Operations Ground	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Fault Operations C Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Fault Operations B Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Fault Operations A Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Unknown Operations	0	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Switching Operations	0	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Operations This Read AM	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Operations Counter AL	194	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Operations Counter AF	194	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Maintenance Operations	0	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Patrol Inspection	General Comments	NEEDS SIGN ON OUTSIDE. WHEN PAINTERS PAINTED GEAR CAUSE OF GRAFFITI, THEY PAINTED OVER SIGNS.	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Amps C Ø	48.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Amps B Ø	40.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Amps A Ø	51.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Maintenance Operations	0	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.1278	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Fault Operations C Ø	0	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Fault Operations Ground	0	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Follow-up Action Required?	n	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Foundation Condition	Good	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	General Comments		
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	General Comments		
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Grounds in Place?	y	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Accumulated Fault Duty B Ph V	6.01	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	Accumulated Fault Duty A Ph V	5.15	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0403	BreakerVacuum	GL-1334-1	VCB Readings	9 Month Operations	30	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Maintenance Operations	2	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Operations Counter AF	124	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Operations Counter AL	124	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	FE000862	Fence	694-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	FE000862	Fence	694-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	FE000862	Fence	694-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	FE000862	Fence	694-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	FE000862	Fence	694-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	FE000862	Fence	694-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	FE000862	Fence	694-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	FE000862	Fence	694-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	FE000862	Fence	694-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Operations This Read Vac	2	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Switching Operations	0	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	WB0155	BreakerVacuum	004-1750	VCB Readings	Unknown Operations	0	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	39	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	44	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations This Read Vac	5	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Amps C Ø	0.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Patrol Inspection	Bushing Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	0	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	W0321	LTCMechanism	648-1	LTC Counter Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	W0321	LTCMechanism	648-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	W0321	LTCMechanism	648-1	LTC Mechanism Patrol Inspection	General Comments		
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	W0321	LTCMechanism	648-1	LTC Counter Readings	General Comments	Indicator head does not work everytime	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	W0321	LTCMechanism	648-1	LTC Counter Readings	LTC As Found Counter	10172	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	W0321	LTCMechanism	648-1	LTC Counter Readings	LTC As Left Counter	10180	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	W0321	LTCMechanism	648-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	W0321	LTCMechanism	648-1	LTC Counter Readings	LTC Current Tap Position	7L	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	W0321	LTCMechanism	648-1	LTC Counter Readings	LTC Max Tap Position	5L	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	W0321	LTCMechanism	648-1	LTC Counter Readings	LTC Min Tap Position	7L	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	W0321	LTCMechanism	648-1	LTC Counter Readings	LTC Operations Since Last Insp	552	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	W0321	LTCMechanism	648-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	W0321	LTCMechanism	648-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	W0321	LTCMechanism	648-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Patrol Inspection	Foundation Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Patrol Inspection	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Patrol Inspection	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Patrol Inspection	Grounds in Place?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Maintenance Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Operations Counter AF	68	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Operations Counter AL	68	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Operations This Read Vac	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Switching Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1340	BreakerVacuum	GL-1330-1	VCB Readings	Unknown Operations	0	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	General Comments		
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Foundation Condition	Good	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Follow-up Action Required?	n	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Fault Operations Ground	0	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Fault Operations C Ø	0	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Fault Operations B Ø	0	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Fault Operations A Ø	0	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	9 Months Operations	0	
11/4/2020 9:41	Distribution	Taylorville Quarterly Inspection	LTCC000164	LTCControl	647-1	LTC Control Insp	All Connections OK?	y	
11/4/2020 9:41	Distribution	Taylorville Quarterly Inspection	LTCC000164	LTCControl	647-1	LTC Control Insp	Follow-up Action Required?	n	
11/4/2020 9:41	Distribution	Taylorville Quarterly Inspection	LTCC000164	LTCControl	647-1	LTC Control Insp	General Comments		
11/4/2020 9:41	Distribution	Taylorville Quarterly Inspection	LTCC000164	LTCControl	647-1	LTC Control Insp	LTC Operation Checked?	y	
11/4/2020 9:41	Distribution	Taylorville Quarterly Inspection	LTCC000164	LTCControl	647-1	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
11/4/2020 9:41	Distribution	Taylorville Quarterly Inspection	LTCC000164	LTCControl	647-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/4/2020 9:41	Distribution	Taylorville Quarterly Inspection	LTCC000164	LTCControl	647-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/4/2020 9:41	Distribution	Taylorville Quarterly Inspection	LTCC000164	LTCControl	647-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	4200	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	.8	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1259	BreakerVacuum	GL-14KV TR 3	VCB Readings	9 Month Operations	1	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Readings	Oil Temp Present	40	°C
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Readings	Oil Temp Max	40	°C
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	536.76	kw
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Readings	General Comments		
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Patrol Inspection	Follow-up Action Required?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Follow-up Action Required?	n	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Fault Operations Ground	0	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Fault Operations C Ø	0	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Fault Operations B Ø	0	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Fault Operations A Ø	0	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Patrol Inspection	Equipment Properly Labeled?	n	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Amps C Ø	140.0	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Amps B Ø	210.0	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Amps A Ø	150.0	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0551	BreakerAirMagnetic	LG-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	General Comments		
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Patrol Inspection	Grounds in Place?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0293	BreakerVacuum	441-0734	VCB Readings	General Comments		
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0337	NonLTC	622-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	General Comments		
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	BAT001291	Battery	LG-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	26	°C
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	9 Month Operations	2	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps A Ø	123.0	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps B Ø	123.0	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps C Ø	104.0	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Operations Counter AF	428	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Maintenance Operations	0	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	General Comments		
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	LTC Totalizer Reading	7568.64	kw
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	800	psi
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	Oil Temp Max	30	°C
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	Oil Temp Present	20	°C
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	Totalizer Meter Reading	.5256	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	Winding Temp Max	30	°C
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Unknown Operations	0	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Switching Operations	3	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	General Comments		
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	General Comments		
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	General Comments		
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	General Comments		
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Unknown Operations	0	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	General Comments		
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	General Comments		
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Grounds in Place?	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Maintenance Operations	4	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	9 Month Operations	1	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Amps A ∅	175.0	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Amps B ∅	160.0	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Bushing Condition	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Amps C ∅	50.0	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Amps B ∅	35.0	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Amps A ∅	35.0	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	9 Month Operations	2	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Unknown Operations	0	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Switching Operations	0	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Operations This Read Vac	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Operations Counter AL	428	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	140.0	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	145.0	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	140.0	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	2	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Bushing Condition	Good	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Amps C Ø	10.0	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Amps B Ø	10.0	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Follow-up Action Required?	n	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Foundation Condition	Good	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	General Comments		
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	General Comments		
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Grounds in Place?	y	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	LTCC000669	LTCControl	733-1	LTC Control Insp	VRR Base Voltage AF	120.0	VAC
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	LTCC000669	LTCControl	733-1	LTC Control Insp	VRR Base Voltage AL	120.0	VAC
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	LTCC000669	LTCControl	733-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Fault Operations Ground	0	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Fault Operations C Ø	0	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Fault Operations B Ø	0	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Fault Operations A Ø	0	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Readings	Oil Temp Present	25	°C
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	30.00	
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Readings	General Comments		
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Bushing Condition	Good	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Amps C Ø	0.0	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Amps B Ø	0.0	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Amps A Ø	0.0	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	9 Month Operations	5	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	Winding Temp Present	20	°C
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	Maintenance Operations	1	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations Counter AF	174	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations Counter AL	174	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations This Read Vac	1	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	Switching Operations	0	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0138	BreakerVacuum	912-Offline-Distribution	VCB Readings	Unknown Operations	0	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Operations This Read Vac	3	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Operations Counter AL	203	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Operations Counter AF	203	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Maintenance Operations	0	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Grounds in Place?	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	General Comments		
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	General Comments		
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Grounds in Place?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	General Comments		
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	General Comments		
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Foundation Condition	Good	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Follow-up Action Required?	n	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Amps C Ø	125.0	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Bushing Condition	Good	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Switching Operations	0	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	9 Month Operations	27	
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Patrol Inspection	Foundation Condition	Good	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	KB0107	BreakerVacuum	559-0871	VCB Readings	Follow-up Action Required?	n	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	LTCC000669	LTCControl	733-1	LTC Control Insp	All Connections OK?	y	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	LTCC000669	LTCControl	733-1	LTC Control Insp	Follow-up Action Required?	n	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	LTCC000669	LTCControl	733-1	LTC Control Insp	General Comments		
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	LTCC000669	LTCControl	733-1	LTC Control Insp	LTC Operation Checked?	y	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	LTCC000669	LTCControl	733-1	LTC Control Insp	LTC Output Voltage Level	120.0	VAC
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Fault Operations A Ø	0	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Fault Operations B Ø	0	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Fault Operations C Ø	0	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Fault Operations Ground	0	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Fault Operations Ground	0	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Fault Operations C Ø	0	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Fault Operations B Ø	0	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Fault Operations A Ø	0	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Present	30	°C
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Amps A Ø	60.0	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	9 Month Operations	18	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	700	psi
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	Oil Temp Max	47	°C
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	Oil Temp Present	26	°C
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	44	°C
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	15	°C
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Max	55	°C
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	LTC Totalizer Reading	6220.80	kw
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	General Comments		
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Maintenance Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Fault Operations A Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Fault Operations B Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Fault Operations C Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Fault Operations Ground	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Patrol Inspection	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Maintenance Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Operations Counter AF	138	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Operations Counter AL	138	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Operations This Read Vac	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Switching Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Unknown Operations	0	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Grounds in Place?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	General Comments		
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	General Comments		
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Foundation Condition	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Follow-up Action Required?	n	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Bushing Condition	Good	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Amps C Ø	60.0	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Fault Operations Ground	0	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Fault Operations C Ø	0	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Fault Operations B Ø	0	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Fault Operations A Ø	0	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Amps B Ø	60.0	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Amps A Ø	30.0	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Amps B Ø	30.0	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Amps C Ø	73.0	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Amps C Ø	0.0	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	LTCC000825	LTCControl	640-1	LTC Control Insp	All Connections OK?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	LTCC000825	LTCControl	640-1	LTC Control Insp	Follow-up Action Required?	n	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Reading	.6480	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	LTCC000825	LTCControl	640-1	LTC Control Insp	General Comments		
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Amps A Ø	28.0	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Amps B Ø	32.0	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	LTCC000825	LTCControl	640-1	LTC Control Insp	LTC Operation Checked?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	LTCC000825	LTCControl	640-1	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	LTCC000825	LTCControl	640-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	LTCC000825	LTCControl	640-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Fault Operations A Ø	0	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Fault Operations B Ø	0	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Fault Operations C Ø	0	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Fault Operations Ground	0	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Follow-up Action Required?	n	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	General Comments		
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	General Comments		
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Heaters (All) Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Amps C Ø	28.0	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Maintenance Operations	0	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Operations Counter AF	538	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Operations Counter AL	538	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Operations This Read Vac	0	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Switching Operations	0	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	General Comments		
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Operations Counter	209	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Tank Leaks	None	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	RC000435	RecloserElectronic	622-1416	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	LTC000825	LTCControl	640-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Fault Operations A Ø	0	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Fault Operations B Ø	0	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Fault Operations C Ø	0	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Fault Operations Ground	0	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Follow-up Action Required?	n	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	FE000842	Fence	022-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Operations Counter AF	57	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Operations Counter AL	57	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Operations This Read Vac	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Counter Readings	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Counter Readings	LTC As Found Counter	21664	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Counter Readings	LTC As Left Counter	21664	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Counter Readings	LTC Current Tap Position	7L	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Counter Readings	LTC Max Tap Position	2L	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Counter Readings	LTC Min Tap Position	9L	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	44	°C
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	15	°C
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	370	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0293	LTCMechanism	GL-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	B0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	96.00	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	General Comments		
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	48	°C
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	26	°C
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0293	WithLTC	GL-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	44	°C
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	2	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	2	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	257	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	257	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C ∅	0	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B ∅	0	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A ∅	0	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0186	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0269	NonLTC	489-1 C	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Readings	Follow-up Action Required?	n	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Unknown Operations	0	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Switching Operations	0	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Operations This Read Vac	0	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Operations Counter AL	111	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Operations Counter AF	111	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Maintenance Operations	0	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Grounds in Place?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	General Comments		
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	General Comments		
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Foundation Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Follow-up Action Required?	n	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Fault Operations Ground	0	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Fault Operations C ∅	0	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Readings	Oil Temp Present	40	°C
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Readings	Oil Temp Max	45	°C
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	General Comments		
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Fault Operations B Ø	0	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Fault Operations A Ø	0	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Patrol Inspection	Bushing Condition	Good	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Amps C Ø	60.0	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Amps B Ø	60.0	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Amps A Ø	60.0	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Follow-up Action Required?	n	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Foundation Condition	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	General Comments		
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	General Comments	51-N INST Flag down,	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Grounds in Place?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Maintenance Operations	0	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Operations Counter AF	82	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Operations Counter AL	82	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Operations This Read Vac	0	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Switching Operations	0	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Unknown Operations	0	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Readings	Totalizer Meter Reading	.5712	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Readings	Oil Temp Present	45	°C
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Readings	Oil Temp Max	45	°C
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Readings	LTC Totalizer Reading	2741.76	kw
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	General Comments		
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	95.00	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0244	NonLTC	489-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Readings	General Comments		
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	General Comments		
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Wood Structures OK?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	CH000446	ControlHouse	LG-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	110.00	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Totalizer Meter Reading	.7092	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	9 Month Operations	4	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Amps A Ø	100.0	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Amps B Ø	110.0	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Amps C Ø	120.0	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Bushing Condition	Good	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Fault Operations A Ø	0	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Fault Operations B Ø	0	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Fault Operations C Ø	0	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Fault Operations Ground	0	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Follow-up Action Required?	n	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Foundation Condition	Good	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	General Comments		
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	General Comments		
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Grounds in Place?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Maintenance Operations	0	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Operations Counter AF	346	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Operations Counter AL	346	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Operations This Read Vac	0	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Switching Operations	0	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0235	BreakerVacuum	441-0727	VCB Readings	Unknown Operations	0	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Oil Temp Present	54	°C
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Oil Temp Max	59	°C
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Readings	LTC Totalizer Reading	2269.44	kw
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Readings	General Comments		
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	C0414	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0263	BreakerVacuum	600-0475	VCB Readings	9 Month Operations	4	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0336	NonLTC	622-1 C	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	BAT001484	Battery	733-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	BAT001484	Battery	733-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	*F
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	BAT001484	Battery	733-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	BAT001484	Battery	733-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	BAT001484	Battery	733-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	BAT001484	Battery	733-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	BAT001484	Battery	733-Battery Bank	Battery Patrol Inspection	General Comments		
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	General Comments		
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Readings	General Comments		
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Readings	LTC Totalizer Reading	665.28	kw
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Readings	Oil Temp Max	85	*C
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Readings	Oil Temp Present	45	*C
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	BAT001484	Battery	733-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.2	VDC
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	S0009	WithLTC	508-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	CH000446	ControlHouse	LG-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	CH000446	ControlHouse	LG-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	CH000446	ControlHouse	LG-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	CH000446	ControlHouse	LG-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	CH000446	ControlHouse	LG-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	CH000446	ControlHouse	LG-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	CH000446	ControlHouse	LG-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	All Identified and Legible?	y	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	CH000446	ControlHouse	LG-Battery Control House	Control House Patrol Inspection	General Comments		
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Foundation Condition	Good	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	General Comments		
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Ground Connections Intact?	y	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	BAT001484	Battery	733-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.8	VDC
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	BAT001484	Battery	733-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	BAT001484	Battery	733-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	M0055	WithLTC	786-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	ST000847	Structure	020-Structure Distribution	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Readings	Oil Temp Present	25	°C
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1050.84	kw
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Counter Readings	Follow-up Action Required?	n	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Counter Readings	General Comments		
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Mechanism Patrol Inspection	General Comments		
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Counter Readings	LTC As Found Counter	41505	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Counter Readings	LTC As Left Counter	41505	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Counter Readings	LTC Current Tap Position	7L	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Counter Readings	LTC Max Tap Position	11L	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Counter Readings	LTC Min Tap Position	4L	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	25	°C
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	25	°C
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Counter Readings	LTC Operations Since Last Insp	443	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2	psi
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Amps A Ø	65.0	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Amps B Ø	60.0	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Amps C Ø	60.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Amps B Ø	0.0	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Unknown Operations	0	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	General Comments		
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0	psi
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	B0247	WithLTC	585-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	General Comments		
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	General Comments		
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	LTC Totalizer Reading	4273.92	kw
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0178	BreakerVacuum	888-1438	VCB Readings	Unknown Operations	0	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Operations Counter AF	358	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Operations Counter AL	358	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Operations This Read Vac	8	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Switching Operations	4	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	BB0424	BreakerVacuum	559-0872	VCB Readings	Unknown Operations	0	
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	General Comments		
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Maintenance Operations	1	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Operations Counter AF	160	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Operations Counter AL	160	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Operations This Read Vac	1	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Readings	Switching Operations	0	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0157	BreakerVacuum	610-0747	VCB Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	C0306	NonLTC	434-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	9 Month Operations	2	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/4/2020 9:41	Distribution	Taylorville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 9:41	Distribution	Taylorville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
11/4/2020 9:41	Distribution	Taylorville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	Oil Temp Max	30	°C
11/4/2020 9:41	Distribution	Taylorville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	Oil Temp Present	20	°C
11/4/2020 9:41	Distribution	Taylorville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 9:41	Distribution	Taylorville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/4/2020 9:41	Distribution	Taylorville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/4/2020 9:41	Distribution	Taylorville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 9:41	Distribution	Taylorville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/4/2020 9:41	Distribution	Taylorville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/4/2020 9:41	Distribution	Taylorville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 9:41	Distribution	Taylorville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/4/2020 9:41	Distribution	Taylorville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	Totalizer Meter Reading	.4452	
11/4/2020 9:41	Distribution	Taylorville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	Winding Temp Max	35	°C
11/4/2020 9:41	Distribution	Taylorville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	Winding Temp Present	20	°C
11/4/2020 9:41	Distribution	Taylorville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/4/2020 9:41	Distribution	Taylorville Quarterly Inspection	S0073	WithLTC	647-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	FE000832	Fence	585-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5838	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1800	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Bushing Condition	Good	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Operations Counter AL	105	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Operations This Read Vac	1	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Switching Operations	0	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Amps A Ø	0.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1265	BreakerVacuum	GL-1339	VCB Readings	9 Month Operations	0	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Fault Operations A Ø	0	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Unknown Operations	1	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Readings	Oil Temp Present	35	°C
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Readings	Oil Temp Max	55	°C
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.5	psi
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Readings	General Comments		
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	General Comments		
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0315	NonLTC	510-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	General Comments		
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Panels Dusted?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	CH000449	ControlHouse	585-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Fault Operations B Ø	0	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Fault Operations C Ø	0	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	WB0177	BreakerVacuum	888-1437	VCB Readings	Fault Operations Ground	0	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Readings	General Comments		
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	General Comments		
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Amps A Ø	10.0	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	B0258	NonLTC	785-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	BB0359	BreakerVacuum	441-0728	VCB Readings	9 Month Operations	4	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	9 Month Operations	5	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Amps A Ø	35.0	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Amps B Ø	35.0	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Amps C Ø	35.0	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Bushing Condition	Good	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Fault Adjusted Amps A Phase V	2.52	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Fault Adjusted Amps B Phase V	2.52	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Fault Adjusted Amps C Phase V	2.52	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Fault Operations A Ø	0	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Fault Operations B Ø	0	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Fault Operations C Ø	0	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Fault Operations Ground	0	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Follow-up Action Required?	n	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Foundation Condition	Good	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	General Comments		
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	General Comments		
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Grounds in Place?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Maintenance Operations	0	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BB0262	BreakerVacuum	600-0476	VCB Readings	Operations Counter AF	105	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Counter Readings	Follow-up Action Required?	n	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Counter Readings	General Comments		
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Mechanism Patrol Inspection	General Comments		
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Counter Readings	LTC As Found Counter	208448	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Counter Readings	LTC As Left Counter	208455	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Counter Readings	LTC Current Tap Position	2R	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Counter Readings	LTC Max Tap Position	4R	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Counter Readings	LTC Min Tap Position	2L	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Counter Readings	LTC Operations Since Last Insp	645	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	W0262	LTCMechanism	888-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Readings	General Comments		
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	General Comments	Bottle - 1500 psi	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	117.50	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	110.00	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Counter Readings	Follow-up Action Required?	n	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Readings	Top Oil Temperature Max	42	°C
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Readings	Top Oil Temperature Present	34	°C
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	General Comments		
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Readings	General Comments		
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1400	psi
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	10.08	kw
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Maintenance Operations	0	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Operations Counter AF	154	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Operations Counter AL	154	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Counter Readings	LTC Operations Since Last Insp	430	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	15	°C
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	20	°C
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Counter Readings	LTC Min Tap Position	13L	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Counter Readings	LTC Max Tap Position	4L	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Counter Readings	LTC Current Tap Position	10L	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Counter Readings	LTC As Left Counter	29076	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Counter Readings	LTC As Found Counter	29073	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Mechanism Patrol Inspection	General Comments		
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Counter Readings	General Comments		
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Amps A Ø	40.0	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Amps B Ø	40.0	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Amps C Ø	40.0	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Bushing Condition	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Fault Operations A Ø	0	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Fault Operations B Ø	0	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Fault Operations C Ø	0	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Fault Operations Ground	0	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Follow-up Action Required?	n	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Foundation Condition	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	General Comments		
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	General Comments		
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Grounds in Place?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0153	NonLTC	476-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	General Comments		
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Readings	General Comments		
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	479.04	kw
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Readings	Oil Temp Max	58	°C
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	LTCC000754	LTCControl	585-1	LTC Control Insp	All Connections OK?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	LTCC000754	LTCControl	585-1	LTC Control Insp	Follow-up Action Required?	n	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	LTCC000754	LTCControl	585-1	LTC Control Insp	General Comments		
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	LTCC000754	LTCControl	585-1	LTC Control Insp	LTC Operation Checked?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	LTCC000754	LTCControl	585-1	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	LTCC000754	LTCControl	585-1	LTC Control Insp	VRR Base Voltage AF	124	VAC
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	LTCC000754	LTCControl	585-1	LTC Control Insp	VRR Base Voltage AL	124	VAC
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	LTCC000754	LTCControl	585-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	BCH001144	Charger	640-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.120	millivolts
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	BCH001144	Charger	640-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.9	VDC
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	BCH001144	Charger	640-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	BCH001144	Charger	640-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	BCH001144	Charger	640-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	BCH001144	Charger	640-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5988	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	BCH001144	Charger	640-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	BCH001145	Charger	888-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.1	VDC
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	BCH001145	Charger	888-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.1	VDC
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	BCH001145	Charger	888-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	BCH001145	Charger	888-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	BCH001145	Charger	888-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Operations This Read Vac	0	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Switching Operations	0	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Unknown Operations	0	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Readings	Top Oil Temperature Max	53	°C
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Readings	Top Oil Temperature Present	53	°C
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0155	NonLTC	476-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.0126	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	General Comments		
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Readings	General Comments		
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	2300	psi
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	27.50	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Readings	Top Oil Temperature Max	44	°C
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	W0161	NonLTC	476-1 C	NonLTC Transformer Readings	Top Oil Temperature Present	35	°C
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	B0249	NonLTC	718-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	Oil Temp Present	15	°C
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	Oil Temp Max	25	°C
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	LTCC000308	LTCControl	786-1	LTC Control Insp	All Connections OK?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	LTCC000308	LTCControl	786-1	LTC Control Insp	Follow-up Action Required?	n	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	LTCC000308	LTCControl	786-1	LTC Control Insp	General Comments		
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	LTCC000308	LTCControl	786-1	LTC Control Insp	LTC Operation Checked?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	LTCC000308	LTCControl	786-1	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	LTCC000308	LTCControl	786-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	LTCC000308	LTCControl	786-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	LTCC000308	LTCControl	786-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	LTC Totalizer Reading	5592.96	kw
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	General Comments		
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	General Comments		
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	LTCC000749	LTCControl	920-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	LTCC000749	LTCControl	920-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	LTCC000749	LTCControl	920-Offline-Distribution	LTC Control Insp	General Comments		
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	LTCC000749	LTCControl	920-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	LTCC000749	LTCControl	920-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	LTCC000749	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	LTCC000749	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	LTCC000749	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	LTCC000852	LTCControl	600-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	LTCC000852	LTCControl	600-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	LTCC000852	LTCControl	600-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	LTCC000852	LTCControl	600-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	LTCC000852	LTCControl	600-1	LTC Control Insp	LTC Operation Checked?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	BCH001301	Charger	022-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	BCH001301	Charger	022-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	BCH001301	Charger	022-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	BCH001301	Charger	022-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.9	VDC
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	BCH001301	Charger	022-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.9	VDC
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	BCH001301	Charger	022-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	BAT001378	Battery	022-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	BAT001378	Battery	022-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	BAT001378	Battery	022-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	BAT001378	Battery	022-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	BAT001378	Battery	022-Battery Bank	Battery Patrol Inspection	General Comments		
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	BAT001378	Battery	022-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	BAT001378	Battery	022-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	BAT001378	Battery	022-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	BAT001378	Battery	022-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	BAT001378	Battery	022-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	BAT001378	Battery	022-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	BAT001378	Battery	022-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	BAT001378	Battery	022-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	BAT001378	Battery	022-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	LTCC000033	LTCControl	888-1	LTC Control Insp	All Connections OK?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	LTCC000033	LTCControl	888-1	LTC Control Insp	Follow-up Action Required?	n	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	LTCC000033	LTCControl	888-1	LTC Control Insp	General Comments		
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	LTCC000033	LTCControl	888-1	LTC Control Insp	LTC Operation Checked?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	LTCC000033	LTCControl	888-1	LTC Control Insp	LTC Output Voltage Level	121.7	VAC
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	LTCC000033	LTCControl	888-1	LTC Control Insp	VRR Base Voltage AF	121.5	VAC
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	LTCC000033	LTCControl	888-1	LTC Control Insp	VRR Base Voltage AL	121.5	VAC
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	LTCC000033	LTCControl	888-1	LTC Control Insp	VRR Time Delay	60	Seconds
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	LTCC000025	LTCControl	912-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	LTCC000025	LTCControl	912-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	LTCC000025	LTCControl	912-Offline-Distribution	LTC Control Insp	General Comments		
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	LTCC000025	LTCControl	912-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	LTCC000025	LTCControl	912-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	121.5	VAC
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	LTCC000025	LTCControl	912-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	121.0	VAC
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	LTCC000025	LTCControl	912-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	121.0	VAC
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	LTCC000025	LTCControl	912-Offline-Distribution	LTC Control Insp	VRR Time Delay	90	Seconds
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	Winding Temp Present	25	*C
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	Winding Temp Max	30	*C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	Totalizer Meter Reading	.5826	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KT0023	WithLTC	854-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	LTCC000459	LTCControl	854-1	LTC Control Insp	Follow-up Action Required?	n	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	LTCC000459	LTCControl	854-1	LTC Control Insp	All Connections OK?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5628	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1350.72	kw
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Readings	General Comments		
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	General Comments		
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	B0292	NonLTC	705-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LTCC000407	LTCControl	GL-TRANS 3	LTC Control Insp	VRR Base Voltage AF	115.7	VAC
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LTCC000407	LTCControl	GL-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LTCC000407	LTCControl	GL-TRANS 3	LTC Control Insp	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LTCC000407	LTCControl	GL-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KT0023	LTCMechanism	854-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	LTCC000852	LTCControl	600-1	LTC Control Insp	General Comments		
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	LTCC000852	LTCControl	600-1	LTC Control Insp	Follow-up Action Required?	n	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	LTCC000852	LTCControl	600-1	LTC Control Insp	All Connections OK?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BCH001290	Charger	529-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BCH001290	Charger	529-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BCH001290	Charger	529-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BCH001290	Charger	529-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BCH001290	Charger	529-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BCH001290	Charger	529-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.3	VDC
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BCH001290	Charger	529-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.3	VDC
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BCH001290	Charger	529-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5172	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Readings	Top Oil Temperature Present	40	°C
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Readings	Top Oil Temperature Max	40	°C
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	413.76	kw
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Readings	General Comments		
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	General Comments		
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	W0243	NonLTC	458-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	LTCC000459	LTCControl	854-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	LTCC000459	LTCControl	854-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	LTCC000459	LTCControl	854-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	LTCC000459	LTCControl	854-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	LTCC000459	LTCControl	854-1	LTC Control Insp	LTC Output Voltage Level	125.5	VAC
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	LTCC000459	LTCControl	854-1	LTC Control Insp	LTC Operation Checked?	y	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	LTCC000459	LTCControl	854-1	LTC Control Insp	General Comments		
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	K0137	BreakerVacuum	510-1461	VCB Readings	9 Month Operations	3	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1604.16	kw
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Readings	General Comments		
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	General Comments		
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Readings	Totalizer Meter Reading	.1908	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Readings	Oil Temp Present	40	°C
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Readings	Oil Temp Max	60	°C
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.5	psi
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Readings	LTC Totalizer Reading	1526.40	kw
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Readings	General Comments		
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	General Comments		
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Amps A Ø	120.0	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	9 Month Operations	2	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Amps A Ø	0.0	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	9 Month Operations	5	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Unknown Operations	0	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Switching Operations	0	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Operations This Read Vac	1	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Operations Counter AL	138	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Operations Counter AF	138	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Maintenance Operations	1	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Grounds in Place?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	General Comments	Trip CK	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	General Comments		
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Foundation Condition	Good	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Follow-up Action Required?	n	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Fault Operations Ground	0	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Fault Operations C Ø	0	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Fault Operations B Ø	0	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Fault Operations A Ø	0	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Patrol Inspection	Bushing Condition	Good	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Amps C Ø	120.0	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0123	BreakerVacuum	712-0827	VCB Readings	Amps B Ø	120.0	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6684	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	W0359	NonLTC	865-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	9 Month Operations	4	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Amps A Ø	85.0	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Amps B Ø	80.0	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Amps C Ø	88.0	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Fault Operations A Ø	0	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Fault Operations B Ø	0	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Fault Operations C Ø	0	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Fault Operations Ground	0	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Follow-up Action Required?	n	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Patrol Inspection	General Comments		
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	General Comments		
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Maintenance Operations	0	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Operations Counter AF	143	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Operations Counter AL	143	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Operations This Read Vac	0	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Switching Operations	0	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Unknown Operations	0	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	9 Month Operations	4	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Amps A Ø	102.0	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Amps B Ø	88.0	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Amps C Ø	116.0	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	W0262	WithLTC	888-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	Winding Temp Present	30	°C
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	Winding Temp Max	30	°C
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	Totalizer Meter Reading	.8178	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	Oil Temp Present	20	°C
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	Oil Temp Max	20	°C
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	5888.16	kw
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	General Comments		
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	General Comments		
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	S0063	NonLTC	786-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	BCH001152	Charger	559-Battery Charger-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	BCH001152	Charger	559-Battery Charger-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	BCH001152	Charger	559-Battery Charger-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	BCH001152	Charger	559-Battery Charger-Distribution	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	BCH001152	Charger	559-Battery Charger-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	BCH001152	Charger	559-Battery Charger-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	BCH001152	Charger	559-Battery Charger-Distribution	Battery Charger Patrol Insp	General Comments		
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Readings	Totalizer Meter Reading	.4044	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Readings	Oil Temp Present	30	°C
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Readings	Oil Temp Max	40	°C
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Readings	LTC Totalizer Reading	2426.40	kw
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Readings	General Comments		
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	General Comments		
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	C0431	WithLTC	610-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	BAT001204	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	BAT001204	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	BAT001204	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	BAT001204	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	BAT001204	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	BAT001204	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	BAT001204	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	BAT001204	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	BAT001204	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	BAT001204	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	27.2	VDC
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	BAT001204	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	28.4	VDC
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	BAT001204	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	BAT001204	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	BAT001205	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	BAT001205	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	58	°F
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	BAT001205	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	BAT001205	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	BAT001205	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	BAT001205	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	BAT001205	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	BAT001205	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	BAT001205	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	BAT001205	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	BAT001205	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	28.1	VDC
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	BAT001205	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.9	VDC
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	BAT001205	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	BAT001205	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	LTCC000757	LTCControl	648-1	LTC Control Insp	All Connections OK?	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	LTCC000757	LTCControl	648-1	LTC Control Insp	Follow-up Action Required?	n	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	LTCC000757	LTCControl	648-1	LTC Control Insp	General Comments		
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	LTCC000757	LTCControl	648-1	LTC Control Insp	LTC Operation Checked?	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	LTCC000757	LTCControl	648-1	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	LTCC000757	LTCControl	648-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	LTCC000757	LTCControl	648-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	LTCC000757	LTCControl	648-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	LTCC000757	LTCControl	648-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	All Connections OK?	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	69	°F
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	BAT001209	Battery	559-Battery Bank-Distribution	Battery Patrol Inspection	General Comments		
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Readings	LTC Totalizer Reading	5932.80	kw
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Readings	Oil Temp Max	55	°C
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Readings	Oil Temp Present	25	°C
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Readings	Totalizer Meter Reading	.6180	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Unknown Operations	0	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Switching Operations	3	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Operations This Read Vac	3	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Operations Counter AL	379	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Operations Counter AF	379	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Maintenance Operations	0	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Grounds in Place?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	General Comments		
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	General Comments		
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Foundation Condition	Good	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Follow-up Action Required?	n	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Fault Operations Ground	0	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Fault Operations C ∅	0	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Fault Operations B ∅	0	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Fault Operations A ∅	0	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Patrol Inspection	Bushing Condition	Good	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Amps C ∅	0.0	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000558	BreakerVacuum	694-302	VCB Readings	Amps B ∅	0.0	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	General Comments		
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Readings	General Comments		
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	5123.52	kw
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Readings	Oil Temp Max	40	°C
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Readings	Oil Temp Present	40	°C
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	S0025	NonLTC	888-2	NonLTC Transformer Readings	Totalizer Meter Reading	1.0674	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	General Comments		
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Readings	General Comments		
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	B0399	WithLTC	694-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	10.00	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	17.50	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	3165.12	kw
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	337	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	337	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Readings	General Comments		
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	General Comments		
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Follow-up Action Required?	n	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Fault Operations Ground	0	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Fault Operations C ∅	0	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Fault Operations B ∅	0	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Fault Operations A ∅	0	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	9 Month Operations	3	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	100.0	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	100.0	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	100.0	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.3188	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1506.24	kw
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Readings	General Comments		
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	General Comments		
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	9 Month Operations	3	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Amps A Ø	50.0	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Amps B Ø	52.0	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Amps C Ø	52.0	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Bushing Condition	Good	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	9 Month Operations	2	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Amps A Ø	170.0	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Amps B Ø	170.0	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	W0291	NonLTC	712-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	C0431	LTCMechanism	610-1	LTC Counter Readings	Follow-up Action Required?	n	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	C0431	LTCMechanism	610-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	C0431	LTCMechanism	610-1	LTC Counter Readings	General Comments		
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	C0431	LTCMechanism	610-1	LTC Mechanism Patrol Inspection	General Comments		
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	C0431	LTCMechanism	610-1	LTC Counter Readings	LTC As Found Counter	799	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	C0431	LTCMechanism	610-1	LTC Counter Readings	LTC As Left Counter	803	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	C0431	LTCMechanism	610-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	C0431	LTCMechanism	610-1	LTC Counter Readings	LTC Current Tap Position	10L	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	C0431	LTCMechanism	610-1	LTC Counter Readings	LTC Max Tap Position	8L	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	C0431	LTCMechanism	610-1	LTC Counter Readings	LTC Min Tap Position	13L	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	C0431	LTCMechanism	610-1	LTC Counter Readings	LTC Operations Since Last Insp	7	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	C0431	LTCMechanism	610-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	C0431	LTCMechanism	610-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	C0431	LTCMechanism	610-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	General Comments		
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	General Comments		
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	LTC Totalizer Reading	1896.48	kw
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	Oil Temp Max	45	°C
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	Oil Temp Present	35	°C
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	Totalizer Meter Multiplier	3600	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	Totalizer Meter Reading	.5268	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	Winding Temp Max	0	°C
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	Winding Temp Present	0	°C
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	W0352	WithLTC	640-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6276	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	W0276	NonLTC	508-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Counter Readings	Follow-up Action Required?	n	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Mechanism Patrol Inspection	General Comments		
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Counter Readings	General Comments	Min arm sticks when resetting	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Counter Readings	LTC As Found Counter	4005	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Counter Readings	LTC As Left Counter	4014	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Counter Readings	LTC Current Tap Position	10L	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Counter Readings	LTC Max Tap Position	8L	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Counter Readings	LTC Min Tap Position	12L	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Counter Readings	LTC Operations Since Last Insp	586	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	W0352	LTCMechanism	640-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Readings	Unknown Operations	0	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Reading	.6200	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Tank Leaks	None	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Tank 3 Oil Level	Good	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Tank 2 Oil level	Good	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Tank 1 Oil Level	Good	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Readings	Switching Operations	0	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Pressure Vessel Condition	Good	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Pop-off Valve Tested Date	2020-11-04 00:00:00.000000	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Readings	Operations This Read Oil	0	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Readings	Operations Counter AL	55	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Readings	Operations Counter AF	55	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Readings	Number of Ops last 9 Months	0	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Readings	Maintenance Operations	0	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Heaters (All) Functioning?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Grounds in Place?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Readings	General Comments		
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	General Comments		
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Foundation Condition	Good	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Readings	Follow-up Action Required?	n	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Readings	Fault Operations	0	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	BAT001401	Battery	610-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	BAT001401	Battery	610-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	BAT001401	Battery	610-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.5	VDC
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	BAT001401	Battery	610-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.2	VDC
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	BAT001401	Battery	610-Battery Bank	Battery Patrol Inspection	General Comments		
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	BAT001401	Battery	610-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	BAT001401	Battery	610-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	BAT001401	Battery	610-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	BAT001401	Battery	610-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	BAT001401	Battery	610-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	BAT001401	Battery	610-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	BAT001401	Battery	610-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	BAT001401	Battery	610-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	General Comments		
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Readings	General Comments		
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Readings	LTC Totalizer Reading	1036.80	kw
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Readings	Oil Temp Max	55	°C
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Readings	Oil Temp Present	35	°C
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Readings	Totalizer Meter Reading	.1728	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	WithLTC	733-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Counter Readings	LTC Max Tap Position	3L	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Counter Readings	LTC Current Tap Position	4L	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Counter Readings	LTC As Left Counter	47277	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Counter Readings	LTC As Found Counter	47370	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Mechanism Patrol Inspection	General Comments		
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	8	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Counter Readings	Follow-up Action Required?	n	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Counter Readings	General Comments		
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Mechanism Patrol Inspection	General Comments		
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Counter Readings	General Comments		
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Counter Readings	Follow-up Action Required?	n	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Counter Readings	LTC As Found Counter	26125	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Counter Readings	LTC As Left Counter	26128	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Counter Readings	LTC Current Tap Position	3R	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Counter Readings	LTC Max Tap Position	6R	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Counter Readings	LTC Min Tap Position	4L	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Counter Readings	LTC Operations Since Last Insp	1018	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	B0399	LTCMechanism	694-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0325	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Unknown Operations	0	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Switching Operations	1	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Operations This Read Vac	1	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Operations Counter AL	180	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Operations Counter AF	179	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	Maintenance Operations	0	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Readings	General Comments		
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	KB0103	BreakerVacuum	022-3411	VCB Patrol Inspection	Foundation Condition	Good	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Bushing Oil Level	Good	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Bushing Condition	Good	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Air Pressure OK?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Air Leaks	None	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Air Compressor Oil Status	Good	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	TB0189	BreakerOil	600-708	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	LTCC000249	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	LTCC000249	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	LTCC000249	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	LTCC000249	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	LTCC000249	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	LTCC000249	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	LTCC000249	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	LTCC000249	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Counter Readings	LTC Operations Since Last Insp	494	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	S0073	LTCMechanism	647-1	LTC Counter Readings	LTC Min Tap Position	8L	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	30	°C
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	80	°C
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	110.00	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	120.00	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Readings	Non LTC Totalizer Reading	1488.00	kw
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	C0348	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Filters Condition OK?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Readings	General Comments		
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.3	psi
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Readings	Oil Temp Max	65	°C
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Readings	Oil Temp Present	20	°C
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN37	WithLTC	LG-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BCH001302	Charger	600-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BCH001302	Charger	600-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BCH001302	Charger	600-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BCH001302	Charger	600-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BCH001302	Charger	600-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	9 Month Operations	17	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	9 Month Operations	2	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Amps A Ø	336.0	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Amps B Ø	319.0	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Amps C Ø	301.0	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Bushing Condition	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Fault Operations A Ø	0	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Fault Operations B Ø	0	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Fault Operations C Ø	0	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Fault Operations Ground	0	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Follow-up Action Required?	n	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Foundation Condition	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	General Comments		
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	General Comments		
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Grounds in Place?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Maintenance Operations	0	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Operations Counter AF	179	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Panels Dusted?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Operations Counter AL	179	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Operations This Read Vac	0	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Switching Operations	0	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	BK000726	BreakerVacuum	888-0437	VCB Readings	Unknown Operations	0	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	General Comments		
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BAT001379	Battery	600-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BAT001379	Battery	600-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1143	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Counter Readings	LTC Min Tap Position	6L	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Counter Readings	LTC Max Tap Position	3R	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Counter Readings	LTC Current Tap Position	4L	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	60	°C
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	40	°C
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	60	°C
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	40	°C
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	60	°C
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	40	°C
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Counter Readings	LTC As Left Counter	88014	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Counter Readings	LTC As Found Counter	88014	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Mechanism Patrol Inspection	General Comments	oil level needs to be checked and oil added for winter.	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Counter Readings	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0084	LTCMechanism	GL-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	170	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Counter Readings	LTC Min Tap Position	8L	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Counter Readings	LTC Max Tap Position	3L	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Counter Readings	LTC Current Tap Position	7L	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Counter Readings	LTC As Left Counter	23370	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Counter Readings	LTC As Found Counter	32370	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Mechanism Patrol Inspection	General Comments	low oil level needs to be checked and oil added.	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Counter Readings	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0083	LTCMechanism	GL-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	BCH001301	Charger	022-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	BCH001301	Charger	022-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	General Comments		
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Broom on Site?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CH000413	ControlHouse	786-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BCH001302	Charger	600-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.9	VDC
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BCH001302	Charger	600-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.9	VDC
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BCH001302	Charger	600-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BAT001379	Battery	600-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BAT001379	Battery	600-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BAT001379	Battery	600-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BAT001379	Battery	600-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BAT001379	Battery	600-Battery Bank	Battery Patrol Inspection	General Comments		
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BAT001379	Battery	600-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BAT001379	Battery	600-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BAT001379	Battery	600-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BAT001379	Battery	600-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BAT001379	Battery	600-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BAT001379	Battery	600-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	BAT001379	Battery	600-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN48	WithLTC	LG-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Amps A Ø	26.0	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	BK000611	BreakerVacuum	648-1761	VCB Readings	9 Month Operations	5	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Fault Operations A Ø	0	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Fault Operations B Ø	0	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Fault Operations C Ø	0	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Fault Operations Ground	0	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Follow-up Action Required?	n	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Foundation Condition	Good	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Maintenance Operations	1	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Operations Counter AF	179	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Operations Counter AL	179	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Operations This Read Vac	1	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Switching Operations	0	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Unknown Operations	0	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	Totalizer Meter Reading	.8160	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	Winding Temp Max	45	°C
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	Winding Temp Present	30	°C
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Unknown Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Switching Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Operations This Read Vac	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Operations Counter AL	181	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Operations Counter AF	181	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Maintenance Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Patrol Inspection	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Fault Operations Ground	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Fault Operations C Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Fault Operations B Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Fault Operations A Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Amps C Ø	717.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Amps B Ø	722.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Amps A Ø	735.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0408	BreakerVacuum	GL-14KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	BK000720	BreakerVacuum	648-1762	VCB Readings	Unknown Operations	0	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	9 Month Operations	1	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Amps A Ø	110.0	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Amps B Ø	129.0	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Amps C Ø	113.0	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Bushing Condition	Good	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	LTC Totalizer Reading	7833.60	kw
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	Oil Temp Max	45	°C
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	Oil Temp Present	30	°C
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Grounds in Place?	y	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Maintenance Operations	2	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Operations Counter AF	143	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Operations Counter AL	143	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Operations This Read Vac	2	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Switching Operations	0	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	K0158	BreakerVacuum	610-0746	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Fault Operations A Ø	0	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Fault Operations B Ø	0	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Fault Operations C Ø	0	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Fault Operations Ground	0	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Readings	Follow-up Action Required?	n	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	Foundation Condition	Good	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	BK000723	BreakerVacuum	004-1751	VCB Patrol Inspection	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	35	°C
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	55	°C
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Operations Counter AL	166	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Operations Counter AF	166	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Maintenance Operations	0	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Grounds in Place?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	General Comments		
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Foundation Condition	Good	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Follow-up Action Required?	n	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Fault Operations Ground	0	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Fault Operations C Ø	0	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Fault Operations B Ø	0	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Fault Operations A Ø	0	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	40	°C
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	40	°C
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	30	°C
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	50	°C
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	LTCC000781	LTCControl	610-1	LTC Control Insp	All Connections OK?	y	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	LTCC000781	LTCControl	610-1	LTC Control Insp	Follow-up Action Required?	n	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	LTCC000781	LTCControl	610-1	LTC Control Insp	General Comments		
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	LTCC000781	LTCControl	610-1	LTC Control Insp	LTC Operation Checked?	y	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	LTCC000781	LTCControl	610-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	LTCC000781	LTCControl	610-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	LTCC000781	LTCControl	610-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	LTCC000781	LTCControl	610-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Unknown Operations	0	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Tank Paint Condition	Good	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Switching Operations	0	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Operations This Read Vac	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	35	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	75	°C
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	35	°C
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	70	°C
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	40	°C
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	80	°C
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	Oil Temp Present	35	°C
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	35	°C
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	70	°C
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0084	WithLTC	GL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Fault Operations A Ø	0	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Fault Operations B Ø	0	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Fault Operations C Ø	0	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Fault Operations Ground	0	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	9 Month Operations	2	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Accumulated Fault Duty A Ph V	1.96	%
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Accumulated Fault Duty B Ph V	1.96	%
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Accumulated Fault Duty C Ph V	1.96	%
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Amps A Ø	44	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Amps B Ø	44	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Amps C Ø	44	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Bushing Condition	Good	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Bushing Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Foundation Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Grounds in Place?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Oil Temp Max	40	°C
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Radiator Leaks	None	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Tank Leaks	None	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0298	GroundTransformer	GL-GND TR 3	Ground Transformer Patrol Inspection	Winding Temp Max	20	°C
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Fault Operations A Ø	0	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Fault Operations C Ø	0	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Fault Operations Ground	0	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Follow-up Action Required?	n	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Bushing Condition	Good	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Amps C Ø	145.0	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Amps B Ø	150.0	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Amps A Ø	165.0	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	9 Month Operations	2	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	Oil Temp Present	35	°C
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	Oil Temp Max	35	°C
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	H2 Winding Temp Present	30	°C
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	H2 Winding Temp Max	50	°C
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0083	WithLTC	GL-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	9 Month Operations	6	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Amps A Ø	63.0	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Amps B Ø	91.0	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Amps C Ø	53.0	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Bushing Condition	Good	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Fault Operations B Ø	0	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Fault Operations C Ø	0	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Fault Operations Ground	0	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Follow-up Action Required?	n	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Foundation Condition	Good	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	General Comments		
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	General Comments		
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Grounds in Place?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Maintenance Operations	0	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Operations Counter AF	176	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Operations Counter AL	176	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Operations This Read Vac	0	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Switching Operations	0	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Unknown Operations	0	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Unknown Operations	0	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Switching Operations	0	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	General Comments		
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Readings	General Comments		
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Readings	Oil Temp Max	50	°C
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Readings	Oil Temp Present	40	°C
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Follow-up Action Required?	n	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Foundation Condition	Good	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	General Comments		
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	General Comments		
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Grounds in Place?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Maintenance Operations	0	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Operations Counter AF	176	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Operations Counter AL	176	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Operations This Read Vac	0	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Switching Operations	0	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Unknown Operations	0	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	9 Month Operations	12	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Amps A Ø	45.0	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Amps B Ø	45.0	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Amps C Ø	60.0	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Bushing Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Counter Readings	LTC Operations Since Last Insp	638	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Counter Readings	LTC Min Tap Position	7L	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Counter Readings	LTC Max Tap Position	3L	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Counter Readings	LTC Current Tap Position	3L	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Counter Readings	LTC As Left Counter	5687	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Counter Readings	LTC As Found Counter	5680	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Mechanism Patrol Inspection	General Comments		
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Counter Readings	General Comments		
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	M0055	LTCMechanism	786-1	LTC Counter Readings	Follow-up Action Required?	n	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000916	BreakerVacuum	694-0461	VCB Readings	Fault Operations A Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Operations This Read Vac	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Operations Counter AL	122	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Operations Counter AF	122	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Maintenance Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Patrol Inspection	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Fault Operations Ground	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Fault Operations C Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Fault Operations B Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Fault Operations A Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Amps C Ø	0.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Amps B Ø	0.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Amps A Ø	0.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	9 Month Operations	0	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	72	*F
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	General Comments		
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BAT001228	Battery	705-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BCH001177	Charger	705-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BCH001177	Charger	705-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BCH001177	Charger	705-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BCH001177	Charger	705-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BCH001177	Charger	705-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BCH001177	Charger	705-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BCH001177	Charger	705-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BCH001177	Charger	705-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	W0335	NonLTC	622-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Counter Readings	LTC Operations Since Last Insp	237	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Counter Readings	LTC Min Tap Position	11L	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Counter Readings	LTC Max Tap Position	7L	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Counter Readings	LTC Current Tap Position	9L	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Counter Readings	LTC As Left Counter	268367	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Counter Readings	LTC As Found Counter	268363	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Mechanism Patrol Inspection	General Comments		
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Counter Readings	General Comments		
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	B0247	LTCMechanism	585-1	LTC Counter Readings	Follow-up Action Required?	n	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Operations This Read AM	0	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Operations Counter AL	416	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Operations Counter AF	416	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Maintenance Operations	0	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	General Comments		
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Patrol Inspection	General Comments		
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Follow-up Action Required?	n	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Fault Operations Ground	0	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Fault Operations C Ø	0	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Fault Operations B Ø	0	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Fault Operations A Ø	0	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Amps C Ø	220.0	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Amps B Ø	310.0	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Amps A Ø	325.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0554	BreakerAirMagnetic	LG-4	AMCB Readings	9 Months Operations	1	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	LTCMechanism	733-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	LTCMechanism	733-1	LTC Mechanism Patrol Inspection	General Comments		
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	LTCMechanism	733-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	LTCMechanism	733-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	C0451	LTCMechanism	733-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Unknown Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1263	BreakerVacuum	GL-1337	VCB Readings	Switching Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Accumulated Fault Duty B Ph V	1.72	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Accumulated Fault Duty C Ph V	1.72	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Amps A Ø	231.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Amps B Ø	221.0	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Amps C Ø	221.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Fault Operations A Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Fault Operations B Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Fault Operations C Ø	0	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	BCH001359	Charger	407-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.020	millivolts
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	BCH001359	Charger	407-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	BCH001359	Charger	407-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	BCH001359	Charger	407-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	BCH001359	Charger	407-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	BCH001359	Charger	407-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	BCH001359	Charger	407-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	BCH001359	Charger	407-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	9 Month Operations	18	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Accumulated Fault Duty A Ph V	0	%
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Accumulated Fault Duty B Ph V	0	%
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Accumulated Fault Duty C Ph V	0	%
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Amps A Ø	120	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Amps B Ø	115	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Amps C Ø	120	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Bushing Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Fault Operations Ground	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Follow-up Action Required?	n	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Readings	Totalizer Meter Reading	.5076	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Readings	Oil Temp Present	45	°C
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Readings	Oil Temp Max	55	°C
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Readings	General Comments		
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	General Comments		
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Readings	LTC Totalizer Reading	3654.72	kw
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Readings	General Comments		
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	9 Month Operations	21	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Accumulated Fault Duty A Ph V	1.72	%
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	General Comments		
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	General Comments		
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Patrol Inspection	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Maintenance Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Operations Counter AF	25	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Operations Counter AL	25	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Operations This Read Vac	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Switching Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0400	BreakerVacuum	GL-1332-2	VCB Readings	Unknown Operations	0	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BCH001371	Charger	402-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	Bushing Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	Foundation Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	Grounds in Place?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.2	psi
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	Radiator Leaks	None	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	Tank Leaks	None	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0256	GroundTransformer	AL-GND TR 2	Ground Transformer Patrol Inspection	Winding Temp Max	50	°C
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BCH001371	Charger	402-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.9	VDC
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BCH001371	Charger	402-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.9	VDC
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BCH001371	Charger	402-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.9	amps

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Fault Operations A Ø	0	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Fault Operations B Ø	0	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Fault Operations C Ø	0	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Fault Operations Ground	0	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Follow-up Action Required?	n	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Foundation Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	General Comments		
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	General Comments		
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Grounds in Place?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Maintenance Operations	0	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Operations Counter AF	337	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Operations Counter AL	337	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Operations This Read Vac	0	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Switching Operations	0	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0147	BreakerVacuum	705-0725	VCB Readings	Unknown Operations	0	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	BCH001366	Charger	647-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.030	millivolts
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	BCH001366	Charger	647-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	BCH001366	Charger	647-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	BCH001366	Charger	647-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	BCH001366	Charger	647-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	BCH001366	Charger	647-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	BCH001366	Charger	647-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	BCH001366	Charger	647-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	Winding Temp Present	30	°C
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	Winding Temp Max	35	°C
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4344	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	4170.24	kw
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	KT0034	NonLTC	634-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Unknown Operations	0	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Follow-up Action Required?	n	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Foundation Condition	Good	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	General Comments		
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	General Comments		
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Grounds in Place?	y	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Maintenance Operations	0	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Operations Counter AF	292	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Operations Counter AL	292	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Operations This Read Vac	4	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Switching Operations	4	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	KB0117	BreakerVacuum	647-2530	VCB Readings	Unknown Operations	0	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Readings	General Comments		
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Readings	LTC Totalizer Reading	164.16	kw
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-2.0	psi
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Readings	Oil Temp Max	46	°C
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Readings	Oil Temp Present	30	°C
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	2400	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Readings	Totalizer Meter Reading	.0684	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Follow-up Action Required?	n	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Foundation Condition	Good	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	General Comments		
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	General Comments		
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Grounds in Place?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Maintenance Operations	0	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Operations Counter AF	188	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Operations Counter AL	188	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Operations This Read Vac	0	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Switching Operations	0	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000945	BreakerVacuum	585-0723	VCB Readings	Unknown Operations	0	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	9 Month Operations	2	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Accumulated Fault Duty A Ph V	0	%
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Accumulated Fault Duty B Ph V	0	%
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Accumulated Fault Duty C Ph V	0	%
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Amps A Ø	60	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Amps B Ø	90	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Amps C Ø	75	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Bushing Condition	Good	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Fault Operations A Ø	0	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Fault Operations B Ø	0	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Fault Operations C Ø	0	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Fault Operations Ground	0	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Follow-up Action Required?	n	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Foundation Condition	Good	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	General Comments		
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	General Comments		
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Grounds in Place?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Maintenance Operations	0	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Operations Counter AF	195	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Operations Counter AL	195	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Operations This Read Vac	0	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Readings	Switching Operations	0	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BK000946	BreakerVacuum	585-0724	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	35	°C
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	45	°C
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	30.00	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	37.50	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Readings	Non LTC Totalizer Reading	8265.60	kw
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1700	psi
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments	Radiator leaking from the top on back of transformer	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Readings	Totalizer Meter Reading	.654	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Readings	Oil Temp Present	25	°C
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Readings	Oil Temp Max	40	°C
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	110	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	117.5	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	1569.6	kw
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	O0171	NonLTC	705-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	B0377	WithLTC	600-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	W0298	WithLTC	912-Offline-Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	8	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	210	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	210	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0323	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Reading	.5904	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Multiplier	14000	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	T0177	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	Seeping	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Bushing Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Amps C Ø	94.0	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Amps B Ø	109.0	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Amps A Ø	101.0	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	9 Month Operations	1	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	9 Month Operations	4	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	General Comments		
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Readings	General Comments		
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	2380.80	kw
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	26.00	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Readings	Top Oil Temperature Max	48	°C
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Readings	Top Oil Temperature Present	41	°C
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Readings	Totalizer Meter Reading	.7440	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Fault Operations Ground	0	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Fault Operations C Ø	0	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Fault Operations B Ø	0	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Fault Operations A Ø	0	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Bushing Condition	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Amps C Ø	88.0	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Amps B Ø	70.0	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Amps A Ø	95.0	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	9 Month Operations	5	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Unknown Operations	0	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Switching Operations	0	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Operations This Read Vac	1	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Operations Counter AL	190	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Operations Counter AF	190	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Maintenance Operations	1	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Grounds in Place?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	General Comments		
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	General Comments		
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Foundation Condition	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Follow-up Action Required?	n	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Fault Operations Ground	0	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Fault Operations C Ø	0	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Fault Operations B Ø	0	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Fault Operations A Ø	0	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000537	BreakerVacuum	508-1728	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LTCC000445	LTCControl	GL-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LTCC000445	LTCControl	GL-TRANS 2	LTC Control Insp	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LTCC000445	LTCControl	GL-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LTCC000445	LTCControl	GL-TRANS 2	LTC Control Insp	VRR Base Voltage AF	116.2	VAC
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LTCC000446	LTCControl	GL-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LTCC000446	LTCControl	GL-TRANS 1	LTC Control Insp	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LTCC000446	LTCControl	GL-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LTCC000446	LTCControl	GL-TRANS 1	LTC Control Insp	VRR Base Voltage AF	115.7	VAC
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Readings	Totalizer Meter Reading	.9306	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	9 Month Operations	2	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Amps A Ø	0.0	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Amps B Ø	0.0	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Amps C Ø	0.0	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Bushing Condition	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Fault Operations A Ø	0	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Fault Operations B Ø	0	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Fault Operations C Ø	0	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Fault Operations Ground	0	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Follow-up Action Required?	n	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps A Ø	65.0	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps B Ø	50.0	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps C Ø	35.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Readings	Oil Temp Present	40	°C
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Readings	Oil Temp Max	55	°C
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Readings	General Comments		
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	General Comments		
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	5.86	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	5.86	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	5.86	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	General Comments		
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	General Comments		
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0314	NonLTC	510-1 B	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	Maintenance Operations	1	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Patrol Inspection	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Fault Operations Ground	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Fault Operations C Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Fault Operations B Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Fault Operations A Ø	0	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	BCH001275	Charger	648-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	BCH001275	Charger	648-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	BCH001275	Charger	648-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	BCH001275	Charger	648-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.1	VDC
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	BCH001275	Charger	648-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.1	VDC
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	2	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	42	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	42	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	1	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	3.60	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	3.60	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	3.60	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Unknown Operations	0	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Switching Operations	0	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Operations This Read Vac	1	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Operations Counter AL	180	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Operations Counter AF	180	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Fault Operations A Ø	0	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Fault Operations B Ø	0	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Fault Operations C Ø	0	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Fault Operations Ground	0	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Follow-up Action Required?	n	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Patrol Inspection	General Comments		
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	General Comments		
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Maintenance Operations	0	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Operations Counter AF	186	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Operations Counter AL	186	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Operations This Read Vac	0	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Switching Operations	0	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.7	VDC
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.8	VDC
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	General Comments		
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	72	*F
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	BAT001361	Battery	648-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Unknown Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Unknown Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Switching Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Operations This Read Vac	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Operations Counter AL	182	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Operations Counter AF	182	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Maintenance Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	General Comments		
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Bushing Condition	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Amps C Ø	92.0	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Amps B Ø	54.0	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Amps A Ø	54.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	9 Month Operations	3	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Unknown Operations	0	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Switching Operations	0	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Operations This Read Vac	1	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Operations Counter AL	169	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Operations Counter AF	169	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Maintenance Operations	1	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Grounds in Place?	y	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Winding Temp Max	50	°C
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LT0255	GroundTransformer	GL-GND TR 1	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	General Comments		
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	General Comments		
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Foundation Condition	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Readings	Follow-up Action Required?	n	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000538	BreakerVacuum	508-1725	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Maintenance Operations	1	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Grounds in Place?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	General Comments		
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	General Comments		
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	100.0	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	100.0	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	100.0	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Amps C Ø	253.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Amps B Ø	262.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Amps A Ø	250.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0398	BreakerVacuum	GL-1331-2	VCB Readings	9 Month Operations	14	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	9 Month Operations	2	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Accumulated Fault Duty A Ph V	0	%
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Accumulated Fault Duty B Ph V	0	%
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Accumulated Fault Duty C Ph V	0	%
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Amps A Ø	60	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Amps B Ø	50	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Amps C Ø	45	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Patrol Inspection	Bushing Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BB0324	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	10	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 12:15	Distribution	Morganfield Quarterly Inspection	W0217	NonLTC	004-5	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Foundation Condition	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Fault Operations Ground	0	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Fault Operations C Ø	0	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Fault Operations B Ø	0	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	BK000539	BreakerVacuum	508-1726	VCB Readings	Fault Operations A Ø	0	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Readings	Oil Temp Present	40	°C
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Readings	Oil Temp Max	55	°C
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	1728.00	kw
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Readings	General Comments		
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	General Comments		
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	9 Month Operations	1	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	LTCC000876	LTCControl	559-1	LTC Control Insp	All Connections OK?	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	LTCC000876	LTCControl	559-1	LTC Control Insp	Follow-up Action Required?	n	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	LTCC000876	LTCControl	559-1	LTC Control Insp	General Comments		
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	LTCC000876	LTCControl	559-1	LTC Control Insp	LTC Operation Checked?	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	LTCC000876	LTCControl	559-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	LTCC000876	LTCControl	559-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	LTCC000876	LTCControl	559-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	LTCC000876	LTCControl	559-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Counter Readings	General Comments		
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Patrol Inspection	General Comments		
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Unknown Operations	0	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Switching Operations	0	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Operations This Read Vac	1	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Operations Counter AL	180	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Operations Counter AF	180	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Maintenance Operations	1	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Grounds in Place?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	General Comments	Trip CK	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	General Comments		
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Foundation Condition	Good	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Follow-up Action Required?	n	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Fault Operations Ground	0	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Fault Operations C Ø	0	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Fault Operations B Ø	0	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Patrol Inspection	Bushing Condition	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.2400	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Amps C Ø	100.0	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Amps B Ø	120.0	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Amps A Ø	120.0	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	K0122	BreakerVacuum	712-0825	VCB Readings	9 Month Operations	2	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	180	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	180	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	5	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	5	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Counter Readings	LTC Operations Since Last Insp	209	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Counter Readings	LTC Min Tap Position	7L	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Counter Readings	LTC Max Tap Position	5L	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Counter Readings	LTC Current Tap Position	6L	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Counter Readings	LTC As Left Counter	101943	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Counter Readings	LTC As Found Counter	101940	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Mechanism Patrol Inspection	General Comments		
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Counter Readings	General Comments		
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	B0377	LTCMechanism	600-1	LTC Counter Readings	Follow-up Action Required?	n	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	9 Month Operations	12	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Amps A Ø	70.0	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Amps B Ø	75.0	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Amps C Ø	65.0	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Bushing Condition	Good	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Fault Operations A Ø	0	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Fault Operations B Ø	0	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Fault Operations C Ø	0	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BK000915	BreakerVacuum	694-0460	VCB Readings	Fault Operations Ground	0	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	W0313	NonLTC	510-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	75.0	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	90.0	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	100.0	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	*F
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BCH001031	Charger	786-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BCH001031	Charger	786-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BCH001031	Charger	786-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BCH001031	Charger	786-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BCH001031	Charger	786-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.3	amps
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BCH001031	Charger	786-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BCH001031	Charger	786-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BCH001031	Charger	786-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.020	millivolts
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Fault Operations Ground	0	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	CB0192	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Fault Operations A Ø	0	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Fault Operations B Ø	0	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Fault Operations C Ø	0	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations Counter AF	171	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations Counter AL	171	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations This Read Vac	2	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	Switching Operations	0	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	KB0139	BreakerVacuum	912-Offline-Distribution	VCB Readings	Unknown Operations	1	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Fault Operations Ground	0	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Follow-up Action Required?	n	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Patrol Inspection	Foundation Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Patrol Inspection	General Comments		
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	General Comments		
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Patrol Inspection	Grounds in Place?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Maintenance Operations	0	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Operations Counter AF	179	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Operations Counter AL	179	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Operations This Read Vac	0	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Switching Operations	0	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001417	BreakerVacuum	705-0715	VCB Readings	Unknown Operations	0	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	9 Month Operations	4	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Accumulated Fault Duty A Ph V	0	%
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Accumulated Fault Duty B Ph V	0	%
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Accumulated Fault Duty C Ph V	0	%
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	BAT001090	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	BAT001090	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Foundation Condition	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	General Comments		
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	General Comments	Off-Line	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Grounds in Place?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Maintenance Operations	0	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Operations Counter AF	70	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Operations Counter AL	70	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Operations This Read Vac	0	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Switching Operations	0	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	CB0272	BreakerVacuum	888-1440	VCB Readings	Unknown Operations	0	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Counter Readings	Follow-up Action Required?	n	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Counter Readings	General Comments		
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Mechanism Patrol Inspection	General Comments		
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Counter Readings	LTC As Found Counter	37780	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Counter Readings	LTC As Left Counter	37789	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Counter Readings	LTC Current Tap Position	7L	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Counter Readings	LTC Max Tap Position	4L	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Counter Readings	LTC Min Tap Position	12L	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Counter Readings	LTC Operations Since Last Insp	759	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	S0009	LTCMechanism	508-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Readings	Oil Temp Present	38	°C
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Readings	Oil Temp Max	45	°C
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Readings	LTC Totalizer Reading	8933.76	kw
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Readings	Grounds in Place?	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Readings	General Comments		
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	General Comments		
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	W0321	WithLTC	648-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	53	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Counter Readings	LTC Min Tap Position	9L	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4L	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Counter Readings	LTC Current Tap Position	9L	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Counter Readings	LTC As Left Counter	329905	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Counter Readings	LTC As Found Counter	329905	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Counter Readings	General Comments		
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	BCH001037	Charger	LG-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	BCH001037	Charger	LG-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	BCH001037	Charger	LG-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	BCH001037	Charger	LG-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	BCH001037	Charger	LG-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.6	VDC
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	BCH001037	Charger	LG-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.6	VDC
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	BCH001037	Charger	LG-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	252	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Unknown Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Switching Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Operations Counter AL	111	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Operations Counter AF	111	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1261	BreakerVacuum	GL-Offline-Distribution	VCB Readings	Maintenance Operations	0	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.5	VDC
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.2	VDC
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BAT001068	Battery	786-Battery Bank	Battery Patrol Inspection	General Comments		
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Counter Readings	LTC Min Tap Position	13L	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Counter Readings	LTC Max Tap Position	6L	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Counter Readings	LTC Current Tap Position	12L	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Counter Readings	LTC As Left Counter	380513	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Counter Readings	LTC As Found Counter	380513	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN37	LTCMechanism	LG-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	BAT001090	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	.2	VDC
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	BAT001090	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	BAT001090	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	BAT001090	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	BAT001090	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	BAT001090	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	BAT001090	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	BAT001090	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	BAT001090	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	BAT001090	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	BCH001050	Charger	610-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	BCH001050	Charger	610-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	BCH001050	Charger	610-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	BCH001050	Charger	610-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.8	VDC
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	BCH001050	Charger	610-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.8	VDC
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Amps A Ø	110	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Amps B Ø	100	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Amps C Ø	80	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Patrol Inspection	Bushing Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Fault Operations A Ø	0	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Fault Operations B Ø	0	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Fault Operations C Ø	0	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Fault Operations Ground	0	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Follow-up Action Required?	n	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Patrol Inspection	Foundation Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Patrol Inspection	General Comments		
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	General Comments		
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Patrol Inspection	Grounds in Place?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Maintenance Operations	2	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Operations Counter AF	185	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Operations Counter AL	185	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Operations This Read Vac	2	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Switching Operations	0	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	BK001418	BreakerVacuum	705-0716	VCB Readings	Unknown Operations	0	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	PN48	LTCMechanism	LG-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Amps C Ø	0.0	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Amps B Ø	0.0	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Amps A Ø	0.0	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	9 Months Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Ambient Temp	55	*F
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Vegetation	None	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	YD000590	Yard	GL-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Unknown Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Switching Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Operations This Read Vac	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Operations Counter AL	209	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Operations Counter AF	209	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Maintenance Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Patrol Inspection	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Fault Operations Ground	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Fault Operations C Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Fault Operations B Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Fault Operations A Ø	0	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	FE000253	Fence	648-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	General Comments		
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Max Tap Position	3L	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124	volts
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Ambient Temp	72	°F
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Regulator As Left Counter	10631	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	FE000586	Fence	GL-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	ST000585	Structure	GL-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Regulator As Left Counter	15970	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123	volts
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Max Tap Position	3L	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Unknown Operations	0	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Switching Operations	0	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Operations This Read AM	0	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Operations Counter AL	272	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Operations Counter AF	272	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Maintenance Operations	0	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Patrol Inspection	General Comments	needs sign, painted over	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	General Comments		
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Follow-up Action Required?	n	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Fault Operations Ground	0	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Fault Operations C ∅	0	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Fault Operations B ∅	0	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Fault Operations A ∅	0	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0557	BreakerAirMagnetic	LG-SEC 1 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	n	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	General Comments		
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Current Tap Position	8L	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Current Tap Position	3L	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	General Comments		
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	General Comments		
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Current Tap Position	6L	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0868	Regulator	705-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	ST000523	Structure	634-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	General Comments		
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Vegetation	None	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	General Comments		
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	FE000413	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	FE000413	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	FE000413	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	FE000413	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	FE000413	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	FE000413	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	FE000413	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	General Comments		
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	FE000413	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	FE000413	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	FE000413	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	FE000413	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	ST000406	Structure	670-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	FE000413	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	FE000413	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	FE000413	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	FE000413	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Regulator As Left Counter	59177	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Amps C Ø	0.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Amps B Ø	0.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Amps A Ø	0.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Accumulated Fault Duty C Ph V	.86	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Accumulated Fault Duty B Ph V	.86	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	Accumulated Fault Duty A Ph V	.86	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0406	BreakerVacuum	GL-1335-2	VCB Readings	9 Month Operations	23	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Ambient Temp	72	*F
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	General Comments		
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Vegetation	None	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	YD000412	Yard	705-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Max Tap Position	4L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Fault Operations Ground	0	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Follow-up Action Required?	n	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Foundation Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Vegetation	None	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	General Comments		
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	General Comments		
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	General Comments		
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Grounds in Place?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Maintenance Operations	0	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Operations Counter AF	177	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Operations Counter AL	177	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Operations This Read Vac	3	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Switching Operations	3	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Unknown Operations	0	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	YD000366	Yard	022-Yard	Yard Patrol Inspection	Ambient Temp	60	*F
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Min Tap Position	10L	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Max Tap Position	6L	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	General Comments		
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Current Tap Position	8L	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	General Comments		
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	All Identified and Legible?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Amps C Ø	0.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Amps B Ø	0.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Amps A Ø	0.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	9 Month Operations	0	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Fault Operations A Ø	0	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Fault Operations B Ø	0	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Fault Operations C Ø	0	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Fault Operations Ground	0	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Follow-up Action Required?	n	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Patrol Inspection	General Comments		
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	General Comments		
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Maintenance Operations	0	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Operations Counter AF	411	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Operations Counter AL	411	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Operations This Read AM	0	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Switching Operations	0	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Tank Leaks	None	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Regulator As Left Counter	39989	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1436	Regulator	786-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Unknown Operations	0	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	General Comments		
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	FE000245	Fence	610-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	General Comments		
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	FE000498	Fence	434-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	ST000507	Structure	434-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	ST000507	Structure	434-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	ST000507	Structure	434-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Fault Operations B Ø	0	
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	ST000507	Structure	434-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	ST000507	Structure	434-Structure	Structure Patrol Inspection	General Comments		
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	ST000507	Structure	434-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	ST000507	Structure	434-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	ST000507	Structure	434-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	ST000507	Structure	434-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	ST000507	Structure	434-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	ST000507	Structure	434-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	FE000502	Fence	733-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	YD000508	Yard	733-Yard	Yard Patrol Inspection	Ambient Temp	68	°F
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	YD000508	Yard	733-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	YD000508	Yard	733-Yard	Yard Patrol Inspection	Clear of Obstacles?	n	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	YD000508	Yard	733-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	YD000508	Yard	733-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	YD000508	Yard	733-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	YD000508	Yard	733-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	YD000508	Yard	733-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	YD000508	Yard	733-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	YD000508	Yard	733-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	YD000508	Yard	733-Yard	Yard Patrol Inspection	General Comments		
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	YD000508	Yard	733-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	YD000508	Yard	733-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	YD000508	Yard	733-Yard	Yard Patrol Inspection	Vegetation	None	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	YD000508	Yard	733-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	General Comments		
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	ST000511	Structure	733-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	General Comments		
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	FE000581	Fence	LG-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	KR0044	Regulator	785-1 A	Regulator Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Vegetation	None	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	General Comments		
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	General Comments		
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Ambient Temp	60	*F
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	General Comments		
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Regulator As Left Counter	101498	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124	volts
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Max Tap Position	2L	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	General Comments		
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	R1066	Regulator	785-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	ST000422	Structure	785-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Vegetation	None	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	General Comments		
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	FE000502	Fence	733-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	FE000502	Fence	733-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	FE000502	Fence	733-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	FE000502	Fence	733-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	FE000502	Fence	733-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	FE000502	Fence	733-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	FE000502	Fence	733-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	FE000502	Fence	733-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	FE000502	Fence	733-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	FE000502	Fence	733-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	FE000502	Fence	733-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	FE000502	Fence	733-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	FE000502	Fence	733-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	FE000502	Fence	733-Fence	Fence Patrol Inspection	General Comments		
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	YD000420	Yard	785-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Maintenance Operations	1	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Operations Counter AF	138	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Operations Counter AL	138	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Operations This Read Vac	1	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Switching Operations	0	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Unknown Operations	0	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Min Tap Position	12L	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	General Comments		
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Current Tap Position	9L	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	BAT000392	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	BAT000392	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	BAT000392	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	BAT000392	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	BAT000392	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	BAT000392	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	BAT000392	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	General Comments		
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	FE000189	Fence	888-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	Ambient Temp	62	°F
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	General Comments		
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	Vegetation	None	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	YD000187	Yard	888-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	General Comments		
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Regulator As Left Counter	297732	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	General Comments		
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	ST000216	Structure	865-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Vegetation	None	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	General Comments		
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	YD000209	Yard	865-Yard	Yard Patrol Inspection	Ambient Temp	70	*F
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	General Comments		
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	FE000209	Fence	865-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Tank Leaks	None	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Fault Operations A Ø	0	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Fault Operations B Ø	0	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Fault Operations C Ø	0	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Fault Operations Ground	0	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Follow-up Action Required?	n	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Foundation Condition	Good	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	General Comments		
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	General Comments		
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Grounds in Place?	y	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	General Comments		
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Regulator As Left Counter	112184	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	57	*F
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	General Comments		
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	84	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	64	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	Amps C Ø	110	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	Amps B Ø	103	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	Amps A Ø	110	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	CX0643	RecloserHydraulic	785-0731	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	88	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Regulator As Left Counter	156352	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BAT000510	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	72	*F
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Grounds in Place?	y	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	General Comments		
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Foundation Condition	Good	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	BB0411	BreakerVacuum	733-2536	VCB Patrol Inspection	Bushing Condition	Good	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	BAT000392	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	BAT000392	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	BAT000392	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	.1	VDC
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	BAT000392	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	.3	VDC
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	BAT000392	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	BAT000392	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/4/2020 9:41	Distribution	Taylorville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/4/2020 9:41	Distribution	Taylorville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	37	*F
11/4/2020 9:41	Distribution	Taylorville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/4/2020 9:41	Distribution	Taylorville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/4/2020 9:41	Distribution	Taylorville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/4/2020 9:41	Distribution	Taylorville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/4/2020 9:41	Distribution	Taylorville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/4/2020 9:41	Distribution	Taylorville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/4/2020 9:41	Distribution	Taylorville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
11/4/2020 9:41	Distribution	Taylorville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 9:41	Distribution	Taylorville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	General Comments		
11/4/2020 9:41	Distribution	Taylorville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
11/4/2020 9:41	Distribution	Taylorville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.4	VDC
11/4/2020 9:41	Distribution	Taylorville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/4/2020 9:41	Distribution	Taylorville Quarterly Inspection	BAT000551	Battery	647-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R1092	Regulator	712-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	ST000404	Structure	694-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	General Comments		
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BAT000504	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BAT000504	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BAT000504	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BAT000504	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BAT000504	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BAT000504	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BAT000504	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BAT000504	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BAT000504	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BAT000504	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BAT000504	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BAT000504	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BAT000504	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BAT000504	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1190	Regulator	508-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	ST000214	Structure	492-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0610	Regulator	510-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	BCH000432	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	51.3	VDC
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	BCH000432	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	51.3	VDC
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	BCH000432	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	BCH000432	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	BCH000432	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Vegetation	None	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	General Comments		
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	BCH000442	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	55.4	VDC
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	BCH000442	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	BCH000442	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	BCH000454	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.2	VDC
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	BCH000454	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	52.2	VDC
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	BCH000454	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	BCH000454	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	BCH000454	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Ambient Temp	63	°F
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	General Comments		
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Vegetation	None	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	YD000230	Yard	718-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	General Comments		
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	ST000237	Structure	718-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	YD000406	Yard	585-Yard	Yard Patrol Inspection	Ambient Temp	72	°F
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Yard Lights Working?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Vegetation	None	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	General Comments		
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	YD000401	Yard	694-Yard	Yard Patrol Inspection	Ambient Temp	57	*F
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	Vegetation	Needs Attention	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	General Comments	weeds are bad around XFMR's	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	General Comments		
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	YD000241	Yard	476-Yard	Yard Patrol Inspection	Ambient Temp	72	*F
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	ST000202	Structure	458-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Unknown Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Switching Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Operations This Read Vac	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Operations Counter AL	127	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Operations Counter AF	127	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Maintenance Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Patrol Inspection	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Fault Operations Ground	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Fault Operations C Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Fault Operations B Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Fault Operations A Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Amps C Ø	0.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Amps B Ø	0.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Amps A Ø	0.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0410	BreakerVacuum	GL-GND TR 2	VCB Readings	9 Month Operations	3	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	242	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	267	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	Amps C Ø	15.6	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	Amps B Ø	16.7	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Amps C Ø	30.0	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Bushing Condition	Good	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	Amps A Ø	18.0	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	251	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	SWG000192	Switchgear	GL-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	General Comments		
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Max Tap Position	2L	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Min Tap Position	6L	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	125	volts
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Regulator As Left Counter	63450	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0899	Regulator	705-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Regulator As Left Counter	170384	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Min Tap Position	12L	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	General Comments		
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Current Tap Position	9L	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R1093	Regulator	712-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	General Comments		
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	FE000378	Fence	029-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Ambient Temp	72	*F
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	General Comments		
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Vegetation	None	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	YD000384	Yard	029-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	General Comments		
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	9 Month Operations	1	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Amps A Ø	20.0	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	YD000518	Yard	634-Yard	Yard Patrol Inspection	Ambient Temp	37	*F
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	General Comments		
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/5/2020 15:49	Distribution	Bromley Quarterly Inspection	ST000387	Structure	029-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	FE000514	Fence	634-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	K0113	BreakerVacuum	458-1404	VCB Readings	Amps B Ø	40.0	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	WX0472	RecloserHydraulic	865-1731	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Amps A Ø	23.0	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Amps B Ø	25.0	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Amps C Ø	23.0	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Battery Load Check OK?	n	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	General Comments		
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	General Comments		
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Operations Counter	9	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	WX0257	RecloserElectronic	489-0729	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	WX0166	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	WX0166	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	WX0166	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	WX0166	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	WX0166	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	WX0166	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	WX0166	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	769	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	WX0166	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	WX0166	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	WX0166	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	387	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	WX0166	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	40.0	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	WX0166	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	36.0	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	FE000242	Fence	476-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Max Tap Position	11R	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Min Tap Position	4L	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Regulator As Left Counter	69933	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Tank Leaks	None	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	General Comments		
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Max Tap Position	5L	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Regulator As Left Counter	451338	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	C0414	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	8L	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	C0414	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Max Tap Position	4L	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	C0414	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Min Tap Position	12L	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	C0414	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	989	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	C0414	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	C0414	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	C0414	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	General Comments		
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	General Comments	Could use some new spare fuse barrels because fiberglass is coming apart. Whole station needs wildlife protection. The secondary co	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	General Comments	Control Changed out This is the counter that is on this control.	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Operations Counter	1	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Tank Leaks	None	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	ST000247	Structure	476-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	General Comments		
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Max Tap Position	5L	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Fault Operations A Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Fault Operations B Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Fault Operations Ground	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Patrol Inspection	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Maintenance Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Operations Counter AF	140	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Current Tap Position	4R	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Regulator As Left Counter	36219	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	General Comments		
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Max Tap Position	5R	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Min Tap Position	1R	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Regulator As Left Counter	76104	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1050	Regulator	476-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	General Comments		
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	ST000192	Structure	888-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Operations Counter AL	140	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Operations This Read Vac	1	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Switching Operations	1	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Unknown Operations	0	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Regulator As Left Counter	903614	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1034	Regulator	458-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Regulator As Left Counter	6737	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	General Comments	sight glass needs replaced	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	9 Month Operations	3	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R1276	Regulator	489-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	PF000111	PowerFuse	GL-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	SWG000022	Switchgear	LG-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	WX0166	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	35.0	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	WX0166	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	411	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Regulator As Left Counter	144402	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Min Tap Position	4L	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	General Comments		
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	PF000111	PowerFuse	GL-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1242	Regulator	865-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Amps A Ø	0.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Amps B Ø	0.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Amps C Ø	0.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1292	BreakerVacuum	GL-14KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Follow-up Action Required?	n	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Current Tap Position	5L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	General Comments		
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Max Tap Position	4L	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.1	volts
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Regulator As Left Counter	94875	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Fault Operations Ground	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Fault Operations C Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Fault Operations B Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Fault Operations A Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Amps C Ø	0.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Amps B Ø	0.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Amps A Ø	0.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	9 Month Operations	9	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	General Comments		
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Max Tap Position	3L	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	Ambient Temp	65	*F
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Amps A Ø	105.0	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Amps B Ø	78.0	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	X0313	RecloserElectronic	647-2529	Recloser Electronic Patrol Inspection	Amps C Ø	80.0	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	General Comments		
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	General Comments		
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Unknown Operations	0	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Switching Operations	0	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	ST000327	Structure	510-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	General Comments		
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	FE000319	Fence	510-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Operations This Read Vac	0	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Operations Counter AL	400	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Operations Counter AF	400	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Maintenance Operations	0	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Grounds in Place?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	General Comments		
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	General Comments		
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Foundation Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Follow-up Action Required?	n	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Fault Operations Ground	0	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Fault Operations C Ø	0	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Fault Operations B Ø	0	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Fault Operations A Ø	0	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Patrol Inspection	Bushing Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Amps C Ø	0	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Amps B Ø	0	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Amps A Ø	0	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Accumulated Fault Duty C Ph V	0	%
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Accumulated Fault Duty B Ph V	0	%
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	Accumulated Fault Duty A Ph V	0	%
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	K0148	BreakerVacuum	705-0726	VCB Readings	9 Month Operations	7	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0578	Regulator	441-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Unknown Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Switching Operations	8	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Operations This Read Vac	8	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Operations Counter AL	195	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Operations Counter AF	195	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	Maintenance Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Readings	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1260	BreakerVacuum	GL-14KV BUS TIE SEC 3	VCB Patrol Inspection	General Comments		
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Max Tap Position	1R	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Min Tap Position	6L	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Regulator As Left Counter	73358	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Tank Leaks	None	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Current Tap Position	2L	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1349	Regulator	888-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	C0414	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	C0414	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	C0414	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	General Comments		
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	C0414	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	C0414	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	233399	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	PF000114	PowerFuse	GL-14KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	PF000114	PowerFuse	GL-14KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	PF000113	PowerFuse	GL-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	PF000113	PowerFuse	GL-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	PF000112	PowerFuse	GL-14KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	PF000112	PowerFuse	GL-14KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	PF000110	PowerFuse	GL-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	PF000110	PowerFuse	GL-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	PF000109	PowerFuse	GL-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	PF000109	PowerFuse	GL-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Regulator As Left Counter	207158	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123	volts
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Max Tap Position	3L	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	General Comments		
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0869	Regulator	705-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	C0414	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	233409	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	C0414	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1033	Regulator	458-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	Vegetation	None	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	YD000586	Yard	LG-Yard	Yard Patrol Inspection	Yard Lights Working?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Warning Signs OK?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Tank Leaks	None	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Grounds in Place?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	General Comments		
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Foundation Condition	Good	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Capacitor Condition	Good	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Cap bank CT in Good Condition?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	Bushing Condition	Good	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	CAP000031	CapacitorBank	694-302 Cap Bank	Capacitor Patrol Inspection	All Connections OK?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	122.8	volts
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Regulator As Left Counter	82946	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Panels Dusted?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	General Comments		
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	CH000370	ControlHouse	600-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Panels Dusted?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	General Comments	No breaker control to red flag	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/3/2020 14:21	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0579	Regulator	441-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Current Tap Position	1L	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1348	Regulator	888-2 B	Regulator Patrol Inspection	General Comments		
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.5	volts
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Regulator As Left Counter	46565	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	General Comments		
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Amps B Ø	0.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Amps A Ø	0.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	9 Month Operations	13	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	General Comments		
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Max Tap Position	3L	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Unknown Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Switching Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Operations This Read Vac	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Operations Counter AL	131	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Operations Counter AF	131	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Regulator As Left Counter	49288	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1355	Regulator	634-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	9 Month Operations	7	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Accumulated Fault Duty B Ph V	6.01	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Accumulated Fault Duty A Ph V	9.45	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	9 Month Operations	18	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	Vegetation	None	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	Yard Lights Working?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	ST000230	Structure	712-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	General Comments		
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	FE000231	Fence	718-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	YD000255	Yard	648-Yard	Yard Patrol Inspection	Ambient Temp	72	°F
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	YD000255	Yard	648-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	YD000255	Yard	648-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	YD000255	Yard	648-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	YD000255	Yard	648-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	YD000255	Yard	648-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	YD000255	Yard	648-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	YD000255	Yard	648-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	YD000255	Yard	648-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	YD000255	Yard	648-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	YD000255	Yard	648-Yard	Yard Patrol Inspection	General Comments	SPR system removed	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	YD000255	Yard	648-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	YD000255	Yard	648-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	YD000255	Yard	648-Yard	Yard Patrol Inspection	Vegetation	None	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	YD000255	Yard	648-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	General Comments		
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Max Tap Position	4L	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Unknown Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Switching Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Operations This Read Vac	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Operations Counter AL	123	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Operations Counter AF	123	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Maintenance Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	General Comments	ok	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Patrol Inspection	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Fault Operations Ground	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Fault Operations C ∅	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Fault Operations B ∅	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Fault Operations A ∅	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0409	BreakerVacuum	GL-GND TR 1	VCB Readings	Amps C ∅	0.0	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1354	Regulator	634-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	General Comments		
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Fault Operations Ground	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Fault Operations C Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Fault Operations B Ø	0	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	FE000420	Fence	647-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Operations Counter AF	36	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Operations Counter AL	36	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Operations This Read Vac	2	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Switching Operations	0	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Unknown Operations	2	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Amps A Ø	68.0	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Amps B Ø	65.0	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Amps C Ø	83.0	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Bushing Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Fault Operations A Ø	0	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	General Comments		
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Current Tap Position	8L	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Fault Operations A Ø	0	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	9 Months Operations	0	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Amps A Ø	130.0	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Amps B Ø	130.0	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Amps C Ø	140.0	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	BAT000355	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	BAT000355	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	BAT000355	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	BAT000355	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	BAT000355	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	BAT000355	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	BAT000355	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	BAT000355	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	BAT000355	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	BAT000355	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	.8	VDC
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	BAT000355	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	.2	VDC
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	BAT000355	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	BAT000355	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0552	BreakerAirMagnetic	LG-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	General Comments		
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	ST000426	Structure	647-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Vegetation	None	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	General Comments		
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Amps A Ø	30.0	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Amps B Ø	20.0	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Amps C Ø	20.0	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Bushing Condition	Good	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	9 Month Operations	4	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	BK000156	BreakerVacuum	786-2541	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Fault Adjusted Amps A Phase V	3.49	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Fault Adjusted Amps B Phase V	3.49	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Fault Adjusted Amps C Phase V	3.49	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Fault Operations A Ø	0	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Fault Operations B Ø	0	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Fault Operations C Ø	0	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Fault Operations Ground	0	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Follow-up Action Required?	n	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Tank Leaks	None	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Regulator As Left Counter	40289	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Maintenance Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Patrol Inspection	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Readings	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1264	BreakerVacuum	GL-GND TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/4/2020 9:41	Distribution	Taylorsville Quarterly Inspection	YD000424	Yard	647-Yard	Yard Patrol Inspection	Ambient Temp	37	*F
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Min Tap Position	9L	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Max Tap Position	8L	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1438	Regulator	786-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Foundation Condition	Good	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	General Comments		
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	General Comments		
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Grounds in Place?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	WB0147	BreakerVacuum	640-1468	VCB Readings	Maintenance Operations	0	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Amps A Ø	105.0	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Amps B Ø	100.0	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Amps C Ø	105.0	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Fault Adjusted Amps C Phase V	4.44	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Fault Operations A Ø	0	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Fault Operations B Ø	0	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Fault Operations C Ø	1	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Fault Operations Ground	0	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Follow-up Action Required?	n	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Foundation Condition	Good	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	General Comments		
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	General Comments	1 - Trip check, 1 - IC & IN	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Grounds in Place?	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Maintenance Operations	1	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Operations Counter AF	180	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Operations Counter AL	180	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Operations This Read Vac	2	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Switching Operations	0	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	YD000505	Yard	434-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	YD000505	Yard	434-Yard	Yard Patrol Inspection	General Comments		
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Regulator As Left Counter	44756	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Unknown Operations	0	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Readings	Totalizer Meter Reading	.1870	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	110.00	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	116.00	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Readings	Non LTC Totalizer Reading	149.60	kw
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Readings	General Comments		
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	General Comments		
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	B0267	NonLTC	489-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BCH000546	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BCH000546	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BCH000546	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BCH000546	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	General Comments		
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	FE000472	Fence	786-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Ambient Temp	70	*F
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	General Comments		
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Vegetation	None	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	YD000478	Yard	786-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	General Comments		
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Max Tap Position	3L	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	BCH000893	Charger	733-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.010	millivolts
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	BCH000893	Charger	733-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	General Comments		
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1241	Regulator	865-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	YD000505	Yard	434-Yard	Yard Patrol Inspection	Ambient Temp	52	*F
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	ST000480	Structure	786-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	YD000505	Yard	434-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	YD000505	Yard	434-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	YD000505	Yard	434-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	YD000505	Yard	434-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	YD000505	Yard	434-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	YD000505	Yard	434-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/4/2020 9:31	Distribution	Woodlake Quarterly Inspection	YD000505	Yard	434-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	BCH000893	Charger	733-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/4/2020 12:33	Distribution	Mid Valley Simpsonville Quarterly Inspection	BCH000893	Charger	733-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	9 Month Operations	3	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	WB0154	BreakerVacuum	648-1763	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Patrol Inspection	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Fault Operations Ground	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Fault Operations C Ø	0	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Operations Counter	302	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	General Comments	A-x3/B-x2/C-x1	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Amps C Ø	2.3	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Amps B Ø	2.3	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	WX0358	RecloserHydraulic	718-0447	Recloser Hydraulic Patrol Inspection	Amps A Ø	6.5	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Regulator As Left Counter	62667	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Max Tap Position	5L	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	General Comments		
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Fault Operations B Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Fault Operations A Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Amps C Ø	0.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Amps B Ø	0.0	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Current Tap Position	8L	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0532	Regulator	510-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Amps A Ø	0.0	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	General Comments		
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	Ambient Temp	67	*F
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	General Comments		
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	YD000224	Yard	712-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Accumulated Fault Duty C Ph V	6.01	%
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BCH000546	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BCH000546	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	BCH000546	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Min Tap Position	4L	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Max Tap Position	3L	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	General Comments		
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	General Comments		
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Readings	General Comments		
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Readings	LTC Totalizer Reading	2112.00	kw
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Readings	Oil Temp Max	30	°C
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Readings	Oil Temp Present	30	°C
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Readings	Totalizer Meter Reading	.2200	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	B0462	WithLTC	559-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R0969	Regulator	489-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	General Comments		
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	FE000133	Fence	492-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Unknown Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Switching Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Operations This Read Vac	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Operations Counter AL	204	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Operations Counter AF	204	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0402	BreakerVacuum	GL-1333-2	VCB Readings	Maintenance Operations	0	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	FE000224	Fence	712-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Amps A Ø	90.0	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Amps B Ø	110.0	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Amps C Ø	115.0	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	Vegetation	None	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	General Comments		
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	FE000216	Fence	622-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Ambient Temp	51	*F
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	13.8	volts
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	General Comments		
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Regulator As Left Counter	84418	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	General Comments		
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Regulator As Left Counter	85001	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	General Comments		
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1191	Regulator	508-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	General Comments	ok	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Unknown Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Switching Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Operations This Read Vac	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Operations Counter AL	241	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Operations Counter AF	241	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Maintenance Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Patrol Inspection	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Fault Operations Ground	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Fault Operations C Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Fault Operations B Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Fault Operations A Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Amps C Ø	88.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Amps B Ø	79.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Amps A Ø	87.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Accumulated Fault Duty C Ph V	6.01	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Accumulated Fault Duty B Ph V	6.01	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	Accumulated Fault Duty A Ph V	6.01	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0401	BreakerVacuum	GL-1333-1	VCB Readings	9 Month Operations	27	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Readings	Oil Temp Max	70	°C
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9510	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Fault Operations A Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Fault Operations B Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Amps B Ø	0.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Amps A Ø	0.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Accumulated Fault Duty C Ph V	2.58	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Accumulated Fault Duty B Ph V	2.58	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Accumulated Fault Duty A Ph V	2.58	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	9 Month Operations	25	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Fault Operations C Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Fault Operations Ground	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Patrol Inspection	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Maintenance Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Operations Counter AF	136	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Operations Counter AL	136	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Operations This Read Vac	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Switching Operations	0	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	General Comments		
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Regulator As Left Counter	55221	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	R1240	Regulator	865-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Vegetation	None	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	General Comments	UF disabled	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Vegetation	None	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	YD000217	Yard	622-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	General Comments	1 op, C phase to G	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	YD000413	Yard	600-Yard	Yard Patrol Inspection	Ambient Temp	65	*F
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Switching Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Operations This Read Vac	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Operations Counter AL	227	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Operations Counter AF	227	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Maintenance Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Patrol Inspection	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Fault Operations Ground	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Fault Operations C Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Fault Operations B Ø	0	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Operations Counter	193	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Tank Leaks	None	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KX0064	RecloserElectronic	854-0481	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	9 Month Operations	7	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Accumulated Fault Duty A Ph V	1.72	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Amps A Ø	50.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Amps B Ø	41.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Amps C Ø	51.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Fault Operations A Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Amps C Ø	0.0	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	General Comments		
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Readings	General Comments		
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2282.40	kw
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	B0260	NonLTC	441-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	General Comments		
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	General Comments		
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	General Comments		
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	General Comments		
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	ST000152	Structure	640-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Vegetation	None	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	General Comments		
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	YD000148	Yard	640-Yard	Yard Patrol Inspection	Ambient Temp	55	*F
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	General Comments		
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Patrol Inspection	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Fault Operations Ground	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Fault Operations C Ø	0	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	FE000336	Fence	785-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Fault Operations B Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Fault Operations A Ø	0	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	General Comments		
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	FE000152	Fence	508-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Amps C Ø	0.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Amps B Ø	0.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Amps A Ø	0.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Accumulated Fault Duty C Ph V	.86	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Accumulated Fault Duty B Ph V	.86	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Accumulated Fault Duty A Ph V	.86	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	9 Month Operations	24	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	General Comments		
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	5L	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	8L	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	28257	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Tank Leaks	None	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Regulator As Left Counter	39293	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Min Tap Position	10L	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Max Tap Position	8L	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	General Comments		
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Current Tap Position	8L	
11/4/2020 14:02	Distribution	Simpsonville Quarterly Inspection	R1437	Regulator	786-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	General Comments	wrong counter read last qtr is 1147 reg	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Max Tap Position	4L	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	Ambient Temp	55	°F

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Panels Dusted?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	General Comments		
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	CH000089	ControlHouse	022-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	General Comments		
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	Vegetation	None	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	YD000195	Yard	458-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 8:13	Distribution	Webcoal 2 Quarterly Inspection	ST000223	Structure	622-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	ST000408	Structure	585-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	6L	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0941	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	ST000251	Structure	610-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	General Comments		
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	General Comments		
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	115	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	107	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	Amps C Ø	16	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	Amps B Ø	21	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	Amps A Ø	20	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	BX0714	RecloserHydraulic	785-0730	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	96	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Regulator As Left Counter	251846	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	General Comments		
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	General Comments		
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Max Tap Position	4L	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	General Comments		
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	BAT000980	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	BAT000980	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.8	VDC
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	BAT000980	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	26.2	VDC
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	BAT000980	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	BAT000980	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	BAT000980	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	ST000376	Structure	854-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	General Comments		
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	Vegetation	None	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Min Tap Position	5L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	General Comments		
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/4/2020 14:04	Distribution	Shadrack Quarterly Inspection	ST000415	Structure	600-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Regulator As Left Counter	94558	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	General Comments		
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/4/2020 13:27	Distribution	Morganfield Industrial Quarterly Inspection	ST000262	Structure	648-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	9	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	General Comments	debris covering operation counter window; counter estimated	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Operations Counter	198	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	60.0	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	60.0	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	60.0	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	416	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	416	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	0	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Vegetation	None	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Switch Stick Next Test Date	2022-01-03 00:00:00.000000	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	General Comments		
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	YD000373	Yard	854-Yard	Yard Patrol Inspection	Ambient Temp	58	*F
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 9:18	Distribution	Christian Quarterly Inspection	R1035	Regulator	458-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Max Tap Position	4L	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	FE000367	Fence	854-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Regulator As Left Counter	2752	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Ambient Temp	66	*F
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Current Tap Position	3L	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	General Comments		
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Max Tap Position	1R	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Min Tap Position	6L	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Amps A Ø	40.0	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Regulator As Left Counter	72856	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Tank Leaks	None	
11/4/2020 10:34	Distribution	Spencer Chemical Quarterly Inspection	R1347	Regulator	888-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Amps B Ø	60.0	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Amps C Ø	20.0	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 15:46	Distribution	Stamping Ground Quarterly Inspection	KX0063	RecloserElectronic	854-0480	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	R0577	Regulator	441-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	General Comments		
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Regulator As Left Counter	52818	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124	volts
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Operations Counter	231	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	General Comments	A-x3/B-x2?C-x1	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Amps C Ø	50.1	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Amps B Ø	46.8	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	X0026	RecloserHydraulic	718-0446	Recloser Hydraulic Patrol Inspection	Amps A Ø	43.1	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Min Tap Position	2L	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Max Tap Position	2L	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 15:42	Distribution	Sparta Quarterly Inspection	R1018	Regulator	785-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	37	*F
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	General Comments		
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	ST000414	Structure	705-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB1262	BreakerVacuum	GL-1336	VCB Readings	Unknown Operations	0	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	SWG000126	Switchgear	LG-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	General Comments		
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	FE000407	Fence	705-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	YD000151	Yard	508-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	26.6	VDC
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	BAT000967	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Regulator As Left Counter	15313	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	FE000186	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	FE000186	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	FE000186	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	FE000186	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	W0298	LTCMechanism	912-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	778818	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	FE000186	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	FE000186	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	FE000186	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	FE000186	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	FE000186	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	FE000186	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	FE000186	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	FE000186	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	FE000186	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	FE000186	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	FE000186	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	General Comments		
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	R1193	Regulator	508-1 C	Regulator Patrol Inspection	Max Tap Position	1L	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	W0298	LTCMechanism	912-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	778832	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	W0298	LTCMechanism	912-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	W0298	LTCMechanism	912-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	11L	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	W0298	LTCMechanism	912-Offline-Distribution	LTC Counter Readings	LTC Max Tap Position	10L	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	W0298	LTCMechanism	912-Offline-Distribution	LTC Counter Readings	LTC Min Tap Position	13L	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	W0298	LTCMechanism	912-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	W0298	LTCMechanism	912-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	156	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	W0298	LTCMechanism	912-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	W0298	LTCMechanism	912-Offline-Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	W0298	LTCMechanism	912-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	LTCC000647	LTCControl	694-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	LTCC000647	LTCControl	694-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	LTCC000647	LTCControl	694-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	LTCC000647	LTCControl	694-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	LTCC000647	LTCControl	694-1	LTC Control Insp	LTC Operation Checked?	y	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	LTCC000647	LTCControl	694-1	LTC Control Insp	General Comments		
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	LTCC000647	LTCControl	694-1	LTC Control Insp	Follow-up Action Required?	n	
11/4/2020 10:30	Distribution	Pepper Pike Quarterly Inspection	LTCC000647	LTCControl	694-1	LTC Control Insp	All Connections OK?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	General Comments		
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	BCH000984	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	General Comments		
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	Ambient Temp	58	*F
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	YD000206	Yard	492-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	BCH000984	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	BCH000984	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	BCH000984	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	BCH000984	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	BAT000980	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Regulator As Left Counter	49233	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Min Tap Position	4L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/4/2020 8:22	Distribution	Zion Quarterly Inspection	FE000149	Fence	640-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	W0298	LTCMechanism	912-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	W0298	LTCMechanism	912-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	W0298	LTCMechanism	912-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	W0298	LTCMechanism	912-Offline-Distribution	LTC Counter Readings	General Comments	121.5	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Regulator As Left Counter	15828	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	BAT000980	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	BAT000980	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	BAT000980	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	BAT000980	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	BAT000980	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	BAT000980	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/4/2020 9:11	Distribution	Uniontown Quarterly Inspection	BAT000980	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	R0971	Regulator	489-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	General Comments		
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 7:55	Distribution	Fairfield Quarterly Inspection	R1353	Regulator	634-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Current Tap Position	8L	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	General Comments		
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Max Tap Position	5L	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	R0669	Regulator	510-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	General Comments		
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	ST000380	Structure	559-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Vegetation	None	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	Operating Linkage OK?	y	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	Wood Structures OK?	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Switch Stick Next Test Date	2020-11-02 00:00:00.000000	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	General Comments		
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	YD000376	Yard	559-Yard	Yard Patrol Inspection	Ambient Temp	68	*F
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	5L	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Broom on Site?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Evidence of Insects	None	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Floor Swept?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	Vegetation	None	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	General Comments		
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	Foundation Condition	Good	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	General Comments		
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	Ground Connections Intact?	y	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	YD000379	Yard	441-Yard	Yard Patrol Inspection	Ambient Temp	68	*F
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	General Comments		
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	FE000373	Fence	441-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	General Comments		
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	General Comments		
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	General Comments		
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/3/2020 14:32	Distribution	Frankfort Quarterly Inspection	ST000281	Structure	022-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	Maintenance Operations	1	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations Counter AF	246	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations Counter AL	246	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Panels Dusted?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Trash Emptied?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	CH000175	ControlHouse	GL-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	General Comments		
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/4/2020 12:37	Distribution	Warsaw East Quarterly Inspection	FE000370	Fence	559-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	General Comments		
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	ST000379	Structure	489-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Vegetation	None	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	General Comments		
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	9 Month Operations	2	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	Ambient Temp	58	*F
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	General Comments		
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	Vegetation	None	
11/4/2020 9:29	Distribution	Airline Road Quarterly Inspection	YD000321	Yard	510-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Current Tap Position	3R	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	General Comments		
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Max Tap Position	4R	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Min Tap Position	1L	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Regulator As Left Counter	53022	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Current Tap Position	9L	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	General Comments		
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Min Tap Position	11L	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	General Comments		
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/4/2020 15:31	Distribution	Scholls Quarterly Inspection	BAT000371	Battery	585-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BCH000513	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BCH000513	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BCH000513	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BCH000513	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BCH000513	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BCH000513	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	BCH000513	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123	volts
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Max Tap Position	4L	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	General Comments		
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	6L	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	5L	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	8L	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	105200	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0940	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1143	Regulator	476-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Current Tap Position	4L	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	General Comments		
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Max Tap Position	3L	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Min Tap Position	7L	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	125	volts
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Regulator As Left Counter	69369	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Tank Leaks	None	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	156428	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	YD000213	Yard	Retired Distribution	Yard Patrol Inspection	Ambient Temp	64	*F
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	YD000213	Yard	Retired Distribution	Yard Patrol Inspection	Clear of Obstacles?	y	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	YD000213	Yard	Retired Distribution	Yard Patrol Inspection	Clear of Trash?	y	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	YD000213	Yard	Retired Distribution	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	YD000213	Yard	Retired Distribution	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	YD000213	Yard	Retired Distribution	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	YD000213	Yard	Retired Distribution	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	9L	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	YD000213	Yard	Retired Distribution	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	YD000213	Yard	Retired Distribution	Yard Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	YD000213	Yard	Retired Distribution	Yard Patrol Inspection	General Comments		
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	YD000213	Yard	Retired Distribution	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	YD000213	Yard	Retired Distribution	Yard Patrol Inspection	Vegetation	None	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	YD000213	Yard	Retired Distribution	Yard Patrol Inspection	Yard Lights Working?	y	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	All Identified and Legible?	y	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	ST000220	Structure	Retired Distribution	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	4L	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
11/4/2020 10:35	Distribution	Finchville Quarterly Inspection	R0815	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Current Tap Position	6L	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	General Comments		
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Max Tap Position	5L	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Min Tap Position	8L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	124	volts
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Regulator As Left Counter	25460	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0870	Regulator	705-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Tank Leaks	None	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0593	Regulator	705-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	General Comments		
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Regulator As Left Counter	66847	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/4/2020 13:31	Distribution	Warsaw Quarterly Inspection	ST000383	Structure	441-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 14:20	Distribution	East Diamond Quarterly Inspection	R0730	Regulator	712-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 15:17	Distribution	Owenton Quarterly Inspection	R0900	Regulator	705-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Amps B Ø	120.0	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Amps A Ø	130.0	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	General Comments		
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	9 Months Operations	0	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Vegetation	None	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	116	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	139	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	Amps C Ø	7.0	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	Amps B Ø	7.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	General Comments		
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	Amps A Ø	12.0	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	112	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	9 Month Operations	16	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Panels Dusted?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Regulator As Left Counter	62983	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0399	BreakerVacuum	GL-1332-1	VCB Readings	Unknown Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Accumulated Fault Duty A Ph V	6.01	%
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	General Comments		
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Patrol Inspection	Follow-up Action Required?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Follow-up Action Required?	n	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Fault Operations Ground	0	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Fault Operations C ∅	0	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Fault Operations B ∅	0	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Evidence of Insects	None	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	General Comments		
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Fault Operations A ∅	0	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Patrol Inspection	Equipment Properly Labeled?	n	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Amps C ∅	100.0	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1149	Regulator	718-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Regulator As Left Counter	87383	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Vegetation	None	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/4/2020 11:49	Distribution	Sunoco Quarterly Inspection	WX0343	RecloserHydraulic	865-1732	Recloser Hydraulic Patrol Inspection	General Comments		
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	General Comments		
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Operations This Read Vac	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Operations Counter AL	242	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Operations Counter AF	242	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Maintenance Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	General Comments		
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	General Comments		
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Current Tap Position	7L	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	General Comments		
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1148	Regulator	718-1 B	Regulator Patrol Inspection	Max Tap Position	5L	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Patrol Inspection	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Fault Operations Ground	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Fault Operations C Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Fault Operations B Ø	0	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Vegetation	None	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Fault Operations A Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Min Tap Position	Neutral	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Max Tap Position	5R	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Accumulated Fault Duty B Ph V	6.01	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Accumulated Fault Duty C Ph V	6.01	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Amps A Ø	90.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Amps B Ø	79.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Amps C Ø	87.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	General Comments		
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	General Comments	wrong reg counter, R1149 read	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Max Tap Position	5L	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Regulator As Left Counter	132210	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Current Tap Position	3R	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/4/2020 14:12	Distribution	Overland South Quarterly Inspection	R1052	Regulator	476-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Unknown Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0405	BreakerVacuum	GL-1335-1	VCB Readings	Switching Operations	0	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	YD000375	Yard	489-Yard	Yard Patrol Inspection	Ambient Temp	69	°F
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Unknown Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Switching Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Operations This Read Vac	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Operations Counter AL	228	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	General Comments		
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Operations Counter AF	228	
11/4/2020 11:13	Distribution	Sturgis Quarterly Inspection	ST000156	Structure	508-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Ambient Temp	61	°F
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/4/2020 14:19	Distribution	Markland Dam Quarterly Inspection	FE000369	Fence	489-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	General Comments		
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Maintenance Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Patrol Inspection	General Comments		
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Fault Operations Ground	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Fault Operations C Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Fault Operations B Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Fault Operations A Ø	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Amps C Ø	226.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Amps B Ø	235.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Amps A Ø	233.0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Accumulated Fault Duty C Ph V	1.72	%
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Accumulated Fault Duty B Ph V	2.58	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	Accumulated Fault Duty A Ph V	1.72	%
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0396	BreakerVacuum	GL-1330-2	VCB Readings	9 Month Operations	30	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Maintenance Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Operations Counter AF	213	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Operations Counter AL	213	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Operations This Read Vac	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Switching Operations	0	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	LB0404	BreakerVacuum	GL-1334-2	VCB Readings	Unknown Operations	0	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	FE000399	Fence	670-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/4/2020 12:52	Distribution	Grade Lane Quarterly Inspection	SWG000063	Switchgear	GL-Swgr Sec 1 & 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	LTCC000580	LTCControl	695-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	LTCC000580	LTCControl	695-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	LTCC000580	LTCControl	695-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	LTCC000580	LTCControl	695-1	LTC Control Insp	LTC Operation Checked?	y	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	LTCC000580	LTCControl	695-1	LTC Control Insp	General Comments		
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	LTCC000580	LTCControl	695-1	LTC Control Insp	Follow-up Action Required?	n	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	LTCC000580	LTCControl	695-1	LTC Control Insp	All Connections OK?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Operations Counter AL	364	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Operations This Read AM	0	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Switching Operations	0	
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	LTCC000580	LTCControl	695-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/2/2020 14:08	Distribution	Rogers Gap Quarterly Inspection	LTCC000580	LTCControl	695-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Ambient Temp	70	*F
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/4/2020 12:59	Distribution	Poole Quarterly Inspection	R1147	Regulator	718-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations This Read Vac	1	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	Switching Operations	0	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
11/4/2020 9:55	Distribution	Overland North Quarterly Inspection	WB0108	BreakerVacuum	912-Offline-Distribution	VCB Readings	Unknown Operations	0	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/4/2020 10:37	Distribution	Morganfield City Quarterly Inspection	YD000245	Yard	610-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Patrol Inspection	General Comments	NEEDS SIGN, PAINTED OVER	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Maintenance Operations	0	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Unknown Operations	0	
11/4/2020 11:26	Distribution	Forks Of Elkhorn Quarterly Inspection	YD000404	Yard	670-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
11/4/2020 14:23	Distribution	Logan Quarterly Inspection	LB0553	BreakerAirMagnetic	LG-3	AMCB Readings	Operations Counter AF	364	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Tank Leaks	None	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Operations Counter	181	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	General Comments		
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps C Ø	90.0	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps B Ø	100.0	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	X0124	RecloserElectronic	920-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps A Ø	90.0	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Operations Counter	174	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Tank Leaks	None	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	General Comments		
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps B Ø	28.0	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps C Ø	30.0	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps A Ø	39.0	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	BX1352	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	BAT001275	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	BAT001275	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	BAT001275	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	BAT001275	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	BAT001275	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	BAT001275	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	BAT001275	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	BAT001275	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	LTCC000637	LTCControl	912-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	LTCC000637	LTCControl	912-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	LTCC000637	LTCControl	912-Offline-Distribution	LTC Control Insp	General Comments		
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	LTCC000637	LTCControl	912-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	LTCC000637	LTCControl	912-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	LTCC000637	LTCControl	912-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	LTCC000637	LTCControl	912-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	LTCC000637	LTCControl	912-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.4687	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Switching Operations	0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Amps B Ø	65.0	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Amps A Ø	65.0	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	9 Month Operations	2	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Amps C Ø	65.0	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	9 Month Operations	4	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	600	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BAT001135	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BAT001135	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Fault Operations B Ø	0	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Fault Operations A Ø	0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Fault Operations Ground	0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Fault Operations C Ø	0	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Fault Operations B Ø	0	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Fault Operations A Ø	0	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	FE000444	Fence	897-Fence	Fence Patrol Inspection	General Comments		
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Unknown Operations	0	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Operations This Read Vac	0	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Operations Counter AL	179	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Operations Counter AF	179	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Amps A Ø	110.0	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Amps B Ø	110.0	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Amps C Ø	90.0	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Counter Readings	LTC As Found Counter	17907	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Mechanism Patrol Inspection	General Comments	reset	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Counter Readings	General Comments		
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Counter Readings	Follow-up Action Required?	n	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Fault Operations A Ø	0	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Fault Operations B Ø	0	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Fault Operations C Ø	0	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Fault Operations Ground	0	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Follow-up Action Required?	n	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	General Comments		
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	General Comments		
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Maintenance Operations	0	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BAT001135	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Readings	Oil Temp Present	35	°C
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BAT001135	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BAT001135	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BAT001135	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BAT001135	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	28.8	VDC
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BAT001135	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	27.2	VDC
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BAT001135	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BAT001135	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	281.22	kw
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Readings	General Comments		
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	B0188	NonLTC	501-1 A	NonLTC Transformer Patrol Inspection	General Comments		
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	General Comments		
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Max Tap Position	3L	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Regulator As Left Counter	30562	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Counter Readings	LTC Operations Since Last Insp	118	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	°C
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	40	°C
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Counter Readings	LTC Min Tap Position	9L	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Counter Readings	LTC Max Tap Position	6L	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Counter Readings	LTC Current Tap Position	8L	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	S0070	LTCMechanism	449-1	LTC Counter Readings	LTC As Left Counter	17909	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	General Comments		
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	General Comments		
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	LTC Totalizer Reading	4538.88	kw
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	Oil Temp Max	60	°C
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Regulator As Left Counter	59574	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BCH001096	Charger	869-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	57.1	VDC
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BCH001096	Charger	869-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	57.1	VDC
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BCH001096	Charger	869-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	Oil Temp Present	30	°C
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	General Comments		
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Amps A Ø	140.0	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	General Comments		
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Readings	Totalizer Meter Reading	.4422	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Readings	Oil Temp Present	30	°C
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Readings	Oil Temp Max	55	°C
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Readings	LTC Totalizer Reading	4245.12	kw
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Readings	General Comments		
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	General Comments		
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Readings	Follow-up Action Required?	n	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	C0475	WithLTC	197-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	9 Month Operations	4	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Amps B Ø	140.0	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Readings	Amps C Ø	140.0	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0129	BreakerVacuum	869-0811	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Regulator As Left Counter	21103	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	KR0004	Regulator	447-1 C	Regulator Patrol Inspection	General Comments		
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Regulator As Left Counter	84869	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Max Tap Position	2L	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	General Comments		
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1196	Regulator	689-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	LTCC000582	LTCControl	723-1	LTC Control Insp	LTC Operation Checked?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	LTCC000582	LTCControl	723-1	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	LTCC000582	LTCControl	723-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	LTCC000582	LTCControl	723-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	LTCC000582	LTCControl	723-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Counter Readings	Follow-up Action Required?	n	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Counter Readings	General Comments		
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Counter Readings	LTC As Found Counter	35485	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Counter Readings	LTC As Left Counter	35487	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Counter Readings	LTC Current Tap Position	6L	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Counter Readings	LTC Max Tap Position	3L	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Counter Readings	LTC Min Tap Position	8L	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Counter Readings	LTC Operations Since Last Insp	137	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	B0474	LTCMechanism	677-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Operations This Read Vac	2	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Operations Counter AL	217	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Operations Counter AF	217	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Maintenance Operations	0	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	General Comments		
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	General Comments		
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Follow-up Action Required?	n	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Fault Operations Ground	0	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	General Comments	Nitro Gauge needs attention	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Readings	General Comments	Meter not functioning, Meter Dept notified and addressing issue.	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Fault Operations C Ø	0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	ST000450	Structure	897-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Unknown Operations	0	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	BK000704	BreakerVacuum	563-0868	VCB Readings	Switching Operations	2	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	Totalizer Meter Reading	.4728	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	BAT000476	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	BAT000476	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	BAT000476	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	6.7	VDC
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	BCH000616	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	BCH000616	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	BCH000616	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	BCH000616	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	BCH000616	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	BCH000616	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Readings	Totalizer Meter Reading	0.0000	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	0	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Readings	Top Oil Temperature Present	30	°C
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Readings	Top Oil Temperature Max	60	°C
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	BAT000476	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	2.3	VDC
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	BAT000476	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	BAT000476	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	BAT000476	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	BAT000476	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	BAT000476	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	BAT000476	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	BAT000476	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	BAT000476	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	67	°F
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	BAT000476	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BCH001096	Charger	869-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	10.00	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	0.00	kw
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	LTCC000582	LTCControl	723-1	LTC Control Insp	All Connections OK?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	LTCC000582	LTCControl	723-1	LTC Control Insp	Follow-up Action Required?	n	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	LTCC000582	LTCControl	723-1	LTC Control Insp	General Comments		
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-5	psi
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	W0219	NonLTC	447-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BAT001135	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BAT001135	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	52	*F
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BAT001135	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Platform/Walkway/Railing OK?	y	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	ST000326	Structure	892-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	General Comments		
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	R1289	Regulator	447-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	General Comments		
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Counter Readings	LTC Operations Since Last Insp	25465	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	*C
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	60	*C
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Counter Readings	LTC Min Tap Position	15L	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Counter Readings	LTC Max Tap Position	8R	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Counter Readings	LTC Current Tap Position	1L	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	50	*F
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BAT000372	Battery	669-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	General Comments		
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Readings	General Comments		
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Counter Readings	LTC As Left Counter	739755	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Counter Readings	LTC As Found Counter	739752	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Mechanism Patrol Inspection	General Comments	not reset	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Counter Readings	General Comments		
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Counter Readings	Follow-up Action Required?	n	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	W0272	NonLTC	689-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	W0272	NonLTC	689-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	W0272	NonLTC	689-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	General Comments		
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	General Comments		
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	LTC Totalizer Reading	13728.96	kw
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	Oil Temp Max	40	°C
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	Oil Temp Present	25	°C
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	BCH000437	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	BCH000437	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	BCH000437	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	BCH000437	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.3	VDC
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	BCH000437	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.3	VDC
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	Totalizer Meter Reading	.9534	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	Winding Temp Max	55	°C
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	Winding Temp Present	40	°C
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	C0483	WithLTC	402-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Readings	Totalizer Meter Reading	.654	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	BAT001380	Battery	677-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	BCH001304	Charger	677-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	BCH001304	Charger	677-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	BCH001304	Charger	677-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	BCH001304	Charger	677-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	BCH001304	Charger	677-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.7	amps
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	BCH001304	Charger	677-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	BCH001304	Charger	677-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	BCH001304	Charger	677-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BCH001303	Charger	669-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BCH001303	Charger	669-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BCH001303	Charger	669-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BCH001303	Charger	669-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BCH001303	Charger	669-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.4	amps
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BCH001303	Charger	669-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BCH001303	Charger	669-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53	VDC
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BCH001303	Charger	669-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	General Comments		
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	FE000854	Fence	677-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Ambient Temp	62	*F
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Readings	9 Month Operations	27	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Readings	Amps A Ø	53.0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Readings	Amps B Ø	38.0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Readings	Amps C Ø	12.0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	W0272	NonLTC	689-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	52.50	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	W0272	NonLTC	689-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.5	psi
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	W0272	NonLTC	689-1	NonLTC Transformer Patrol Inspection	General Comments		
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	W0272	NonLTC	689-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	W0272	NonLTC	689-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	W0272	NonLTC	689-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	W0272	NonLTC	689-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2092.8	kw
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Regulator As Left Counter	148433	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Min Tap Position	12L	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Max Tap Position	5L	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	R1039	Regulator	501-1 A	Regulator Patrol Inspection	Current Tap Position	8L	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	General Comments		
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Readings	General Comments		
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-5	psi
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	818.88	kw
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0274	NonLTC	669-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	52	°C
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	65	°C
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	52	°C
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	70	°C
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	55	°C
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	LTCC000306	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	LTCC000306	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	LTCC000306	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	LTCC000306	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	LTCC000306	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	LTCC000306	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	LTCC000306	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	LTCC000306	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	LTCC000306	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	General Comments		
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Readings	General Comments		
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1912.32	kw
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	General Comments		
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	General Comments		
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Maintenance Operations	0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Operations Counter AF	350	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Operations Counter AL	350	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Operations This Read Vac	1	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Switching Operations	1	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Unknown Operations	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Readings	General Comments		
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	General Comments	NEEDS NITRO	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-4.5	psi
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Readings	Oil Temp Max	30	°C
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Readings	Oil Temp Present	25	°C
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	9 Month Operations	5	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Amps A Ø	100.0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Amps B Ø	100.0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Amps C Ø	100.0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Fault Operations A Ø	0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Fault Operations B Ø	0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Fault Operations C Ø	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0106	WithLTC	LS-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	65	°C
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Fault Operations Ground	0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Follow-up Action Required?	n	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	Oil Temp Max	70	°C
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BCH001306	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Ground Lights	None	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BCH001306	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	General Comments		
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BCH001306	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BCH001306	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BCH001306	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BCH001306	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BCH001306	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0014	LTCMechanism	723-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BCH001306	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	LTC Totalizer Reading	8208.00	kw
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	General Comments		
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	General Comments		
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	BAT001380	Battery	677-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	BAT001380	Battery	677-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	BAT001380	Battery	677-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	BAT001380	Battery	677-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	BAT001380	Battery	677-Battery Bank	Battery Patrol Inspection	General Comments		
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	BAT001380	Battery	677-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	BAT001380	Battery	677-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	BAT001380	Battery	677-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	BAT001380	Battery	677-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	BAT001380	Battery	677-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	BAT001380	Battery	677-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	BAT001380	Battery	677-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	BAT001380	Battery	677-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	61	*F
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	YD000320	Yard	892-Yard	Yard Patrol Inspection	Vegetation	None	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	YD000320	Yard	892-Yard	Yard Patrol Inspection	General Comments		
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	YD000320	Yard	892-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	YD000320	Yard	892-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	YD000320	Yard	892-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	YD000320	Yard	892-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	YD000320	Yard	892-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	YD000320	Yard	892-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	YD000320	Yard	892-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	YD000320	Yard	892-Yard	Yard Patrol Inspection	Ambient Temp	63	*F
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	FE000317	Fence	725-Fence	Fence Patrol Inspection	General Comments		
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	BCH000242	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	BCH000242	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	BCH000242	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.3	VDC
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	BCH000242	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.3	VDC
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	BAT000325	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	BAT000325	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	BAT000325	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	.8	VDC
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	BAT000325	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	.2	VDC
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	BAT000325	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	BAT000325	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	BAT000325	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	BAT000325	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	BAT000325	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	BAT000325	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	BAT000325	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	BAT000325	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	BAT000325	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	CS000014	CircuitSwitcher	591-1 Trans-Rupter	Circuit Switcher Inspection	Ambient Temp	54	*F
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	CS000014	CircuitSwitcher	591-1 Trans-Rupter	Circuit Switcher Inspection	Comments		
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	CS000014	CircuitSwitcher	591-1 Trans-Rupter	Circuit Switcher Inspection	Equipment Properly Labeled?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	CS000014	CircuitSwitcher	591-1 Trans-Rupter	Circuit Switcher Inspection	Follow-up Action Required?	n	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	CS000014	CircuitSwitcher	591-1 Trans-Rupter	Circuit Switcher Inspection	SF6 Indicator Zone	OK	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	LTCC000301	LTCControl	522-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	LTCC000301	LTCControl	522-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	LTCC000301	LTCControl	522-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	LTCC000301	LTCControl	522-1	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	LTCC000301	LTCControl	522-1	LTC Control Insp	LTC Operation Checked?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	LTCC000301	LTCControl	522-1	LTC Control Insp	General Comments		
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	LTCC000301	LTCControl	522-1	LTC Control Insp	Follow-up Action Required?	n	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	LTCC000301	LTCControl	522-1	LTC Control Insp	All Connections OK?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	W0246	NonLTC	787-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5976	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BCH001308	Charger	522-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BCH001308	Charger	522-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BCH001308	Charger	522-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BCH001308	Charger	522-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BCH001308	Charger	522-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BCH001308	Charger	522-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BCH001308	Charger	522-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BCH001308	Charger	522-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	Winding Temp Present	40	°C
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	Winding Temp Max	69	°C
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	Totalizer Meter Reading	.5700	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	W0311	WithLTC	699-1	LTC Transformer Readings	Oil Temp Present	35	°C
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Unknown Operations	0	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Switching Operations	0	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	LTCC000346	LTCControl	723-2	LTC Control Insp	All Connections OK?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	LTCC000346	LTCControl	723-2	LTC Control Insp	Follow-up Action Required?	n	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	LTCC000346	LTCControl	723-2	LTC Control Insp	General Comments		
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	LTCC000346	LTCControl	723-2	LTC Control Insp	LTC Operation Checked?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	LTCC000346	LTCControl	723-2	LTC Control Insp	LTC Output Voltage Level	125.1	VAC
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	LTCC000346	LTCControl	723-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	LTCC000346	LTCControl	723-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	LTCC000346	LTCControl	723-2	LTC Control Insp	VRR Time Delay	30	Seconds
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Amps C Ø	215.0	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Amps B Ø	220.0	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Amps A Ø	220.0	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	LTCC000350	LTCControl	638-1	LTC Control Insp	All Connections OK?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	LTCC000350	LTCControl	638-1	LTC Control Insp	Follow-up Action Required?	n	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	LTCC000350	LTCControl	638-1	LTC Control Insp	General Comments		
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	LTCC000350	LTCControl	638-1	LTC Control Insp	LTC Operation Checked?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	LTCC000350	LTCControl	638-1	LTC Control Insp	LTC Output Voltage Level	123.4	VAC
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	LTCC000350	LTCControl	638-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	LTCC000350	LTCControl	638-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	LTCC000350	LTCControl	638-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	9 Month Operations	3	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Operations This Read Vac	0	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Operations Counter AL	297	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Operations Counter AF	297	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Maintenance Operations	0	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	General Comments		
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	General Comments		
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Follow-up Action Required?	n	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Fault Operations Ground	0	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Fault Operations C Ø	0	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Fault Operations B Ø	0	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Fault Operations A Ø	0	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	General Comments		
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	RC001240	RecloserHydraulic	140-0333-2	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	RC001240	RecloserHydraulic	140-0333-2	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	RC001240	RecloserHydraulic	140-0333-2	Recloser Hydraulic Patrol Inspection	Operations Counter	31	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	RC001240	RecloserHydraulic	140-0333-2	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	RC001240	RecloserHydraulic	140-0333-2	Recloser Hydraulic Patrol Inspection	General Comments		
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	RC001240	RecloserHydraulic	140-0333-2	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	RC001240	RecloserHydraulic	140-0333-2	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	RC001240	RecloserHydraulic	140-0333-2	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	RC001240	RecloserHydraulic	140-0333-2	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	0	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	RC001240	RecloserHydraulic	140-0333-2	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	RC001240	RecloserHydraulic	140-0333-2	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	RC001240	RecloserHydraulic	140-0333-2	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	0	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	RC001240	RecloserHydraulic	140-0333-2	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	RC001240	RecloserHydraulic	140-0333-2	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	RC001240	RecloserHydraulic	140-0333-2	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	RC001240	RecloserHydraulic	140-0333-2	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	0	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	RC001237	RecloserHydraulic	140-0333-1	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	RC001237	RecloserHydraulic	140-0333-1	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	BAT000350	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	8.0	VDC
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Counter Readings	Follow-up Action Required?	n	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Follow-up Action Required?	n	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Fault Operations Ground	0	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Fault Operations C Ø	0	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Fault Operations B Ø	0	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Fault Operations A Ø	0	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Counter Readings	LTC Operations Since Last Insp	294	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	°C
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	20	°C
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Counter Readings	LTC Min Tap Position	11L	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Counter Readings	LTC Max Tap Position	8L	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Counter Readings	LTC Current Tap Position	10L	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Counter Readings	LTC As Left Counter	14781	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Counter Readings	LTC As Found Counter	14773	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Mechanism Patrol Inspection	General Comments		
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	RC001237	RecloserHydraulic	140-0333-1	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	0	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	RC001237	RecloserHydraulic	140-0333-1	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	RC001237	RecloserHydraulic	140-0333-1	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	RC001237	RecloserHydraulic	140-0333-1	Recloser Hydraulic Patrol Inspection	Amps A Ø	12.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	RC001237	RecloserHydraulic	140-0333-1	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	0	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	BCH000412	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	BCH000412	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	BCH000412	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	55.1	VDC
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1454	Regulator	613-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Counter Readings	General Comments		
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	KT0050	LTCMechanism	638-1	LTC Counter Readings	Follow-up Action Required?	n	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Amps A Ø	10.0	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	9 Month Operations	8	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Unknown Operations	0	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Switching Operations	0	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Operations This Read Vac	0	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Operations Counter AL	332	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Operations Counter AF	332	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Maintenance Operations	0	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	General Comments		
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	General Comments		
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Readings	Follow-up Action Required?	n	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0145	BreakerVacuum	677-0588	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Amps C Ø	10.0	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Amps B Ø	10.0	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Counter Readings	Follow-up Action Required?	n	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Counter Readings	General Comments		
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Mechanism Patrol Inspection	General Comments		
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	BAT000350	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	BAT000350	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Counter Readings	LTC As Found Counter	10187	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	BAT000350	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	BAT000350	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	BAT000350	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	BAT000350	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	BAT000350	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	BAT000350	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	BAT000350	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	General Comments		
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Max Tap Position	3L	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Counter Readings	LTC As Left Counter	10195	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Counter Readings	LTC Current Tap Position	8L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Regulator As Left Counter	32236	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1451	Regulator	613-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	RC001237	RecloserHydraulic	140-0333-1	Recloser Hydraulic Patrol Inspection	Operations Counter	54	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	RC001237	RecloserHydraulic	140-0333-1	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	RC001237	RecloserHydraulic	140-0333-1	Recloser Hydraulic Patrol Inspection	General Comments		
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	RC001237	RecloserHydraulic	140-0333-1	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	RC001237	RecloserHydraulic	140-0333-1	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	RC001237	RecloserHydraulic	140-0333-1	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	RC001237	RecloserHydraulic	140-0333-1	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	0	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	RC001237	RecloserHydraulic	140-0333-1	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	RC001237	RecloserHydraulic	140-0333-1	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Counter Readings	LTC Max Tap Position	2R	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Counter Readings	LTC Min Tap Position	13L	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Counter Readings	LTC Operations Since Last Insp	695	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	W0311	LTCMechanism	699-1	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Unknown Operations	0	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	LTCC000855	LTCCControl	402-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	LTCC000855	LTCCControl	402-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	LTCC000855	LTCCControl	402-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	LTCC000855	LTCCControl	402-1	LTC Control Insp	LTC Output Voltage Level	125.2	VAC
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	LTCC000855	LTCCControl	402-1	LTC Control Insp	LTC Operation Checked?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	LTCC000855	LTCCControl	402-1	LTC Control Insp	General Comments		
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	LTCC000855	LTCCControl	402-1	LTC Control Insp	Follow-up Action Required?	n	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	LTCC000855	LTCCControl	402-1	LTC Control Insp	All Connections OK?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Unknown Operations	0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Switching Operations	0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Switching Operations	2	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Operations This Read Vac	2	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Operations Counter AL	175	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Operations This Read Vac	0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Operations Counter AF	175	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Maintenance Operations	0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	General Comments	oos	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	General Comments		
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	General Comments		
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Follow-up Action Required?	n	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Fault Operations Ground	0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Fault Operations C Ø	0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Fault Operations B Ø	0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Fault Operations A Ø	0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Operations Counter AL	124	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Operations Counter AF	124	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Readings	Fault Operations A Ø	0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Readings	Fault Operations B Ø	0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Readings	Fault Operations C Ø	0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Readings	Fault Operations Ground	0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Readings	Follow-up Action Required?	n	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Patrol Inspection	General Comments		
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Readings	General Comments		
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Readings	Maintenance Operations	0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Readings	Operations Counter AF	379	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Readings	Operations Counter AL	379	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Readings	Operations This Read Vac	1	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Readings	Switching Operations	1	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0044	BreakerVacuum	897-2508	VCB Readings	Unknown Operations	0	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Readings	Oil Temp Present	25	°C
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	B0321	NonLTC	725-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.0236	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	General Comments		
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Vegetation	None	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	YD000243	Yard	725-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Arching Horns Good Condition?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Free of Audible Arching?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	General Comments		
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	ST000410	Structure	669-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	General Comments		
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Counter Readings	LTC Operations Since Last Insp	2834	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Counter Readings	LTC Min Tap Position	Neutral	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Counter Readings	LTC Current Tap Position	Neutral	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Counter Readings	LTC As Left Counter	16037	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Counter Readings	LTC As Found Counter	16037	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Counter Readings	General Comments	out of service on portable	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Mechanism Patrol Inspection	General Comments		
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0537	LTCMechanism	897-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	BAT000350	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	BAT000350	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	BAT000350	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	7.6	VDC
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	General Comments		
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	FE000393	Fence	449-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Ambient Temp	57	*F
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	General Comments		
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Vegetation	None	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	YD000398	Yard	449-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	ST000401	Structure	449-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Amps C Ø	0.0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Amps B Ø	0.0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Amps A Ø	0.0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001283	BreakerVacuum	897-2510	VCB Readings	9 Month Operations	4	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	ST000249	Structure	725-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	General Comments		
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	Maintenance Operations	0	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0013	BreakerVacuum	699-1805	VCB Readings	General Comments		
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	ST000215	Structure	613-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Counter Readings	LTC Operations Since Last Insp	712	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Counter Readings	LTC Min Tap Position	8L	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Counter Readings	LTC Max Tap Position	3L	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Counter Readings	LTC Current Tap Position	8L	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Counter Readings	LTC As Left Counter	11823	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Counter Readings	LTC As Found Counter	11823	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Mechanism Patrol Inspection	General Comments		
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Counter Readings	General Comments		
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	B0393	LTCMechanism	591-1	LTC Counter Readings	Follow-up Action Required?	n	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	General Comments		
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Negative DC Ground	32.0	VDC
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Positive DC Ground	30.0	VDC
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	BCH001246	Charger	601-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	BCH001246	Charger	601-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	BCH001246	Charger	601-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	BCH001246	Charger	601-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	BCH001246	Charger	601-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	BCH001246	Charger	601-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	BCH001246	Charger	601-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Readings	9 Month Operations	18	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	General Comments		
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	ST000553	Structure	649-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Switching Operations	2	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Operations This Read Vac	2	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Operations Counter AL	260	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Operations Counter AF	260	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Maintenance Operations	0	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	General Comments		
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	General Comments		
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Follow-up Action Required?	n	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Fault Operations Ground	0	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Fault Operations C Ø	0	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Fault Operations B Ø	0	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Fault Operations A Ø	0	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Amps C Ø	45.0	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Amps B Ø	45.0	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Amps A Ø	45.0	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	9 Month Operations	7	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	General Comments		
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	Ambient Temp	64	°F
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Regulator As Left Counter	28163	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	YD000249	Yard	501-Yard	Yard Patrol Inspection	Ambient Temp	68	°F
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	YD000249	Yard	501-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	YD000249	Yard	501-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	YD000249	Yard	501-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	YD000249	Yard	501-Yard	Yard Patrol Inspection	General Comments		
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	YD000249	Yard	501-Yard	Yard Patrol Inspection	Vegetation	Needs Attention	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	General Comments		
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Platform/Walkway/Railing OK?	y	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	ST000255	Structure	501-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Readings	Amps A Ø	437.0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Readings	Amps B Ø	386.0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Readings	Amps C Ø	393.0	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	General Comments		
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Max Tap Position	4L	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	R1456	Regulator	613-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Readings	Fault Operations A Ø	0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Readings	Fault Operations B Ø	0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Readings	Fault Operations C Ø	0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Readings	Fault Operations Ground	0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Patrol Inspection	General Comments		
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Readings	General Comments		
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Readings	Maintenance Operations	0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Readings	Operations Counter AF	232	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Readings	Operations Counter AL	232	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Readings	Operations This Read Vac	0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Readings	Switching Operations	0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001127	BreakerVacuum	897-BT1-2	VCB Readings	Unknown Operations	0	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	Vegetation	None	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	YD000232	Yard	502-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Counter Readings	Follow-up Action Required?	n	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Counter Readings	General Comments		
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Mechanism Patrol Inspection	General Comments		
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Counter Readings	LTC As Found Counter	30377	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Counter Readings	LTC As Left Counter	30377	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Counter Readings	LTC Current Tap Position	Neutral	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Counter Readings	LTC Max Tap Position	3R	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Counter Readings	LTC Min Tap Position	8L	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	5	psi
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Counter Readings	LTC Operations Since Last Insp	1035	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	LTCM000033	LTCMechanism	669-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Counter Readings	Follow-up Action Required?	n	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Counter Readings	General Comments		
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Mechanism Patrol Inspection	General Comments		
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Counter Readings	LTC As Found Counter	64427	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Counter Readings	LTC As Left Counter	64430	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Counter Readings	LTC Current Tap Position	8L	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Counter Readings	LTC Max Tap Position	13L	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Counter Readings	LTC Min Tap Position	5L	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Counter Readings	LTC Operations Since Last Insp	374	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	C0373	LTCMechanism	649-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Vegetation	None	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	General Comments		
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	Winding Temp Present	25	°C
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	General Comments		
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	ST000352	Structure	723-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Regulator As Left Counter	66830	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	121.1	volts
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Max Tap Position	2L	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	General Comments		
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Current Tap Position	9L	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1041	Regulator	677-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Switching Operations	1	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Operations This Read Vac	1	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Operations Counter AL	270	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Operations Counter AF	270	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Maintenance Operations	0	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	General Comments		
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	General Comments		
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Fault Operations Ground	0	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Fault Operations C Ø	0	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Fault Operations B Ø	0	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Fault Operations A Ø	0	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Amps C Ø	175	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Amps B Ø	115	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Amps A Ø	85	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Accumulated Fault Duty C Ph V	.77	%
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Accumulated Fault Duty B Ph V	.77	%
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Accumulated Fault Duty A Ph V	0	%
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	9 Month Operations	1	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	K0188	BreakerVacuum	563-0867	VCB Readings	Unknown Operations	0	
11/3/2020 13:57	Distribution	Beattville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/3/2020 13:57	Distribution	Beattville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/3/2020 13:57	Distribution	Beattville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/3/2020 13:57	Distribution	Beattville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/3/2020 13:57	Distribution	Beattville City Quarterly Inspection	YD000547	Yard	649-Yard	Yard Patrol Inspection	Ambient Temp	60	*F
11/3/2020 13:57	Distribution	Beattville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2020 13:57	Distribution	Beattville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	General Comments		
11/3/2020 13:57	Distribution	Beattville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/3/2020 13:57	Distribution	Beattville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/3/2020 13:57	Distribution	Beattville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/3/2020 13:57	Distribution	Beattville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/3/2020 13:57	Distribution	Beattville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 13:57	Distribution	Beattville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/3/2020 13:57	Distribution	Beattville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/3/2020 13:57	Distribution	Beattville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/3/2020 13:57	Distribution	Beattville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/3/2020 13:57	Distribution	Beattville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/3/2020 13:57	Distribution	Beattville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/3/2020 13:57	Distribution	Beattville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/3/2020 13:57	Distribution	Beattville City Quarterly Inspection	FE000542	Fence	649-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	Winding Temp Max	60	°C
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	Totalizer Meter Reading	.5988	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	Oil Temp Present	25	°C
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	Oil Temp Max	60	°C
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	LTC Totalizer Reading	5748.48	kw
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	General Comments		
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	General Comments		
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Fans Operational?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	S0070	WithLTC	449-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0095	BreakerVacuum	669-0421	VCB Readings	Unknown Operations	0	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Operations Counter AL	166	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Operations This Read Vac	1	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Switching Operations	1	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Unknown Operations	0	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	General Comments		
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Ambient Temp	67	°F
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	General Comments		
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Vegetation	None	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	YD000207	Yard	613-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Yard Lights Working?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Vegetation	None	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	General Comments		
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Clear of Trash?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Fault Operations Ground	0	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Follow-up Action Required?	n	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Patrol Inspection	General Comments		
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	General Comments	T on A and G	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Maintenance Operations	0	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Operations Counter AF	167	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Operations Counter AL	167	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Operations This Read Vac	2	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Switching Operations	1	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Unknown Operations	0	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	9 Month Operations	4	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Amps A Ø	175.0	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Amps B Ø	145.0	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Amps C Ø	190.0	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Fault Operations A Ø	0	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Fault Operations B Ø	0	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Fault Operations C Ø	0	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Fault Operations Ground	0	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Follow-up Action Required?	n	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Patrol Inspection	General Comments		
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	General Comments		
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Maintenance Operations	0	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001151	BreakerVacuum	402-0501	VCB Readings	Operations Counter AF	166	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Amps C Ø	175	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Amps B Ø	155	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Amps A Ø	140	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Accumulated Fault Duty C Ph V	.77	%
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Accumulated Fault Duty B Ph V	.77	%
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Accumulated Fault Duty A Ph V	1.54	%
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	9 Month Operations	1	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Current Tap Position	9L	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	General Comments	ok	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	ST000240	Structure	502-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	General Comments		
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Clear of Obstacles?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	YD000449	Yard	897-Yard Distribution	Yard Patrol Inspection	Ambient Temp	43	°F
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Regulator As Left Counter	104542	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Min Tap Position	10L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Max Tap Position	6L	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1094	Regulator	787-1 A	Regulator Patrol Inspection	General Comments		
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Unknown Operations	0	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Switching Operations	1	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Operations This Read Vac	1	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Operations Counter AL	286	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Operations Counter AF	286	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Maintenance Operations	0	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	General Comments		
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Follow-up Action Required?	n	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Fault Operations Ground	0	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Fault Operations C Ø	0	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Fault Operations B Ø	0	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Fault Operations A Ø	0	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	K0094	BreakerVacuum	669-0420	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	General Comments		
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Vegetation	None	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	General Comments		
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	YD000315	Yard	762-Yard	Yard Patrol Inspection	Ambient Temp	58	°F
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	FE000310	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	FE000310	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	FE000310	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	FE000310	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	FE000310	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	FE000310	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	FE000310	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	FE000310	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	FE000310	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	FE000310	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	FE000310	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	FE000310	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	FE000262	Fence	869-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3766	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	200	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Readings	Oil Temp Max	30	°C
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	75.32	kw
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Readings	General Comments		
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	General Comments		
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	C0355	NonLTC	892-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Unknown Operations	0	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Switching Operations	0	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Operations This Read Vac	1	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Operations Counter AL	182	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	ST000322	Structure	762-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Fault Operations A Ø	0	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Amps C Ø	50.0	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Amps B Ø	20.0	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Amps A Ø	40.0	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	9 Month Operations	1	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Operations Counter AF	195	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Operations Counter AL	195	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Operations This Read Vac	2	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Switching Operations	2	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Unknown Operations	0	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	9 Month Operations	7	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Amps A Ø	90.0	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Amps B Ø	85.0	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Amps C Ø	90.0	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Fault Adjusted Amps A Phase V	5.99	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Fault Operations A Ø	1	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Fault Operations B Ø	0	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001150	BreakerVacuum	402-0500	VCB Readings	Fault Operations C Ø	0	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	FE000310	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	FE000310	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	FE000310	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	FE000208	Fence	613-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	9 Month Operations	3	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Amps A Ø	125.0	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Amps B Ø	125.0	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Amps C Ø	95.0	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Fault Operations A Ø	0	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Fault Operations B Ø	0	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Fault Operations C Ø	0	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Fault Operations Ground	0	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Follow-up Action Required?	n	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Patrol Inspection	General Comments		
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	General Comments		
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BK001149	BreakerVacuum	402-0515	VCB Readings	Maintenance Operations	0	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Operations Counter AF	182	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Maintenance Operations	1	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	General Comments		
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	General Comments		
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Follow-up Action Required?	n	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Fault Operations Ground	0	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Fault Operations C Ø	0	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	WB0158	BreakerVacuum	502-1427	VCB Readings	Fault Operations B Ø	0	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	General Comments		
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Counter Readings	Follow-up Action Required?	n	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Counter Readings	General Comments		
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Mechanism Patrol Inspection	General Comments		
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Counter Readings	LTC As Found Counter	7608	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Counter Readings	LTC As Left Counter	7610	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Counter Readings	LTC Current Tap Position	4L	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Counter Readings	LTC Max Tap Position	4L	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Counter Readings	LTC Min Tap Position	7L	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Counter Readings	LTC Operations Since Last Insp	454	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	KT0032	LTCMechanism	522-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	General Comments		
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	°C
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Readings	Winding Temp Present	50	°C
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Readings	Winding Temp Max	50	°C
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Readings	Totalizer Meter Reading	.8100	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Readings	Oil Temp Present	50	°C
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Readings	Oil Temp Max	55	°C
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1700	psi
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Readings	LTC Totalizer Reading	11664.00	kw
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Readings	General Comments		
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	General Comments		
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	KT0032	WithLTC	522-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C \emptyset	0	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B \emptyset	0	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A \emptyset	0	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Amps C \emptyset	10.0	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Amps B \emptyset	25.0	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Amps A \emptyset	10.0	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	0	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Accumulated Fault Duty B Ph V	.7	%
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Accumulated Fault Duty C Ph V	.7	%
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Amps A \emptyset	95	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Amps B \emptyset	100	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Amps C \emptyset	75	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Fault Adjusted Amps B Phase V	9.37	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	ST000368	Structure	402-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Regulator As Left Counter	437830	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/3/2020 14:38	Distribution	Fies City Quarterly Inspection	R1209	Regulator	892-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	BCH001223	Charger	699-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	BCH001223	Charger	699-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	56.2	VDC
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	BCH001223	Charger	699-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	56.2	VDC
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	BCH001223	Charger	699-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	BCH001223	Charger	699-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	BCH001223	Charger	699-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	9 Month Operations	7	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Accumulated Fault Duty A Ph V	.7	%
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	1042	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	1042	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	105.00	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1148.80	kw
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Readings	General Comments		
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	General Comments		
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.0150	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	600	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Readings	Oil Temp Max	5025	°C
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	26.00	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	9.00	kw

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Readings	General Comments		
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	General Comments		
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0220	NonLTC	651-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	General Comments		
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	C0536	NonLTC	140-1 AC	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Readings	Totalizer Meter Reading	.7180	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	C0349	NonLTC	677-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1600	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	200	psi
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	Oil Temp Max	70	°C
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	Oil Temp Present	40	°C
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	Totalizer Meter Reading	.9350	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	Winding Temp Max	45	°C
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	Winding Temp Present	45	°C
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	General Comments		
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	Follow-up Action Required?	n	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	General Comments		
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	General Comments		
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	LTC Totalizer Reading	14486.40	kw
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	400	psi
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	Oil Temp Max	60	°C
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	Oil Temp Present	40	°C
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	Totalizer Meter Reading	1.0060	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	Winding Temp Max	50	°C
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	Winding Temp Present	40	°C
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0014	WithLTC	723-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	General Comments		
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	General Comments		
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	LTC Totalizer Reading	13464.00	kw
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	General Comments	Ct bonding wire needs to be repaired work order already written.	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Free of Audible Arcing?	n	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Vegetation	None	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	General Comments		
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	ST000271	Structure	869-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	General Comments		
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	General Comments		
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	YD000349	Yard	723-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	ST000445	Structure	638-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	LTCC000784	LTCControl	699-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	LTCC000784	LTCControl	699-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	LTCC000784	LTCControl	699-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	LTCC000784	LTCControl	699-1	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	LTCC000784	LTCControl	699-1	LTC Control Insp	LTC Operation Checked?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	LTCC000784	LTCControl	699-1	LTC Control Insp	General Comments		
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	LTCC000784	LTCControl	699-1	LTC Control Insp	Follow-up Action Required?	n	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	LTCC000784	LTCControl	699-1	LTC Control Insp	All Connections OK?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	General Comments		
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	ST000229	Structure	447-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	General Comments		
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	FE000345	Fence	723-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	General Comments	Wildlife Prot needed	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	ST000225	Structure	787-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Vegetation	None	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	General Comments		
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	YD000220	Yard	787-Yard	Yard Patrol Inspection	Ambient Temp	70	*F
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	FE000220	Fence	787-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	General Comments		
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Fault Operations B Ø	0	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Fault Operations C Ø	0	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	LTCC000162	LTCControl	449-1	LTC Control Insp	All Connections OK?	y	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	LTCC000162	LTCControl	449-1	LTC Control Insp	Follow-up Action Required?	n	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	LTCC000162	LTCControl	449-1	LTC Control Insp	General Comments		
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	LTCC000162	LTCControl	449-1	LTC Control Insp	LTC Operation Checked?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Unknown Operations	0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Switching Operations	1	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	LTCC000162	LTCControl	449-1	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	LTCC000162	LTCControl	449-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	LTCC000162	LTCControl	449-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	LTCC000162	LTCControl	449-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	LTCC000162	LTCControl	449-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Operations This Read Vac	1	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Operations Counter AL	337	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Operations Counter AF	337	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Maintenance Operations	0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Fault Operations Ground	0	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Fault Operations A Ø	0	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Fault Operations B Ø	2	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Fault Operations C Ø	0	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Fault Operations Ground	0	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Follow-up Action Required?	n	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	General Comments		
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	General Comments		
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	SWG000074	Switchgear	LS-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Maintenance Operations	0	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Operations Counter AF	184	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Operations Counter AL	184	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Operations This Read Vac	5	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Switching Operations	3	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001035	BreakerVacuum	669-0425	VCB Readings	Unknown Operations	0	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	9 Month Operations	3	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Accumulated Fault Duty A Ph V	0	%
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Accumulated Fault Duty B Ph V	0	%
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Accumulated Fault Duty C Ph V	0	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Amps A Ø	45	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Amps B Ø	45	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Amps C Ø	60	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Fault Operations A Ø	0	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	ST000364	Structure	522-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	General Comments		
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	General Comments		
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Vegetation	None	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	YD000408	Yard	669-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	General Comments		
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Max Tap Position	3R	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Regulator As Left Counter	56548	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	R1288	Regulator	447-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Follow-up Action Required?	n	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	General Comments		
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	General Comments		
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Maintenance Operations	0	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Operations Counter AF	194	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Operations Counter AL	194	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Operations This Read Vac	1	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Switching Operations	1	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	BK001036	BreakerVacuum	669-0427	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	General Comments		
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	General Comments		
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Follow-up Action Required?	n	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Fault Operations Ground	0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Fault Operations C Ø	0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Fault Operations B Ø	0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Fault Operations A Ø	0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Amps C Ø	188.0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Amps B Ø	142.0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Amps A Ø	187.0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0139	BreakerVacuum	897-2509	VCB Readings	9 Month Operations	4	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	FE000223	Fence	447-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	5.0	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	5.0	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	5.0	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	181	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	181	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	General Comments	1407T needs linkage ground installed	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	General Comments		
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	General Comments		
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Maintenance Operations	0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Operations Counter AF	297	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Operations Counter AL	297	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Operations This Read Vac	0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Switching Operations	0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Unknown Operations	0	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	General Comments		
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Vegetation	None	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Vegetation	None	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	General Comments		
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	FE000411	Fence	669-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Ambient Temp	38	*F
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	General Comments		
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Vegetation	None	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	YD000443	Yard	638-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Current Tap Position	12L	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Readings	9 Month Operations	3	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Readings	Amps A Ø	0.0	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Regulator As Left Counter	70025	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	120.9	volts
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Min Tap Position	11L	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Max Tap Position	2L	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	General Comments		
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	ST000331	Structure	689-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Regulator As Left Counter	67720	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	119.4	volts
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Min Tap Position	12L	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Max Tap Position	6L	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	General Comments		
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1042	Regulator	677-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	General Comments		
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	ST000499	Structure	140-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Amps C Ø	350.0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Amps B Ø	350.0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Amps A Ø	350.0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	9 Month Operations	2	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	RC000754	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	RC000754	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	RC000754	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	189	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	RC000754	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	RC000754	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	RC000754	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	RC000754	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	RC000754	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	RC000754	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	RC000754	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	LTCC000744	LTCControl	669-2	LTC Control Insp	VRR Time Delay	30	Seconds
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	LTCC000744	LTCControl	669-2	LTC Control Insp	VRR Base Voltage AL	124	VAC
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	LTCC000744	LTCControl	669-2	LTC Control Insp	VRR Base Voltage AF	124	VAC
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	LTCC000744	LTCControl	669-2	LTC Control Insp	LTC Output Voltage Level	124	VAC
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	LTCC000744	LTCControl	669-2	LTC Control Insp	LTC Operation Checked?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	LTCC000744	LTCControl	669-2	LTC Control Insp	General Comments		
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	LTCC000744	LTCControl	669-2	LTC Control Insp	Follow-up Action Required?	n	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	LTCC000744	LTCControl	669-2	LTC Control Insp	All Connections OK?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Counter Readings	Follow-up Action Required?	n	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Counter Readings	General Comments		
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	General Comments		
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Mechanism Patrol Inspection	General Comments	not reset	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Counter Readings	LTC As Found Counter	61727	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Counter Readings	LTC As Left Counter	61729	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Fault Operations Ground	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Fault Operations C Ø	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Fault Operations B Ø	1	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Fault Operations A Ø	1	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Amps C Ø	440.0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Amps B Ø	400.0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Amps A Ø	360.0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	9 Month Operations	5	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Unknown Operations	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Switching Operations	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Operations This Read Vac	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Operations Counter AL	143	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Operations Counter AF	143	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Maintenance Operations	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	General Comments		
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	General Comments		
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Follow-up Action Required?	n	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Fault Operations Ground	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Fault Operations C Ø	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Fault Operations B Ø	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Fault Operations A Ø	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000763	BreakerVacuum	LS-12KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Ambient Temp	65	*F
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Ambient Temp	50	*F
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	YD000264	Yard	869-Yard	Yard Patrol Inspection	General Comments		
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Ambient Temp	54	*F
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	YD000514	Yard	591-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	9 Month Operations	7	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Amps A Ø	0.0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Amps B Ø	0.0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Amps C Ø	0.0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Fault Operations A Ø	0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Fault Operations B Ø	0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Fault Operations C Ø	0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Fault Operations Ground	0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0013	BreakerVacuum	723-BT1-2	VCB Readings	Follow-up Action Required?	n	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Counter Readings	LTC Current Tap Position	2L	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Counter Readings	LTC Max Tap Position	2R	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Counter Readings	LTC Min Tap Position	11L	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	60	*C
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	*C
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Counter Readings	LTC Operations Since Last Insp	1390	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KT0011	LTCMechanism	723-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	General Comments		
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Vegetation	None	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	General Comments		
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	YD000223	Yard	447-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	228	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	228	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	General Comments		
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	Vegetation	None	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	General Comments		
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Fault Operations Ground	0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Follow-up Action Required?	n	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	General Comments		
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	General Comments		
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Maintenance Operations	0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Operations Counter AF	301	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Operations Counter AL	301	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Operations This Read Vac	0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Switching Operations	0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Unknown Operations	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	PF000200	PowerFuse	LS-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	PF000200	PowerFuse	LS-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	ST000333	Structure	699-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	8	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	10.0	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	15.0	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	10.0	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Readings	General Comments		
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	General Comments		
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Vegetation	None	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	General Comments		
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Readings	Oil Temp Present	25	°C
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Readings	Oil Temp Max	55	°C
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	40.00	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	46.00	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	YD000325	Yard	689-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	General Comments		
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	FE000322	Fence	689-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Readings	General Comments		
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	General Comments		
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0222	NonLTC	651-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	YD000327	Yard	699-Yard	Yard Patrol Inspection	Ambient Temp	58	°F
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	General Comments		
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	FE000324	Fence	699-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Counter Readings	Follow-up Action Required?	n	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Counter Readings	General Comments		
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Mechanism Patrol Inspection	General Comments		
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Counter Readings	LTC As Found Counter	35882	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Counter Readings	LTC As Left Counter	35886	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Counter Readings	LTC Current Tap Position	4L	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Counter Readings	LTC Max Tap Position	1L	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Counter Readings	LTC Min Tap Position	8L	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Counter Readings	LTC Operations Since Last Insp	568	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	C0483	LTCMechanism	402-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Readings	Oil Temp Present	25	°C
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Readings	Oil Temp Max	50	°C
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	26.00	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	W0221	NonLTC	651-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Readings	Switching Operations	2	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Readings	Unknown Operations	0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Unknown Operations	0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Switching Operations	0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Operations This Read Vac	0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Operations Counter AL	444	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Operations Counter AF	444	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Maintenance Operations	0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	General Comments		
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	General Comments		
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Follow-up Action Required?	n	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Fault Operations Ground	0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Fault Operations C ∅	0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Fault Operations B ∅	0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Fault Operations A ∅	0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	General Comments		
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Follow-up Action Required?	n	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Fault Operations Ground	0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Fault Operations C Ø	0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Fault Operations B Ø	0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Fault Operations A Ø	0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Current Tap Position	9L	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	R1040	Regulator	677-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Unknown Operations	0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Switching Operations	0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Operations This Read Vac	0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Operations Counter AL	248	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Operations Counter AF	248	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Maintenance Operations	0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	General Comments		
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Readings	Amps B Ø	0.0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Readings	Amps C Ø	0.0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Readings	Fault Operations A Ø	0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Readings	Fault Operations B Ø	0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Readings	Fault Operations C Ø	0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Readings	Fault Operations Ground	0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Readings	Follow-up Action Required?	n	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Patrol Inspection	General Comments		
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Readings	General Comments	out of service on portable	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Readings	Maintenance Operations	0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Readings	Operations Counter AF	189	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Readings	Operations Counter AL	189	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK001249	BreakerVacuum	897-1	VCB Readings	Operations This Read Vac	2	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	9 Month Operations	4	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Amps A Ø	260.0	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Amps B Ø	320.0	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Amps C Ø	300.0	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Fault Operations A Ø	0	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Fault Operations B Ø	0	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Fault Operations C Ø	0	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Fault Operations Ground	0	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Follow-up Action Required?	n	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	General Comments		
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	General Comments	counter hard to read	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Maintenance Operations	0	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Operations Counter AF	158	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Operations Counter AL	158	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Operations This Read Vac	0	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Switching Operations	0	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	K0136	BreakerVacuum	699-1	VCB Readings	Unknown Operations	0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Fault Operations A Ø	0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Fault Operations B Ø	0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Fault Operations C Ø	0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Amps C Ø	500.0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Amps B Ø	495.0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Amps A Ø	465.0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0014	BreakerVacuum	723-1	VCB Readings	9 Month Operations	1	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Amps C Ø	200.0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Amps B Ø	180.0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Amps A Ø	190.0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	9 Month Operations	5	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	9 Month Operations	2	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	General Comments		
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	FE000439	Fence	638-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Amps A Ø	100.0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Amps B Ø	100.0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Amps C Ø	100.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Patrol Inspection	General Comments		
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	General Comments		
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Maintenance Operations	0	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Operations Counter AF	157	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Operations Counter AL	157	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Operations This Read Vac	0	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Switching Operations	0	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Unknown Operations	0	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	9 Month Operations	3	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Amps A Ø	45.0	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Amps B Ø	45.0	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Amps C Ø	45.0	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Fault Operations A Ø	0	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Fault Operations A Ø	0	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Fault Operations B Ø	0	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Fault Operations C Ø	0	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Fault Operations Ground	0	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Follow-up Action Required?	n	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	General Comments		
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	General Comments		
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Ambient Temp	65	*F
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	General Comments		
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Vegetation	None	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	9 Month Operations	3	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Amps A Ø	345.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Amps B Ø	260.0	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Amps C Ø	360.0	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Fault Operations A Ø	0	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Fault Operations B Ø	0	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Fault Operations C Ø	0	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Fault Operations Ground	0	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Readings	Follow-up Action Required?	n	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001166	BreakerVacuum	522-0513	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Fault Operations A Ø	0	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Fault Operations B Ø	0	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Fault Operations C Ø	0	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Fault Operations Ground	0	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Follow-up Action Required?	n	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Patrol Inspection	General Comments		
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	General Comments		
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Maintenance Operations	0	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Operations Counter AF	157	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Operations Counter AL	157	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Operations This Read Vac	0	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Switching Operations	0	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Unknown Operations	0	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	LTCC000397	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	LTCC000397	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	LTCC000397	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	LTCC000397	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	LTCC000397	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	LTCC000397	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	LTCC000397	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	LTCC000397	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Regulator As Left Counter	24363	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Min Tap Position	5L	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Max Tap Position	11L	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	General Comments		
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	General Comments		
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Maintenance Operations	0	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Operations Counter AF	43	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Operations Counter AL	43	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Operations This Read Vac	0	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Switching Operations	0	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Unknown Operations	0	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Fault Operations B Ø	0	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Fault Operations C Ø	0	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Fault Operations Ground	0	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Follow-up Action Required?	n	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Patrol Inspection	General Comments		
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	General Comments		
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Maintenance Operations	0	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Operations Counter AF	156	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Operations Counter AL	156	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Operations This Read Vac	0	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Switching Operations	0	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001167	BreakerVacuum	522-0514	VCB Readings	Unknown Operations	0	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	9 Month Operations	3	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Amps A Ø	125.0	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Amps B Ø	105.0	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Amps C Ø	85.0	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BK001168	BreakerVacuum	522-0512	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	General Comments		
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Vegetation	None	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	112	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	112	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	6	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Readings	General Comments	open	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0100	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	FE000234	Fence	502-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	General Comments		
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	45	°F
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	BAT001208	Battery	522-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	General Comments		
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Vegetation	None	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	YD000423	Yard	857-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Switching Operations	0	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Operations This Read Vac	2	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Operations Counter AL	136	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Operations Counter AF	136	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Maintenance Operations	2	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	General Comments		
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	General Comments		
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Follow-up Action Required?	n	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Fault Operations Ground	0	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Fault Operations C Ø	0	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Fault Operations B Ø	0	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Fault Operations A Ø	0	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Amps C Ø	115.0	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Amps B Ø	100.0	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Amps A Ø	100.0	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	9 Month Operations	2	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	General Comments		
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	ST000519	Structure	591-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	Ambient Temp	61	*F
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	General Comments		
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	Vegetation	None	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	YD000287	Yard	677-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Readings	Unknown Operations	0	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0104	BreakerVacuum	787-1472	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	9 Month Operations	1	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Amps A Ø	330.0	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Amps B Ø	360.0	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Readings	Amps C Ø	330.0	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	CB0223	BreakerVacuum	638-1	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	YD000557	Yard	651-Yard	Yard Patrol Inspection	General Comments		
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	YD000557	Yard	651-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	YD000557	Yard	651-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	YD000557	Yard	651-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	YD000557	Yard	651-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	YD000557	Yard	651-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	YD000557	Yard	651-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	YD000557	Yard	651-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	YD000557	Yard	651-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	YD000557	Yard	651-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	YD000557	Yard	651-Yard	Yard Patrol Inspection	Ambient Temp	65	*F

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Current Tap Position	7L	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Amps C Ø	500.0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Amps B Ø	410.0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Amps A Ø	430.0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	9 Month Operations	2	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Unknown Operations	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Switching Operations	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Operations This Read Vac	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Operations Counter AL	142	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Operations Counter AF	142	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Maintenance Operations	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	General Comments	DNO	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	General Comments		
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Readings	Follow-up Action Required?	n	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000766	BreakerVacuum	LS-1247	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	General Comments		
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Ambient Temp	53	*F
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	General Comments		
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Vegetation	None	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	YD000368	Yard	563-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	ST000370	Structure	563-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Current Tap Position	6L	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	Platform/Walkway/Railing OK?	y	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	General Comments		
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/3/2020 13:35	Distribution	Estill Stone Quarterly Inspection	ST000561	Structure	651-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Operations Counter AL	167	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Operations Counter AF	167	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	General Comments		
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Regulator As Left Counter	357405	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1250	Regulator	725-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Fault Operations Ground	0	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Follow-up Action Required?	n	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	General Comments		
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	General Comments		
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Maintenance Operations	0	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Operations Counter AF	99748	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Operations Counter AL	99748	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Operations This Read Vac	1	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Switching Operations	0	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Unknown Operations	1	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	General Comments		
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	FE000359	Fence	402-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Ambient Temp	49	*F
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	General Comments		
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Vegetation	None	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Current Tap Position	9L	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0115	Regulator	857-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Regulator As Left Counter	21761	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Max Tap Position	12L	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	General Comments		
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Current Tap Position	9L	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	9 Month Operations	6	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Amps A Ø	340.0	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Amps B Ø	330.0	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Amps C Ø	330.0	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Fault Adjusted Amps A Phase V	14.48	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Fault Adjusted Amps B Phase V	14.48	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Fault Adjusted Amps C Phase V	14.48	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Fault Operations A Ø	0	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Fault Operations B Ø	0	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BB0453	BreakerVacuum	402-1	VCB Readings	Fault Operations C Ø	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Fault Operations Ground	0	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	General Comments		
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Readings	General Comments		
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1703.52	kw
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Readings	Oil Temp Max	48	°C
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	W0270	NonLTC	502-1	NonLTC Transformer Readings	Totalizer Meter Reading	.7098	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Fault Operations C Ø	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Fault Operations B Ø	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Fault Operations A Ø	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	YD000365	Yard	402-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0114	Regulator	857-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Regulator As Left Counter	27128	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	General Comments		
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	KR0113	Regulator	857-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	FE000362	Fence	563-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Unknown Operations	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Switching Operations	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Operations This Read Vac	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Operations Counter AL	168	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Operations Counter AF	168	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Maintenance Operations	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	General Comments		
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	General Comments		
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Follow-up Action Required?	n	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Readings	Amps A Ø	82.0	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Readings	Amps B Ø	74.0	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Readings	Amps C Ø	77.0	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Readings	Fault Operations A Ø	0	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Readings	Fault Operations B Ø	0	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Readings	Fault Operations C Ø	0	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Readings	Fault Operations Ground	0	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Readings	Follow-up Action Required?	n	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Patrol Inspection	General Comments		
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Readings	General Comments		
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Maintenance Operations	0	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Readings	Operations Counter AF	152	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Readings	Operations Counter AL	152	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Readings	Operations This Read Vac	1	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Readings	Switching Operations	1	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Operations Counter AF	141	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Readings	Unknown Operations	0	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	General Comments		
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	General Comments		
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Maintenance Operations	0	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Operations Counter AF	188	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Operations Counter AL	188	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Operations This Read Vac	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Counter Readings	LTC Max Tap Position	4R	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Counter Readings	LTC Min Tap Position	8L	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Operations Counter AL	141	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Operations This Read Vac	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Switching Operations	0	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Readings	9 Month Operations	1	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Readings	Amps A Ø	27.0	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Readings	Amps B Ø	30.0	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Readings	Amps C Ø	25.0	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Follow-up Action Required?	n	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Readings	Fault Operations A Ø	0	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Readings	Fault Operations B Ø	0	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Readings	Fault Operations C Ø	0	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Readings	Fault Operations Ground	0	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	Winding Temp Present	20	°C
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	Winding Temp Max	20	°C
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	Totalizer Meter Reading	.5634	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Readings	Follow-up Action Required?	n	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Patrol Inspection	General Comments		
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Readings	General Comments		
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Readings	Maintenance Operations	0	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Readings	Operations Counter AF	184	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Readings	Operations Counter AL	184	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Readings	Operations This Read Vac	0	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Readings	Switching Operations	0	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001432	BreakerVacuum	857-0330	VCB Readings	Unknown Operations	0	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Readings	9 Month Operations	2	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BK001433	BreakerVacuum	857-0331	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Follow-up Action Required?	n	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Patrol Inspection	General Comments		
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	General Comments		
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Maintenance Operations	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Operations Counter AF	138	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Operations Counter AL	138	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Operations This Read Vac	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Switching Operations	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Unknown Operations	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	9 Month Operations	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Amps A Ø	75.0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Amps B Ø	51.0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Readings	Amps C Ø	100.0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000526	BreakerVacuum	LS-1244	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Regulator As Left Counter	19756	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	9 Month Operations	1	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Amps A Ø	88.0	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Amps B Ø	81.0	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Amps C Ø	64.0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Fault Operations A Ø	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Fault Operations B Ø	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Fault Operations C Ø	0	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Fault Operations Ground	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Follow-up Action Required?	n	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Patrol Inspection	General Comments		
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	General Comments	DNO	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	Winding Temp Present	35	°C
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	Winding Temp Max	55	°C
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	Top Oil Temperature Present	35	°C
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	Top Oil Temperature Max	55	°C
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	Oil Temp Present	35	°C
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	Oil Temp Max	55	°C
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	600	psi
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	H3 Winding Temp Present	20	°C
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	H3 Winding Temp Max	20	°C
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	H2 Winding Temp Present	20	°C
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	H2 Winding Temp Max	45	°C
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Fault Operations B Ø	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Fault Operations C Ø	2	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Fault Operations Ground	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Follow-up Action Required?	n	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	General Comments		
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	General Comments		
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Maintenance Operations	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Operations Counter AF	135	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Operations Counter AL	135	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Operations This Read Vac	2	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Amps B Ø	0.0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Amps A Ø	0.0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	9 Month Operations	3	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	General Comments		
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Switching Operations	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Unknown Operations	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	9 Month Operations	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Amps A Ø	0.0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Amps B Ø	0.0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000522	BreakerVacuum	LS-1242	VCB Readings	Amps C Ø	0.0	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	FE000509	Fence	591-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	Follow-up Action Required?	n	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Switching Operations	0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Unknown Operations	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Counter Readings	Follow-up Action Required?	n	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Counter Readings	General Comments		
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Mechanism Patrol Inspection	General Comments	needs desiccant	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Counter Readings	LTC As Found Counter	80696	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Counter Readings	LTC As Left Counter	80696	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Fault Operations A Ø	0	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Fault Operations B Ø	0	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Fault Operations C Ø	0	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Fault Operations Ground	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Counter Readings	LTC Current Tap Position	6L	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Max Tap Position	1L	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	General Comments		
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Current Tap Position	8L	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	H1 Winding Temp Present	15	°C
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	H1 Winding Temp Max	40	°C
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Readings	General Comments		
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	General Comments		
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0080	WithLTC	LS-TRANS 5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	BAT001049	Battery	649-Battery Bank	Battery Patrol Inspection	General Comments		
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	9 Month Operations	5	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Amps A Ø	180.0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Amps B Ø	200.0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Amps C Ø	190.0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Fault Operations A Ø	0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Fault Operations B Ø	0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Fault Operations C Ø	0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Fault Operations Ground	0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Follow-up Action Required?	n	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	General Comments		
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	General Comments		
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Maintenance Operations	0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Operations Counter AF	308	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Operations Counter AL	308	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Operations This Read Vac	0	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Fault Operations A Ø	0	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Fault Operations B Ø	0	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Fault Operations C Ø	0	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Fault Operations Ground	0	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Follow-up Action Required?	n	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Patrol Inspection	General Comments		
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	Oil Temp Present	30	°C
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	Oil Temp Max	30	°C
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1000	psi
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	LTC Totalizer Reading	10141.20	kw
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	General Comments		
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	General Comments		
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	General Comments		
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Maintenance Operations	0	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Operations Counter AF	170	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Operations Counter AL	170	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Operations This Read Vac	1	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Switching Operations	1	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Unknown Operations	0	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Operations Counter	1123	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Max Tap Position	6L	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Min Tap Position	12L	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	5.0	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	5.0	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	5.0	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	General Comments		
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Max Tap Position	2L	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124	volts
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Regulator As Left Counter	19835	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Tank Leaks	None	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Readings	General Comments	out of service	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	General Comments		
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Current Tap Position	9L	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	General Comments		
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Max Tap Position	6L	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Min Tap Position	12L	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Readings	Totalizer Meter Multiplier	0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Readings	Oil Temp Present	10	°C
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Readings	Oil Temp Max	50	°C
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	General Comments	switching op	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Amps C Ø	30.0	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Amps B Ø	30.0	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	BX0734	RecloserElectronic	449-0581	Recloser Electronic Patrol Inspection	Amps A Ø	30.0	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Regulator As Left Counter	19086	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Counter Readings	LTC Operations Since Last Insp	545	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Counter Readings	LTC Min Tap Position	2L	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Counter Readings	LTC Max Tap Position	2L	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Counter Readings	LTC Current Tap Position	2L	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Counter Readings	LTC As Left Counter	9312	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	9 Month Operations	4	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Amps A Ø	96.0	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Amps B Ø	78.0	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Amps C Ø	93.0	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Current Tap Position	9L	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Follow-up Action Required?	n	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Patrol Inspection	General Comments		
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	General Comments		
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Maintenance Operations	0	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Operations Counter AF	167	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	General Comments		
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124	volts
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Regulator As Left Counter	21190	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000024	Regulator	669-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Operations Counter AL	167	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Operations This Read Vac	2	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Switching Operations	1	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Maintenance Operations	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Operations Counter AF	121	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Operations Counter AL	121	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Operations This Read Vac	1	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Switching Operations	1	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000528	BreakerVacuum	LS-12KV TR 5	VCB Readings	Unknown Operations	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	9 Month Operations	3	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Amps A Ø	0.0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Amps B Ø	0.0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LT0080	LTCMechanism	LS-TRANS 5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Switching Operations	0	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0066	BreakerVacuum	197-2502	VCB Readings	Unknown Operations	0	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	9 Month Operations	9	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Amps A Ø	128.0	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Amps B Ø	120.0	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Amps C Ø	121.0	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Fault Adjusted Amps A Phase V	4.31	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Fault Adjusted Amps B Phase V	4.31	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Fault Adjusted Amps C Phase V	4.31	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Fault Operations A Ø	0	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Fault Operations B Ø	0	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Fault Operations C Ø	0	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Fault Operations Ground	0	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Min Tap Position	Neutral	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Regulator As Left Counter	18329	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	General Comments		
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Max Tap Position	3L	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124	volts
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Regulator As Left Counter	20037	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000026	Regulator	669-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Amps A Ø	126.0	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Amps B Ø	105.0	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Amps C Ø	110.0	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	6	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	KT0050	WithLTC	638-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Current Tap Position	9L	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000037	Regulator	502-1 B	Regulator Patrol Inspection	General Comments		
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	General Comments		
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	RG000025	Regulator	669-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001459	BreakerVacuum	638-2512	VCB Readings	Unknown Operations	1	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	9 Month Operations	8	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001460	BreakerVacuum	638-2513	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Amps C Ø	0.0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	ST000294	Structure	677-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Fault Operations A Ø	0	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	General Comments		
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Max Tap Position	7L	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Min Tap Position	12L	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000036	Regulator	502-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Max Tap Position	14R	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	General Comments		
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Amps A Ø	20.0	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Amps B Ø	20.0	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Amps C Ø	20.0	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Unknown Operations	0	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	CX0135	RecloserElectronic	677-0585	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	CX0135	RecloserElectronic	677-0585	Recloser Electronic Patrol Inspection	Tank Leaks	None	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	CX0135	RecloserElectronic	677-0585	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	CX0135	RecloserElectronic	677-0585	Recloser Electronic Patrol Inspection	Operations Counter	340	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	CX0135	RecloserElectronic	677-0585	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	CX0135	RecloserElectronic	677-0585	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	CX0135	RecloserElectronic	677-0585	Recloser Electronic Patrol Inspection	General Comments		
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	CX0135	RecloserElectronic	677-0585	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Amps C Ø	435.0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Amps B Ø	440.0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Amps A Ø	430.0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	9 Month Operations	4	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Ambient Temp	60	*F
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	334	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	334	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Switching Operations	0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Operations This Read Vac	0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Operations Counter AL	315	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Operations Counter AF	315	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Maintenance Operations	0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	General Comments		
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	General Comments		
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Follow-up Action Required?	n	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Fault Operations Ground	0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Fault Operations C ∅	0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Fault Operations B ∅	0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Fault Operations A ∅	0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	General Comments		
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	General Comments		
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	General Comments	oos	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Maintenance Operations	0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Operations Counter AF	247	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Operations Counter AL	247	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Operations This Read Vac	1	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Switching Operations	1	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Readings	General Comments		
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	General Comments	Turned fans off	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1170.72	kw
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	52.50	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Readings	Oil Temp Max	35	°C
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Counter Readings	Follow-up Action Required?	n	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Counter Readings	General Comments		
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Mechanism Patrol Inspection	General Comments		
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Counter Readings	LTC As Found Counter	138951	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Counter Readings	LTC As Left Counter	138951	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Counter Readings	LTC Min Tap Position	8L	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	10	°C
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4878	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	Winding Temp Present	40	°C
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	Winding Temp Max	45	°C
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5232	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	10	°C
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Counter Readings	LTC Operations Since Last Insp	64	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	LTCM000047	LTCMechanism	897-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	General Comments		
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Vegetation	None	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	YD000496	Yard	140-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Regulator As Left Counter	568908	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BAT001487	Battery	897-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BAT001487	Battery	897-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BAT001487	Battery	897-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C ∅	0	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B ∅	0	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A ∅	0	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	General Comments		
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1249	Regulator	725-1 A	Regulator Patrol Inspection	Current Tap Position	7L	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/3/2020 13:28	Distribution	Tunnel Hill Quarterly Inspection	C0337	NonLTC	613-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Foundation Condition	Good	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	General Comments		
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Readings	Oil Temp Present	35	°C
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Readings	Oil Temp Max	55	°C
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Readings	LTC Totalizer Reading	4757.76	kw
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Readings	Totalizer Meter Reading	.1854	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Readings	Winding Temp Max	55	°C
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Readings	Winding Temp Present	40	°C
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Readings	Follow-up Action Required?	n	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	General Comments		
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Readings	General Comments		
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Readings	LTC Totalizer Reading	6370.56	kw
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Readings	Oil Temp Max	50	°C
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Readings	Oil Temp Present	30	°C
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Readings	Totalizer Meter Reading	.4956	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Readings	Oil Temp Present	40	°C
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Readings	Oil Temp Max	55	°C
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Readings	LTC Totalizer Reading	2669.76	kw
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Readings	General Comments		
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	General Comments		
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	B0393	WithLTC	591-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	General Comments		
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Fault Operations A Ø	0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Readings	Oil Temp Present	35	°C
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BAT001487	Battery	897-Battery Bank	Battery Patrol Inspection	General Comments		
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BAT001487	Battery	897-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.5	VDC
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	General Comments		
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Readings	Oil Temp Max	50	°C
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Readings	LTC Totalizer Reading	2140.80	kw
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Readings	General Comments		
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	General Comments		
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	LTCC000504	LTCControl	591-1	LTC Control Insp	All Connections OK?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	LTCC000504	LTCControl	591-1	LTC Control Insp	Follow-up Action Required?	n	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	LTCC000504	LTCControl	591-1	LTC Control Insp	General Comments		
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	LTCC000504	LTCControl	591-1	LTC Control Insp	LTC Operation Checked?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	LTCC000504	LTCControl	591-1	LTC Control Insp	LTC Output Voltage Level	123.8	VAC
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	LTCC000504	LTCControl	591-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	LTCC000504	LTCControl	591-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	LTCC000504	LTCControl	591-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Readings	General Comments		
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	ST000425	Structure	857-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BAT001487	Battery	897-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BAT001487	Battery	897-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BAT001487	Battery	897-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BAT001487	Battery	897-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BAT001487	Battery	897-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BAT001487	Battery	897-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BAT001487	Battery	897-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	43	°F
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Fault Operations B Ø	0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Fault Operations C Ø	0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Fault Operations Ground	0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Follow-up Action Required?	n	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	General Comments		
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Readings	Follow-up Action Required?	n	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	B0350	WithLTC	197-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Readings	Totalizer Meter Reading	.6636	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	B0474	WithLTC	677-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BAT001487	Battery	897-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Readings	Totalizer Meter Reading	.6690	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	C0373	WithLTC	649-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BAT000952	Battery	857-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	BAT001465	Battery	723-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	BAT001465	Battery	723-Battery Bank	Battery Patrol Inspection	General Comments		
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	BAT001465	Battery	723-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	BAT001465	Battery	723-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	BAT001465	Battery	723-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	BAT001465	Battery	723-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	BAT001465	Battery	723-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	BAT001465	Battery	723-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	BAT001465	Battery	723-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	BAT001465	Battery	723-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	50	°F
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	BAT001465	Battery	723-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Max Tap Position	15R	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Amps C Ø	145	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Amps B Ø	100	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Amps A Ø	145	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Accumulated Fault Duty C Ph V	1.75	%
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Accumulated Fault Duty B Ph V	3.14	%
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Accumulated Fault Duty A Ph V	4.54	%
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	9 Month Operations	1	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	LTCC000905	LTCCControl	649-1	LTC Control Insp	All Connections OK?	y	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	LTCC000905	LTCCControl	649-1	LTC Control Insp	Follow-up Action Required?	n	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	LTCC000905	LTCCControl	649-1	LTC Control Insp	General Comments		
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	LTCC000905	LTCCControl	649-1	LTC Control Insp	LTC Operation Checked?	y	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	LTCC000905	LTCCControl	649-1	LTC Control Insp	LTC Output Voltage Level	125.1	VAC
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	LTCC000905	LTCCControl	649-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	LTCC000905	LTCCControl	649-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	LTC000905	LTCControl	649-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	9 Month Operations	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Battery Load Check OK?	n	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Amps C Ø	1.0	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Amps B Ø	1.0	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Amps A Ø	1.0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	9 Month Operations	5	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Amps A Ø	0.0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Amps B Ø	0.0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Amps C Ø	0.0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	BCH001403	Charger	563-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	BCH001403	Charger	563-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	BCH001403	Charger	563-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	BCH001403	Charger	563-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	BAT001467	Battery	563-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	BAT001467	Battery	563-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	General Comments		
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	General Comments		
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Follow-up Action Required?	n	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Fault Operations Ground	0	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Fault Operations C Ø	0	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Fault Operations B Ø	0	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Fault Operations A Ø	0	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Fault Adjusted Amps C Phase V	0	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Fault Adjusted Amps B Phase V	0	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Fault Adjusted Amps A Phase V	0	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	BAT001467	Battery	563-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	BAT001467	Battery	563-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	BAT001467	Battery	563-Battery Bank	Battery Patrol Inspection	General Comments		
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	BAT001467	Battery	563-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	BAT001467	Battery	563-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	BAT001467	Battery	563-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	BAT001467	Battery	563-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	BAT001467	Battery	563-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	BAT001467	Battery	563-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	BAT001467	Battery	563-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	BAT001467	Battery	563-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	53	*F
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	BAT001467	Battery	563-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BAT001082	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BAT001082	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BAT001082	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	26.8	VDC
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BAT001082	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	25.7	VDC
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BAT001082	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BAT001082	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	BAT001465	Battery	723-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BCH001051	Charger	689-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BCH001051	Charger	689-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BCH001051	Charger	689-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.9	amps
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BCH001051	Charger	689-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BCH001051	Charger	689-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	BAT001465	Battery	723-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	BAT001465	Battery	723-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Min Tap Position	13L	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Regulator As Left Counter	15207	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Fault Operations A Ø	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Fault Operations B Ø	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Fault Operations C Ø	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Fault Operations Ground	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Follow-up Action Required?	n	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	General Comments		
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	General Comments		
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Maintenance Operations	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Operations Counter AF	133	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Operations Counter AL	133	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Operations This Read Vac	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Switching Operations	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Unknown Operations	0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Unknown Operations	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	9 Month Operations	3	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Amps A Ø	17.0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Amps B Ø	15.0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Amps C Ø	17.0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000520	BreakerVacuum	LS-1241	VCB Readings	Fault Adjusted Amps C Phase V	22.36	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Counter Readings	Follow-up Action Required?	n	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Fault Operations A Ø	0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Fault Operations B Ø	0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Fault Operations C Ø	0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Fault Operations Ground	0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Follow-up Action Required?	n	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Counter Readings	General Comments		
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	General Comments		
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	General Comments	oos	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Maintenance Operations	0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Operations Counter AF	87	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Operations Counter AL	87	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Operations This Read Vac	3	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Readings	Switching Operations	3	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	CB0287	BreakerVacuum	897-2511	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Amps A Ø	0.0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Amps B Ø	0.0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000518	BreakerVacuum	LS-1240	VCB Readings	Amps C Ø	0.0	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Mechanism Patrol Inspection	General Comments	has breather	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Counter Readings	LTC As Found Counter	188765	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Counter Readings	LTC As Left Counter	188770	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Counter Readings	LTC Current Tap Position	7L	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Counter Readings	LTC Max Tap Position	3L	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Counter Readings	LTC Min Tap Position	10L	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Counter Readings	LTC Operations Since Last Insp	502	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	C0475	LTCMechanism	197-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Regulator As Left Counter	271213	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	R1251	Regulator	725-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BAT001443	Battery	638-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	Follow-up Action Required?	n	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	140.0	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	150.0	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	140.0	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0196	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	12	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BAT001443	Battery	638-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BAT001443	Battery	638-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BAT001443	Battery	638-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Operations Counter	218	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	BCH001044	Charger	652-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	BCH001044	Charger	652-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	BCH001044	Charger	652-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	BCH001044	Charger	652-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	BCH001044	Charger	652-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	BCH001044	Charger	652-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	BCH001044	Charger	652-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	BCH001044	Charger	652-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Amps A Ø	10.0	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Amps B Ø	19.0	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Amps C Ø	24.0	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	FE000419	Fence	857-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	Oil Temp Present	34	°C
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	Oil Temp Max	47	°C
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	5022.72	kw
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	CX0135	RecloserElectronic	677-0585	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	BCH001403	Charger	563-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	CX0135	RecloserElectronic	677-0585	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	CX0135	RecloserElectronic	677-0585	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	CX0135	RecloserElectronic	677-0585	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BAT001443	Battery	638-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	General Comments		
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	General Comments		
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BAT001443	Battery	638-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	38	°F
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BAT001443	Battery	638-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	S0033	NonLTC	857-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BAT001443	Battery	638-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BAT001443	Battery	638-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BAT001443	Battery	638-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BAT001443	Battery	638-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BAT001443	Battery	638-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BAT001443	Battery	638-Battery Bank	Battery Patrol Inspection	General Comments		
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	General Comments		
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Door Alarms OK?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Evidence of Insects	None	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	220.00	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	K0190	BreakerVacuum	897-2472	VCB Readings	Amps C Ø	0.0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	General Comments		
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Panel Lights OK?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Panels Dusted?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Vent Fans OK?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	SWG000207	Switchgear	LS-Swgr Sec 5	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BAT001082	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BAT001082	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BAT001082	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BAT001082	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BAT001082	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BAT001082	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BAT001082	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Follow-up Action Required?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Unknown Operations	0	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Switching Operations	1	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Operations This Read Vac	1	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Operations Counter AL	266	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Operations Counter AF	266	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Readings	Maintenance Operations	0	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	KB0060	BreakerVacuum	669-0426	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	BCH001403	Charger	563-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	BCH001403	Charger	563-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	BCH001403	Charger	563-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	General Comments	GF target light on	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Operations Counter	60	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	RC000483	RecloserElectronic	725-0843	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/3/2020 11:47	Distribution	Ashbyburg Pump Quarterly Inspection	KX0126	RecloserElectronic	725-0844	Recloser Electronic Patrol Inspection	General Comments	No Control Cabinet located. Battery Test Fal/Batt Problem Light still on meter chk shows 25.7Vdc on batteries.	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	General Comments		
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	General Comments	out of service on portable	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	Oil Temp Max	45	°C
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	Oil Temp Present	5	°C
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	CX0135	RecloserElectronic	677-0585	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	CX0135	RecloserElectronic	677-0585	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	CX0135	RecloserElectronic	677-0585	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	CX0135	RecloserElectronic	677-0585	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	CX0135	RecloserElectronic	677-0585	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	CX0135	RecloserElectronic	677-0585	Recloser Electronic Patrol Inspection	Amps C Ø	75.0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	Totalizer Meter Multiplier	0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0537	WithLTC	897-2	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	CX0135	RecloserElectronic	677-0585	Recloser Electronic Patrol Inspection	Amps B Ø	90.0	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	CX0135	RecloserElectronic	677-0585	Recloser Electronic Patrol Inspection	Amps A Ø	85.0	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Current Tap Position	2R	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BCH001341	Charger	897-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BCH001341	Charger	897-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BCH001341	Charger	897-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	302	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	302	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Fault Operations A Ø	0	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Fault Operations B Ø	0	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Fault Operations C Ø	0	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Fault Operations Ground	0	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Amps A Ø	71.0	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	CX0553	RecloserHydraulic	501-1410	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	CX0553	RecloserHydraulic	501-1410	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	CX0553	RecloserHydraulic	501-1410	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	CX0553	RecloserHydraulic	501-1410	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	CX0553	RecloserHydraulic	501-1410	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	CX0553	RecloserHydraulic	501-1410	Recloser Hydraulic Patrol Inspection	General Comments		
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	CX0553	RecloserHydraulic	501-1410	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	CX0553	RecloserHydraulic	501-1410	Recloser Hydraulic Patrol Inspection	Operations Counter	178	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	VRR Bandwidth AF	3.0	VAC
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	Reset Tap Drag Hands	Reset	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	Min Tap Position	8L	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	Max Tap Position	Neutral	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	General Comments	out of service	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	Follow-up Action Required?	n	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	9 Month Operations	2	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Amps A Ø	72.0	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Amps B Ø	73.0	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Amps C Ø	79.0	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	FCP Lower AL	0.0	VAC
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	FCP Lower AF	0.0	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	FCP Block Raise AL	0.0	VAC
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	FCP Block Raise AF	0.0	VAC
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	Current Tap Position	Neutral	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	All Connections OK?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BCH001341	Charger	897-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BCH001341	Charger	897-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.1	VDC
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BCH001341	Charger	897-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.1	VDC
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BCH001341	Charger	897-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.2	amps
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BCH001341	Charger	897-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	130.0	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	110.0	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	140.0	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	9 Month Operations	16	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	9 Month Operations	2	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Amps A Ø	450.0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Amps B Ø	480.0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Amps C Ø	470.0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.7	volts
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Regulator As Left Counter	19255	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Amps A Ø	256.0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Amps B Ø	258.0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Amps C Ø	211.0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Fault Operations A Ø	0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Fault Operations B Ø	0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Fault Operations C Ø	0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Fault Operations Ground	0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Follow-up Action Required?	n	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	CX0553	RecloserHydraulic	501-1410	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
11/3/2020 12:56	Distribution	Diamond Quarterly Inspection	CX0553	RecloserHydraulic	501-1410	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	FE000869	Fence	140-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	FE000869	Fence	140-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	FE000869	Fence	140-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	FE000869	Fence	140-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	FE000869	Fence	140-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	FE000869	Fence	140-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	FE000869	Fence	140-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	FE000869	Fence	140-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	FE000869	Fence	140-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	FE000869	Fence	140-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	FE000869	Fence	140-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	FE000869	Fence	140-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	FE000869	Fence	140-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	FE000869	Fence	140-Fence	Fence Patrol Inspection	General Comments		
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	FE000869	Fence	140-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Operations Counter	1037	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	9 Month Operations	2	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Amps A Ø	64.0	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Amps B Ø	93.0	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Amps C Ø	80.0	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	General Comments		
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Min Tap Position	4L	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	CB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Operations Counter AL	204	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Operations This Read Vac	0	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Switching Operations	0	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Unknown Operations	0	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	General Comments		
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	28.33	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Readings	Totalizer Meter Reading	.2866	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Readings	Oil Temp Present	32	°C
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Readings	Oil Temp Max	45	°C
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Readings	LTC Totalizer Reading	2751.36	kw
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Readings	General Comments		
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	General Comments		
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	644.76	kw
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	40.0	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.0746	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	600	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BCH001367	Charger	857-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BCH001367	Charger	857-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BCH001367	Charger	857-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BCH001360	Charger	638-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Readings	Oil Temp Max	0	°C
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	1665	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	1665	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Operations Counter AF	204	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Readings	Totalizer Meter Reading	.4542	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Readings	Oil Temp Present	45	°C
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Readings	Oil Temp Max	50	°C
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Readings	LTC Totalizer Reading	4360.32	kw
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Readings	General Comments		
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	General Comments		
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	S0007	WithLTC	563-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	VRR X Compensation AL	0	Position
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	VRR X Compensation AF	0	Position
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	VRR Time Delay	0	Seconds
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	VRR R Compensation AL	0	Position
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	VRR R Compensation AF	0	Position
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	VRR Counter AL	138951	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	VRR Counter AF	138951	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	VRR Base Voltage AL	124.0	VAC
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	VRR Base Voltage AF	124.0	VAC
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	KRC000414	RegulatorControl	897-1	Regulator Annual Control Inspection	VRR Bandwidth AL	3.0	VAC
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Amps C Ø	61.0	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Amps B Ø	47.0	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BAT001458	Battery	402-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BAT001458	Battery	402-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BAT001458	Battery	402-Battery Bank	Battery Patrol Inspection	General Comments		
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BAT001458	Battery	402-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BAT001458	Battery	402-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BAT001458	Battery	402-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Readings	General Comments	Temp guage inop	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	General Comments		
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Amps A Ø	30.0	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Amps B Ø	30.0	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Amps C Ø	30.0	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	0939	NonLTC	762-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Counter Readings	LTC As Left Counter	14949	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Counter Readings	LTC As Found Counter	14940	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Mechanism Patrol Inspection	General Comments		
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BAT001458	Battery	402-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Counter Readings	General Comments		
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Unknown Operations	0	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Switching Operations	0	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Operations This Read Vac	0	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Operations Counter AL	165	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Operations Counter AF	165	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Maintenance Operations	0	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	General Comments		
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	General Comments		
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Follow-up Action Required?	n	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Fault Operations Ground	0	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Fault Operations C Ø	0	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Fault Operations B Ø	0	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Fault Operations A Ø	0	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BAT001458	Battery	402-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BAT001458	Battery	402-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Unknown Operations	0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Switching Operations	1	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Operations This Read Vac	1	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Operations Counter AL	247	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Operations Counter AF	247	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BCH001360	Charger	638-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.3	VDC
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Regulator As Left Counter	81765	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Current Tap Position	7L	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	General Comments		
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Max Tap Position	3L	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Regulator As Left Counter	104089	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1197	Regulator	787-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BCH001360	Charger	638-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.3	VDC
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BCH001360	Charger	638-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.020	millivolts
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	15	°C
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Counter Readings	LTC Min Tap Position	11L	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BAT001458	Battery	402-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BAT001458	Battery	402-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	49	°F
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BAT001458	Battery	402-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Counter Readings	LTC Max Tap Position	3R	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Counter Readings	LTC Current Tap Position	8L	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Readings	Totalizer Meter Reading	.83	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	40	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	LTCC000358	LTCControl	897-2	LTC Control Insp	All Connections OK?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	LTCC000358	LTCControl	897-2	LTC Control Insp	Follow-up Action Required?	n	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	LTCC000358	LTCControl	897-2	LTC Control Insp	General Comments	out of service	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	LTCC000358	LTCControl	897-2	LTC Control Insp	LTC Operation Checked?	n	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	LTCC000358	LTCControl	897-2	LTC Control Insp	LTC Output Voltage Level	0.0	VAC
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	LTCC000358	LTCControl	897-2	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	LTCC000358	LTCControl	897-2	LTC Control Insp	VRR Base Voltage AL	125.0	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	LTCC000358	LTCControl	897-2	LTC Control Insp	VRR Time Delay	30	Seconds
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Maintenance Operations	0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	General Comments		
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	General Comments		
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Follow-up Action Required?	n	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	9 Month Operations	2	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Unknown Operations	0	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Counter Readings	Follow-up Action Required?	n	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Counter Readings	General Comments		
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Mechanism Patrol Inspection	General Comments		
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Counter Readings	LTC As Found Counter	84919	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Counter Readings	LTC As Left Counter	84922	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Counter Readings	LTC Current Tap Position	6L	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Counter Readings	LTC Max Tap Position	3L	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Counter Readings	LTC Min Tap Position	9L	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Counter Readings	LTC Operations Since Last Insp	425	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	B0350	LTCMechanism	197-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Amps C Ø	75.0	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Amps B Ø	126.0	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Amps A Ø	79.0	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Readings	Follow-up Action Required?	n	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	General Comments		
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Readings	General Comments		
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Readings	LTC Totalizer Reading	7968	kw
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Readings	Oil Temp Max	90	°C
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Readings	Oil Temp Present	35	°C
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Counter Readings	Follow-up Action Required?	n	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	Winding Temp Present	29	°C
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	Winding Temp Max	51	°C
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	Totalizer Meter Reading	.4194	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000455	BreakerVacuum	689-1407	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/3/2020 7:57	Distribution	Georgetown Quarterly Inspection	B0412	WithLTC	669-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Fault Operations B Ø	0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Fault Operations C Ø	0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Fault Operations Ground	0	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Operations Counter	1397	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Operations This Read Vac	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Switching Operations	0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Unknown Operations	0	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Follow-up Action Required?	n	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Follow-up Action Required?	n	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	General Comments		
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	General Comments		
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Maintenance Operations	0	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Operations Counter AF	191	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Operations Counter AL	191	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Operations This Read Vac	0	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Switching Operations	0	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	General Comments		
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	General Comments		
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Maintenance Operations	0	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Operations Counter AF	154	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Unknown Operations	0	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	General Comments		
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	General Comments		
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Heaters (All) Functioning?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Maintenance Operations	0	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Operations Counter AF	243	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	KB0015	BreakerVacuum	723-2	VCB Readings	Operations Counter AL	243	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Regulator As Left Counter	84158	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1194	Regulator	689-1 A	Regulator Patrol Inspection	Tank Leaks	None	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Fault Operations A ∅	0	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Fault Operations B ∅	0	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Fault Operations C ∅	0	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000256	BreakerVacuum	869-0810	VCB Readings	Fault Operations Ground	0	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	General Comments	operations for switching due to replaced line side leads	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1113	Regulator	762-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Counter Readings	LTC As Left Counter	37997	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Counter Readings	LTC Current Tap Position	2L	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Counter Readings	LTC Max Tap Position	12R	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Counter Readings	LTC Min Tap Position	6L	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	1780	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Counter Readings	Follow-up Action Required?	n	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Fault Operations A Ø	0	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Counter Readings	General Comments		
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Mechanism Patrol Inspection	General Comments		
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	S0007	LTCMechanism	563-1	LTC Counter Readings	LTC As Found Counter	9310	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Operations This Read Vac	0	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Switching Operations	0	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BCH001360	Charger	638-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BCH001360	Charger	638-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BCH001360	Charger	638-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BCH001360	Charger	638-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Counter Readings	LTC Operations Since Last Insp	860	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	LTCM000029	LTCMechanism	869-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	40	°C
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	General Comments		
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	R1195	Regulator	689-1 B	Regulator Patrol Inspection	Max Tap Position	2L	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	Follow-up Action Required?	n	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	General Comments		
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	Grounds in Place?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	LTC Totalizer Reading	6039.36	kw
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	Oil Temp Max	50	°C
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Readings	Oil Temp Present	28	°C
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	TX000045	WithLTC	869-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Tank Leaks	None	
11/3/2020 13:13	Distribution	Shun Pike Quarterly Inspection	X0025	RecloserElectronic	449-0580	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 14:06	Distribution	Clay KU Quarterly Inspection	BK000454	BreakerVacuum	689-1408	VCB Readings	Operations Counter AL	154	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Current Tap Position	2R	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1114	Regulator	762-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	BK000416	BreakerVacuum	649-2300	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	General Comments		
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 12:30	Distribution	Onton Quarterly Inspection	WX0241	RecloserElectronic	447-0832	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Counter Readings	General Comments		
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	LTCM000014	LTCMechanism	LS-TRANS 3	LTC Counter Readings	LTC As Found Counter	37997	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Amps A Ø	214.0	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Amps B Ø	250.0	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Amps C Ø	233.0	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Switching Operations	0	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Fault Operations A Ø	0	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Fault Operations B Ø	0	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Fault Operations C Ø	0	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Fault Operations Ground	0	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Follow-up Action Required?	n	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	General Comments		
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	General Comments		
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Maintenance Operations	0	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Operations Counter AF	150	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Unknown Operations	2	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	9 Month Operations	1	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Amps A Ø	0.0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Amps B Ø	0.0	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Operations Counter AL	150	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Operations This Read Vac	0	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Switching Operations	0	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	Unknown Operations	0	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Amps B Ø	100.0	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Amps A Ø	100.0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Amps C Ø	0.0	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Counter Readings	Follow-up Action Required?	n	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	9 Month Operations	8	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	9 Month Operations	1	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Amps A Ø	10.0	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Amps B Ø	50.0	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Amps C Ø	115.0	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Counter Readings	LTC Max Tap Position	16R	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Counter Readings	LTC Current Tap Position	8L	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Counter Readings	LTC As Left Counter	239558	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Counter Readings	LTC As Found Counter	239553	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Mechanism Patrol Inspection	General Comments		
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Counter Readings	General Comments		
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Fault Operations A Ø	0	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Switching Operations	0	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Regulator As Left Counter	17303	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Fault Operations B Ø	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Fault Operations C Ø	0	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Unknown Operations	0	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Bushing Condition	Good	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Current Tap Position	3R	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Fault Operations A Ø	0	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Fault Operations B Ø	0	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Fault Operations C Ø	0	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Fault Operations Ground	0	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Follow-up Action Required?	n	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	General Comments		
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	General Comments		
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Maintenance Operations	0	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Amps C Ø	100.0	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	BK000385	BreakerVacuum	869-1	VCB Readings	9 Month Operations	2	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Fault Operations Ground	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Follow-up Action Required?	n	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	General Comments		
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	General Comments		
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Maintenance Operations	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Operations Counter AF	144	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Operations Counter AL	144	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Readings	Operations This Read Vac	2	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000529	BreakerVacuum	LS-12KV BUS TIE SEC 5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	LTCC000363	LTCControl	197-6	LTC Control Insp	Follow-up Action Required?	n	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	BCH001376	Charger	723-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	BCH001376	Charger	723-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	BCH001376	Charger	723-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	BCH001376	Charger	723-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.3	amps
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	BCH001376	Charger	723-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	BCH001376	Charger	723-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	BCH001376	Charger	723-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Vegetation	None	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
11/3/2020 8:24	Distribution	Lemons Mill Quarterly Inspection	BCH001376	Charger	723-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	LTCC000885	LTCControl	563-1	LTC Control Insp	All Connections OK?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	LTCC000885	LTCControl	563-1	LTC Control Insp	Follow-up Action Required?	n	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	LTCC000885	LTCControl	563-1	LTC Control Insp	General Comments		
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	LTCC000363	LTCControl	197-6	LTC Control Insp	All Connections OK?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	LTCC000885	LTCControl	563-1	LTC Control Insp	LTC Operation Checked?	y	
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	LTCC000885	LTCControl	563-1	LTC Control Insp	LTC Output Voltage Level	125.8	VAC
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	LTCC000885	LTCControl	563-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	LTCC000885	LTCControl	563-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
11/3/2020 11:19	Distribution	Shannon Run Quarterly Inspection	LTCC000885	LTCControl	563-1	LTC Control Insp	VRR Time Delay	30	Seconds
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Tank Leaks	None	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
11/3/2020 14:44	Distribution	Lockport Quarterly Inspection	CX0129	RecloserElectronic	591-2532	Recloser Electronic Patrol Inspection	Operations Counter	495	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Tank Leaks	None	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Surge Arrester Condition	Good	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Regulator As Left Counter	953	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Reg Output Voltage Level	122.8	volts
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Reg Oil Level	Good	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Min Tap Position	6R	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Max Tap Position	3L	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Grounds in Place?	y	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	General Comments		
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 13:40	Distribution	Bear Track Quarterly Inspection	RG000205	Regulator	140-1	Regulator Patrol Inspection	Foundation Condition	Good	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	LTCC000619	LTCControl	197-5	LTC Control Insp	All Connections OK?	y	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	LTCC000619	LTCControl	197-5	LTC Control Insp	Follow-up Action Required?	n	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	LTCC000619	LTCControl	197-5	LTC Control Insp	General Comments		
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	LTCC000619	LTCControl	197-5	LTC Control Insp	LTC Operation Checked?	y	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	LTCC000619	LTCControl	197-5	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	LTCC000619	LTCControl	197-5	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	LTCC000619	LTCControl	197-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	LTCC000619	LTCControl	197-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	LTCC000619	LTCControl	197-5	LTC Control Insp	VRR Time Delay	30	Seconds
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Unknown Operations	0	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Switching Operations	0	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Operations This Read Vac	0	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Operations Counter AL	185	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Readings	Operations Counter AF	185	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	KB0067	BreakerVacuum	197-2501	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Amps C Ø	85.0	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Amps B Ø	85.0	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Amps A Ø	85.0	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Operations Counter AF	128	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Operations Counter AL	128	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Operations This Read Vac	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Switching Operations	0	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	9 Month Operations	2	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Unknown Operations	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Fault Operations A Ø	0	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Fault Operations B Ø	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Fault Operations A Ø	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Fault Operations B Ø	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Fault Operations C Ø	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Fault Operations Ground	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Follow-up Action Required?	n	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Fault Operations C Ø	0	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Fault Operations Ground	0	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Follow-up Action Required?	n	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	General Comments		
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Patrol Inspection	General Comments		
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BCH001367	Charger	857-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BCH001367	Charger	857-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BCH001367	Charger	857-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BCH001367	Charger	857-Battery Charger	Battery Charger Patrol Insp	General Comments		
11/3/2020 15:00	Distribution	Waco Quarterly Inspection	BCH001367	Charger	857-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	General Comments		
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	General Comments		
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Readings	Maintenance Operations	0	
11/3/2020 15:34	Distribution	Lyndon South Quarterly Inspection	BK000530	BreakerVacuum	LS-LY 12KV BUS TIE	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Ambient Temp	45	*F
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Clear of Trash?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	YD000361	Yard	522-Yard	Yard Patrol Inspection	General Comments		
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	LTCC000363	LTCControl	197-6	LTC Control Insp	VRR Time Delay	30	Seconds
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	LTCC000363	LTCControl	197-6	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	LTCC000363	LTCControl	197-6	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	LTCC000363	LTCControl	197-6	LTC Control Insp	LTC Output Voltage Level	124.6	VAC
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	LTCC000363	LTCControl	197-6	LTC Control Insp	LTC Operation Checked?	y	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	LTCC000363	LTCControl	197-6	LTC Control Insp	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Maintenance Operations	1	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Fault Operations A Ø	0	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Operations Counter AF	126	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Operations Counter AL	126	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Operations This Read Vac	1	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Switching Operations	0	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	K0103	BreakerVacuum	787-1473	VCB Readings	Unknown Operations	0	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	General Comments		
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	General Comments		
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Follow-up Action Required?	n	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Fault Operations Ground	0	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Fault Operations C Ø	0	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Fault Operations B Ø	0	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BAT001458	Battery	402-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
11/3/2020 10:34	Distribution	Alexander Quarterly Inspection	BAT001458	Battery	402-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Maintenance Operations	0	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Fault Operations A Ø	0	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Amps C Ø	5.0	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Amps B Ø	5.0	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Amps A Ø	20.0	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	9 Month Operations	2	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	226	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Current Tap Position	8L	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	General Comments		
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Max Tap Position	5L	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Regulator As Left Counter	96019	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Tank Leaks	None	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Operations Counter AF	319	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	General Comments		
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	General Comments		
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Follow-up Action Required?	n	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Fault Operations Ground	0	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Fault Operations C Ø	0	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Operations Counter AL	319	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Operations This Read Vac	0	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Switching Operations	0	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Unknown Operations	0	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Fault Adjusted Amps C Phase V	8.63	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Fault Adjusted Amps B Phase V	8.63	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Amps C Ø	165.0	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Amps B Ø	132.0	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Amps A Ø	178.0	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	9 Month Operations	17	
11/3/2020 12:20	Distribution	Dixon Quarterly Inspection	RG000038	Regulator	502-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
11/3/2020 16:52	Distribution	Wilmore Quarterly Inspection	K0144	BreakerVacuum	677-0587	VCB Readings	Fault Operations B Ø	0	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	General Comments		
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Tank Leaks	None	
11/3/2020 16:27	Distribution	High Bridge Quarterly Inspection	R1115	Regulator	762-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Unknown Operations	0	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Switching Operations	0	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Operations This Read Vac	0	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Operations Counter AL	213	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Operations Counter AF	213	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Readings	Maintenance Operations	0	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/3/2020 9:13	Distribution	Hanson Quarterly Inspection	K0127	BreakerVacuum	869-0809	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Maintenance Operations	0	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	8	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Unknown Operations	0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Switching Operations	0	
11/3/2020 9:50	Distribution	Lagrange East Quarterly Inspection	C0488	WithLTC	897-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Follow-up Action Required?	n	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Operations This Read Vac	0	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Operations Counter AL	70	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Operations Counter AF	70	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	65.0	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	CB0155	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	100.0	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Counter Readings	LTC Operations Since Last Insp	509	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Counter Readings	LTC Min Tap Position	5L	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Counter Readings	LTC Max Tap Position	9L	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Counter Readings	LTC Current Tap Position	7L	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Counter Readings	LTC As Left Counter	71225	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Counter Readings	LTC As Found Counter	71222	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Mechanism Patrol Inspection	General Comments		
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Operations This Read Vac	4	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Operations Counter AL	175	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Operations Counter AF	175	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Maintenance Operations	0	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	General Comments		
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Patrol Inspection	General Comments		
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Counter Readings	Follow-up Action Required?	n	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 14:33	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Counter Readings	General Comments		
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
11/3/2020 9:47	Distribution	Versailles West Quarterly Inspection	FE000355	Fence	522-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Fault Operations A Ø	0	
11/3/2020 14:13	Distribution	Sebree Quarterly Inspection	R1192	Regulator	787-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	9 Month Operations	5	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Fault Operations B Ø	2	
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Fault Operations C Ø	2	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Amps A Ø	81.0	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Counter Readings	LTC Min Tap Position	12L	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Counter Readings	LTC Operations Since Last Insp	304	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Fault Operations B Ø	0	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Fault Operations C Ø	0	
11/3/2020 14:25	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Amps B Ø	88.0	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Amps C Ø	82.0	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Bushing Condition	Good	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Fault Operations A Ø	0	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Fault Operations B Ø	0	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Fault Operations C Ø	0	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	General Comments		
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	226	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Fault Operations Ground	0	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	Follow-up Action Required?	n	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	General Comments		
11/3/2020 10:59	Distribution	Eminence Quarterly Inspection	K0006	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Patrol Inspection	Grounds in Place?	y	
11/3/2020 9:53	Distribution	Borg-Warner Quarterly Inspection	BK000540	BreakerVacuum	699-1807	VCB Readings	General Comments		
11/3/2020 8:54	Distribution	Lagrange Penal Quarterly Inspection	BK001461	BreakerVacuum	638-2514	VCB Readings	Fault Operations Ground	0	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Foundation Condition	Good	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Follow-up Action Required?	n	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Patrol Inspection	Follow-up Action Required?	n	
11/3/2020 13:57	Distribution	Beattyville City Quarterly Inspection	CB0197	BreakerVacuum	649-2301	VCB Readings	Fault Operations Ground	0	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Readings	LTC Totalizer Reading	12636.00	kw
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	850	psi
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Readings	Oil Temp Max	25	°C
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Readings	Oil Temp Present	25	°C
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Unknown Operations	0	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Tank Paint Condition	Good	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Switching Operations	1	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Operations This Read Vac	1	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	42000	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	Totalizer Meter Reading	.1632	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	Winding Temp Max	40	°C
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	Winding Temp Present	20	°C
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Foundation Condition	Good	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Readings	Totalizer Meter Reading	.7020	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	General Comments		
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	General Comments		
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Grounds in Place?	y	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Maintenance Operations	0	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Operations Counter AF	535	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Operations Counter AL	535	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	LTCC000075	LTCControl	108-5	LTC Control Insp	All Connections OK?	y	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Readings	Winding Temp Max	25	°C
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Amps B Ø	170.0	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Amps A Ø	170.0	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	General Comments		
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	General Comments		
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Readings	Winding Temp Present	25	°C
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1250	psi
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	6854.40	kw

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	117.50	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	110.00	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	T0182	NonLTC	108-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	9 Month Operations	6	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Amps C Ø	150.0	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Bushing Condition	Good	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Fault Operations A Ø	0	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Fault Operations B Ø	0	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Fault Operations C Ø	0	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Fault Operations Ground	0	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Follow-up Action Required?	n	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Follow-up Action Required?	n	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Foundation Condition	Good	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	General Comments		
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	General Comments		
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Grounds in Place?	y	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Maintenance Operations	0	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Operations Counter AF	275	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Operations Counter AL	275	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Operations This Read Vac	0	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Switching Operations	0	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Patrol Inspection	Tank Paint Condition	Good	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0180	BreakerVacuum	108-0453	VCB Readings	Unknown Operations	0	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	9 Month Operations	0	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Amps A Ø	70.0	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	9 Month Operations	3	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Fault Operations B Ø	0	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Fault Operations C Ø	0	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Fault Operations Ground	0	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Follow-up Action Required?	n	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Follow-up Action Required?	n	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Foundation Condition	Good	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	General Comments		
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	General Comments		
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Grounds in Place?	y	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Maintenance Operations	0	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Operations Counter AF	275	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Operations Counter AL	275	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Operations This Read Vac	1	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Switching Operations	1	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Readings	General Comments		
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	General Comments		
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Tank Paint Condition	Good	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Unknown Operations	0	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Readings	Follow-up Action Required?	n	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Bushing Condition	Good	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Amps C Ø	125.0	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Amps B Ø	95.0	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Amps A Ø	125.0	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Operations This Read Vac	0	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Amps B Ø	70.0	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Amps C Ø	70.0	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Bushing Condition	Good	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Fault Operations A Ø	0	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Operations Counter AL	234	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Operations Counter AF	234	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Maintenance Operations	0	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Patrol Inspection	Heaters (All) Functioning?	y	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Patrol Inspection	Grounds in Place?	y	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	General Comments		
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Patrol Inspection	General Comments		
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Patrol Inspection	Foundation Condition	Good	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Follow-up Action Required?	n	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Patrol Inspection	Follow-up Action Required?	n	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Fault Operations Ground	0	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Fault Operations C Ø	0	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Fault Operations B Ø	0	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Fault Operations A Ø	0	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Patrol Inspection	Bushing Condition	Good	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Amps C Ø	270.0	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Amps B Ø	275.0	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Amps A Ø	300.0	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Fault Operations A Ø	0	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Fault Operations B Ø	0	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Counter Readings	Follow-up Action Required?	n	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Counter Readings	General Comments		
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Mechanism Patrol Inspection	General Comments		
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Counter Readings	LTC As Found Counter	27142	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Counter Readings	LTC As Left Counter	27144	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Switching Operations	0	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Counter Readings	LTC Current Tap Position	5L	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Counter Readings	LTC Max Tap Position	4L	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Counter Readings	LTC Min Tap Position	11L	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	40	°C
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Counter Readings	LTC Operations Since Last Insp	791	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KT0036	LTCMechanism	108-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Cabinet Paint Condition	Good	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Bushings Connection/Risers	Good	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	LTCC000075	LTCControl	108-5	LTC Control Insp	Follow-up Action Required?	n	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	LTCC000075	LTCControl	108-5	LTC Control Insp	General Comments		
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	LTCC000075	LTCControl	108-5	LTC Control Insp	LTC Operation Checked?	y	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	K0179	BreakerVacuum	108-0452	VCB Readings	9 Month Operations	6	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Follow-up Action Required?	n	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Patrol Inspection	Follow-up Action Required?	n	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Readings	Unknown Operations	0	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KB0091	BreakerVacuum	108-5	VCB Patrol Inspection	Tank Paint Condition	Good	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	LTCC000075	LTCControl	108-5	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	LTCC000075	LTCControl	108-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	LTCC000075	LTCControl	108-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	LTCC000075	LTCControl	108-5	LTC Control Insp	VRR Time Delay	30	Seconds
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Fault Operations Ground	0	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	KT0036	WithLTC	108-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
11/2/2020 16:07	Distribution	Adams Quarterly Inspection	BK000557	BreakerVacuum	108-3401	VCB Readings	Fault Operations C Ø	0	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Follow-up Action Required?	n	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Fault Operations A Ø	0	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Eyewash Solution	Good	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Amps A Ø	0.0	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	9 Month Operations	10	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	BCH000573	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	General Comments		
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	BCH000573	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	9 Month Operations	4	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Amps A Ø	0.0	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Amps B Ø	0.0	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Amps C Ø	0.0	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Bushing Condition	Good	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Counter Readings	LTC Operations Since Last Insp	196	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	LTCC000112	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	LTCC000112	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	LTCC000112	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Counter Readings	LTC Min Tap Position	9L	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Counter Readings	LTC Max Tap Position	5L	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Counter Readings	LTC Current Tap Position	7L	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Counter Readings	LTC As Left Counter	187329	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Counter Readings	LTC As Found Counter	187325	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Mechanism Patrol Inspection	General Comments		
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Counter Readings	General Comments		
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Bushing Condition	Good	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Amps C Ø	0.0	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Amps B Ø	0.0	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	BCH000573	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	BCH000573	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	48.0	VDC
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Battery Overall Condition	Good	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	BAT001043	Battery	204-Battery Bank Dist	Battery Patrol Inspection	All Connections OK?	y	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	BCH000573	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	BCH000573	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	BCH000573	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Grounds in Place?	y	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Fault Operations B Ø	0	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Fault Operations C Ø	0	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Fault Operations Ground	0	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Follow-up Action Required?	n	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Follow-up Action Required?	n	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Foundation Condition	Good	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	General Comments		
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	General Comments		
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Grounds in Place?	y	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Maintenance Operations	0	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Maintenance Operations	0	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Operations Counter AF	218	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Operations Counter AL	218	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Operations This Read Vac	4	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Switching Operations	4	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Patrol Inspection	Tank Paint Condition	Good	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0258	BreakerVacuum	204-2125	VCB Readings	Unknown Operations	0	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Operations Counter AF	178	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Operations Counter AL	178	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Operations This Read Vac	2	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Switching Operations	2	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Tank Paint Condition	Good	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Unknown Operations	0	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Amps C Ø	0.0	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Amps B Ø	0.0	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	LTCC000112	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Grounds in Place?	y	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Maintenance Operations	0	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Operations Counter AF	728	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Operations Counter AL	728	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Operations This Read Vac	0	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Switching Operations	0	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Bushing Condition	Good	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	9 Month Operations	5	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Tank Paint Condition	Good	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Unknown Operations	0	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Amps A Ø	0.0	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Follow-up Action Required?	n	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Fault Operations Ground	0	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	LTCC000112	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Fault Operations C Ø	0	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Follow-up Action Required?	n	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	LTCC000112	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	Foundation Condition	Good	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	LTCC000112	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	0.0	VAC
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Fault Operations A Ø	0	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Fault Operations B Ø	0	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	C0450	LTCMechanism	204-5	LTC Counter Readings	Follow-up Action Required?	n	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Patrol Inspection	General Comments		
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	General Comments		
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	LTCC000112	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Fault Operations C Ø	0	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Fault Operations B Ø	0	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Fault Operations A Ø	0	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	CB0224	BreakerVacuum	204-2124	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Fault Operations Ground	0	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Follow-up Action Required?	n	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	General Comments		
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	General Comments		
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Patrol Inspection	Foundation Condition	Good	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	BK000253	BreakerVacuum	204-2123	VCB Readings	Follow-up Action Required?	n	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	Oil Temp Present	25	°C
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	Oil Temp Max	90	°C
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	General Comments		
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	General Comments		
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/30/2020 6:46	Distribution	Danville North Quarterly Inspection	C0450	WithLTC	204-5	LTC Transformer Readings	Follow-up Action Required?	n	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Readings	Non LTC Totalizer Reading	885.12	kw
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	50	°C
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	30	°C
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Reading	.2766	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	70.00	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0304	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BCH001104	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BCH001104	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BCH001104	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BCH001104	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Battery Charger Current	1	amps
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BCH001104	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	132	VDC
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BCH001104	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	132	VDC
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BCH001104	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	General Comments		
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	9 Month Operations	32	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Accumulated Fault Duty A Ph V	0	%
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Vegetation	None	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Accumulated Fault Duty B Ph V	0	%
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Accumulated Fault Duty C Ph V	0	%
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Amps A Ø	63	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Amps B Ø	54	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Amps C Ø	57	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Follow-up Action Required?	n	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Follow-up Action Required?	n	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Fault Operations Ground	0	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Fault Operations C Ø	0	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Fault Operations B Ø	0	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	General Comments		
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Bushing Condition	Good	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Unknown Operations	0	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Tank Paint Condition	Good	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	General Comments		
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Grounds in Place?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Maintenance Operations	16	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Operations Counter AF	502	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Operations Counter AL	502	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Operations This Read Vac	17	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Switching Operations	1	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Tank Paint Condition	Good	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Unknown Operations	0	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	General Comments		
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	BAT000966	Battery	582-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	LTC Operations Since Last Insp	316	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	1	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0	%
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	2.2	%
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	2.2	%
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	420	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	500	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	470	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	General Comments		
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	Winding Temp Present	30	°C
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	Winding Temp Max	45	°C
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	Totalizer Meter Reading	.479	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	55.00	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	Winding Temp Present	40	°C
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	Winding Temp Max	50	°C
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	Totalizer Meter Reading	.4420	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	Oil Temp Present	40	°C
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	Oil Temp Max	50	°C
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	LTC Totalizer Reading	7956.00	kw
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	General Comments		
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	General Comments		
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	General Comments		
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0516	WithLTC	582-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BAT001153	Battery	532-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	9 Month Operations	26	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Accumulated Fault Duty A Ph V	0	%
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Accumulated Fault Duty B Ph V	0	%
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Accumulated Fault Duty C Ph V	0	%
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Amps A Ø	115	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Amps B Ø	165	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Amps C Ø	122	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Bushing Condition	Good	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Fault Operations A Ø	0	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Fault Operations B Ø	0	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Fault Operations C Ø	0	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Fault Operations Ground	0	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Follow-up Action Required?	n	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Readings	Follow-up Action Required?	n	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0446	BreakerVacuum	532-0145	VCB Patrol Inspection	General Comments		
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Amps A Ø	100	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Accumulated Fault Duty C Ph V	10.91	%
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Accumulated Fault Duty B Ph V	10.91	%
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Accumulated Fault Duty A Ph V	11.82	%
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	9 Month Operations	9	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0	psi
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	LTC Min Tap Position	8L	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	LTC Current Tap Position	7L	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	LTC As Left Counter	71636	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	LTC As Found Counter	71636	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Mechanism Patrol Inspection	General Comments		
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	General Comments		
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	B0458	LTCMechanism	532-1	LTC Counter Readings	Follow-up Action Required?	n	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	General Comments		
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	FE000348	Fence	532-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Ambient Temp	75	*F
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	YD000352	Yard	532-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	General Comments		
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	FE000538	Fence	582-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	ST000356	Structure	532-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	CH000343	ControlHouse	532-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	236	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	236	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0357	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Unknown Operations	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Tank Paint Condition	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Switching Operations	0	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Operations This Read Vac	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Operations Counter AL	243	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Operations Counter AF	243	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Maintenance Operations	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	Oil Temp Present	30	°C
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Grounds in Place?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	General Comments		
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Foundation Condition	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Follow-up Action Required?	n	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Follow-up Action Required?	n	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Fault Operations Ground	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Fault Operations C ∅	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Fault Operations B ∅	0	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	Oil Temp Max	40	°C
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Fault Operations A ∅	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	LTC Totalizer Reading	11496	kw
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	General Comments		
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	General Comments		
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	B0458	WithLTC	532-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Patrol Inspection	Bushing Condition	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Amps C ∅	100	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0062	BreakerVacuum	463-0053	VCB Readings	Amps B Ø	100	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Fault Operations Ground	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Fault Operations C Ø	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Fault Operations B Ø	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Fault Operations A Ø	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Operations This Read Vac	27	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Operations Counter AL	394	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Operations Counter AF	394	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Maintenance Operations	26	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Grounds in Place?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	General Comments		
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	General Comments		
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Foundation Condition	Good	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Follow-up Action Required?	n	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Fault Operations Ground	0	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Fault Operations C Ø	0	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Fault Operations B Ø	0	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Fault Operations A Ø	0	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Bushing Condition	Good	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Amps C Ø	344	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	9 Month Operations	6	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Amps B Ø	371	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Amps A Ø	343	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Accumulated Fault Duty C Ph V	0	%
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Accumulated Fault Duty B Ph V	0	%
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Min Tap Position	11L	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Regulator As Left Counter	7818	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	RG000053	Regulator	582-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Unknown Operations	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Tank Paint Condition	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Switching Operations	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Operations This Read Vac	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Operations Counter AL	219	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Operations Counter AF	219	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Maintenance Operations	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Grounds in Place?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	General Comments		
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	General Comments		
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Foundation Condition	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	9 Month Operations	4	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Accumulated Fault Duty A Ph V	12.16	%
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Accumulated Fault Duty B Ph V	12.16	%
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Patrol Inspection	Tank Paint Condition	Good	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Switching Operations	1	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Bushing Condition	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Amps C Ø	110.0	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Amps B Ø	65.0	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Amps A Ø	110.0	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Follow-up Action Required?	n	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Follow-up Action Required?	n	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Tank Paint Condition	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Switching Operations	1	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Patrol Inspection	Bushing Condition	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Amps C Ø	100	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Amps B Ø	100	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Amps A Ø	100	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Accumulated Fault Duty C Ph V	.91	%
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Accumulated Fault Duty B Ph V	.91	%
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	Accumulated Fault Duty A Ph V	.91	%
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Operations This Read Vac	1	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Operations Counter AL	254	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Operations Counter AF	254	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Maintenance Operations	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Grounds in Place?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	General Comments		
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	General Comments		
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	General Comments		
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0189	BreakerVacuum	463-0040	VCB Readings	9 Month Operations	4	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Fault Operations A Ø	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Fault Operations B Ø	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Fault Operations C Ø	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Fault Operations Ground	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Follow-up Action Required?	n	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Follow-up Action Required?	n	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Foundation Condition	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	General Comments		
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	General Comments		
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Grounds in Place?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	Accumulated Fault Duty A Ph V	0	%
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0450	BreakerVacuum	532-1	VCB Readings	9 Month Operations	37	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Accumulated Fault Duty C Ph V	4.68	%
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Amps A Ø	240	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Amps B Ø	240	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Amps C Ø	240	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Unknown Operations	0	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Tank Paint Condition	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Switching Operations	3	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Operations This Read Vac	3	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Operations Counter AL	313	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Operations Counter AF	313	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Maintenance Operations	0	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Grounds in Place?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	General Comments		
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	General Comments		
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Foundation Condition	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Follow-up Action Required?	n	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Follow-up Action Required?	n	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Fault Operations Ground	0	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Fault Operations C Ø	0	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Fault Operations B Ø	0	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Fault Operations A Ø	0	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Patrol Inspection	Bushing Condition	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Amps C Ø	80.0	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Amps B Ø	80.0	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Amps A Ø	80.0	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0238	BreakerVacuum	582-2110	VCB Readings	9 Month Operations	8	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Bushing Condition	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Unknown Operations	0	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	845	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Ambient Temp	65	*F
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	General Comments		
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Max Tap Position	8L	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Min Tap Position	11L	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Regulator As Left Counter	6977	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	9 Month Operations	0	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Amps A Ø	300.0	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Amps B Ø	300.0	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Amps C Ø	300.0	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Bushing Condition	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Counter Readings	LTC As Found Counter	66186	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Counter Readings	LTC As Left Counter	66186	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Counter Readings	LTC Current Tap Position	4L	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Counter Readings	LTC Min Tap Position	7L	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	2	psi
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Counter Readings	LTC Operations Since Last Insp	544	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Current Tap Position	10L	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	RG000051	Regulator	582-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	General Comments		
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	ST000548	Structure	582-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Vegetation	None	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	General Comments		
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	YD000544	Yard	582-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	K0039	BreakerVacuum	582-2	VCB Readings	Unknown Operations	0	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Fault Operations Ground	0	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Fault Operations C Ø	0	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Fault Operations B Ø	0	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Fault Operations A Ø	0	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	100	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	140	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	100	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	12.16	%
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	7.48	%
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	7.48	%
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0267	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Current Tap Position	11L	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	RG000052	Regulator	582-1 B	Regulator Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Maintenance Operations	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Operations Counter AF	618	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Operations Counter AL	618	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Operations This Read Vac	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Switching Operations	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Tank Paint Condition	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Unknown Operations	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	Totalizer Meter Reading	1.246	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	Winding Temp Max	70	°C
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	Winding Temp Present	60	°C
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	90	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Unknown Operations	0	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Tank Paint Condition	Good	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Switching Operations	1	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Operations This Read Vac	17	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Operations Counter AL	592	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Operations Counter AF	592	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Readings	Maintenance Operations	16	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0448	BreakerVacuum	532-0147	VCB Patrol Inspection	Grounds in Place?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	General Comments		
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	General Comments		
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	LTC Totalizer Reading	29904	kw
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	Oil Temp Max	50	°C
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	Oil Temp Present	50	°C
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Amps A Ø	100	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Amps B Ø	140	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Amps C Ø	100	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Bushing Condition	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Maintenance Operations	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	FE000388	Fence	463-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	9 Month Operations	5	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Accumulated Fault Duty A Ph V	4.68	%
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Accumulated Fault Duty B Ph V	1.87	%
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Accumulated Fault Duty C Ph V	0	%
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Amps A Ø	240	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Amps B Ø	240	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Amps C Ø	240	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Bushing Condition	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Fault Operations A Ø	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Fault Operations B Ø	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Fault Operations C Ø	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Fault Operations Ground	0	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Unknown Operations	0	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Tank Paint Condition	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Switching Operations	0	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Operations This Read Vac	0	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Operations Counter AL	343	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Operations Counter AF	343	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Maintenance Operations	0	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Grounds in Place?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	General Comments		
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	General Comments		
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Foundation Condition	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Follow-up Action Required?	n	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Patrol Inspection	Follow-up Action Required?	n	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Fault Operations Ground	0	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Fault Operations C Ø	0	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Fault Operations B Ø	0	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Fault Operations A Ø	0	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0246	BreakerVacuum	582-0164	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Follow-up Action Required?	n	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Readings	Follow-up Action Required?	n	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	Foundation Condition	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	K0156	BreakerVacuum	463-0102	VCB Patrol Inspection	General Comments		
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	9 Month Operations	4	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Accumulated Fault Duty A Ph V	8.42	%
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Accumulated Fault Duty B Ph V	6.55	%
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0397	BreakerVacuum	463-0069	VCB Readings	Accumulated Fault Duty C Ph V	9.35	%
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	BCH000609	Charger	582-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	BCH000609	Charger	582-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	BCH000609	Charger	582-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	BCH000609	Charger	582-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	BCH000609	Charger	582-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	BCH000609	Charger	582-Battery Charger	Battery Charger Patrol Insp	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	General Comments		
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	General Comments		
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	LTC Totalizer Reading	24576	kw
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2	psi
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	Oil Temp Max	75	°C
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	Oil Temp Present	50	°C
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	Totalizer Meter Reading	1.024	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	Winding Temp Max	70	°C
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	Winding Temp Present	40	°C
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0400	WithLTC	463-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Operations Counter AF	776	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Operations Counter AL	776	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Operations This Read Vac	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Switching Operations	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Patrol Inspection	Tank Paint Condition	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0398	BreakerVacuum	463-0044	VCB Readings	Unknown Operations	0	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Counter Readings	LTC Operations Since Last Insp	544	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Counter Readings	LTC Min Tap Position	12L	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Counter Readings	LTC Max Tap Position	5L	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Counter Readings	LTC Current Tap Position	10L	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Counter Readings	LTC As Left Counter	91031	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Counter Readings	LTC As Found Counter	91027	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Mechanism Patrol Inspection	General Comments		
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Counter Readings	General Comments		
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	C0516	LTCMechanism	582-2	LTC Counter Readings	Follow-up Action Required?	n	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	7	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0	%
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0	%
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0	%
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Amps A ∅	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Amps B ∅	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Patrol Inspection	Bushing Condition	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Readings	Amps C ∅	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0299	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Amps C ∅	182	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Amps B ∅	181	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Amps A ∅	152	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Accumulated Fault Duty C Ph V	9.35	%
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Accumulated Fault Duty B Ph V	4.68	%
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	Accumulated Fault Duty A Ph V	10.29	%
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	KB0112	BreakerVacuum	463-0188	VCB Readings	9 Month Operations	1	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0451	WithLTC	463-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Ambient Temp	75	*F
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	General Comments		
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Foundation Condition	Good	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Follow-up Action Required?	n	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Follow-up Action Required?	n	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Fault Operations Ground	0	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Fault Operations C Ø	0	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	5.0	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	277	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	277	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Bushing Condition	Good	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Amps C Ø	48	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Amps B Ø	63	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Amps A Ø	79	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	General Comments		
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	General Comments		
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	ST000397	Structure	463-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Vegetation	None	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	5.0	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	5.0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	YD000394	Yard	463-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Maintenance Operations	18	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Operations Counter AF	507	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Operations Counter AL	507	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Operations This Read Vac	19	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Operations This Read Vac	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Operations Counter AL	650	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Operations Counter AF	650	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Maintenance Operations	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Grounds in Place?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	General Comments		
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	General Comments		
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Foundation Condition	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	9 Month Operations	4	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Switching Operations	1	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Tank Paint Condition	Good	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Fault Operations B Ø	0	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Fault Operations A Ø	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Follow-up Action Required?	n	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Follow-up Action Required?	n	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Fault Operations Ground	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Fault Operations C Ø	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Accumulated Fault Duty A Ph V	5.61	%
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Accumulated Fault Duty B Ph V	9.35	%
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Accumulated Fault Duty C Ph V	7.48	%
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Amps A Ø	220	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Amps B Ø	210	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Amps C Ø	240	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Bushing Condition	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Fault Operations B Ø	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Fault Operations A Ø	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Accumulated Fault Duty C Ph V	0	%
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Accumulated Fault Duty B Ph V	0	%
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Accumulated Fault Duty A Ph V	0	%
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	9 Month Operations	24	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	LTCC000859	LTCControl	463-1	LTC Control Insp	All Connections OK?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	LTCC000859	LTCControl	463-1	LTC Control Insp	Follow-up Action Required?	n	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	LTCC000859	LTCControl	463-1	LTC Control Insp	General Comments		
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Broom on Site?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	LTCC000812	LTCControl	463-2	LTC Control Insp	All Connections OK?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Follow-up Action Required?	n	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	LTCC000812	LTCControl	463-2	LTC Control Insp	Follow-up Action Required?	n	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	LTCC000812	LTCControl	463-2	LTC Control Insp	General Comments		
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	LTCC000812	LTCControl	463-2	LTC Control Insp	LTC Operation Checked?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	LTCC000859	LTCControl	463-1	LTC Control Insp	LTC Operation Checked?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	LTCC000859	LTCControl	463-1	LTC Control Insp	LTC Output Voltage Level	124	VAC
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	LTCC000859	LTCControl	463-1	LTC Control Insp	VRR Base Voltage AF	124	VAC
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	LTCC000859	LTCControl	463-1	LTC Control Insp	VRR Base Voltage AL	124	VAC
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	LTCC000859	LTCControl	463-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Unknown Operations	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	LTCC000812	LTCControl	463-2	LTC Control Insp	LTC Output Voltage Level	124	VAC
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	LTCC000812	LTCControl	463-2	LTC Control Insp	VRR Base Voltage AF	124	VAC
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	LTCC000812	LTCControl	463-2	LTC Control Insp	VRR Base Voltage AL	124	VAC
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	LTCC000812	LTCControl	463-2	LTC Control Insp	VRR Time Delay	30	Seconds
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Tank Paint Condition	Good	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Readings	Switching Operations	0	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	BB0401	BreakerVacuum	463-0101	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Foundation Condition	Good	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	General Comments		
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	General Comments		
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Grounds in Place?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0449	BreakerVacuum	532-0148	VCB Readings	Unknown Operations	0	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Grounds in Place?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	General Comments		
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Maintenance Operations	7	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Operations Counter AF	798	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Operations Counter AL	798	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Operations This Read Vac	8	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Switching Operations	1	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Maintenance Operations	0	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	General Comments		
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Foundation Condition	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0260	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	8	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Bushing Condition	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Amps C Ø	20.0	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Amps B Ø	20.0	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Grounds in Place?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	General Comments		
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Follow-up Action Required?	n	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	General Comments		
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Foundation Condition	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Follow-up Action Required?	n	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Follow-up Action Required?	n	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Fault Operations Ground	0	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Amps A Ø	20.0	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	LTCC000854	LTCControl	532-1	LTC Control Insp	All Connections OK?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	LTCC000854	LTCControl	532-1	LTC Control Insp	Follow-up Action Required?	n	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Trash Emptied?	n	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	CH000333	ControlHouse	463-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	LTCC000854	LTCControl	532-1	LTC Control Insp	General Comments		
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	9 Month Operations	10	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	LTCC000854	LTCControl	532-1	LTC Control Insp	LTC Operation Checked?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	LTCC000854	LTCControl	532-1	LTC Control Insp	LTC Output Voltage Level	124	VAC
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	LTCC000854	LTCControl	532-1	LTC Control Insp	VRR Base Voltage AF	124	VAC
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	LTCC000854	LTCControl	532-1	LTC Control Insp	VRR Base Voltage AL	124	VAC
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Fault Operations C Ø	0	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Fault Operations A Ø	0	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Fault Operations B Ø	0	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Operations Counter AF	401	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Operations Counter AL	401	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Operations This Read Vac	6	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Switching Operations	6	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Tank Paint Condition	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Readings	Unknown Operations	0	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Operations Counter AF	390	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Operations Counter AL	390	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Operations This Read Vac	0	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Patrol Inspection	Grounds in Place?	y	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	General Comments		
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Switching Operations	0	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Tank Paint Condition	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Unknown Operations	0	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	BB0447	BreakerVacuum	532-0146	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0244	BreakerVacuum	582-0162	VCB Readings	Maintenance Operations	0	
10/29/2020 7:51	Distribution	Clays Mill Quarterly Inspection	LTCC000854	LTCControl	532-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Mechanism Patrol Inspection	General Comments		
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Counter Readings	Follow-up Action Required?	n	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/29/2020 8:12	Distribution	Reynolds Quarterly Inspection	B0451	LTCMechanism	463-1	LTC Counter Readings	General Comments		
10/29/2020 16:27	Distribution	Danville Central Quarterly Inspection	CB0245	BreakerVacuum	582-0163	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	General Comments		
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	General Comments		
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	LTC Totalizer Reading	8748	kw
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	Oil Temp Max	60	°C
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0283	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0283	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0283	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0283	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	Oil Temp Present	40	°C
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	General Comments		
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0283	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0283	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0283	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0283	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Unknown Operations	0	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0270	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0270	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0270	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0270	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Fence Ties Intact?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Acceptable Building Appearance?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Broom on Site?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Control House Lighting OK?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Door Alarms OK?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Switching Operations	8	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Operations This Read Vac	8	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Operations Counter AL	322	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Operations Counter AF	322	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Evidence of Insects	None	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Floor Swept?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Maintenance Operations	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Grounds in Place?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	General Comments		
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	General Comments		
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Foundation Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	General Comments	ok	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Vegetation	None	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	ST000344	Structure	617-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Follow-up Action Required?	n	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Fault Operations Ground	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Fault Operations C ∅	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Fault Operations B ∅	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Fault Operations A ∅	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Panel Lights OK?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Panels Dusted?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Station Ground Set On Site?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	Trash Emptied?	y	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	Totalizer Meter Reading	.249	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Unknown Operations	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	9 Month Operations	2	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000732	BreakerVacuum	617-2	VCB Readings	Accumulated Fault Duty A Ph V	0	%
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Counter Readings	General Comments		
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Mechanism Patrol Inspection	General Comments		
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	Totalizer Meter Reading	.486	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	Winding Temp Max	50	°C
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	Winding Temp Present	40	°C
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Readings	General Comments		
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0931	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0931	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0931	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0931	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0931	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	70.00	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0931	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0931	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0931	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Counter Readings	LTC As Found Counter	126076	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Counter Readings	LTC As Left Counter	126076	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Counter Readings	LTC Current Tap Position	8L	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Counter Readings	LTC Max Tap Position	4L	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Counter Readings	LTC Min Tap Position	12L	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Counter Readings	LTC Operations Since Last Insp	594	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	Oil Temp Present	30	°C
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	Oil Temp Max	45	°C
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	LTC Totalizer Reading	2390.4	kw
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	General Comments		
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	9 Month Operations	19	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Accumulated Fault Duty A Ph V	1.01	%
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Accumulated Fault Duty B Ph V	1.01	%
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	8	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pop-off Valve Tested Date	2020-01-09 00:00:00.000000000	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000138	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Accumulated Fault Duty C Ph V	0	%
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Amps A Ø	51	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Amps B Ø	48	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Readings	Amps C Ø	56	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Bushing Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0154	BreakerVacuum	617-0057	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Bushing Condition	Good	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Amps C Ø	14	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Amps B Ø	15	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Amps A Ø	12	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Accumulated Fault Duty C Ph V	.68	%
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Accumulated Fault Duty B Ph V	.34	%
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0426	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0426	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0426	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0426	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0426	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0426	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0426	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0426	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Accumulated Fault Duty A Ph V	1.02	%
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	9 Month Operations	5	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Unknown Operations	0	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Switching Operations	0	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Operations This Read Vac	0	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Operations Counter AL	189	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Operations Counter AF	189	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Maintenance Operations	0	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Grounds in Place?	y	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	General Comments		
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BCH000380	Charger	Retired Distribution	Battery Charger Patrol Insp	Ground Lights	None	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BCH000380	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BCH000380	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BCH000380	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	2.5	amps
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BCH000380	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53	VDC
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Unknown Operations	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Switching Operations	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Fault Operations A Ø	0	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Fault Operations B Ø	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Amps C Ø	0	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Amps B Ø	0	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Amps A Ø	0	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Accumulated Fault Duty C Ph V	0	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Accumulated Fault Duty B Ph V	0	%
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Accumulated Fault Duty A Ph V	0	%
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	9 Month Operations	35	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Unknown Operations	0	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Switching Operations	0	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Operations This Read Vac	0	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Operations Counter AL	172	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Operations Counter AF	172	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Maintenance Operations	0	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Grounds in Place?	y	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	General Comments		
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	General Comments		
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Foundation Condition	Good	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Follow-up Action Required?	n	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Fault Operations Ground	0	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Fault Operations C Ø	0	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000212	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Fault Operations B Ø	0	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Fault Operations A Ø	0	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000920	BreakerVacuum	660-0063	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	General Comments		
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	70.00	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Amps A Ø	320	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Accumulated Fault Duty C Ph V	0	%
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Accumulated Fault Duty B Ph V	5.07	%
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Accumulated Fault Duty A Ph V	6.09	%
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	9 Month Operations	6	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BCH000380	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53	VDC
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BCH000380	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0282	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0282	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0282	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0282	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	45.00	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0282	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0282	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0282	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0282	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	General Comments		
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	FE000351	Fence	658-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Fault Operations C Ø	0	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Fault Operations Ground	0	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Follow-up Action Required?	n	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Foundation Condition	Good	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	General Comments		
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Operations This Read Vac	4	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Operations Counter AL	287	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Operations Counter AF	287	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Maintenance Operations	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Grounds in Place?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	General Comments		
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Foundation Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Follow-up Action Required?	n	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Fault Operations Ground	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Fault Operations C Ø	2	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Fault Operations B Ø	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Fault Operations A Ø	2	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Fault Adjusted Amps C Phase V	27.22	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Fault Adjusted Amps A Phase V	27.22	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Patrol Inspection	Bushing Condition	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	ST000360	Structure	658-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Amps C Ø	320	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	K0181	BreakerVacuum	617-0110	VCB Readings	Amps B Ø	330	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0207	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	15.00	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0413	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0413	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0413	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0413	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0413	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0413	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Amps B Ø	185	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Unknown Operations	0	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Switching Operations	1	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Operations This Read Vac	1	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Operations Counter AL	253	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Operations Counter AF	253	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Maintenance Operations	0	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Grounds in Place?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Amps A Ø	193	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Accumulated Fault Duty C Ph V	8.33	%
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Accumulated Fault Duty B Ph V	15.62	%
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	General Comments		
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Foundation Condition	Good	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Follow-up Action Required?	n	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Fault Operations Ground	0	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Fault Operations C Ø	0	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Fault Operations B Ø	0	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Fault Operations A Ø	0	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Patrol Inspection	Bushing Condition	Good	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Amps C Ø	115	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0270	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0270	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0270	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0270	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	YD000341	Yard	617-Yard	Yard Patrol Inspection	Ambient Temp	75	*F
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Oil Status	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	General Comments		
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	FE000824	Fence	617-Yard	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Fans Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0980	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0413	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0413	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0358	WithLTC	617-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Maintenance Operations	0	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Grounds in Place?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	General Comments		
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	General Comments		
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Foundation Condition	Good	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Follow-up Action Required?	n	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Fault Operations Ground	0	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Fault Operations C Ø	0	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Fault Operations B Ø	0	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Fault Operations A Ø	0	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	Oil Temp Present	40	°C
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	Oil Temp Max	55	°C
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	LTC Totalizer Reading	11646	kw
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	General Comments		
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	General Comments		
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Bushing Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Amps B Ø	111	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Amps A Ø	108	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Accumulated Fault Duty C Ph V	0	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Accumulated Fault Duty B Ph V	0	%
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	Accumulated Fault Duty A Ph V	0	%
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0390	BreakerVacuum	658-1	VCB Readings	9 Month Operations	23	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0038	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	625	psi
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000131	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Unknown Operations	0	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Switching Operations	1	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Operations This Read Vac	1	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Operations Counter AL	300	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BB0468	BreakerVacuum	658-0836	VCB Readings	Operations Counter AF	300	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Accumulated Fault Duty A Ph V	9.37	%
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	9 Month Operations	2	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	9 Month Operations	10	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Accumulated Fault Duty A Ph V	2.04	%
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Accumulated Fault Duty B Ph V	1.02	%
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Accumulated Fault Duty C Ph V	1.02	%
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Amps A Ø	84	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Amps B Ø	68	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Readings	Amps C Ø	86	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Bushing Condition	Good	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BK000919	BreakerVacuum	660-0037	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	Winding Temp Present	40	°C
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	Winding Temp Max	60	°C
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0370	WithLTC	617-2	LTC Transformer Readings	Totalizer Meter Reading	.647	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Follow-up Action Required?	n	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Foundation Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	General Comments		
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	General Comments		
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Grounds in Place?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Maintenance Operations	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	General Comments		
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Operations Counter AF	191	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Operations Counter AL	191	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Operations This Read Vac	0	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0413	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0413	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0413	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0413	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Switching Operations	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Unknown Operations	0	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Counter Readings	Follow-up Action Required?	n	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Counter Readings	General Comments		
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Mechanism Patrol Inspection	General Comments		
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Counter Readings	LTC As Found Counter	37496	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Counter Readings	LTC As Left Counter	37496	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Counter Readings	LTC Current Tap Position	4L	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Counter Readings	LTC Max Tap Position	2R	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Counter Readings	LTC Min Tap Position	5L	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Counter Readings	LTC Operations Since Last Insp	330	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Bushing Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	9 Month Operations	26	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Accumulated Fault Duty A Ph V	0	%
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Accumulated Fault Duty B Ph V	0	%
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Accumulated Fault Duty C Ph V	0	%
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Amps A Ø	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Amps B Ø	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Amps C Ø	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Patrol Inspection	Bushing Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Retired Distribution		
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Retired Distribution		
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0270	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Unknown Operations	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Switching Operations	1	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Operations This Read Vac	1	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Operations Counter AL	237	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Operations Counter AF	237	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0270	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Fault Operations A Ø	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Fault Operations B Ø	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Fault Operations C Ø	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Fault Operations Ground	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	820	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	General Comments		
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	820	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	3	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	3	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	*F
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Counter Readings	LTC Current Tap Position	7L	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Counter Readings	LTC Max Tap Position	1L	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Counter Readings	LTC Min Tap Position	12L	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Counter Readings	LTC Operations Since Last Insp	727	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000063	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	35.00	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Fault Operations Ground	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Follow-up Action Required?	n	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Patrol Inspection	Foundation Condition	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Patrol Inspection	General Comments		
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	General Comments		
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Patrol Inspection	Grounds in Place?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Maintenance Operations	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	LTCC000910	LTCControl	658-1	LTC Control Insp	LTC Operation Checked?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	LTCC000910	LTCControl	658-1	LTC Control Insp	LTC Output Voltage Level	122	VAC
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	LTCC000910	LTCControl	658-1	LTC Control Insp	VRR Base Voltage AF	122	VAC
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	LTCC000910	LTCControl	658-1	LTC Control Insp	VRR Base Voltage AL	122	VAC
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	LTCC000910	LTCControl	658-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	LTCC000646	LTCControl	660-1	LTC Control Insp	VRR Base Voltage AF	124	VAC
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	LTCC000646	LTCControl	660-1	LTC Control Insp	VRR Base Voltage AL	124	VAC
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	LTCC000646	LTCControl	660-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0410	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0410	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0410	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0410	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0410	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	20.00	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0410	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0410	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	LTCC000775	LTCControl	617-2	LTC Control Insp	All Connections OK?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	LTCC000775	LTCControl	617-2	LTC Control Insp	Follow-up Action Required?	n	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	LTCC000775	LTCControl	617-2	LTC Control Insp	General Comments		
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0410	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	C0410	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Operations Counter AF	155	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Operations Counter AL	155	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Operations This Read Vac	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Switching Operations	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Unknown Operations	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	LTCC000775	LTCControl	617-2	LTC Control Insp	VRR Time Delay	30	Seconds
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	LTCC000775	LTCControl	617-2	LTC Control Insp	VRR Base Voltage AL	124	VAC
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	LTCC000775	LTCControl	617-2	LTC Control Insp	VRR Base Voltage AF	124	VAC
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	LTCC000775	LTCControl	617-2	LTC Control Insp	LTC Output Voltage Level	124	VAC
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	General Comments		
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low, note cell #'s
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	LTCC000775	LTCControl	617-2	LTC Control Insp	LTC Operation Checked?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	70.00	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	O0202	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Amps C Ø	152	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	LTCC000646	LTCControl	660-1	LTC Control Insp	All Connections OK?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	LTCC000646	LTCControl	660-1	LTC Control Insp	Follow-up Action Required?	n	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	LTCC000646	LTCControl	660-1	LTC Control Insp	General Comments		
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	LTCC000646	LTCControl	660-1	LTC Control Insp	LTC Operation Checked?	y	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	LTCC000646	LTCControl	660-1	LTC Control Insp	LTC Output Voltage Level	124	VAC
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	35.00	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	B0361	LTCMechanism	658-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0370	LTCMechanism	617-2	LTC Counter Readings	Follow-up Action Required?	n	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000062	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	CH000352	ControlHouse	617-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	LTCC000762	LTCControl	617-1	LTC Control Insp	All Connections OK?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	LTCC000762	LTCControl	617-1	LTC Control Insp	Follow-up Action Required?	n	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	LTCC000762	LTCControl	617-1	LTC Control Insp	General Comments		
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	LTCC000762	LTCControl	617-1	LTC Control Insp	LTC Operation Checked?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	LTCC000762	LTCControl	617-1	LTC Control Insp	LTC Output Voltage Level	124	VAC
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	LTCC000762	LTCControl	617-1	LTC Control Insp	VRR Base Voltage AF	124	VAC
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	LTCC000762	LTCControl	617-1	LTC Control Insp	VRR Base Voltage AL	124	VAC
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	LTCC000762	LTCControl	617-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	TX000061	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Fault Operations A Ø	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Fault Operations B Ø	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK001256	BreakerVacuum	617-BT2-1	VCB Readings	Fault Operations C Ø	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Foundation Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	General Comments		
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	W0074	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	W0074	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	W0074	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	General Comments		
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Grounds in Place?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Maintenance Operations	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	LTCC000910	LTCControl	658-1	LTC Control Insp	All Connections OK?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	LTCC000910	LTCControl	658-1	LTC Control Insp	Follow-up Action Required?	n	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	LTCC000910	LTCControl	658-1	LTC Control Insp	General Comments		
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Ambient Temp	75	°F
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0426	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0426	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Readings	Winding Temp Present	30	°C
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Readings	Winding Temp Max	45	°C
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Readings	Totalizer Meter Reading	.174	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Readings	Oil Temp Present	35	°C
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Readings	Oil Temp Max	50	°C
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Readings	LTC Totalizer Reading	2505.6	kw
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Readings	General Comments		
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	General Comments		
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0426	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	B0426	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	88	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BCH000873	Charger	658-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BCH000873	Charger	658-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BCH000873	Charger	658-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	CH000133	ControlHouse	BR-Control House 1	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	Follow-up Action Required?	n	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0480	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	General Comments		
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	LTC As Found Counter	112430	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	LTC As Left Counter	112430	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	LTC Current Tap Position	5L	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	LTC Max Tap Position	3R	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	LTC Min Tap Position	7L	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	LTC Operations Since Last Insp	744	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0013	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Readings	General Comments		
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0013	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0013	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0013	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	26.00	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0013	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0013	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0013	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Hydraulic Leaks	None	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Hydraulic Oil Levels OK?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Hydraulic Pressure Acceptable?	y	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	M0013	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	1	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	TB0497	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	88	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	W0075	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	W0075	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	W0075	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	W0075	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	35.00	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	W0075	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	W0075	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	W0075	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	W0075	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	W0074	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	W0074	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	W0074	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	W0074	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	W0074	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Follow-up Action Required?	n	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BAT001051	Battery	658-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	19	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	13.19	%
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	13.19	%
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	11.16	%
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	240	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	240	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	250	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Fault Operations Ground	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Fault Operations C Ø	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Fault Operations B Ø	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Fault Operations A Ø	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000248	BreakerVacuum	617-0103	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Counter Readings	Follow-up Action Required?	n	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BB0393	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Counter Readings	General Comments		
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Mechanism Patrol Inspection	General Comments		
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Counter Readings	LTC As Found Counter	9521	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Counter Readings	LTC As Left Counter	9521	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	B0358	LTCMechanism	617-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BAT001122	Battery	617-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Vegetation	None	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0271	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0271	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0271	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0271	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0271	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0271	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	35.00	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0271	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0271	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0271	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0271	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	9 Month Operations	2	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	General Comments		
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Accumulated Fault Duty A Ph V	0	%
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Accumulated Fault Duty B Ph V	0	%
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Accumulated Fault Duty C Ph V	0	%
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Amps A Ø	397	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Amps B Ø	376	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	YD000357	Yard	658-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Readings	Amps C Ø	381	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	General Comments		
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	CH000353	ControlHouse	658-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	B0361	WithLTC	658-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BCH000873	Charger	658-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BCH000873	Charger	658-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133	VDC
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BCH000873	Charger	658-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133	VDC
10/28/2020 17:57	Distribution	IBM North Quarterly Inspection	BCH000873	Charger	658-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2	amps
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/28/2020 9:09	Distribution	Pineville Substation Department Transformer Quarterly Inspection	0947	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/28/2020 18:16	Distribution	IBM Quarterly Inspection	BK000500	BreakerVacuum	617-1	VCB Patrol Inspection	Bushing Condition	Good	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	144	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	144	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	6	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0	%
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0	%
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0	%
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	BB0241	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	498	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	498	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	1.63	%
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	1.63	%
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	1.63	%
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	8	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	1	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	BB0236	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	5.07	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	BAT001408	Battery	930-Offline-Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	BAT001408	Battery	930-Offline-Distribution	Battery Patrol Inspection	General Comments		
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	BAT001408	Battery	930-Offline-Distribution	Battery Patrol Inspection	Negative DC Ground	0	VDC
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	BAT001408	Battery	930-Offline-Distribution	Battery Patrol Inspection	Positive DC Ground	0	VDC
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	BAT001408	Battery	930-Offline-Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	BAT001408	Battery	930-Offline-Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	BCH001326	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	BCH001326	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	BCH001326	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	BCH001326	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	BCH001326	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	BCH001326	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	BCH001326	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	General Comments		
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	BCH001326	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Ground Lights	None	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Foundation Condition	Good	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	General Comments		
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Moisture and Leak Free?	y	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Operating Linkage OK?	y	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	UG Pothead Condition Good?	y	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Ground Connections Intact?	y	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	All Identified and Legible?	y	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	ST000412	Structure	Retired Distribution	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	General Comments		
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	55.00	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0172	NonLTC	582-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BK001635	BreakerVacuum	012-Offline-Distribution	VCB Readings	Amps A Ø	100.0	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BK001635	BreakerVacuum	012-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BK001635	BreakerVacuum	012-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BK001635	BreakerVacuum	012-Offline-Distribution	VCB Readings	Amps C Ø	100.0	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BK001635	BreakerVacuum	012-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BK001635	BreakerVacuum	012-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BK001635	BreakerVacuum	012-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BK001635	BreakerVacuum	012-Offline-Distribution	VCB Readings	9 Month Operations	0	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BK001635	BreakerVacuum	012-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BK001635	BreakerVacuum	012-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BK001635	BreakerVacuum	012-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BK001635	BreakerVacuum	012-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BK001635	BreakerVacuum	012-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BK001635	BreakerVacuum	012-Offline-Distribution	VCB Readings	Amps B Ø	90.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Bushing Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	Fault Operations A Ø	0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	Fault Operations B Ø	0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	Fault Operations C Ø	0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	Fault Operations Ground	0	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Readings	Oil Temp Max	70	°C
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Readings	Oil Temp Present	40	°C
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	Follow-up Action Required?	n	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Foundation Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	General Comments		
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	General Comments		
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Grounds in Place?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	Maintenance Operations	0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	Operations Counter AF	120	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	Operations Counter AL	120	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	Operations This Read Vac	0	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	General Comments		
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Grounds in Place?	y	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Maintenance Operations	0	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Operations Counter AF	199	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Maintenance Operations	0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Grounds in Place?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	General Comments		
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Foundation Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Follow-up Action Required?	n	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Fault Operations Ground	0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Fault Operations C Ø	0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Fault Operations B Ø	0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Fault Operations A Ø	1	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Fault Adjusted Amps C Phase V	6.41	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Fault Adjusted Amps B Phase V	6.41	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Fault Adjusted Amps A Phase V	12.82	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Bushing Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Amps C Ø	90.0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Amps B Ø	110.0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Amps A Ø	100.0	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Amps A Ø	5.0	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	9 Month Operations	11	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Foundation Condition	Good	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Follow-up Action Required?	n	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Fault Operations Ground	0	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Amps B Ø	5.0	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Fault Operations C Ø	0	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Fault Operations B Ø	0	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Fault Operations A Ø	0	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	150.0	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	165.0	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	189.0	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	9 Month Operations	0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	9 Month Operations	9	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	9 Month Operations	18	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Bushing Condition	Good	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Amps C Ø	5.0	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BCH001354	Charger	662-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BCH001354	Charger	662-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BCH001354	Charger	662-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Counter Readings	Follow-up Action Required?	n	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Counter Readings	General Comments		
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BCH001354	Charger	662-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.2	amps
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BCH001354	Charger	662-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BCH001354	Charger	662-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BCH001354	Charger	662-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BCH001354	Charger	662-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Mechanism Patrol Inspection	General Comments		
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	General Comments		
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Counter Readings	LTC As Found Counter	98266	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Counter Readings	LTC As Left Counter	98268	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Counter Readings	LTC Current Tap Position	2L	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Counter Readings	LTC Max Tap Position	4R	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Counter Readings	LTC Min Tap Position	5L	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Follow-up Action Required?	n	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Fault Operations Ground	0	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Fault Operations C Ø	0	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Fault Operations B Ø	0	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Fault Operations A Ø	0	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	FE000492	Fence	413-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	245.00	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	B0281	LTCMechanism	662-1	LTC Counter Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	Oil Temp Present	40	°C
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	Oil Temp Max	60	°C
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	MegaWatt Demand Meter Min	.30	MegaWatts
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	MegaWatt Demand Meter Max	.70	MegaWatts
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	MegaVar Demand Meter Min	-.60	MegaVars
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	MegaVar Demand Meter Max	.20	MegaVars
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	General Comments		
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Amps A Ø	10.0	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Amps B Ø	10.0	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Amps C Ø	10.0	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Bushing Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	Switching Operations	0	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Patrol Inspection	Tank Paint Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0058	BreakerVacuum	662-3	VCB Readings	Unknown Operations	0	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	9 Month Operations	8	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Operations Counter AL	199	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Readings	Totalizer Meter Reading	.749	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Operations This Read Vac	0	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	General Comments		
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	LTCC000814	LTCControl	662-2	LTC Control Insp	VRR Time Delay	30	Seconds
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	LTCC000814	LTCControl	662-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	LTCC000814	LTCControl	662-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	LTCC000814	LTCControl	662-2	LTC Control Insp	LTC Output Voltage Level	123.2	VAC
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	LTCC000814	LTCControl	662-2	LTC Control Insp	LTC Operation Checked?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	LTCC000814	LTCControl	662-2	LTC Control Insp	General Comments		
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	LTCC000814	LTCControl	662-2	LTC Control Insp	Follow-up Action Required?	n	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	LTCC000814	LTCControl	662-2	LTC Control Insp	All Connections OK?	y	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	LTCC000628	LTCControl	834-1	LTC Control Insp	VRR Time Delay	30	Seconds

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Counter Readings	LTC Operations Since Last Insp	897	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	B0373	LTCMechanism	739-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	LTCC000914	LTCControl	662-3	LTC Control Insp	VRR Time Delay	30	Seconds
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	LTCC000914	LTCControl	662-3	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	LTCC000914	LTCControl	662-3	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	LTCC000914	LTCControl	662-3	LTC Control Insp	LTC Output Voltage Level	123.3	VAC
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	LTCC000914	LTCControl	662-3	LTC Control Insp	LTC Operation Checked?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	LTCC000914	LTCControl	662-3	LTC Control Insp	General Comments		
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	LTCC000914	LTCControl	662-3	LTC Control Insp	Follow-up Action Required?	n	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	LTCC000914	LTCControl	662-3	LTC Control Insp	All Connections OK?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Switching Operations	0	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Counter Readings	LTC Operations Since Last Insp	629	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Counter Readings	LTC Min Tap Position	9L	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Counter Readings	LTC Max Tap Position	5R	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Counter Readings	LTC Current Tap Position	5L	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Counter Readings	LTC As Left Counter	143353	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Counter Readings	LTC As Found Counter	143350	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Mechanism Patrol Inspection	General Comments		
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Counter Readings	General Comments		
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	B0427	LTCMechanism	834-2	LTC Counter Readings	Follow-up Action Required?	n	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	LTCC000665	LTCControl	662-1	LTC Control Insp	All Connections OK?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	LTCC000665	LTCControl	662-1	LTC Control Insp	Follow-up Action Required?	n	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	LTCC000665	LTCControl	662-1	LTC Control Insp	General Comments		
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	LTCC000665	LTCControl	662-1	LTC Control Insp	LTC Operation Checked?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	LTCC000665	LTCControl	662-1	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	LTCC000665	LTCControl	662-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	LTCC000665	LTCControl	662-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	LTCC000665	LTCControl	662-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	LTCC000610	LTCControl	834-2	LTC Control Insp	VRR Time Delay	30	Seconds
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	LTCC000610	LTCControl	834-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	LTCC000610	LTCControl	834-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	LTCC000610	LTCControl	834-2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	LTCC000610	LTCControl	834-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	LTCC000610	LTCControl	834-2	LTC Control Insp	LTC Operation Checked?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	LTCC000610	LTCControl	834-2	LTC Control Insp	General Comments		
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	LTCC000610	LTCControl	834-2	LTC Control Insp	Follow-up Action Required?	n	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	LTCC000610	LTCControl	834-2	LTC Control Insp	All Connections OK?	y	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Patrol Inspection	Tank Paint Condition	Good	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0283	BreakerVacuum	834-2115	VCB Readings	Unknown Operations	0	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	250.00	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0326	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Tank Paint Condition	Good	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Switching Operations	0	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	266	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	266	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Fault Operations A Ø	0	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Bushing Condition	Good	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Amps C Ø	160.0	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Amps B Ø	125.0	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	B0281	LTCMechanism	662-1	LTC Counter Readings	LTC Max Tap Position	1R	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	B0281	LTCMechanism	662-1	LTC Counter Readings	LTC Current Tap Position	6L	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	B0281	LTCMechanism	662-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	B0281	LTCMechanism	662-1	LTC Counter Readings	LTC As Left Counter	4783	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	B0281	LTCMechanism	662-1	LTC Counter Readings	LTC As Found Counter	4781	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	B0281	LTCMechanism	662-1	LTC Mechanism Patrol Inspection	General Comments		
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	B0281	LTCMechanism	662-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Amps A Ø	150.0	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0166	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	General Comments		
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	ST000464	Structure	404-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	General Comments		
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Readings	General Comments		
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Readings	LTC Totalizer Reading	7190.4	kw
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Unknown Operations	1	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Tank Paint Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Switching Operations	0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Operations This Read Vac	2	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Operations Counter AL	99801	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0054	BreakerVacuum	662-0109	VCB Readings	Operations Counter AF	99801	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Amps A Ø	0.0	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Amps B Ø	0.0	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Amps C Ø	0.0	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Bushing Condition	Good	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000065	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000065	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	15.00	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000065	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Fault Operations A Ø	0	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Fault Operations B Ø	0	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Fault Operations C Ø	0	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Fault Operations Ground	0	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Follow-up Action Required?	n	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Foundation Condition	Good	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	General Comments		
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	General Comments		
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Grounds in Place?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Maintenance Operations	0	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Operations Counter AF	2118	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Operations Counter AL	2118	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Operations This Read Vac	0	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Switching Operations	0	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Patrol Inspection	Tank Paint Condition	Good	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0242	BreakerVacuum	834-2116	VCB Readings	Unknown Operations	0	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000065	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000065	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000065	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	TX000065	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Operations Counter AL	201	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Operations Counter AF	201	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Maintenance Operations	0	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	B0281	LTCMechanism	662-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	B0281	LTCMechanism	662-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	B0281	LTCMechanism	662-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	B0281	LTCMechanism	662-1	LTC Counter Readings	LTC Operations Since Last Insp	624	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	B0281	LTCMechanism	662-1	LTC Counter Readings	LTC Min Tap Position	8L	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Grounds in Place?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	General Comments		
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	9 Month Operations	4	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	General Comments		
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Foundation Condition	Good	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Follow-up Action Required?	n	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Fault Operations Ground	0	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Fault Operations C Ø	0	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Fault Operations B Ø	0	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	LTCC000628	LTCControl	834-1	LTC Control Insp	General Comments		
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	LTCC000628	LTCControl	834-1	LTC Control Insp	Follow-up Action Required?	n	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	LTCC000628	LTCControl	834-1	LTC Control Insp	All Connections OK?	y	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	B0373	WithLTC	739-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	CB0289	BreakerVacuum	404-0774	VCB Readings	Unknown Operations	0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	S0029	LTCMechanism	662-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	S0029	LTCMechanism	662-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	S0029	LTCMechanism	662-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	S0029	LTCMechanism	662-3	LTC Counter Readings	LTC Operations Since Last Insp	602	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	S0029	LTCMechanism	662-3	LTC Counter Readings	LTC Min Tap Position	11L	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	S0029	LTCMechanism	662-3	LTC Counter Readings	LTC Max Tap Position	Neutral	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	S0029	LTCMechanism	662-3	LTC Counter Readings	LTC Current Tap Position	6L	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	S0029	LTCMechanism	662-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	S0029	LTCMechanism	662-3	LTC Counter Readings	LTC As Left Counter	38363	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	S0029	LTCMechanism	662-3	LTC Counter Readings	LTC As Found Counter	38361	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	S0029	LTCMechanism	662-3	LTC Mechanism Patrol Inspection	General Comments		
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	S0029	LTCMechanism	662-3	LTC Counter Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	S0029	LTCMechanism	662-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	S0029	LTCMechanism	662-3	LTC Counter Readings	Follow-up Action Required?	n	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	FE000522	Fence	920-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	FE000522	Fence	920-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	FE000522	Fence	920-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	FE000522	Fence	920-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	FE000522	Fence	920-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	FE000522	Fence	920-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	FE000522	Fence	920-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	FE000522	Fence	920-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	FE000522	Fence	920-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	FE000522	Fence	920-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	FE000522	Fence	920-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	FE000522	Fence	920-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	FE000522	Fence	920-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	FE000522	Fence	920-Fence	Fence Patrol Inspection	General Comments		
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	FE000522	Fence	920-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	YD000528	Yard	920-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	YD000528	Yard	920-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	YD000528	Yard	920-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	YD000528	Yard	920-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	YD000528	Yard	920-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	YD000528	Yard	920-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	9 Month Operations	2	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Amps A Ø	240.0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Amps B Ø	260.0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Amps C Ø	240.0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Patrol Inspection	Bushing Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Readings	Maintenance Operations	0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Readings	Operations Counter AF	188	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Readings	Operations Counter AL	188	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Readings	Operations This Read Vac	0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Readings	Switching Operations	0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Patrol Inspection	Tank Paint Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Readings	Unknown Operations	0	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	LTCC000706	LTCControl	739-2	LTC Control Insp	VRR Time Delay	30	Seconds
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	LTCC000706	LTCControl	739-2	LTC Control Insp	VRR Base Voltage AL	124	VAC
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	LTCC000706	LTCControl	739-2	LTC Control Insp	VRR Base Voltage AF	124	VAC
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	LTCC000706	LTCControl	739-2	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	LTCC000706	LTCControl	739-2	LTC Control Insp	LTC Operation Checked?	y	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	LTCC000706	LTCControl	739-2	LTC Control Insp	General Comments		
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	LTCC000706	LTCControl	739-2	LTC Control Insp	Follow-up Action Required?	n	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	LTCC000706	LTCControl	739-2	LTC Control Insp	All Connections OK?	y	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	Oil Temp Present	28	°C
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	Oil Temp Max	48	°C
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	LTC Totalizer Reading	2753.28	kw
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	General Comments		
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	General Comments		
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Counter Readings	Follow-up Action Required?	n	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Counter Readings	General Comments		
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Counter Readings	LTC As Found Counter	178780	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Counter Readings	LTC As Left Counter	178783	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Counter Readings	LTC Current Tap Position	11L	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Counter Readings	LTC Max Tap Position	13L	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Counter Readings	LTC Min Tap Position	10L	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Counter Readings	LTC Operations Since Last Insp	169	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	O0218	LTCMechanism	404-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Operations Counter AF	171	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Operations Counter AL	171	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Operations This Read Vac	0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Switching Operations	0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Patrol Inspection	Tank Paint Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Unknown Operations	0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	9 Month Operations	0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Amps A Ø	240.0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Amps B Ø	260.0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Amps C Ø	235.0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Patrol Inspection	Bushing Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Fault Operations A Ø	0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Fault Operations B Ø	0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Fault Operations C Ø	0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Fault Operations Ground	0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Follow-up Action Required?	n	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Patrol Inspection	Foundation Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Patrol Inspection	General Comments		
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	General Comments		
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Patrol Inspection	Grounds in Place?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Maintenance Operations	0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Operations Counter AF	149	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Operations Counter AL	149	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Operations This Read Vac	0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Switching Operations	0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001330	BreakerVacuum	662-2	VCB Readings	Unknown Operations	0	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	General Comments		
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Readings	LTC Totalizer Reading	883.20	kw
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	51	°F
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BAT000531	Battery	662-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Fault Operations A Ø	0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Fault Operations B Ø	0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Fault Operations C Ø	0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Fault Operations Ground	0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Follow-up Action Required?	n	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Patrol Inspection	Foundation Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Patrol Inspection	General Comments		
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	General Comments		
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Patrol Inspection	Grounds in Place?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Maintenance Operations	0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Operations Counter AF	149	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Operations Counter AL	149	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Operations This Read Vac	0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Switching Operations	0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Patrol Inspection	Tank Paint Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001328	BreakerVacuum	662-0130	VCB Readings	Unknown Operations	0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	9 Month Operations	4	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Amps A Ø	0.0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Amps B Ø	0.0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Amps C Ø	0.0	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	YD000528	Yard	920-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	YD000528	Yard	920-Yard	Yard Patrol Inspection	General Comments		
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	YD000528	Yard	920-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	YD000528	Yard	920-Yard	Yard Patrol Inspection	Vegetation	None	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	YD000528	Yard	920-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Patrol Inspection	Bushing Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Fault Operations A Ø	0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Fault Operations B Ø	0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Fault Operations C Ø	0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Fault Operations Ground	0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Follow-up Action Required?	n	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Patrol Inspection	Foundation Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Patrol Inspection	General Comments		
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	General Comments		
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Patrol Inspection	Grounds in Place?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001329	BreakerVacuum	662-0180	VCB Readings	Maintenance Operations	0	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Unknown Operations	0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Unknown Operations	0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Switching Operations	7	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Operations This Read Vac	7	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Operations Counter AL	323	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Operations Counter AF	323	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Maintenance Operations	0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	General Comments	7 operations that are unaccounted.	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Follow-up Action Required?	y	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Fault Operations C Ø	0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Fault Operations B Ø	0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Fault Operations A Ø	0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Amps C Ø	150.0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Amps B Ø	135.0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Amps A Ø	140.0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	BAT000611	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BCH000561	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BCH000561	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BCH000561	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BCH000561	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BCH000561	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BCH000561	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Ambient Temp	65	*F
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	General Comments		
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	YD000461	Yard	404-Yard	Yard Patrol Inspection	Vegetation	None	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	9 Month Operations	4	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Amps A Ø	300.0	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Amps B Ø	300.0	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Readings	Amps C Ø	285.0	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	CB0288	BreakerVacuum	404-0773	VCB Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Readings	Fault Operations A Ø	0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Readings	Fault Operations B Ø	0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Readings	Fault Operations C Ø	0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Readings	Fault Operations Ground	0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Readings	Follow-up Action Required?	n	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Patrol Inspection	Foundation Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Patrol Inspection	General Comments		
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Readings	General Comments		
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001327	BreakerVacuum	662-0016	VCB Patrol Inspection	Grounds in Place?	y	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Oil Temp Max	55	°C
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Oil Temp Present	30	°C
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	9 Month Operations	8	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Amps A Ø	5.0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Amps B Ø	5.0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Amps C Ø	5.0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Bushing Condition	Good	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	0	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Fault Adjusted Amps A Phase V	6.55	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Fault Adjusted Amps B Phase V	6.55	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Fault Adjusted Amps C Phase V	13.10	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Fault Operations A Ø	0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Fault Operations B Ø	0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Fault Operations C Ø	1	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Fault Operations Ground	0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Follow-up Action Required?	n	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Foundation Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	General Comments		
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	General Comments		
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Grounds in Place?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Maintenance Operations	0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Operations Counter AF	48	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Operations Counter AL	48	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Operations This Read Vac	2	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Switching Operations	0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Patrol Inspection	Tank Paint Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0047	BreakerVacuum	662-0085	VCB Readings	Unknown Operations	1	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	WithLTC	920-Offline-Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Readings	9 Month Operations	7	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	BK001326	BreakerVacuum	662-0011	VCB Readings	Amps A Ø	70.0	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	BCH000614	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	2.2	amps
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	BCH000614	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	BCH000614	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Unknown Operations	0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Switching Operations	8	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Operations This Read Vac	8	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Operations Counter AL	651	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Operations Counter AF	651	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Maintenance Operations	0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	General Comments	8 operations that have been accounted.	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Follow-up Action Required?	y	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Fault Operations Ground	0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Fault Operations C Ø	0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Fault Operations B Ø	0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Fault Operations A Ø	0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Amps C Ø	105.0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Amps B Ø	100.0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Amps A Ø	95.0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Readings	9 Month Operations	18	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Ambient Temp	55	*F
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	General Comments		
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Vegetation	None	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	YD000389	Yard	516-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	General Comments		
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Vegetation	None	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	BCH000613	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	BCH000613	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	BCH000613	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	BCH000613	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	46.0	amps
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	BCH000613	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	BCH000613	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0381	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BCH001431	Charger	516-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BCH001431	Charger	516-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BCH001431	Charger	516-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BCH001431	Charger	516-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BCH001431	Charger	516-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BCH001431	Charger	516-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BCH001431	Charger	516-Battery Charger	Battery Charger Patrol Insp	General Comments	**ABOVE READINGS ARE NOT ACCURATE**	PS000016 PORTABLE SUB CHARGER: .67 DCA and 53.9 VDC
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BCH001431	Charger	516-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BAT001501	Battery	516-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BAT001501	Battery	516-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	55	°F
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BAT001501	Battery	516-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BAT001501	Battery	516-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BAT001501	Battery	516-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BAT001501	Battery	516-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BAT001501	Battery	516-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BAT001501	Battery	516-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BAT001501	Battery	516-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BAT001501	Battery	516-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BAT001501	Battery	516-Battery Bank	Battery Patrol Inspection	General Comments		
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BAT001501	Battery	516-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BAT001501	Battery	516-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BAT001501	Battery	516-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	23.0	VDC
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BAT000626	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BAT001501	Battery	516-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	BCH000614	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	BCH000614	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	BCH000614	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Readings	LTC Totalizer Reading	9835.20	kw
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Readings	Oil Temp Max	55	°C
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Readings	Oil Temp Present	15	°C
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Readings	Totalizer Meter Reading	.6830	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Readings	Winding Temp Max	40	°C
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Readings	Winding Temp Present	40	°C
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Readings	Winding Temp Present	40	°C
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Readings	Winding Temp Max	60	°C
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Readings	Totalizer Meter Reading	.5310	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Readings	Oil Temp Present	35	°C
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Readings	Oil Temp Max	65	°C
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Readings	LTC Totalizer Reading	7646.40	kw
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Readings	General Comments		
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	General Comments		
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	B0417	WithLTC	662-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	ST000392	Structure	516-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	FE000872	Fence	516-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	FE000872	Fence	516-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	FE000872	Fence	516-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	FE000872	Fence	516-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	FE000872	Fence	516-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	FE000872	Fence	516-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	FE000872	Fence	516-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	FE000872	Fence	516-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	FE000872	Fence	516-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	FE000872	Fence	516-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	FE000872	Fence	516-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	FE000872	Fence	516-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	FE000872	Fence	516-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	BCH001329	Charger	404-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	BCH001329	Charger	404-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	BCH001329	Charger	404-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	BCH001329	Charger	404-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	BAT001410	Battery	404-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	BAT001410	Battery	404-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	BAT001410	Battery	404-Battery Bank	Battery Patrol Inspection	Positive DC Ground	25.0	VDC
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	BAT001410	Battery	404-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	BAT001410	Battery	404-Battery Bank	Battery Patrol Inspection	General Comments		
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	BAT001410	Battery	404-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	BAT001410	Battery	404-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	BAT001410	Battery	404-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	BAT001410	Battery	404-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	FE000872	Fence	516-Fence	Fence Patrol Inspection	General Comments		
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	FE000872	Fence	516-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	BAT001410	Battery	404-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	BAT001410	Battery	404-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	BAT001410	Battery	404-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	BAT001410	Battery	404-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	BAT001410	Battery	404-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Readings	Follow-up Action Required?	n	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Patrol Inspection	General Comments		
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	S0029	WithLTC	662-3	LTC Transformer Readings	General Comments		
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Readings	Totalizer Meter Reading	.3490	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	B0281	WithLTC	662-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Readings	Oil Temp Present	37	°C
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Readings	Oil Temp Max	58	°C
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Readings	LTC Totalizer Reading	8712.00	kw
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Readings	General Comments		
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	B0427	WithLTC	834-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Readings	Totalizer Meter Reading	.2760	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	C0351	WithLTC	834-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Follow-up Action Required?	n	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Foundation Condition	Good	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	General Comments		
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	General Comments		
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Grounds in Place?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Maintenance Operations	0	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Operations Counter AF	185	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Operations Counter AL	185	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Operations This Read Vac	0	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Switching Operations	0	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Patrol Inspection	Tank Paint Condition	Good	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	BK000532	BreakerVacuum	834-2112	VCB Readings	Unknown Operations	0	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	BCH001329	Charger	404-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	BCH001329	Charger	404-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	BCH001329	Charger	404-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	BCH001329	Charger	404-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Readings	9 Month Operations	8	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	General Comments		
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	FE000405	Fence	739-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/27/2020 15:14	Distribution	Vine Street Quarterly Inspection	YD000410	Yard	739-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Unknown Operations	0	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Tank Paint Condition	Good	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Switching Operations	0	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Operations This Read Vac	0	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Operations Counter AL	137	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Operations Counter AF	137	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Maintenance Operations	0	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Grounds in Place?	y	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	General Comments		
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	General Comments		
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Foundation Condition	Good	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Follow-up Action Required?	n	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Fault Operations Ground	0	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Fault Operations C Ø	0	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Fault Operations B Ø	0	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Fault Operations A Ø	0	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	General Comments		
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	ST000353	Structure	662-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Patrol Inspection	Bushing Condition	Good	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Amps C Ø	8.0	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Amps B Ø	7.0	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Amps A Ø	7.0	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0305	BreakerVacuum	413-0281	VCB Readings	9 Month Operations	8	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BK001630	BreakerVacuum	012-Offline-Distribution	VCB Readings	9 Month Operations	0	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BK001630	BreakerVacuum	012-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BK001630	BreakerVacuum	012-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Counter Readings	Follow-up Action Required?	n	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Counter Readings	General Comments		
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Mechanism Patrol Inspection	General Comments		
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Counter Readings	LTC As Found Counter	592914	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Counter Readings	LTC As Left Counter	592918	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Counter Readings	LTC Current Tap Position	12L	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BK001630	BreakerVacuum	012-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BK001630	BreakerVacuum	012-Offline-Distribution	VCB Readings	Amps A Ø	330.0	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BK001630	BreakerVacuum	012-Offline-Distribution	VCB Readings	Amps B Ø	325.0	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BK001630	BreakerVacuum	012-Offline-Distribution	VCB Readings	Amps C Ø	330.0	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BK001630	BreakerVacuum	012-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BK001630	BreakerVacuum	012-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	Totalizer Meter Reading	.2868	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	WithLTC	413-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	General Comments		
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	9 Month Operations	8	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Amps A Ø	100.0	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Amps B Ø	100.0	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Amps C Ø	100.0	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Bushing Condition	Good	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Fault Operations A Ø	0	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Fault Operations B Ø	0	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Fault Operations C Ø	0	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Fault Operations Ground	0	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Follow-up Action Required?	n	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Foundation Condition	Good	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	General Comments		
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	General Comments		
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Grounds in Place?	y	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Maintenance Operations	0	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Operations Counter AF	238	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Operations Counter AL	238	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Operations This Read Vac	0	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	KT0001	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	LTCC000171	LTCControl	466-9	LTC Control Insp	All Connections OK?	y	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	LTCC000171	LTCControl	466-9	LTC Control Insp	Follow-up Action Required?	n	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	LTCC000171	LTCControl	466-9	LTC Control Insp	General Comments		
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	LTCC000171	LTCControl	466-9	LTC Control Insp	LTC Operation Checked?	y	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	LTCC000171	LTCControl	466-9	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	LTCC000171	LTCControl	466-9	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	General Comments		
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	LTCC000171	LTCControl	466-9	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	LTCC000171	LTCControl	466-9	LTC Control Insp	VRR Time Delay	30	Seconds
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	FE000536	Fence	834-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Ambient Temp	65	*F
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	General Comments		
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Vegetation	None	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	YD000541	Yard	834-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C ∅	0	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B ∅	0	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A ∅	0	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Amps C ∅	320.0	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Amps B ∅	360.0	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Amps A ∅	365.0	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	FE000839	Fence	662-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	FE000839	Fence	662-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	FE000839	Fence	662-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	FE000839	Fence	662-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	FE000839	Fence	662-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	FE000839	Fence	662-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BK001630	BreakerVacuum	012-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BK001630	BreakerVacuum	012-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BK001630	BreakerVacuum	012-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BK001630	BreakerVacuum	012-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BK001630	BreakerVacuum	012-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BK001630	BreakerVacuum	012-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BK001630	BreakerVacuum	012-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BK001630	BreakerVacuum	012-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BK001630	BreakerVacuum	012-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Switching Operations	0	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Patrol Inspection	Tank Paint Condition	Good	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	BB0306	BreakerVacuum	413-0280	VCB Readings	Unknown Operations	0	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Counter Readings	LTC As Found Counter	32474	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Mechanism Patrol Inspection	General Comments		
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Counter Readings	General Comments		
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Counter Readings	Follow-up Action Required?	n	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	FE000839	Fence	662-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	FE000839	Fence	662-Fence	Fence Patrol Inspection	General Comments		
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Counter Readings	LTC Max Tap Position	3L	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Counter Readings	LTC Min Tap Position	12L	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Counter Readings	LTC Operations Since Last Insp	343	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	C0351	LTCMechanism	834-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	FE000839	Fence	662-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	FE000839	Fence	662-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	FE000839	Fence	662-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BK001630	BreakerVacuum	012-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BK001630	BreakerVacuum	012-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BK001630	BreakerVacuum	012-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BK001630	BreakerVacuum	012-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BK001630	BreakerVacuum	012-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BK001630	BreakerVacuum	012-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BK001630	BreakerVacuum	012-Offline-Distribution	VCB Patrol Inspection	General Comments		
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BK001630	BreakerVacuum	012-Offline-Distribution	VCB Readings	General Comments	In service, counter estimated	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BK001630	BreakerVacuum	012-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BK001630	BreakerVacuum	012-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	General Comments		
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	FE000839	Fence	662-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	FE000839	Fence	662-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	FE000839	Fence	662-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	FE000839	Fence	662-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	3	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	3	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0200	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	C0370	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	Oil Temp Present	53	°C
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	Oil Temp Max	63	°C
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Fault Operations A Ø	0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Fault Operations B Ø	0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Fault Operations C Ø	0	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	LTCC000216	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	LTCC000216	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	LTCC000216	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	LTCC000216	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	LTCC000216	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	LTCC000216	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	LTCC000216	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	LTCC000216	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Fault Operations Ground	0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Follow-up Action Required?	n	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Foundation Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	General Comments		
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	General Comments		
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Bushing Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Grounds in Place?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Maintenance Operations	0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Amps C Ø	150.0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Amps B Ø	200.0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Amps A Ø	180.0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Operations Counter AF	327	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Operations Counter AL	327	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Operations This Read Vac	0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Switching Operations	0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Tank Paint Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Unknown Operations	0	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	LTC Totalizer Reading	7132.80	kw
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	General Comments		
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	General Comments		
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	YD000350	Yard	662-Yard	Yard Patrol Inspection	Vegetation	None	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Readings	Amps A Ø	0.0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Readings	Amps B Ø	0.0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Readings	Amps C Ø	0.0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Bushing Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BK001630	BreakerVacuum	012-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BK001630	BreakerVacuum	012-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BK001630	BreakerVacuum	012-Offline-Distribution	VCB Readings	Switching Operations	0	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BK001630	BreakerVacuum	012-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BK001630	BreakerVacuum	012-Offline-Distribution	VCB Readings	Unknown Operations	0	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Readings	9 Month Operations	8	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	Totalizer Meter Reading	.7430	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Ambient Temp	65	*F
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	YD000350	Yard	662-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	General Comments		
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BK001630	BreakerVacuum	012-Offline-Distribution	VCB Readings	Operations Counter AL	111	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BK001630	BreakerVacuum	012-Offline-Distribution	VCB Readings	Operations Counter AF	111	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BK001630	BreakerVacuum	012-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/27/2020 14:26	Distribution	West High Street Quarterly Inspection	BK001630	BreakerVacuum	012-Offline-Distribution	VCB Readings	Maintenance Operations	0	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Vegetation	None	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	YD000498	Yard	413-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	ST000501	Structure	413-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0052	BreakerVacuum	662-0039	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Readings	Maintenance Operations	0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Readings	Operations Counter AF	241	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Readings	Operations Counter AL	241	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Readings	Operations This Read Vac	0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Readings	Switching Operations	0	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	0	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Min Tap Position	12L	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Max Tap Position	2L	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	3L	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	4805	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	4805	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	General Comments		
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 14:59	Distribution	Danville Substation Department Quarterly Transformer Pad Inspection	B0277	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	YD000350	Yard	662-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	YD000350	Yard	662-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	YD000350	Yard	662-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	YD000350	Yard	662-Yard	Yard Patrol Inspection	General Comments		
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	YD000350	Yard	662-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	YD000350	Yard	662-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	YD000350	Yard	662-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	YD000350	Yard	662-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	YD000350	Yard	662-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	YD000350	Yard	662-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	YD000350	Yard	662-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	YD000350	Yard	662-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	YD000350	Yard	662-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	YD000350	Yard	662-Yard	Yard Patrol Inspection	Ambient Temp	51	*F
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Operations This Read Vac	0	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Switching Operations	0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Tank Paint Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Readings	Unknown Operations	0	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Counter Readings	LTC Operations Since Last Insp	123	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Counter Readings	LTC Min Tap Position	5L	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Counter Readings	LTC Max Tap Position	2L	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Counter Readings	LTC Current Tap Position	5L	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/27/2020 14:02	Distribution	Vaksdahl Avenue Quarterly Inspection	S0030	LTCMechanism	413-1	LTC Counter Readings	LTC As Left Counter	32477	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Patrol Inspection	Tank Paint Condition	Good	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	CB0165	BreakerVacuum	834-2113	VCB Readings	Unknown Operations	0	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	FE000455	Fence	404-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/27/2020 14:39	Distribution	Danville East Quarterly Inspection	ST000545	Structure	834-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Grounds in Place?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Readings	General Comments		
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	General Comments		
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Readings	Fault Operations A Ø	0	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/27/2020 17:44	Distribution	Harrodsburg North Quarterly Inspection	O0218	WithLTC	404-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Readings	Fault Operations B Ø	0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Readings	Fault Operations C Ø	0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Readings	Fault Operations Ground	0	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Follow-up Action Required?	n	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Readings	Follow-up Action Required?	n	
10/27/2020 10:32	Distribution	Lexington Water Company Quarterly Inspection	K0053	BreakerVacuum	662-0179	VCB Patrol Inspection	Foundation Condition	Good	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	LTCC000794	LTCControl	747-1	LTC Control Insp	All Connections OK?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	LTCC000794	LTCControl	747-1	LTC Control Insp	Follow-up Action Required?	n	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	LTCC000794	LTCControl	747-1	LTC Control Insp	General Comments		
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	LTCC000794	LTCControl	747-1	LTC Control Insp	LTC Operation Checked?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	LTCC000794	LTCControl	747-1	LTC Control Insp	LTC Output Voltage Level	123.3	VAC
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	LTCC000794	LTCControl	747-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	LTCC000794	LTCControl	747-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	LTCC000794	LTCControl	747-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Fault Operations Ground	0	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Fault Operations C Ø	0	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Bushing Condition	Good	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Amps C Ø	290.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Amps B Ø	300.0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Operations Counter AL	176	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Amps A Ø	270.0	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	BK000974	BreakerVacuum	621-2	VCB Readings	9 Month Operations	0	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Unknown Operations	0	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Switching Operations	0	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Operations This Read Vac	0	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Operations Counter AF	176	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Maintenance Operations	0	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	General Comments		
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	General Comments		
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Readings	Follow-up Action Required?	n	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	BK000973	BreakerVacuum	621-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	General Comments		
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	ST000351	Structure	621-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Readings	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1	psi
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Readings	Oil Temp Max	50	°C
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	92.0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	94.0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	93.0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	10.63	%
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	11.96	%
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	9.3	%
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	3	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	X3 Winding Temp Present	32	°C
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Readings	Winding Temp Max	56	°C
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Readings	Winding Temp Present	30	°C
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	Follow-up Action Required?	n	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	General Comments		
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	General Comments		
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	LTC As Found Counter	7433	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	LTC As Left Counter	7435	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	LTC Current Tap Position	6L	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	LTC Max Tap Position	1R	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	LTC Min Tap Position	9L	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	45	°C
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	19	°C
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	LTC Operations Since Last Insp	761	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	LTCM000088	LTCMechanism	509-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BCH001203	Charger	BR-Battery Charger 48V	Battery Charger Patrol Insp	A.C. Ripple on Batteries	4.100	millivolts
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BCH001203	Charger	BR-Battery Charger 48V	Battery Charger Patrol Insp	As Found Float Voltage	54.1	VDC
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BCH001203	Charger	BR-Battery Charger 48V	Battery Charger Patrol Insp	As Left Float Voltage	54.1	VDC
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BCH001203	Charger	BR-Battery Charger 48V	Battery Charger Patrol Insp	Battery Charger Current	9.3	amps
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BCH001203	Charger	BR-Battery Charger 48V	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BCH001203	Charger	BR-Battery Charger 48V	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BCH001203	Charger	BR-Battery Charger 48V	Battery Charger Patrol Insp	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	476	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	476	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	X3 Winding Temp Max	69	°C
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	X2 Winding Temp Present	32	°C
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	X2 Winding Temp Max	69	°C
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	X1 Winding Temp Present	32	°C
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	X1 Winding Temp Max	69	°C
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	40.00	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	Oil Temp Present	31	°C
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	Oil Temp Max	60	°C
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	400	psi
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0096	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	General Comments		
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Readings	General Comments		
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Readings	LTC Totalizer Reading	8280.00	kw
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1600	psi
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Readings	Oil Temp Max	52	°C
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Readings	Oil Temp Present	30	°C
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	TX000217	WithLTC	509-2	LTC Transformer Readings	Totalizer Meter Reading	.3450	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	Totalizer Meter Reading	.3500	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	X3 Winding Temp Present	61	°C
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	X3 Winding Temp Max	76	°C
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	X2 Winding Temp Present	61	°C
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	X2 Winding Temp Max	76	°C
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	X1 Winding Temp Present	61	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	X1 Winding Temp Max	76	°C
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	Winding Temp Max	50	°C
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	Winding Temp Present	22	°C
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	LTCC000796	LTCControl	621-2	LTC Control Insp	All Connections OK?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	LTCC000796	LTCControl	621-2	LTC Control Insp	Follow-up Action Required?	n	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	LTCC000796	LTCControl	621-2	LTC Control Insp	General Comments		
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	LTCC000796	LTCControl	621-2	LTC Control Insp	LTC Operation Checked?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	LTCC000796	LTCControl	621-2	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	LTCC000796	LTCControl	621-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	LTCC000796	LTCControl	621-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	LTCC000796	LTCControl	621-2	LTC Control Insp	VRR Time Delay	30	Seconds
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Counter Readings	Follow-up Action Required?	n	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Counter Readings	General Comments		
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	General Comments		
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Counter Readings	LTC As Found Counter	7368	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Counter Readings	LTC As Left Counter	7370	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Counter Readings	LTC Current Tap Position	10L	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Counter Readings	LTC Max Tap Position	4L	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Counter Readings	LTC Min Tap Position	12L	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	45	°C
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	18	°C
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Counter Readings	LTC Operations Since Last Insp	814	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	LTCM000089	LTCMechanism	621-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Bushing Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Foundation Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Grounds in Place?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Radiator Leaks	None	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Tank Leaks	None	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0244	GroundTransformer	BR-GND TR 1C	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1262	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1262	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0090	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0092	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	LTCC000780	LTCControl	875-1	LTC Control Insp	All Connections OK?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BAT001510	Battery	BR-Battery Bank 48V	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BAT001510	Battery	BR-Battery Bank 48V	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BAT001510	Battery	BR-Battery Bank 48V	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BAT001510	Battery	BR-Battery Bank 48V	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BAT001510	Battery	BR-Battery Bank 48V	Battery Patrol Inspection	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BAT001510	Battery	BR-Battery Bank 48V	Battery Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BAT001510	Battery	BR-Battery Bank 48V	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BAT001510	Battery	BR-Battery Bank 48V	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BAT001510	Battery	BR-Battery Bank 48V	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BAT001510	Battery	BR-Battery Bank 48V	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BAT001510	Battery	BR-Battery Bank 48V	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BAT001510	Battery	BR-Battery Bank 48V	Battery Patrol Inspection	Battery Overall Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BAT001510	Battery	BR-Battery Bank 48V	Battery Patrol Inspection	Battery Area Ambient Temp	75	*F
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BAT001510	Battery	BR-Battery Bank 48V	Battery Patrol Inspection	All Connections OK?	y	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	LTCC000780	LTCControl	875-1	LTC Control Insp	Follow-up Action Required?	n	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	LTCC000780	LTCControl	875-1	LTC Control Insp	General Comments		
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	LTCC000780	LTCControl	875-1	LTC Control Insp	LTC Operation Checked?	y	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	LTCC000780	LTCControl	875-1	LTC Control Insp	LTC Output Voltage Level	124.9	VAC
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	LTCC000780	LTCControl	875-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	LTCC000780	LTCControl	875-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	LTCC000780	LTCControl	875-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Bushing Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Foundation Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Grounds in Place?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Radiator Leaks	None	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Tank Leaks	None	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0242	GroundTransformer	BR-GND TR 1A	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Bushing Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Follow-up Action Required?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Foundation Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	General Comments	oil level guage shows low oil pic sent to Stinson	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Grounds in Place?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Tank Leaks	None	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	General Comments		
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Tank Oil Level	Low	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0245	GroundTransformer	BR-GND TR 2	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	LTC Totalizer Reading	8400.00	kw
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1200	psi
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	Oil Temp Max	49	°C
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Readings	Oil Temp Present	22	°C
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	TX000218	WithLTC	621-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	9.3	%
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	109.0	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Amps A Ø	230.0	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Amps B Ø	240.0	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Amps C Ø	280.0	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Bushing Condition	Good	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	5	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	19.93	%
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	25.25	%
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Ambient Temperature	55	°F
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Readings	Unknown Operations	0	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Tank Paint Condition	Good	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Readings	Switching Operations	0	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	SF6 Pressure Pole 3	60	psi
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	SF6 Pressure Pole 2	60	psi
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	857	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	857	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	1	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0088	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	1	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	SF6 Pressure Pole 1	60	psi
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	SF6 Bushing Condition	Good	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Readings	Operations This Read SF6	0	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Readings	Operations Counter AL	79	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Readings	Operations Counter AF	79	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Readings	Num Operations Last 9 Months	0	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Moisture and Leak Free?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Readings	Maintenance Operations	0	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Heaters (All) Functioning?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Grounds in Place?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	General Comments	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Readings	General Comments		
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Gauge(s) Condition	Good	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Foundation Condition	Good	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Readings	Follow-up Action Required?	n	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Readings	Fault Operations	0	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Equipment Properly Labeled?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Cabinet Paint Condition	Good	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Bushings Connection/Risers	Good	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000962	BreakerSF6	509-608	GCB Patrol Inspection	Ambient Temperature	55	°F
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Unknown Operations	0	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Tank Paint Condition	Good	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Switching Operations	0	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Operations This Read Vac	0	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Operations Counter AL	185	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Readings	Operations Counter AF	185	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000960	BreakerVacuum	509-0096	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	97.0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	105.0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	96.0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	27.91	%
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	43.68	%
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	33.97	%
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0086	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	14	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Readings	Operations Counter AF	111	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Readings	Num Operations Last 9 Months	0	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Operations Counter AF	158	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Operations Counter AL	158	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Operations This Read Vac	0	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Switching Operations	0	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000967	BreakerVacuum	509-2	VCB Readings	Unknown Operations	0	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000968	BreakerVacuum	509-BT2-1	VCB Readings	9 Month Operations	2	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Readings	Maintenance Operations	0	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Heaters (All) Functioning?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Grounds in Place?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	General Comments	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Readings	General Comments		
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Foundation Condition	Good	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0087	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Follow-up Action Required?	n	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Foundation Condition	Good	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	General Comments		
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	General Comments		
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Grounds in Place?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Maintenance Operations	0	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Operations Counter AF	141	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Operations Counter AL	141	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Operations This Read Vac	0	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Switching Operations	0	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Patrol Inspection	Tank Paint Condition	Good	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	BK001042	BreakerVacuum	621-1	VCB Readings	Unknown Operations	0	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	BK001040	BreakerVacuum	621-0159	VCB Readings	9 Month Operations	2	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Readings	Operations Counter AL	111	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Readings	Operations This Read SF6	0	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	SF6 Pressure Pole 1	62	psi
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	SF6 Pressure Pole 2	62	psi
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	SF6 Pressure Pole 3	62	psi
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Readings	Switching Operations	0	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Patrol Inspection	Tank Paint Condition	Good	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000964	BreakerSF6	509-618	GCB Readings	Unknown Operations	0	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	9 Month Operations	2	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Amps A Ø	100.0	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Amps B Ø	100.0	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Amps C Ø	120.0	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Bushing Condition	Good	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Fault Operations A Ø	0	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Fault Operations B Ø	0	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000965	BreakerVacuum	509-0199	VCB Readings	Fault Operations C Ø	0	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Follow-up Action Required?	n	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Fault Operations Ground	0	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Fault Operations C Ø	0	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Fault Operations B Ø	0	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Fault Operations A Ø	0	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Patrol Inspection	Bushing Condition	Good	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Amps C Ø	240.0	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Amps B Ø	225.0	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Amps A Ø	245.0	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000956	BreakerVacuum	509-0097	VCB Readings	9 Month Operations	4	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	BK000970	BreakerVacuum	621-0189	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Fault Adjusted Amps B Phase V	12.90	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Patrol Inspection	Bushing Condition	Good	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Amps C Ø	85.0	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Amps B Ø	75.0	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Amps A Ø	65.0	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000959	BreakerVacuum	509-0198	VCB Readings	9 Month Operations	5	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Unknown Operations	0	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	Tank Paint Condition	Good	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Switching Operations	0	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Operations This Read Vac	0	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Readings	Follow-up Action Required?	n	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	Foundation Condition	Good	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	BK000969	BreakerVacuum	621-0116	VCB Patrol Inspection	General Comments		
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Operations Counter AL	179	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Operations Counter AF	179	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Maintenance Operations	0	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	Grounds in Place?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	General Comments		
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	General Comments		
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	Foundation Condition	Good	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Follow-up Action Required?	n	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BK000958	BreakerVacuum	509-0098	VCB Readings	Fault Operations Ground	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	3	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	34.65	%
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LTCC000838	LTCControl	BR-TRANS 1	LTC Control Insp	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LTCC000838	LTCControl	BR-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	34.65	%
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	34.65	%
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	804	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	804	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0097	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LTCC000839	LTCControl	BR-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LTCC000839	LTCControl	BR-TRANS 2	LTC Control Insp	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LTCC000839	LTCControl	BR-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Panels Dusted?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Evidence of Insects	None	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LTCC000529	LTCControl	BR-TRANS 5	LTC Control Insp	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LTCC000529	LTCControl	BR-TRANS 5	LTC Control Insp	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LTCC000529	LTCControl	BR-TRANS 5	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	417	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	417	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BCH001263	Charger	509-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.9	amps
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BCH001263	Charger	509-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BCH001263	Charger	509-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BCH001263	Charger	509-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BCH001263	Charger	509-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	General Comments		
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BAT001322	Battery	509-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LTCC000838	LTCControl	BR-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	General Comments		
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	General Comments		
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	LTC Totalizer Reading	10368.00	kw
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	Oil Temp Max	60	°C
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	Oil Temp Present	35	°C
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	Totalizer Meter Reading	.4320	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	Winding Temp Max	60	°C
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	Winding Temp Present	40	°C
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Counter Readings	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Mechanism Patrol Inspection	General Comments	Desiccant needs to be changed	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Counter Readings	LTC As Found Counter	62123	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Counter Readings	LTC As Left Counter	62123	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Counter Readings	LTC Current Tap Position	3L	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	2581	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0021	LTCMechanism	BR-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	LTC As Found Counter	180560	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	LTC As Left Counter	180560	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	LTC Current Tap Position	10L	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	LTC Max Tap Position	Neutral	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	LTC Min Tap Position	14L	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	LTC Operations Since Last Insp	1481	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0025	LTCMechanism	BR-TRANS 4	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	2645	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Counter Readings	LTC Min Tap Position	2L	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Counter Readings	LTC Max Tap Position	5L	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Counter Readings	LTC Current Tap Position	3L	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Counter Readings	LTC As Left Counter	100455	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Counter Readings	LTC As Found Counter	100455	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	SWG000106	Switchgear	BR-Swgr Sec 5	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Counter Readings	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	600.0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	620.0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	600.0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	468	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	468	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	General Comments		
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	53	*F
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BAT000512	Battery	875-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	232.0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	237.0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	211.0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0101	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	AMCB Patrol Inspection	Ventilation Free of Debris?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Unknown Operations	0	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	General Comments		
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	FE000850	Fence	509-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	General Comments		
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	FE000851	Fence	621-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0102	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	541	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	LTC Min Tap Position	4L	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	LTC Max Tap Position	10R	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	LTC Current Tap Position	7L	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	LTC As Left Counter	333710	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	LTC As Found Counter	333710	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	General Comments		
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	PN16	LTCMechanism	BK-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Counter Readings	LTC Operations Since Last Insp	1798	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Counter Readings	LTC Min Tap Position	12L	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Counter Readings	LTC Max Tap Position	1R	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Counter Readings	LTC Current Tap Position	7L	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Counter Readings	LTC As Left Counter	177952	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Counter Readings	LTC As Found Counter	177952	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Mechanism Patrol Inspection	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Counter Readings	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0024	LTCMechanism	BR-TRANS 5	LTC Counter Readings	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	1363	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Counter Readings	LTC Min Tap Position	15L	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Counter Readings	LTC Max Tap Position	1L	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Counter Readings	LTC Current Tap Position	10L	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Counter Readings	LTC As Left Counter	168591	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Counter Readings	LTC As Found Counter	168591	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Counter Readings	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0023	LTCMechanism	BR-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0022	LTCMechanism	BR-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	359	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	359	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	9 Month Operations	2	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Accumulated Fault Duty A Ph V	6.56	%
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Accumulated Fault Duty B Ph V	5.96	%
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Accumulated Fault Duty C Ph V	4.17	%
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Amps A Ø	179.0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Amps B Ø	168.0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Amps C Ø	176.0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Bushing Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Fault Operations A Ø	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Fault Operations B Ø	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Fault Operations C Ø	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Fault Operations Ground	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Foundation Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Grounds in Place?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Maintenance Operations	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Operations Counter AF	174	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Operations Counter AL	174	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Operations This Read Vac	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Switching Operations	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000436	BreakerVacuum	BR-1351	VCB Readings	Unknown Operations	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	9 Month Operations	3	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Accumulated Fault Duty A Ph V	23.85	%
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Accumulated Fault Duty B Ph V	44.72	%
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Accumulated Fault Duty C Ph V	15.5	%
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Amps A Ø	177.0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Amps B Ø	175.0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Amps C Ø	178.0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Bushing Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Fault Operations A Ø	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Fault Operations B Ø	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Fault Operations C Ø	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Fault Operations Ground	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Oil Status	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Readings	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	779	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	779	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0108	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	General Comments		
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	FE000641	Fence	BK-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	6	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	7.97	%
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	18.6	%
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	9.3	%
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	81.0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	76.0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	70.0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0094	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Vegetation	None	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	General Comments		
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	YD000353	Yard	875-Yard	Yard Patrol Inspection	Ambient Temp	53	*F
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	1	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	551	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	551	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	11.18	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	124.0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	100.0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	112.0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	41.2	%
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	46.51	%
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	47.84	%
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	10	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	LTC Operations Since Last Insp	869	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	LTC Min Tap Position	5L	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	LTC Max Tap Position	6R	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	LTC Current Tap Position	1L	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	LTC As Left Counter	63696	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	LTC As Found Counter	63694	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Mechanism Patrol Inspection	General Comments		
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	General Comments		
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	C0454	LTCMechanism	875-1	LTC Counter Readings	Follow-up Action Required?	n	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	B0383	WithLTC	621-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LTCC000496	LTCControl	BR-TRANS 4	LTC Control Insp	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LTCC000496	LTCControl	BR-TRANS 4	LTC Control Insp	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LTCC000496	LTCControl	BR-TRANS 4	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BCH001263	Charger	509-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BCH001263	Charger	509-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.9	VDC
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	BCH001263	Charger	509-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.9	VDC
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Foundation Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Grounds in Place?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Maintenance Operations	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Operations Counter AF	228	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Operations Counter AL	228	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Operations This Read Vac	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Switching Operations	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000437	BreakerVacuum	BR-1352	VCB Readings	Unknown Operations	0	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	General Comments		
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	Oil Temp Max	50	°C
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	40	°C
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	PN16	WithLTC	BK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	30	°C
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	General Comments		
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	1	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0095	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	ST000357	Structure	875-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Retired Distribution	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0099	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Patrol Inspection	General Comments		
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	General Comments		
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Patrol Inspection	Grounds in Place?	y	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Maintenance Operations	0	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Operations Counter AF	193	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	PF000048	PowerFuse	BR-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	PF000048	PowerFuse	BR-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	PF000047	PowerFuse	BR-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	PF000047	PowerFuse	BR-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	ok	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Counter Readings	LTC Operations Since Last Insp	1591	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	-.5	psi
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Counter Readings	LTC Min Tap Position	10L	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Counter Readings	LTC Current Tap Position	8L	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	PF000051	PowerFuse	BR-STA SER NO 5	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	PF000051	PowerFuse	BR-STA SER NO 5	Disconnect Powerfuse Inspection	General Comments	ok	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Counter Readings	LTC As Left Counter	1993	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Counter Readings	LTC As Found Counter	1993	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Mechanism Patrol Inspection	General Comments		
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Counter Readings	General Comments		
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	B0383	LTCMechanism	621-1	LTC Counter Readings	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LTCC000475	LTCControl	BR-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LTCC000475	LTCControl	BR-TRANS 3	LTC Control Insp	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LTCC000475	LTCControl	BR-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	PF000042	PowerFuse	BR-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	PF000042	PowerFuse	BR-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	BCH000115	Charger	BK-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	BCH000115	Charger	BK-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.7	VDC
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	BCH000115	Charger	BK-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.7	VDC
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	BCH000115	Charger	BK-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	BCH000115	Charger	BK-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	BCH000115	Charger	BK-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	BCH000115	Charger	BK-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	General Comments		
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	CH000476	ControlHouse	BK-Battery Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BCH000548	Charger	875-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BCH000548	Charger	875-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BCH000548	Charger	875-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BCH000548	Charger	875-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.6	amps
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BCH000548	Charger	875-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BCH000548	Charger	875-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Fault Operations A Ø	0	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Fault Operations B Ø	0	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Fault Operations C Ø	0	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Fault Operations Ground	0	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Follow-up Action Required?	n	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	Foundation Condition	Good	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	General Comments		
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	Grounds in Place?	y	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Maintenance Operations	0	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Operations Counter AF	179	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Operations Counter AL	179	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Operations This Read Vac	0	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Switching Operations	0	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Patrol Inspection	Tank Paint Condition	Good	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BK001260	BreakerVacuum	875-0084	VCB Readings	Unknown Operations	0	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	647	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	647	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	LTC Operations Since Last Insp	1325	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	LTC Min Tap Position	12L	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	LTC Max Tap Position	1L	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	LTC Current Tap Position	10L	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	LTC As Left Counter	206676	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	LTC As Found Counter	206674	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Mechanism Patrol Inspection	General Comments		
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	General Comments		
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	B0368	LTCMechanism	509-1	LTC Counter Readings	Follow-up Action Required?	n	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	General Comments		
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0100	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	480.0	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Vegetation	None	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	YD000393	Yard	509-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	ST000396	Structure	509-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	9 Months Operations	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1235	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1235	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	SWG000026	Switchgear	BR-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Readings	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0109	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	903	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	903	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	143.0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	128.0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	141.0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	17.28	%
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	45.18	%
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	39.87	%
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0089	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Amps C Ø	50.0	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Amps B Ø	75.0	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0115	BreakerAirMagnetic	BK-3	AMCB Readings	Amps A Ø	110.0	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	Totalizer Meter Reading	1.0446	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Bushing Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Patrol Inspection	Tank Paint Condition	Good	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	Unknown Operations	0	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	9 Month Operations	8	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Amps A Ø	165.0	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Amps B Ø	175.0	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Amps C Ø	175.0	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Patrol Inspection	Bushing Condition	Good	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BK001258	BreakerVacuum	875-0066	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	PF000038	PowerFuse	BR-14KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	PF000038	PowerFuse	BR-14KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	PF000039	PowerFuse	BR-GND TR 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	PF000039	PowerFuse	BR-GND TR 1	Disconnect Powerfuse Inspection	General Comments	ok	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Foundation Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Grounds in Place?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0243	GroundTransformer	BR-GND TR 1B	Ground Transformer Patrol Inspection	Radiator Leaks	None	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Unknown Operations	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000714	BreakerVacuum	BR-14KV TR 2	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	Fault Operations B Ø	0	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	Fault Operations C Ø	0	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	Fault Operations Ground	0	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	Follow-up Action Required?	n	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Patrol Inspection	Foundation Condition	Good	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Patrol Inspection	General Comments		
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	General Comments		
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Patrol Inspection	Grounds in Place?	y	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	Maintenance Operations	0	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	Operations Counter AF	222	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	Operations Counter AL	222	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	Operations This Read Vac	0	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	BK001257	BreakerVacuum	875-0065	VCB Readings	Switching Operations	0	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	Oil Temp Max	65	°C
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Readings	Oil Temp Present	45	°C
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	C0454	WithLTC	875-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Operations Counter AL	421	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	SWG000017	Switchgear	BK-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Vegetation	None	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Operations Counter AF	421	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Maintenance Operations	0	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	General Comments		
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Patrol Inspection	General Comments		
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Follow-up Action Required?	n	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Fault Operations Ground	0	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Ambient Temp	53	°F
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Fault Operations C Ø	0	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Fault Operations B Ø	0	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Fault Operations A Ø	0	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Amps C Ø	50.0	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Amps B Ø	75.0	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Amps A Ø	25.0	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	9 Months Operations	2	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	Oil Temp Max	65	°C
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	Oil Temp Present	55	°C
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	75	°C
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Panels Dusted?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	55	°C
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	75	°C
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	55	°C
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	75	°C
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	55	°C
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	ANN000006	Annunciator	BR-Annunciator Panel 1	Annunciator Patrol Inspection	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	ANN000006	Annunciator	BR-Annunciator Panel 1	Annunciator Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	ANN000006	Annunciator	BR-Annunciator Panel 1	Annunciator Patrol Inspection	ESOC Received Alarm Test?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	ANN000006	Annunciator	BR-Annunciator Panel 1	Annunciator Patrol Inspection	Control House Alarm Audible?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	ANN000006	Annunciator	BR-Annunciator Panel 1	Annunciator Patrol Inspection	All Lights Functioning?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Unknown Operations	0	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Switching Operations	0	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0113	BreakerAirMagnetic	BK-1	AMCB Readings	Operations This Read AM	0	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	LTCC000690	LTCControl	621-1	LTC Control Insp	LTC Output Voltage Level	123.8	VAC
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	LTCC000690	LTCControl	621-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	LTCC000690	LTCControl	621-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	LTCC000690	LTCControl	621-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Unknown Operations	0	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Switching Operations	0	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Operations This Read AM	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Operations Counter AL	676	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Operations Counter AF	676	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Maintenance Operations	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Evidence of Insects	None	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	SWG000105	Switchgear	BR-Swgr Sec 4	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	BAT001439	Battery	BK-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	BAT001439	Battery	BK-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	BAT001439	Battery	BK-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	BAT001439	Battery	BK-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	BAT001439	Battery	BK-Battery Bank	Battery Patrol Inspection	General Comments		
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	General Comments		
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Patrol Inspection	General Comments		
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Follow-up Action Required?	n	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Fault Operations Ground	0	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Fault Operations C Ø	0	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Fault Operations B Ø	0	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Fault Operations A Ø	0	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Amps C Ø	160.0	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Amps B Ø	50.0	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Amps A Ø	100.0	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	LB0114	BreakerAirMagnetic	BK-2	AMCB Readings	9 Months Operations	0	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	General Comments		
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	YD000348	Yard	621-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	General Comments		
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	General Comments		
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	General Comments		
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	LTC Totalizer Reading	10032.00	kw
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	Oil Temp Max	65	°C
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	Oil Temp Present	35	°C
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	Totalizer Meter Reading	.4180	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	Winding Temp Max	62	°C
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	Winding Temp Present	32	°C
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
10/26/2020 14:54	Distribution	Stonewall Quarterly Inspection	B0368	WithLTC	509-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/26/2020 15:33	Distribution	Procter and Gamble Quarterly Inspection	FE000349	Fence	875-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	LTCC000690	LTCCControl	621-1	LTC Control Insp	All Connections OK?	y	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	LTCC000690	LTCCControl	621-1	LTC Control Insp	Follow-up Action Required?	n	
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	LTCC000690	LTCCControl	621-1	LTC Control Insp	General Comments		
10/26/2020 12:27	Distribution	Viley Road Quarterly Inspection	LTCC000690	LTCCControl	621-1	LTC Control Insp	LTC Operation Checked?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Grounds in Place?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Maintenance Operations	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Operations Counter AF	214	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Operations Counter AL	214	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	BAT001439	Battery	BK-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	BAT001439	Battery	BK-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	74	°F
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	BAT001439	Battery	BK-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	BAT001439	Battery	BK-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Operations This Read Vac	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Foundation Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Switching Operations	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Unknown Operations	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Fault Operations Ground	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Fault Operations C Ø	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Fault Operations B Ø	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Fault Operations A Ø	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Fault Adjusted Amps C Phase V	16.00	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Fault Adjusted Amps B Phase V	16.00	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Fault Adjusted Amps A Phase V	16.00	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Bushing Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Amps C Ø	115.0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Amps B Ø	113.0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Amps A Ø	118.0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Accumulated Fault Duty C Ph V	5.96	%
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Accumulated Fault Duty B Ph V	7.75	%
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Accumulated Fault Duty A Ph V	7.16	%
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	9 Month Operations	6	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	860	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	860	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Grounds in Place?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Tank Oil Level	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Tank Leaks	None	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Maintenance Operations	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Operations Counter AF	216	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Operations Counter AL	216	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Operations This Read Vac	2	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Switching Operations	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Readings	Unknown Operations	2	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	9 Month Operations	2	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Accumulated Fault Duty A Ph V	8.94	%
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Accumulated Fault Duty B Ph V	14.31	%
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Accumulated Fault Duty C Ph V	9.54	%
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Amps A Ø	40.0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Amps B Ø	39.0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Amps C Ø	38.0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Bushing Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Fault Operations A Ø	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Fault Operations B Ø	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Fault Operations C Ø	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Fault Operations Ground	0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Readings	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	Foundation Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000554	BreakerVacuum	BR-1356	VCB Patrol Inspection	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	BK000555	BreakerVacuum	BR-1354	VCB Patrol Inspection	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	6.64	%
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	11.96	%
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	3.99	%
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	3	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	85.00	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Bushing Condition	Good	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Vegetation	None	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	YD000645	Yard	BK-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Readings	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0023	WithLTC	BR-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Grounds in Place?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0112	BreakerOil	BR-GND TR 2	OCB Patrol Inspection	Foundation Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Readings	Oil Temp Present	50	°C
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Readings	Oil Temp Max	55	°C
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	154.0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	151.0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	161.0	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	BAT001439	Battery	BK-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	BAT001439	Battery	BK-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	BAT001439	Battery	BK-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	BAT001439	Battery	BK-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/26/2020 13:46	Distribution	Brook Quarterly Inspection	BAT001439	Battery	BK-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Readings	General Comments		
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LT0021	WithLTC	BR-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/28/2020 6:49	Distribution	Breckenridge Quarterly Inspection	LB0085	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	LTCC000349	LTCControl	930-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	LTCC000349	LTCControl	930-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	LTCC000349	LTCControl	930-Offline-Distribution	LTC Control Insp	General Comments		
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	LTCC000349	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	LTCC000349	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	LTCC000349	LTCControl	930-Offline-Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	LTCC000349	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	LTCC000349	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	LTCC000349	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Follow-up Action Required?	n	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Fault Operations Ground	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Fault Operations C Ø	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Fault Operations B Ø	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Fault Operations A Ø	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Operations Counter AF	145	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Operations Counter AL	145	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Patrol Inspection	General Comments		
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	General Comments		
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Clear of Trash?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Maintenance Operations	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Operations This Read Vac	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Switching Operations	0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0432	BreakerVacuum	HN-1200	VCB Patrol Inspection	General Comments		
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	General Comments		
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	General Comments		
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.8	psi
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1100	psi
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	BCH001432	Charger	846-Battery Charger Distribution	Battery Charger Patrol Insp	Ground Lights	None	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	BCH001432	Charger	846-Battery Charger Distribution	Battery Charger Patrol Insp	General Comments		
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	BCH001432	Charger	846-Battery Charger Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	BCH001432	Charger	846-Battery Charger Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	BCH001432	Charger	846-Battery Charger Distribution	Battery Charger Patrol Insp	Battery Charger Current	3.5	amps
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	n	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	General Comments		
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	General Comments	Trans needs nitro	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	Oil Temp Max	60	°C
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	Oil Temp Present	50	°C
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	BCH001432	Charger	846-Battery Charger Distribution	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	BCH001432	Charger	846-Battery Charger Distribution	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	BCH001432	Charger	846-Battery Charger Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	X2 Winding Temp Present	45	°C
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	X2 Winding Temp Max	60	°C
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	X1 Winding Temp Present	45	°C
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	X1 Winding Temp Max	60	°C
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Amps C Ø	48.0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Amps B Ø	50.0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Amps A Ø	44.0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	9 Month Operations	37	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	X3 Winding Temp Present	45	°C
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	X3 Winding Temp Max	60	°C
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	100.0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	100.0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	100.0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Ambient Temp	79	°F
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Counter Readings	LTC Operations Since Last Insp	553	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	LTC Min Tap Position	14L	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4L	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	LTC Current Tap Position	11L	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	LTC As Left Counter	58454	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	4	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	60	°C
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	30	°C
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	60	°C
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	LTC As Found Counter	58454	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	General Comments		
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	40	°C
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	60	°C
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	40	°C
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0191	WithLTC	TA-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Fault Operations Ground	0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Fault Operations C Ø	0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Fault Operations B Ø	0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Fault Operations A Ø	0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Amps C Ø	80.0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Amps B Ø	75.0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Unknown Operations	0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Switching Operations	1	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Operations This Read Vac	1	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Operations Counter AL	410	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Operations Counter AF	410	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Maintenance Operations	0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	General Comments		
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	General Comments		
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Follow-up Action Required?	n	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Fault Operations Ground	0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Fault Operations C Ø	0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Fault Operations B Ø	0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Amps A Ø	70.0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	9 Month Operations	13	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	122	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	122	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments	ok	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	192.0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	168.0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	171.0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0976	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	24	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Fault Operations A Ø	0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	9 Month Operations	27	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Amps A Ø	85.0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Amps B Ø	105.0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Amps C Ø	100.0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	Winding Temp Max	55	°C
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	Totalizer Meter Reading	.9620	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	Oil Temp Present	32	°C
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	Oil Temp Max	50	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1800	psi
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	LTC Totalizer Reading	13852.80	kw
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	General Comments		
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	General Comments		
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	Follow-up Action Required?	n	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	LTCC000252	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	LTCC000252	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	LTCC000252	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	LTCC000252	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	LTCC000252	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	LTCC000252	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	LTCC000252	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	LTCC000252	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BCH000382	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BCH000382	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53	VDC
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BCH000382	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53	VDC
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BCH000382	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BCH000382	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BCH000382	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	LTC Operations Since Last Insp	1307	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	LTC Min Tap Position	6L	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	LTC Max Tap Position	6R	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	LTC Current Tap Position	1R	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	LTC As Left Counter	60342	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	LTC As Found Counter	60342	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Mechanism Patrol Inspection	General Comments		
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	General Comments		
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0017	LTCMechanism	846-1	LTC Counter Readings	Follow-up Action Required?	n	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Unknown Operations	0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Switching Operations	0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Operations This Read Vac	0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Operations Counter AL	290	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Operations Counter AF	290	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Maintenance Operations	0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	General Comments		
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	General Comments		
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0014	BreakerVacuum	846-0051	VCB Readings	Follow-up Action Required?	n	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	9 Month Operations	2	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Maintenance Operations	0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Operations Counter AF	356	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Operations Counter AL	365	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Operations This Read Vac	2	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Switching Operations	2	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Unknown Operations	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LTO190	WithLTC	TA-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	General Comments		
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	B0367	WithLTC	660-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0190	WithLTC	TA-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	General Comments		
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	General Comments		
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Counter Readings	Follow-up Action Required?	n	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LT0087	LTCMechanism	HN-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	681	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Counter Readings	General Comments		
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Mechanism Patrol Inspection	General Comments		
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Counter Readings	LTC As Found Counter	41640	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Counter Readings	LTC As Left Counter	41640	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Counter Readings	LTC Current Tap Position	7L	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Counter Readings	LTC Max Tap Position	2L	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	B0355	LTCMechanism	196-5	LTC Counter Readings	LTC Min Tap Position	10L	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	YD000470	Yard	846-Yard	Yard Patrol Inspection	Vegetation	None	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	40.00	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	Winding Temp Present	40	°C
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	Winding Temp Max	75	°C
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	Totalizer Meter Reading	.6570	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	Oil Temp Present	40	°C
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	Oil Temp Max	40	°C
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Fault Operations A Ø	0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Fault Operations B Ø	0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Fault Operations C Ø	0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Fault Operations Ground	0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	Follow-up Action Required?	n	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	General Comments		
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	257	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	257	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0282	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Readings	LTC Totalizer Reading	9460.80	kw
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0017	WithLTC	846-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Readings	General Comments		
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0016	BreakerVacuum	846-0074	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Amps C Ø	100.0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Amps B Ø	100.0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Amps A Ø	100.0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0427	BreakerVacuum	863-0061	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Maintenance Operations	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Operations Counter AF	168	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Operations Counter AL	168	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Operations This Read Vac	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Switching Operations	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Unknown Operations	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	9 Month Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Amps B Ø	100.0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Amps A Ø	120.0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Follow-up Action Required?	n	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Patrol Inspection	General Comments		
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	General Comments		
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	141	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	141	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Follow-up Action Required?	n	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Fault Operations Ground	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Fault Operations C Ø	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Fault Operations B Ø	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Fault Operations A Ø	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Follow-up Action Required?	n	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Patrol Inspection	General Comments		
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Amps C Ø	10.0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Amps B Ø	10.0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Amps A Ø	10.0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	9 Month Operations	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Unknown Operations	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Switching Operations	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Operations This Read Vac	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Operations Counter AL	212	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Operations Counter AF	212	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	Maintenance Operations	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Readings	General Comments		
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	General Comments		
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000583	BreakerVacuum	196-0090	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	110.00	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	110	°C
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	70	°C
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	110	°C
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0189	WithLTC	TA-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	70	°C
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Amps C Ø	300.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Fault Operations A Ø	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Fault Operations B Ø	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Fault Operations C Ø	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Fault Operations Ground	0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Fault Operations Ground	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Fault Operations C Ø	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Fault Operations B Ø	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Fault Operations A Ø	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	LTC Totalizer Reading	6881.76	kw
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1800	psi
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	Oil Temp Max	40	°C
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	Oil Temp Present	35	°C
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	Totalizer Meter Reading	.4779	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	Winding Temp Max	40	°C
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	Winding Temp Present	35	°C
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Amps A Ø	135.0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Amps B Ø	145.0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Amps C Ø	140.0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	9 Month Operations	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Unknown Operations	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Switching Operations	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Operations This Read Vac	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Operations Counter AL	206	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Vegetation	None	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	General Comments		
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Readings	General Comments		
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	General Comments		
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KT0035	WithLTC	863-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	1	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	80.0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	80.0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	80.0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	YD000339	Yard	863-Yard	Yard Patrol Inspection	Ambient Temp	82	*F
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Operations Counter AF	206	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Maintenance Operations	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	General Comments		
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Follow-up Action Required?	n	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	Totalizer Meter Reading	.2780	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Amps C Ø	210.0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Amps B Ø	210.0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Amps A Ø	185.0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Operations This Read Vac	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Switching Operations	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Unknown Operations	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	9 Month Operations	2	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Amps A Ø	0.0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Amps B Ø	0.0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Readings	Amps C Ø	0.0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000585	BreakerVacuum	196-0178	VCB Readings	9 Month Operations	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Unknown Operations	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Switching Operations	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Operations This Read Vac	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Operations Counter AL	190	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Operations Counter AF	190	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	Maintenance Operations	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000584	BreakerVacuum	196-0144	VCB Readings	General Comments		
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000587	BreakerVacuum	196-BT5-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Fault Operations A Ø	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Fault Operations B Ø	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Fault Operations C Ø	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Fault Operations Ground	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Follow-up Action Required?	n	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	General Comments		
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	Follow-up Action Required?	n	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	General Comments		
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	General Comments		
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Maintenance Operations	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Operations Counter AF	158	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000586	BreakerVacuum	196-5	VCB Readings	Operations Counter AL	158	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	General Comments		
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	LTC Totalizer Reading	4003.20	kw
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	Oil Temp Max	50	°C
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Readings	Oil Temp Present	35	°C
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	B0355	WithLTC	196-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	82	°F
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Unknown Operations	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Switching Operations	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Operations This Read Vac	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Operations Counter AL	87	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Operations Counter AF	87	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Maintenance Operations	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Patrol Inspection	General Comments	ok	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	General Comments		
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Follow-up Action Required?	n	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Fault Operations Ground	0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	General Comments		
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	General Comments		
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Ambient Temp	75	*F
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Follow-up Action Required?	n	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Fault Operations Ground	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Fault Operations C Ø	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Fault Operations B Ø	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Fault Operations A Ø	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Amps C Ø	75.0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Amps B Ø	70.0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Amps A Ø	65.0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	9 Month Operations	0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Patrol Inspection	General Comments		
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0433	BreakerVacuum	HN-1201	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	LTC Operations Since Last Insp	690	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	LTC Min Tap Position	8L	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	LTC Max Tap Position	5R	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	LTC As Left Counter	18850	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	LTC As Found Counter	18850	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Mechanism Patrol Inspection	General Comments		
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	General Comments		
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KT0035	LTCMechanism	863-1	LTC Counter Readings	Follow-up Action Required?	n	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BAT000527	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Follow-up Action Required?	n	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Fault Operations Ground	0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Fault Operations C Ø	0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	General Comments		
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Fault Operations A Ø	0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Amps C Ø	195.0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Amps B Ø	205.0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Amps A Ø	190.0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	9 Month Operations	1	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BCH000369	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BCH000369	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BCH000369	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BCH000369	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BCH000369	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BCH000369	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Amps C Ø	320.0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Amps B Ø	251.0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Amps A Ø	297.0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	9 Month Operations	15	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK000021	BreakerVacuum	TA-1138	VCB Readings	Unknown Operations	0	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	General Comments		
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Vegetation	None	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	YD000473	Yard	660-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	ST000475	Structure	660-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	ST000342	Structure	863-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Fault Operations C Ø	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Fault Operations B Ø	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Fault Operations A Ø	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK000022	BreakerVacuum	TA-12KV TR 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Unknown Operations	0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Switching Operations	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Operations This Read Vac	1	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Operations Counter AL	229	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Operations Counter AF	229	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	Maintenance Operations	0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Readings	General Comments		
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	General Comments		
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0109	BreakerVacuum	863-0232	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	Oil Temp Max	80	°C
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	LTC Totalizer Reading	9443.52	kw
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	General Comments		
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	General Comments		
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Switching Operations	0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Operations This Read Vac	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Operations Counter AL	206	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Operations Counter AF	206	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	99986	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	99986	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Maintenance Operations	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	General Comments		
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	General Comments		
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Maintenance Operations	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Operations Counter AF	164	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Operations Counter AL	164	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Operations This Read Vac	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Switching Operations	0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	Winding Temp Present	50	°C
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	Winding Temp Max	65	°C
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	Totalizer Meter Reading	.6558	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000588	BreakerVacuum	196-6	VCB Readings	Unknown Operations	0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0281	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	19	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	381.0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	385.0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	404.0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0991	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	B0398	WithLTC	863-2	LTC Transformer Readings	Oil Temp Present	50	°C
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Unknown Operations	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Switching Operations	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Operations This Read Vac	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Operations Counter AL	211	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Operations Counter AF	211	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	Maintenance Operations	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Readings	General Comments		
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	General Comments		
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	Oil Temp Present	35	°C
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	Oil Temp Max	57	°C
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1000	psi
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	30	°C
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	50	°C
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	General Comments		
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	FE000467	Fence	660-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000581	BreakerVacuum	196-0008	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	ST000472	Structure	846-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	General Comments		
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	General Comments		
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Follow-up Action Required?	n	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Fault Operations Ground	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Fault Operations C Ø	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Fault Operations B Ø	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Fault Operations A Ø	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	40	°C
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	59	°C
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	32	°C
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	48	°C
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	34	°C
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	52	°C
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LT0087	WithLTC	HN-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Amps C Ø	10.0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Amps B Ø	15.0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Amps A Ø	10.0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000582	BreakerVacuum	196-0052	VCB Readings	9 Month Operations	2	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Fault Operations A Ø	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Fault Operations B Ø	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Fault Operations C Ø	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Fault Operations Ground	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Follow-up Action Required?	n	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	General Comments		
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	General Comments		
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Maintenance Operations	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Operations Counter AF	236	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Operations Counter AL	236	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Operations This Read Vac	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	9 Month Operations	2	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Unknown Operations	0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	9 Month Operations	15	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Fault Operations A Ø	0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Amps A Ø	315.0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Amps B Ø	280.0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Amps C Ø	315.0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Fault Operations A Ø	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Fault Operations B Ø	0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Unknown Operations	0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Unknown Operations	0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Switching Operations	0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Operations This Read Vac	0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Switching Operations	2	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Operations This Read Vac	2	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Operations Counter AL	172	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Operations Counter AF	172	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Maintenance Operations	0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	General Comments		
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	General Comments		
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Follow-up Action Required?	n	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Fault Operations Ground	0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Fault Operations C Ø	0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Fault Operations B Ø	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	9 Month Operations	2	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Amps A Ø	55.0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Amps B Ø	55.0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	BK000245	BreakerVacuum	196-0009	VCB Readings	Amps C Ø	55.0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Operations Counter AL	559	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Operations Counter AF	559	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Maintenance Operations	0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	General Comments	Racked out & carded.	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Patrol Inspection	General Comments		
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Follow-up Action Required?	n	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Fault Operations Ground	0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Fault Operations C Ø	0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Fault Operations B Ø	0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Fault Operations A Ø	0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Fault Operations A Ø	0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Amps C Ø	185.0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Amps B Ø	195.0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Amps A Ø	195.0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0171	BreakerVacuum	846-0064	VCB Readings	9 Month Operations	0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Operations Counter AF	176	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Operations Counter AL	176	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Operations This Read Vac	11	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Switching Operations	1	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Unknown Operations	0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Unknown Operations	0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Switching Operations	2	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Operations This Read Vac	2	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Operations Counter AL	218	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Operations Counter AF	218	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Amps A Ø	120.0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Amps B Ø	140.0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Amps C Ø	130.0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	General Comments		
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	General Comments		
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Maintenance Operations	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Operations Counter AF	121	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Operations Counter AL	121	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Operations This Read Vac	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Switching Operations	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Fault Operations A Ø	0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Fault Operations B Ø	0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Fault Operations C Ø	0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Fault Operations Ground	0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Follow-up Action Required?	n	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	General Comments		
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	General Comments		
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Readings	Maintenance Operations	10	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000247	BreakerVacuum	863-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Amps C Ø	0.0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Amps B Ø	0.0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	KB0123	BreakerVacuum	863- BT1-2	VCB Readings	Amps A Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001064	BreakerVacuum	TA-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Fault Operations A Ø	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Fault Operations B Ø	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Fault Operations C Ø	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Fault Operations Ground	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Follow-up Action Required?	n	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	General Comments		
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	General Comments		
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Fault Adjusted Amps B Phase V	50.87	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Fault Operations A Ø	3	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Fault Operations B Ø	3	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Fault Operations C Ø	0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Fault Operations Ground	0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Follow-up Action Required?	n	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	General Comments		
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	General Comments		
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Maintenance Operations	0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Operations Counter AF	459	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Operations Counter AL	459	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Operations This Read Vac	6	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Switching Operations	0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Unknown Operations	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Maintenance Operations	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Operations Counter AF	117	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Operations Counter AL	117	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Operations This Read Vac	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Switching Operations	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Unknown Operations	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	9 Month Operations	37	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Amps A Ø	105.0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Amps B Ø	100.0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Readings	Amps C Ø	115.0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001063	BreakerVacuum	TA-1106	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	4	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	44.72	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	154.0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0982	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	88.0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001065	BreakerVacuum	TA-12KV BUS TIE SEC 1	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	SWG000079	Switchgear	HN-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	General Comments		
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Patrol Inspection	General Comments		
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Fault Operations Ground	0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	24	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Evidence of Insects	None	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	General Comments		
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Panels Dusted?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	SWG000188	Switchgear	TA-Swgr Sec 4	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Amps C Ø	400.0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Amps B Ø	350.0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Amps A Ø	350.0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0438	BreakerVacuum	HN-12KV TR 1	VCB Readings	9 Month Operations	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	142.0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	138.0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	146.0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	129	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	129	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0280	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	SWG000187	Switchgear	TA-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	General Comments		
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Mechanism Patrol Inspection	General Comments		
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	LTC As Found Counter	143750	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	LTC As Left Counter	143750	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	LTC Current Tap Position	4L	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	LTC Min Tap Position	7L	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	LTC Operations Since Last Insp	2050	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	B0398	LTCMechanism	863-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1107	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1107	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0978	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	9 Month Operations	0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Amps A Ø	0.0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Amps B Ø	0.0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Amps C Ø	0.0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Fault Operations A Ø	0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Fault Operations B Ø	0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Fault Operations C Ø	0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Fault Operations Ground	0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Follow-up Action Required?	n	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Patrol Inspection	General Comments		
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	General Comments	Rack out & carded.	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Maintenance Operations	0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Operations Counter AF	234	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Operations Counter AL	234	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Operations This Read Vac	0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Switching Operations	0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0434	BreakerVacuum	HN-1202	VCB Readings	Unknown Operations	0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	BAT001457	Battery	846-Battery Bank Distribution	Battery Patrol Inspection	All Connections OK?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	BAT001457	Battery	846-Battery Bank Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	79	*F
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	BAT001457	Battery	846-Battery Bank Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	BAT001457	Battery	846-Battery Bank Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	BAT001457	Battery	846-Battery Bank Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	BAT001457	Battery	846-Battery Bank Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0981	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Amps C Ø	0.0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Amps B Ø	0.0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Amps A Ø	0.0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0021	BreakerVacuum	846-BT1-2	VCB Readings	9 Month Operations	20	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Amps C Ø	0.0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Amps B Ø	0.0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Amps A Ø	0.0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0435	BreakerVacuum	HN-1203	VCB Readings	9 Month Operations	0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	General Comments		
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	FE000353	Fence	846-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	General Comments		
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	46567	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	46567	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	2L	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Max Tap Position	4R	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Min Tap Position	7L	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	608	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0034	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	9 Month Operations	3	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001066	BreakerVacuum	TA-1132	VCB Readings	Unknown Operations	0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Fault Operations A Ø	0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Fault Operations B Ø	0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Fault Operations C Ø	0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Fault Operations Ground	0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Follow-up Action Required?	n	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	General Comments		
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	General Comments		
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Maintenance Operations	0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Operations Counter AF	367	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Operations Counter AL	367	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Operations This Read Vac	0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Switching Operations	0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	LTCC000813	LTCControl	863-2	LTC Control Insp	All Connections OK?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	LTCC000813	LTCControl	863-2	LTC Control Insp	Follow-up Action Required?	n	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	LTCC000813	LTCControl	863-2	LTC Control Insp	General Comments		
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	LTCC000813	LTCControl	863-2	LTC Control Insp	LTC Operation Checked?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	LTCC000813	LTCControl	863-2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	LTCC000813	LTCControl	863-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	LTCC000813	LTCControl	863-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	LTCC000813	LTCControl	863-2	LTC Control Insp	VRR Time Delay	30	Seconds
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0015	BreakerVacuum	846-0939	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Fault Operations A Ø	0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Fault Operations B Ø	0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Fault Operations C Ø	0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Fault Operations Ground	0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Follow-up Action Required?	n	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	General Comments		
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	General Comments		
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Maintenance Operations	0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Operations Counter AF	185	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Operations Counter AL	185	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Operations This Read Vac	0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Switching Operations	0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	KB0062	BreakerVacuum	846-2	VCB Readings	Unknown Operations	0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	General Comments		
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	FE000333	Fence	863-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	15	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0979	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	PF000355	PowerFuse	TA-12KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	PF000355	PowerFuse	TA-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	PF000355	PowerFuse	TA-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	9 Month Operations	8	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Amps A Ø	85.0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Amps B Ø	65.0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Amps C Ø	80.0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Fault Operations A Ø	0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Fault Operations B Ø	0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Fault Operations C Ø	0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Fault Operations Ground	0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Unknown Operations	0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Switching Operations	0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Operations This Read Vac	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Operations Counter AL	393	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Operations Counter AF	393	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Maintenance Operations	0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	General Comments		
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Follow-up Action Required?	n	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Fault Operations Ground	0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Fault Operations C Ø	0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Fault Operations B Ø	0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Fault Operations A Ø	0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LTCC000518	LTCControl	HN-TRANS 1	LTC Control Insp	All Connections OK?	y	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LTCC000518	LTCControl	HN-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	LTC Current Tap Position	11L	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	LTC Max Tap Position	1R	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	LTC Min Tap Position	14L	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	1256	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	General Comments		
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	LTC As Found Counter	23305	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	°C
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	°C
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	Winding Temp Present	45	°C
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	Winding Temp Max	86	°C
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	Totalizer Meter Reading	.5760	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	Oil Temp Present	40	°C
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	Oil Temp Max	65	°C
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	LTC Totalizer Reading	10368.00	kw
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	General Comments		
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	S0034	WithLTC	846-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	PF000354	PowerFuse	TA-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	LTC As Left Counter	23305	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	LTC Current Tap Position	12L	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	LTC Max Tap Position	5R	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	LTC Min Tap Position	15L	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1577	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0190	LTCMechanism	TA-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	PF000353	PowerFuse	TA-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	PF000353	PowerFuse	TA-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	PF000353	PowerFuse	TA-STA SER NO 3	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	PF000352	PowerFuse	TA-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	ok	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	SWG000051	Switchgear	TA-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	PF000354	PowerFuse	TA-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	PF000354	PowerFuse	TA-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Switching Operations	0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Unknown Operations	0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	9 Month Operations	0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Amps A Ø	330.0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Amps B Ø	375.0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Amps C Ø	370.0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	PF000352	PowerFuse	TA-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	PF000352	PowerFuse	TA-STA SER NO 4	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Amps A Ø	75.0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Amps B Ø	75.0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Amps C Ø	75.0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Fault Operations A Ø	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	PF000351	PowerFuse	TA-12KV TR 4 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	PF000351	PowerFuse	TA-12KV TR 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	PF000351	PowerFuse	TA-12KV TR 4 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	PF000350	PowerFuse	TA-12KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	PF000350	PowerFuse	TA-12KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	PF000350	PowerFuse	TA-12KV TR 3 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Fault Operations A Ø	0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Fault Operations B Ø	0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Fault Operations Ground	0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Fault Operations B Ø	0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Fault Operations C Ø	0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Fault Operations Ground	0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Follow-up Action Required?	n	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Patrol Inspection	General Comments		
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Follow-up Action Required?	n	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	General Comments		
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	General Comments		
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Maintenance Operations	11	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Operations Counter AF	173	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Operations Counter AL	173	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Operations This Read Vac	12	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Switching Operations	1	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Unknown Operations	0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Unknown Operations	0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Switching Operations	0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Operations This Read Vac	0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Operations Counter AL	495	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Operations Counter AF	495	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	Maintenance Operations	0	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LB0436	BreakerVacuum	HN-1204	VCB Readings	General Comments		
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	LTC000518	LTCControl	HN-TRANS 1	LTC Control Insp	General Comments		
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	9 Month Operations	5	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Amps A Ø	140.0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Amps B Ø	140.0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Amps C Ø	135.0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Fault Operations A Ø	0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Fault Operations B Ø	0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Fault Operations C Ø	0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Fault Operations Ground	0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Follow-up Action Required?	n	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	General Comments		
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	General Comments		
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Maintenance Operations	0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Operations Counter AF	231	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Operations Counter AL	231	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Operations This Read Vac	0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Switching Operations	0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Patrol Inspection	Tank Paint Condition	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	BK000706	BreakerVacuum	846-0083	VCB Readings	Unknown Operations	0	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Mechanism Patrol Inspection	General Comments		
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	B0367	LTCMechanism	660-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	9 Month Operations	12	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Amps C Ø	125.0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Amps B Ø	125.0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Amps A Ø	125.0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0168	BreakerVacuum	846-0100	VCB Readings	9 Month Operations	22	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	PF000177	PowerFuse	HN-12KV SEC 1 BUS POTS	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/23/2020 13:30	Distribution	Hancock Quarterly Inspection	PF000177	PowerFuse	HN-12KV SEC 1 BUS POTS	Disconnect Powerfuse Inspection	General Comments	ok	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Follow-up Action Required?	n	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Foundation Condition	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	General Comments		
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	General Comments		
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Grounds in Place?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Maintenance Operations	0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Operations Counter AF	229	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Operations Counter AL	229	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	K0020	BreakerVacuum	846-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BK000503	BreakerVacuum	863-0158	VCB Readings	Operations This Read Vac	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Counter Readings	LTC As Left Counter	9704	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Counter Readings	LTC As Left Counter	229340	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Counter Readings	LTC As Found Counter	229340	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	General Comments	Trans needs nitrogen	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Counter Readings	General Comments		
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Counter Readings	Follow-up Action Required?	n	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	LTCC000743	LTCControl	846-1	LTC Control Insp	All Connections OK?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	LTCC000743	LTCControl	846-1	LTC Control Insp	Follow-up Action Required?	n	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	LTCC000743	LTCControl	846-1	LTC Control Insp	General Comments		
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	LTCC000743	LTCControl	846-1	LTC Control Insp	LTC Operation Checked?	y	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	LTCC000743	LTCControl	846-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	31	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	80.0	
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	LTCC000743	LTCControl	846-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	LTCC000743	LTCControl	846-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
10/23/2020 15:59	Distribution	Parkers Mill Quarterly Inspection	LTCC000743	LTCControl	846-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	82.0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	93.0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	LTCC000723	LTCControl	196-6	LTC Control Insp	All Connections OK?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	LTCC000723	LTCControl	196-6	LTC Control Insp	Follow-up Action Required?	n	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	LTCC000723	LTCControl	196-6	LTC Control Insp	General Comments		
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	LTCC000723	LTCControl	196-6	LTC Control Insp	LTC Operation Checked?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	LTCC000723	LTCControl	196-6	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	LTCC000723	LTCControl	196-6	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Counter Readings	LTC As Found Counter	9704	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	LTCC000723	LTCControl	196-6	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	LTCC000723	LTCControl	196-6	LTC Control Insp	VRR Time Delay	30	Seconds
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	General Comments		
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	LTC As Found Counter	67187	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Counter Readings	LTC Operations Since Last Insp	1432	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	0	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	0	°C
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Counter Readings	LTC Min Tap Position	15L	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Counter Readings	LTC Max Tap Position	1R	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Counter Readings	LTC Current Tap Position	11L	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LTCM000075	LTCMechanism	TA-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	LTCC000736	LTCCControl	196-5	LTC Control Insp	VRR Time Delay	30	Seconds
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	LTCC000736	LTCCControl	196-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	LTCC000736	LTCCControl	196-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	LTCC000736	LTCCControl	196-5	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	LTCC000736	LTCCControl	196-5	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	LTCC000736	LTCCControl	196-5	LTC Control Insp	LTC Operation Checked?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	LTCC000736	LTCCControl	196-5	LTC Control Insp	General Comments		
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	LTCC000736	LTCCControl	196-5	LTC Control Insp	Follow-up Action Required?	n	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	LTCC000736	LTCCControl	196-5	LTC Control Insp	All Connections OK?	y	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	General Comments		
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
10/28/2020 17:50	Distribution	Hughes Lane Quarterly Inspection	BAT000964	Battery	660-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Counter Readings	LTC Operations Since Last Insp	619	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	°C
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	45	°C
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Counter Readings	LTC Min Tap Position	12L	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Counter Readings	LTC Max Tap Position	3L	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Counter Readings	LTC Current Tap Position	10L	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Amps A Ø	126.0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Amps B Ø	146.0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Amps C Ø	127.0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	9 Month Operations	31	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Fault Adjusted Amps A Phase V	50.87	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Patrol Inspection	Bushing Condition	Good	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments	ok	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	9 Month Operations	10	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	BK001062	BreakerVacuum	TA-1173	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	173	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Amps C Ø	100.0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Amps B Ø	100.0	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Amps A Ø	100.0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	LTC As Left Counter	67187	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	Winding Temp Present	35	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	TX000130	WithLTC	196-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/23/2020 13:53	Distribution	Picadome Quarterly Inspection	BB0428	BreakerVacuum	863-0080	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LB0985	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	173	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
10/23/2020 12:48	Distribution	Taylor Quarterly Inspection	LT0189	LTCMechanism	TA-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Counter Readings	Follow-up Action Required?	n	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Counter Readings	General Comments		
10/23/2020 11:45	Distribution	American Avenue Quarterly Inspection	LTCM000062	LTCMechanism	196-6	LTC Mechanism Patrol Inspection	General Comments		
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Operations Counter AL	397	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Operations This Read Vac	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Switching Operations	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	General Comments		
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	9 Month Operations	2	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	429	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Accumulated Fault Duty A Ph V	6.69	%
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Accumulated Fault Duty B Ph V	2.39	%
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Accumulated Fault Duty C Ph V	1.91	%
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Amps A Ø	110	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Amps B Ø	115	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Amps C Ø	120	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Bushing Condition	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	2	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	3	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	General Comments		
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	General Comments		
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	General Comments		
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	6.41	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	1	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	General Comments	I on A phase	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	2064	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	2064	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	FE000376	Fence	898-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Unknown Operations	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	Totalizer Meter Reading	.7188	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	Winding Temp Max	75	°C
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	Winding Temp Present	60	°C
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Bushing Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	126	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	126	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
10/22/2020 15:33	Distribution	Traffon Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/22/2020 15:33	Distribution	Traffon Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/22/2020 15:33	Distribution	Traffon Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/22/2020 15:33	Distribution	Traffon Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/22/2020 15:33	Distribution	Traffon Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Foundation Condition	Good	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	General Comments		
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Grounds in Place?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1364	BreakerVacuum	TT-34KV TR 2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/22/2020 15:33	Distribution	Traffon Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/22/2020 15:33	Distribution	Traffon Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/22/2020 15:33	Distribution	Traffon Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/22/2020 15:33	Distribution	Traffon Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	Totalizer Meter Reading	.624	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	General Comments		
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	General Comments		
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	LTC Totalizer Reading	12938.40	kw
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	Oil Temp Max	65	°C
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	Oil Temp Present	62	°C
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/22/2020 15:33	Distribution	Traffon Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
10/22/2020 15:33	Distribution	Traffon Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65	
10/22/2020 15:33	Distribution	Traffon Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	Totalizer Meter Reading	.43	
10/22/2020 15:33	Distribution	Traffon Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
10/22/2020 15:33	Distribution	Traffon Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/22/2020 15:33	Distribution	Traffon Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/22/2020 15:33	Distribution	Traffon Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/22/2020 15:33	Distribution	Traffon Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/22/2020 15:33	Distribution	Traffon Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/22/2020 15:33	Distribution	Traffon Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/22/2020 15:33	Distribution	Traffon Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/22/2020 15:33	Distribution	Traffon Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	Oil Temp Present	40	°C
10/22/2020 15:33	Distribution	Traffon Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	Oil Temp Max	45	°C
10/22/2020 15:33	Distribution	Traffon Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
10/22/2020 15:33	Distribution	Traffon Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/22/2020 15:33	Distribution	Traffon Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	LTC Totalizer Reading	3440	kw
10/22/2020 15:33	Distribution	Traffon Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/22/2020 15:33	Distribution	Traffon Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	General Comments		
10/22/2020 15:33	Distribution	Traffon Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	General Comments		
10/22/2020 15:33	Distribution	Traffon Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/22/2020 15:33	Distribution	Traffon Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/22/2020 15:33	Distribution	Traffon Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/22/2020 15:33	Distribution	Traffon Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 15:33	Distribution	Traffon Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/22/2020 15:33	Distribution	Traffon Avenue Quarterly Inspection	B0303	WithLTC	898-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	2	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	480.0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	480.0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	480.0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0159	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	Totalizer Meter Reading	.588	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Unknown Operations	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Tank Paint Condition	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Switching Operations	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Operations This Read Vac	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Operations Counter AL	274	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Operations Counter AF	274	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Maintenance Operations	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	Oil Temp Present	40	°C
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	Oil Temp Max	60	°C
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1750	psi
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	LTC Totalizer Reading	8467.2	kw
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	Oil Temp Present	40	°C
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	Oil Temp Max	60	°C
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	LTC Totalizer Reading	4492.8	kw
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	General Comments		
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	General Comments		
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Grounds in Place?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	General Comments		
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	General Comments		
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Foundation Condition	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Follow-up Action Required?	n	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Fault Operations Ground	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Fault Operations C Ø	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Fault Operations B Ø	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Fault Operations A Ø	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0084	BreakerVacuum	898-0404	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0351	WithLTC	717-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	B0431	WithLTC	451-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	General Comments		
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	General Comments		
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	LTC Totalizer Reading	7830.00	kw
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	Oil Temp Max	45	°C
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	Oil Temp Present	45	°C
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	Totalizer Meter Reading	.4350	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	Winding Temp Max	63	°C
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	Winding Temp Present	50	°C
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	C0497	WithLTC	451-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	Winding Temp Present	40	°C
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KT0022	WithLTC	898-2	LTC Transformer Readings	Winding Temp Max	60	°C
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Accumulated Fault Duty B Ph V	0	%
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Accumulated Fault Duty A Ph V	0	%
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	9 Month Operations	3	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Unknown Operations	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Switching Operations	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Operations This Read Vac	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Operations Counter AL	276	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Operations Counter AF	276	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Maintenance Operations	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	General Comments		
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	General Comments		
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Follow-up Action Required?	n	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Fault Operations Ground	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Fault Operations C Ø	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Fault Operations B Ø	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Fault Operations A Ø	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Unknown Operations	0	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Tank Paint Condition	Good	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Operations This Read Vac	0	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Operations Counter AL	206	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Operations Counter AF	206	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Maintenance Operations	0	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Grounds in Place?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	General Comments		
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	General Comments		
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Foundation Condition	Good	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Follow-up Action Required?	n	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Fault Operations Ground	0	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Fault Operations C Ø	0	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Fault Operations B Ø	0	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Fault Operations A Ø	0	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Amps C Ø	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Amps B Ø	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Amps A Ø	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0	%
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	130	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	2.06	%
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	2.06	%
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	5.14	%
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0218	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	6	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Unknown Operations	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Tank Paint Condition	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Switching Operations	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Operations This Read Vac	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Operations Counter AL	501	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Operations Counter AF	501	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Maintenance Operations	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Grounds in Place?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	General Comments		
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	General Comments		
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Foundation Condition	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Follow-up Action Required?	n	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Fault Operations Ground	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Fault Operations C Ø	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Fault Operations B Ø	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Fault Operations A Ø	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	General Comments		
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	FE000537	Fence	835-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Patrol Inspection	Bushing Condition	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Amps C Ø	60	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Amps B Ø	60	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Amps A Ø	60	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0443	BreakerVacuum	898-0078	VCB Readings	Accumulated Fault Duty C Ph V	0	%
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	9 Month Operations	5	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	513	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	513	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	9 Month Operations	4	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Accumulated Fault Duty A Ph V	2.44	%
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Accumulated Fault Duty B Ph V	1.46	%
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Accumulated Fault Duty C Ph V	2.44	%
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Amps A Ø	125	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Amps B Ø	125	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Amps C Ø	145	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Bushing Condition	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Fault Operations A Ø	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Fault Operations B Ø	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Fault Operations C Ø	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Fault Operations Ground	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Follow-up Action Required?	n	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Foundation Condition	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	General Comments		
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	General Comments		
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Grounds in Place?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Maintenance Operations	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Operations Counter AF	189	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Operations Counter AL	189	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Operations This Read Vac	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Switching Operations	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Patrol Inspection	Tank Paint Condition	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	KB0079	BreakerVacuum	717-0599	VCB Readings	Unknown Operations	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	LTCC000835	LTCCControl	717-2	LTC Control Insp	All Connections OK?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	LTCC000835	LTCCControl	717-2	LTC Control Insp	Follow-up Action Required?	n	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	LTCC000835	LTCCControl	717-2	LTC Control Insp	General Comments		
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	LTCC000835	LTCCControl	717-2	LTC Control Insp	LTC Operation Checked?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	LTCC000835	LTCCControl	717-2	LTC Control Insp	LTC Output Voltage Level	123.8	VAC
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	LTCC000835	LTCCControl	717-2	LTC Control Insp	VRR Base Voltage AF	124	VAC
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	LTCC000835	LTCCControl	717-2	LTC Control Insp	VRR Base Voltage AL	124	VAC
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	LTCC000835	LTCCControl	717-2	LTC Control Insp	VRR Time Delay	30	Seconds
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0	%
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0	%
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	K0186	BreakerVacuum	717-BT1-2	VCB Readings	9 Month Operations	7	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	General Comments		
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	ST000546	Structure	835-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Vegetation	None	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	General Comments		
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Patrol Inspection	Bushing Condition	Good	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Amps C Ø	10.0	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Amps B Ø	10.0	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Amps A Ø	10.0	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	CB0296	BreakerVacuum	835-0174	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	YD000542	Yard	835-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	12	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	360.0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	360.0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	360.0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0232	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Grounds in Place?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	General Comments		
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Patrol Inspection	Tank Paint Condition	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	Switching Operations	2	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	Operations This Read Vac	2	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	Operations Counter AL	166	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	Operations Counter AF	166	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	Maintenance Operations	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Patrol Inspection	Grounds in Place?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	General Comments		
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Patrol Inspection	General Comments		
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Patrol Inspection	Foundation Condition	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	Follow-up Action Required?	n	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	Fault Operations Ground	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	Fault Operations C Ø	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	Fault Operations B Ø	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	Fault Operations A Ø	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Patrol Inspection	Bushing Condition	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	Amps C Ø	130	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	Amps B Ø	100	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	Amps A Ø	115	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	Accumulated Fault Duty C Ph V	0	%
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	Accumulated Fault Duty B Ph V	0	%
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	Accumulated Fault Duty A Ph V	0	%
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK001102	BreakerVacuum	717-0099	VCB Readings	9 Month Operations	7	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	ST000476	Structure	659-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	General Comments		
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Foundation Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Follow-up Action Required?	n	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Fault Operations Ground	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Fault Operations C Ø	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Fault Operations B Ø	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Fault Operations A Ø	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	Follow-up Action Required?	n	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	General Comments		
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	429	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Readings	General Comments		
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	2	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	255	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	255	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0146	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	10.0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	10.0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	10.0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0236	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Operations Counter AF	397	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Maintenance Operations	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Bushing Condition	Good	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	General Comments		
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	FE000416	Fence	659-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Vegetation	None	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	General Comments		
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	General Comments		
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	LTC Totalizer Reading	2112.00	kw
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	Oil Temp Max	40	°C
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	Oil Temp Present	40	°C
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	Totalizer Meter Reading	.2200	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Vegetation	None	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	General Comments		
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	General Comments		
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	YD000417	Yard	717-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	YD000474	Yard	659-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Mechanism Patrol Inspection	General Comments		
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	LTC As Found Counter	195874	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	LTC As Left Counter	195876	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	LTC Current Tap Position	3L	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	LTC Max Tap Position	2R	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Patrol Inspection	Bushing Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Amps C Ø	340.0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Amps B Ø	340.0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Amps A Ø	340.0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0204	BreakerVacuum	451-2	VCB Readings	9 Month Operations	3	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	LTC Min Tap Position	6L	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	LTC Operations Since Last Insp	1539	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	B0303	LTCMechanism	898-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	BCH001422	Charger	835-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	BCH001422	Charger	835-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	BCH001422	Charger	835-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	BCH001422	Charger	835-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	BCH001422	Charger	835-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	BCH001422	Charger	835-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	BCH001422	Charger	835-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	BCH001422	Charger	835-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	BAT001491	Battery	835-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	BAT001491	Battery	835-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	BAT001491	Battery	835-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	BAT001491	Battery	835-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	BAT001491	Battery	835-Battery Bank	Battery Patrol Inspection	General Comments		
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	BAT001491	Battery	835-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	BAT001491	Battery	835-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	BAT001491	Battery	835-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	BAT001491	Battery	835-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	BAT001491	Battery	835-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	BAT001491	Battery	835-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	BAT001491	Battery	835-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	BAT001491	Battery	835-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Tank Paint Condition	Good	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Grounds in Place?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	General Comments		
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Foundation Condition	Good	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1362	BreakerVacuum	TT-CAP BK 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	C0532	WithLTC	835-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Operations This Read Vac	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Switching Operations	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Patrol Inspection	Tank Paint Condition	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Unknown Operations	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	9 Month Operations	7	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Accumulated Fault Duty A Ph V	.98	%
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Accumulated Fault Duty B Ph V	.49	%
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Accumulated Fault Duty C Ph V	0	%
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Amps A Ø	30	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Amps B Ø	35	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Amps C Ø	20	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Patrol Inspection	Bushing Condition	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Fault Operations A Ø	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Fault Operations B Ø	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Fault Operations C Ø	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Fault Operations Ground	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Follow-up Action Required?	n	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Patrol Inspection	Foundation Condition	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Patrol Inspection	General Comments		
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	General Comments		
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Patrol Inspection	Grounds in Place?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Maintenance Operations	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Operations Counter AF	175	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Operations Counter AL	175	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Operations This Read Vac	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Switching Operations	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Patrol Inspection	Tank Paint Condition	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000844	BreakerVacuum	717-0047	VCB Readings	Unknown Operations	0	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Accumulated Fault Duty A Ph V	0	%
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Accumulated Fault Duty B Ph V	0	%
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Accumulated Fault Duty C Ph V	0	%
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Amps A Ø	110	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Amps B Ø	135	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Amps C Ø	90	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Patrol Inspection	Bushing Condition	Good	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Grounds in Place?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	General Comments		
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Foundation Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	9	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	431	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	431	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	LTCC000708	LTCControl	659-1	LTC Control Insp	All Connections OK?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Fault Operations A Ø	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Fault Operations B Ø	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Fault Operations C Ø	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Fault Operations Ground	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Follow-up Action Required?	n	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Patrol Inspection	Foundation Condition	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Patrol Inspection	General Comments		
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	General Comments		
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Patrol Inspection	Grounds in Place?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Maintenance Operations	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Operations Counter AF	180	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	Operations Counter AL	180	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	LTCC000708	LTCControl	659-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	General Comments		
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	FE000412	Fence	717-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Tank Paint Condition	Good	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Grounds in Place?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	General Comments		
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Foundation Condition	Good	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1361	BreakerVacuum	TT-3313	VCB Patrol Inspection	Bushing Condition	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	Winding Temp Present	40	°C
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	Winding Temp Max	75	°C
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Unknown Operations	0	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Tank Paint Condition	Good	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Switching Operations	0	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Operations This Read Vac	0	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Operations Counter AL	183	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Operations Counter AF	183	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Maintenance Operations	0	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Grounds in Place?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	General Comments		
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Foundation Condition	Good	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Follow-up Action Required?	n	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	General Comments		
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	General Comments		
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	LTC Totalizer Reading	8974	kw
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2	psi
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	Oil Temp Max	45	°C
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	Oil Temp Present	45	°C
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	Totalizer Meter Multiplier	14000	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	Totalizer Meter Reading	.641	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	C0496	WithLTC	659-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Bushing Condition	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	General Comments		
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	All Identified and Legible?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	General Comments		
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	LTCC000708	LTCControl	659-1	LTC Control Insp	Follow-up Action Required?	n	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	LTCC000708	LTCControl	659-1	LTC Control Insp	General Comments		
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	LTCC000708	LTCControl	659-1	LTC Control Insp	LTC Operation Checked?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	LTCC000708	LTCControl	659-1	LTC Control Insp	LTC Output Voltage Level	125.8	VAC
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	LTCC000708	LTCControl	659-1	LTC Control Insp	VRR Base Voltage AF	125	VAC
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	LTCC000708	LTCControl	659-1	LTC Control Insp	VRR Base Voltage AL	125	VAC
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	ST000419	Structure	717-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Counter Readings	LTC Operations Since Last Insp	392	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BCH000367	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53	VDC
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BCH000367	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Counter Readings	LTC Operations Since Last Insp	276	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Counter Readings	LTC Min Tap Position	11L	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Counter Readings	LTC Max Tap Position	4L	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Counter Readings	LTC Current Tap Position	8L	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Counter Readings	LTC As Left Counter	69223	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Counter Readings	LTC As Found Counter	69220	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Mechanism Patrol Inspection	General Comments		
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Unknown Operations	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Tank Paint Condition	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Switching Operations	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Operations This Read Vac	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Operations Counter AL	495	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Operations Counter AF	495	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Maintenance Operations	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Grounds in Place?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	General Comments		
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	General Comments		
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Foundation Condition	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Follow-up Action Required?	n	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Fault Operations Ground	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Fault Operations C Ø	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Fault Operations B Ø	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Fault Operations A Ø	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Patrol Inspection	Bushing Condition	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Amps C Ø	380	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Amps B Ø	360	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Amps A Ø	360	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Accumulated Fault Duty C Ph V	0	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Accumulated Fault Duty B Ph V	0	%
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	Accumulated Fault Duty A Ph V	0	%
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	General Comments		
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	0.0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	0.0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	0.0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	General Comments		
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Grounds in Place?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Tank Leaks	None	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Warning Signs OK?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Counter Readings	LTC Max Tap Position	2L	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Counter Readings	LTC Min Tap Position	11L	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Fault Operations B Ø	0	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Fault Operations C Ø	0	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Fault Operations Ground	0	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Follow-up Action Required?	n	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Foundation Condition	Good	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	General Comments		
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	General Comments		
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Grounds in Place?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Maintenance Operations	0	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Operations Counter AF	157	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Operations Counter AL	157	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Operations This Read Vac	0	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Switching Operations	0	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Tank Paint Condition	Good	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	10.0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Tank Paint Condition	Good	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Grounds in Place?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	General Comments		
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Foundation Condition	Good	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1363	BreakerVacuum	TT-3314	VCB Patrol Inspection	Bushing Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Readings	General Comments		
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Tank Paint Condition	Good	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1356	BreakerVacuum	TT-3316	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000843	BreakerVacuum	717-0025	VCB Readings	9 Month Operations	4	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0442	BreakerVacuum	898-0077	VCB Readings	9 Month Operations	3	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Counter Readings	General Comments		
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	C0532	LTCMechanism	835-1	LTC Counter Readings	Follow-up Action Required?	n	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Tank Paint Condition	Good	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Grounds in Place?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	General Comments		
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Foundation Condition	Good	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Counter Readings	LTC Operations Since Last Insp	630	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Counter Readings	LTC Min Tap Position	13L	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Counter Readings	LTC Max Tap Position	6L	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Counter Readings	LTC Current Tap Position	10L	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Counter Readings	LTC As Left Counter	15041	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Counter Readings	LTC As Found Counter	15038	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1357	BreakerVacuum	TT-34KV BUS TIE & TFR	VCB Patrol Inspection	Bushing Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Mechanism Patrol Inspection	General Comments		
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Counter Readings	General Comments		
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	B0431	LTCMechanism	451-1	LTC Counter Readings	Follow-up Action Required?	n	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	9 Month Operations	1	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Amps A Ø	13.0	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Amps B Ø	18.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Amps C Ø	15.0	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Bushing Condition	Good	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	10.0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0104	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	10.0	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	BK000113	BreakerVacuum	835-0173	VCB Readings	Fault Operations A Ø	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0	VDC
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Fault Operations A Ø	0	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Fault Operations B Ø	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0	VDC
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Amps A Ø	10	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Accumulated Fault Duty C Ph V	0	%
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Accumulated Fault Duty B Ph V	0	%
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Accumulated Fault Duty A Ph V	0	%
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	9 Month Operations	2	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Unknown Operations	0	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Tank Paint Condition	Good	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Switching Operations	0	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Operations This Read Vac	0	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Operations Counter AL	172	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Operations Counter AF	172	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Maintenance Operations	0	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Grounds in Place?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	General Comments		
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	General Comments		
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Foundation Condition	Good	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Follow-up Action Required?	n	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Fault Operations Ground	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	Totalizer Meter Reading	.476	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	Oil Temp Present	40	°C
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	Oil Temp Max	65	°C
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	General Comments		
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	General Comments		
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Foundation Condition	Good	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Follow-up Action Required?	n	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Fault Operations Ground	0	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Fault Operations B Ø	0	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Fault Operations A Ø	0	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Bushing Condition	Good	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Amps C Ø	10	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Amps B Ø	10	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	295.00	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	45	°C
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	40	°C
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	32	°C
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	30	°C
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	42	°C
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	38	°C
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	BCH000607	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	BCH000607	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	BCH000607	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	BCH000607	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	9 Month Operations	4	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Amps A Ø	10.0	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Amps B Ø	10.0	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Amps C Ø	10.0	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Bushing Condition	Good	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	BCH000607	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	BCH000607	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Foundation Condition	Good	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	General Comments		
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	General Comments		
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Grounds in Place?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Maintenance Operations	0	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Operations Counter AF	32	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Operations Counter AL	32	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Operations This Read Vac	0	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Counter Readings	Follow-up Action Required?	n	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Counter Readings	General Comments		
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Mechanism Patrol Inspection	General Comments		
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Counter Readings	LTC As Found Counter	29774	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Counter Readings	LTC As Left Counter	29776	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Counter Readings	LTC Current Tap Position	7L	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Counter Readings	LTC Max Tap Position	2R	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Counter Readings	LTC Min Tap Position	11L	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Counter Readings	LTC Operations Since Last Insp	1023	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0380	LTCMechanism	717-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Switching Operations	0	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Tank Paint Condition	Good	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Patrol Inspection	Bushing Condition	Good	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Amps C Ø	5	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Amps B Ø	5	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Amps A Ø	5	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Accumulated Fault Duty C Ph V	0	%
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Accumulated Fault Duty B Ph V	0	%
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Accumulated Fault Duty A Ph V	0	%
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	9 Month Operations	2	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Counter Readings	LTC Operations Since Last Insp	744	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Counter Readings	LTC Min Tap Position	12L	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Counter Readings	LTC Max Tap Position	2L	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Counter Readings	LTC Current Tap Position	9L	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Counter Readings	LTC As Left Counter	29649	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Counter Readings	LTC As Found Counter	29647	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Mechanism Patrol Inspection	General Comments		
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Counter Readings	General Comments		
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	LTC Totalizer Reading	6854.4	kw
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BAT000539	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Counter Readings	Follow-up Action Required?	n	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0351	LTCMechanism	717-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Counter Readings	Follow-up Action Required?	n	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Counter Readings	General Comments		
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Mechanism Patrol Inspection	General Comments		
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Counter Readings	LTC As Found Counter	66291	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Counter Readings	LTC As Left Counter	66293	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	General Comments		
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	General Comments		
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	B0380	WithLTC	717-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Fault Operations C Ø	0	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Fault Operations B Ø	0	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Fault Operations A Ø	0	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Counter Readings	LTC Current Tap Position	11L	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Counter Readings	LTC Max Tap Position	8L	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Counter Readings	LTC Min Tap Position	16L	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Counter Readings	LTC Operations Since Last Insp	51	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	C0496	LTCMechanism	659-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Fault Adjusted Amps C Phase V	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000577	BreakerVacuum	659-0012	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Fault Operations C Ø	0	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Fault Operations Ground	0	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	MB0175	BreakerVacuum	835-0223	VCB Readings	Follow-up Action Required?	n	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	LTCC000720	LTCControl	451-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	LTCC000720	LTCControl	451-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	LTCC000720	LTCControl	451-1	LTC Control Insp	LTC Output Voltage Level	123.7	VAC
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	LTCC000720	LTCControl	451-1	LTC Control Insp	LTC Operation Checked?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	LTCC000720	LTCControl	451-1	LTC Control Insp	General Comments		
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	LTCC000720	LTCControl	451-1	LTC Control Insp	Follow-up Action Required?	n	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	LTCC000720	LTCControl	451-1	LTC Control Insp	All Connections OK?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Bushing Condition	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BCH000381	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BCH000381	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BCH000381	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BCH000381	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	2.5	amps
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BCH000381	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BCH000381	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCControl	898-2	LTC Control Insp	All Connections OK?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCControl	898-2	LTC Control Insp	Follow-up Action Required?	n	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCControl	898-2	LTC Control Insp	General Comments		
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCControl	898-2	LTC Control Insp	LTC Operation Checked?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCControl	898-2	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCControl	898-2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCControl	898-2	LTC Control Insp	VRR Base Voltage AF	124	VAC
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCControl	898-2	LTC Control Insp	VRR Base Voltage AL	124	VAC
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	LTCC000073	LTCControl	898-2	LTC Control Insp	VRR Time Delay	30	Seconds
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	9 Month Operations	1	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Accumulated Fault Duty A Ph V	0	%
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Accumulated Fault Duty B Ph V	0	%
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Accumulated Fault Duty C Ph V	0	%
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Amps A Ø	245	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Amps B Ø	285	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Amps C Ø	245	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Patrol Inspection	Bushing Condition	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Fault Operations Ground	0	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Fault Operations C Ø	0	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Fault Operations B Ø	0	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Fault Operations A Ø	0	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	235	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	LTC Min Tap Position	11L	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1L	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	LTC Current Tap Position	9L	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	LTC As Left Counter	54241	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	LTC As Found Counter	54241	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	General Comments		
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LT0194	LTCMechanism	TT-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Patrol Inspection	Bushing Condition	Good	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Amps C Ø	5	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Amps B Ø	10	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Amps A Ø	20	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Accumulated Fault Duty C Ph V	1.1	%
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Accumulated Fault Duty B Ph V	1.1	%
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	Accumulated Fault Duty A Ph V	1.1	%
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000580	BreakerVacuum	659-0094	VCB Readings	9 Month Operations	2	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Unknown Operations	0	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Tank Paint Condition	Good	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Switching Operations	0	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Operations This Read Vac	0	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Operations Counter AL	176	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Operations Counter AF	176	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Tank Paint Condition	Good	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Grounds in Place?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	General Comments		
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Foundation Condition	Good	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1359	BreakerVacuum	TT-3311	VCB Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	LTCC000720	LTCControl	451-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Unknown Operations	0	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Amps B Ø	380	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Amps A Ø	380	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Accumulated Fault Duty C Ph V	0	%
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Accumulated Fault Duty B Ph V	0	%
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Accumulated Fault Duty A Ph V	.37	%
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	9 Month Operations	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	9 Month Operations	3	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Accumulated Fault Duty A Ph V	0	%
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Unknown Operations	0	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Tank Paint Condition	Good	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Switching Operations	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Accumulated Fault Duty B Ph V	0	%
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Accumulated Fault Duty C Ph V	.37	%
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Amps A Ø	40	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Amps B Ø	40	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Amps C Ø	50	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Bushing Condition	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Fault Operations A Ø	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Fault Operations B Ø	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Fault Operations C Ø	0	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Operations This Read Vac	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Fault Operations Ground	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Follow-up Action Required?	n	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	General Comments		
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	General Comments		
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Grounds in Place?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Maintenance Operations	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Operations Counter AF	180	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Operations Counter AL	180	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Operations This Read Vac	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Switching Operations	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Patrol Inspection	Tank Paint Condition	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000909	BreakerVacuum	717-0071	VCB Readings	Unknown Operations	0	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Operations Counter AL	196	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Operations Counter AF	196	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Readings	Maintenance Operations	0	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000578	BreakerVacuum	659-0013	VCB Patrol Inspection	Grounds in Place?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Fault Operations A Ø	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Fault Operations B Ø	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Fault Operations C Ø	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Fault Operations Ground	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Follow-up Action Required?	n	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Patrol Inspection	Foundation Condition	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Patrol Inspection	General Comments		
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	General Comments		
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Patrol Inspection	Grounds in Place?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Maintenance Operations	0	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	General Comments		
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1400	psi
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Maintenance Operations	0	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Grounds in Place?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	General Comments		
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	General Comments		
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Foundation Condition	Good	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Follow-up Action Required?	n	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Fault Operations Ground	0	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Fault Operations C Ø	0	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Fault Operations B Ø	0	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Fault Operations A Ø	0	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Patrol Inspection	Bushing Condition	Good	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BK000579	BreakerVacuum	659-0032	VCB Readings	Amps C Ø	380	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	Oil Temp Max	58	°C
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Readings	Oil Temp Present	35	°C
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LT0194	WithLTC	TT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Operations Counter AF	161	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Operations Counter AL	161	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Operations This Read Vac	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	BK000649	BreakerVacuum	717-2	VCB Readings	Switching Operations	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	B80217	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	160	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Unknown Operations	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	LTCC000121	LTCCControl	451-2	LTC Control Insp	VRR Time Delay	30	Seconds
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Fault Operations A Ø	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Fault Operations B Ø	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Fault Operations C Ø	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Fault Operations Ground	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Follow-up Action Required?	n	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Foundation Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	LTCC000121	LTCCControl	451-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	LTCC000121	LTCCControl	451-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	LTCC000121	LTCCControl	451-2	LTC Control Insp	LTC Output Voltage Level	123.8	VAC
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	LTCC000121	LTCCControl	451-2	LTC Control Insp	LTC Operation Checked?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	General Comments		
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	General Comments		
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Grounds in Place?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	LTCC000121	LTCCControl	451-2	LTC Control Insp	Follow-up Action Required?	n	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	LTCC000121	LTCCControl	451-2	LTC Control Insp	All Connections OK?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Tank Paint Condition	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Maintenance Operations	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Bushing Condition	Good	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Amps C Ø	60.0	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Amps B Ø	59.0	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Amps A Ø	60.0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	General Comments		
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Vegetation	None	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	9 Month Operations	8	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Amps A Ø	5.0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Amps B Ø	5.0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Amps C Ø	5.0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Bushing Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	160	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Bushing Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Amps C Ø	320.0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Amps B Ø	320.0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Amps A Ø	320.0	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BCH001127	Charger	659-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BCH001127	Charger	659-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BCH001127	Charger	659-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BCH001127	Charger	659-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.1	amps
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BCH001127	Charger	659-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BCH001127	Charger	659-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	9 Month Operations	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Accumulated Fault Duty A Ph V	2.31	%
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Accumulated Fault Duty B Ph V	0	%
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Accumulated Fault Duty C Ph V	0	%
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Amps A Ø	380	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Amps B Ø	385	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Amps C Ø	365	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Bushing Condition	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	9 Month Operations	17	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Operations Counter AF	313	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Operations Counter AL	313	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Operations This Read Vac	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Switching Operations	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Patrol Inspection	Tank Paint Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0128	BreakerVacuum	451-2122	VCB Readings	Unknown Operations	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BAT001184	Battery	659-Battery Bank	Battery Patrol Inspection	General Comments		
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Switching Operations	1	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Operations This Read Vac	1	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Operations Counter AL	228	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Operations Counter AF	228	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BAT000525	Battery	898-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Maintenance Operations	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Grounds in Place?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	General Comments		
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	General Comments		
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Foundation Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Follow-up Action Required?	n	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Fault Operations Ground	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Fault Operations C ∅	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Fault Operations B ∅	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Fault Operations A ∅	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Amps A ∅	160	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	BAT000604	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Fault Operations Ground	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Follow-up Action Required?	n	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Foundation Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	General Comments		
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	General Comments		
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Grounds in Place?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Maintenance Operations	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Operations Counter AF	179	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Operations Counter AL	179	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Operations This Read Vac	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Switching Operations	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Tank Paint Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Unknown Operations	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	LTCC000740	LTCControl	898-1	LTC Control Insp	All Connections OK?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	LTCC000740	LTCControl	898-1	LTC Control Insp	Follow-up Action Required?	n	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Tank Paint Condition	Good	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Switching Operations	0	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Operations This Read Vac	0	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Operations Counter AL	69	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Operations Counter AF	69	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Maintenance Operations	0	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Grounds in Place?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	General Comments		
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	General Comments		
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	LTCC000740	LTCControl	898-1	LTC Control Insp	General Comments		
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	LTCC000740	LTCControl	898-1	LTC Control Insp	LTC Operation Checked?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	LTCC000740	LTCControl	898-1	LTC Control Insp	LTC Output Voltage Level	123.1	VAC
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	LTCC000740	LTCControl	898-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	LTCC000740	LTCControl	898-1	LTC Control Insp	VRR Base Voltage AF	125	VAC
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	LTCC000740	LTCControl	898-1	LTC Control Insp	VRR Base Voltage AL	125	VAC
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	LTCC000740	LTCControl	898-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Foundation Condition	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Follow-up Action Required?	n	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	PF000362	PowerFuse	TT-34KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	PF000362	PowerFuse	TT-34KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	PF000362	PowerFuse	TT-34KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	PF000361	PowerFuse	TT-34KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	PF000361	PowerFuse	TT-34KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	PF000361	PowerFuse	TT-34KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	PF000360	PowerFuse	TT-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	PF000360	PowerFuse	TT-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	PF000360	PowerFuse	TT-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	9 Month Operations	9	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	General Comments	.	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	1499	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	1499	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Amps A Ø	5.0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Amps B Ø	5.0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Amps C Ø	5.0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Bushing Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Fault Operations A Ø	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Fault Operations B Ø	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0007	BreakerVacuum	451-2121	VCB Readings	Fault Operations C Ø	0	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Tank Leaks	None	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Warning Signs OK?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	General Comments		
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Vegetation	None	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	YD000392	Yard	898-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	General Comments		
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	ST000395	Structure	898-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	FE000554	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Ambient Temp	65	*F
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	YD000561	Yard	451-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Fault Operations Ground	0	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Fault Operations C Ø	0	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Fault Operations B Ø	0	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Fault Operations A Ø	0	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	LB1360	BreakerVacuum	TT-34KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	LTC Operations Since Last Insp	1110	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	45	*C
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	LTC Min Tap Position	11L	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	LTC Max Tap Position	5R	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	LTC Current Tap Position	6L	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	LTC As Left Counter	39960	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	LTC As Found Counter	39958	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Mechanism Patrol Inspection	General Comments		
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	General Comments		
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KT0022	LTCMechanism	898-2	LTC Counter Readings	Follow-up Action Required?	n	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	LTCC000291	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	LTCC000291	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	LTCC000291	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	LTCC000291	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.8	VAC
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	LTCC000291	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	LTCC000291	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	LTCC000291	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
10/22/2020 9:51	Distribution	Minor Farm Quarterly Inspection	LTCC000291	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BCH000367	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BCH000367	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BCH000367	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BCH000367	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53	VDC
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	All Connections OK?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Bushing Condition	Good	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Capacitor Patrol Inspection	Good	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Cap bank CT in Good Condition?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Capacitor Condition	Good	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Foundation Condition	Good	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	General Comments		
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Grounds in Place?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	CAP000133	CapacitorBank	TT-Cap Bank 1	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	ST000565	Structure	451-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Foundation Condition	Good	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	LTCC000505	LTCControl	930-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	LTCC000505	LTCControl	930-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Counter Readings	Follow-up Action Required?	n	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 15:59	Distribution	GE Lamp Works Quarterly Inspection	BCH001127	Charger	659-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Switching Operations	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Operations This Read Vac	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Operations Counter AL	188	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Operations Counter AF	188	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Counter Readings	General Comments		
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Mechanism Patrol Inspection	General Comments		
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Counter Readings	LTC As Found Counter	153262	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Counter Readings	LTC As Left Counter	153265	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	LTCC000505	LTCControl	930-Offline-Distribution	LTC Control Insp	General Comments		
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	LTCC000505	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Maintenance Operations	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	LTCC000505	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	123.2	VAC
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Grounds in Place?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	General Comments		
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	LTCC000505	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	124	VAC
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	LTCC000505	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	K0008	BreakerVacuum	451-2120	VCB Readings	9 Month Operations	11	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Fault Operations A Ø	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Fault Operations B Ø	0	
10/22/2020 15:49	Distribution	Joyland Quarterly Inspection	LTCC000505	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	124	VAC
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	216	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	216	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	9.25	%
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	5.14	%
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Fault Operations C Ø	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Fault Operations Ground	0	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Readings	Follow-up Action Required?	n	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	Foundation Condition	Good	
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	KB0082	BreakerVacuum	898-2	VCB Patrol Inspection	General Comments		
10/22/2020 15:33	Distribution	Trafton Avenue Quarterly Inspection	BB0217	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	6.17	%
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	CB0178	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/22/2020 10:10	Distribution	Danville Industrial Quarterly Inspection	C0497	LTCMechanism	451-2	LTC Counter Readings	LTC Current Tap Position	8L	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	All Connections OK?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Bushing Condition	Good	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Cap bank CT in Good Condition?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
10/22/2020 14:54	Distribution	Tip Top Quarterly Inspection	CAP000064	CapacitorBank	TT-Cap Bank 2	Capacitor Patrol Inspection	Capacitor Condition	Good	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	General Comments		
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Operations Counter	133	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	9 Month Operations	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Panels Dusted?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	LTC Current Tap Position	10L	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	General Comments		
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Operations A Ø	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Operations B Ø	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Operations C Ø	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Cleaned Mechanism Cabinet?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	4572	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Operations Ground	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Follow-up Action Required?	n	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Patrol Inspection	General Comments		
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	General Comments		
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Maintenance Operations	0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	LTC Min Tap Position	11L	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1L	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Operations Counter AF	31	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Operations Counter AL	31	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Operations This Read AM	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Switching Operations	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Amps A Ø	59.0	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Amps B Ø	63.0	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Amps C Ø	59.0	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	RC000098	RecloserElectronic	744-0553	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Follow-up Action Required?	n	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Patrol Inspection	General Comments		
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	General Comments		
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Maintenance Operations	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Maintenance Operations	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Operations Counter AF	123	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Operations Counter AL	123	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Operations This Read Vac	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Switching Operations	0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Fault Operations A Ø	0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	18	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	24.05	%
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	21.79	%
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	14.28	%
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	30.0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	30.0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	72.0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Amps C Ø	100.0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Amps B Ø	115.0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	General Comments		
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	952	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	961	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	9	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	9	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Unknown Operations	0	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Tank Paint Condition	Good	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Switching Operations	0	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Operations This Read Vac	0	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Operations Counter AL	205	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Operations Counter AF	205	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Maintenance Operations	0	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Grounds in Place?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	General Comments		
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Evidence of Insects	None	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	SWG000114	Switchgear	ML-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	LTC As Left Counter	516941	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	LTC As Found Counter	516941	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	General Comments		
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN44	LTCMechanism	CB-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Amps A Ø	0.0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Amps B Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Amps C Ø	0.0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	SWG000172	Switchgear	ML-Swgr Sec 6	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Fault Operations A Ø	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Fault Operations B Ø	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Fault Operations C Ø	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Readings	Fault Operations Ground	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Unknown Operations	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB1293	BreakerVacuum	ML-1288	VCB Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Switching Operations	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Fault Operations C Ø	0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Fault Operations B Ø	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Operations This Read Vac	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Operations Counter AL	383	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Operations Counter AF	383	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	General Comments		
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	General Comments		
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	H2 Winding Temp Max	45	°C
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	H2 Winding Temp Present	20	°C
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1700	psi
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	Oil Temp Max	25	°C
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	Oil Temp Present	25	°C
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Patrol Inspection	General Comments		
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Follow-up Action Required?	n	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Vegetation	None	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Counter Readings	LTC As Found Counter	25520	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Counter Readings	LTC As Left Counter	25520	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Counter Readings	LTC Current Tap Position	9L	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Counter Readings	LTC Max Tap Position	15L	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Counter Readings	LTC Min Tap Position	6L	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	480	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Patrol Inspection	General Comments		
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LB1153	BreakerAirMagnetic	WH-1115	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	30	°C
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	30	°C
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	30	°C
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	30	°C
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	60	°C
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	35	°C
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Operations This Read AM	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Operations Counter AL	318	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Operations Counter AF	318	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	X2 Winding Temp Present	50	°C
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	X3 Winding Temp Max	90	°C
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	X3 Winding Temp Present	50	°C
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	BCH000379	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	BCH000379	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	BCH001034	Charger	CB-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	BCH001034	Charger	CB-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	BCH001034	Charger	CB-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	BCH001034	Charger	CB-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	BCH001034	Charger	CB-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.8	VDC
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	BCH001034	Charger	CB-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.8	VDC
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	BCH001034	Charger	CB-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	General Comments		
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	BCH000379	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	BCH000379	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	BCH000379	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	BCH000379	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0134	WithLTC	ML-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	BAT001072	Battery	CB-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0086	LTCMechanism	GR-TRANS 2	LTC Counter Readings	General Comments	LTC IS ON THE LOWER SIDE	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Maintenance Operations	0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Regulator As Left Counter	6093	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Max Tap Position	4L	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	General Comments		
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Current Tap Position	7L	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Regulator As Left Counter	7972	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	General Comments		
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Current Tap Position	6L	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000087	Regulator	731-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	9 Months Operations	5	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Amps A Ø	100.0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Amps B Ø	200.0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Amps C Ø	100.0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0257	GroundTransformer	GR-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0666	BreakerAirMagnetic	ML-1281	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Maintenance Operations	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	General Comments		
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Patrol Inspection	General Comments		
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Follow-up Action Required?	n	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Operations Ground	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Operations C Ø	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Operations B Ø	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Operations A Ø	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Amps C Ø	220.0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Amps B Ø	210.0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Amps A Ø	300.0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Fault Operations Ground	0	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	General Comments		
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0670	BreakerAirMagnetic	ML-1285	AMCB Readings	9 Months Operations	3	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	ST000354	Structure	832-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Regulator As Left Counter	7607	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Max Tap Position	2L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	General Comments		
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Current Tap Position	7L	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000089	Regulator	731-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	RG000088	Regulator	731-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	General Comments		
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	YD000351	Yard	832-Yard	Yard Patrol Inspection	Ambient Temp	75	°F
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Counter Readings	Follow-up Action Required?	n	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	9 Month Operations	4	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	Winding Temp Present	30	°C
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	Winding Temp Max	40	°C
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	Totalizer Meter Reading	.1850	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Counter Readings	General Comments		
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Mechanism Patrol Inspection	General Comments		
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Counter Readings	LTC As Found Counter	34964	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Counter Readings	LTC As Left Counter	34964	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Counter Readings	LTC Current Tap Position	1R	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Counter Readings	LTC Max Tap Position	5R	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Counter Readings	LTC Min Tap Position	7L	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Counter Readings	LTC Operations Since Last Insp	872	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1776.00	kw
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	General Comments		
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Amps B Ø	608.0	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Fault Operations C Ø	0	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Fault Operations B Ø	0	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Fault Operations A Ø	0	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Bushing Condition	Good	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Amps C Ø	85.0	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Amps B Ø	81.0	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Amps A Ø	105.0	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Amps C Ø	620.0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Fault Operations A Ø	0	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Trash Emptied?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	General Comments	3 8ft bulbs out	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Follow-up Action Required?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	9 Months Operations	3	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Patrol Inspection	General Comments		
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Patrol Inspection	Foundation Condition	Good	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Follow-up Action Required?	n	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps C Ø	20.0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	9 Month Operations	2	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Switching Operations	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Operations This Read Vac	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Operations Counter AL	365	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Operations Counter AF	365	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Maintenance Operations	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	General Comments		
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Patrol Inspection	General Comments		
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Follow-up Action Required?	n	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Broom on Site?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	CH000158	ControlHouse	WH-Control House	Control House Patrol Inspection	Control House Lighting OK?	n	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Fault Operations Ground	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Operations Counter	1702	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	General Comments		
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BCH000612	Charger	731-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BCH000612	Charger	731-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BCH000612	Charger	731-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BCH000612	Charger	731-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BCH000612	Charger	731-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BCH000612	Charger	731-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	General Comments		
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Counter Readings	General Comments		
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Counter Readings	LTC As Found Counter	103451	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Counter Readings	LTC As Left Counter	103451	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Counter Readings	LTC Current Tap Position	3L	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	457	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0085	LTCMechanism	GR-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	LTCC000840	LTCControl	847-1	LTC Control Insp	All Connections OK?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	LTCC000840	LTCControl	847-1	LTC Control Insp	Follow-up Action Required?	n	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	LTCC000840	LTCControl	847-1	LTC Control Insp	General Comments		
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	LTCC000840	LTCControl	847-1	LTC Control Insp	LTC Operation Checked?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	LTCC000840	LTCControl	847-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	KT0033	NonLTC	731-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	LTCC000840	LTCControl	847-1	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	LTCC000840	LTCControl	847-1	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	LTCC000840	LTCControl	847-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	Bushing Condition	Good	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Operations A Ø	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Operations B Ø	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Operations C Ø	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Amps C Ø	257.0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Amps B Ø	270.0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Amps A Ø	265.0	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Fault Operations Ground	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps A Ø	20.0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LX0050	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps B Ø	20.0	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	B0402	LTCMechanism	832-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Unknown Operations	0	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Switching Operations	3	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Operations This Read Vac	3	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Operations Counter AL	207	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Operations Counter AF	207	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Maintenance Operations	0	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Patrol Inspection	Grounds in Place?	y	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	General Comments		
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Amps B Ø	55.0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Amps A Ø	53.0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	9 Month Operations	7	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Amps A Ø	27.0	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Amps B Ø	29.0	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Amps C Ø	49.0	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Patrol Inspection	Bushing Condition	Good	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Fault Operations A Ø	0	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Fault Operations B Ø	0	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Fault Operations C Ø	0	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Fault Operations Ground	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	9 Month Operations	0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	LTC As Found Counter	55917	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	LTC As Left Counter	55917	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	LTC Current Tap Position	8L	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	LTC Max Tap Position	3L	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Amps A Ø	0.0	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	9 Month Operations	2	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Unknown Operations	0	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Tank Paint Condition	Good	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	LTC Min Tap Position	10L	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	2970	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN67	LTCMechanism	CB-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Follow-up Action Required?	n	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Patrol Inspection	Foundation Condition	Good	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Patrol Inspection	General Comments		
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Switching Operations	0	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	General Comments		
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	General Comments		
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Amps A Ø	100.0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	Grounds in Place?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	General Comments		
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	General Comments		
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	Foundation Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Follow-up Action Required?	n	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Fault Operations Ground	0	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Foundation Condition	Good	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Follow-up Action Required?	n	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Fault Operations Ground	0	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Fault Operations C Ø	0	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Fault Operations B Ø	0	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Fault Operations A Ø	0	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	General Comments		
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Patrol Inspection	Bushing Condition	Good	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Amps C Ø	0.0	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000423	BreakerVacuum	847-0058	VCB Readings	Amps B Ø	0.0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Switching Operations	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Operations This Read Vac	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Operations Counter AL	230	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Operations Counter AF	230	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Maintenance Operations	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	General Comments		
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Patrol Inspection	General Comments		
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Follow-up Action Required?	n	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Operations Ground	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Operations C Ø	0	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Operations B Ø	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Operations A Ø	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0675	BreakerVacuum	ML-1290	VCB Readings	Amps C Ø	54.0	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Maintenance Operations	0	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Fault Operations A Ø	0	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Fault Operations B Ø	0	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Fault Operations C Ø	0	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Fault Operations Ground	0	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Follow-up Action Required?	n	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Patrol Inspection	Foundation Condition	Good	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Patrol Inspection	General Comments		
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	General Comments		
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Patrol Inspection	Grounds in Place?	y	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Maintenance Operations	0	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Grounds in Place?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	General Comments		
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	General Comments		
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Foundation Condition	Good	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Follow-up Action Required?	n	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Fault Operations Ground	0	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Operations Counter AF	185	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Operations Counter AL	185	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Operations This Read Vac	3	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Switching Operations	3	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Patrol Inspection	Tank Paint Condition	Good	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Unknown Operations	0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	General Comments		
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Operations Counter	70	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LX0049	RecloserHydraulic	GR-GND TR 2	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	SWG000044	Switchgear	WH-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Patrol Inspection	Grounds in Place?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	9 Month Operations	5	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Maintenance Operations	0	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Operations Counter AF	181	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Operations Counter AL	181	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Operations This Read Vac	5	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Switching Operations	5	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Operations This Read Vac	0	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Operations Counter AL	207	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BK000422	BreakerVacuum	847-0010	VCB Readings	Operations Counter AF	207	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	9 Month Operations	12	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Amps A Ø	46.0	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Amps B Ø	24.0	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Amps C Ø	48.0	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Patrol Inspection	Bushing Condition	Good	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Fault Operations A Ø	0	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Fault Operations B Ø	0	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001281	BreakerVacuum	832-0117	VCB Readings	Fault Operations C Ø	0	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Patrol Inspection	Tank Paint Condition	Good	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	FE000541	Fence	731-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Fault Operations C Ø	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001247	BreakerVacuum	GR-14KV TR 2	VCB Readings	Fault Operations B Ø	0	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001098	BreakerVacuum	832-0104	VCB Readings	Unknown Operations	0	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	9 Month Operations	5	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Amps A Ø	113.0	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Amps B Ø	110.0	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Readings	Amps C Ø	115.0	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Patrol Inspection	Bushing Condition	Good	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0678	BreakerVacuum	ML-12KV TR 3	VCB Readings	Amps A Ø	648.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/21/2020 7:48	Distribution	Donerall Quarterly Inspection	BK001099	BreakerVacuum	832-0105	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Maintenance Operations	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Operations Counter AF	351	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Operations Counter AL	351	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Operations This Read Vac	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Switching Operations	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	Tank Paint Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Unknown Operations	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	9 Month Operations	9	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Amps A Ø	187.0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Amps B Ø	200.0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Amps C Ø	190.0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Bushing Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Fault Adjusted Amps A Phase V	12.90	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Fault Adjusted Amps B Phase V	12.90	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Fault Adjusted Amps C Phase V	12.90	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Fault Operations A Ø	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Fault Operations B Ø	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Fault Operations C Ø	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	9 Months Operations	25	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PF000159	PowerFuse	GR-GND TR 1	Disconnect Powerfuse Inspection	General Comments	OK	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PF000160	PowerFuse	GR-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PF000160	PowerFuse	GR-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PF000161	PowerFuse	GR-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PF000161	PowerFuse	GR-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	OK	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Amps A Ø	510.0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Amps B Ø	560.0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Amps C Ø	560.0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Readings	General Comments		
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Readings	Oil Temp Max	47	°C
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Readings	Oil Temp Present	25	°C
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	General Comments		
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Ambient Temp	64	°F
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	General Comments		
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Vegetation	None	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	YD000636	Yard	CB-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Unknown Operations	0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Switching Operations	0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Operations This Read AM	0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Operations Counter AL	326	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Operations Counter AF	326	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Maintenance Operations	0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	General Comments		
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Patrol Inspection	General Comments		
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Follow-up Action Required?	n	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Fault Operations Ground	0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Fault Operations C ∅	0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Fault Operations B ∅	0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Fault Operations A ∅	0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Amps C ∅	0.0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Amps B ∅	0.0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	Amps A ∅	0.0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0249	BreakerAirMagnetic	CB-SEC 2 SPARE	AMCB Readings	9 Months Operations	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	Bushing Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Fault Operations A ∅	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Fault Operations B ∅	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Fault Operations C ∅	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Fault Operations Ground	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Follow-up Action Required?	n	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	Foundation Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	General Comments		
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	General Comments		
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	Grounds in Place?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Operations Counter AF	237	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Maintenance Operations	0	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Switching Operations	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Tank Paint Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Unknown Operations	1	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Grounds in Place?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	General Comments		
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	General Comments		
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	9 Months Operations	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Amps A Ø	250.0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Amps B Ø	200.0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Amps C Ø	190.0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Fault Operations A Ø	0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Fault Operations B Ø	0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Fault Operations C Ø	0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Fault Operations Ground	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	Bushing Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Follow-up Action Required?	n	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Patrol Inspection	General Comments		
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	General Comments		
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Maintenance Operations	0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Operations Counter AF	274	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Operations Counter AL	274	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Operations This Read AM	0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Switching Operations	0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0246	BreakerAirMagnetic	CB-4	AMCB Readings	Unknown Operations	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	Cleaned Mechanism Cabinet?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	Foundation Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	General Comments		
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	Grounds in Place?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	Tank Leaks	None	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0258	GroundTransformer	GR-GND TR 2	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Foundation Condition	Good	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Follow-up Action Required?	n	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Fault Operations Ground	0	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Fault Operations C Ø	0	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Fault Operations B Ø	0	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Fault Operations A Ø	0	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Bushing Condition	Good	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Amps C Ø	33.0	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Amps B Ø	30.0	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Amps A Ø	25.0	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN67	WithLTC	CB-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Operations A Ø	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Operations B Ø	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Operations C Ø	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Fault Operations Ground	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Follow-up Action Required?	n	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Patrol Inspection	General Comments		
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	General Comments		
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Maintenance Operations	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Operations Counter AF	390	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Operations Counter AL	390	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Operations This Read AM	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0668	BreakerAirMagnetic	ML-1283	AMCB Readings	Switching Operations	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Readings	General Comments		
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	General Comments	NEEDS NIT	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Readings	LV Winding Temp Max	70	°C
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Readings	LV Winding Temp Present	50	°C
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Readings	Oil Temp Max	60	°C
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Readings	Oil Temp Present	45	°C
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	75.00	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0086	WithLTC	GR-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Follow-up Action Required?	n	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Foundation Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	General Comments		
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	General Comments		
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Grounds in Place?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Maintenance Operations	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Operations Counter AF	355	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Operations Counter AL	355	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Readings	Operations This Read Vac	1	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Unknown Operations	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001181	BreakerVacuum	GR-1463	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Patrol Inspection	Tank Paint Condition	Good	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Switching Operations	0	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Operations This Read Vac	0	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	Operations Counter AL	237	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Foundation Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Follow-up Action Required?	n	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Fault Operations Ground	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Fault Operations C Ø	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Fault Operations B Ø	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Fault Operations A Ø	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Bushing Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Amps C Ø	104.0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Amps B Ø	109.0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Amps A Ø	108.0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	9 Month Operations	58	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Unknown Operations	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	Tank Paint Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Switching Operations	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Operations This Read Vac	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Operations Counter AL	356	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Operations Counter AF	356	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Maintenance Operations	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	Grounds in Place?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	General Comments		
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	General Comments		
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	Foundation Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Follow-up Action Required?	n	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Fault Operations Ground	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Fault Operations C Ø	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Fault Operations B Ø	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Fault Operations A Ø	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Maintenance Operations	0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Operations Counter AF	485	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Operations Counter AL	485	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Operations This Read AM	0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Switching Operations	0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Unknown Operations	0	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LTCC000182	LTCControl	WH-TRANS 3	LTC Control Insp	General Comments		
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LTCC000182	LTCControl	WH-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LTCC000182	LTCControl	WH-TRANS 3	LTC Control Insp	All Connections OK?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	9 Month Operations	0	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	Seeping	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	Seeping	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PF000154	PowerFuse	GR-GND TR 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PF000154	PowerFuse	GR-GND TR 2	Disconnect Powerfuse Inspection	General Comments	OK	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PF000155	PowerFuse	GR-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Fault Operations A Ø	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Fault Operations B Ø	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Fault Operations C Ø	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Fault Operations Ground	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Follow-up Action Required?	n	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Foundation Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	General Comments		
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	General Comments		
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Grounds in Place?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Maintenance Operations	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Operations Counter AF	339	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Operations Counter AL	339	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Operations This Read Vac	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Switching Operations	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Tank Paint Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Unknown Operations	0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	9 Months Operations	1	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Amps A Ø	250.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Amps B Ø	220.0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Amps C Ø	240.0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Fault Operations A Ø	0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Fault Operations B Ø	0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Fault Operations C Ø	0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Fault Operations Ground	0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	Follow-up Action Required?	n	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Patrol Inspection	General Comments		
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Readings	General Comments		
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0244	BreakerAirMagnetic	CB-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Patrol Inspection	Bushing Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Amps C Ø	117.0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Amps B Ø	120.0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Amps A Ø	116.0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001179	BreakerVacuum	GR-1465	VCB Readings	9 Month Operations	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Unknown Operations	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Tank Paint Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Switching Operations	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Operations This Read Vac	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Operations Counter AL	369	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Operations Counter AF	369	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	Maintenance Operations	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	Grounds in Place?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Readings	General Comments		
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001178	BreakerVacuum	GR-1464	VCB Patrol Inspection	General Comments		
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	888	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	LTC Min Tap Position	9L	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	LTC Max Tap Position	2R	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	LTC Current Tap Position	7L	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	LTC As Left Counter	79086	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Bushing Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Amps C Ø	185.0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Amps B Ø	195.0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Amps A Ø	190.0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	9 Month Operations	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	LTC As Found Counter	79086	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	General Comments		
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	9 Month Operations	5	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Amps A Ø	200.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Amps B Ø	200.0	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Amps C Ø	200.0	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Bushing Condition	Good	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Amps B Ø	80.0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Amps C Ø	78.0	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Fault Operations A Ø	0	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Fault Operations B Ø	0	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Fault Operations C Ø	0	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Fault Operations Ground	0	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Follow-up Action Required?	n	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Foundation Condition	Good	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	General Comments		
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	General Comments		
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Grounds in Place?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Maintenance Operations	0	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Operations Counter AF	401	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Operations Counter AL	401	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Operations This Read Vac	0	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Switching Operations	0	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Patrol Inspection	Tank Paint Condition	Good	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	K0057	BreakerVacuum	847-0005	VCB Readings	Unknown Operations	0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	FE000632	Fence	CB-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001180	BreakerVacuum	GR-1462	VCB Readings	Amps A Ø	91.0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PF000155	PowerFuse	GR-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PF000157	PowerFuse	GR-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PF000157	PowerFuse	GR-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PF000159	PowerFuse	GR-GND TR 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Patrol Inspection	Bushing Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Amps C Ø	0.0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Amps B Ø	0.0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Amps A Ø	0.0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001177	BreakerVacuum	GR-14KV BUS TIE	VCB Readings	9 Month Operations	7	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Unknown Operations	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Tank Paint Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Switching Operations	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Operations This Read Vac	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Operations Counter AL	323	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Operations Counter AF	323	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Maintenance Operations	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Grounds in Place?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	General Comments		
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	General Comments		
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Foundation Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Follow-up Action Required?	n	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Fault Operations Ground	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Fault Operations B Ø	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Fault Operations A Ø	0	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Readings	Oil Temp Present	30	°C
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Readings	Oil Temp Max	60	°C
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001176	BreakerVacuum	GR-1466	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	General Comments	oil seeping from radiator and fitting, pic sent to stinson	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Readings	General Comments		
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0223	WithLTC	WH-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0134	LTCMechanism	ML-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	PF000426	PowerFuse	Retired Distribution	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	PF000426	PowerFuse	Retired Distribution	Disconnect Powerfuse Inspection	General Comments	ok	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	PF000248	PowerFuse	ML-STA SER NO 3	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	PF000248	PowerFuse	ML-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	PF000248	PowerFuse	ML-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	PF000249	PowerFuse	ML-STA SER NO 6	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	PF000249	PowerFuse	ML-STA SER NO 6	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	PF000249	PowerFuse	ML-STA SER NO 6	Disconnect Powerfuse Inspection	General Comments	ok	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	PF000250	PowerFuse	ML-12KV TR 3 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	PF000250	PowerFuse	ML-12KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	PF000250	PowerFuse	ML-12KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	PF000252	PowerFuse	ML-STA SER NO 4	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	731-2100	0	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Patrol Inspection	Tank Paint Condition	Good	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Switching Operations	0	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Operations This Read Vac	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	PF000252	PowerFuse	ML-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	PF000252	PowerFuse	ML-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	ok	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PF000156	PowerFuse	GR-14KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PF000156	PowerFuse	GR-14KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	PF000427	PowerFuse	Retired Distribution	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	PF000427	PowerFuse	Retired Distribution	Disconnect Powerfuse Inspection	General Comments	ok	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PF000158	PowerFuse	GR-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PF000158	PowerFuse	GR-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	PF000425	PowerFuse	WH-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	PF000425	PowerFuse	WH-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Amps C Ø	6.0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Amps B Ø	4.0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Amps A Ø	7.0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Accumulated Fault Duty C Ph V	3.45	%
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Accumulated Fault Duty B Ph V	5.29	%
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Accumulated Fault Duty A Ph V	3.45	%
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	9 Month Operations	1	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	Follow-up Action Required?	n	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	General Comments		
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	General Comments		
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Counter Readings	LTC Operations Since Last Insp	717	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Counter Readings	LTC Min Tap Position	1R	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Counter Readings	LTC Max Tap Position	7L	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Counter Readings	LTC Current Tap Position	6L	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Fault Operations C Ø	0	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Fault Operations Ground	0	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Follow-up Action Required?	n	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	Foundation Condition	Good	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LTCC000387	LTCControl	WH-TRANS 2	LTC Control Insp	All Connections OK?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	General Comments		
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	General Comments		
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Unknown Operations	0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Switching Operations	1	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Operations This Read Vac	1	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Operations Counter AL	125	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Operations Counter AF	125	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Maintenance Operations	0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	General Comments		
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	SWG000061	Switchgear	CB-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	Grounds in Place?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Maintenance Operations	0	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Operations Counter AF	168	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Operations Counter AL	168	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Operations This Read Vac	0	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Switching Operations	0	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	Tank Paint Condition	Good	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Unknown Operations	0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Follow-up Action Required?	n	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Fault Operations Ground	0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Fault Operations C Ø	0	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	General Comments		
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Fault Operations B Ø	0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Fault Operations A Ø	0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	General Comments		
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Patrol Inspection	Grounds in Place?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	General Comments		
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Patrol Inspection	General Comments		
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Patrol Inspection	Foundation Condition	Good	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Follow-up Action Required?	n	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Fault Operations Ground	0	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Fault Operations C Ø	0	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Fault Operations B Ø	0	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Fault Operations A Ø	0	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Patrol Inspection	Bushing Condition	Good	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Amps C Ø	13.0	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Amps B Ø	26.0	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Amps A Ø	22.0	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	9 Month Operations	2	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Battery Bank Volts	27.0	VDC
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Battery Bank Amps	0.0	AMPS
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	75	*F
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BAT000853	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	FE000859	Fence	832-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	PF000251	PowerFuse	ML-12KV TR 6 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	General Comments		
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Vegetation	None	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	Oil Temp Max	75	°C
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	Oil Temp Present	45	°C
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	X1 Winding Temp Max	80	°C
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	X1 Winding Temp Present	45	°C
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LT0133	WithLTC	ML-TRANS 6	LTC Transformer Readings	X2 Winding Temp Max	90	°C
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Counter Readings	LTC As Left Counter	22212	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Counter Readings	LTC As Found Counter	22210	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Mechanism Patrol Inspection	General Comments		
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BAT001188	Battery	731-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Counter Readings	General Comments		
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	M0097	LTCMechanism	744-1	LTC Counter Readings	Follow-up Action Required?	n	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	PF000251	PowerFuse	ML-12KV TR 6 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	PF000251	PowerFuse	ML-12KV TR 6 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	946	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Counter Readings	LTC Min Tap Position	4L	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Counter Readings	LTC Max Tap Position	1L	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Counter Readings	LTC Current Tap Position	2L	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Counter Readings	LTC As Left Counter	298544	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Counter Readings	LTC As Found Counter	298544	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Counter Readings	General Comments		
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PN57	LTCMechanism	GR-CLASS-B TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	General Comments		
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	ST000358	Structure	745-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Ambient Temp	75	*F
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	YD000355	Yard	745-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Operations Counter AL	182	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Operations Counter AF	182	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001144	BreakerVacuum	731-2100	VCB Readings	Maintenance Operations	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Fault Operations A Ø	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Fault Operations B Ø	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Fault Operations C Ø	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Fault Operations Ground	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Follow-up Action Required?	n	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Foundation Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	General Comments		
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	General Comments		
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Grounds in Place?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Maintenance Operations	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Operations Counter AF	377	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Operations Counter AL	377	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Operations This Read Vac	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Switching Operations	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Tank Paint Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Unknown Operations	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	9 Months Operations	7	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Amps A Ø	640.0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Amps B Ø	640.0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Amps C Ø	630.0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Fault Operations A Ø	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Fault Operations B Ø	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Fault Operations C Ø	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Patrol Inspection	General Comments		
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Follow-up Action Required?	n	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Operations Ground	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Operations C Ø	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Operations B Ø	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Operations A Ø	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Amps C Ø	410.0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Fault Operations Ground	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Follow-up Action Required?	n	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Patrol Inspection	General Comments		
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	General Comments		
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Maintenance Operations	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Amps B Ø	500.0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Amps A Ø	410.0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	9 Months Operations	10	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Unknown Operations	0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Switching Operations	0	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0096	BreakerVacuum	745-0019	VCB Readings	9 Month Operations	0	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BCH000876	Charger	847-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BCH000876	Charger	847-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BCH000876	Charger	847-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BCH000876	Charger	847-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BCH000876	Charger	847-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BCH000876	Charger	847-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BCH000876	Charger	847-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	General Comments		
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	FE000606	Fence	WH-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	9 Month Operations	7	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Amps A Ø	378.0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Amps B Ø	380.0	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	General Comments	yard light by TR 3 not working need small bucket	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Readings	Amps C Ø	375.0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	BK001188	BreakerVacuum	GR-14KV TR 1	VCB Patrol Inspection	Bushing Condition	Good	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Vegetation	None	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	YD000609	Yard	WH-Yard	Yard Patrol Inspection	Yard Lights Working?	n	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	General Comments		
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	ST000599	Structure	WH-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Switching Operations	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Operations This Read AM	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Operations Counter AL	61	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Operations Counter AF	61	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	Maintenance Operations	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0669	BreakerAirMagnetic	ML-1284	AMCB Readings	General Comments		
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	LTC Totalizer Reading	2788.80	kw

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	General Comments		
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	General Comments		
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	LV Winding Temp Present	30	°C
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	Oil Temp Max	52	°C
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	Oil Temp Present	28	°C
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Amps C Ø	36.0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Amps B Ø	33.0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Amps A Ø	34.0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Accumulated Fault Duty C Ph V	3.91	%
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Accumulated Fault Duty B Ph V	2.53	%
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Accumulated Fault Duty A Ph V	2.99	%
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	9 Month Operations	18	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LTCC000387	LTCControl	WH-TRANS 2	LTC Control Insp	General Comments		
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LTCC000387	LTCControl	WH-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0224	WithLTC	WH-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	9 Month Operations	1	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Amps A Ø	54.0	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Amps B Ø	73.0	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Amps C Ø	40.0	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	Bushing Condition	Good	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Fault Operations A Ø	0	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	BK001263	BreakerVacuum	WH-1116	VCB Readings	Fault Operations B Ø	0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Operations This Read Vac	0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Operations Counter AL	67	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Operations Counter AF	67	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Maintenance Operations	0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	General Comments		
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Follow-up Action Required?	n	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Fault Operations Ground	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Operations This Read Vac	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Operations Counter AL	399	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Operations Counter AF	399	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Maintenance Operations	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	General Comments		
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Patrol Inspection	General Comments		
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Follow-up Action Required?	n	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Operations Ground	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Operations C Ø	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Operations B Ø	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Operations A Ø	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Amps C Ø	236.0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Amps B Ø	247.0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Amps A Ø	257.0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0672	BreakerVacuum	ML-1287	VCB Readings	9 Month Operations	0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Fault Operations C Ø	0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Fault Operations B Ø	0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Fault Operations A Ø	0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	General Comments		
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	PN44	WithLTC	CB-TRANS 1	LTC Transformer Readings	LV Winding Temp Max	70	°C
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Operations Counter AF	558	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Operations Counter AL	558	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Operations This Read AM	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0679	BreakerAirMagnetic	ML-12KV TR 6	AMCB Readings	Switching Operations	0	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	Totalizer Meter Reading	.5810	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	Oil Temp Present	37	°C
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Readings	Oil Temp Max	37	°C
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	M0097	WithLTC	744-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Readings	General Comments		
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Readings	LV Winding Temp Max	65	°C
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Readings	LV Winding Temp Present	50	°C
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Readings	General Comments		
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	General Comments	NEEDS NIT	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	8	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	16	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	140	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	130	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	2	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C ∅	2	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B ∅	2	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A ∅	2	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	9.37	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	9.37	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	9.37	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Amps C ∅	84.0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Amps B ∅	84.0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Amps A ∅	72.0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	26.3	%
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	22.55	%
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	15.78	%
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	37	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	LTC Current Tap Position	10L	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Readings	Oil Temp Max	50	°C
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Readings	Oil Temp Present	35	°C
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Max Tap Position	4R	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	General Comments		
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Regulator As Left Counter	9270	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	General Comments		
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	SWG000048	Switchgear	CB-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	260.00	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LT0085	WithLTC	GR-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Operations Counter	255	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	General Comments		
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Amps C Ø	59.0	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Amps B Ø	63.0	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	X0304	RecloserElectronic	744-0153	Recloser Electronic Patrol Inspection	Amps A Ø	59.0	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Regulator As Left Counter	10853	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000050	Regulator	745-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	General Comments		
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	9 Month Operations	2	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Amps A Ø	124.0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Amps B Ø	118.0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Amps C Ø	112.0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	FE000813	Fence	847-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Operations A Ø	0	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Operations B Ø	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Operations C Ø	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Fault Operations Ground	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Follow-up Action Required?	n	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Patrol Inspection	General Comments		
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	General Comments		
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Maintenance Operations	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Operations Counter AF	586	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Switching Operations	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Operations This Read Vac	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Operations Counter AL	366	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Operations Counter AF	366	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Maintenance Operations	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	General Comments		
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Patrol Inspection	General Comments		
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Follow-up Action Required?	n	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Operations Ground	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Operations C Ø	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Operations B Ø	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Operations A Ø	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Amps C Ø	36.0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Amps B Ø	44.0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Amps A Ø	43.0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0674	BreakerVacuum	ML-1289	VCB Readings	9 Month Operations	4	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Unknown Operations	0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Switching Operations	0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Operations This Read AM	0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Operations Counter AL	408	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Operations Counter AF	408	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Maintenance Operations	0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	General Comments		
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Patrol Inspection	General Comments		
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Follow-up Action Required?	n	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Fault Operations Ground	0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Fault Operations C Ø	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Fault Operations B Ø	0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Fault Operations A Ø	0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Amps C Ø	20.0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Amps B Ø	20.0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Amps A Ø	20.0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Amps B Ø	0.0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Amps C Ø	0.0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Fault Operations A Ø	0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Fault Operations B Ø	0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Fault Operations C Ø	0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Fault Operations Ground	0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Follow-up Action Required?	n	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Patrol Inspection	General Comments		
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	General Comments		
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Maintenance Operations	0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Operations Counter AF	336	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Operations Counter AL	336	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Operations This Read AM	0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Switching Operations	0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Unknown Operations	0	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	BCH001174	Charger	745-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	BCH001174	Charger	745-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	BCH001174	Charger	745-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	BCH001174	Charger	745-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	BCH001174	Charger	745-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	BCH001174	Charger	745-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	BCH001174	Charger	745-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	BCH001174	Charger	745-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0245	BreakerAirMagnetic	CB-3	AMCB Readings	9 Months Operations	0	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	PN57	WithLTC	GR-CLASS-B TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Operations Counter AL	586	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Operations This Read Vac	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0671	BreakerVacuum	ML-1286	VCB Readings	Switching Operations	0	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	LTCC000641	LTCControl	744-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	LTCC000641	LTCControl	744-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	LTCC000641	LTCControl	744-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	LTCC000641	LTCControl	744-1	LTC Control Insp	LTC Output Voltage Level	123.4	VAC
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	LTCC000641	LTCControl	744-1	LTC Control Insp	LTC Operation Checked?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	LTCC000641	LTCControl	744-1	LTC Control Insp	General Comments		
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	LTCC000641	LTCControl	744-1	LTC Control Insp	Follow-up Action Required?	n	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	LTCC000641	LTCControl	744-1	LTC Control Insp	All Connections OK?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	General Comments		
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	BAT001225	Battery	745-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	Follow-up Action Required?	n	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	General Comments		
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Mechanism Patrol Inspection	General Comments		
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	LTC As Found Counter	18346	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	LTC As Left Counter	18346	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Ambient Temp	75	*F
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	General Comments		
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	YD000342	Yard	847-Yard	Yard Patrol Inspection	Vegetation	None	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	9 Months Operations	0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0248	BreakerAirMagnetic	CB-SEC 1 SPARE	AMCB Readings	Amps A Ø	0.0	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9140	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	LTC Max Tap Position	1R	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	LTC Min Tap Position	11L	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Amps B Ø	37.0	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Amps C Ø	51.0	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Patrol Inspection	Bushing Condition	Good	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	LTC Operations Since Last Insp	1132	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	General Comments		
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	9 Month Operations	2	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Amps A Ø	176.0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Amps B Ø	165.0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Amps C Ø	161.0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Operations A Ø	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Operations B Ø	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Operations C Ø	0	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	Totalizer Meter Reading	.7180	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Amps C Ø	380.0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Amps B Ø	340.0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Amps A Ø	340.0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	9 Months Operations	7	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	Oil Temp Present	30	°C
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	Oil Temp Max	50	°C
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	LTC Totalizer Reading	6892.80	kw
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	General Comments		
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	General Comments		
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	B0402	WithLTC	832-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	9 Month Operations	0	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Amps A Ø	38.0	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Fault Operations A Ø	0	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Fault Operations B Ø	0	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Fault Operations C Ø	0	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Fault Operations Ground	0	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Follow-up Action Required?	n	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Patrol Inspection	Foundation Condition	Good	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LTCM000039	LTCMechanism	ML-TRANS 6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	General Comments		
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Patrol Inspection	General Comments		
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	General Comments		
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Patrol I Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Maintenance Operations	0	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	BAT001023	Battery	WH-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Unknown Operations	0	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Patrol Inspection	Tank Paint Condition	Good	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Switching Operations	0	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Operations This Read Vac	0	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Operations Counter AL	147	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Operations Counter AF	147	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Fault Operations Ground	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Follow-up Action Required?	n	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Patrol Inspection	General Comments		
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Maintenance Operations	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Operations Counter AF	572	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Operations Counter AL	572	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Operations This Read Vac	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0673	BreakerVacuum	ML-1291	VCB Readings	Switching Operations	0	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Fault Operations A Ø	0	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Fault Operations B Ø	0	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Fault Operations C Ø	0	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Fault Operations Ground	0	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Follow-up Action Required?	n	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Patrol Inspection	Foundation Condition	Good	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Patrol Inspection	General Comments		
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	General Comments		
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Patrol Inspection	Grounds in Place?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Maintenance Operations	0	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Operations Counter AF	195	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Operations Counter AL	195	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	BAT000965	Battery	847-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	*F
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Operations This Read Vac	0	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Switching Operations	0	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Patrol Inspection	Tank Paint Condition	Good	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001593	BreakerVacuum	731-2101	VCB Readings	Unknown Operations	0	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	9 Month Operations	2	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Amps A Ø	11.0	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Amps B Ø	19.0	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Readings	Amps C Ø	12.0	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Patrol Inspection	Bushing Condition	Good	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	BK001594	BreakerVacuum	731-2102	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Counter Readings	General Comments		
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	General Comments		
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	9 Month Operations	11	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Amps A Ø	0.0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Amps B Ø	0.0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Amps C Ø	0.0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Operations A Ø	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Operations B Ø	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Operations C Ø	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Fault Operations Ground	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	Follow-up Action Required?	n	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Follow-up Action Required?	n	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Patrol Inspection	General Comments		
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	Totalizer Meter Reading	.3470	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000049	Regulator	745-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	General Comments		
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	FE000468	Fence	745-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1052	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Counter Readings	LTC Min Tap Position	14L	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Counter Readings	LTC Max Tap Position	1L	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Counter Readings	LTC Current Tap Position	12L	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Counter Readings	LTC As Left Counter	14404	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Counter Readings	LTC As Found Counter	14404	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Counter Readings	General Comments		
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0224	LTCMechanism	WH-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	693	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Counter Readings	LTC Min Tap Position	14L	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Counter Readings	LTC Max Tap Position	5L	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Counter Readings	LTC Current Tap Position	13L	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Regulator As Left Counter	10452	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	RG000048	Regulator	745-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Counter Readings	LTC As Left Counter	30104	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Counter Readings	LTC As Found Counter	30104	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LT0223	LTCMechanism	WH-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	General Comments		
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Maintenance Operations	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AF	341	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AL	341	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Operations This Read Vac	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0676	BreakerVacuum	ML-12KV BUS TIE SEC 3	VCB Readings	Switching Operations	0	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	100.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2193.60	kw
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	General Comments		
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	General Comments		
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Switching Operations	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Operations This Read AM	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Operations Counter AL	596	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Operations Counter AF	596	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Maintenance Operations	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	General Comments		
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Patrol Inspection	General Comments		
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Follow-up Action Required?	n	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Operations Ground	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Operations C Ø	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Operations B Ø	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Operations A Ø	0	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/21/2020 11:58	Distribution	Mud Lane Quarterly Inspection	LB0667	BreakerAirMagnetic	ML-1282	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	B0282	NonLTC	745-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	Oil Temp Present	40	°C
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	Oil Temp Max	50	°C
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	LTC Totalizer Reading	2776.00	kw
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	General Comments		
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	General Comments		
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	B0411	WithLTC	847-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	General Comments		
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Mechanism Patrol Inspection	General Comments		
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	LTC As Found Counter	27072	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	LTC As Left Counter	27072	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	LTC Current Tap Position	6L	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	LTC Max Tap Position	1L	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	LTC Min Tap Position	8L	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	LTC Operations Since Last Insp	597	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	B0411	LTCMechanism	847-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	General Comments		
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	General Comments		
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Grounds in Place?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Maintenance Operations	0	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Operations Counter AF	373	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Operations Counter AL	373	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Vegetation	None	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	YD000459	Yard	744-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Vegetation	None	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Operations This Read Vac	0	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Switching Operations	0	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Tank Paint Condition	Good	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Unknown Operations	0	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Amps A Ø	102.0	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Amps B Ø	82.0	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Amps C Ø	90.0	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Bushing Condition	Good	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Amps B Ø	0.0	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Amps A Ø	0.0	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Fault Operations A Ø	0	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Fault Operations B Ø	0	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Fault Operations C Ø	0	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Fault Operations Ground	0	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Follow-up Action Required?	n	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	Foundation Condition	Good	
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Patrol Inspection	General Comments		
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	General Comments		
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/21/2020 7:48	Distribution	Donerail Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	General Comments		
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	BCH000122	Charger	WH-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	BCH000122	Charger	WH-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	BCH000122	Charger	WH-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	BCH000122	Charger	WH-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	BCH000122	Charger	WH-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	5.0	amps
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	BCH000122	Charger	WH-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.6	VDC
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	BCH000122	Charger	WH-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.6	VDC
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	BCH000122	Charger	WH-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	7.500	millivolts
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	9 Months Operations	0	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	FE000453	Fence	744-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	General Comments		
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Interrupters/Puffrs Visual OK?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Tank Leaks	None	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Tank Oil Level	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Tank Paint Condition	Good	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	LTCC000079	LTCControl	832-1	LTC Control Insp	All Connections OK?	y	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	LTCC000079	LTCControl	832-1	LTC Control Insp	Follow-up Action Required?	n	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	LTCC000079	LTCControl	832-1	LTC Control Insp	General Comments		
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Readings	Unknown Operations	0	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	LTCC000079	LTCControl	832-1	LTC Control Insp	LTC Operation Checked?	y	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	LTCC000079	LTCControl	832-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	LTCC000079	LTCControl	832-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	LTCC000079	LTCControl	832-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	LTCC000079	LTCControl	832-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	LTCC000079	LTCControl	832-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	General Comments		
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 16:33	Distribution	Shelby City Quarterly Inspection	ST000461	Structure	744-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Readings	Fault Operations	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Readings	Follow-up Action Required?	n	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	ST000551	Structure	731-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Foundation Condition	Good	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	General Comments		
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Readings	General Comments		
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Grounds in Place?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Readings	Maintenance Operations	0	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Readings	Number of Ops last 9 Months	10	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Readings	Operations Counter AF	2775	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Readings	Operations Counter AL	2775	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Readings	Operations This Read Oil	0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	General Comments		
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/21/2020 10:49	Distribution	Grady Quarterly Inspection	LB0419	BreakerOil	GR-GND TR 1	OCB Readings	Switching Operations	0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	CH000440	ControlHouse	CB-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Operations Counter AF	493	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Operations Counter AL	493	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Operations This Read AM	0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Switching Operations	0	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Unknown Operations	0	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Switching Operations	0	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Operations This Read AM	0	
10/21/2020 9:22	Distribution	Crop Quarterly Inspection	LB0243	BreakerAirMagnetic	CB-1	AMCB Readings	Unknown Operations	0	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Fault Operations B Ø	0	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Fault Operations C Ø	0	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Fault Operations Ground	0	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Follow-up Action Required?	n	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Patrol Inspection	General Comments		
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	General Comments		
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Maintenance Operations	0	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Operations Counter AF	1342	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Ambient Temp	70	*F
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Operations Counter AL	1342	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 16:46	Distribution	Atoka Quarterly Inspection	YD000548	Yard	731-Yard	Yard Patrol Inspection	General Comments		
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	General Comments		
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/21/2020 8:07	Distribution	Buchanan Quarterly Inspection	ST000345	Structure	847-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/21/2020 8:15	Distribution	Kunkel Quarterly Inspection	K0097	BreakerVacuum	745-0026	VCB Readings	9 Month Operations	3	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Amps C Ø	0.0	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/26/2020 6:44	Distribution	WHAS Quarterly Inspection	LB1152	BreakerAirMagnetic	WH-1114	AMCB Readings	Fault Operations A Ø	0	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	*F
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/21/2020 7:48	Distribution	Doneraill Quarterly Inspection	BAT000996	Battery	832-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Operations Counter AL	8	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Operations Counter AF	8	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Maintenance Operations	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	General Comments	Actual counter, offline	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Patrol Inspection	General Comments		
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	385.0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	391.0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	408.0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	9 Month Operations	9	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	General Comments		
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Follow-up Action Required?	n	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Fault Operations Ground	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Fault Operations C Ø	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Fault Operations B Ø	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Fault Operations A Ø	0	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Tank Leaks	None	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	General Comments		
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	General Comments		
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	6854.40	kw
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Unknown Operations	1	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	9 Month Operations	2	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Unknown Operations	0	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Tank Paint Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Switching Operations	0	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Amps A Ø	0.0	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Operations This Read Vac	0	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Current Tap Position	1L	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Switching Operations	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Operations This Read Vac	1	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Operations Counter AL	123	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Operations Counter AF	123	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Follow-up Action Required?	n	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Fault Operations Ground	0	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Fault Operations C Ø	0	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Fault Operations B Ø	0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	Follow-up Action Required?	n	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Fault Operations A Ø	0	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	Follow-up Action Required?	n	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	General Comments		
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	General Comments		
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	LTC Totalizer Reading	5846.40	kw
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	9 Month Operations	5	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Amps A Ø	69.0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	Oil Temp Max	41	°C
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	Oil Temp Present	31	°C
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol I Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Bushing Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Amps B Ø	0.0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Amps C Ø	0.0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	Winding Temp Present	19	°C
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	Winding Temp Max	19	°C
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Amps B Ø	170.0	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Amps C Ø	170.0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Readings	Totalizer Meter Reading	.6090	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	Totalizer Meter Reading	.7140	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	Winding Temp Max	60	°C
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	Winding Temp Present	40	°C
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Max Tap Position	3R	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Min Tap Position	10L	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Regulator As Left Counter	15742	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	9 Month Operations	8	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Amps A Ø	180.0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	Oil Temp Present	30	°C
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	Oil Temp Max	40	°C
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	PF000266	PowerFuse	OX-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	PF000266	PowerFuse	OX-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	PF000268	PowerFuse	OX-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	PF000268	PowerFuse	OX-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	LTC Totalizer Reading	3254.40	kw
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	General Comments		
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	General Comments		
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0023	WithLTC	158-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	Maintenance Operations	0	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Grounds in Place?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Readings	General Comments		
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	General Comments		
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0276	BreakerVacuum	874-2235	VCB Patrol Inspection	Foundation Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Switching Operations	1	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Operations This Read Vac	1	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Operations Counter AL	171	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Operations Counter AF	170	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Maintenance Operations	0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Patrol Inspection	Grounds in Place?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	General Comments		
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Patrol Inspection	General Comments		
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Patrol Inspection	Foundation Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Follow-up Action Required?	n	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Fault Operations Ground	0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Fault Operations C Ø	0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Fault Operations B Ø	0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Fault Operations A Ø	0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Patrol Inspection	Bushing Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Amps C Ø	79.0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Amps B Ø	89.0	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	BCH001311	Charger	874-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	BCH001311	Charger	874-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	9 Month Operations	12	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Amps A Ø	192.0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Amps B Ø	240.0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	54.00	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Amps C Ø	240.0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Bushing Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Amps C Ø	0.0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Amps B Ø	0.0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Amps A Ø	0.0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Unknown Operations	0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	General Comments		
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Fault Operations A Ø	0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Fault Operations B Ø	0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Fault Operations A Ø	0	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Fault Operations B Ø	0	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Fault Operations C Ø	0	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Fault Operations Ground	0	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Follow-up Action Required?	n	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Foundation Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	General Comments		
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	General Comments		
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Grounds in Place?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	906	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Counter Readings	LTC Min Tap Position	10L	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Counter Readings	LTC Max Tap Position	Neutral	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Counter Readings	LTC Current Tap Position	6L	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Counter Readings	LTC As Left Counter	99146	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Counter Readings	LTC As Found Counter	99146	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Counter Readings	General Comments		
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Amps B Ø	0.0	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	9 Month Operations	4	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Amps A Ø	50.0	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Amps B Ø	50.0	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Amps C Ø	45.0	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Patrol Inspection	Bushing Condition	Good	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Amps A Ø	0.0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	9 Month Operations	15	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Unknown Operations	2	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Switching Operations	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Operations This Read Vac	2	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Operations Counter AL	257	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Operations Counter AF	257	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Maintenance Operations	0	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Operations Counter AF	287	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Operations Counter AL	287	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Operations This Read Vac	0	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Switching Operations	0	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Tank Paint Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Maintenance Operations	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	General Comments	offline	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Patrol Inspection	General Comments		
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Fault Operations Ground	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	54.00	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	54.00	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Readings	Unknown Operations	0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK001339	BreakerVacuum	158-0660	VCB Patrol Inspection	Tank Paint Condition	Good	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	66	*F
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Amps C Ø	0.0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Fault Adjusted Amps A Phase V	33.54	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Fault Adjusted Amps B Phase V	33.54	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Fault Adjusted Amps C Phase V	33.54	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	Totalizer Meter Reading	.6162	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Fault Operations A Ø	0	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Tank Leaks	None	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Regulator As Left Counter	14306	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Fault Operations B Ø	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Fault Operations C Ø	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Fault Operations Ground	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Follow-up Action Required?	n	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Patrol Inspection	General Comments		
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	General Comments	Actual counter, Offline	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Maintenance Operations	0	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Operations Counter AF	235	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Operations Counter AL	235	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Operations This Read Vac	3	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Switching Operations	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000513	BreakerVacuum	OX-1273	VCB Readings	Unknown Operations	3	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	9 Month Operations	1	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	66	*F
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	General Comments		
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Negative DC Ground	30.0	VDC
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Positive DC Ground	28.0	VDC
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BAT001167	Battery	427-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BCH001115	Charger	427-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BCH001115	Charger	427-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BCH001115	Charger	427-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BCH001115	Charger	427-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.9	amps
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BCH001115	Charger	427-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BCH001115	Charger	427-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Amps A Ø	0.0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Amps B Ø	0.0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Amps C Ø	0.0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Min Tap Position	11L	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Max Tap Position	1R	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	General Comments		
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000126	Regulator	427-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000514	BreakerVacuum	OX-1275	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	ST000117	Structure	158-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Fault Operations C Ø	0	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Fault Operations A Ø	0	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Fault Operations B Ø	0	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Fault Operations C Ø	0	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Fault Operations Ground	0	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Follow-up Action Required?	n	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Patrol Inspection	Foundation Condition	Good	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Patrol Inspection	General Comments		
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	General Comments		
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Patrol Inspection	Grounds in Place?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Maintenance Operations	0	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Operations Counter AF	179	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Operations Counter AL	179	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Operations This Read Vac	3	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Switching Operations	3	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Patrol Inspection	Tank Paint Condition	Good	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	BK001412	BreakerVacuum	409-2219	VCB Readings	Unknown Operations	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000512	BreakerVacuum	OX-12KV TR 1	VCB Readings	9 Month Operations	2	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	BCH001311	Charger	874-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Fault Operations Ground	0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Follow-up Action Required?	n	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Foundation Condition	Good	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	General Comments		
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	General Comments		
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	LTC Totalizer Reading	5915.52	kw
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	Oil Temp Max	62	°C
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	Oil Temp Present	37	°C
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	General Comments		
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	General Comments		
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Grounds in Place?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Maintenance Operations	0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Operations Counter AF	182	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Operations Counter AL	185	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Operations This Read Vac	3	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Switching Operations	3	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Patrol Inspection	Tank Paint Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0066	BreakerVacuum	158-5	VCB Readings	Unknown Operations	0	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	BCH001311	Charger	874-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.7	amps
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	BCH001311	Charger	874-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	BCH001311	Charger	874-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	BCH001311	Charger	874-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	BCH001311	Charger	874-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	53.0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	43.0	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	General Comments		
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Vegetation	None	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Maintenance Operations	0	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Operations Counter AF	260	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Operations Counter AL	260	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Operations This Read Vac	0	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Switching Operations	0	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Tank Paint Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Unknown Operations	0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BCH000973	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BCH000973	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BCH000973	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	54.0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	Acual counter	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	168	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	168	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	Num Operations Last 9 Months	3	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	Operations Counter AF	68	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	Operations Counter AL	68	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	Operations This Read SF6	1	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	SF6 Pressure Indicator	good	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	Positive DC Ground	64.0	VDC
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Unknown Operations	0	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Tank Paint Condition	Good	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Switching Operations	26	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	Switching Operations	1	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Operations This Read Vac	26	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Operations Counter AL	334	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	General Comments		
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Operations Counter AF	334	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Maintenance Operations	0	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Grounds in Place?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	General Comments	install sel	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Unknown Operations	0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Tank Paint Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Switching Operations	1	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Operations This Read Vac	11	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Operations Counter AL	53	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Operations Counter AF	43	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Foundation Condition	Good	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Follow-up Action Required?	n	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Fault Operations Ground	0	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Fault Operations C Ø	0	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	Fault Operations	0	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	General Comments		
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Vegetation	None	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	LTCC000696	LTCControl	874-1	LTC Control Insp	All Connections OK?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	LTCC000696	LTCControl	874-1	LTC Control Insp	Follow-up Action Required?	n	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	LTCC000696	LTCControl	874-1	LTC Control Insp	General Comments		
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	LTCC000696	LTCControl	874-1	LTC Control Insp	LTC Operation Checked?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	LTCC000696	LTCControl	874-1	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	LTCC000696	LTCControl	874-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	LTCC000696	LTCControl	874-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	LTCC000696	LTCControl	874-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Regulator As Left Counter	122682	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	Follow-up Action Required?	n	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Foundation Condition	Good	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	General Comments		
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	General Comments	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Grounds in Place?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Heaters (All) Functioning?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Readings	Maintenance Operations	0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BCH000973	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	135.0	VDC
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BCH000973	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	135.0	VDC
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BCH000973	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	General Comments		
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	FE000464	Fence	409-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Ambient Temp	66	*F
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	YD000469	Yard	409-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0713	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	Actual counter, Red light socket is broken for in service	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	37	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	37	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0718	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Vegetation	None	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	General Comments		
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Regulator As Left Counter	25340	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Min Tap Position	11L	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1510	Regulator	427-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	General Comments		
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	YD000502	Yard	427-Yard	Yard Patrol Inspection	Ambient Temp	66	°F
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	General Comments		
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Fault Operations B Ø	0	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Fault Operations A Ø	0	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Patrol Inspection	Bushing Condition	Good	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Amps C Ø	350.0	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Amps B Ø	340.0	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Amps A Ø	349.0	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	K0035	BreakerVacuum	409-2220	VCB Readings	9 Month Operations	34	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Maintenance Operations	10	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Grounds in Place?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	General Comments		
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Foundation Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Follow-up Action Required?	n	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Fault Operations Ground	0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Fault Operations C Ø	0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Fault Operations B Ø	0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Fault Operations A Ø	0	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	Negative DC Ground	57.0	VDC
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	General Comments		
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	BAT001383	Battery	874-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LTCC000281	LTCControl	OX-TRANS 1	LTC Control Insp	All Connections OK?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LTCC000281	LTCControl	OX-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LTCC000281	LTCControl	OX-TRANS 1	LTC Control Insp	General Comments		
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LTCC000281	LTCControl	OX-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Max Tap Position	1L	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Min Tap Position	12L	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Regulator As Left Counter	82213	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Patrol Inspection	Bushing Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Amps C Ø	0.0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Amps B Ø	0.0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Amps A Ø	0.0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0065	BreakerVacuum	158-BT5-6	VCB Readings	9 Month Operations	21	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Tank Paint Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	FE000495	Fence	427-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Fault Operations A Ø	0	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Fault Operations B Ø	0	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Fault Operations C Ø	0	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Fault Operations Ground	0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	Totalizer Meter Reading	.3390	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	Winding Temp Max	42	°C
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	Winding Temp Present	28	°C
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Vegetation	None	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	General Comments		
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Follow-up Action Required?	n	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Foundation Condition	Good	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	General Comments		
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	General Comments		
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Grounds in Place?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Maintenance Operations	0	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Operations Counter AF	77	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Operations Counter AL	77	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Operations This Read Vac	1	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Switching Operations	1	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Tank Paint Condition	Good	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Unknown Operations	0	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Tank Leaks	None	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Regulator As Left Counter	15237	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Fault Operations A Ø	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Fault Operations B Ø	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Fault Operations C Ø	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Fault Operations Ground	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Follow-up Action Required?	n	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Patrol Inspection	General Comments		
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	9 Month Operations	2	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Min Tap Position	10L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Max Tap Position	2R	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	General Comments		
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Amps A Ø	271.0	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Amps B Ø	263.0	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Amps C Ø	302.0	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Bushing Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0032	WithLTC	158-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Amps A Ø	5.0	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Amps B Ø	5.0	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Amps C Ø	5.0	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Bushing Condition	Good	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	ST000443	Structure	409-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	Actual counter	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	7505	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	7505	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0720	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Fault Operations A Ø	0	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Fault Operations B Ø	0	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Fault Operations C Ø	0	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Fault Operations Ground	0	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Follow-up Action Required?	n	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Foundation Condition	Good	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	General Comments		
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	General Comments		
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Grounds in Place?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KT0010	NonLTC	427-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	General Comments		
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Current Tap Position	Neutral	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000125	Regulator	427-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	9 Month Operations	9	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Amps A Ø	60.0	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Amps B Ø	60.0	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Amps C Ø	45.0	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Bushing Condition	Good	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0194	BreakerVacuum	874-0219	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	General Comments		
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	General Comments	Actual Counter, offline	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Maintenance Operations	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Operations Counter AF	126	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Operations Counter AL	126	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Operations This Read Vac	1	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Switching Operations	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	BK000515	BreakerVacuum	OX-1276	VCB Readings	Unknown Operations	1	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Trash Emptied?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	General Comments		
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Max Tap Position	5R	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Current Tap Position	1L	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	RG000124	Regulator	427-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Ambient Temperature	66	*F
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1509	Regulator	427-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000603	BreakerSF6	427-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	General Comments		
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	FE000112	Fence	158-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	YD000113	Yard	158-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Maintenance Operations	0	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Operations Counter AF	222	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Operations Counter AL	222	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Operations This Read Vac	1	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Switching Operations	1	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Patrol Inspection	Tank Paint Condition	Good	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CB0193	BreakerVacuum	874-0218	VCB Readings	Unknown Operations	0	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Fault Operations A ∅	0	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	YD000534	Yard	874-Yard	Yard Patrol Inspection	Ambient Temp	66	°F
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	FE000529	Fence	874-Fence	Fence Patrol Inspection	General Comments		
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	10	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A ∅	340.0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B ∅	343.0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C ∅	316.0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A ∅	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B ∅	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C ∅	0	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1323	Regulator	409-1 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	Actual counter, A, B, and C phase ARC sense	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1419	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1419	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0715	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Fault Operations B ∅	0	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Fault Operations C ∅	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Fault Operations Ground	0	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	Follow-up Action Required?	n	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Foundation Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	General Comments		
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Readings	General Comments		
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0006	BreakerVacuum	427-2207	VCB Patrol Inspection	Grounds in Place?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Broom on Site?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	CH000035	ControlHouse	158-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Fault Operations Ground	0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Fault Operations C Ø	0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Fault Operations B Ø	0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Fault Operations A Ø	0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	76	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	76	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	Actual counter	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0716	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Amps C Ø	103.0	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Amps B Ø	100.0	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Amps A Ø	77.0	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	9 Month Operations	8	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Unknown Operations	0	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Tank Paint Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Switching Operations	0	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Operations This Read Vac	0	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Operations Counter AL	244	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Operations Counter AF	244	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Maintenance Operations	0	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Grounds in Place?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	General Comments		
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Foundation Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Follow-up Action Required?	n	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Fault Operations Ground	0	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Fault Operations C Ø	0	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Fault Operations B Ø	0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0060	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Unknown Operations	0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Switching Operations	1	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Operations This Read Vac	1	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Operations Counter AL	0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Operations Counter AF	96	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Maintenance Operations	0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Grounds in Place?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	General Comments		
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	General Comments		
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Foundation Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Follow-up Action Required?	n	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	General Comments		
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	General Comments		
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	LTCC000918	LTCControl	158-5	LTC Control Insp	All Connections OK?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	LTCC000918	LTCControl	158-5	LTC Control Insp	Follow-up Action Required?	n	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	LTCC000918	LTCControl	158-5	LTC Control Insp	General Comments		
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	LTCC000918	LTCControl	158-5	LTC Control Insp	LTC Operation Checked?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	LTCC000918	LTCControl	158-5	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	LTCC000918	LTCControl	158-5	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	LTCC000918	LTCControl	158-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	LTCC000918	LTCControl	158-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	LTCC000918	LTCControl	158-5	LTC Control Insp	VRR Time Delay	60	Seconds
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	LTCC000919	LTCControl	158-6	LTC Control Insp	All Connections OK?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	LTCC000919	LTCControl	158-6	LTC Control Insp	Follow-up Action Required?	n	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	PF000269	PowerFuse	OX-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	PF000269	PowerFuse	OX-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	LTCC000919	LTCControl	158-6	LTC Control Insp	General Comments		
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Regulator As Left Counter	130180	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	General Comments		
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	LTCC000919	LTCControl	158-6	LTC Control Insp	LTC Operation Checked?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	LTCC000919	LTCControl	158-6	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	LTCC000919	LTCControl	158-6	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	LTCC000919	LTCControl	158-6	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	LTCC000919	LTCControl	158-6	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	LTCC000919	LTCControl	158-6	LTC Control Insp	VRR Time Delay	60	Seconds
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Counter Readings	General Comments	Transformer is offline due to switch gear getting updated	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Counter Readings	LTC As Found Counter	206650	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Counter Readings	LTC As Left Counter	206650	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Counter Readings	LTC Max Tap Position	5R	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Counter Readings	LTC Min Tap Position	10L	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1215	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0141	LTCMechanism	OX-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	Tank Paint Condition	Good	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Readings	Switching Operations	8	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	SF6 Pressure	90	psi
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	SF6 Bushing Condition	Good	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Readings	Operations This Read SF6	8	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Readings	Operations Counter AL	67	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Readings	Operations Counter AF	67	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Readings	Num Operations Last 9 Months	8	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	Moisture and Leak Free?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Operations Counter AL	548	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Operations Counter AF	548	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Maintenance Operations	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	General Comments	Actual counter, offline	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Patrol Inspection	General Comments		
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Follow-up Action Required?	n	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Fault Operations Ground	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Fault Operations C Ø	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Fault Operations B Ø	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Fault Operations A Ø	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Fault Adjusted Amps C Phase V	55.90	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Fault Adjusted Amps B Phase V	55.90	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Fault Adjusted Amps A Phase V	55.90	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Amps C Ø	0.0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Amps B Ø	0.0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Amps A Ø	0.0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LB0710	BreakerVacuum	OX-1274	VCB Readings	9 Month Operations	14	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Patrol Inspection	Bushing Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Amps C Ø	37.0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Amps B Ø	40.0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Amps A Ø	41.0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000559	BreakerVacuum	158-2	VCB Readings	9 Month Operations	1	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	BCH001361	Charger	409-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	BCH001361	Charger	409-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	BCH001361	Charger	409-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	BCH001361	Charger	409-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	BCH001361	Charger	409-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.1	amps
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	BCH001361	Charger	409-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	BCH001361	Charger	409-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	BCH001361	Charger	409-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Fault Operations A Ø	0	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Patrol Inspection	General Comments		
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Readings	General Comments		
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	7104.00	kw
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Readings	Oil Temp Max	65	°C
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.0990	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	Oil Temp Present	45	°C
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	Oil Temp Max	68	°C
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	10550.40	kw
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	S0015	NonLTC	409-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	50	°C
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	30.00	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Unknown Operations	0	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Tank Paint Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Switching Operations	1	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Operations This Read Vac	1	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Operations Counter AL	236	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Operations Counter AF	236	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Maintenance Operations	0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Counter Readings	Follow-up Action Required?	n	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Counter Readings	General Comments		
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Mechanism Patrol Inspection	General Comments		
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Counter Readings	LTC As Found Counter	90208	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Counter Readings	LTC As Left Counter	90211	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Counter Readings	LTC Current Tap Position	1L	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Counter Readings	LTC Max Tap Position	1R	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Counter Readings	LTC Min Tap Position	7L	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Counter Readings	LTC Operations Since Last Insp	563	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0023	LTCMechanism	158-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Grounds in Place?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	General Comments		
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	General Comments		
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Foundation Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Follow-up Action Required?	n	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Counter Readings	Follow-up Action Required?	n	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Counter Readings	General Comments		
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Mechanism Patrol Inspection	General Comments		
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Counter Readings	LTC As Found Counter	78204	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Counter Readings	LTC As Left Counter	78208	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Counter Readings	LTC Current Tap Position	4L	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Counter Readings	LTC Max Tap Position	4L	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Counter Readings	LTC Min Tap Position	11L	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Counter Readings	LTC Operations Since Last Insp	627	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	S0032	LTCMechanism	158-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Fault Operations Ground	0	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Fault Operations C ∅	0	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	Oil Temp Present	45	°C
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1000	psi
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	TV Winding Temp Present	31	°C
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	TV Winding Temp Max	35	°C
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	SWG000131	Switchgear	OX-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	LTC Operations Since Last Insp	886	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	LTC Min Tap Position	11L	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	LTC Max Tap Position	1L	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	LTC Current Tap Position	6L	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	LTC As Left Counter	8562	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	LTC As Found Counter	8560	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Mechanism Patrol Inspection	General Comments		
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	General Comments		
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	C0494	LTCMechanism	874-1	LTC Counter Readings	Follow-up Action Required?	n	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BAT000251	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BAT000251	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	72	°F
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BAT000251	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BAT000251	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BAT000251	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BAT000251	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BAT000251	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BAT000251	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BAT000251	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	General Comments		
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	ST000538	Structure	874-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BAT000251	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BAT000251	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BAT000251	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BAT000251	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BAT000251	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	20	°C
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	60	°C
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	30	°C
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	70	°C
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	20	°C
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Fault Operations B Ø	0	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Fault Operations A Ø	0	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	General Comments		
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Unknown Operations	0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Tank Paint Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Switching Operations	3	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Operations This Read Vac	3	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Operations Counter AL	205	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Operations Counter AF	202	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Maintenance Operations	0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Grounds in Place?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	General Comments		
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	General Comments		
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Foundation Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Follow-up Action Required?	n	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Fault Operations Ground	0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Fault Operations C Ø	0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Fault Operations B Ø	0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Fault Operations A Ø	0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Patrol Inspection	Bushing Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Amps C Ø	190.0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Amps B Ø	190.0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Amps A Ø	160.0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	K0079	BreakerVacuum	158-6	VCB Readings	9 Month Operations	7	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000637	BreakerVacuum	427-2241	VCB Patrol Inspection	Bushing Condition	Good	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	9 Month Operations	31	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Amps A Ø	14.0	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	K0026	BreakerVacuum	409-2218	VCB Readings	Amps B Ø	20.0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	Oil Temp Present	32	°C
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	Oil Temp Max	40	°C
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	2450	psi
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	5.0	psi
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	LV Winding Temp Present	32	°C
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	LV Winding Temp Max	39	°C
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	HV Winding Temp Present	34	°C
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	HV Winding Temp Max	38	°C
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	General Comments		
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	General Comments		
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	T0178	WithLTC	158-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	DB0032	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	General Comments		
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	66	°F
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	BAT000953	Battery	409-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	General Comments		
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0141	WithLTC	OX-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Regulator As Left Counter	76173	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	R1511	Regulator	427-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Counter Readings	LTC As Left Counter	63782	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Counter Readings	LTC As Found Counter	63782	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	General Comments	one 8ft bulb is out. Swgr is offline due to getting updated	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0140	LTCMechanism	OX-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	9 Month Operations	2	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Amps A Ø	0.0	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	40	°C
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	50	°C
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	35	°C
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	45	°C
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	35	°C
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	45	°C
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Current Tap Position	Neutral	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	General Comments		
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Max Tap Position	5R	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Regulator As Left Counter	137119	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Readings	Totalizer Meter Reading	.7400	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	9 Month Operations	7	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	General Comments	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Counter Readings	LTC Current Tap Position	1L	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Readings	General Comments		
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	Gauge(s) Condition	Good	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	Foundation Condition	Good	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Counter Readings	Follow-up Action Required?	n	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Amps A Ø	222.0	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Amps B Ø	218.0	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Readings	Amps C Ø	235.0	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Bushing Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	BK000636	BreakerVacuum	427-2240	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Bushing Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Foundation Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1325	Regulator	409-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	S0027	NonLTC	427-2	NonLTC Transformer Readings	Oil Temp Present	45	°C
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	General Comments		
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Grounds in Place?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	Grounds in Place?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Readings	Maintenance Operations	0	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Counter Readings	LTC Max Tap Position	1L	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Counter Readings	LTC Min Tap Position	1L	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Counter Readings	LTC Operations Since Last Insp	380	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000480	BreakerVacuum	158-0214	VCB Patrol Inspection	Tank Paint Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Amps B Ø	0.0	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Mechanism Patrol Inspection	General Comments		
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Counter Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Tank Paint Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Bushing Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Readings	Follow-up Action Required?	n	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Readings	Fault Operations	0	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	Bushings Connection/Risers	Good	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	C0494	WithLTC	874-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	PF000267	PowerFuse	OX-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	PF000267	PowerFuse	OX-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	BK001268	BreakerSF6	874-708	GCB Patrol Inspection	Ambient Temperature	66	*F
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	T0178	LTCMechanism	158-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Readings	Amps C Ø	0.0	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Bushing Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	KB0005	BreakerVacuum	427-2206	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Grounds in Place?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	General Comments		
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Foundation Condition	Good	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Follow-up Action Required?	n	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	General Comments		
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/20/2020 15:00	Distribution	Bond Quarterly Inspection	BK000481	BreakerVacuum	158-0215	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	General Comments		
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Trash Emptied?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LTCC000215	LTCControl	OX-TRANS 2	LTC Control Insp	All Connections OK?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LTCC000215	LTCControl	OX-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	General Comments		
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
10/20/2020 16:30	Distribution	Lebanon West Quarterly Inspection	CH000395	ControlHouse	874-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/20/2020 16:21	Distribution	Lebanon South Quarterly Inspection	R1324	Regulator	409-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LTCC000215	LTCControl	OX-TRANS 2	LTC Control Insp	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LTCC000215	LTCControl	OX-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.8	psi
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1700	psi
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/20/2020 17:35	Distribution	Lebanon East Quarterly Inspection	ST000504	Structure	427-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	Oil Temp Max	55	°C
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	LT0140	WithLTC	OX-TRANS 2	LTC Transformer Readings	Oil Temp Present	40	°C
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	n	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/26/2020 6:41	Distribution	Oxmoor Quarterly Inspection	SWG000025	Switchgear	OX-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Amps C Ø	0.0	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Amps B Ø	0.0	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	LTCC000270	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124	VAC
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	General Comments		
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BAT001376	Battery	586-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BAT001376	Battery	586-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BAT001376	Battery	586-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BAT001376	Battery	586-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	LTCC000270	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BAT001376	Battery	586-Battery Bank	Battery Patrol Inspection	Negative DC Ground	22	VDC
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Floor Swept?	n	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Operations Counter	35	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	General Comments		
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BCH001007	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.400	millivolts
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BCH001007	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BCH001007	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BCH001007	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.3	amps
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Broom on Site?	n	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BCH001007	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BAT001376	Battery	586-Battery Bank	Battery Patrol Inspection	General Comments		
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BCH001299	Charger	586-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BCH001299	Charger	586-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BCH001299	Charger	586-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BCH001299	Charger	586-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Ambient Temp	61	°F
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	General Comments		
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Vegetation	None	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	YD000437	Yard	586-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Fault Operations A ∅	0	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Fault Operations B ∅	0	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Fault Operations C ∅	0	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Fault Operations Ground	0	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Follow-up Action Required?	n	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BAT001376	Battery	586-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Unknown Operations	0	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Tank Paint Condition	Good	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Switching Operations	0	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Operations This Read Vac	0	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Operations Counter AL	166	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Operations Counter AF	166	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Maintenance Operations	0	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Grounds in Place?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	General Comments		
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	General Comments		
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BAT001376	Battery	586-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BAT001376	Battery	586-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BCH001007	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BCH001007	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BCH001007	Charger	Retired Distribution	Battery Charger Patrol Insp	Ground Lights	None	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BAT001376	Battery	586-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Foundation Condition	Good	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Follow-up Action Required?	n	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	LTC Totalizer Reading	1234.56	kw
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	General Comments		
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	Totalizer Meter Reading	.0810	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BCH001299	Charger	586-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BCH001299	Charger	586-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53	VDC
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BCH001299	Charger	586-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53	VDC
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BCH001299	Charger	586-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1	amps
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	Oil Temp Present	40	°C
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	Oil Temp Max	45	°C
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	LTC Totalizer Reading	583.20	kw
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	General Comments		
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	General Comments		
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	B0394	WithLTC	841-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Bushing Condition	Good	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Amps C Ø	6.0	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Amps B Ø	7.0	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Amps A Ø	5.0	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	9 Month Operations	1	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Unknown Operations	0	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Tank Paint Condition	Good	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Switching Operations	0	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Operations This Read Vac	2	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Operations Counter AL	192	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Operations Counter AF	192	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Maintenance Operations	0	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Grounds in Place?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	General Comments		
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	General Comments		
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Foundation Condition	Good	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Follow-up Action Required?	n	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Follow-up Action Required?	n	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Fault Operations B Ø	0	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Fault Operations C Ø	0	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Fault Operations Ground	0	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Fault Operations Ground	0	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Fault Operations C Ø	1	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Fault Operations B Ø	1	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Fault Operations A Ø	0	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Fault Adjusted Amps C Phase V	2.94	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Fault Adjusted Amps B Phase V	2.94	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Patrol Inspection	Bushing Condition	Good	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Amps C Ø	28.0	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Amps B Ø	31.0	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Amps A Ø	29.0	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001088	BreakerVacuum	841-0487	VCB Readings	9 Month Operations	6	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	LTCC000270	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	LTCC000270	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	LTCC000270	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Counter Readings	Follow-up Action Required?	n	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Counter Readings	General Comments		
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Follow-up Action Required?	n	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Mechanism Patrol Inspection	General Comments		
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Counter Readings	LTC As Found Counter	6104	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Counter Readings	LTC As Left Counter	6115	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Counter Readings	LTC Current Tap Position	10L	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Counter Readings	LTC Max Tap Position	3L	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Counter Readings	LTC Min Tap Position	16L	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Counter Readings	LTC Operations Since Last Insp	1173	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Accumulated Fault Duty A Ph V	0	%
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Accumulated Fault Duty B Ph V	0	%
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Accumulated Fault Duty C Ph V	.65	%
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Amps A Ø	115	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Amps B Ø	110	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Amps C Ø	145	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Bushing Condition	Good	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	General Comments		
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	General Comments	tower foundations are crumbling	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Fault Operations A Ø	0	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Fault Operations B Ø	0	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Fault Operations C Ø	0	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Fault Operations Ground	0	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Follow-up Action Required?	n	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Follow-up Action Required?	n	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Foundation Condition	Good	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	General Comments		
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	General Comments		
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Grounds in Place?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Maintenance Operations	0	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	General Comments		
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Operations Counter AF	191	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Operations Counter AL	191	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	ST000440	Structure	586-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Operations This Read Vac	0	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Switching Operations	0	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Patrol Inspection	Tank Paint Condition	Good	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BK001089	BreakerVacuum	841-0488	VCB Readings	Unknown Operations	0	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	ST000075	Structure	841-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Ambient Temp	55	*F
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	LTCC000776	LTCControl	841-1	LTC Control Insp	VRR Time Delay	60	Seconds
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Counter Readings	LTC Operations Since Last Insp	221	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Counter Readings	LTC Min Tap Position	8L	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Counter Readings	LTC Max Tap Position	5L	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Counter Readings	LTC Current Tap Position	7L	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Counter Readings	LTC As Left Counter	238556	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Counter Readings	LTC As Found Counter	238552	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Maintenance Operations	0	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	General Comments		
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Operations Counter AF	177	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Operations Counter AL	177	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Operations This Read Vac	8	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Switching Operations	8	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	CH000001	ControlHouse	841-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BAT001376	Battery	586-Battery Bank	Battery Patrol Inspection	Positive DC Ground	20	VDC
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Patrol Inspection	Bushing Condition	Good	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Amps C Ø	85	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Mechanism Patrol Inspection	General Comments		
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Counter Readings	General Comments		
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Counter Readings	Follow-up Action Required?	n	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Amps B Ø	65	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Amps A Ø	72	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Accumulated Fault Duty C Ph V	0	%
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Accumulated Fault Duty B Ph V	0	%
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	Accumulated Fault Duty A Ph V	0	%
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000391	BreakerVacuum	586-2127	VCB Readings	9 Month Operations	1	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Unknown Operations	0	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	Totalizer Meter Reading	.3858	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BAT001376	Battery	586-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BAT001376	Battery	586-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Tank Paint Condition	Good	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	B0394	LTCMechanism	841-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	LTCC000270	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	LTCC000270	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	LTCC000270	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	LTCC000270	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124	VAC
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	LTCC000776	LTCControl	841-1	LTC Control Insp	All Connections OK?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	LTCC000776	LTCControl	841-1	LTC Control Insp	Follow-up Action Required?	n	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	LTCC000776	LTCControl	841-1	LTC Control Insp	General Comments		
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	LTCC000776	LTCControl	841-1	LTC Control Insp	LTC Operation Checked?	n	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	LTCC000776	LTCControl	841-1	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	LTCC000776	LTCControl	841-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	LTCC000776	LTCControl	841-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	Follow-up Action Required?	n	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Foundation Condition	Good	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	General Comments		
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	General Comments	barb wire is rusty, and top rail is getting rusty. Back left corner post needs replaced.	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	KX0079	RecloserElectronic	841-0489	Recloser Electronic Patrol Inspection	Amps A Ø	1.0	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	General Comments		
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Grounds in Place?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	BK000390	BreakerVacuum	586-2126	VCB Readings	9 Month Operations	9	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	General Comments		
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	FE000828	Fence	586-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	Oil Temp Max	50	°C
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Readings	Oil Temp Present	35	°C
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	C0422	WithLTC	586-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	BAT001102	Battery	841-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	n	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	FE000002	Fence	841-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/19/2020 16:50	Distribution	Harrodsburg City Quarterly Inspection	C0422	LTCMechanism	586-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/19/2020 10:29	Distribution	Robbins Quarterly Inspection	YD000003	Yard	841-Yard	Yard Patrol Inspection	Vegetation	None	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	LTC As Left Counter	265012	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	General Comments		
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	General Comments		
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	LTC Totalizer Reading	2236.80	kw
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.5	psi
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	Oil Temp Max	44	°C
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4R	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	LTC Min Tap Position	11L	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	Oil Temp Present	21	°C
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	40	°C
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Ambient Temp	67	°F
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1899	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	BCH001312	Charger	826-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	BAT001384	Battery	826-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	BAT001384	Battery	826-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	BAT001384	Battery	826-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	General Comments		
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	General Comments		
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Max Tap Position	5R	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	BCH001312	Charger	826-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	9 Month Operations	2	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Amps A Ø	65.0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Amps B Ø	65.0	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Readings	Totalizer Meter Reading	.2720	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	LTCC000299	LTCControl	428-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	LTCC000299	LTCControl	428-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	LTCC000299	LTCControl	428-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Amps C Ø	65.0	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	LTC As Found Counter	265012	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	General Comments		
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0090	LTCMechanism	HK-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Fault Operations C Ø	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Fault Operations B Ø	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Fault Operations A Ø	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	BCH001312	Charger	826-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	BCH001312	Charger	826-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	BCH001312	Charger	826-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1550	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	LTC Min Tap Position	14L	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	9 Month Operations	2	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	BCH001312	Charger	826-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	BCH001312	Charger	826-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	BCH001312	Charger	826-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Counter Readings	General Comments		
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Mechanism Patrol Inspection	General Comments		
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Counter Readings	LTC As Found Counter	329630	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Counter Readings	LTC As Left Counter	329633	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Counter Readings	LTC Current Tap Position	6L	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Counter Readings	LTC Max Tap Position	9L	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Counter Readings	LTC Min Tap Position	2L	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Amps A Ø	578.0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Amps B Ø	591.0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Amps C Ø	560.0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Fault Operations Ground	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Patrol Inspection	General Comments		
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Maintenance Operations	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Operations Counter AF	113	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Operations Counter AL	113	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Operations This Read Vac	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Switching Operations	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Unknown Operations	0	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Counter Readings	LTC Operations Since Last Insp	193	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Counter Readings	LTC Operations Since Last Insp	540	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Counter Readings	LTC Min Tap Position	7L	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Fault Operations Ground	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	BAT000194	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	BAT000194	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	BAT000194	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	9 Month Operations	0	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	BAT000194	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	BAT000194	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	BAT000194	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	BAT000194	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	BAT000194	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	25.0	VDC
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	28.0	VDC
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Fault Operations Ground	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Fault Operations C ∅	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Fault Operations B ∅	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Fault Operations A ∅	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0539	BreakerVacuum	KE-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Counter Readings	Follow-up Action Required?	n	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	LTCMechanism	746-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Counter Readings	LTC Min Tap Position	2L	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Counter Readings	LTC Operations Since Last Insp	977	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LTCC000016	LTCControl	KE-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallellIND	Position
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LTCC000016	LTCControl	KE-TRANS 1	LTC Control Insp	General Comments		
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LTCC000016	LTCControl	KE-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LTCC000016	LTCControl	KE-TRANS 1	LTC Control Insp	All Connections OK?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LTCC000015	LTCControl	KE-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallellIND	Position
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LTCC000015	LTCControl	KE-TRANS 2	LTC Control Insp	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LTCC000015	LTCControl	KE-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LTCC000015	LTCControl	KE-TRANS 2	LTC Control Insp	All Connections OK?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Follow-up Action Required?	n	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Patrol Inspection	General Comments		
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	General Comments		
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Maintenance Operations	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Operations Counter AF	203	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Operations Counter AL	203	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Operations This Read Vac	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Switching Operations	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Unknown Operations	0	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	General Comments		
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	General Comments		
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1200	psi
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	Oil Temp Max	61	°C
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	Oil Temp Present	22	°C
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Amps C Ø	294.0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Amps B Ø	270.0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Amps A Ø	279.0	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Counter Readings	LTC Max Tap Position	2R	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Counter Readings	LTC Current Tap Position	6L	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Counter Readings	LTC As Left Counter	73482	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Counter Readings	LTC As Found Counter	73482	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Mechanism Patrol Inspection	General Comments		
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Counter Readings	General Comments		
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	B0465	LTCMechanism	823-1	LTC Counter Readings	Follow-up Action Required?	n	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	9 Months Operations	0	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Counter Readings	Follow-up Action Required?	n	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Counter Readings	General Comments		
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Mechanism Patrol Inspection	General Comments		
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Counter Readings	LTC As Found Counter	16165	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Counter Readings	LTC As Left Counter	16168	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Counter Readings	LTC Current Tap Position	4R	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0425	LTCMechanism	826-2	LTC Counter Readings	LTC Max Tap Position	9R	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Fault Operations Ground	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Follow-up Action Required?	n	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Patrol Inspection	General Comments		
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	General Comments		
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Maintenance Operations	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Operations Counter AF	189	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Operations Counter AL	189	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Operations This Read Vac	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Switching Operations	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Unknown Operations	0	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	General Comments		
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Regulator As Left Counter	74090	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	BCH000269	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	BCH000269	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	BCH000269	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	498271	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Vegetation	None	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	YD000422	Yard	826-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	BCH000390	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	BCH000390	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	BCH000390	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	BCH000390	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	BCH000390	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	BCH000390	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	67	*F
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	General Comments		
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Readings	General Comments		
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Readings	Oil Temp Max	42	°C
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Readings	Oil Temp Present	27	°C
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	BAT000605	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	0989	NonLTC	342-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	ST000012	Structure	342-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Vegetation	None	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Operations Counter AL	559	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Operations Counter AF	559	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Maintenance Operations	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	General Comments		
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Patrol Inspection	General Comments		
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Follow-up Action Required?	n	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Fault Operations A Ø	0	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	Totalizer Meter Reading	.8388	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	Oil Temp Present	25	°C
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	Oil Temp Max	33	°C
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	2013.12	kw
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	General Comments		
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	General Comments		
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	W0169	NonLTC	310-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Fault Operations B Ø	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Fault Operations C Ø	0	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	7L	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	6R	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	3R	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	BAT001384	Battery	826-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Amps A Ø	155.0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Amps B Ø	165.0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Unknown Operations	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Switching Operations	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0538	BreakerAirMagnetic	KE-12KV TR 1	AMCB Readings	Operations This Read AM	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Amps C Ø	160.0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0535	BreakerVacuum	KE-1162	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Min Tap Position	2R	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0600	Regulator	595-1 B	Regulator Patrol Inspection	Max Tap Position	4L	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Ambient Temp	42	°F
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	General Comments		
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0822	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	YD000648	Yard	KE-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Readings	Oil Temp Present	50	°C
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Readings	Oil Temp Max	60	°C
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Readings	General Comments		
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	General Comments		
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	General Comments		
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	General Comments	nitro cyl at 0 psi	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	General Comments		
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	Totalizer Meter Reading	.5339	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	Oil Temp Present	30	°C
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	Oil Temp Max	50	°C
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	LTC Totalizer Reading	5125.44	kw
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	General Comments		
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	LTCC000726	LTCControl	428-2	LTC Control Insp	All Connections OK?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	LTCC000726	LTCControl	428-2	LTC Control Insp	Follow-up Action Required?	n	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	LTCC000726	LTCControl	428-2	LTC Control Insp	General Comments		
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	LTCC000726	LTCControl	428-2	LTC Control Insp	LTC Operation Checked?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	LTCC000726	LTCControl	428-2	LTC Control Insp	LTC Output Voltage Level	125.0	VAC
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	LTCC000726	LTCControl	428-2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	LTCC000726	LTCControl	428-2	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	LTCC000726	LTCControl	428-2	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	LTCC000726	LTCControl	428-2	LTC Control Insp	VRR Time Delay	30	Seconds
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	General Comments	Vegetation needs to be cut back away from the fence to the proper level.	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	FE000122	Fence	310-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Regulator As Left Counter	74090	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Min Tap Position	Neutral	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Max Tap Position	9L	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	70	°C
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	40	°C
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	PF000192	PowerFuse	KE-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	PF000192	PowerFuse	KE-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	PF000191	PowerFuse	KE-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	PF000191	PowerFuse	KE-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Readings	General Comments		
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	70	°C
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	40	°C
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	70	°C
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0508	NonLTC	746-3 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	FE000018	Fence	342-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Counter Readings	General Comments		
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Mechanism Patrol Inspection	General Comments		
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Counter Readings	LTC As Found Counter	16693	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Counter Readings	LTC As Left Counter	16696	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Counter Readings	LTC Current Tap Position	4L	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Counter Readings	LTC Max Tap Position	2L	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Operations This Read AM	1	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Operations Counter AL	696	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Operations Counter AF	696	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Maintenance Operations	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	General Comments		
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Patrol Inspection	General Comments		
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Follow-up Action Required?	n	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Fault Operations Ground	0	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Counter Readings	LTC Min Tap Position	8L	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Counter Readings	LTC Operations Since Last Insp	494	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	X1 Winding Temp Max	48	°C
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	X1 Winding Temp Present	28	°C
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	X2 Winding Temp Max	48	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	X2 Winding Temp Present	24	°C
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	X3 Winding Temp Max	48	°C
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	X3 Winding Temp Present	24	°C
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Counter Readings	Follow-up Action Required?	n	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Counter Readings	General Comments		
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Mechanism Patrol Inspection	General Comments		
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Counter Readings	LTC As Found Counter	7740	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Counter Readings	LTC As Left Counter	7740	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Fault Operations C Ø	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Fault Operations B Ø	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Fault Operations A Ø	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Fault Adjusted Amps C Phase AM	11.18	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Amps C Ø	20.0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Amps B Ø	14.0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Amps A Ø	20.0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Current Tap Position	Neutral	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Foundation Condition	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	General Comments		
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Grounds in Place?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Max Tap Position	Neutral	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Min Tap Position	Neutral	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Reg Oil Level	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Reg Output Voltage Level	121.0	volts
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Regulator As Left Counter	46876	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Counter Readings	Follow-up Action Required?	n	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Bushing Condition	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Tank Leaks	None	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R1015	Regulator	746-2 AB	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	Winding Temp Present	28	°C
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	Winding Temp Max	48	°C
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	Totalizer Meter Reading	4.4250	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	PF000183	PowerFuse	HK-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	PF000183	PowerFuse	HK-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	General Comments		
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	ST000731	Structure	310-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	PF000184	PowerFuse	HK-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	PF000184	PowerFuse	HK-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Unknown Operations	1	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	Switching Operations	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	LTC As Left Counter	42333	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	LTC As Found Counter	42333	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	Totalizer Meter Multiplier	1000	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	Top Oil Temperature Present	28	°C
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	Top Oil Temperature Max	48	°C
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	General Comments		
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Min Tap Position	Neutral	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Reg Oil Level	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Reg Output Voltage Level	121.0	volts
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Regulator As Left Counter	49096	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1150	psi
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Readings	LTC Totalizer Reading	4425.00	kw
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	TX000137	WithLTC	428-2	LTC Transformer Patrol Inspection	General Comments		
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LTCC000429	LTCControl	HK-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LTCC000429	LTCControl	HK-TRANS 2	LTC Control Insp	General Comments		
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LTCC000429	LTCControl	HK-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0538	WithLTC	826-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0530	BreakerAirMagnetic	KE-1157	AMCB Readings	9 Months Operations	1	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	BCH000023	Charger	KE-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Counter Readings	LTC Current Tap Position	5L	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Counter Readings	LTC Min Tap Position	7L	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	46	°C
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	29	°C
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Counter Readings	LTC Operations Since Last Insp	387	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	LTCM000066	LTCMechanism	428-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0538	LTCMechanism	826-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LTCC000429	LTCControl	HK-TRANS 2	LTC Control Insp	All Connections OK?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	BCH000023	Charger	KE-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	BCH000023	Charger	KE-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Bushing Condition	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Current Tap Position	Neutral	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	BCH000023	Charger	KE-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	6.0	amps
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	BCH000023	Charger	KE-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	BCH000023	Charger	KE-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	BCH000023	Charger	KE-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	BCH000023	Charger	KE-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	General Comments		
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Grounds in Place?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Max Tap Position	Neutral	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	1600	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	47	°C
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	15	°C
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	LTC Min Tap Position	15L	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	LTC Max Tap Position	5R	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0320	LTCMechanism	HK-TRANS 3	LTC Counter Readings	LTC Current Tap Position	12L	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0090	WithLTC	HK-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Operations Counter AL	233	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Operations Counter AF	233	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Maintenance Operations	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	General Comments		
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Patrol Inspection	General Comments		
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Follow-up Action Required?	n	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Fault Operations Ground	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Fault Operations C ∅	0	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	LTCC000319	LTCControl	746-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	LTCC000319	LTCControl	746-1	LTC Control Insp	VRR Base Voltage AL	120.0	VAC
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	LTCC000319	LTCControl	746-1	LTC Control Insp	VRR Base Voltage AF	120.0	VAC
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Fault Operations B ∅	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Fault Operations A ∅	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	LTCC000319	LTCControl	746-1	LTC Control Insp	LTC Output Voltage Level	120.5	VAC
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	LTCC000319	LTCControl	746-1	LTC Control Insp	LTC Operation Checked?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Ambient Temp	58	*F
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	General Comments		
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	LTCC000319	LTCControl	746-1	LTC Control Insp	General Comments		
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	LTCC000319	LTCControl	746-1	LTC Control Insp	Follow-up Action Required?	n	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	LTCC000319	LTCControl	746-1	LTC Control Insp	All Connections OK?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	General Comments		
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	BAT001384	Battery	826-Battery Bank	Battery Patrol Inspection	General Comments		
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	PF000190	PowerFuse	KE-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	PF000190	PowerFuse	KE-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	PF000189	PowerFuse	KE-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	PF000189	PowerFuse	KE-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	BAT001384	Battery	826-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	BAT001384	Battery	826-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	BAT001384	Battery	826-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	BAT001384	Battery	826-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	BAT001384	Battery	826-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	BAT001384	Battery	826-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	BAT001384	Battery	826-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	BAT001384	Battery	826-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Vegetation	None	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	General Comments		
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	YD000503	Yard	428-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	4R	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	6L	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	370729	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	FE000496	Fence	428-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	Oil Temp Present	30	°C
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	Oil Temp Max	50	°C
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	LTC Totalizer Reading	1030.20	kw
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	General Comments		
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	General Comments		
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	220.00	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	Totalizer Meter Reading	.6990	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	M0039	WithLTC	310-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Regulator As Left Counter	161130	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R1099	Regulator	342-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	9 Month Operations	2	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Amps A Ø	0.0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Amps B Ø	0.0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Readings	Amps C Ø	0.0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	LTCC000294	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	LTCC000294	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	General Comments		
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	LTC As Found Counter	234426	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	LTC As Left Counter	234426	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	LTC Current Tap Position	12L	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0089	LTCMechanism	HK-TRANS 2	LTC Counter Readings	LTC Max Tap Position	3R	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	LTCC000294	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	LTCC000294	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	LTCC000294	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.8	VAC
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	LTCC000294	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	LTCC000294	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	LTCC000294	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	LTCC000299	LTCControl	428-1	LTC Control Insp	All Connections OK?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	LTCC000299	LTCControl	428-1	LTC Control Insp	Follow-up Action Required?	n	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	LTCC000299	LTCControl	428-1	LTC Control Insp	General Comments		
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	LTCC000299	LTCControl	428-1	LTC Control Insp	LTC Operation Checked?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	LTCC000299	LTCControl	428-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	LTCC000299	LTCControl	428-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0075	BreakerVacuum	428-0598	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	Totalizer Meter Reading	.1717	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0417	WithLTC	746-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	28	°C
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	70	°C
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	30	°C
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	30	°C
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	70	°C
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	30	°C
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	70	°C
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	Oil Temp Present	37	°C
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	General Comments		
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1616	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1616	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	30	°C
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	70	°C
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	PF000182	PowerFuse	HK-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	PF000182	PowerFuse	HK-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	PF000181	PowerFuse	HK-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	PF000181	PowerFuse	HK-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Unknown Operations	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Switching Operations	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Operations This Read Vac	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Operations Counter AL	210	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Operations Counter AF	210	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	General Comments		
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0599	Regulator	595-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	General Comments		
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	Oil Temp Max	70	°C
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	Oil Temp Present	30	°C
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Fans Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	1	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	32	°C
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	70	°C
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	1L	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Tank Leaks	None	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R1016	Regulator	746-2 BC	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0102	WithLTC	KE-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	9 Month Operations	1	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	30	°C
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	167520	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	2L	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	5R	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments	Drag hands do not work.	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	2L	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0902	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	ST000505	Structure	428-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Maintenance Operations	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	General Comments		
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Patrol Inspection	General Comments		
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Follow-up Action Required?	n	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Fault Operations Ground	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Fault Operations C Ø	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Fault Operations B Ø	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Fault Operations A Ø	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Amps C Ø	180.0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Amps B Ø	220.0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Amps A Ø	195.0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0076	BreakerVacuum	428-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	CB0151	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Unknown Operations	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Switching Operations	0	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	General Comments		
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Readings	General Comments		
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Readings	LTC Totalizer Reading	1305.60	kw
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0047	BreakerVacuum	428-0591	VCB Readings	Operations This Read Vac	0	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Readings	Oil Temp Max	40	°C
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Readings	Oil Temp Present	20	°C
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	B0465	WithLTC	823-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R1069	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2020 14:20	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/16/2020 14:20	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/16/2020 14:20	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
10/16/2020 14:20	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Amps A Ø	110.0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Amps B Ø	120.0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Amps C Ø	105.0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Fault Operations A Ø	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Fault Operations B Ø	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Fault Operations C Ø	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Fault Operations Ground	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Follow-up Action Required?	n	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Patrol Inspection	General Comments		
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	General Comments		
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Maintenance Operations	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Operations Counter AF	247	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Operations Counter AL	247	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Operations This Read Vac	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Switching Operations	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Unknown Operations	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Operations A Ø	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Operations B Ø	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Operations C Ø	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Operations Ground	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Follow-up Action Required?	n	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Patrol Inspection	General Comments		
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	General Comments		
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Maintenance Operations	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Operations Counter AF	312	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Operations Counter AL	312	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Operations This Read AM	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Unknown Operations	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Switching Operations	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Operations This Read AM	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Operations Counter AL	683	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Operations Counter AF	683	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Maintenance Operations	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Patrol Inspection	General Comments		
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Follow-up Action Required?	n	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Fault Operations Ground	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Fault Operations C Ø	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Fault Operations B Ø	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Fault Operations A Ø	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Amps C Ø	43.0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Amps B Ø	45.0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Amps A Ø	46.0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0528	BreakerAirMagnetic	KE-1155	AMCB Readings	9 Months Operations	2	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Switching Operations	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Unknown Operations	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	General Comments		
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Platform/Walkway/Railing OK?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	LTCC000651	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	LTCC000651	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	LTCC000651	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	LTCC000651	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	LTCC000651	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	LTCC000651	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	LTCC000651	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	LTCC000651	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	9 Month Operations	2	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0072	BreakerVacuum	428-0595	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	SWG000173	Switchgear	KE-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	9 Months Operations	26	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Accumulated Fault Duty A Ph AM	6.02	%
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Accumulated Fault Duty B Ph AM	7.23	%
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Accumulated Fault Duty C Ph AM	3.61	%
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Amps A Ø	0.0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Amps B Ø	0.0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Amps C Ø	0.0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0446	BreakerAirMagnetic	HK-1234	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/16/2020 14:20	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Vegetation	None	
10/16/2020 14:20	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/16/2020 14:20	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	General Comments		
10/16/2020 14:20	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 14:20	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/16/2020 14:20	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/16/2020 14:20	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/16/2020 14:20	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/16/2020 14:20	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/16/2020 14:20	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/16/2020 14:20	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/16/2020 14:20	Distribution	Critical Fork Quarterly Inspection	YD000120	Yard	364-Yard	Yard Patrol Inspection	Ambient Temp	60	*F
10/16/2020 14:20	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/16/2020 14:20	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	General Comments	Trees up against and over the fence	
10/16/2020 14:20	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/16/2020 14:20	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/16/2020 14:20	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/16/2020 14:20	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
10/16/2020 14:20	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 14:20	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/16/2020 14:20	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/16/2020 14:20	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/16/2020 14:20	Distribution	Critical Fork Quarterly Inspection	FE000118	Fence	364-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	General Comments		
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Vegetation	None	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	General Comments		
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	ST000350	Structure	823-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	3R	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Amps A Ø	78.0	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Amps B Ø	77.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Amps C Ø	77.0	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1197	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	LTC Min Tap Position	12L	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	LTC Max Tap Position	2R	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	LTC Current Tap Position	11L	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	LTC As Left Counter	198481	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	LTC As Found Counter	198481	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	General Comments		
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0102	LTCMechanism	KE-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1182	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	LTC Min Tap Position	13L	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	LTC Max Tap Position	2R	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	LTC Current Tap Position	10L	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	LTC As Left Counter	108920	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	General Comments		
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	BAT001016	Battery	KE-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	General Comments		
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	LTC000902	LTCControl	826-2	LTC Control Insp	All Connections OK?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	ST000470	Structure	595-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Vegetation	None	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	General Comments		
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	YD000467	Yard	595-Yard	Yard Patrol Inspection	Ambient Temp	66	*F
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	General Comments		
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LTCC000099	LTCControl	HK-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallellND	Position
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LTCC000099	LTCControl	HK-TRANS 3	LTC Control Insp	General Comments		
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LTCC000099	LTCControl	HK-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LTCC000099	LTCControl	HK-TRANS 3	LTC Control Insp	All Connections OK?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	LTCC000902	LTCControl	826-2	LTC Control Insp	Follow-up Action Required?	n	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	LTCC000902	LTCControl	826-2	LTC Control Insp	General Comments		
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	LTCC000902	LTCControl	826-2	LTC Control Insp	LTC Operation Checked?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	LTCC000902	LTCControl	826-2	LTC Control Insp	LTC Output Voltage Level	123.8	VAC
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	LTCC000902	LTCControl	826-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	LTCC000902	LTCControl	826-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	LTCC000902	LTCControl	826-2	LTC Control Insp	VRR Time Delay	30	Seconds
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	FE000343	Fence	823-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Ambient Temp	58	*F
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	YD000347	Yard	823-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Amps B Ø	7.2	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	76	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Unknown Operations	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Switching Operations	0	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Regulator As Left Counter	120897	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Max Tap Position	6R	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	General Comments		
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Operations This Read Vac	1	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Operations Counter AL	339	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Operations Counter AF	339	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Maintenance Operations	0	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	R0933	Regulator	342-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	General Comments		
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Patrol Inspection	General Comments		
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Follow-up Action Required?	n	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Fault Operations Ground	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Fault Operations C Ø	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Fault Operations B Ø	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Fault Operations A Ø	1	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Amps C Ø	59.0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Amps B Ø	63.0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Amps A Ø	66.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0532	BreakerVacuum	KE-1159	VCB Readings	9 Month Operations	3	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	9 Month Operations	17	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Amps A Ø	60.0	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Amps B Ø	96.0	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Amps C Ø	96.0	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Bushing Condition	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Fault Operations A Ø	0	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Fault Operations B Ø	0	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Fault Operations C Ø	0	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Fault Operations Ground	0	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Follow-up Action Required?	n	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Ambient Temp	50	*F
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	MegaVar Demand Meter Max	4.16	MegaVars
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	LTC Totalizer Reading	24100.00	kw
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	Kwh Reading	71457	kWh
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	General Comments		
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	General Comments		
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Ambient Temp	60	*F
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	General Comments		
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	FE000530	Fence	746-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/16/2020 14:20	Distribution	Critical Fork Quarterly Inspection	ST000846	Structure	364-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
10/16/2020 14:20	Distribution	Critical Fork Quarterly Inspection	ST000846	Structure	364-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/16/2020 14:20	Distribution	Critical Fork Quarterly Inspection	ST000846	Structure	364-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/16/2020 14:20	Distribution	Critical Fork Quarterly Inspection	ST000846	Structure	364-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/16/2020 14:20	Distribution	Critical Fork Quarterly Inspection	ST000846	Structure	364-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/16/2020 14:20	Distribution	Critical Fork Quarterly Inspection	ST000846	Structure	364-Structure	Structure Patrol Inspection	General Comments		
10/16/2020 14:20	Distribution	Critical Fork Quarterly Inspection	ST000846	Structure	364-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/16/2020 14:20	Distribution	Critical Fork Quarterly Inspection	ST000846	Structure	364-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 14:20	Distribution	Critical Fork Quarterly Inspection	ST000846	Structure	364-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	General Comments		
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	91	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	DX0056	RecloserHydraulic	342-4620	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	76	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Amps B Ø	150.0	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Amps A Ø	150.0	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	9 Months Operations	10	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Amps A Ø	121.0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Amps B Ø	105.0	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	General Comments		
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	General Comments		
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	257.04	kw
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	10.00	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	B0275	NonLTC	595-1	NonLTC Transformer Readings	Totalizer Meter Reading	.2142	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Amps C Ø	126.0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Fault Adjusted Amps B Phase AM	33.54	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Fault Operations A Ø	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Fault Operations B Ø	3	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Fault Operations C Ø	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Follow-up Action Required?	n	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Patrol Inspection	General Comments		
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	General Comments		
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Maintenance Operations	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Operations Counter AF	973	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Operations Counter AL	973	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Operations This Read AM	3	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Switching Operations	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0529	BreakerAirMagnetic	KE-1156	AMCB Readings	Unknown Operations	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Follow-up Action Required?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	General Comments		vegetation over and coming through fence South side of station
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	FE000643	Fence	KE-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	ST000628	Structure	KE-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Foundation Condition	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	General Comments		
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	General Comments		
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Grounds in Place?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Maintenance Operations	0	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Operations Counter AF	249	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	9 Months Operations	17	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Amps A Ø	0.0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Amps B Ø	0.0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Amps C Ø	0.0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Operations Counter AL	257	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Operations This Read Vac	8	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Switching Operations	8	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Patrol Inspection	Tank Paint Condition	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	K0028	BreakerVacuum	310-4623	VCB Readings	Unknown Operations	0	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Operations Counter	1425	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Fault Operations A Ø	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Fault Operations B Ø	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Fault Operations C Ø	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Fault Operations Ground	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Follow-up Action Required?	n	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	General Comments		
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Patrol Inspection	General Comments		
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	General Comments		
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Operations Counter AF	429	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Operations Counter AL	429	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Operations This Read AM	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Switching Operations	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0449	BreakerAirMagnetic	HK-1237	AMCB Readings	Unknown Operations	0	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	General Comments		
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	ST000127	Structure	310-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	CX0116	RecloserElectronic	826-2226	Recloser Electronic Patrol Inspection	Amps C Ø	180.0	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Amps A Ø	180.0	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Amps B Ø	180.0	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Amps C Ø	180.0	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Bushing Condition	Good	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Fault Operations A Ø	0	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Fault Operations B Ø	0	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Fault Operations C Ø	0	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Fault Operations Ground	0	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Follow-up Action Required?	n	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Foundation Condition	Good	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	General Comments		
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	General Comments		
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Grounds in Place?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Maintenance Operations	0	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Operations Counter AF	354	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Operations Counter AL	354	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Operations This Read Vac	0	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Switching Operations	0	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Patrol Inspection	Tank Paint Condition	Good	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Unknown Operations	0	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	CH000491	ControlHouse	310-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	n	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	CH000491	ControlHouse	310-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	CH000491	ControlHouse	310-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	LTCC000357	LTCCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	LTCC000357	LTCCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	LTCC000357	LTCCControl	Retired Distribution	LTC Control Insp	General Comments		
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	LTCC000357	LTCCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	LTCC000357	LTCCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	LTCC000357	LTCCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	LTCC000357	LTCCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	LTCC000357	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Broom on Site?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	General Comments		
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BAT001230	Battery	823-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	General Comments		
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Fault Operations A Ø	0	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Fault Operations B Ø	0	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Fault Operations C Ø	0	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Fault Operations Ground	0	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Follow-up Action Required?	n	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Foundation Condition	Good	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	General Comments		
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	General Comments		
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Grounds in Place?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	Oil Temp Present	30	*C
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	Totalizer Meter Reading	1.1940	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	9 Months Operations	23	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Amps A Ø	163.0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Amps B Ø	202.0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Amps C Ø	195.0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Patrol Inspection	General Comments		
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Maintenance Operations	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Operations Counter AF	91	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Operations Counter AL	91	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Operations This Read AM	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Switching Operations	0	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Maintenance Operations	0	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Operations Counter AF	227	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Operations Counter AL	227	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Operations This Read Vac	4	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Switching Operations	4	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Tank Paint Condition	Good	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Unknown Operations	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0456	BreakerAirMagnetic	HK-12KV TR 2	AMCB Readings	Unknown Operations	0	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	CH000491	ControlHouse	310-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	CH000491	ControlHouse	310-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	CH000491	ControlHouse	310-Control House	Control House Patrol Inspection	Trash Emptied?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	CH000491	ControlHouse	310-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	n	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	CH000491	ControlHouse	310-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	CH000491	ControlHouse	310-Control House	Control House Patrol Inspection	Panels Dusted?	n	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	CH000491	ControlHouse	310-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	CH000491	ControlHouse	310-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	CH000491	ControlHouse	310-Control House	Control House Patrol Inspection	General Comments	Building has no equipment yet.	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	CH000491	ControlHouse	310-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	CH000491	ControlHouse	310-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	CH000491	ControlHouse	310-Control House	Control House Patrol Inspection	Floor Swept?	n	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	CH000491	ControlHouse	310-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	9 Month Operations	4	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0038	BreakerVacuum	826-2225	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	General Comments		
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Switching Operations	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Operations This Read AM	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AL	125	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AF	125	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Maintenance Operations	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	General Comments		
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Patrol Inspection	General Comments		
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Follow-up Action Required?	n	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	9 Month Operations	2	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Amps A Ø	160.0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Amps B Ø	165.0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Amps C Ø	140.0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Fault Operations A Ø	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Fault Operations B Ø	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Fault Operations C Ø	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Fault Operations Ground	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Follow-up Action Required?	n	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Patrol Inspection	General Comments		
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	General Comments		
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Maintenance Operations	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Operations Counter AF	202	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Operations Counter AL	202	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Operations This Read Vac	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Switching Operations	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0046	BreakerVacuum	428-0592	VCB Readings	Unknown Operations	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	9 Months Operations	13	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Amps A Ø	0.0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Amps B Ø	0.0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Amps C Ø	0.0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations A Ø	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations B Ø	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations C Ø	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations Ground	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Trash Emptied?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	CH000154	ControlHouse	KE-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	SWG000035	Switchgear	KE-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	CH000491	ControlHouse	310-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	CH000491	ControlHouse	310-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	CH000491	ControlHouse	310-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	CH000491	ControlHouse	310-Control House	Control House Patrol Inspection	Broom on Site?	n	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BCH001178	Charger	823-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BCH001178	Charger	823-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BCH001178	Charger	823-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BCH001178	Charger	823-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BCH001178	Charger	823-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BCH001178	Charger	823-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BCH001178	Charger	823-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	CH000491	ControlHouse	310-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	General Comments		
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	FE000838	Fence	595-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	CH000491	ControlHouse	310-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0454	BreakerAirMagnetic	HK-12KV BUS TIE SEC 2	AMCB Readings	Unknown Operations	0	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links QTY OK?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	ST000424	Structure	826-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	SWG000128	Switchgear	HK-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Fault Operations A Ø	0	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Fault Operations B Ø	0	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Fault Operations C Ø	0	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Fault Operations Ground	0	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Follow-up Action Required?	n	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Foundation Condition	Good	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	General Comments		
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	General Comments		
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Grounds in Place?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Maintenance Operations	0	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Operations Counter AF	273	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Operations Counter AL	273	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Operations This Read Vac	0	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Switching Operations	0	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Tank Paint Condition	Good	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Unknown Operations	0	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	General Comments		
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Operations Counter	56	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Unknown Operations	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Switching Operations	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Operations This Read AM	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Operations Counter AL	1211	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	9 Month Operations	20	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Amps A Ø	100.0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Amps B Ø	120.0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Amps C Ø	95.0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	General Comments		
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Fault Operations A Ø	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Fault Operations B Ø	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Fault Operations C Ø	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Fault Operations Ground	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Follow-up Action Required?	n	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Patrol Inspection	General Comments		
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	General Comments		
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Maintenance Operations	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Operations Counter AF	214	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Operations Counter AL	214	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Operations This Read Vac	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Switching Operations	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0073	BreakerVacuum	428-0596	VCB Readings	Unknown Operations	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Operations Counter AF	1211	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Maintenance Operations	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	General Comments		
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Patrol Inspection	General Comments		
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	LTC As Found Counter	108920	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	General Comments		
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0101	LTCMechanism	KE-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	269	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	269	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	General Comments		
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0536	BreakerVacuum	KE-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	0	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	35565	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	R0517	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Operations Counter	202	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	General Comments		
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	0	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	0	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Amps B Ø	12.0	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	CX0495	RecloserHydraulic	595-0866 B	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	0	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	9 Month Operations	4	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Amps A Ø	60.0	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Amps B Ø	60.0	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Readings	Amps C Ø	60.0	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Bushing Condition	Good	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	K0037	BreakerVacuum	826-0224	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Amps A Ø	12.1	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Amps B Ø	13.0	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Amps C Ø	15.9	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	General Comments		
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Operations Counter	394	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	MX0493	RecloserHydraulic	310-4650	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Operations Counter	0	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Vegetation	None	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	General Comments	Driveway rutted out at the culvert.	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	n	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	n	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	n	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	General Comments		
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	149	
10/16/2020 14:17	Distribution	Rocky Fork Quarterly Inspection	YD000013	Yard	342-Yard	Yard Patrol Inspection	Ambient Temp	62	*F
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	7	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Amps C Ø	20.0	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Amps B Ø	17.0	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	Amps A Ø	18.0	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	CX0124	RecloserHydraulic	595-0220	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	265	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	General Comments		
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	9 Month Operations	6	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	General Comments		
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	LTC Totalizer Reading	5731.20	kw
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	C0425	WithLTC	826-2	LTC Transformer Readings	Oil Temp Max	50	°C
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Amps A Ø	30.0	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Amps B Ø	35.0	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Readings	Amps C Ø	35.0	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Bushing Condition	Good	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BK000252	BreakerVacuum	823-0093	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	399	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	399	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/16/2020 12:58	Distribution	Springfield Quarterly Inspection	FE000479	Fence	826-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	20.0	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	20.0	
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	20.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/16/2020 15:00	Distribution	Spindletop Quarterly Inspection	BB0251	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	8	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Follow-up Action Required?	n	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Fault Operations Ground	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Fault Operations C Ø	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Fault Operations B Ø	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Fault Operations A Ø	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Counter Readings	LTC Operations Since Last Insp	1894	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Counter Readings	LTC Min Tap Position	9L	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Amps C Ø	100.0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Amps B Ø	108.0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Amps A Ø	93.0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Counter Readings	LTC Max Tap Position	2R	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Counter Readings	LTC Current Tap Position	3L	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Counter Readings	LTC As Left Counter	41560	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Counter Readings	LTC As Found Counter	41557	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Mechanism Patrol Inspection	General Comments		
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Counter Readings	General Comments		
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	M0039	LTCMechanism	310-1	LTC Counter Readings	Follow-up Action Required?	n	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0531	BreakerAirMagnetic	KE-1158	AMCB Readings	9 Months Operations	3	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	MX0329	RecloserElectronic	310-4625	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Operations Ground	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Amps C Ø	345.0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Amps B Ø	367.0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Amps A Ø	385.0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	9.63	%
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	9.63	%
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	9.63	%
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	9 Month Operations	28	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	9 Month Operations	17	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Accumulated Fault Duty A Ph V	39.86	%
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Accumulated Fault Duty B Ph V	70.15	%
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Accumulated Fault Duty C Ph V	19.13	%
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Amps A Ø	40.0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Amps B Ø	48.0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Amps C Ø	44.0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Operations A Ø	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Operations B Ø	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Operations C Ø	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Operations Ground	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Follow-up Action Required?	n	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Patrol Inspection	General Comments		
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Maintenance Operations	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Operations Counter AF	327	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Counter Readings	LTC Operations Since Last Insp	432	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	°C
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	35	°C
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Counter Readings	LTC Min Tap Position	3L	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Counter Readings	LTC Max Tap Position	3R	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Counter Readings	LTC Current Tap Position	3L	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Counter Readings	LTC As Left Counter	26187	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Counter Readings	LTC As Found Counter	26187	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Mechanism Patrol Inspection	General Comments		
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Counter Readings	General Comments		
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	LTCMechanism	428-1	LTC Counter Readings	Follow-up Action Required?	n	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Operations Counter AL	327	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Operations This Read Vac	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Switching Operations	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Unknown Operations	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	9 Month Operations	7	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	3.85	%
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	5.78	%
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	3.85	%
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Amps A Ø	255.0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Amps B Ø	238.0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Amps C Ø	266.0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Operations A Ø	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Operations B Ø	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Fault Operations A Ø	1	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Fault Operations B Ø	1	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Fault Operations C Ø	1	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Fault Operations Ground	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Follow-up Action Required?	n	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Patrol Inspection	General Comments		
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	General Comments		
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0533	BreakerVacuum	KE-1160	VCB Readings	Maintenance Operations	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Unknown Operations	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Switching Operations	0	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	Oil Temp Present	50	°C
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	Oil Temp Max	60	°C
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	0.00	kw
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	General Comments		
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	General Comments		
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Operations This Read Vac	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Operations Counter AL	196	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Operations Counter AF	196	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Maintenance Operations	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	General Comments		
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Patrol Inspection	General Comments		
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Follow-up Action Required?	n	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Fault Operations Ground	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Fault Operations C Ø	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Fault Operations B Ø	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Fault Operations A Ø	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Amps C Ø	315.0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Amps B Ø	360.0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Amps A Ø	360.0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0044	BreakerVacuum	428-1	VCB Readings	9 Month Operations	1	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Accumulated Fault Duty C Ph AM	3.61	%
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Accumulated Fault Duty B Ph AM	18.07	%
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Accumulated Fault Duty A Ph AM	3.61	%
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	9 Months Operations	28	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Switching Operations	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Operations This Read Vac	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Operations Counter AL	225	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Operations Counter AF	225	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Maintenance Operations	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	General Comments		
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Patrol Inspection	General Comments		
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	General Comments		
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Readings	General Comments		
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	96.00	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Readings	Oil Temp Max	60	°C
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Readings	Oil Temp Present	50	°C
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0371	NonLTC	746-2 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Fault Operations Ground	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Follow-up Action Required?	n	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Patrol Inspection	General Comments		
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	General Comments		
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Maintenance Operations	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Operations Counter AF	217	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Operations Counter AL	217	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Operations This Read Vac	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Switching Operations	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0074	BreakerVacuum	428-0597	VCB Readings	Unknown Operations	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Operations Ground	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Operations C Ø	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Operations B Ø	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Operations A Ø	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Amps C Ø	107.0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Amps B Ø	99.0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Amps A Ø	124.0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Accumulated Fault Duty C Ph V	7.97	%
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Accumulated Fault Duty B Ph V	23.92	%
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Accumulated Fault Duty A Ph V	35.87	%
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	9 Month Operations	23	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Unknown Operations	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Switching Operations	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Operations This Read Vac	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Operations Counter AL	338	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Operations Counter AF	338	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Maintenance Operations	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	General Comments		
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Patrol Inspection	General Comments		
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Follow-up Action Required?	n	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Fault Operations Ground	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Fault Operations C Ø	0	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	3	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	2.47	%
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	2.47	%
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	2.47	%
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	180.0	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	230.0	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	220.0	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	52	°C
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	15	°C
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	65	°C
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	22	°C
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	65	°C
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	22	°C
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Unknown Operations	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Switching Operations	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Operations This Read Vac	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Operations Counter AL	176	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Operations Counter AF	176	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	General Comments		
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	Oil Temp Max	68	°C
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	Oil Temp Present	25	°C
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	70	°C
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	28	°C
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	72	°C
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	30	°C
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	74	°C
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LT0101	WithLTC	KE-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	35	°C
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Maintenance Operations	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	General Comments		
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Patrol Inspection	General Comments		
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Follow-up Action Required?	n	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Fault Operations Ground	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Fault Operations C Ø	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Fault Operations B Ø	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Fault Operations A Ø	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Amps C Ø	0.0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Amps B Ø	0.0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Amps A Ø	0.0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000511	BreakerVacuum	HK-1236	VCB Readings	9 Month Operations	20	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Unknown Operations	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Patrol Inspection	General Comments		
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	General Comments		
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Maintenance Operations	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Operations Counter AF	135	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Operations Counter AL	135	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Operations This Read Vac	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Switching Operations	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Unknown Operations	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Operations C Ø	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Operations B Ø	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Operations A Ø	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Amps C Ø	81.0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Amps B Ø	107.0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Amps A Ø	88.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	279	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	279	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	CB0235	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Fault Operations B Ø	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Fault Operations A Ø	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Amps C Ø	173.0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Amps B Ø	175.0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LTCC000519	LTCControl	HK-TRANS 1	LTC Control Insp	All Connections OK?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LTCC000519	LTCControl	HK-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LTCC000519	LTCControl	HK-TRANS 1	LTC Control Insp	General Comments		
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LTCC000519	LTCControl	HK-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Amps A Ø	171.0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000509	BreakerVacuum	HK-1240	VCB Readings	9 Month Operations	19	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Unknown Operations	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Switching Operations	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Operations This Read Vac	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Operations Counter AL	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Operations Counter AF	227	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Maintenance Operations	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	General Comments		
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Patrol Inspection	General Comments		
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Follow-up Action Required?	n	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Operations Ground	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	9 Month Operations	1	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Amps A Ø	0.0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Amps B Ø	0.0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Amps C Ø	0.0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Fault Operations A Ø	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Fault Operations B Ø	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Fault Operations C Ø	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Fault Operations Ground	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0043	BreakerVacuum	428-BT1-2	VCB Readings	Follow-up Action Required?	n	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Grounds in Place?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	General Comments		
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Foundation Condition	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Current Tap Position	3L	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Bushing Condition	Good	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	9 Month Operations	2	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Amps A Ø	135.0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Amps B Ø	125.0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Amps C Ø	105.0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Fault Operations A Ø	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Fault Operations B Ø	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Fault Operations C Ø	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Fault Operations Ground	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Follow-up Action Required?	n	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Patrol Inspection	General Comments		
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	General Comments		
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Maintenance Operations	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Operations Counter AF	251	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Operations Counter AL	251	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Operations This Read Vac	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Switching Operations	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KB0048	BreakerVacuum	428-0594	VCB Readings	Unknown Operations	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	9 Month Operations	4	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Amps A Ø	28.0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Amps B Ø	36.0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Amps C Ø	30.0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Fault Operations A Ø	1	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Fault Operations B Ø	1	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Fault Operations C Ø	1	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Fault Operations Ground	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Follow-up Action Required?	n	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Patrol Inspection	General Comments		
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	General Comments		
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Maintenance Operations	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Operations Counter AF	269	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Operations Counter AL	269	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Operations This Read Vac	3	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Switching Operations	0	
10/16/2020 22:07	Distribution	Kenwood Quarterly Inspection	LB0534	BreakerVacuum	KE-1161	VCB Readings	Unknown Operations	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	General Comments		
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Maintenance Operations	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AF	230	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AL	230	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Operations This Read Vac	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Switching Operations	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Unknown Operations	0	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	SWG000196	Switchgear	428-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	SWG000197	Switchgear	428-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Tank Leaks	None	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Regulator As Left Counter	78343	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Reg Output Voltage Level	120.4	volts
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Reg Oil Level	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Min Tap Position	3L	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R0925	Regulator	746-3 AB	Regulator Patrol Inspection	Max Tap Position	3L	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	6000	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	C0509	NonLTC	746-3 A	NonLTC Transformer Readings	Totalizer Meter Reading	0.0000	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	PF001161	PowerFuse	HK-12KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	PF001161	PowerFuse	HK-12KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	PF001162	PowerFuse	HK-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	PF001162	PowerFuse	HK-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Vegetation	None	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	General Comments		
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/16/2020 10:42	Distribution	Dixiana Quarterly Inspection	YD000123	Yard	310-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	SWG000028	Switchgear	HK-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Max Tap Position	8L	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	General Comments		
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	X3 Winding Temp Present	25	°C
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	X3 Winding Temp Max	55	°C
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	X2 Winding Temp Present	25	°C
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	X2 Winding Temp Max	56	°C
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	X1 Winding Temp Present	25	°C
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	X1 Winding Temp Max	56	°C
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	Winding Temp Present	25	°C
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	Winding Temp Max	56	°C
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	Totalizer Meter Reading	24.1000	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	Totalizer Meter Multiplier	1000	
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	Top Oil Temperature Present	25	°C
10/16/2020 17:21	Distribution	Innovation Drive Quarterly Inspection	KT0008	WithLTC	428-1	LTC Transformer Readings	Top Oil Temperature Max	53	°C
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Min Tap Position	Neutral	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Regulator As Left Counter	84784	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/16/2020 15:31	Distribution	Mackville Quarterly Inspection	R0570	Regulator	595-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	General Comments		
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	9 Months Operations	11	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Amps A Ø	0.0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Amps B Ø	0.0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Amps C Ø	0.0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Fault Operations A Ø	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Fault Operations B Ø	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Fault Operations C Ø	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Fault Operations Ground	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Follow-up Action Required?	n	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Patrol Inspection	General Comments		
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	General Comments		
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Maintenance Operations	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Operations Counter AF	41	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Operations Counter AL	41	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Operations This Read AM	0	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	ST000539	Structure	746-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Vegetation	None	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	General Comments		
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	YD000535	Yard	746-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Switching Operations	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	LB0451	BreakerAirMagnetic	HK-1239	AMCB Readings	Unknown Operations	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	SWG000199	Switchgear	HK-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Operations Counter AF	171	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Operations Counter AL	171	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Operations This Read Vac	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Switching Operations	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Unknown Operations	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	9 Month Operations	18	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Accumulated Fault Duty A Ph V	84.5	%
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Accumulated Fault Duty B Ph V	66.96	%
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Accumulated Fault Duty C Ph V	71.75	%
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Amps A Ø	0.0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Amps B Ø	0.0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Amps C Ø	0.0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Operations A Ø	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Fault Operations B Ø	0	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Unknown Operations	0	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Tank Paint Condition	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Switching Operations	3	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Operations This Read Vac	3	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Operations Counter AL	232	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Operations Counter AF	232	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Readings	Maintenance Operations	0	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	K0090	BreakerVacuum	746-0170	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Tank Leaks	None	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty A Ph V	38.5	%
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty B Ph V	38.5	%
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty C Ph V	38.5	%
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Amps A Ø	0.0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Amps B Ø	0.0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Amps C Ø	0.0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Regulator As Left Counter	17209	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Reg Output Voltage Level	120.4	volts
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/16/2020 7:42	Distribution	Corning Harrodsburg Quarterly Inspection	R1308	Regulator	746-3 BC	Regulator Patrol Inspection	Reg Oil Level	Good	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Operations A Ø	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Operations B Ø	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Operations This Read Vac	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Operations C Ø	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Switching Operations	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Unknown Operations	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Operations Ground	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Follow-up Action Required?	n	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Patrol Inspection	General Comments		
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	9 Month Operations	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Accumulated Fault Duty A Ph V	11.16	%
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Accumulated Fault Duty B Ph V	11.16	%
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Accumulated Fault Duty C Ph V	11.16	%
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Operations Counter AL	344	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Amps A Ø	0.0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	9 Month Operations	3	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Operations Counter AF	344	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Accumulated Fault Duty A Ph V	14.35	%
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Accumulated Fault Duty B Ph V	14.35	%
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Accumulated Fault Duty C Ph V	14.35	%
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Amps A Ø	13.0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Amps B Ø	13.0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Amps C Ø	13.0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Readings	Maintenance Operations	0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000069	BreakerVacuum	HK-1243	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Amps B Ø	0.0	
10/16/2020 13:44	Distribution	Harrods Creek Quarterly Inspection	BK000070	BreakerVacuum	HK-1244	VCB Readings	Amps C Ø	0.0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	CX0892	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	CX0892	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	CX0892	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	CX0892	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	CX0892	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	CX0892	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	CX0892	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	CX0892	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	69	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	CX0892	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	CX0892	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Readings	X1 Winding Temp Max	80	°C
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Readings	Switching Operations	14	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Readings	Operations This Read Oil	14	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Readings	Operations Counter AL	1972	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Readings	Operations Counter AF	1972	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Readings	Number of Ops last 9 Months	15	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Readings	X1 Winding Temp Present	29	°C
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Readings	X2 Winding Temp Max	78	°C
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Readings	X2 Winding Temp Present	29	°C
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Readings	X3 Winding Temp Max	76	°C
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Readings	Maintenance Operations	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Readings	Totalizer Meter Reading	1.0700	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Readings	General Comments	''	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Readings	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Readings	Fault Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Readings	Amps C Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Readings	Amps B Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Readings	Amps A Ø	0.0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	LTCC000589	LTCControl	825-3	LTC Control Insp	All Connections OK?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	LTCC000589	LTCControl	825-3	LTC Control Insp	Follow-up Action Required?	n	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	LTCC000589	LTCControl	825-3	LTC Control Insp	General Comments		
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Readings	X3 Winding Temp Present	29	°C
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	Operations Counter AL	1166	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	Operations This Read Oil	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	Switching Operations	0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Fault Operations A Ø	0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Fault Operations B Ø	0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Fault Operations C Ø	0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Fault Operations Ground	0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Follow-up Action Required?	n	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Follow-up Action Required?	n	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Foundation Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	General Comments		
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	General Comments		
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Grounds in Place?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Maintenance Operations	0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Operations Counter AF	169	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Operations Counter AL	169	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Operations This Read Vac	0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Switching Operations	0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Tank Paint Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Unknown Operations	0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	CX0893	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	Operations Counter AF	1166	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	Number of Ops last 9 Months	3	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	CX0891	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	CX0891	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	CX0891	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	127	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	CX0891	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	CX0891	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	CX0891	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	Amps A Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	Amps B Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	Amps C Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	Fault Operations	0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	CX0891	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	CX0891	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	CX0891	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	CX0891	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	Maintenance Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	General Comments	''	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	Switching Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	Operations This Read Oil	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	Operations Counter AL	127	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	Operations Counter AF	127	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	Number of Ops last 9 Months	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	Maintenance Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	Fault Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	Amps C Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	Amps B Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Readings	Amps A Ø	0.0	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Bushing Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	CX0893	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	BAT001489	Battery	788-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	BAT001489	Battery	788-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	BAT001489	Battery	788-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	BAT001489	Battery	788-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	9 Month Operations	3	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Amps A Ø	0.0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Amps B Ø	0.0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Amps C Ø	0.0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Bushing Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Fault Operations A Ø	0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Fault Operations B Ø	0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Fault Operations C Ø	0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Fault Operations Ground	0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Follow-up Action Required?	n	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	BAT001489	Battery	788-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	BAT001489	Battery	788-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Readings	Totalizer Meter Reading	1.2600	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Readings	Unknown Operations	0	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Tank Leaks	None	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Readings	Switching Operations	1	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Readings	Operations This Read Oil	1	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Readings	Operations Counter AL	2046	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Readings	Operations Counter AF	2046	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Readings	Number of Ops last 9 Months	5	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Readings	Maintenance Operations	0	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Grounds in Place?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Readings	General Comments		
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	General Comments		
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Foundation Condition	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Readings	Follow-up Action Required?	n	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Readings	Fault Operations	0	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Patrol Inspection	Bushing Condition	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Readings	Amps C Ø	40.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Readings	Amps B Ø	60.0	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0012	BreakerOil	930-Offline-Distribution	OCB Readings	Amps A Ø	40.0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	9 Month Operations	1	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Amps A Ø	168.0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Amps B Ø	166.0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0130	BreakerVacuum	825-3	VCB Readings	Amps C Ø	104.0	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	Follow-up Action Required?	n	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	LTCC000589	LTCControl	825-3	LTC Control Insp	VRR Time Delay	30	Seconds
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	CX0893	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	CX0893	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	CX0893	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	CX0893	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	CX0893	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	CX0893	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	68	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	CX0893	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	CX0893	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Readings	LTC Totalizer Reading	30240.00	kw
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Readings	General Comments		
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	General Comments		
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	LTCC000589	LTCControl	825-3	LTC Control Insp	VRR Base Voltage AL	121.0	VAC
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	LTCC000589	LTCControl	825-3	LTC Control Insp	VRR Base Voltage AF	121.0	VAC
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	LTCC000589	LTCControl	825-3	LTC Control Insp	LTC Output Voltage Level	121.0	VAC
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	LTCC000589	LTCControl	825-3	LTC Control Insp	LTC Operation Checked?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	Switching Operations	14	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	Operations This Read Oil	14	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	Operations Counter AL	3856	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	Operations Counter AF	3856	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	Number of Ops last 9 Months	29	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Readings	Maintenance Operations	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Readings	X3 Winding Temp Present	29	°C
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Readings	X3 Winding Temp Max	71	°C
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Readings	X2 Winding Temp Present	29	°C
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Readings	X2 Winding Temp Max	72	°C
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Readings	X1 Winding Temp Present	29	°C
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Readings	X1 Winding Temp Max	73	°C
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Readings	Oil Temp Present	28	°C
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Readings	Oil Temp Max	68	°C
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1600	psi
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000259	WithLTC	899-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	BAT001489	Battery	788-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	BAT001489	Battery	788-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	BAT001489	Battery	788-Battery Bank	Battery Patrol Inspection	General Comments		
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	BAT001489	Battery	788-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	BAT001489	Battery	788-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	BAT001489	Battery	788-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	BAT001489	Battery	788-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	BCH001420	Charger	788-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	BCH001420	Charger	788-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	BCH001420	Charger	788-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	BCH001420	Charger	788-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	BCH001420	Charger	788-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	BCH001420	Charger	788-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	BCH001420	Charger	788-Battery Charger	Battery Charger Patrol Insp	General Comments	throw over not hooked up	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	BCH001420	Charger	788-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	Amps A Ø	270.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	Amps B Ø	290.0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Follow-up Action Required?	n	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Foundation Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	General Comments		
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	General Comments		
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Grounds in Place?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Maintenance Operations	0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Operations Counter AF	184	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Operations Counter AL	184	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Operations This Read Vac	0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Switching Operations	0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Patrol Inspection	Tank Paint Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0100	BreakerVacuum	825-BT2-3	VCB Readings	Unknown Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	Amps C Ø	290.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Readings	Fault Operations	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Operations Counter AF	107	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	Switching Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	Operations This Read Oil	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	Operations Counter AL	1831	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	Operations Counter AF	1831	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	Number of Ops last 9 Months	1	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	Maintenance Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	Fault Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	Amps C Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	Amps B Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Readings	Amps A Ø	0.0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Operations Counter AL	107	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Operations This Read Vac	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Switching Operations	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Unknown Operations	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	9 Month Operations	9	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Amps A Ø	145.0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Amps B Ø	115.0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Amps C Ø	145.0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Fault Operations A Ø	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Fault Operations B Ø	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Fault Operations C Ø	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Fault Operations Ground	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Follow-up Action Required?	n	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Patrol Inspection	General Comments		
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	General Comments		
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Maintenance Operations	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Operations Counter AF	117	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Operations Counter AL	117	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Operations This Read Vac	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Switching Operations	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001486	BreakerVacuum	899-0081	VCB Readings	Unknown Operations	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	9 Month Operations	39	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Amps A Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Amps B Ø	0.0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Amps C Ø	0.0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Amps A Ø	30.0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Amps B Ø	30.0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Amps C Ø	40.0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Unknown Operations	0	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Tank Paint Condition	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Switching Operations	0	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Operations This Read Vac	0	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Operations Counter AL	288	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Operations Counter AF	288	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Maintenance Operations	0	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Grounds in Place?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	General Comments		
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	General Comments		
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Foundation Condition	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Follow-up Action Required?	n	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Follow-up Action Required?	n	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Fault Operations Ground	0	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Fault Operations C Ø	0	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Fault Operations B Ø	0	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Fault Operations A Ø	0	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Patrol Inspection	Bushing Condition	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Amps C Ø	60.0	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Amps B Ø	60.0	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Amps A Ø	60.0	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0162	BreakerVacuum	860-2131	VCB Readings	9 Month Operations	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Fault Operations A Ø	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Fault Operations B Ø	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Fault Operations C Ø	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Fault Operations Ground	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Follow-up Action Required?	n	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Patrol Inspection	General Comments		
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	General Comments		
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	Maintenance Operations	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	LTCM000105	LTCMechanism	899-1	LTC Counter Readings	LTC As Left Counter	1055	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	LTCM000105	LTCMechanism	899-1	LTC Counter Readings	LTC As Found Counter	1055	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	LTCM000105	LTCMechanism	899-1	LTC Mechanism Patrol Inspection	General Comments		
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	LTCM000105	LTCMechanism	899-1	LTC Counter Readings	General Comments		
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	LTCM000105	LTCMechanism	899-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	LTCM000105	LTCMechanism	899-1	LTC Counter Readings	Follow-up Action Required?	n	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	LTCC000866	LTCControl	899-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	LTCC000866	LTCControl	899-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	LTCC000866	LTCControl	899-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	LTCC000866	LTCControl	899-1	LTC Control Insp	LTC Output Voltage Level	123.7	VAC
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	Amps A Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	Amps B Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	Amps C Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	Fault Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	General Comments	..	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	Maintenance Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	Number of Ops last 9 Months	6	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	Operations Counter AF	709	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	Operations Counter AL	709	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	Operations This Read Oil	6	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Readings	Switching Operations	6	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	LTCC000866	LTCCControl	899-1	LTC Control Insp	LTC Operation Checked?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	LTCC000866	LTCCControl	899-1	LTC Control Insp	General Comments		
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	LTCC000866	LTCCControl	899-1	LTC Control Insp	Follow-up Action Required?	n	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	LTCC000866	LTCCControl	899-1	LTC Control Insp	All Connections OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	Switching Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	Operations This Read Oil	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	Operations Counter AL	1311	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	Operations Counter AF	1311	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	Number of Ops last 9 Months	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	Maintenance Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	Fault Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	Amps C Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	Amps B Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Readings	Amps A Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	9 Month Operations	1	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Amps A Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Amps B Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Amps C Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Fault Operations A Ø	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Fault Operations B Ø	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Fault Operations C Ø	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Fault Operations Ground	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Maintenance Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Operations Counter AF	674	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Operations Counter AL	674	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Fault Operations A Ø	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Fault Operations B Ø	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Fault Operations C Ø	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Fault Operations Ground	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Follow-up Action Required?	n	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Patrol Inspection	General Comments		
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	General Comments	open	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Maintenance Operations	30	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Operations Counter AF	130	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Operations Counter AL	130	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Operations This Read Vac	30	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	LTCC000867	LTCCControl	899-2	LTC Control Insp	VRR Time Delay	30	Seconds
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	LTCC000867	LTCCControl	899-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	LTCC000867	LTCCControl	899-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	LTCC000867	LTCCControl	899-2	LTC Control Insp	LTC Output Voltage Level	123.3	VAC
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	LTCC000867	LTCCControl	899-2	LTC Control Insp	LTC Operation Checked?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	LTCC000867	LTCCControl	899-2	LTC Control Insp	General Comments		
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	LTCC000867	LTCCControl	899-2	LTC Control Insp	Follow-up Action Required?	n	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	LTCC000867	LTCCControl	899-2	LTC Control Insp	All Connections OK?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	LTCM000106	LTCMechanism	899-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	LTCM000106	LTCMechanism	899-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	LTCM000106	LTCMechanism	899-2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	LTCM000106	LTCMechanism	899-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	LTCM000106	LTCMechanism	899-2	LTC Counter Readings	LTC Operations Since Last Insp	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	LTCM000106	LTCMechanism	899-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	23	°C
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	LTCM000106	LTCMechanism	899-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	64	°C
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	LTCM000106	LTCMechanism	899-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	LTCM000106	LTCMechanism	899-2	LTC Counter Readings	LTC Min Tap Position	8L	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	LTCM000106	LTCMechanism	899-2	LTC Counter Readings	LTC Max Tap Position	6R	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	LTCM000106	LTCMechanism	899-2	LTC Counter Readings	LTC Current Tap Position	7L	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	LTCM000106	LTCMechanism	899-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	LTCM000106	LTCMechanism	899-2	LTC Counter Readings	LTC As Left Counter	1998	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	LTCM000106	LTCMechanism	899-2	LTC Counter Readings	LTC As Found Counter	1998	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	LTCM000106	LTCMechanism	899-2	LTC Mechanism Patrol Inspection	General Comments		
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	LTCM000106	LTCMechanism	899-2	LTC Counter Readings	General Comments		
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	LTCM000106	LTCMechanism	899-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	LTCM000106	LTCMechanism	899-2	LTC Counter Readings	Follow-up Action Required?	n	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	LTCM000105	LTCMechanism	899-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	LTCM000105	LTCMechanism	899-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	LTCM000105	LTCMechanism	899-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Switching Operations	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001487	BreakerVacuum	899-B1 FUT	VCB Readings	Unknown Operations	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	LTCM000105	LTCMechanism	899-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	LTCM000105	LTCMechanism	899-1	LTC Counter Readings	LTC Operations Since Last Insp	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	LTCM000105	LTCMechanism	899-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	°C
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	LTCM000105	LTCMechanism	899-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	55	°C
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	LTCM000105	LTCMechanism	899-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	LTCM000105	LTCMechanism	899-1	LTC Counter Readings	LTC Min Tap Position	8L	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	LTCM000105	LTCMechanism	899-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	LTCM000105	LTCMechanism	899-1	LTC Counter Readings	LTC Current Tap Position	8L	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	LTCM000105	LTCMechanism	899-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Counter Readings	Follow-up Action Required?	n	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Counter Readings	LTC Operations Since Last Insp	360	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	26	°C
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	30	°C
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Counter Readings	LTC Min Tap Position	4L	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Counter Readings	LTC Max Tap Position	9L	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Counter Readings	LTC Current Tap Position	7L	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Counter Readings	LTC As Left Counter	19817	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Counter Readings	LTC As Found Counter	19814	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Mechanism Patrol Inspection	General Comments		
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Counter Readings	General Comments		
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0051	LTCMechanism	825-2	LTC Counter Readings	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Readings	Switching Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Readings	Operations This Read Oil	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Readings	Operations Counter AL	1159	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Readings	Operations Counter AF	1159	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Readings	Number of Ops last 9 Months	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Readings	Maintenance Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Readings	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Readings	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Readings	Fault Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Readings	Amps C Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Readings	Amps B Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Readings	Amps A Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	Amps A Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	Amps B Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	Amps C Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	Fault Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	Maintenance Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	Number of Ops last 9 Months	29	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	Operations Counter AF	1714	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	Operations Counter AL	1714	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	Operations This Read Oil	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Readings	Switching Operations	0	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	Follow-up Action Required?	n	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Mechanism Patrol Inspection	General Comments		
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	LTC As Found Counter	26248	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	LTC As Left Counter	26250	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	LTC Current Tap Position	5L	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	LTC Max Tap Position	11L	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	LTC Min Tap Position	3L	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	LTC Operations Since Last Insp	773	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	C0455	LTCMechanism	788-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Counter Readings	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	9 Month Operations	1	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Amps A Ø	49.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Amps B Ø	50.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Amps C Ø	50.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Fault Operations A Ø	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Fault Operations B Ø	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Fault Operations C Ø	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Fault Operations Ground	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Maintenance Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Operations Counter AF	841	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Operations Counter AL	841	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Operations This Read Vac	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Switching Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0743	BreakerVacuum	P-1393-1	VCB Readings	Unknown Operations	0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	General Comments		
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	CH000350	ControlHouse	825-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Counter Readings	LTC Operations Since Last Insp	417	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	°C
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	36	°C
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Counter Readings	LTC Min Tap Position	6L	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Counter Readings	LTC Max Tap Position	11L	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Counter Readings	LTC Current Tap Position	8L	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Counter Readings	LTC As Left Counter	20765	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Counter Readings	LTC As Found Counter	20762	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Mechanism Patrol Inspection	General Comments		
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0052	LTCMechanism	825-3	LTC Counter Readings	General Comments		
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	Amps A Ø	0.0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	Amps B Ø	0.0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	Amps C Ø	0.0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	Fault Operations A Ø	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	Fault Operations B Ø	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	Fault Operations C Ø	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	Fault Operations Ground	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	Follow-up Action Required?	n	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Patrol Inspection	General Comments		
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	General Comments	open	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	Maintenance Operations	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	Operations Counter AF	93	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	Operations Counter AL	93	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	Operations This Read Vac	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	Switching Operations	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	Unknown Operations	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	9 Month Operations	9	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Amps A Ø	160.0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Amps B Ø	150.0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Amps C Ø	120.0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Fault Operations A Ø	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Fault Operations B Ø	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Fault Operations C Ø	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Fault Operations Ground	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Follow-up Action Required?	n	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Patrol Inspection	General Comments		
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	General Comments		
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Maintenance Operations	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Operations Counter AF	103	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Operations Counter AL	103	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Operations This Read Vac	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Switching Operations	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001484	BreakerVacuum	899-0073	VCB Readings	Unknown Operations	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001485	BreakerVacuum	899-0114	VCB Readings	9 Month Operations	9	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Counter Readings	General Comments		
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Mechanism Patrol Inspection	General Comments		
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Counter Readings	LTC As Found Counter	142630	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Counter Readings	LTC As Left Counter	142633	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Counter Readings	LTC Current Tap Position	6L	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Counter Readings	LTC Max Tap Position	6L	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Counter Readings	LTC Min Tap Position	9L	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Counter Readings	LTC Operations Since Last Insp	228	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0456	LTCMechanism	860-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	Amps A Ø	270.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	Amps B Ø	290.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	Amps C Ø	320.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	Fault Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	Maintenance Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	Number of Ops last 9 Months	12	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	Operations Counter AF	1479	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	Operations Counter AL	1479	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	Operations This Read Oil	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Readings	Switching Operations	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	9 Month Operations	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Amps A Ø	315.0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Amps B Ø	285.0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Amps C Ø	300.0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Fault Operations A Ø	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Fault Operations B Ø	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Fault Operations C Ø	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Fault Operations Ground	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Follow-up Action Required?	n	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Patrol Inspection	General Comments		
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	General Comments		
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Maintenance Operations	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Operations Counter AF	111	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Operations Counter AL	111	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Operations This Read Vac	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Switching Operations	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001482	BreakerVacuum	899-1	VCB Readings	Unknown Operations	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	9 Month Operations	9	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001483	BreakerVacuum	899-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	LTCC000345	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	Follow-up Action Required?	n	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Patrol Inspection	General Comments		
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Readings	Switching Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Readings	Operations This Read Oil	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Readings	Operations Counter AL	1060	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Readings	Operations Counter AF	1060	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Readings	Number of Ops last 9 Months	10	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Readings	Maintenance Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Readings	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Readings	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Readings	Fault Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Readings	Amps C Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Readings	Amps B Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Readings	Amps A Ø	0.0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	Maintenance Operations	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	Operations Counter AF	91	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	Operations Counter AL	91	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	Operations This Read Vac	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	Switching Operations	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	Unknown Operations	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Readings	9 Month Operations	7	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Readings	Amps A Ø	100.0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Readings	Amps B Ø	110.0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Readings	Amps C Ø	105.0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Readings	Fault Operations A Ø	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Readings	Fault Operations B Ø	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Readings	Fault Operations C Ø	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Readings	Fault Operations Ground	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Readings	Follow-up Action Required?	n	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Patrol Inspection	General Comments		
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Readings	General Comments		
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Readings	Maintenance Operations	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Readings	Operations Counter AF	101	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Readings	Operations Counter AL	101	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Readings	Operations This Read Vac	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Readings	Switching Operations	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001536	BreakerVacuum	899-0197	VCB Readings	Unknown Operations	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	9 Month Operations	5	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	General Comments		
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	General Comments		
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Foundation Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Follow-up Action Required?	n	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Follow-up Action Required?	n	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Fault Operations Ground	0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Fault Operations C Ø	0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Fault Operations B Ø	0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Fault Operations A Ø	0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Bushing Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Amps C Ø	219.0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Amps B Ø	233.0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Amps A Ø	141.0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	9 Month Operations	1	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Readings	Maintenance Operations	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Readings	Operations Counter AF	127	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Readings	Operations Counter AL	127	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Readings	Operations This Read Vac	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Readings	Switching Operations	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Readings	Unknown Operations	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	9 Month Operations	6	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	LTCC000345	LTCCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	LTCC000345	LTCCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	LTCC000345	LTCCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	LTCC000345	LTCCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	LTCC000345	LTCCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	LTCC000345	LTCCControl	Retired Distribution	LTC Control Insp	General Comments		
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	Amps A Ø	90.0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	Amps B Ø	90.0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	Amps C Ø	85.0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	Fault Operations A Ø	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	Fault Operations C Ø	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001535	BreakerVacuum	899-0137	VCB Readings	Fault Operations Ground	0	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	LTCC000345	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	SWG000220	Switchgear	899-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	SWG000220	Switchgear	899-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	SWG000220	Switchgear	899-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	SWG000220	Switchgear	899-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	SWG000220	Switchgear	899-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	SWG000220	Switchgear	899-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	SWG000220	Switchgear	899-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	SWG000220	Switchgear	899-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	SWG000220	Switchgear	899-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	SWG000220	Switchgear	899-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	SWG000220	Switchgear	899-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	SWG000220	Switchgear	899-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	SWG000220	Switchgear	899-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	SWG000220	Switchgear	899-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	SWG000220	Switchgear	899-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	SWG000220	Switchgear	899-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	SWG000220	Switchgear	899-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	SWG000220	Switchgear	899-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	SWG000221	Switchgear	899-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	SWG000221	Switchgear	899-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	SWG000221	Switchgear	899-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	SWG000221	Switchgear	899-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	SWG000221	Switchgear	899-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	SWG000221	Switchgear	899-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	SWG000221	Switchgear	899-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	SWG000221	Switchgear	899-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	SWG000221	Switchgear	899-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	SWG000221	Switchgear	899-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	SWG000221	Switchgear	899-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	SWG000221	Switchgear	899-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	SWG000221	Switchgear	899-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	SWG000221	Switchgear	899-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	SWG000221	Switchgear	899-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	SWG000221	Switchgear	899-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	SWG000221	Switchgear	899-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	9 Month Operations	1	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Amps A Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Amps B Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Amps C Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Fault Operations A Ø	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Fault Operations B Ø	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Fault Operations C Ø	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Fault Operations Ground	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Maintenance Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Operations Counter AF	1141	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Operations Counter AL	1141	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Operations This Read Vac	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Switching Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Readings	Unknown Operations	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	371	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	371	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	12	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Readings	General Comments		
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Amps A Ø	0.0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Amps B Ø	0.0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Amps C Ø	0.0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Fault Operations A Ø	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Fault Operations B Ø	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Fault Operations C Ø	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Fault Operations Ground	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Follow-up Action Required?	n	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Patrol Inspection	General Comments		
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	General Comments	open	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Maintenance Operations	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Operations Counter AF	100	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Operations Counter AL	100	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	10.0	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	10.0	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0114	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	10.0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Operations This Read Vac	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Switching Operations	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001537	BreakerVacuum	899-B2 FUT	VCB Readings	Unknown Operations	0	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	LTCC000904	LTCControl	788-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	LTCC000904	LTCControl	788-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	LTCC000904	LTCControl	788-2	LTC Control Insp	VRR Time Delay	30	Seconds
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Regulator As Left Counter	7305	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001532	BreakerVacuum	899-2	VCB Readings	9 Month Operations	7	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001532	BreakerVacuum	899-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001532	BreakerVacuum	899-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001532	BreakerVacuum	899-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001532	BreakerVacuum	899-2	VCB Readings	Amps A Ø	278.0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001532	BreakerVacuum	899-2	VCB Readings	Amps B Ø	250.0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001532	BreakerVacuum	899-2	VCB Readings	Amps C Ø	240.0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001532	BreakerVacuum	899-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001532	BreakerVacuum	899-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001532	BreakerVacuum	899-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001532	BreakerVacuum	899-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001532	BreakerVacuum	899-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	BCH000587	Charger	825-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	BCH000587	Charger	825-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	BCH000587	Charger	825-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	BCH000587	Charger	825-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	BCH000587	Charger	825-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	BCH000587	Charger	825-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001532	BreakerVacuum	899-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001532	BreakerVacuum	899-2	VCB Readings	Fault Operations A Ø	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001532	BreakerVacuum	899-2	VCB Readings	Fault Operations B Ø	0	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Max Tap Position	3L	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	General Comments		
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	BCH000587	Charger	825-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Current Tap Position	6L	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	RG000072	Regulator	860-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Regulator As Left Counter	7726	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Operations This Read Vac	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Switching Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Readings	Unknown Operations	0	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	General Comments		
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	FE000866	Fence	788-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	Winding Temp Present	35	°C
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	Winding Temp Max	35	°C
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	Totalizer Meter Reading	.8340	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	Oil Temp Present	20	°C
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	Oil Temp Max	30	°C
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	LTC Totalizer Reading	12009.60	kw
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	General Comments		
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	General Comments		
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	Follow-up Action Required?	n	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0052	WithLTC	825-3	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	LTCC000904	LTCControl	788-2	LTC Control Insp	All Connections OK?	y	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	LTCC000904	LTCControl	788-2	LTC Control Insp	Follow-up Action Required?	n	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	LTCC000904	LTCControl	788-2	LTC Control Insp	General Comments		
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	LTCC000904	LTCControl	788-2	LTC Control Insp	LTC Operation Checked?	y	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	LTCC000904	LTCControl	788-2	LTC Control Insp	LTC Output Voltage Level	123.4	VAC
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Readings	Operations Counter AL	101	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Readings	Operations This Read Vac	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Readings	Switching Operations	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001533	BreakerVacuum	899-BT2-1	VCB Readings	Unknown Operations	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Readings	9 Month Operations	8	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Readings	Amps A Ø	110.0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Readings	Amps B Ø	65.0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Readings	Amps C Ø	65.0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Readings	Fault Operations A Ø	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Readings	Fault Operations B Ø	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Readings	Fault Operations C Ø	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Readings	Fault Operations Ground	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Readings	Follow-up Action Required?	n	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Patrol Inspection	General Comments		
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Readings	General Comments		
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	BK001534	BreakerVacuum	899-0072	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Regulator As Left Counter	6226	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Max Tap Position	3L	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	General Comments		
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	RG000070	Regulator	860-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Unknown Operations	0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Tank Paint Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Switching Operations	0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Operations This Read Vac	0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Operations Counter AL	115	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Operations Counter AF	115	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Readings	Maintenance Operations	0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0002	BreakerVacuum	825-0177	VCB Patrol Inspection	Grounds in Place?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Max Tap Position	2L	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	RG000071	Regulator	860-1 B	Regulator Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	9 Month Operations	1	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Amps C Ø	13.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Amps B Ø	13.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Amps A Ø	13.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	9 Month Operations	1	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	General Comments		
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	Totalizer Meter Reading	.4556	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Fault Operations A Ø	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Fault Operations B Ø	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Fault Operations C Ø	0	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Operations This Read Vac	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Operations Counter AL	747	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0456	WithLTC	860-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Operations Counter AF	747	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Maintenance Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Fault Operations Ground	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Maintenance Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Operations Counter AF	156	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Operations Counter AL	156	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Operations This Read Vac	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Switching Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Fault Operations Ground	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Fault Operations C Ø	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Fault Operations B Ø	0	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Ambient Temp	55	*F
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Fault Operations Ground	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Fault Operations C Ø	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Fault Operations B Ø	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Fault Operations A Ø	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Unknown Operations	0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Switching Operations	0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Operations This Read Vac	0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Operations Counter AL	163	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Operations Counter AF	163	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Maintenance Operations	0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Grounds in Place?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	General Comments		
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	General Comments		
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Patrol Inspection	Foundation Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KB0128	BreakerVacuum	825-2	VCB Readings	Follow-up Action Required?	n	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Vegetation	None	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	General Comments		
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Unknown Operations	0	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Tank Paint Condition	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Switching Operations	0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	ST000549	Structure	825-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Operations This Read Vac	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	Amps A Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	Amps B Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	Amps C Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	Fault Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	Maintenance Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	Number of Ops last 9 Months	1	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	Operations Counter AF	827	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	Operations Counter AL	827	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	Operations This Read Oil	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Readings	Switching Operations	0	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Operations Counter AL	35	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Operations Counter AF	35	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Maintenance Operations	0	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	General Comments		
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	General Comments		
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Foundation Condition	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Follow-up Action Required?	n	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Follow-up Action Required?	n	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Fault Operations Ground	0	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Fault Operations C Ø	0	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Fault Operations B Ø	0	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Fault Operations A Ø	0	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	General Comments		
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Fault Operations A Ø	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Amps C Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Amps B Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Amps A Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	9 Month Operations	1	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	ST000446	Structure	788-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	FE000539	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Ambient Temp	70	*F
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	General Comments		
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	YD000545	Yard	825-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Readings	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Readings	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Readings	Fault Operations	0	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1962	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Readings	Amps C Ø	250.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Readings	Amps B Ø	240.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Readings	Amps A Ø	230.0	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	6	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	General Comments		
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	General Comments		
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0533	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Fault Operations Ground	0	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Follow-up Action Required?	n	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Follow-up Action Required?	n	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Foundation Condition	Good	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	General Comments		
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	General Comments		
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Grounds in Place?	y	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Maintenance Operations	0	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Operations Counter AF	252	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Operations Counter AL	252	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Operations This Read Vac	18	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Switching Operations	18	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Tank Paint Condition	Good	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Unknown Operations	0	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	40.0	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	40.0	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	40.0	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Readings	General Comments		
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	8	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1177	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Vegetation	None	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	YD000377	Yard	899-Yard	Yard Patrol Inspection	General Comments		
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1177	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	9 Month Operations	2	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Unknown Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0764	BreakerVacuum	P-GND TR 1	VCB Readings	Switching Operations	0	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	CB0093	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Amps A Ø	77.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Amps B Ø	78.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Amps C Ø	77.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	Operations Counter AL	3249	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	Operations Counter AF	3249	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	Number of Ops last 9 Months	1	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	Maintenance Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	General Comments	„	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	Fault Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	Amps C Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	Amps B Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Readings	Amps A Ø	0.0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	R1274	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	General Comments		
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	R1274	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	R1274	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	R1274	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	R1274	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	R1274	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	R1274	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	60.0	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	100.0	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0011	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	60.0	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	9 Month Operations	22	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Amps A Ø	140.0	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Amps B Ø	140.0	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Amps C Ø	120.0	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Bushing Condition	Good	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	LTC Totalizer Reading	4373.76	kw
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	Oil Temp Max	60	°C
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Readings	Oil Temp Present	40	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	C0455	WithLTC	788-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Fault Operations A Ø	0	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Fault Operations B Ø	0	
10/15/2020 11:28	Distribution	Lebanon City Quarterly Inspection	K0165	BreakerVacuum	788-2216	VCB Readings	Fault Operations C Ø	0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Tank Paint Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Unknown Operations	0	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	General Comments		
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	General Comments		
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Switching Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Operations This Read Vac	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Operations Counter AL	37	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Operations Counter AF	37	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5860	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Maintenance Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Fault Operations Ground	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Fault Operations C Ø	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Fault Operations B Ø	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Fault Operations A Ø	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Readings	Amps A Ø	1000.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Readings	Amps B Ø	1000.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Readings	Amps C Ø	1000.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Readings	Fault Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Readings	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Readings	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Readings	Maintenance Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Readings	Number of Ops last 9 Months	5	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Readings	Operations Counter AF	1164	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Readings	Operations Counter AL	1164	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Readings	Operations This Read Oil	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Readings	Switching Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Amps C Ø	245.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Amps B Ø	248.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Amps A Ø	243.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	67.0	VDC
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	65.0	VDC
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	BAT000584	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Readings	9 Month Operations	2	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Switching Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Operations This Read Vac	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Operations Counter AL	95	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Operations Counter AF	95	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Maintenance Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Follow-up Action Required?	n	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Readings	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Readings	Fault Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Readings	Amps C Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Readings	Amps B Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Readings	Amps A Ø	0.0	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	9 Month Operations	2	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Amps A Ø	173.0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Amps B Ø	169.0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Amps C Ø	100.0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Bushing Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0534	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Fault Operations A Ø	0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Fault Operations B Ø	0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Fault Operations C Ø	0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Fault Operations Ground	0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Follow-up Action Required?	n	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Follow-up Action Required?	n	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Foundation Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	General Comments		
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	General Comments		
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Grounds in Place?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Maintenance Operations	0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Operations Counter AF	127	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Operations Counter AL	127	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Operations This Read Vac	0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	K0024	BreakerVacuum	825-0176	VCB Readings	Switching Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Fault Operations Ground	0	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1875.20	kw
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	217.50	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	200.00	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	General Comments		
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Vegetation	None	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Arching Horns Good Condition?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	General Comments		
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	ST000536	Structure	860-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	General Comments		
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Readings	General Comments		
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Readings	LTC Totalizer Reading	25680.00	kw
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1600	psi
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Readings	Oil Temp Max	64	°C
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Readings	Oil Temp Present	28	°C
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/6/2020 5:53	Distribution	Wilson Downing Quarterly Inspection	TX000258	WithLTC	899-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	Amps A Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	Amps B Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	Amps C Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	Fault Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	General Comments	,,	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	Maintenance Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	Number of Ops last 9 Months	2	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	Amps A Ø	98.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	Amps B Ø	101.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	Amps C Ø	99.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	Fault Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	Operations Counter AF	1481	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	Maintenance Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	Number of Ops last 9 Months	4	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	Operations Counter AF	977	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	Operations Counter AL	977	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	Operations Counter AL	1481	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	Operations This Read Oil	1	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	Operations This Read Oil	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	Switching Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Readings	Unknown Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Readings	Switching Operations	1	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	Amps A Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	Amps B Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	Amps C Ø	0.0	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	General Comments		
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	FE000527	Fence	860-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Ambient Temp	70	*F
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	YD000532	Yard	860-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	Fault Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	Maintenance Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	Number of Ops last 9 Months	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	Operations Counter AF	5489	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	Operations Counter AL	5489	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	Operations This Read Oil	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Readings	Switching Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	9 Month Operations	1	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Amps A Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Amps B Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Amps C Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Fault Operations A Ø	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Readings	Fault Operations B Ø	0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	LTCC000069	LTCControl	825-2	LTC Control Insp	VRR Time Delay	30	Seconds
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	Amps A Ø	0.0	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Bushing Condition	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	Amps B Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	Amps C Ø	0.0	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	C0336	NonLTC	860-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	Fault Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	Amps C Ø	0.0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Readings	Switching Operations	0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	SF6 Pressure	70	psi
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Readings	Operations This Read SF6	0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Readings	Operations Counter AL	82	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Readings	Operations Counter AF	82	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Readings	Num Operations Last 9 Months	1	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Foundation Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Gauge(s) Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	Maintenance Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	Number of Ops last 9 Months	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	Operations Counter AF	1165	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	Operations Counter AL	1165	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	Operations This Read Oil	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	Switching Operations	0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	General Comments		
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Readings	General Comments		
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Grounds in Place?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Heaters (All) Functioning?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Readings	Maintenance Operations	0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Moisture and Leak Free?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Readings	Num Operations Last 9 Months	1	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Readings	Operations Counter AF	81	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Readings	Operations Counter AL	81	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Readings	Operations This Read SF6	0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	SF6 Bushing Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	SF6 Pressure	66	psi
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Readings	Switching Operations	0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	LTCC000069	LTCControl	825-2	LTC Control Insp	LTC Operation Checked?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	LTCC000069	LTCControl	825-2	LTC Control Insp	General Comments		
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	LTCC000069	LTCControl	825-2	LTC Control Insp	Follow-up Action Required?	n	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	LTCC000069	LTCControl	825-2	LTC Control Insp	All Connections OK?	y	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	9 Month Operations	1	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Readings	Follow-up Action Required?	n	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Follow-up Action Required?	n	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Readings	Fault Operations	0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Equipment Properly Labeled?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Cabinet Paint Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Amps A Ø	120.0	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Amps B Ø	120.0	
10/15/2020 14:48	Distribution	Harrodsburg East Quarterly Inspection	CB0161	BreakerVacuum	860-2130	VCB Readings	Amps C Ø	120.0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Bushings Connection/Risers	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Ambient Temperature	70	*F
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	LTCC000069	LTCControl	825-2	LTC Control Insp	LTC Output Voltage Level	120.9	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	LTCC000069	LTCControl	825-2	LTC Control Insp	VRR Base Voltage AF	121.0	VAC
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	LTCC000069	LTCControl	825-2	LTC Control Insp	VRR Base Voltage AL	121.0	VAC
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	Winding Temp Max	32	°C
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	Winding Temp Present	32	°C
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	Totalizer Meter Reading	.2368	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Readings	Follow-up Action Required?	n	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Follow-up Action Required?	n	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Readings	Fault Operations	0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	TB1480	BreakerSF6	825-608	GCB Patrol Inspection	Tank Paint Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Ambient Temperature	70	°F
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	Fault Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	Follow-up Action Required?	n	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	General Comments		
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	General Comments		
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	LTC Totalizer Reading	3409.92	kw
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	Oil Temp Max	32	°C
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Readings	Oil Temp Present	29	°C
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Readings	Maintenance Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Readings	General Comments		
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Readings	Maintenance Operations	0	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Heaters (All) Functioning?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Grounds in Place?	y	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Readings	General Comments		
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	KT0051	WithLTC	825-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	General Comments		
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	TB1479	BreakerSF6	825-618	GCB Patrol Inspection	Foundation Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Readings	Number of Ops last 9 Months	1	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Readings	Operations Counter AF	847	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Readings	Operations Counter AL	847	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Readings	Operations This Read Oil	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	Amps A Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Readings	Amps B Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Readings	Switching Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/15/2020 15:27	Distribution	Corning 12kV Quarterly Inspection	C0535	NonLTC	920-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	Operations This Read Oil	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	Operations Counter AL	120	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	Operations Counter AF	120	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	Number of Ops last 9 Months	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	Maintenance Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Readings	General Comments		
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Reading	.4200	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Present	30	°C
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Max	50	°C
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	LTC Totalizer Reading	4032.00	kw
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	General Comments		
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	B0349	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	LTCC000909	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	LTCC000909	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	LTCC000909	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	LTCC000909	LTCControl	932-Offline Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	LTCC000909	LTCControl	932-Offline Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	LTCC000909	LTCControl	932-Offline Distribution	LTC Control Insp	LTC Operation Checked?	y	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	LTCC000909	LTCControl	932-Offline Distribution	LTC Control Insp	General Comments		
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	LTCC000909	LTCControl	932-Offline Distribution	LTC Control Insp	Follow-up Action Required?	n	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	LTCC000909	LTCControl	932-Offline Distribution	LTC Control Insp	All Connections OK?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	n	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	n	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	3041	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	28	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Maintenance Operations	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	General Comments		
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Patrol Inspection	General Comments		
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Follow-up Action Required?	n	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Operations Counter AL	99968	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Operations This Read AM	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Switching Operations	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Unknown Operations	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	General Comments	Cabinet heater not working	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Amps B Ø	112.0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Amps A Ø	115.0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	9 Month Operations	1	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	Oil Temp Max	70	°C
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	Oil Temp Present	45	°C
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	35	°C
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	60	°C
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	40	°C
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LTCC000538	LTCControl	CY-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LTCC000538	LTCControl	CY-TRANS 1	LTC Control Insp	General Comments		
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LTCC000538	LTCControl	CY-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	38	°C
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	65	°C
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	60	°C
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Unknown Operations	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Switching Operations	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Operations This Read Vac	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Operations Counter AL	167	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	Top Oil Temperature Max	61	°C
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Operations Counter AF	167	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	SWG000005	Switchgear	CY-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	45	°C
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	70	°C
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	38	°C
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	Top Oil Temperature Present	37	°C
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	65	°C
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	38	°C
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	65	°C
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Fault Operations Ground	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Fault Operations C ∅	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Fault Operations B ∅	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Fault Operations A ∅	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0184	BreakerVacuum	CY-1482	VCB Readings	Amps C ∅	110.0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	General Comments		
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	FE000807	Fence	459-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	9 Months Operations	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Amps A ∅	0.0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Amps B ∅	0.0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Amps C ∅	0.0	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Counter Readings	LTC Min Tap Position	10L	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4R	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Counter Readings	LTC Current Tap Position	7L	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Counter Readings	LTC As Left Counter	388424	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Counter Readings	LTC As Found Counter	388424	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Counter Readings	General Comments		
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Fault Operations A ∅	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Fault Operations B ∅	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Fault Operations C ∅	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Fault Operations Ground	0	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	PN56	LTCMechanism	GI-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Follow-up Action Required?	n	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Patrol Inspection	General Comments		
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1400	psi
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	Oil Temp Max	61	°C
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Readings	Oil Temp Present	37	°C
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	TX000165	WithLTC	CY-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0096	WithLTC	HB-TRANS 1	LTC Transformer Readings	General Comments		
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	General Comments		
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Maintenance Operations	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0188	BreakerAirMagnetic	CY-1488	AMCB Readings	Operations Counter AF	99968	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	General Comments		
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	General Comments		
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	ST000524	Structure	446-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	296	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	296	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C ∅	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B ∅	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A ∅	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	%
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	%
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	%
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C ∅	256.0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B ∅	268.0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A ∅	269.0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0194	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	12	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	Follow-up Action Required?	n	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	General Comments		
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Mechanism Patrol Inspection	General Comments		
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	LTC As Found Counter	11552	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	LTC As Left Counter	11552	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	LTC Current Tap Position	7L	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	LTC Min Tap Position	7L	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	LTC Operations Since Last Insp	676	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	PF000173	PowerFuse	HB-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	PF000173	PowerFuse	HB-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	PF000172	PowerFuse	HB-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	PF000172	PowerFuse	HB-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	PF000171	PowerFuse	HB-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	PF000171	PowerFuse	HB-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	PF000170	PowerFuse	HB-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	PF000170	PowerFuse	HB-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Vegetation	None	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	General Comments		
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	YD000504	Yard	420-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	General Comments		
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	CH000108	ControlHouse	420-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	PF000074	PowerFuse	CY-14KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	PF000074	PowerFuse	CY-14KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	PF000073	PowerFuse	CY-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	PF000073	PowerFuse	CY-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	PF000072	PowerFuse	CY-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	PF000072	PowerFuse	CY-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	420.0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	420.0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	420.0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	99966	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	99966	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0193	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	FE000515	Fence	446-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1587	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1587	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	129.0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	136.0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	130.0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0494	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Readings	General Comments		
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Readings	LV Winding Temp Max	-60	°C
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Readings	LV Winding Temp Present	-60	°C
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-5	psi
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Readings	Oil Temp Max	50	°C
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Readings	Oil Temp Present	28	°C
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	PN56	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	PNS6	WithLTC	GI-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	General Comments	2 4ft bulbs not working, replaced bulbs and nothing happened. Unit heater in 12kv TR1 breaker cab not working, checked voltage and	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	n	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	SWG000009	Switchgear	HB-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	LTCC000907	LTCControl	446-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	LTCC000907	LTCControl	446-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	LTCC000907	LTCControl	446-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	LTCC000907	LTCControl	446-1	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	LTCC000907	LTCControl	446-1	LTC Control Insp	LTC Operation Checked?	y	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	LTCC000907	LTCControl	446-1	LTC Control Insp	General Comments		
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	LTCC000907	LTCControl	446-1	LTC Control Insp	Follow-up Action Required?	n	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	LTCC000907	LTCControl	446-1	LTC Control Insp	All Connections OK?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	B0293	LTCMechanism	420-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	9 Month Operations	2	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Amps A Ø	132.0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Amps B Ø	129.0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Amps C Ø	130.0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Fault Adjusted Amps A Phase V	8.00	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Fault Adjusted Amps B Phase V	8.00	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Fault Adjusted Amps C Phase V	8.00	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Fault Operations A Ø	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Fault Operations B Ø	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Fault Operations C Ø	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Fault Operations Ground	1	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Follow-up Action Required?	n	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Patrol Inspection	General Comments		
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	General Comments	GND TOC	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Maintenance Operations	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Operations Counter AF	250	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Operations Counter AL	250	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Operations This Read Vac	1	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Switching Operations	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB1289	BreakerVacuum	CY-1484	VCB Readings	Unknown Operations	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	General Comments		
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	Oil Temp Max	60	°C
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	Oil Temp Present	40	°C
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	75	°C
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	45	°C
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	60	°C
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	40	°C
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	45	°C
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0095	WithLTC	HB-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	45	°C
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	SWG000010	Switchgear	HB-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	9 Months Operations	3	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Amps A Ø	120.0	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Amps B Ø	30.0	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Amps C Ø	250.0	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Fault Operations A Ø	0	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Fault Operations B Ø	0	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Fault Operations C Ø	0	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Fault Operations Ground	0	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Follow-up Action Required?	n	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Patrol Inspection	General Comments		
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	General Comments		
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Maintenance Operations	0	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Operations Counter AF	546	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Operations Counter AL	546	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Operations This Read AM	0	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Switching Operations	0	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0389	BreakerAirMagnetic	GI-3	AMCB Readings	Unknown Operations	0	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	General Comments		
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Ambient Temp	72	°F
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	General Comments		
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	General Comments		
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	General Comments		
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Switching Operations	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Unknown Operations	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Unknown Operations	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Patrol Inspection	Tank Paint Condition	Good	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Switching Operations	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Operations This Read Vac	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Operations Counter AL	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Operations Counter AF	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Maintenance Operations	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	General Comments		
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Patrol Inspection	General Comments		
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Follow-up Action Required?	n	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Fault Operations Ground	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Fault Operations C Ø	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Fault Operations B Ø	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Fault Operations A Ø	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Patrol Inspection	Bushing Condition	Good	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Amps C Ø	0.0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Amps B Ø	0.0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Amps A Ø	0.0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001141	BreakerVacuum	428-BT2-1	VCB Readings	9 Month Operations	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Unknown Operations	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Switching Operations	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Operations This Read Vac	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Operations Counter AL	115	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Operations Counter AF	115	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Maintenance Operations	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	General Comments		
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Patrol Inspection	General Comments		
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Follow-up Action Required?	n	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Fault Operations Ground	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Fault Operations C Ø	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Fault Operations B Ø	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Fault Operations A Ø	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Amps C Ø	0.0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Amps B Ø	0.0	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	FE000352	Fence	667-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	9 Month Operations	1	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Unknown Operations	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Switching Operations	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	950	psi
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	Oil Temp Max	30	°C
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	Oil Temp Present	30	°C
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	Totalizer Meter Multiplier	1000	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	Totalizer Meter Reading	3.5400	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	Winding Temp Max	30	°C
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	Winding Temp Present	30	°C
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Operations This Read Vac	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Operations Counter AL	177	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Operations Counter AF	177	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Maintenance Operations	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	General Comments		
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Patrol Inspection	General Comments		
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Follow-up Action Required?	n	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Fault Operations Ground	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Fault Operations C Ø	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Fault Operations B Ø	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Fault Operations A Ø	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Counter Readings	Follow-up Action Required?	n	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Counter Readings	General Comments		
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Mechanism Patrol Inspection	General Comments		
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Counter Readings	LTC As Found Counter	22610	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Counter Readings	LTC As Left Counter	22610	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Amps C Ø	200.0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Amps B Ø	220.0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Amps A Ø	195.0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001138	BreakerVacuum	459-2	VCB Readings	9 Month Operations	1	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	LTCC000392	LTCControl	420-1	LTC Control Insp	All Connections OK?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	LTCC000392	LTCControl	420-1	LTC Control Insp	Follow-up Action Required?	n	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	LTCC000392	LTCControl	420-1	LTC Control Insp	General Comments		
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	LTCC000392	LTCControl	420-1	LTC Control Insp	LTC Operation Checked?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	LTCC000392	LTCControl	420-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	Kwh Reading	35720	Kwh
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	LTC Totalizer Reading	3540.00	kw
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Unknown Operations	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Switching Operations	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Operations This Read Vac	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Operations Counter AL	340	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Operations Counter AF	340	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Maintenance Operations	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	General Comments		
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Patrol Inspection	General Comments		
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Follow-up Action Required?	n	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Fault Operations Ground	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Fault Operations C Ø	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Fault Operations B Ø	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Fault Operations A Ø	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Amps C Ø	90.0	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	YD000358	Yard	667-Yard	Yard Patrol Inspection	Vegetation	None	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Amps B Ø	90.0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Amps A Ø	90.0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0183	BreakerVacuum	CY-1481	VCB Readings	9 Month Operations	1	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	General Comments		
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	ST000361	Structure	667-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	MegaVar Demand Meter Max	0.00	MegaVars
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Readings	MegaWatt Demand Meter Max	0.00	MegaWatts
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000021	WithLTC	459-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Amps A Ø	0.0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001140	BreakerVacuum	459-BT2-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	General Comments		
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	General Comments		
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	9 Month Operations	7	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Amps A Ø	0.0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Amps B Ø	0.0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Amps C Ø	0.0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Bushing Condition	Good	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Fault Operations A Ø	0	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Foundation Condition	Good	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Follow-up Action Required?	n	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Follow-up Action Required?	n	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Fault Operations B Ø	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Fault Operations C Ø	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Fault Operations Ground	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Follow-up Action Required?	n	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Foundation Condition	Good	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	General Comments		
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	General Comments		
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Grounds in Place?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Fault Operations Ground	0	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Fault Operations C Ø	1	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Fault Operations B Ø	0	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Fault Operations A Ø	1	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Fault Adjusted Amps C Phase V	4.56	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Fault Adjusted Amps A Phase V	4.56	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Bushing Condition	Good	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Amps C Ø	40.0	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Amps B Ø	25.0	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Amps A Ø	15.0	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	9 Month Operations	4	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	General Comments	bushes coming through fence, pic sent to stinson	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	FE000562	Fence	HB-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Fault Operations B Ø	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Fault Operations A Ø	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Amps C Ø	70.0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Amps B Ø	70.0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Amps A Ø	72.0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	9 Month Operations	1	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Fault Operations C Ø	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Fault Operations Ground	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Follow-up Action Required?	n	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Patrol Inspection	General Comments		
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	General Comments		
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Maintenance Operations	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Operations Counter AF	173	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Operations Counter AL	173	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Operations This Read Vac	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Switching Operations	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0185	BreakerVacuum	CY-1483	VCB Readings	Unknown Operations	0	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Unknown Operations	0	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Tank Paint Condition	Good	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Switching Operations	0	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Operations This Read Vac	2	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Operations Counter AL	200	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Operations Counter AF	200	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Readings	Maintenance Operations	0	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	BK000831	BreakerVacuum	667-0046	VCB Patrol Inspection	Grounds in Place?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	SWG000099	Switchgear	CY-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	6	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	2319	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	2319	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	497	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	497	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0195	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	9 Months Operations	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Amps A Ø	0.0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Amps B Ø	0.0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Amps C Ø	0.0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Fault Operations A Ø	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Fault Operations B Ø	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Fault Operations C Ø	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Fault Operations Ground	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Follow-up Action Required?	n	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Patrol Inspection	General Comments		
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	General Comments		
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Maintenance Operations	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Operations Counter AF	433	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Operations Counter AL	433	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0189	BreakerAirMagnetic	CY-1489	AMCB Readings	Operations This Read AM	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUSTIE SEC 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	712	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Counter Readings	LTC Min Tap Position	3R	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Counter Readings	LTC Max Tap Position	14R	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6R	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Counter Readings	LTC As Left Counter	256925	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Counter Readings	LTC As Found Counter	256925	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Counter Readings	General Comments		
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0053	LTCMechanism	CY-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Operations Counter AF	138	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Operations Counter AL	138	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Operations This Read Vac	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Switching Operations	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Patrol Inspection	Tank Paint Condition	Good	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000864	BreakerVacuum	HB-12KV BUS TIE SEC 1	VCB Readings	Unknown Operations	0	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	10.0	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	10.0	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	10.0	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	General Comments		
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	ST000556	Structure	550-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	CB0002	BreakerOil	Retired Distribution	OCB Readings	General Comments		
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Amps C Ø	85.0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Amps B Ø	70.0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Amps A Ø	60.0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	9 Month Operations	2	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Unknown Operations	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Switching Operations	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LTCC000737	LTCControl	CY-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LTCC000737	LTCControl	CY-TRANS 2	LTC Control Insp	General Comments		
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LTCC000737	LTCControl	CY-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1288	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	26	°C
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	50	°C
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Operations This Read Vac	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Operations Counter AL	177	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Operations Counter AF	177	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Maintenance Operations	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	General Comments		
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Patrol Inspection	General Comments		
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Follow-up Action Required?	n	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Fault Operations Ground	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Fault Operations C Ø	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Fault Operations B Ø	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Fault Operations A Ø	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Amps C Ø	95.0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Ambient Temp	72	°F
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	831	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	LTC Min Tap Position	13L	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	LTC Max Tap Position	Neutral	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Amps C Ø	0.0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Amps B Ø	0.0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Amps A Ø	0.0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	9 Month Operations	2	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Unknown Operations	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Switching Operations	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Operations This Read Vac	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Operations Counter AL	179	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Operations Counter AF	179	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Maintenance Operations	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	General Comments		
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Patrol Inspection	General Comments		
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Follow-up Action Required?	n	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Fault Operations Ground	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Fault Operations C Ø	0	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	BCH000881	Charger	667-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	BCH000881	Charger	667-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Fault Operations B Ø	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Fault Operations A Ø	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001135	BreakerVacuum	459-0293	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Amps B Ø	149.0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Amps A Ø	155.0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	9 Month Operations	18	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Switching Operations	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Operations This Read Vac	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Operations Counter AL	64	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Operations Counter AF	64	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Maintenance Operations	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	General Comments		
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Patrol Inspection	General Comments		
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Follow-up Action Required?	n	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	BCH000881	Charger	667-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	BCH000881	Charger	667-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	BCH000881	Charger	667-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Fault Operations Ground	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Fault Operations C Ø	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Fault Operations B Ø	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Fault Operations A Ø	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Amps C Ø	142.0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Amps B Ø	139.0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Amps A Ø	155.0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000769	BreakerVacuum	HB-1141	VCB Readings	9 Month Operations	15	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Amps C Ø	180.0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Amps B Ø	190.0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Amps A Ø	190.0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	9 Month Operations	30	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Counter Readings	LTC As Found Counter	15483	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	General Comments		
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	276212	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Vegetation	None	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Counter Readings	General Comments		
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	YD000855	Yard	459-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	General Comments		
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	ST000840	Structure	459-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	LTC Current Tap Position	10L	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	LTC As Left Counter	31141	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	LTC As Found Counter	31141	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	General Comments		
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0095	LTCMechanism	HB-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Amps B Ø	120.0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Counter Readings	LTC Min Tap Position	10L	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Counter Readings	LTC Max Tap Position	4R	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Counter Readings	LTC Current Tap Position	6L	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LTCM000072	LTCMechanism	CY-TRANS 2	LTC Counter Readings	LTC As Left Counter	15483	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	General Comments		
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	LTC As Found Counter	24893	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	LTC As Left Counter	24893	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	LTC Current Tap Position	11L	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	LTC Max Tap Position	Neutral	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	LTC Min Tap Position	12L	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	970	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LT0096	LTCMechanism	HB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Amps A Ø	110.0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001134	BreakerVacuum	459-0292	VCB Readings	9 Month Operations	2	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Unknown Operations	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Switching Operations	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Operations This Read Vac	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Operations Counter AL	387	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Operations Counter AF	387	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Maintenance Operations	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	General Comments		
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Patrol Inspection	General Comments		
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Follow-up Action Required?	n	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Fault Operations Ground	0	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	4L	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	1L	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R0756	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	8L	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Fault Operations C Ø	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Fault Operations B Ø	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Fault Operations A Ø	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0186	BreakerVacuum	CY-1486	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	99840	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	99840	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	691.0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	711.0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	795.0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	BCH001338	Charger	GI-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	BCH001338	Charger	GI-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	BCH001338	Charger	GI-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	BCH001338	Charger	GI-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	BCH001338	Charger	GI-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.7	VDC
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	BCH001338	Charger	GI-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.7	VDC
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Amps C Ø	19.0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Amps B Ø	24.0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Amps A Ø	22.0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	9 Month Operations	15	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Unknown Operations	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Switching Operations	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Operations This Read Vac	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Operations Counter AL	213	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Operations Counter AF	213	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Maintenance Operations	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	General Comments		
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Patrol Inspection	General Comments		
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Follow-up Action Required?	n	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Patrol Inspection	Follow-up Action Required?	n	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Fault Operations Ground	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Fault Operations C Ø	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Fault Operations B Ø	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Fault Operations A Ø	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0504	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	33	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Counter Readings	LTC Max Tap Position	4R	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Counter Readings	LTC Min Tap Position	13L	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	30	°C
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	°C
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Counter Readings	LTC Operations Since Last Insp	1475	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	LTCC000392	LTCControl	420-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	LTCC000392	LTCControl	420-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	LTCC000392	LTCControl	420-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Unknown Operations	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Switching Operations	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Operations This Read Vac	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Operations Counter AL	153	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Operations Counter AF	153	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Maintenance Operations	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Unknown Operations	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Switching Operations	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Switching Operations	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Operations This Read Vac	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Operations Counter AL	168	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Operations Counter AF	168	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LTCC000038	LTCControl	HB-TRANS 2	LTC Control Insp	All Connections OK?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Maintenance Operations	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	General Comments		
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Patrol Inspection	General Comments		
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Follow-up Action Required?	n	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Patrol Inspection	Follow-up Action Required?	n	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Fault Operations Ground	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Fault Operations C ∅	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Fault Operations B ∅	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000773	BreakerVacuum	HB-1149	VCB Readings	Fault Operations A ∅	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Operations This Read Vac	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Operations Counter AL	118	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Operations Counter AF	118	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Maintenance Operations	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	General Comments		
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Patrol Inspection	General Comments		
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Follow-up Action Required?	n	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Fault Operations Ground	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Fault Operations C ∅	0	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	BCH001385	Charger	446-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	BCH001385	Charger	446-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	BCH001385	Charger	446-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	BCH001385	Charger	446-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.1	amps
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	BCH001385	Charger	446-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	BCH001385	Charger	446-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	BCH001385	Charger	446-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LTCC000038	LTCControl	HB-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LTCC000038	LTCControl	HB-TRANS 2	LTC Control Insp	General Comments		
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LTCC000038	LTCControl	HB-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	BCH001385	Charger	446-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Fault Operations B ∅	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Fault Operations A ∅	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Counter Readings	LTC Current Tap Position	8L	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Follow-up Action Required?	n	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Patrol Inspection	Tank Paint Condition	Good	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Switching Operations	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Operations This Read Vac	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Operations Counter AL	148	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Patrol Inspection	Follow-up Action Required?	n	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Fault Operations Ground	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Fault Operations C ∅	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Fault Operations B ∅	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Fault Operations A ∅	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Amps C ∅	171.0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Amps B ∅	160.0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Amps A ∅	166.0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	9 Month Operations	18	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Unknown Operations	1	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Switching Operations	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Operations This Read Vac	1	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Operations Counter AL	215	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Operations Counter AF	215	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	General Comments	C phase Arc Sense	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Patrol Inspection	General Comments		
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Follow-up Action Required?	n	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Patrol Inspection	Follow-up Action Required?	n	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Fault Operations Ground	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Fault Operations C Ø	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Fault Operations B Ø	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Fault Operations A Ø	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000770	BreakerVacuum	HB-1142	VCB Readings	Amps C Ø	134.0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Operations Counter AF	148	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Maintenance Operations	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	General Comments		
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Patrol Inspection	General Comments		
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Patrol Inspection	Foundation Condition	Good	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Follow-up Action Required?	n	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Fault Operations Ground	0	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	BCH000881	Charger	667-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Fault Operations C Ø	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Fault Operations B Ø	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Fault Operations A Ø	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	LTCM000016	LTCMechanism	459-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	LTCC000611	LTCControl	459-1	LTC Control Insp	All Connections OK?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	LTCC000611	LTCControl	459-1	LTC Control Insp	Follow-up Action Required?	n	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	LTCC000611	LTCControl	459-1	LTC Control Insp	General Comments		
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	LTCC000611	LTCControl	459-1	LTC Control Insp	LTC Operation Checked?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	LTCC000611	LTCControl	459-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	LTCC000611	LTCControl	459-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	LTCC000611	LTCControl	459-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	LTCC000611	LTCControl	459-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	General Comments		
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Amps C Ø	0.0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Amps B Ø	0.0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Amps A Ø	0.0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000435	BreakerVacuum	459-0191	VCB Readings	9 Month Operations	2	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Patrol Inspection	General Comments		
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Follow-up Action Required?	n	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Fault Operations Ground	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Fault Operations C Ø	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Fault Operations B Ø	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Fault Operations A Ø	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Amps C Ø	110.0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Amps C Ø	60.0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Amps B Ø	65.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Amps A Ø	60.0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001137	BreakerVacuum	459-0295	VCB Readings	9 Month Operations	2	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK001136	BreakerVacuum	459-0294	VCB Readings	Unknown Operations	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Amps B Ø	116.0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Amps A Ø	90.0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000772	BreakerVacuum	HB-1148	VCB Readings	9 Month Operations	14	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Unknown Operations	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Switching Operations	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Operations This Read Vac	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Operations Counter AL	190	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Operations Counter AF	190	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	Maintenance Operations	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Readings	General Comments		
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	BK000771	BreakerVacuum	HB-1143	VCB Patrol Inspection	General Comments		
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	158.0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	161.0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	154.0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	35	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	General Comments		
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	1	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	1	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	65	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	65	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	11.18	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	85.0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	88.0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	82.0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0500	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	22	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Operations Counter AL	269	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Operations This Read Vac	1	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Switching Operations	1	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Tank Paint Condition	Good	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Unknown Operations	0	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	9 Month Operations	2	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Amps A Ø	142.0	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Amps B Ø	167.0	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Amps C Ø	152.0	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Bushing Condition	Good	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Unknown Operations	0	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Tank Paint Condition	Good	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Switching Operations	0	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Operations This Read Vac	0	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Operations Counter AL	237	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Operations Counter AF	237	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Maintenance Operations	0	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Grounds in Place?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	General Comments		
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	General Comments		
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Foundation Condition	Good	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Follow-up Action Required?	n	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Fault Operations Ground	0	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Fault Operations C Ø	0	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Fault Operations B Ø	0	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Fault Operations A Ø	0	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	546	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	546	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0495	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	BAT001483	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	BAT001483	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	9 Month Operations	15	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Amps A Ø	82.0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Amps B Ø	82.0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Amps C Ø	72.0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Fault Operations A Ø	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Fault Operations B Ø	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Fault Operations C Ø	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Fault Operations Ground	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Follow-up Action Required?	n	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Patrol Inspection	General Comments		
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	General Comments		
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Maintenance Operations	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Operations Counter AF	178	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Operations Counter AL	178	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Operations This Read Vac	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0187	BreakerVacuum	CY-1487	VCB Readings	Unknown Operations	0	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	Totalizer Meter Reading	.7450	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Unknown Operations	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Switching Operations	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Operations This Read Vac	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Operations Counter AL	127	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Operations Counter AF	127	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Maintenance Operations	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	General Comments		
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Patrol Inspection	General Comments		
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Fault Operations Ground	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Amps C Ø	557.0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Amps B Ø	576.0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Amps A Ø	582.0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Patrol Inspection	Bushing Condition	Good	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Amps C Ø	60.0	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Amps B Ø	65.0	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Amps A Ø	65.0	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0058	BreakerVacuum	420-0185	VCB Readings	9 Month Operations	4	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Fault Operations A Ø	0	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Fault Operations B Ø	0	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Fault Operations C Ø	0	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Fault Operations Ground	0	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Follow-up Action Required?	n	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Foundation Condition	Good	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	General Comments		
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	General Comments		
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Grounds in Place?	y	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Maintenance Operations	0	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Operations Counter AF	379	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	FE000602	Fence	GI-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Operations Counter AL	379	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Operations This Read Vac	0	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Switching Operations	0	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Patrol Inspection	Tank Paint Condition	Good	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	CB0265	BreakerVacuum	446-2140	VCB Readings	Unknown Operations	0	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	BAT001483	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	BAT001483	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	BAT001483	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	BAT001483	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	BAT001483	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	BAT001483	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	BAT001483	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	BAT001483	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	BAT001483	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB001365	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	5	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	5	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	410	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	410	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	B and C phase IOC, Actual counter	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Vegetation	None	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	General Comments		
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	YD000666	Yard	GI-Yard	Yard Patrol Inspection	Ambient Temp	60	*F
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	55.90	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	55.90	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	55.90	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	120.0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	131.0	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	Amps A Ø	163.0	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	Amps B Ø	134.0	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	Amps C Ø	148.0	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Patrol Inspection	Bushing Condition	Good	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	72	*F
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	BAT000962	Battery	667-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Fault Operations Ground	0	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Follow-up Action Required?	n	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Foundation Condition	Good	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	General Comments		
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	General Comments		
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Grounds in Place?	y	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Maintenance Operations	0	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	CB0271	BreakerVacuum	446-2141	VCB Readings	Operations Counter AF	269	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	132.0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0497	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	96	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	BCH000565	Charger	420-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	BCH000565	Charger	420-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	BCH000565	Charger	420-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	BCH000565	Charger	420-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	BCH000565	Charger	420-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	BCH000565	Charger	420-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	BCH000565	Charger	420-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Broom on Site?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	General Comments		
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	BAT000098	Battery	GI-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	General Comments		
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Trash Emptied?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	CH000139	ControlHouse	HB-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0196	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	264	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Fault Operations Ground	0	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Follow-up Action Required?	n	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Foundation Condition	Good	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	General Comments		
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	General Comments		
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Grounds in Place?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Maintenance Operations	0	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Operations Counter AF	237	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Operations Counter AL	237	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Operations This Read Vac	0	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Switching Operations	0	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Tank Paint Condition	Good	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Unknown Operations	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	Totalizer Meter Reading	.2740	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	Winding Temp Max	49	°C
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	Winding Temp Present	34	°C
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Amps A Ø	0.0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Amps B Ø	0.0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Amps C Ø	0.0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	LTCC000793	LTCControl	459-2	LTC Control Insp	All Connections OK?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	LTCC000793	LTCControl	459-2	LTC Control Insp	Follow-up Action Required?	n	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	LTCC000793	LTCControl	459-2	LTC Control Insp	General Comments		
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	LTCC000793	LTCControl	459-2	LTC Control Insp	LTC Operation Checked?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	LTCC000793	LTCControl	459-2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	LTCC000793	LTCControl	459-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	LTCC000793	LTCControl	459-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	LTCC000793	LTCControl	459-2	LTC Control Insp	VRR Time Delay	30	Seconds
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Counter Readings	Follow-up Action Required?	n	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Unknown Operations	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Switching Operations	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Operations This Read Vac	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Operations Counter AL	246	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Operations Counter AF	246	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Maintenance Operations	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	General Comments		
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	General Comments		
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	General Comments		
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	Kwh Reading	0	Kwh
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	LTC Totalizer Reading	6576.00	kw
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LTCC000573	LTCControl	HB-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIPAR	Position
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LTCC000573	LTCControl	HB-TRANS 1	LTC Control Insp	General Comments		
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LTCC000573	LTCControl	HB-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LTCC000573	LTCControl	HB-TRANS 1	LTC Control Insp	All Connections OK?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	General Comments		
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	BAT000630	Battery	420-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	9 Month Operations	4	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Amps A Ø	380.0	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Amps B Ø	390.0	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Amps C Ø	385.0	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Bushing Condition	Good	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1800	psi
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	Oil Temp Max	49	°C
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	Oil Temp Present	34	°C
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Fault Operations A Ø	0	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Fault Operations B Ø	0	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	KB0059	BreakerVacuum	420-0186	VCB Readings	Fault Operations C Ø	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Switching Operations	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Unknown Operations	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	9 Month Operations	6	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Amps A Ø	70.0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Amps B Ø	80.0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Amps C Ø	70.0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	BCH000598	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Fault Operations A Ø	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Bushing Condition	Good	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Foundation Condition	Good	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	General Comments		
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Grounds in Place?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Oil Temp Max	61	°C
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Fault Operations B Ø	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Fault Operations C Ø	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Fault Operations Ground	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Follow-up Action Required?	n	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Radiator Leaks	None	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Tank Leaks	None	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0249	GroundTransformer	CY-GND TR 2	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Patrol Inspection	General Comments		
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	General Comments		
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Maintenance Operations	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Operations Counter AF	213	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Operations Counter AL	213	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Operations This Read Vac	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Switching Operations	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000365	BreakerVacuum	459-0193	VCB Readings	Unknown Operations	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	9 Month Operations	2	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	BCH000598	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Patrol Inspection	General Comments		
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Follow-up Action Required?	n	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Fault Operations C Ø	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Fault Operations B Ø	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Counter Readings	General Comments		
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	General Comments		
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Counter Readings	LTC As Found Counter	8276	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Counter Readings	LTC As Left Counter	8276	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Counter Readings	LTC Current Tap Position	9L	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Counter Readings	LTC Max Tap Position	3R	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Counter Readings	LTC Min Tap Position	14L	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	45	°C
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	31	°C
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Counter Readings	LTC Operations Since Last Insp	1414	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	LTCM000087	LTCMechanism	459-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Fault Operations A Ø	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Amps C Ø	90.0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Amps B Ø	100.0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Amps A Ø	90.0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000366	BreakerVacuum	459-0194	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Fault Operations A Ø	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Fault Operations B Ø	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Fault Operations C Ø	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Fault Operations Ground	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Follow-up Action Required?	n	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Patrol Inspection	General Comments		
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	General Comments		
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Maintenance Operations	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Operations Counter AF	179	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Operations Counter AL	179	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	BCH000598	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Operations This Read Vac	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Readings	Oil Temp Max	70	°C
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	General Comments	Nitrogen cylinder is empty.	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Readings	General Comments		
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Patrol Inspection	Switchgear Patrol Inspection	y
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	SWG000062	Switchgear	GI-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	BAT001488	Battery	446-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	General Comments		
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	General Comments		
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB1324	BreakerVacuum	HB-12KV TR 1	VCB Readings	9 Month Operations	22	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Oil Temp Max	65	°C
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0248	GroundTransformer	CY-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	Oil Temp Present	55	°C
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	Oil Temp Max	35	°C
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	LTC Totalizer Reading	3576.00	kw
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	BAT001488	Battery	446-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	BAT001488	Battery	446-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	77	°F
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	BAT001488	Battery	446-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	BAT001488	Battery	446-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	BAT001488	Battery	446-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	BAT001488	Battery	446-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	BAT001488	Battery	446-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	BAT001488	Battery	446-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	BAT001488	Battery	446-Battery Bank	Battery Patrol Inspection	General Comments		
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	BAT001488	Battery	446-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	BAT001488	Battery	446-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	BAT001488	Battery	446-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	40	°C
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	60	°C
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LT0053	WithLTC	CY-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	GND000031	BreakerGroundDevice	459-Offline Distribution	Breaker Ground Device Inspection	All Connections OK?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	GND000031	BreakerGroundDevice	459-Offline Distribution	Breaker Ground Device Inspection	Bearings lubricated?	n	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	GND000031	BreakerGroundDevice	459-Offline Distribution	Breaker Ground Device Inspection	Comments		
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	GND000031	BreakerGroundDevice	459-Offline Distribution	Breaker Ground Device Inspection	Equipment Properly Labeled?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	GND000031	BreakerGroundDevice	459-Offline Distribution	Breaker Ground Device Inspection	Follow-up Action Required?	n	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	GND000031	BreakerGroundDevice	459-Offline Distribution	Breaker Ground Device Inspection	Ground Connections Intact?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	GND000031	BreakerGroundDevice	459-Offline Distribution	Breaker Ground Device Inspection	Rosettes Clean and Lubed?	n	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	GND000031	BreakerGroundDevice	459-Offline Distribution	Breaker Ground Device Inspection	Vacuum and Clean Breaker?	n	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Unknown Operations	0	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Switching Operations	0	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Operations This Read AM	0	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Operations Counter AL	459	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Operations Counter AF	459	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Maintenance Operations	0	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	General Comments		
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Patrol Inspection	General Comments		
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Follow-up Action Required?	n	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Fault Operations Ground	0	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Fault Operations C Ø	0	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Fault Operations B Ø	0	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Fault Operations A Ø	0	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Amps C Ø	100.0	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Amps B Ø	100.0	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Amps A Ø	150.0	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0388	BreakerAirMagnetic	GI-2	AMCB Readings	9 Months Operations	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	TX000216	WithLTC	459-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	B0293	WithLTC	420-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	9 Month Operations	2	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Amps A Ø	155.0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Amps B Ø	170.0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Amps C Ø	155.0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Fault Operations A Ø	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Fault Operations B Ø	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Fault Operations C Ø	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Fault Operations Ground	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Follow-up Action Required?	n	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Patrol Inspection	General Comments		
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	General Comments		
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Maintenance Operations	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Operations Counter AF	161	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Operations Counter AL	161	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Operations This Read Vac	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Switching Operations	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000360	BreakerVacuum	459-1	VCB Readings	Unknown Operations	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	9 Month Operations	2	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000364	BreakerVacuum	459-0192	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	SWG000212	Switchgear	459-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Vegetation	None	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	General Comments		
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	9 Months Operations	0	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	9 Month Operations	2	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Amps A Ø	0.0	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	3R	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	4L	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Amps B Ø	0.0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Ambient Temp	60	*F
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	General Comments		
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	Follow-up Action Required?	n	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Amps C Ø	0.0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	CH000474	ControlHouse	GI-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	CH000474	ControlHouse	GI-Battery Control House	Control House Patrol Inspection	General Comments		
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	CH000474	ControlHouse	GI-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	CH000474	ControlHouse	GI-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	CH000474	ControlHouse	GI-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	CH000474	ControlHouse	GI-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	CH000474	ControlHouse	GI-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	CH000474	ControlHouse	GI-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	CH000474	ControlHouse	GI-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Fault Operations A Ø	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Fault Operations B Ø	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Fault Operations C Ø	0	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	2L	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	Oil Temp Present	40	°C
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	Oil Temp Max	40	°C
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	LTC Totalizer Reading	3948.00	kw
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	General Comments		
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	General Comments		
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Operations This Read AM	0	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Operations Counter AL	359	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Operations Counter AF	359	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Maintenance Operations	0	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	General Comments		
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Patrol Inspection	General Comments		
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Follow-up Action Required?	n	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Fault Operations C Ø	0	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Fault Operations B Ø	0	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Fault Operations A Ø	0	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Amps C Ø	300.0	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Amps B Ø	250.0	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Amps A Ø	150.0	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	LTC Operations Since Last Insp	1059	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	LTC Min Tap Position	9L	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	LTC Max Tap Position	4R	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	LTC Current Tap Position	5L	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	LTC As Left Counter	152758	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Counter Readings	LTC As Found Counter	152758	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Mechanism Patrol Inspection	General Comments		
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	YD000571	Yard	HB-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Amps B Ø	80.0	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Amps C Ø	75.0	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Bushing Condition	Good	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Fault Adjusted Amps A Phase V	4.56	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Fault Adjusted Amps B Phase V	4.56	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BCH001006	Charger	459-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BCH001006	Charger	459-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BCH001006	Charger	459-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BCH001006	Charger	459-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.2	amps
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BCH001006	Charger	459-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BCH001006	Charger	459-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BCH001006	Charger	459-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	751	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	751	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Fault Adjusted Amps C Phase V	4.56	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Fault Operations A Ø	0	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Fault Operations B Ø	0	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Fault Operations C Ø	0	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Fault Operations Ground	0	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Follow-up Action Required?	n	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Foundation Condition	Good	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	General Comments		
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	General Comments		
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Grounds in Place?	y	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Maintenance Operations	280	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Operations Counter AF	280	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Operations Counter AL	280	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Operations This Read Vac	281	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Switching Operations	0	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Patrol Inspection	Tank Paint Condition	Good	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Unknown Operations	1	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0192	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R0338	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Fault Operations Ground	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Follow-up Action Required?	n	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Patrol Inspection	General Comments		
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	General Comments		
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Maintenance Operations	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Operations Counter AF	144	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Operations Counter AL	144	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Operations This Read Vac	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Switching Operations	0	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BK000413	BreakerVacuum	459-BT1-2	VCB Readings	Unknown Operations	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	PF000071	PowerFuse	CY-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	PF000071	PowerFuse	CY-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Counter Readings	Follow-up Action Required?	n	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Counter Readings	General Comments		
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Mechanism Patrol Inspection	General Comments		
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Counter Readings	LTC As Found Counter	80690	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Counter Readings	LTC As Left Counter	80694	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Counter Readings	LTC Current Tap Position	5L	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Counter Readings	LTC Max Tap Position	7L	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Counter Readings	LTC Min Tap Position	1R	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Counter Readings	LTC Operations Since Last Insp	485	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	LTCMechanism	446-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB1336	BreakerVacuum	HB-Sec 1 Spare Vac Bkr	VCB Patrol Inspection	Follow-up Action Required?	n	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB1336	BreakerVacuum	HB-Sec 1 Spare Vac Bkr	VCB Patrol Inspection	General Comments		
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB1336	BreakerVacuum	HB-Sec 1 Spare Vac Bkr	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	General Comments		
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	3R	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	General Comments		
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	Neutral	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	7R	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	64079	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	R1275	Regulator	920-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	9 Month Operations	283	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	KB0125	BreakerVacuum	667-0045	VCB Readings	Amps A Ø	80.0	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	General Comments		
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	General Comments		
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	General Comments		
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3210	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Vegetation	None	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	General Comments		
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Vegetation	None	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	207.0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	204.0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	209.0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	11.18	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	YD000552	Yard	550-Yard	Yard Patrol Inspection	Ambient Temp	70	*F
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	General Comments		
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	40	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	Oil Temp Present	40	*C
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	165	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	165	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	Oil Temp Max	45	*C
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	1	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
10/19/2020 6:49	Distribution	Hurstbourne Quarterly Inspection	LB0496	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	1	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	97.50	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	256.80	kw
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/14/2020 13:15	Distribution	Haley Quarterly Inspection	LTCM000142	LTCMechanism	846-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	SWG000204	Switchgear	459-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
10/14/2020 16:34	Distribution	Hume Road Quarterly Inspection	BAT001041	Battery	459-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	Totalizer Meter Reading	.6580	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	General Comments		
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	FE000497	Fence	420-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	FE000545	Fence	550-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/14/2020 11:08	Distribution	Briar Hill Road Quarterly Inspection	ST000506	Structure	420-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	BK001274	BreakerVacuum	446-2139	VCB Readings	9 Month Operations	2	
10/14/2020 12:51	Distribution	Gilligan Quarterly Inspection	LB0387	BreakerAirMagnetic	GI-1	AMCB Readings	Switching Operations	0	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	C0433	WithLTC	446-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	General Comments		
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	549	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	549	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
10/14/2020 14:37	Distribution	Lancaster 1 Quarterly Inspection	YD000519	Yard	446-Yard	Yard Patrol Inspection	Ambient Temp	77	*F
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/14/2020 14:27	Distribution	Garrard Ct Quarterly Inspection	C0319	NonLTC	550-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/14/2020 12:30	Distribution	Clay LGE Quarterly Inspection	LB0190	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	47	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	14	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	12.0	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	14.0	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	21.0	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	DX0115	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	3	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	General Comments		
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0038	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	BAT001294	Battery	FC-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0284	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0284	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0284	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	General Comments		
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Readings	General Comments		
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0284	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0284	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Adequate	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	55	*C
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	*C
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Operations Counter AL	234	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Operations This Read Vac	1	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Operations Since Last Insp	0	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Mechanism Patrol Inspection	General Comments		
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0469	LTCMechanism	433-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Broken skirts	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	General Comments		
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Operations Counter	165	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Patrol Inspection	General Comments		
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	C0464	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	38	°C
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	C0464	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Follow-up Action Required?	n	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Operations Ground	0	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Operations C Ø	0	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Operations B Ø	0	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Operations A Ø	0	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Amps C Ø	120.0	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Amps B Ø	130.0	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Amps A Ø	130.0	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	C0464	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	C0464	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	C0464	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	9 Months Operations	1	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Maintenance Operations	0	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	General Comments		
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Follow-up Action Required?	n	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Fault Operations Ground	0	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Fault Operations C Ø	0	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Fault Operations B Ø	0	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Fault Operations A Ø	0	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Switching Operations	1	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Unknown Operations	0	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0049	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0049	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0049	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Mechanism Patrol Inspection	General Comments		
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Unknown Operations	0	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Unknown Operations	0	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Switching Operations	2	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	C0464	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	C0464	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	C0464	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Readings	Oil Temp Present	43	°C
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Readings	Oil Temp Max	52	°C
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Operations This Read Vac	2	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Operations Counter AL	242	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	97.50	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	M0026	NonLTC	555-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	C0464	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	C0464	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	°C
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Operations Counter AF	242	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Switching Operations	0	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Operations This Read AM	0	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Operations Counter AL	325	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Operations Counter AF	325	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	Maintenance Operations	0	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0310	BreakerAirMagnetic	FC-3	AMCB Readings	General Comments		
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	General Comments		
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	97	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	9 Month Operations	3	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	General Comments		
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Amps A Ø	0.0	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Amps B Ø	0.0	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Amps C Ø	0.0	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	LTC Min Tap Position	12L	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	LTC Max Tap Position	8L	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	LTC As Left Counter	76132	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	LTC As Found Counter	76132	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1301	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	LTC Min Tap Position	11L	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0049	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0049	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0049	LTCMechanism	951-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	LTC Max Tap Position	4L	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	LTC Current Tap Position	10L	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	LTC As Left Counter	411254	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Counter Readings	LTC As Found Counter	411254	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0473	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN52	LTCMechanism	FC-TRANS 2	LTC Mechanism Patrol Inspection	General Comments	lrc low oil level	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Follow-up Action Required?	n	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Counter Readings	General Comments		
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Found Counter	7444	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Left Counter	7444	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Current Tap Position	Neutral	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Max Tap Position	Neutral	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Min Tap Position	Neutral	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Maintenance Operations	0	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	SWG000090	Switchgear	FC-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Operations Counter AF	234	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	W0318	LTCMechanism	670-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	W0318	LTCMechanism	670-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	W0318	LTCMechanism	670-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-5	psi
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	General Comments		
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	W0318	WithLTC	670-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0069	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	-5	psi
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0369	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	General Comments	ok	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Counter Readings	Follow-up Action Required?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN32	LTCMechanism	FC-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1350	psi
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000056	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	LTCM000038	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	LTCM000038	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	LTCM000038	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	LTCM000038	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	LTCM000038	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	LTCM000038	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Fault Operations A Ø	0	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	CH000453	ControlHouse	FC-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Amps A Ø	8	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Amps B Ø	8	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	CX0658	RecloserHydraulic	122-2159	Recloser Hydraulic Patrol Inspection	Amps C Ø	9	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Fault Operations B Ø	0	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Fault Operations C Ø	0	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Fault Operations Ground	0	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Mechanism Patrol Inspection	General Comments		
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	S0019	LTCMechanism	466-9	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	W0318	LTCMechanism	670-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	W0318	LTCMechanism	670-1	LTC Mechanism Patrol Inspection	General Comments		
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	Follow-up Action Required?	n	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000213	NonLTC	022-2	NonLTC Transformer Patrol Inspection	General Comments		
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Patrol Inspection	General Comments		
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0126	BreakerVacuum	812-0183	VCB Readings	General Comments		
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	3	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	709	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	709	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	General Comments	T on B/N	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	2	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	24.40	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	80.0	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	80.0	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	80.0	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0406	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	7	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Readings	Top Oil Temperature Present	40	°C
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Readings	Top Oil Temperature Max	44	°C
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	220	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	225	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Readings	General Comments		
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	General Comments		
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	T0108	NonLTC	122-6	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Fault Operations A Ø	0	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Fault Operations B Ø	0	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Fault Operations C Ø	0	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Fault Operations Ground	0	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Follow-up Action Required?	n	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Patrol Inspection	General Comments		
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	General Comments		
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Maintenance Operations	0	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Operations Counter AF	34892	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Operations Counter AL	34892	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Operations This Read AM	0	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Switching Operations	0	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Unknown Operations	0	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Amps A Ø	10	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Amps B Ø	11	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Amps C Ø	10	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	General Comments		
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Operations Counter	32	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	CX0086	RecloserHydraulic	122-2158	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	General Comments		
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	ST000477	Structure	812-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	FE000469	Fence	812-Fence	Fence Patrol Inspection	General Comments		
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	General Comments		
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Readings	General Comments		
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Readings	Oil Temp Max	55	°C
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Readings	Oil Temp Present	48	°C
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	C0079	NonLTC	122-5 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Current Tap Position	6L	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	General Comments		
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0333	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Regulator As Left Counter	230335	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Min Tap Position	12L	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000081	NonLTC	951-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0816	Regulator	555-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	General Comments		
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Readings	General Comments		
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Readings	Oil Temp Max	32	°C
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Readings	Oil Temp Present	30	°C
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	C0078	NonLTC	122-5 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	51	°F
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BAT000963	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	C0077	NonLTC	122-5 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	270.00	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	C0313	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Current Tap Position	5L	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Tank Leaks	None	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	General Comments		
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	FE000815	Fence	932-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Amps C Ø	0.0	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Amps B Ø	0.0	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Amps A Ø	0.0	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	KB0124	BreakerVacuum	812-0181	VCB Readings	9 Month Operations	4	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Tank Leaks	None	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Regulator As Left Counter	44227	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	124	volts
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Min Tap Position	3L	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Max Tap Position	7L	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Operations Counter	299	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	General Comments		
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	CX0728	RecloserHydraulic	122-2160	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	General Comments		
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1257	Regulator	122-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Counter Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Counter Readings	General Comments		
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	General Comments	Barbed wire is rusty, and trees are overhanging the fence	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	B0407	WithLTC	812-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	°C
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	55	°C
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Mechanism Patrol Inspection	General Comments		
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0356	LTCMechanism	314-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	LTCM000076	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	LTCM000076	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	LTCM000076	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	LTCM000076	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	LTCM000076	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0069	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	9 Months Operations	1	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Amps A Ø	100.0	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Amps B Ø	210.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Readings	Amps C Ø	210.0	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0311	BreakerAirMagnetic	FC-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	General Comments		
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	S0019	WithLTC	466-9	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Regulator As Left Counter	44794	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	124	volts
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Min Tap Position	3L	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Max Tap Position	6L	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	General Comments		
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Current Tap Position	5L	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1256	Regulator	122-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Tank Leaks	None	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Regulator As Left Counter	47052	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	124	volts
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Mechanism Patrol Inspection	General Comments		
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Counter Readings	LTC As Found Counter	88461	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Counter Readings	LTC As Left Counter	88463	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Counter Readings	LTC Current Tap Position	8L	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Counter Readings	LTC Max Tap Position	1L	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Counter Readings	LTC Min Tap Position	9L	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Counter Readings	LTC Operations Since Last Insp	616	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	B0407	LTCMechanism	812-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Min Tap Position	1L	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Max Tap Position	6L	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	General Comments		
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Current Tap Position	2L	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	R1255	Regulator	122-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	FE000121	Fence	555-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0038	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0038	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0038	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	O0177	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	O0177	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Unknown Operations	0	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	80.0	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Readings	General Comments		
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Readings	Oil Temp Max	50	°C
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Readings	Oil Temp Present	20	°C
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN32	WithLTC	FC-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	80.0	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0045	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0045	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0045	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0045	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Readings	General Comments		
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Readings	Oil Temp Max	45	°C
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	PN52	WithLTC	FC-TRANS 2	LTC Transformer Readings	Oil Temp Present	20	°C
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	SWG000070	Switchgear	FC-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	280	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	280	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Ambient Temp	51	°F
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	Follow-up Action Required?	n	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0473	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0473	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0473	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0473	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0473	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0473	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	Winding Temp Present	30	°C
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	Winding Temp Max	50	°C
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	Totalizer Meter Reading	.3240	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	Oil Temp Present	30	°C
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	Oil Temp Max	50	°C
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	LTC Totalizer Reading	7776.00	kw
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	General Comments		
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	General Comments		
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	200	psi
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0029	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0029	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BCH000362	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BCH000362	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BCH000362	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BCH000362	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BCH000362	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BCH000362	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BCH000362	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	828	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	828	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0029	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0029	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0029	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	BCH000129	Charger	FC-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	BCH000129	Charger	FC-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.7	VDC
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	BCH000129	Charger	FC-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.7	VDC
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	BCH000129	Charger	FC-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	9 Month Operations	3	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Vegetation	None	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Exp Boom Needs Corr	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	General Comments	berm needs gravel	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	YD000056	Yard	555-Yard	Yard Patrol Inspection	Ambient Temp	54	*F
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Amps A Ø	155.0	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Amps B Ø	135.0	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Amps C Ø	165.0	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Fault Operations A Ø	0	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	C0529	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	C0529	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-5	psi
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	C0529	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	70.00	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	C0529	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	C0529	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	C0529	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0029	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	80.0	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0405	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0404	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	52	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	General Comments		
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Maintenance Operations	0	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Operations Counter AF	223	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Operations Counter AL	223	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Operations This Read Vac	0	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Switching Operations	0	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	O0177	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	O0177	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	O0177	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BK000705	BreakerVacuum	812-0182	VCB Readings	Fault Operations B Ø	0	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0356	WithLTC	314-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	General Comments		
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	ST000055	Structure	555-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	LTCC000857	LTCControl	176-5	LTC Control Insp	All Connections OK?	y	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	LTCC000857	LTCControl	176-5	LTC Control Insp	Follow-up Action Required?	n	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	LTCC000857	LTCControl	176-5	LTC Control Insp	General Comments		
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	LTCC000857	LTCControl	176-5	LTC Control Insp	LTC Operation Checked?	y	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	LTCC000857	LTCControl	176-5	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	LTCC000857	LTCControl	176-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	LTCC000857	LTCControl	176-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	LTCC000857	LTCControl	176-5	LTC Control Insp	VRR Time Delay	30	Seconds
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-.5	psi
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	TX000252	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0404	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	Oil Temp Max	49	°C
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	72.50	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	Non LTC Totalizer Reading	385.20	kw
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	General Comments		
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	General Comments		
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	9 Month Operations	24	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	LTCC000834	LTCControl	812-1	LTC Control Insp	All Connections OK?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	LTCC000834	LTCControl	812-1	LTC Control Insp	Follow-up Action Required?	n	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	LTCC000834	LTCControl	812-1	LTC Control Insp	General Comments		
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	LTCC000834	LTCControl	812-1	LTC Control Insp	LTC Operation Checked?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	LTCC000834	LTCControl	812-1	LTC Control Insp	LTC Output Voltage Level	123.2	VAC
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	LTCC000834	LTCControl	812-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	LTCC000834	LTCControl	812-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	LTCC000834	LTCControl	812-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	27.50	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	LTCM000049	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Accumulated Fault Duty A Ph V	0	%
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	LTCM000049	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	LTCM000049	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	Follow-up Action Required?	n	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	General Comments		
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	General Comments		
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	LTCM000049	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0190	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0284	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	LTC As Found Counter	152824	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	LTC As Left Counter	152828	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	LTC Current Tap Position	5L	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	LTC Max Tap Position	2R	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	LTC Min Tap Position	7L	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	LTC Operations Since Last Insp	516	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Operations Counter AL	404	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Regulator As Left Counter	162114	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	General Comments		
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Patrol Inspection	General Comments		
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Follow-up Action Required?	n	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Fault Operations Ground	0	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Fault Operations C Ø	0	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Fault Operations B Ø	0	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Fault Operations A Ø	0	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0432	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Current Tap Position	7L	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	General Comments		
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Max Tap Position	6L	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Min Tap Position	13L	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0025	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0025	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0025	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0025	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0025	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0025	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0271	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0271	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0271	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0271	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0271	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0271	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0271	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	226.00	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0271	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Operations This Read AM	0	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Switching Operations	0	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Unknown Operations	0	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	Totalizer Meter Reading	.3210	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Adequate	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	M0027	NonLTC	555-1 C	NonLTC Transformer Readings	Oil Temp Present	40	°C
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	53	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	53	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0284	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0284	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0284	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	LTCM000048	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	20	°C
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	LTCM000048	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	35	°C
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	LTCM000048	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	LTCM000048	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Unknown Operations	0	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Switching Operations	23	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Operations This Read Vac	23	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Operations Counter AL	120	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Operations Counter AF	120	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Maintenance Operations	0	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	General Comments		
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Follow-up Action Required?	n	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Fault Operations Ground	0	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Fault Operations C ∅	0	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Fault Operations B ∅	0	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Fault Operations A ∅	0	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	122.9	volts
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0818	Regulator	555-1 C	Regulator Patrol Inspection	Regulator As Left Counter	56067	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0430	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0430	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0430	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0430	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0430	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Accumulated Fault Duty C Ph V	0	%
10/13/2020 15:32	Distribution	West Cliff Quarterly Inspection	LB1358	BreakerVacuum	122-3427	VCB Readings	Accumulated Fault Duty B Ph V	0	%
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	LTCMechanism	176-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	1	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Amps C ∅	200.0	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Amps B ∅	120.0	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Amps A ∅	120.0	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	9 Months Operations	0	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	160.0	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	150.0	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	165.0	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.5	psi
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	KT0046	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0284	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	O0177	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	O0177	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Vegetation	None	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	General Comments		
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	O0177	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	O0177	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	O0177	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	O0177	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0284	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	BB0300	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	C0464	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	C0464	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	C0464	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	C0464	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Max Tap Position	6L	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Min Tap Position	14L	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Amps A Ø	160.0	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	260.0	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	220.0	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.7	volts
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Amps C Ø	180.0	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Amps B Ø	180.0	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	240.0	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Operations A Ø	0	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	O0177	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	O0177	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	O0177	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Operations B Ø	0	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Operations C Ø	0	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	O0177	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	O0177	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Fault Operations Ground	0	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Follow-up Action Required?	n	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Patrol Inspection	General Comments		
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0432	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0432	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	General Comments		
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0432	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	-.5	psi
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	C0464	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	C0464	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	M0049	WithLTC	951-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	C0464	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Unknown Operations	0	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0284	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	LTCM000048	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	LTCM000048	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	LTCM000048	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Maintenance Operations	0	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Operations Counter AF	404	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0284	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Current Tap Position	8L	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	General Comments		
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Switching Operations	0	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Operations This Read AM	0	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Operations Counter AL	1301	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Operations Counter AF	1301	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Readings	Maintenance Operations	0	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0309	BreakerAirMagnetic	FC-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	B0450	WithLTC	176-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0348	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	General Comments		
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	FE000654	Fence	FC-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Ambient Temp	70	*F
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/13/2020 15:23	Distribution	Loudon Avenue Quarterly Inspection	BB0403	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	1	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0469	WithLTC	433-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	YD000659	Yard	FC-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0432	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0432	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0432	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	General Comments		
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/13/2020 14:46	Distribution	Falls City Quarterly Inspection	LB0308	BreakerAirMagnetic	FC-1	AMCB Readings	9 Months Operations	3	
10/13/2020 9:56	Distribution	Eastland Quarterly Inspection	YD000475	Yard	812-Yard	Yard Patrol Inspection	Vegetation	None	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	General Comments		
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/13/2020 10:56	Distribution	Daniel Branch Quarterly Inspection	R0817	Regulator	555-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	C0476	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0369	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0284	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0284	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	B0284	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/13/2020 13:03	Distribution	Eastland Storage Quarterly Inspection	LTCM000048	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Maintenance Operations	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Operations Counter AF	360	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Operations Counter AL	360	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Operations This Read Vac	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Switching Operations	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Unknown Operations	0	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	438	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	General Comments		
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	LTCC000253	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	LTCC000253	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	LTCC000253	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	LTCC000253	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	9.0	VDC
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	9.5	VDC
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Min Tap Position	12L	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Regulator As Left Counter	114433	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	LTCC000253	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.1	VAC
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	LTCC000253	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.3	VAC
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	541	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Amps A Ø	16.0	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Amps B Ø	15.0	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Amps C Ø	16.0	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	388	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	LTCC000253	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	9 Month Operations	5	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Amps A Ø	100.0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Amps B Ø	100.0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Amps C Ø	100.0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Fault Operations A Ø	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Fault Operations B Ø	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Fault Operations C Ø	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Fault Operations Ground	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	Follow-up Action Required?	n	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	General Comments		
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0056	BreakerVacuum	549-0904	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	General Comments		
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	General Comments		
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Counter Readings	General Comments		
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Counter Readings	LTC As Found Counter	28368	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Counter Readings	LTC As Left Counter	28368	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Counter Readings	LTC Current Tap Position	13L	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1R	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Counter Readings	LTC Min Tap Position	15L	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	55	°C
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	35	°C
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1487	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LT0301	LTCMechanism	EW-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	BCH000429	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	BCH000429	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	BCH000429	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	56.5	VDC
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	DX0126	RecloserHydraulic	810-0491	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	General Comments		
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Current Tap Position	8L	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	BAT000351	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	Totalizer Meter Reading	.9960	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	58	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	58	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	Oil Temp Present	48	°C
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	Oil Temp Max	49	°C
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	S0039	WithLTC	583-1	LTC Transformer Readings	LTC Totalizer Reading	7171.20	kw
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Vegetation	Light	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	General Comments	light by trans is out need bucket truck	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Fault Operations A Ø	0	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Ambient Temp	75	°F
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	General Comments		
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Maintenance Operations	0	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	CH000455	ControlHouse	DU-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	CH000455	ControlHouse	DU-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	CH000455	ControlHouse	DU-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	CH000455	ControlHouse	DU-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	CH000455	ControlHouse	DU-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	CH000455	ControlHouse	DU-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	CH000455	ControlHouse	DU-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	CH000455	ControlHouse	DU-Battery Control House	Control House Patrol Inspection	General Comments		
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	CH000455	ControlHouse	DU-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	CH000456	ControlHouse	EI-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	CH000456	ControlHouse	EI-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	CH000456	ControlHouse	EI-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	CH000456	ControlHouse	EI-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	CH000456	ControlHouse	EI-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	CH000456	ControlHouse	EI-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	CH000456	ControlHouse	EI-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	CH000456	ControlHouse	EI-Battery Control House	Control House Patrol Inspection	General Comments		
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	CH000456	ControlHouse	EI-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Door Alarms OK?	n	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Broom on Site?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Fault Operations A Ø	0	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Amps C Ø	140.0	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Amps B Ø	100.0	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Amps A Ø	180.0	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	9 Months Operations	1	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Fault Operations A Ø	0	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Fault Operations B Ø	0	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Fault Operations C Ø	0	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Fault Operations Ground	0	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Follow-up Action Required?	n	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Patrol Inspection	General Comments		
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	9 Month Operations	7	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Amps A Ø	190.0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Amps B Ø	200.0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Amps C Ø	200.0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Trash Emptied?	n	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	n	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Station Ground Set On Site?	n	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	General Comments		
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	CH000431	ControlHouse	583-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	General Comments		
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Regulator As Left Counter	276440	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Yard Lights Working?	n	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	YD000663	Yard	DX-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BCH001173	Charger	549-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BCH001173	Charger	549-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BCH001173	Charger	549-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BCH001173	Charger	549-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BCH001173	Charger	549-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.2	amps
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BCH001173	Charger	549-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BCH001173	Charger	549-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BCH001173	Charger	549-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	General Comments		
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BAT001224	Battery	549-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Unknown Operations	0	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Switching Operations	0	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Operations This Read Vac	0	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Operations Counter AL	209	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Operations Counter AF	209	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Fault Adjusted Amps C Phase V	6.13	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Fault Operations A Ø	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Fault Operations B Ø	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Fault Operations C Ø	1	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Fault Operations Ground	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Follow-up Action Required?	n	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	General Comments		
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	General Comments	I on C phase	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Maintenance Operations	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Fault Operations B Ø	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Fault Operations C Ø	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Fault Operations Ground	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Follow-up Action Required?	n	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	General Comments		
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	General Comments		
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Maintenance Operations	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Operations Counter AF	381	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Operations Counter AL	381	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Operations This Read Vac	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Switching Operations	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0459	BreakerVacuum	549-0151	VCB Readings	Unknown Operations	0	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Operations Counter AF	268	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Operations Counter AL	268	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Operations This Read Vac	1	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	9 Month Operations	5	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Amps A Ø	100.0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Amps B Ø	100.0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Amps C Ø	100.0	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Switching Operations	1	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	9 Month Operations	1	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	FE000658	Fence	DX-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Fault Operations A Ø	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Fault Operations B Ø	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Fault Operations C Ø	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Fault Operations Ground	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Follow-up Action Required?	n	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	El-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	El-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	El-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	El-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	El-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	El-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	El-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	El-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	El-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	El-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Exp/Missing Not Repl	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Regulator As Left Counter	288804	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Min Tap Position	13L	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Readings	Maintenance Operations	0	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Readings	Num Operations Last 9 Months	0	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Readings	Operations Counter AF	58	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Readings	Operations Counter AL	58	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Readings	Operations This Read SF6	0	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	SF6 Bushing Condition	Good	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	SF6 Pressure Indicator	good	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Readings	Switching Operations	0	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	PF000100	PowerFuse	DX-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	PF000100	PowerFuse	DX-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Max Tap Position	3L	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	General Comments		
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1223	Regulator	426-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	9 Month Operations	1	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Amps A Ø	200.0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Amps B Ø	180.0	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	General Comments		
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	72	*F
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BAT000150	Battery	EW-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	BCH000120	Charger	DU-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	BCH000120	Charger	DU-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	BCH000120	Charger	DU-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	BCH000120	Charger	DU-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	BCH000120	Charger	DU-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.6	VDC
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	BCH000120	Charger	DU-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.6	VDC
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	BCH000120	Charger	DU-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	200.0	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	200.0	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	200.0	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BB0266	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	6	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Ambient Temperature	72	*F
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Readings	Fault Operations	0	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Readings	Follow-up Action Required?	n	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Foundation Condition	Good	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Gauge(s) Condition	Good	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	General Comments		
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Readings	General Comments		
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LB001375	BreakerSF6	EW-6658	GCB Patrol Inspection	Grounds in Place?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.1	VDC
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	General Comments		
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	BAT001241	Battery	583-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Amps A Ø	31.0	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Amps B Ø	54.0	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Amps C Ø	61.0	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Fault Operations A Ø	0	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Fault Operations B Ø	0	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Fault Operations C Ø	0	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Fault Operations Ground	0	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Follow-up Action Required?	n	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Patrol Inspection	General Comments		
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	General Comments		
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Maintenance Operations	0	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Operations Counter AF	173	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Operations Counter AL	173	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Operations This Read Vac	1	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Switching Operations	1	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	9 Month Operations	6	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Amps A Ø	161.0	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Amps B Ø	89.0	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Amps C Ø	155.0	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000031	BreakerVacuum	EW-1241	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Unknown Operations	0	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Switching Operations	0	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Operations This Read AM	0	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Operations Counter AL	7	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Operations Counter AF	7	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Maintenance Operations	0	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	General Comments		
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Patrol Inspection	General Comments		
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Follow-up Action Required?	n	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Fault Operations Ground	0	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Fault Operations C Ø	0	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	LB0276	BreakerAirMagnetic	DU-2	AMCB Readings	Fault Operations B Ø	0	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	General Comments		
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	ST000266	Structure	440-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Amps C Ø	185.0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Unknown Operations	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Switching Operations	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Operations This Read Vac	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Operations Counter AL	273	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Operations Counter AF	273	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Maintenance Operations	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	General Comments		
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	General Comments		
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Follow-up Action Required?	n	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Fault Operations Ground	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Fault Operations C Ø	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Fault Operations B Ø	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Fault Operations A Ø	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Amps C Ø	0.0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Amps B Ø	0.0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Amps A Ø	0.0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0059	BreakerVacuum	549-BT1-2	VCB Readings	9 Month Operations	3	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	General Comments		
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Min Tap Position	12L	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	9 Month Operations	3	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000030	BreakerVacuum	EW-1240	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Ambient Temp	65	*F
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	General Comments		
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	Totalizer Meter Reading	.2364	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3800	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	Oil Temp Max	0	°C
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	200.00	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	220.00	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	898.32	kw
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	General Comments		
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	General Comments		
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	B0197	NonLTC	426-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	ST000474	Structure	529-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Vegetation	None	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	General Comments		
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Max Tap Position	2L	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Min Tap Position	15L	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	General Comments		
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	ST000390	Structure	549-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Vegetation	None	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	General Comments		
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	Totalizer Meter Reading	.8410	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	Winding Temp Max	100	°C
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	Winding Temp Present	50	°C
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	140.00	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	YD000387	Yard	549-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	9 Month Operations	2	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	General Comments		
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	FE000466	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	Totalizer Meter Reading	0.0000	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	0	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	LTC Operations Since Last Insp	778	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	LTC Min Tap Position	10L	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	LTC Max Tap Position	1R	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	Oil Temp Max	110	°C
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	300.00	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Unknown Operations	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Switching Operations	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Operations This Read Vac	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Operations Counter AL	247	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Operations Counter AF	247	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Maintenance Operations	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Heaters (All) Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	General Comments		
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	General Comments		
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Follow-up Action Required?	n	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Fault Operations Ground	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Fault Operations C Ø	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Fault Operations B Ø	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Fault Operations A Ø	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	SWG000023	Switchgear	DX-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	YD000472	Yard	529-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Amps C Ø	0.0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Amps B Ø	0.0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Amps A Ø	0.0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0031	BreakerVacuum	549-0875	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Amps B Ø	200.0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Amps C Ø	200.0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Fault Operations A Ø	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Fault Operations B Ø	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Fault Operations C Ø	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Fault Operations Ground	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Follow-up Action Required?	n	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	General Comments		
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	General Comments		
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Maintenance Operations	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Operations Counter AF	452	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Operations Counter AL	452	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Operations This Read Vac	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Switching Operations	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Unknown Operations	0	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	414566	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	LTCC000704	LTCControl	807-1	LTC Control Insp	All Connections OK?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	LTCC000704	LTCControl	807-1	LTC Control Insp	Follow-up Action Required?	n	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	LTCC000704	LTCControl	807-1	LTC Control Insp	General Comments		
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	LTCC000704	LTCControl	807-1	LTC Control Insp	LTC Operation Checked?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	General Comments		
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	BCH000121	Charger	El-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	BCH000121	Charger	El-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	BCH000121	Charger	El-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	BCH000121	Charger	El-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	BCH000121	Charger	El-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.8	VDC
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	BCH000121	Charger	El-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.8	VDC
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	BCH000121	Charger	El-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	12.4	VDC
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	10.6	VDC
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	76	*F
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	BAT000335	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	BCH001070	Charger	DA-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	6.100	millivolts
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	BCH001070	Charger	DA-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	134.7	VDC
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	BCH001070	Charger	DA-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	134.7	VDC
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	BCH001070	Charger	DA-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.9	amps
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	BCH001070	Charger	DA-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	BCH001070	Charger	DA-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	BCH001070	Charger	DA-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	BCH001070	Charger	DA-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Counter Readings	Follow-up Action Required?	n	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Counter Readings	General Comments		
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Mechanism Patrol Inspection	General Comments		
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Counter Readings	LTC As Found Counter	55378	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Counter Readings	LTC As Left Counter	55391	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Counter Readings	LTC Current Tap Position	13L	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Counter Readings	LTC Max Tap Position	6L	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Counter Readings	LTC Min Tap Position	13L	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Counter Readings	LTC Operations Since Last Insp	697	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	B0422	LTCMechanism	711-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BCH000376	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BCH000376	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BCH000376	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	2.6	amps
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BCH000376	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BCH000376	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BCH000376	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	9 Month Operations	5	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0461	BreakerVacuum	549-0149	VCB Readings	Amps A Ø	200.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	Operations Counter AL	1070	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	Operations Counter AF	1070	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	Number of Ops last 9 Months	2	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	Maintenance Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	General Comments	,,	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	Fault Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	Amps C Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	Amps B Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	Amps A Ø	0.0	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Broom on Site?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	General Comments		
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	LTC Totalizer Reading	15138.00	kw
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	12L	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	2L	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments		
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	6L	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0845	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	Oil Temp Max	90	°C
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Readings	Oil Temp Present	45	°C
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	B0364	WithLTC	529-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Operations Counter	485	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	General Comments		
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Amps C Ø	19.7	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Amps B Ø	26.0	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	WX0332	RecloserHydraulic	440-1708	Recloser Hydraulic Patrol Inspection	Amps A Ø	19.5	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	LTCC000704	LTCControl	807-1	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	LTCC000704	LTCControl	807-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	LTCC000704	LTCControl	807-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	LTCC000704	LTCControl	807-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	LTCC000704	LTCControl	807-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	General Comments	over hanging trees and vegetation growing through fence in multiple spots	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	FE000069	Fence	711-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Ambient Temp	70	*F
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Trash Emptied?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	General Comments		
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	CH000150	ControlHouse	EW-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	General Comments		
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Vegetation	None	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	YD000070	Yard	711-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	Switching Operations	1	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Readings	Operations This Read Oil	1	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	ANN000087	Annunciator	DX-Annunciator Panel	Annunciator Patrol Inspection	General Comments		
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	ANN000087	Annunciator	DX-Annunciator Panel	Annunciator Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	ANN000087	Annunciator	DX-Annunciator Panel	Annunciator Patrol Inspection	ESOC Received Alarm Test?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	ANN000087	Annunciator	DX-Annunciator Panel	Annunciator Patrol Inspection	Control House Alarm Audible?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	ANN000087	Annunciator	DX-Annunciator Panel	Annunciator Patrol Inspection	All Lights Functioning?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Vegetation	None	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	General Comments		
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	YD000261	Yard	426-Yard	Yard Patrol Inspection	Ambient Temp	73	*F
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	Neutral	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	9R	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	6L	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	83514	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	R0588	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Switching Operations	1	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Operations This Read Vac	1	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Operations Counter AL	171	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Operations Counter AF	171	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Maintenance Operations	0	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	General Comments		
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Patrol Inspection	General Comments		
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Follow-up Action Required?	n	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Fault Operations Ground	0	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Fault Operations C Ø	0	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Fault Operations B Ø	0	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Fault Operations A Ø	0	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Amps C Ø	145.0	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Amps B Ø	135.0	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Amps A Ø	140.0	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	9 Month Operations	39	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Unknown Operations	0	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Switching Operations	2	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Operations This Read Vac	2	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Operations Counter AL	176	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	General Comments		
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	Follow-up Action Required?	n	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	General Comments		
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Mechanism Patrol Inspection	General Comments		
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	LTC As Found Counter	35280	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	LTC As Left Counter	35283	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	LTC Current Tap Position	2L	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	LTC Max Tap Position	7R	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	LTC Min Tap Position	10L	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	3.0	psi
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	B0409	LTCMechanism	807-1	LTC Counter Readings	LTC Operations Since Last Insp	1235	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Amps C Ø	150.0	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Amps B Ø	175.0	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Amps A Ø	170.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	9 Month Operations	33	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Regulator As Left Counter	64854	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Min Tap Position	11L	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	General Comments		
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	LTCC000253	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	60	Seconds
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	General Comments		
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Current Tap Position	7L	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0715	Regulator	616-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	General Comments		
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	General Comments		
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	LTC Totalizer Reading	13521.60	kw
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	Oil Temp Max	65	°C
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	Oil Temp Present	60	°C
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	Totalizer Meter Reading	.9390	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	Winding Temp Max	65	°C
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	Winding Temp Present	60	°C
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	55.00	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	B0409	WithLTC	807-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	General Comments		
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Vegetation	None	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	ST000250	Structure	616-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0716	Regulator	616-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Operations Counter AF	176	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Maintenance Operations	0	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	General Comments		
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Patrol Inspection	General Comments		
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Follow-up Action Required?	n	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Fault Operations Ground	0	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Fault Operations C Ø	0	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Fault Operations B Ø	0	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Fault Operations A Ø	0	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001600	BreakerVacuum	807-0120	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Regulator As Left Counter	300688	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0844	Regulator	810-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Unknown Operations	0	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Switching Operations	0	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Operations This Read Vac	0	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Operations Counter AL	143	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Operations Counter AF	143	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Maintenance Operations	0	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	General Comments		
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	General Comments		
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Follow-up Action Required?	n	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Fault Operations Ground	0	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Fault Operations C Ø	0	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Fault Operations B Ø	0	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Fault Operations A Ø	0	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Amps C Ø	605.0	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Amps B Ø	610.0	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Amps A Ø	625.0	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000575	BreakerVacuum	529-1	VCB Readings	9 Month Operations	2	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BAT000534	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BAT000534	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BAT000534	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BAT000534	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BAT000534	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BAT000534	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BAT000534	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BAT000534	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BAT000534	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BAT000534	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BAT000534	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BAT000534	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BAT000534	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BAT000534	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Unknown Operations	0	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	317.50	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	0.00	kw
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	General Comments	No KU meter	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	General Comments		
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	LTC Current Tap Position	6L	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	LTC As Left Counter	159702	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	LTC As Found Counter	159700	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Mechanism Patrol Inspection	General Comments		
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	General Comments		
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	0952	NonLTC	453-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	General Comments		
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	B0364	LTCMechanism	529-1	LTC Counter Readings	Follow-up Action Required?	n	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	ST000473	Structure	807-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Vegetation	None	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	General Comments		
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	YD000471	Yard	807-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Operations Counter	410	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	General Comments		
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Amps C Ø	26.7	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Amps B Ø	15.2	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	X0080	RecloserHydraulic	440-1709	Recloser Hydraulic Patrol Inspection	Amps A Ø	7.7	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	.7	VDC
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	2.7	VDC
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	BCH000438	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	BCH000438	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	BCH000438	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	All Connections OK?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BAT000533	Battery	807-Battery Bank Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Fault Operations Ground	0	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Fault Operations C Ø	0	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Fault Operations B Ø	0	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Fault Operations A Ø	0	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Amps C Ø	145.0	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Amps B Ø	155.0	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Amps A Ø	170.0	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	9 Month Operations	31	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001601	BreakerVacuum	807-0121	VCB Readings	Unknown Operations	0	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Switching Operations	1	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Operations This Read Vac	1	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Operations Counter AL	169	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Operations Counter AF	169	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Maintenance Operations	0	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	General Comments		
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Patrol Inspection	General Comments		
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Follow-up Action Required?	n	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Fault Operations Ground	0	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Ambient Temp	76	*F
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	YD000244	Yard	616-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Fault Operations C Ø	0	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Fault Operations B Ø	0	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Fault Operations A Ø	0	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Amps C Ø	0.0	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Amps B Ø	0.0	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Amps A Ø	0.0	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001603	BreakerVacuum	807-0141	VCB Readings	9 Month Operations	32	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Unknown Operations	0	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Switching Operations	2	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Operations This Read Vac	2	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Operations Counter AL	197	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Operations Counter AF	197	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Maintenance Operations	0	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	General Comments		
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Patrol Inspection	General Comments		
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001602	BreakerVacuum	807-0122	VCB Readings	Follow-up Action Required?	n	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	76	°F
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	BAT000342	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	55.00	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	Oil Temp Present	60	°C
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	Oil Temp Max	75	°C
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	0	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	LTC Min Tap Position	11L	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1511	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Counter Readings	General Comments		
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Counter Readings	LTC As Found Counter	3811	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Counter Readings	LTC As Left Counter	3811	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Counter Readings	LTC Max Tap Position	Neutral	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Counter Readings	LTC Min Tap Position	11L	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	206	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LT0065	LTCMechanism	DX-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	610.0	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	575.0	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	555.0	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Counter Readings	General Comments		
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Counter Readings	LTC As Found Counter	413314	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Counter Readings	LTC As Left Counter	413314	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Counter Readings	LTC Current Tap Position	11R	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Counter Readings	LTC Max Tap Position	11R	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Counter Readings	LTC Min Tap Position	3R	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	373	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	PN18	LTCMechanism	DU-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Counter Readings	General Comments		
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Counter Readings	LTC As Found Counter	15507	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Counter Readings	LTC As Left Counter	15507	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Counter Readings	LTC Current Tap Position	9R	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Current Tap Position	6R	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	General Comments		
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	LV Winding Temp Present	60	°C
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	General Comments		
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	General Comments		
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	General Comments		
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	LTC Totalizer Reading	10526.40	kw
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	Oil Temp Max	60	°C
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	Oil Temp Present	40	°C
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	Totalizer Meter Reading	.7310	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	Winding Temp Max	65	°C
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	Winding Temp Present	65	°C
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	B0464	WithLTC	549-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	40	°C
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	75	°C
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	40	°C
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	75	°C
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	40	°C
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	75	°C
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1300	psi
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	General Comments		
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	General Comments	removed one fan for repair	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	General Comments		
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	n	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LT0065	WithLTC	DX-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	45	°C
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	65	°C
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	45	°C
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	60	°C
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	45	°C
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	65	°C
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	General Comments		
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	General Comments		
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	R0382	Regulator	851-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Counter Readings	LTC Max Tap Position	13R	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Counter Readings	LTC Min Tap Position	8R	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments	New install 10/2/2020 now BK001604	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	521	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	PN30	LTCMechanism	EI-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	General Comments		
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	141	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	141	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BB0309	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	39	°C
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	63	°C
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	38	°C
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	62	°C
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	35	°C
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	59	°C
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LT0301	WithLTC	EW-TRANS 1	LTC Transformer Readings	Oil Temp Present	38	°C
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	General Comments		
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	n	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Follow-up Action Required?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	General Comments	no PT/CT/CCVT's in station	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	9 Month Operations	12	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	n	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	n	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	ST000597	Structure	EW-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Ambient Temp	71	°F
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	BAT001430	Battery	DU-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	BAT001430	Battery	DU-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	BAT001430	Battery	DU-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	BAT001430	Battery	DU-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	BAT001430	Battery	DU-Battery Bank	Battery Patrol Inspection	General Comments		
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	BAT001430	Battery	DU-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	BAT001430	Battery	DU-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	BAT001430	Battery	DU-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	BAT001430	Battery	DU-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	BAT001430	Battery	DU-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	BAT001430	Battery	DU-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	BAT001430	Battery	DU-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	BAT001430	Battery	DU-Battery Bank	Battery Patrol Inspection	Battery Bank Volts	26.6	VDC
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	BAT001430	Battery	DU-Battery Bank	Battery Patrol Inspection	Battery Bank Amps	0.0	AMPS
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	BAT001430	Battery	DU-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	BAT001430	Battery	DU-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	SWG000094	Switchgear	DA-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	General Comments		
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Unknown Operations	1	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Switching Operations	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Operations This Read Vac	11	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Operations Counter AL	188	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Operations Counter AF	188	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Maintenance Operations	10	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	General Comments	Replaced control board	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	General Comments		
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Follow-up Action Required?	n	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Fault Operations Ground	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Fault Operations C Ø	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Fault Operations B Ø	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Fault Operations A Ø	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Fault Adjusted Amps C Phase V	15.14	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Fault Adjusted Amps B Phase V	15.14	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Fault Adjusted Amps A Phase V	15.14	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Amps C Ø	200.0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Amps B Ø	230.0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Amps A Ø	205.0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Counter Readings	General Comments		
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Counter Readings	LTC As Found Counter	2339	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Counter Readings	LTC As Left Counter	2339	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0027	BreakerVacuum	549-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	173	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	290	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Amps C Ø	25.0	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Amps B Ø	28.0	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	Amps A Ø	30.0	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Counter Readings	LTC Current Tap Position	9L	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Counter Readings	LTC Max Tap Position	2R	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Counter Readings	LTC Min Tap Position	13L	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	WX0518	RecloserHydraulic	426-1513	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	233	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	FE000603	Fence	EW-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	LTC As Found Counter	70862	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	LTC As Left Counter	70862	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Ambient Temp	76	*F
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Low	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Readings	Oil Temp Present	28	°C
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Readings	Oil Temp Max	45	°C
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	General Comments	Main tank oil low	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Readings	General Comments		
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	PN30	WithLTC	EI-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	70	°C
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Current Tap Position	9L	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	General Comments		
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Max Tap Position	4L	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Min Tap Position	13L	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Regulator As Left Counter	26590	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	LTC Current Tap Position	8L	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	LTC Max Tap Position	2R	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	Oil Temp Present	35	°C
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	PN18	WithLTC	DU-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	General Comments		
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Vegetation	None	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	YD000606	Yard	EW-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	General Comments		
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Max Tap Position	5L	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Min Tap Position	14L	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Regulator As Left Counter	22090	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1424	Regulator	453-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1426	Regulator	453-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Vegetation	None	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	General Comments		
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	General Comments		
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Readings	General Comments		
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	FE000247	Fence	453-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1120	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	C0345	NonLTC	851-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	YD000248	Yard	453-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0062	LTCMechanism	DA-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Counter Readings	General Comments		
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0063	LTCMechanism	DA-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	General Comments		
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Yard Lights Working?	n	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Vegetation	None	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	General Comments	the front yard light is working, the one in the back did not come on when tested	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	YD000009	Yard	810-Yard	Yard Patrol Inspection	Ambient Temp	68	°F
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	Totalizer Meter Reading	.2466	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Adequate	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	Oil Temp Present	47	°C
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	Oil Temp Max	56	°C
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	295.92	kw
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	General Comments		
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	General Comments		
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	B0265	NonLTC	810-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Broom on Site?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	BCH001342	Charger	583-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	BCH001342	Charger	583-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	BCH001342	Charger	583-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	BCH001342	Charger	583-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	BCH001342	Charger	583-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	BCH001342	Charger	583-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	BCH001342	Charger	583-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	BCH001342	Charger	583-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.900	millivolts
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	General Comments		
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Regulator As Left Counter	353756	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Min Tap Position	13L	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	General Comments		
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Trash Emptied?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	CH000137	ControlHouse	DA-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Ambient Temp	74	°F
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	R0843	Regulator	810-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	ST000010	Structure	810-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Regulator As Left Counter	239832	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Current Tap Position	7L	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Min Tap Position	12L	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Max Tap Position	3L	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	General Comments		
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	Totalizer Meter Reading	.0410	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	Oil Temp Present	28	°C
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	Oil Temp Max	30	°C
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	General Comments		
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	General Comments		
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Readings	LTC Totalizer Reading	393.60	kw
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	B0422	WithLTC	711-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	General Comments		
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Min Tap Position	12R	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0454	Regulator	440-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	General Comments		
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	R1185	Regulator	453-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	General Comments		
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	YD000238	Yard	635-Yard	Yard Patrol Inspection	Vegetation	None	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Regulator As Left Counter	114257	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0455	Regulator	440-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Min Tap Position	12L	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	General Comments		
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	R0683	Regulator	616-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	SWG000198	Switchgear	EW-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	General Comments		
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LTO063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Ambient Temp	73	*F
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	General Comments		
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	45	°C
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	85	°C
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	50	°C
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	80	°C
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	50	°C
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	90	°C
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BCH000890	Charger	EW-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	5.400	millivolts
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BCH000890	Charger	EW-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.3	VDC
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	LTC Operations Since Last Insp	1269	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	LTC Min Tap Position	Neutral	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	LTC Max Tap Position	9L	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	LTC Current Tap Position	4L	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	LTC As Left Counter	212337	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	LTC As Found Counter	212334	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	General Comments		
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	Follow-up Action Required?	n	
7/10/2020 6:17	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
7/10/2020 6:17	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	LTC Operations Since Last Insp	1235	
7/10/2020 6:17	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	LTC Min Tap Position	1R	
7/10/2020 6:17	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	LTC Max Tap Position	11L	
7/10/2020 6:17	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	LTC Current Tap Position	2L	
7/10/2020 6:17	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	LTC As Left Counter	211065	
7/10/2020 6:17	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	LTC As Found Counter	211065	
7/10/2020 6:17	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	General Comments		
7/10/2020 6:17	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Counter Readings	Follow-up Action Required?	n	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	ST000254	Structure	453-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	General Comments		
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	ST000595	Structure	DA-Structure	Structure Patrol Inspection	UG Pothead Condition Good?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	Oil Temp Present	45	°C
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	Oil Temp Max	60	°C
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	700	psi
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.5	psi
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	ST000077	Structure	711-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	General Comments		
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0063	WithLTC	DA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	Vegetation	None	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	YD000259	Yard	440-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	Oil Temp Present	60	°C
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	0	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	Totalizer Meter Reading	0.0000	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BCH000890	Charger	EW-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.3	VDC
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BCH000890	Charger	EW-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.3	amps
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BCH000890	Charger	EW-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BCH000890	Charger	EW-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BCH000890	Charger	EW-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BCH000890	Charger	EW-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	Oil Temp Present	45	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	Oil Temp Max	70	°C
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	General Comments		
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	LT0062	WithLTC	DA-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	El-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	El-Yard	Yard Patrol Inspection	Vegetation	None	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	El-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	El-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	El-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	El-Yard	Yard Patrol Inspection	General Comments		
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	El-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	El-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	El-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	El-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	YD000620	Yard	El-Yard	Yard Patrol Inspection	Ambient Temp	69	°F
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	General Comments		
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	FE000228	Fence	635-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	General Comments		
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	FE000244	Fence	616-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	General Comments		
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	FE000614	Fence	DU-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	General Comments		
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	FE000382	Fence	549-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	El-2	AMCB Readings	9 Months Operations	0	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	El-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	El-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Amps A Ø	50.0	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Amps B Ø	120.0	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Amps C Ø	150.0	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Fault Operations A Ø	0	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Fault Operations B Ø	0	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Fault Operations C Ø	0	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Fault Operations Ground	0	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Follow-up Action Required?	n	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Patrol Inspection	General Comments		
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	General Comments		
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Maintenance Operations	0	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Operations Counter AF	502	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Operations Counter AL	502	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Operations This Read AM	0	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Switching Operations	0	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	LB0279	BreakerAirMagnetic	EI-2	AMCB Readings	Unknown Operations	0	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	FE000465	Fence	807-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	General Comments		
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	General Comments	No KU meter	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	0.00	kw
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	46.00	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	40.00	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	W0247	NonLTC	616-1	NonLTC Transformer Readings	Oil Temp Max	80	°C
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Fault Adjusted Amps A Phase V	6.27	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Fault Adjusted Amps C Phase V	6.27	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.3700	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	200	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Amps A Ø	59.0	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Amps B Ø	60.0	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Amps C Ø	1.0	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	General Comments		
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Operations Counter	9	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	MX0291	RecloserElectronic	711-0483	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	74.00	kw
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Readings	General Comments		
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	General Comments		
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	C0346	NonLTC	851-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Fault Operations A Ø	1	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Fault Operations B Ø	0	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Fault Operations C Ø	1	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Fault Operations Ground	0	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Follow-up Action Required?	n	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Patrol Inspection	General Comments		
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	General Comments	I on C/N and I on A/N	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Maintenance Operations	4	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Operations Counter AF	177	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Operations Counter AL	177	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Operations This Read Vac	7	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Switching Operations	1	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Unknown Operations	0	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	LTC Current Tap Position	9R	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	LTC Max Tap Position	15R	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	LTCC000768	LTCControl	549-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	LTCC000768	LTCControl	549-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	LTCC000768	LTCControl	549-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	LTCC000768	LTCControl	549-1	LTC Control Insp	LTC Output Voltage Level	124.6	VAC
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	General Comments		
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	WX0226	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	WX0226	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	WX0226	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	200	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	WX0226	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	WX0226	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	WX0226	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	WX0226	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	WX0226	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	WX0226	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	WX0226	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	WX0226	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	14.7	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	PF000095	PowerFuse	DA-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	Totalizer Meter Reading	.5022	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	Oil Temp Present	40	°C
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Fault Operations A Ø	0	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Fault Operations B Ø	0	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Fault Operations C Ø	0	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Fault Operations Ground	0	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Follow-up Action Required?	n	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Patrol Inspection	General Comments		
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	General Comments		
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Maintenance Operations	0	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Operations Counter AF	138	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Operations Counter AL	138	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Operations This Read Vac	0	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Switching Operations	0	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	9 Month Operations	0	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	Follow-up Action Required?	n	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	General Comments		
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Mechanism Patrol Inspection	General Comments	ltc oil level low	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	LTC As Found Counter	53098	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	LTC As Left Counter	53111	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Amps A Ø	110.0	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Amps B Ø	100.0	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Amps C Ø	95.0	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Fault Operations A Ø	0	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Fault Operations B Ø	0	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Fault Operations C Ø	0	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Fault Operations Ground	0	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
7/10/2020 6:17	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Fault Operations B Ø	0	
7/10/2020 6:17	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Fault Operations A Ø	0	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Follow-up Action Required?	n	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Patrol Inspection	General Comments		
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	General Comments		
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Maintenance Operations	0	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Operations Counter AF	150	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Operations Counter AL	150	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Operations This Read Vac	0	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Switching Operations	0	
7/10/2020 6:17	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
7/10/2020 6:17	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
7/10/2020 6:17	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
7/10/2020 6:17	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Amps C Ø	203.0	
7/10/2020 6:17	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Amps B Ø	202.0	
7/10/2020 6:17	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Amps A Ø	201.0	
7/10/2020 6:17	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Accumulated Fault Duty C Ph V	.88	%
7/10/2020 6:17	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Accumulated Fault Duty B Ph V	.44	%
7/10/2020 6:17	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Accumulated Fault Duty A Ph V	.22	%
7/10/2020 6:17	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	9 Month Operations	4	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Regulator As Left Counter	307819	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1222	Regulator	426-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	Oil Temp Max	60	°C
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	602.64	kw
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	PF000095	PowerFuse	DA-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	9 Month Operations	3	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Amps A Ø	129.0	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Amps B Ø	128.0	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Amps C Ø	109.0	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	General Comments		
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	General Comments		
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BCH001244	Charger	807-Battery Charger Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BCH001244	Charger	807-Battery Charger Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0138	NonLTC	426-2 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	LTCC000768	LTCControl	549-1	LTC Control Insp	LTC Operation Checked?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	LTCC000768	LTCControl	549-1	LTC Control Insp	General Comments		
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	LTCC000768	LTCControl	549-1	LTC Control Insp	Follow-up Action Required?	n	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	LTCC000768	LTCControl	549-1	LTC Control Insp	All Connections OK?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	LTC Min Tap Position	7R	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	LTC Operations Since Last Insp	0	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	S0039	LTCMechanism	583-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Unknown Operations	0	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Switching Operations	1	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Operations This Read Vac	1	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Operations Counter AL	218	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Operations Counter AF	218	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Maintenance Operations	0	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	General Comments		
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Follow-up Action Required?	n	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Fault Operations Ground	0	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Fault Operations C Ø	0	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Fault Operations B Ø	0	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Fault Operations A Ø	0	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Amps C Ø	165.0	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Amps B Ø	160.0	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Amps A Ø	161.0	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Accumulated Fault Duty C Ph V	.88	%
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Accumulated Fault Duty B Ph V	.44	%
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Accumulated Fault Duty A Ph V	.22	%
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	9 Month Operations	3	
7/10/2020 6:17	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Unknown Operations	0	
7/10/2020 6:17	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Switching Operations	1	
7/10/2020 6:17	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Operations This Read Vac	1	
7/10/2020 6:17	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Operations Counter AL	217	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
7/10/2020 6:17	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Operations Counter AF	216	
7/10/2020 6:17	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Maintenance Operations	0	
7/10/2020 6:17	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	General Comments		
7/10/2020 6:17	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Follow-up Action Required?	n	
7/10/2020 6:17	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Fault Operations Ground	0	
7/10/2020 6:17	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Readings	Fault Operations C Ø	0	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	LTCC000915	LTCControl	549-2	LTC Control Insp	VRR Time Delay	30	Seconds
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	LTCC000915	LTCControl	549-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	LTCC000915	LTCControl	549-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	LTCC000915	LTCControl	549-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	LTCC000915	LTCControl	549-2	LTC Control Insp	LTC Operation Checked?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	LTCC000915	LTCControl	549-2	LTC Control Insp	General Comments		
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	LTCC000915	LTCControl	549-2	LTC Control Insp	Follow-up Action Required?	n	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	LTCC000915	LTCControl	549-2	LTC Control Insp	All Connections OK?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	General Comments		
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	R1224	Regulator	426-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Amps A Ø	0.0	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Amps B Ø	0.0	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Amps C Ø	0.0	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000035	BreakerVacuum	EW-1244	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Operations Counter AL	159	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Switching Operations	0	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Operations This Read Vac	0	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Operations Counter AL	192	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Operations Counter AF	192	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Maintenance Operations	0	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	General Comments		
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	General Comments		
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Follow-up Action Required?	n	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Operations This Read Vac	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Switching Operations	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Unknown Operations	0	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Fault Operations Ground	0	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Fault Operations C Ø	0	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Fault Operations B Ø	0	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Fault Operations A Ø	0	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Current Tap Position	6R	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	General Comments		
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	R0317	Regulator	851-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	Follow-up Action Required?	n	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	General Comments		
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	General Comments		
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	LTC Totalizer Reading	7248.96	kw
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Operations Counter AF	90478	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Operations Counter AL	90478	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Operations This Read Vac	1	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Switching Operations	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	K0055	BreakerVacuum	549-0873	VCB Readings	Unknown Operations	0	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Maintenance Operations	0	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	SWG000081	Switchgear	DU-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	General Comments		
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	General Comments		
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Follow-up Action Required?	n	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	SWG000006	Switchgear	EI-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	General Comments		
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	General Comments		
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Maintenance Operations	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	LTCC000074	LTCControl	932-Offline Distribution	LTC Control Insp	All Connections OK?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	LTCC000074	LTCControl	932-Offline Distribution	LTC Control Insp	Follow-up Action Required?	n	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	LTCC000074	LTCControl	932-Offline Distribution	LTC Control Insp	General Comments		
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	LTCC000074	LTCControl	932-Offline Distribution	LTC Control Insp	LTC Operation Checked?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	LTCC000074	LTCControl	932-Offline Distribution	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	LTCC000074	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	LTCC000074	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	LTCC000074	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Fault Operations Ground	0	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Fault Operations C Ø	0	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Fault Operations B Ø	0	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Fault Operations A Ø	0	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Amps C Ø	110.0	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Amps B Ø	85.0	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Amps A Ø	100.0	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000923	BreakerVacuum	529-0095	VCB Readings	9 Month Operations	5	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Unknown Operations	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BK000707	BreakerVacuum	549-2	VCB Readings	Operations Counter AF	159	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Fault Operations A Ø	0	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Fault Operations B Ø	0	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Fault Operations C Ø	0	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Fault Operations Ground	0	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Follow-up Action Required?	n	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Patrol Inspection	General Comments		
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	General Comments		
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Maintenance Operations	0	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Operations Counter AF	176	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Operations Counter AL	176	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Operations This Read Vac	0	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Switching Operations	0	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	9 Month Operations	1	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Amps A Ø	32.0	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Amps B Ø	31.0	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Amps C Ø	22.0	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000033	BreakerVacuum	EW-1243	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Tank Leaks	None	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Insulators In Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	9 Month Operations	18	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BK001399	BreakerVacuum	807-0123	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Grounds in Place?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	General Comments		
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Capacitor Condition	Good	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	Bushing Condition	Good	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	CAP000014	CapacitorBank	583-Cap Bank	Capacitor Patrol Inspection	All Connections OK?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	PF000097	PowerFuse	DA-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	PF000097	PowerFuse	DA-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	PF000096	PowerFuse	DA-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	PF000096	PowerFuse	DA-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Adequate	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	ST000641	Structure	DX-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	325	psi
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Amps C Ø	180.0	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Amps B Ø	195.0	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Amps A Ø	235.0	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BK000922	BreakerVacuum	529-0092	VCB Readings	9 Month Operations	6	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	Oil Temp Max	60	°C
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	Oil Temp Present	30	°C
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	Totalizer Meter Reading	.5034	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	Winding Temp Max	60	°C
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	Winding Temp Present	30	°C
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KT0030	WithLTC	549-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	PF000101	PowerFuse	DX-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	PF000101	PowerFuse	DX-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	General Comments		
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	General Comments		
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	LTC Totalizer Reading	6246.72	kw
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	Oil Temp Max	75	°C
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	Oil Temp Present	45	°C
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	Totalizer Meter Reading	.4338	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	Winding Temp Max	70	°C
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	Winding Temp Present	30	°C
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	S0028	WithLTC	549-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	PF000115	PowerFuse	DA-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	PF000115	PowerFuse	DA-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	SWG000102	Switchgear	DA-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Amps A Ø	60.0	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Amps B Ø	58.0	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Amps C Ø	87.0	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	BK000032	BreakerVacuum	EW-1242	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Battery Load Check OK?	n	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Amps C Ø	30.0	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Amps B Ø	11.0	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Amps A Ø	29.0	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Amps C Ø	1.0	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	17	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	11	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	General Comments		
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	General Comments		
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	General Comments		
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Vegetation	None	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	General Comments		
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Ambient Temp	69	*F
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	General Comments		
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Broom on Site?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.1488	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	Oil Temp Present	20	*C
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	Oil Temp Max	20	*C
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	119.04	kw
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	YD000121	Yard	583-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	General Comments		
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	General Comments		
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	General Comments		
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	ST000245	Structure	635-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Operations Counter	4	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	MX0290	RecloserElectronic	711-0484	Recloser Electronic Patrol Inspection	General Comments		
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	12	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Amps A Ø	2.0	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	MX0267	RecloserHydraulic	810-0490	Recloser Hydraulic Patrol Inspection	Amps B Ø	3.0	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 11:35	Distribution	Dycusburg Quarterly Inspection	C0172	NonLTC	635-1 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	LTCC000738	LTCControl	529-1	LTC Control Insp	All Connections OK?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	LTCC000738	LTCControl	529-1	LTC Control Insp	Follow-up Action Required?	n	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	LTCC000738	LTCControl	529-1	LTC Control Insp	General Comments		
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	LTCC000738	LTCControl	529-1	LTC Control Insp	LTC Operation Checked?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	LTCC000738	LTCControl	529-1	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	LTCC000738	LTCControl	529-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	LTCC000738	LTCControl	529-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	LTCC000738	LTCControl	529-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	LTCC000738	LTCControl	529-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	LTC Operations Since Last Insp	725	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	50	°C
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	LTC Min Tap Position	11L	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	LTC Max Tap Position	2R	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	LTC Current Tap Position	8L	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	LTC As Left Counter	36373	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	LTC As Found Counter	36370	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Mechanism Patrol Inspection	General Comments		
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	General Comments		
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KT0030	LTCMechanism	549-3	LTC Counter Readings	Follow-up Action Required?	n	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	LTCC000804	LTCControl	711-1	LTC Control Insp	VRR Time Delay	60	Seconds
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	LTCC000804	LTCControl	711-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	LTCC000804	LTCControl	711-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	LTCC000804	LTCControl	711-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	LTCC000804	LTCControl	711-1	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	LTCC000804	LTCControl	711-1	LTC Control Insp	LTC Operation Checked?	y	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	LTCC000804	LTCControl	711-1	LTC Control Insp	General Comments		
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	LTCC000804	LTCControl	711-1	LTC Control Insp	Follow-up Action Required?	n	
10/12/2020 14:07	Distribution	Highsplint Quarterly Inspection	LTCC000804	LTCControl	711-1	LTC Control Insp	All Connections OK?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	General Comments		
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	FE000598	Fence	DA-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	General Comments		
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Vegetation	None	
10/16/2020 10:44	Distribution	Dahlia Quarterly Inspection	YD000603	Yard	DA-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	ST000268	Structure	426-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	General Comments		
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	ST000125	Structure	583-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	FE000259	Fence	426-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	BAT001433	Battery	EI-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	BAT001433	Battery	EI-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	BAT001433	Battery	EI-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	BAT001433	Battery	EI-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	BAT001433	Battery	EI-Battery Bank	Battery Patrol Inspection	General Comments		
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	BAT001433	Battery	EI-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	BAT001433	Battery	EI-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	BAT001433	Battery	EI-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	BAT001433	Battery	EI-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	BAT001433	Battery	EI-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	BAT001433	Battery	EI-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	BAT001433	Battery	EI-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	BAT001433	Battery	EI-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	77	*F
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	BAT001433	Battery	EI-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	General Comments		
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	CH000361	ControlHouse	529-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	FE000256	Fence	440-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Fault Operations C Ø	0	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Fault Operations Ground	0	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Follow-up Action Required?	n	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	General Comments		
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	General Comments		
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	General Comments		
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Follow-up Action Required?	n	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Fault Operations Ground	0	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Fault Operations C Ø	0	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Fault Operations B Ø	0	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Fault Operations A Ø	0	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Amps C Ø	22.0	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Amps B Ø	33.0	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Amps A Ø	27.0	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	General Comments		
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	R0456	Regulator	440-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Ambient Temp	76	°F
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	General Comments	TC	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Maintenance Operations	1	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Operations Counter AF	175	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Operations Counter AL	175	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Operations This Read Vac	1	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Switching Operations	0	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Readings	Oil Temp Present	40	°C
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Readings	Oil Temp Max	55	°C
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BCH001244	Charger	807-Battery Charger Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BCH001244	Charger	807-Battery Charger Distribution	Battery Charger Patrol Insp	Battery Charger Current	3.9	amps
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BCH001244	Charger	807-Battery Charger Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BCH001244	Charger	807-Battery Charger Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BCH001244	Charger	807-Battery Charger Distribution	Battery Charger Patrol Insp	General Comments		
10/12/2020 14:02	Distribution	FMC Quarterly Inspection	BCH001244	Charger	807-Battery Charger Distribution	Battery Charger Patrol Insp	Ground Lights	None	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Unknown Operations	0	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Switching Operations	0	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Operations This Read Vac	1	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Operations Counter AL	177	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Operations Counter AF	177	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Readings	General Comments		
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	General Comments		
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0137	NonLTC	426-2 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	Maintenance Operations	1	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Readings	Oil Temp Present	40	°C
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Readings	Oil Temp Max	45	°C
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Readings	General Comments		
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	General Comments		
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	W0139	NonLTC	426-2 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Fault Operations B Ø	0	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	General Comments		
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	General Comments		
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	398.88	kw
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	General Comments		
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/12/2020 11:39	Distribution	Holmes Mill Quarterly Inspection	FE000849	Fence	810-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4986	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	LTC Operations Since Last Insp	1515	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Trash Emptied?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	CH000184	ControlHouse	DX-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	LTC Min Tap Position	6L	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	LTC Max Tap Position	8R	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	LTC Current Tap Position	1L	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	LTC As Left Counter	103402	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	LTC As Found Counter	103400	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Mechanism Patrol Inspection	General Comments		
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	General Comments		
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	B0464	LTCMechanism	549-1	LTC Counter Readings	Follow-up Action Required?	n	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	General Comments		
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	FE000119	Fence	583-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 11:01	Distribution	Providence Quarterly Inspection	BK000724	BreakerVacuum	453-1422	VCB Readings	Unknown Operations	0	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Vegetation	None	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	YD000198	Yard	851-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	General Comments		
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Platform/Walkway/Railing OK?	y	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/12/2020 12:15	Distribution	Barnhill Quarterly Inspection	ST000205	Structure	851-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	Follow-up Action Required?	n	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	General Comments		
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Mechanism Patrol Inspection	General Comments		
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	LTC As Found Counter	60515	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	LTC As Left Counter	60518	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	LTC Current Tap Position	8L	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	LTC Max Tap Position	2R	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	LTC Min Tap Position	11L	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	LTC Operations Since Last Insp	611	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	S0028	LTCMechanism	549-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 13:24	Distribution	Fredonia Quarry Quarterly Inspection	BK000905	BreakerVacuum	426-1511	VCB Readings	9 Month Operations	2	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	General Comments		
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	FE000615	Fence	EI-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	Vegetation	None	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	General Comments		
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	YD000619	Yard	DU-Yard	Yard Patrol Inspection	Ambient Temp	70	*F
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 12:08	Distribution	Mexico Quarterly Inspection	W0189	NonLTC	440-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Fault Operations Ground	0	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Fault Operations C Ø	0	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Fault Operations B Ø	0	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Fault Operations A Ø	0	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	General Comments		
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Patrol Inspection	General Comments		
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Readings	Follow-up Action Required?	n	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	LB0278	BreakerAirMagnetic	EI-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Hydraulic Pressure Acceptable?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Hydraulic Oil Levels OK?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Fault Operations A Ø	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Fault Operations B Ø	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Fault Operations C Ø	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Fault Operations Ground	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Follow-up Action Required?	n	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	General Comments		
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	General Comments		
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Maintenance Operations	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Operations Counter AF	451	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Operations Counter AL	451	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Operations This Read Vac	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Switching Operations	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Unknown Operations	0	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Hydraulic Leaks	None	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Readings	General Comments		
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Unknown Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	Amps A Ø	0.0	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	Amps A Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	Amps B Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	Amps C Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	Fault Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	General Comments	..	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	Maintenance Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	Number of Ops last 9 Months	2	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	Operations Counter AF	1340	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	Operations Counter AL	1340	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	Operations This Read Oil	1	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Readings	Switching Operations	1	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	9 Month Operations	1	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Amps A Ø	340.0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Amps B Ø	320.0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Readings	Amps C Ø	310.0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0462	BreakerVacuum	549-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LB0270	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	200.0	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Amps C Ø	0.0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	9 Month Operations	0	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Amps A Ø	276.0	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Amps B Ø	220.0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Fault Operations A Ø	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0028	BreakerVacuum	549-BT3-2	VCB Readings	Fault Operations B Ø	0	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Amps C Ø	318.0	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Fault Operations A Ø	0	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Fault Operations B Ø	0	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Fault Operations C Ø	0	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Fault Operations Ground	0	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	774	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	774	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Follow-up Action Required?	n	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	General Comments		
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	General Comments		
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Maintenance Operations	0	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Operations Counter AF	137	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Operations Counter AL	137	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	12	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	100.0	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Operations This Read Vac	0	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Switching Operations	0	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	7	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	3	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	100.0	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	100.0	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LB0271	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	4	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 11:30	Distribution	Providence East Quarterly Inspection	CB0273	BreakerVacuum	616-1425	VCB Readings	Unknown Operations	0	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LB0269	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Operations Counter AL	139	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Operations This Read Vac	0	
10/12/2020 13:14	Distribution	Eastwood West Quarterly Inspection	LB1295	BreakerVacuum	EW-12KV TR1	VCB Readings	Switching Operations	0	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	4	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	4	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	91	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	91	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LB0274	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Follow-up Action Required?	n	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	General Comments		
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	General Comments	Lowside #3 opened	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Maintenance Operations	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Operations Counter AF	239	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Operations Counter AL	239	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Operations This Read Vac	1	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Switching Operations	1	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0029	BreakerVacuum	549-0874	VCB Readings	Unknown Operations	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Follow-up Action Required?	n	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	General Comments		
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	General Comments	Lowside #3 opened	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Maintenance Operations	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Operations Counter AF	248	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Operations Counter AL	248	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Maintenance Operations	0	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	General Comments		
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	Switching Operations	1	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	Operations This Read Oil	1	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	Operations Counter AL	907	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	Operations Counter AF	907	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	Number of Ops last 9 Months	2	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	Maintenance Operations	0	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Follow-up Action Required?	n	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	9 Month Operations	11	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Amps A Ø	40.0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Amps B Ø	40.0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Amps C Ø	40.0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	TB0473	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Fault Operations A Ø	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Fault Operations B Ø	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Fault Operations C Ø	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Fault Operations Ground	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Follow-up Action Required?	n	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	General Comments		
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	General Comments		
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Heaters (All) Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Maintenance Operations	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Operations Counter AF	396	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Operations Counter AL	396	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Operations Counter AL	647	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Operations This Read Vac	0	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Switching Operations	0	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Unknown Operations	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Fault Operations Ground	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Fault Operations C \emptyset	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Fault Operations B \emptyset	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Fault Operations A \emptyset	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Amps C \emptyset	120.0	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Amps B \emptyset	50.0	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Amps A \emptyset	120.0	
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/12/2020 11:56	Distribution	Eighth Street Quarterly Inspection	LB0280	BreakerAirMagnetic	EI-3	AMCB Readings	9 Months Operations	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Amps C \emptyset	65.0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Amps B \emptyset	85.0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Amps A \emptyset	80.0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	9 Month Operations	3	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Unknown Operations	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Switching Operations	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	BB0460	BreakerVacuum	549-0150	VCB Readings	Operations This Read Vac	0	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Amps A \emptyset	186.0	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Amps B \emptyset	185.0	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Amps C \emptyset	188.0	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Bushing Condition	Good	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Fault Operations A \emptyset	0	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Fault Operations B \emptyset	0	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Fault Operations C \emptyset	0	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Fault Operations Ground	0	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Switching Operations	0	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Operations This Read AM	0	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Operations Counter AL	584	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Operations Counter AF	584	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Maintenance Operations	0	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	General Comments		
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Patrol Inspection	General Comments		
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Fault Operations Ground	0	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Fault Operations C ∅	0	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Fault Operations B ∅	0	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Fault Operations A ∅	0	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Follow-up Action Required?	n	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Foundation Condition	Good	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	General Comments		
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Amps C ∅	100.0	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Amps B ∅	100.0	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Amps A ∅	120.0	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	General Comments	new swing panel commisson done on 8/4/20	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Grounds in Place?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Maintenance Operations	22	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Operations Counter AF	73	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Operations Counter AL	73	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Operations This Read Vac	22	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Switching Operations	0	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Unknown Operations	0	
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/12/2020 12:12	Distribution	Dumesnil Quarterly Inspection	LB0275	BreakerAirMagnetic	DU-1	AMCB Readings	9 Months Operations	0	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C ∅	20.0	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B ∅	20.0	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A ∅	20.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	Amps B ∅	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	Amps C ∅	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	Fault Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Readings	General Comments	..	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	6	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	9 Month Operations	27	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Fault Operations A ∅	0	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Fault Operations B ∅	0	
10/12/2020 15:30	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Fault Operations C ∅	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Unknown Operations	0	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Tank Paint Condition	Good	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Switching Operations	1	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A ∅	0	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B ∅	0	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C ∅	0	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/12/2020 12:35	Distribution	Bryant Road Quarterly Inspection	KB0030	BreakerVacuum	549-0905	VCB Readings	Operations This Read Vac	1	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	508	
10/12/2020 10:19	Distribution	Liberty Road Quarterly Inspection	BB0367	BreakerVacuum	529-0091	VCB Readings	Fault Operations Ground	0	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	508	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	2	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	2	
10/12/2020 10:19	Distribution	Dixie Quarterly Inspection	LB0272	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
10/12/2020 13:08	Distribution	Days Branch Quarterly Inspection	K0167	BreakerVacuum	583-0493	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LTCC000146	LTCControl	SSC-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LTCC000146	LTCControl	SSC-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LTC000146	LTCControl	SSC-Offline-Distribution	LTC Control Insp	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LTC000146	LTCControl	SSC-Offline-Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Switching Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Operations This Read Vac	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Operations Counter AL	124	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Operations Counter AF	124	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Maintenance Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Patrol Inspection	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Fault Operations A Ø	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Fault Operations B Ø	0	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000209	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000209	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000209	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Fault Operations C Ø	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Fault Operations Ground	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Follow-up Action Required?	n	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000209	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000209	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000209	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000209	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000209	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000209	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	LTC As Found Counter	18390	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Mechanism Patrol Inspection	General Comments		
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000209	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000209	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000209	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000209	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000209	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	LTC As Left Counter	18390	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	LTC Current Tap Position	8L	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	LTC Operations Since Last Insp	628	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	LTC Min Tap Position	11L	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	LTC Max Tap Position	1L	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Operations Counter AF	105	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Operations Counter AL	105	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Operations This Read Vac	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Switching Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Readings	Oil Temp Max	50	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Readings	Oil Temp Present	40	°C
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	General Comments		
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	ST000221	Structure	794-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	BCH000298	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	56.0	VDC
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	BCH000298	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	BCH000298	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0748	BreakerVacuum	P-1393-2	VCB Patrol Inspection	General Comments		
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	M0042	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	M0042	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	M0042	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	M0042	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	M0042	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	M0042	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	9 Month Operations	2	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Amps A Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Amps B Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Amps C Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Patrol Inspection	Bushing Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Fault Operations A Ø	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	LTCM000080	LTCMechanism	412-2	LTC Counter Readings	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Fault Operations B Ø	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Fault Operations C Ø	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Fault Operations Ground	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Readings	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0146	WithLTC	P-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Readings	Maintenance Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000954	BreakerVacuum	P-1391-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	LTCC000218	LTCControl	896-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	LTCC000218	LTCControl	896-2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	LTCC000218	LTCControl	896-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	LTCC000218	LTCControl	896-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	LTCC000218	LTCControl	896-2	LTC Control Insp	VRR Time Delay	30	Seconds
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	9 Month Operations	5	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Amps A Ø	25.0	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Amps B Ø	25.0	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Amps C Ø	25.0	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Bushing Condition	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0467	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0467	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0467	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0467	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0467	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0467	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0467	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0467	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0467	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0467	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0467	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0467	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0467	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0467	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0467	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0467	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0467	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	SWG000093	Switchgear	P-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0263	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0263	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0263	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0263	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0263	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0263	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0263	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0263	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0263	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Bushing Condition	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Amps C Ø	340.0	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0018	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0018	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0018	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0018	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	LTC Operations Since Last Insp	389	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	LTC Min Tap Position	16L	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	LTC Max Tap Position	9L	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	LTC Current Tap Position	13L	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	LTC As Left Counter	53644	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	LTC As Found Counter	53644	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Mechanism Patrol Inspection	General Comments		
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	General Comments		
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	B0472	LTCMechanism	475-1	LTC Counter Readings	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0187	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0187	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0187	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0187	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0187	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0187	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0187	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0187	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0187	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0187	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0187	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0187	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0187	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0187	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Fault Operations A Ø	0	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Fault Operations B Ø	0	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Fault Operations C Ø	0	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Fault Operations Ground	0	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Follow-up Action Required?	n	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Foundation Condition	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	General Comments		
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	General Comments		
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Grounds in Place?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Maintenance Operations	0	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Operations Counter AF	178	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Operations Counter AL	178	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	LTC Operations Since Last Insp	518	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	LTC Min Tap Position	8L	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	LTC Current Tap Position	5L	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	LTC As Left Counter	47109	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	LTC As Found Counter	47109	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Mechanism Patrol Inspection	General Comments		
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	General Comments		
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Operations This Read Vac	0	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Switching Operations	0	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0272	BreakerVacuum	716-0128	VCB Readings	Unknown Operations	0	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Unknown Operations	0	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	B0478	LTCMechanism	896-1	LTC Counter Readings	Follow-up Action Required?	n	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0018	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0018	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0018	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0018	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0018	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0285	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0285	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments	ok	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0285	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0285	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0285	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0285	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LTCC000145	LTCControl	P-TRANS 2	LTC Control Insp	All Connections OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LTCC000145	LTCControl	P-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LTCC000145	LTCControl	P-TRANS 2	LTC Control Insp	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LTCC000145	LTCControl	P-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	SWG000203	Switchgear	P-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	LTCC000643	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	LTCC000643	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	122.0	VAC
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	LTCC000643	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	122.0	VAC
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0250	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0250	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0250	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0250	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0250	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0250	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0250	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0250	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0250	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	52.50	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0250	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0250	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0250	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0250	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0250	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	LTCC000643	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	120.0	VAC
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	LTCC000643	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	LTCC000643	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	LTCC000643	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	LTCC000643	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0131	LTCMechanism	P-TRANS 4A	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0131	LTCMechanism	P-TRANS 4A	LTC Counter Readings	Follow-up Action Required?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0131	LTCMechanism	P-TRANS 4A	LTC Mechanism Patrol Inspection	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0131	LTCMechanism	P-TRANS 4A	LTC Counter Readings	General Comments	possible operation counter problem	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0131	LTCMechanism	P-TRANS 4A	LTC Counter Readings	LTC As Found Counter	90954	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0131	LTCMechanism	P-TRANS 4A	LTC Counter Readings	LTC As Left Counter	90954	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0225	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0225	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0225	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0225	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0225	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0225	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	256.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0225	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0225	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0225	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0225	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0225	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0225	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0225	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0225	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	LTC Operations Since Last Insp	785	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	40	°C
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	53	°C
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	LTC Min Tap Position	5L	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	LTC Max Tap Position	6R	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	LTC Current Tap Position	1L	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	LTC As Left Counter	20046	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	LTC As Found Counter	20046	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	General Comments		
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	General Comments		
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	KT0055	LTCMechanism	896-2	LTC Counter Readings	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	PF001212	PowerFuse	P-14KV TR-4A AUX PWR	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	PF001212	PowerFuse	P-14KV TR-4A AUX PWR	Disconnect Powerfuse Inspection	General Comments	OK	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	LTC Operations Since Last Insp	390	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	°C
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	55	°C
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	LTC Min Tap Position	11L	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	LTC Current Tap Position	6L	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	LTC As Left Counter	34214	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	LTC As Found Counter	34214	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Mechanism Patrol Inspection	General Comments		
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	General Comments		
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	S0055	LTCMechanism	412-1	LTC Counter Readings	Follow-up Action Required?	n	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0285	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0285	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0285	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0285	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0285	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0285	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Follow-up Action Required?	n	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Foundation Condition	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	General Comments		
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	General Comments		
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Grounds in Place?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Maintenance Operations	0	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Operations Counter AF	194	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Operations Counter AL	194	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Operations This Read Vac	0	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	KB0049	BreakerVacuum	716-1	VCB Readings	Switching Operations	0	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	Winding Temp Present	35	°C
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	Winding Temp Max	55	°C
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	Totalizer Meter Reading	.4840	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	B0478	WithLTC	896-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	PF000291	PowerFuse	P-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	PF000289	PowerFuse	P-STA SER 2	Disconnect Powerfuse Inspection	General Comments	ok	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	PF000289	PowerFuse	P-STA SER 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	General Comments		
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	General Comments		
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	LTC Totalizer Reading	10108.80	kw
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	Oil Temp Max	60	°C
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	Oil Temp Present	35	°C
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	Totalizer Meter Reading	.7020	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	Winding Temp Max	65	°C
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	Winding Temp Present	40	°C
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	110.00	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	B0379	WithLTC	412-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Unknown Operations	0	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Switching Operations	0	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Operations This Read Vac	0	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Operations Counter AL	213	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0467	LTCMechanism	912-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0467	LTCMechanism	912-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0467	LTCMechanism	912-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Operations Counter AF	213	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Maintenance Operations	0	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Grounds in Place?	y	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	General Comments		
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	General Comments		
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Foundation Condition	Good	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Follow-up Action Required?	n	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Fault Operations Ground	0	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Fault Operations C ∅	0	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Fault Operations B ∅	0	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BK000429	BreakerVacuum	896-0136	VCB Readings	Fault Operations A ∅	0	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Amps A ∅	28.0	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Amps B ∅	35.0	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Amps C ∅	18.0	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	General Comments		
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Operations Counter	90	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KX0206	RecloserElectronic	794-0839	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Operations This Read Vac	0	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Ambient Temp	79	°F
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Switching Operations	0	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Unknown Operations	0	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	General Comments		
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Vegetation	None	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	YD000215	Yard	794-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	PF000278	PowerFuse	P-14KV BUS SEC 1-B POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	PF000278	PowerFuse	P-14KV BUS SEC 1-B POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	71	°F
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	BAT000496	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0316	LTCMechanism	912-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0316	LTCMechanism	912-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0316	LTCMechanism	912-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0316	LTCMechanism	912-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0316	LTCMechanism	912-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	PF000292	PowerFuse	P-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	PF000292	PowerFuse	P-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Patrol Inspection	Bushing Condition	Good	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Amps C Ø	115.0	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Amps B Ø	110.0	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Amps A Ø	115.0	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	LTCC000886	LTCControl	896-1	LTC Control Insp	All Connections OK?	y	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	LTCC000886	LTCControl	896-1	LTC Control Insp	Follow-up Action Required?	n	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	LTCC000886	LTCControl	896-1	LTC Control Insp	General Comments		
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	LTCC000886	LTCControl	896-1	LTC Control Insp	LTC Operation Checked?	y	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	LTCC000886	LTCControl	896-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	LTCC000886	LTCControl	896-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	LTCC000886	LTCControl	896-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	LTCC000886	LTCControl	896-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BK000428	BreakerVacuum	896-0119	VCB Readings	9 Month Operations	0	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000080	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	9 Month Operations	7	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000080	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000080	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0335	BreakerVacuum	716-0070	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Patrol Inspection	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000774	BreakerVacuum	P-1385-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0252	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0252	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0252	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0252	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0252	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0252	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0252	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0252	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0252	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0252	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0252	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0252	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0252	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Unknown Operations	0	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Counter Readings	LTC Operations Since Last Insp	0	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Counter Readings	LTC Min Tap Position	Neutral	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Counter Readings	LTC Current Tap Position	Neutral	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Counter Readings	LTC As Left Counter	13897	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Counter Readings	LTC As Found Counter	13897	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Counter Readings	General Comments		
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Counter Readings	Follow-up Action Required?	n	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	General Comments		
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LTCC000007	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LTCC000007	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LTCC000007	LTCControl	Retired Distribution	LTC Control Insp	General Comments	OUT OF SERVICE	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LTCC000007	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	ST000386	Structure	475-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	PF000299	PowerFuse	P-1393 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	PF000299	PowerFuse	P-1393 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	PF000298	PowerFuse	P-1385 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	PF000298	PowerFuse	P-1385 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	PF000297	PowerFuse	P-14KV TR 4-B POT	Disconnect Powerfuse Inspection	General Comments	OUT OF SERVICE	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	PF000297	PowerFuse	P-14KV TR 4-B POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	PF000296	PowerFuse	P-TR 5 AUX PWR	Disconnect Powerfuse Inspection	General Comments	OK	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	PF000296	PowerFuse	P-TR 5 AUX PWR	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	PF000295	PowerFuse	P-14KV TR 5 POT	Disconnect Powerfuse Inspection	General Comments	OK	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	PF000295	PowerFuse	P-14KV TR 5 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	PF000293	PowerFuse	P-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	PF000293	PowerFuse	P-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	PF000291	PowerFuse	P-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Amps A Ø	400.0	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Amps B Ø	400.0	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Amps C Ø	400.0	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Bushing Condition	Good	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Fault Operations A Ø	0	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Fault Operations B Ø	0	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Fault Operations C Ø	0	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Fault Operations Ground	0	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0075	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0075	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0075	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0075	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0075	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0075	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0075	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments	no gauge	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0075	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0075	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0075	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0075	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0075	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0075	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0075	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Follow-up Action Required?	n	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Foundation Condition	Good	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	General Comments		
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	General Comments		
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Grounds in Place?	y	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Maintenance Operations	0	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Operations Counter AF	247	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Operations Counter AL	246	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Operations This Read Vac	0	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0391	BreakerVacuum	896-1	VCB Readings	Switching Operations	0	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0252	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Ambient Temp	71	°F
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	General Comments		
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	YD000382	Yard	475-Yard	Yard Patrol Inspection	Vegetation	None	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000874	LTCControl	716-2	LTC Control Insp	VRR Time Delay	30	Seconds
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000874	LTCControl	716-2	LTC Control Insp	VRR Base Voltage AL	0.0	VAC
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000874	LTCControl	716-2	LTC Control Insp	VRR Base Voltage AF	0.0	VAC
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000874	LTCControl	716-2	LTC Control Insp	LTC Output Voltage Level	0.0	VAC
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000874	LTCControl	716-2	LTC Control Insp	LTC Operation Checked?	n	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000874	LTCControl	716-2	LTC Control Insp	General Comments		
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000874	LTCControl	716-2	LTC Control Insp	Follow-up Action Required?	n	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000874	LTCControl	716-2	LTC Control Insp	All Connections OK?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	General Comments		
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Max Tap Position	7R	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Regulator As Left Counter	29530	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0108	Regulator	794-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0007	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0007	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0007	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0007	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	70.00	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0007	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0007	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0007	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0007	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0007	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0007	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Unknown Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Switching Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Operations This Read Vac	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Operations Counter AL	1171	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Operations Counter AF	1171	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Maintenance Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	General Comments	Cannot read last two digits on operation counter. Needs to be replaced.	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Patrol Inspection	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Follow-up Action Required?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Fault Operations Ground	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Fault Operations C Ø	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Fault Operations B Ø	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Fault Operations A Ø	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Amps C Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Amps B Ø	0.0	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0145	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0145	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0145	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Needs Replacing	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0145	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments	bad gauge	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0145	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0145	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0145	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0145	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0145	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0145	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0145	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0209	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0209	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0209	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0209	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0209	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0209	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0209	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0209	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Counter Readings	LTC Operations Since Last Insp	604	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Counter Readings	LTC Min Tap Position	3L	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Counter Readings	LTC Max Tap Position	6R	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Counter Readings	LTC Current Tap Position	4R	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Counter Readings	LTC As Left Counter	50831	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Counter Readings	LTC As Found Counter	50831	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Mechanism Patrol Inspection	General Comments		
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Counter Readings	General Comments		
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	LTCMechanism	716-1	LTC Counter Readings	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LTCM000006	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LTCM000006	LTCMechanism	Retired Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LTCM000006	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LTCM000006	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Operations Since Last Insp	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LTCM000006	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Min Tap Position	Neutral	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LTCM000006	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Max Tap Position	Neutral	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LTCM000006	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Current Tap Position	Neutral	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LTCM000006	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LTCM000006	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Left Counter	59102	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LTCM000006	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Found Counter	59102	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LTCM000006	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	General Comments	OUT OF SERVICE	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LTCM000006	LTCMechanism	Retired Distribution	LTC Counter Readings	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LTCM000006	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LTCM000006	LTCMechanism	Retired Distribution	LTC Counter Readings	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LTCM000005	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LTCM000005	LTCMechanism	Retired Distribution	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LTCM000005	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LTCM000005	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Operations Since Last Insp	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LTCM000005	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Min Tap Position	Neutral	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LTCM000005	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Max Tap Position	Neutral	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LTCM000005	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Current Tap Position	Neutral	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LTCM000005	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LTCM000005	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Left Counter	35242	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LTCM000005	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Found Counter	35242	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LTCM000005	LTCMechanism	Retired Distribution	LTC Counter Readings	General Comments	OUT OF SERVICE	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LTCM000005	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	General Comments	OUT OF SERVICE	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LTCM000005	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LTCM000005	LTCMechanism	Retired Distribution	LTC Counter Readings	Follow-up Action Required?	n	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Bushing Condition	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Amps C Ø	25.0	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Amps B Ø	25.0	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Amps A Ø	25.0	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	9 Month Operations	6	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	General Comments		
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	General Comments		
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1717.20	kw
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	70.00	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	Top Oil Temperature Max	35	°C
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	Top Oil Temperature Present	40	°C
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3600	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4770	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	Winding Temp Max	50	°C
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KT0054	NonLTC	794-1	NonLTC Transformer Readings	Winding Temp Present	40	°C
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	9 Month Operations	1	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Amps A Ø	65.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Amps B Ø	65.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Readings	Amps C Ø	65.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Patrol Inspection	Bushing Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK000936	BreakerVacuum	P-1386-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	General Comments		
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	FE000673	Fence	412-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000203	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000203	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000203	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000203	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000203	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000203	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000203	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000203	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000203	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000203	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000203	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000203	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000203	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000203	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Amps A Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0734	BreakerVacuum	P-1386-2	VCB Readings	9 Month Operations	1	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Unknown Operations	0	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Switching Operations	0	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Operations This Read Vac	0	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Operations Counter AL	358	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Operations Counter AF	358	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BCH000003	Charger	P-Battery Charger Sec 1 Swgr	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BCH000003	Charger	P-Battery Charger Sec 1 Swgr	Battery Charger Patrol Insp	As Found Float Voltage	135.0	VDC
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BCH000003	Charger	P-Battery Charger Sec 1 Swgr	Battery Charger Patrol Insp	As Left Float Voltage	135.0	VDC
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BCH000003	Charger	P-Battery Charger Sec 1 Swgr	Battery Charger Patrol Insp	Battery Charger Current	3.5	amps
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BCH000003	Charger	P-Battery Charger Sec 1 Swgr	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BCH000003	Charger	P-Battery Charger Sec 1 Swgr	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BCH000003	Charger	P-Battery Charger Sec 1 Swgr	Battery Charger Patrol Insp	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BCH000003	Charger	P-Battery Charger Sec 1 Swgr	Battery Charger Patrol Insp	Ground Lights	None	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Maintenance Operations	0	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Grounds in Place?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	General Comments		
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	General Comments		
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Foundation Condition	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Follow-up Action Required?	n	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Fault Operations C Ø	0	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Fault Operations B Ø	0	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Fault Operations A Ø	0	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	K0018	BreakerVacuum	716-1071	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	85.00	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	200.00	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Readings	X2 Winding Temp Max	0	°C
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0145	WithLTC	Retired Distribution	LTC Transformer Readings	X2 Winding Temp Present	0	°C
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Regulator As Left Counter	30108	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Max Tap Position	16R	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	General Comments		
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0109	Regulator	794-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Regulator As Left Counter	29152	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Max Tap Position	10R	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	General Comments		
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	KR0107	Regulator	794-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000068	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000068	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000068	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000068	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000068	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000068	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	35.00	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Counter Readings	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0146	LTCMechanism	P-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	General Comments		
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	General Comments		
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	LTC Totalizer Reading	6585.60	kw
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	Oil Temp Max	65	°C
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	Oil Temp Present	35	°C
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	Totalizer Meter Reading	.6860	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	Winding Temp Max	70	°C
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	Winding Temp Present	35	°C
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	S0055	WithLTC	412-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0333	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0333	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0333	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0333	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0333	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0333	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	27.50	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0333	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0333	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0333	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0333	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0333	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	C0333	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Patrol Inspection	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0739	BreakerVacuum	P-1389-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	9 Month Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Amps A Ø	250.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Amps B Ø	250.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Amps C Ø	250.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Fault Operations A Ø	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Fault Operations B Ø	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Fault Operations C Ø	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Fault Operations Ground	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Patrol Inspection	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Maintenance Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Operations Counter AF	577	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Operations Counter AL	577	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Operations This Read Vac	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Switching Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0754	BreakerVacuum	P-14KV TR 2	VCB Readings	Unknown Operations	0	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Bushing Condition	Good	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Bushing Oil Level	Good	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Fault Operations	0	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Follow-up Action Required?	n	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Foundation Condition	Good	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	General Comments		
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	General Comments		
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Grounds in Place?	y	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Heaters (All) Functioning?	y	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Hydraulic Leaks	None	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Hydraulic Oil Levels OK?	y	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Hydraulic Pressure Acceptable?	y	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Maintenance Operations	0	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Number of Ops last 9 Months	0	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Operations Counter AF	21	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Operations Counter AL	21	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Operations This Read Oil	0	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Switching Operations	0	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Tank Leaks	None	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Tank Oil Level	Good	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	TB0625	BreakerOil	475-608	OCB Readings	Unknown Operations	0	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Readings	Switching Operations	0	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	SF6 Pressure Indicator	good	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Readings	Operations This Read SF6	0	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Readings	Operations Counter AL	52	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Readings	Operations Counter AF	52	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Readings	Num Operations Last 9 Months	0	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	BK000061	BreakerSF6	412-618	GCB Readings	Maintenance Operations	0	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	CH000375	ControlHouse	412-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0274	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	5	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Amps C Ø	325.0	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Amps B Ø	360.0	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Amps A Ø	350.0	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	K0017	BreakerVacuum	716-BT1-2	VCB Readings	9 Month Operations	2	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000256	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000256	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000256	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000256	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000256	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0316	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0316	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0316	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0316	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0316	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0316	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Unknown Operations	0	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	LTCC000013	LTCControl	412-2	LTC Control Insp	VRR Time Delay	30	Seconds
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	LTCC000013	LTCControl	412-2	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	LTCC000013	LTCControl	412-2	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	LTCC000013	LTCControl	412-2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	LTCC000013	LTCControl	412-2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	General Comments		
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	FE000213	Fence	794-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	LTCC000013	LTCControl	412-2	LTC Control Insp	LTC Operation Checked?	y	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	LTCC000013	LTCControl	412-2	LTC Control Insp	General Comments		
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	LTCC000013	LTCControl	412-2	LTC Control Insp	Follow-up Action Required?	n	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Switching Operations	0	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Operations This Read Vac	0	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Operations Counter AL	534	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	LTCC000013	LTCControl	412-2	LTC Control Insp	All Connections OK?	y	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Operations Counter AF	534	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Maintenance Operations	0	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Grounds in Place?	y	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	General Comments		
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	General Comments		
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Foundation Condition	Good	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Follow-up Action Required?	n	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Fault Operations Ground	0	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Fault Operations C Ø	0	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Fault Operations B Ø	0	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Fault Operations A Ø	0	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0349	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0349	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0349	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0349	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0349	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0349	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0349	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0347	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0347	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Fault Operations A Ø	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Fault Operations B Ø	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Fault Operations C Ø	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Fault Operations Ground	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Follow-up Action Required?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Patrol Inspection	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	General Comments	The last digit on the operation counter is unreadable. Needs to be replaced.	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Maintenance Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Operations Counter AF	1002	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Operations Counter AL	1002	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Operations This Read Vac	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Switching Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Unknown Operations	0	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	9 Month Operations	2	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Amps A Ø	0.0	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Amps B Ø	0.0	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Amps C Ø	0.0	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Bushing Condition	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Fault Operations A Ø	0	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Fault Operations B Ø	0	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Fault Operations C Ø	0	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Fault Operations Ground	0	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Follow-up Action Required?	n	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Foundation Condition	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	General Comments		
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	General Comments		
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Grounds in Place?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Maintenance Operations	0	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Operations Counter AF	727	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Operations Counter AL	0	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Operations This Read Vac	0	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Switching Operations	0	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0362	BreakerVacuum	716-2	VCB Readings	Unknown Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Readings	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	General Comments	There are 5 fans not working on this TR. It appears that new fans were installed recently. Need PNC to troubleshoot.	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1100	psi
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Readings	Oil Temp Max	65	°C
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Readings	Oil Temp Present	45	°C
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0155	WithLTC	P-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	FE000377	Fence	475-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0123	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0123	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0123	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0123	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0158	GroundTransformer	P-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0158	GroundTransformer	P-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0158	GroundTransformer	P-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0158	GroundTransformer	P-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0123	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0158	GroundTransformer	P-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0158	GroundTransformer	P-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0158	GroundTransformer	P-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0158	GroundTransformer	P-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0158	GroundTransformer	P-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0158	GroundTransformer	P-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0158	GroundTransformer	P-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0158	GroundTransformer	P-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0158	GroundTransformer	P-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0158	GroundTransformer	P-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0123	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0123	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0123	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments	no gauge	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0123	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	Bushing Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	Radiator Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	Tank Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0159	GroundTransformer	P-GND TR 2	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0123	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0123	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0123	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0123	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0123	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	LTCC000159	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	LTCC000159	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	LTCC000159	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	LTCC000159	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	LTCC000159	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	122.0	VAC
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	LTCC000159	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	LTCC000159	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	LTCC000159	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	LTCC000159	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Patrol Inspection	Bushing Condition	Good	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Amps C Ø	600.0	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Amps B Ø	600.0	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Amps A Ø	600.0	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	BB0392	BreakerVacuum	896-2	VCB Readings	9 Month Operations	2	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	9 Month Operations	1	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Amps A Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Amps B Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Amps C Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0740	BreakerVacuum	P-1389-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Fault Operations Ground	0	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Fault Operations C Ø	0	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Fault Operations B Ø	0	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Fault Operations A Ø	0	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0155	LTCMechanism	P-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	176	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0155	LTCMechanism	P-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0155	LTCMechanism	P-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0155	LTCMechanism	P-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0186	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LTCC000091	LTCControl	P-TRANS 4A	LTC Control Insp	Follow-up Action Required?	n	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0146	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0146	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0146	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0146	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0146	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0146	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0146	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0146	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments	bad nitro gauge	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0146	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Needs Replacing	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	9 Month Operations	7	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0146	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0146	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0146	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0146	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	B0146	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Bushing Condition	Good	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Amps C Ø	5.0	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Amps B Ø	10.0	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Amps A Ø	10.0	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	9 Month Operations	6	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Unknown Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LTCC000091	LTCControl	P-TRANS 4A	LTC Control Insp	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LTCC000091	LTCControl	P-TRANS 4A	LTC Control Insp	Parallel / Ind. Sw Position	parallellIND	Position
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Readings	Totalizer Meter Reading	.5890	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Switching Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Operations This Read Vac	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Operations Counter AL	15	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Operations Counter AF	15	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Maintenance Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Patrol Inspection	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Fault Operations Ground	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Fault Operations C Ø	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Fault Operations B Ø	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Fault Operations A Ø	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0732	BreakerVacuum	P-1385-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000251	NonLTC	770-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000251	NonLTC	770-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000251	NonLTC	770-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000251	NonLTC	770-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000251	NonLTC	770-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000251	NonLTC	770-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000251	NonLTC	770-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000251	NonLTC	770-1	NonLTC Transformer Patrol Inspection	General Comments		
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000251	NonLTC	770-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000251	NonLTC	770-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000251	NonLTC	770-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000251	NonLTC	770-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000251	NonLTC	770-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	TX000251	NonLTC	770-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0186	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0735	BreakerVacuum	P-1387-1	VCB Patrol Inspection	General Comments		
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0186	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0186	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0186	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0186	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0155	LTCMechanism	P-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0155	LTCMechanism	P-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0155	LTCMechanism	P-TRANS 1	LTC Counter Readings	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0155	LTCMechanism	P-TRANS 1	LTC Counter Readings	LTC As Found Counter	301580	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0155	LTCMechanism	P-TRANS 1	LTC Counter Readings	LTC As Left Counter	301580	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0155	LTCMechanism	P-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0155	LTCMechanism	P-TRANS 1	LTC Counter Readings	LTC Current Tap Position	10L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0155	LTCMechanism	P-TRANS 1	LTC Counter Readings	LTC Max Tap Position	9L	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0155	LTCMechanism	P-TRANS 1	LTC Counter Readings	LTC Min Tap Position	10L	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Unknown Operations	0	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Switching Operations	0	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Operations This Read Vac	1	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Operations Counter AL	280	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Operations Counter AF	280	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Maintenance Operations	1	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Grounds in Place?	y	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	General Comments		
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	General Comments		
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Foundation Condition	Good	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Readings	Follow-up Action Required?	n	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	General Comments		
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Readings	General Comments		
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Readings	LTC Totalizer Reading	14136.00	kw
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Readings	Oil Temp Max	55	°C
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Readings	Oil Temp Present	35	°C
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/9/2020 12:10	Distribution	White Plains Quarterly Inspection	WB0176	BreakerVacuum	794-0837	VCB Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0292	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0292	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0292	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0292	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0292	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0292	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0292	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0292	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0003	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	Winding Temp Present	35	°C
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	Winding Temp Max	45	°C
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0003	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0003	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	15.00	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0003	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0003	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0003	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0003	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0003	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0003	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0003	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0003	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0186	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments	gone to pineville	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0186	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0186	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	207.50	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0186	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0186	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	Totalizer Meter Reading	.3720	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/9/2020 13:09	Distribution	UK Scott Street Quarterly Inspection	B0472	WithLTC	475-1	LTC Transformer Readings	Oil Temp Present	30	°C
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0186	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0292	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0292	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0292	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0292	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0292	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0292	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0292	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0292	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0292	WithLTC	912-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0003	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0003	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	KT0003	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Patrol Inspection	Bushing Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	LTC Totalizer Reading	11472.00	kw
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	YD000680	Yard	412-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	Totalizer Meter Reading	.4780	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001067	BreakerVacuum	P-GND TR 2	VCB Patrol Inspection	Bushing Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	Winding Temp Max	58	°C
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	YD000680	Yard	412-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	YD000680	Yard	412-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	Winding Temp Present	50	°C
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	General Comments		
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	General Comments		
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	General Comments		
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Readings	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Readings	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Fans Operational?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Readings	Oil Temp Max	50	°C
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Readings	Oil Temp Present	39	°C
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0147	WithLTC	P-TRANS 5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LTCC000147	LTCControl	P-TRANS 1	LTC Control Insp	All Connections OK?	y	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Fault Operations A Ø	0	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LTCC000147	LTCControl	P-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LTCC000147	LTCControl	P-TRANS 1	LTC Control Insp	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LTCC000147	LTCControl	P-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	9 Month Operations	1	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0319	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0319	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0319	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Amps B Ø	360.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Amps A Ø	205.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Amps B Ø	208.0	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Amps A Ø	350.0	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	BB0441	BreakerVacuum	716-0023	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Amps C Ø	205.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	S0013	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	S0013	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	S0013	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	S0013	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	S0013	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	S0013	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	S0013	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	S0013	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0471	WithLTC	716-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0319	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	S0013	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	W0319	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	S0013	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	S0013	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Patrol Inspection	Foundation Condition	Good	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	YD000680	Yard	412-Yard	Yard Patrol Inspection	Ambient Temp	71	*F
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Patrol Inspection	General Comments		
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	S0013	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	S0013	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	Oil Temp Present	49	*C
10/9/2020 12:37	Distribution	Earlington Substation Department Quarterly Transformer Inspection	S0013	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	YD000680	Yard	412-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0753	BreakerVacuum	P-14KV TR 1	YCB Readings	Fault Operations B Ø	0	Need size info and qty
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	YD000680	Yard	412-Yard	Yard Patrol Inspection	General Comments		
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	YD000680	Yard	412-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 11:32	Distribution	UK West Quarterly Inspection	YD000680	Yard	412-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	BK001068	BreakerVacuum	P-1387-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 14:20	Distribution	UK Med Center Quarterly Inspection	KT0055	WithLTC	896-2	LTC Transformer Readings	Oil Temp Max	57	*C
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Maintenance Operations	0	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Operations Counter AF	344	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Amps B Ø	255.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Air Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Air Pressure OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Bushing Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Bushing Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Acceptable Building Appearance?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Broom on Site?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Control House Lighting OK?	n	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Door Alarms OK?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Evidence of Insects	None	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Floor Swept?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Follow-up Action Required?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	General Comments	2 8ft bulbs out	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Panel Lights OK?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Amps A Ø	274.0	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Switching Operations	1	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Panels Dusted?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Operations This Read Vac	1	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Station Ground Set On Site?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Operations Counter AL	344	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	BCH000903	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Fault Operations Ground	0	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	BCH000903	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	BCH000903	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	BCH000903	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Amps C Ø	16.0	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Amps B Ø	14.0	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Amps A Ø	16.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Air Pressure OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Air Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Fault Operations C Ø	0	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Cabinet Paint Condition	Adequate	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Bushing Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Bushing Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	General Comments		
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	Amps C Ø	0.0	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Amps C Ø	256.0	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	General Comments		
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	General Comments		
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	LTC Totalizer Reading	3793.92	kw
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	Oil Temp Max	50	°C
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	Oil Temp Present	35	°C
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	11	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	2059	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	2059	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Tank Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	Switching Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	Operations This Read Oil	0	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	Totalizer Meter Reading	.3952	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Counter Readings	LTC Operations Since Last Insp	1666	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	45	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	37	°C
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Counter Readings	LTC Min Tap Position	4R	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	Operations Counter AL	2074	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	Operations Counter AF	2074	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	Number of Ops last 9 Months	0	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Unknown Operations	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Trash Emptied?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	CH000159	ControlHouse	CO-Control House 1	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Readings	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Pressure Vessel Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Tank Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0759	BreakerOil	P-14KV TR 5-A	OCB Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	SWG000046	Switchgear	CO-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	B0438	WithLTC	784-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	Fault Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Bushing Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Bushing Condition	Good	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Unknown Operations	0	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Switching Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	Amps C Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	Amps B Ø	0.0	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Operations This Read AM	0	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Operations Counter AL	510	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Operations Counter AF	510	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Maintenance Operations	0	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	General Comments		
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Patrol Inspection	General Comments		
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Follow-up Action Required?	n	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Fault Operations Ground	0	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Fault Operations C Ø	0	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Fault Operations B Ø	0	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Fault Operations A Ø	0	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Amps C Ø	320.0	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Amps B Ø	350.0	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Amps A Ø	300.0	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	Amps A Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	9 Months Operations	11	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	Switching Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Tank Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	Winding Temp Present	30	°C
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	Winding Temp Max	30	°C
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	Oil Temp Present	31	°C
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	Oil Temp Max	31	°C
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Readings	General Comments	ok	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KT0019	NonLTC	753-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0785	BreakerOil	P-SPARE # 9	OCB Patrol Inspection	Tank Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0785	BreakerOil	P-SPARE # 9	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0785	BreakerOil	P-SPARE # 9	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0785	BreakerOil	P-SPARE # 9	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0785	BreakerOil	P-SPARE # 9	OCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0785	BreakerOil	P-SPARE # 9	OCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0785	BreakerOil	P-SPARE # 9	OCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0785	BreakerOil	P-SPARE # 9	OCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0785	BreakerOil	P-SPARE # 9	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0785	BreakerOil	P-SPARE # 9	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	100.0	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	80.0	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	100.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Tank Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	Switching Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Pressure Vessel Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	Operations This Read Oil	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	Operations Counter AL	6231	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	Operations Counter AF	6231	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	Number of Ops last 9 Months	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	Maintenance Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0771	BreakerOil	P-SEC REA TIE 1-A	OCB Readings	Follow-up Action Required?	n	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	General Comments		
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Bushing Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Bushing Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	General Comments		
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	Fault Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Tank Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0765	BreakerOil	P-GND TR 1 A&B-A	OCB Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0781	BreakerOil	P-SPARE # 5	OCB Patrol Inspection	Tank Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0781	BreakerOil	P-SPARE # 5	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0781	BreakerOil	P-SPARE # 5	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0781	BreakerOil	P-SPARE # 5	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0781	BreakerOil	P-SPARE # 5	OCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0781	BreakerOil	P-SPARE # 5	OCB Patrol Inspection	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0781	BreakerOil	P-SPARE # 5	OCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0781	BreakerOil	P-SPARE # 5	OCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0781	BreakerOil	P-SPARE # 5	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0781	BreakerOil	P-SPARE # 5	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	BCH000903	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	BCH000903	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0444	BreakerAirMagnetic	HL-12KV TR 1	AMCB Readings	9 Months Operations	0	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Fault Operations A Ø	0	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Fault Operations B Ø	0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Amps A Ø	600.0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Amps B Ø	600.0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Amps C Ø	600.0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Fault Operations A Ø	0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Fault Operations B Ø	0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Fault Operations C Ø	0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Fault Operations Ground	0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Follow-up Action Required?	n	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Patrol Inspection	General Comments		
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	General Comments		
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Maintenance Operations	0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Operations Counter AF	99782	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Operations Counter AL	99782	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Operations This Read AM	0	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Patrol Inspection	Bushing Condition	Good	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Tank Paint Condition	Bad	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Tank Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Switching Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	Switching Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Pressure Vessel Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	Operations This Read Oil	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	Operations Counter AL	1270	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	Operations Counter AF	1270	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	Number of Ops last 9 Months	1	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	Maintenance Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	Follow-up Action Required?	n	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0178	BreakerAirMagnetic	CF-12KV TR 1	AMCB Readings	Unknown Operations	0	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Operations Counter	1829	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	MX0268	RecloserElectronic	765-0550	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	SWG000036	Switchgear	HL-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	General Comments		
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Cabinet Paint Condition	Adequate	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Pressure Vessel Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Patrol Inspection	General Comments		
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	General Comments		
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Maintenance Operations	0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Operations Counter AF	254	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0775	BreakerOil	P-SPARE # 1	OCB Patrol Inspection	Tank Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0775	BreakerOil	P-SPARE # 1	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0775	BreakerOil	P-SPARE # 1	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0775	BreakerOil	P-SPARE # 1	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0775	BreakerOil	P-SPARE # 1	OCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0775	BreakerOil	P-SPARE # 1	OCB Patrol Inspection	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0775	BreakerOil	P-SPARE # 1	OCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0775	BreakerOil	P-SPARE # 1	OCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0775	BreakerOil	P-SPARE # 1	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0775	BreakerOil	P-SPARE # 1	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Operations Counter AL	254	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Operations This Read AM	0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Switching Operations	0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Unknown Operations	0	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	General Comments	ok	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Tank Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Tank Paint Condition	Bad	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	General Comments		
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Amps A Ø	510.0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Amps B Ø	580.0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Amps C Ø	510.0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Pressure Vessel Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Cabinet Paint Condition	Adequate	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Fault Operations A Ø	0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Fault Operations B Ø	0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Fault Operations C Ø	0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Fault Operations Ground	0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	Follow-up Action Required?	n	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Bushing Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Bushing Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Air Pressure OK?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	General Comments		
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Regulator As Left Counter	38569	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Bushing Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Bushing Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1401	Regulator	580-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	ST000485	Structure	642-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Amps C Ø	280.0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Amps B Ø	300.0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Amps A Ø	300.0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	9 Month Operations	0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1033	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Bushing Condition	Good	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Operations Counter AL	99980	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Operations Counter AF	99980	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Maintenance Operations	0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	General Comments		
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Patrol Inspection	General Comments		
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Follow-up Action Required?	n	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Fault Operations Ground	0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Fault Operations C Ø	0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Fault Operations B Ø	0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Fault Operations A Ø	0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Amps C Ø	180.0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Amps B Ø	200.0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Amps A Ø	210.0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	9 Months Operations	19	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Vegetation	None	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	General Comments	ok	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	PF001203	PowerFuse	CF-STA SER NO 6	Disconnect Powerfuse Inspection	General Comments	ok	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	PF001203	PowerFuse	CF-STA SER NO 6	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	PF001203	PowerFuse	CF-STA SER NO 6	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	YD000221	Yard	753-Yard	Yard Patrol Inspection	Ambient Temp	64	*F
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	General Comments		
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	FE000477	Fence	642-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	ST000226	Structure	753-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Air Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	PF000300	PowerFuse	P-1382 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	PF000300	PowerFuse	P-1382 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	PF000288	PowerFuse	P-STA SER TRANS B	Disconnect Powerfuse Inspection	General Comments	ok	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	PF000288	PowerFuse	P-STA SER TRANS B	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	PF000287	PowerFuse	P-BUS TIE REA 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	PF000287	PowerFuse	P-BUS TIE REA 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	PF000286	PowerFuse	P-1388 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Switching Operations	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Operations This Read Vac	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Operations Counter AL	255	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Operations Counter AF	255	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Maintenance Operations	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	General Comments		
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Patrol Inspection	General Comments		
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Follow-up Action Required?	n	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Fault Operations Ground	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Fault Operations C Ø	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Fault Operations B Ø	0	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	General Comments		
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CH000377	ControlHouse	642-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	PF000286	PowerFuse	P-1388 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	PF000285	PowerFuse	P-14KV TR 3-B POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	PF000285	PowerFuse	P-14KV TR 3-B POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	PF000284	PowerFuse	P-1384 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	PF000284	PowerFuse	P-1384 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0777	BreakerOil	P-SPARE # 11	OCB Patrol Inspection	Tank Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0777	BreakerOil	P-SPARE # 11	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0777	BreakerOil	P-SPARE # 11	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0777	BreakerOil	P-SPARE # 11	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Unknown Operations	0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Switching Operations	0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0176	BreakerAirMagnetic	CF-1205	AMCB Readings	Operations This Read AM	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Fault Operations A Ø	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB1325	BreakerVacuum	CO-1193	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0777	BreakerOil	P-SPARE # 11	OCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0777	BreakerOil	P-SPARE # 11	OCB Patrol Inspection	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0777	BreakerOil	P-SPARE # 11	OCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0777	BreakerOil	P-SPARE # 11	OCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0777	BreakerOil	P-SPARE # 11	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0777	BreakerOil	P-SPARE # 11	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	General Comments		
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	LTC As Found Counter	22870	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	LTC As Left Counter	22870	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	LTC Current Tap Position	4L	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4R	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LT0051	LTCMechanism	CF-TRANS 1	LTC Counter Readings	LTC Min Tap Position	7L	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Tank Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Radiator Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0156	GroundTransformer	P-GND TR 1 A&B	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Amps C Ø	10.0	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Amps B Ø	10.0	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Amps A Ø	10.0	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	9 Month Operations	5	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Tank Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Tank Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	Switching Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	Operations This Read Oil	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	Operations Counter AL	1634	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	Operations Counter AF	1634	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	Number of Ops last 9 Months	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	Maintenance Operations	0	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	General Comments		
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Vegetation	None	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Arching Horns Good Condition?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	Fault Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Bushing Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Bushing Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Tank Leaks	None	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	General Comments		
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0767	BreakerOil	P-GND TR 2-A	OCB Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Counter Readings	LTC Max Tap Position	8L	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Counter Readings	LTC Current Tap Position	1L	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Counter Readings	LTC As Left Counter	49401	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Counter Readings	LTC As Found Counter	49398	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	General Comments		
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Counter Readings	General Comments		
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	LTCM000097	LTCMechanism	784-1	LTC Counter Readings	Follow-up Action Required?	n	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	General Comments		
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	FE000535	Fence	784-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Ambient Temp	68	*F
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	YD000540	Yard	784-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Unknown Operations	0	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Switching Operations	0	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Operations This Read Vac	0	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Operations Counter AL	207	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Operations Counter AF	207	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Maintenance Operations	0	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	General Comments		
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	General Comments		
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Follow-up Action Required?	n	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Fault Operations Ground	0	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Fault Operations C ∅	0	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Fault Operations B ∅	0	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Fault Operations A ∅	0	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	9 Month Operations	16	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Amps A ∅	10.0	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Amps B ∅	10.0	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Amps C ∅	10.0	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Bushing Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Fault Operations A ∅	0	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Fault Operations B ∅	0	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Fault Operations C ∅	0	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Fault Operations Ground	0	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Follow-up Action Required?	n	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	General Comments		
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	General Comments		
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Maintenance Operations	0	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Operations Counter AF	664	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Operations Counter AL	664	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Operations This Read Vac	0	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Switching Operations	0	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0230	BreakerVacuum	642-2230	VCB Readings	Unknown Operations	0	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0049	BreakerVacuum	407-2208	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	General Comments	ok	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	ST000580	Structure	HL-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	FE000221	Fence	753-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Tank Paint Condition	Bad	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Tank Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0766	BreakerOil	P-GND TR 1 A&B-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	General Comments		
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Readings	General Comments		
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	6007.68	kw
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Positive DC Ground	1.1	VDC
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Readings	Oil Temp Present	45	°C
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Negative DC Ground	1.2	VDC
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	General Comments	ok	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	BAT000344	Battery	753-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	S0040	NonLTC	580-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6258	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Air Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0756	BreakerOil	P-14KV TR 3-B	OCB Patrol Inspection	Air Pressure OK?	y	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0175	BreakerAirMagnetic	CF-1204	AMCB Readings	9 Months Operations	20	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Mechanism Patrol Inspection	General Comments		
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	B0325	LTCMechanism	408-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Bushing Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Patrol Inspection	Bushing Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	Amps C Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	Amps B Ø	0.0	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Amps A Ø	59.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0772	BreakerOil	P-SEC REA TIE 1-B	OCB Readings	Amps A Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	PF000277	PowerFuse	P-14KV BUS SEC 1-A POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	PF000277	PowerFuse	P-14KV BUS SEC 1-A POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Amps B Ø	46.0	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Amps C Ø	64.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	PF000279	PowerFuse	P-14KV BUS SEC 2-A POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	General Comments		
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Operations Counter	101	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	RC000429	RecloserElectronic	765-0552	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	ST000544	Structure	784-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	PF000279	PowerFuse	P-14KV BUS SEC 2-A POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	PF000281	PowerFuse	P-1381 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	PF000281	PowerFuse	P-1381 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0776	BreakerOil	P-SPARE # 10	OCB Patrol Inspection	Tank Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0776	BreakerOil	P-SPARE # 10	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0776	BreakerOil	P-SPARE # 10	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0776	BreakerOil	P-SPARE # 10	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0776	BreakerOil	P-SPARE # 10	OCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0776	BreakerOil	P-SPARE # 10	OCB Patrol Inspection	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0776	BreakerOil	P-SPARE # 10	OCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0776	BreakerOil	P-SPARE # 10	OCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0776	BreakerOil	P-SPARE # 10	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0776	BreakerOil	P-SPARE # 10	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Vegetation	None	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	General Comments		
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	YD000580	Yard	HL-Yard	Yard Patrol Inspection	Ambient Temp	70	*F
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Bushing Condition	Good	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	General Comments		
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	ST000427	Structure	408-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Vegetation	None	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	General Comments		
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	YD000425	Yard	408-Yard	Yard Patrol Inspection	Ambient Temp	77	*F
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	General Comments		
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Operations This Read AM	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Switching Operations	0	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Amps A Ø	0.0	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Amps B Ø	0.0	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Amps C Ø	0.0	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Fault Operations A Ø	0	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Fault Operations B Ø	0	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Fault Operations C Ø	0	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Fault Operations Ground	0	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Follow-up Action Required?	n	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Patrol Inspection	General Comments		
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	General Comments		
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Maintenance Operations	0	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Operations Counter AF	898	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Operations Counter AL	898	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Operations This Read AM	0	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Switching Operations	0	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Unknown Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0783	BreakerOil	P-SPARE # 7	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0783	BreakerOil	P-SPARE # 7	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0783	BreakerOil	P-SPARE # 7	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0783	BreakerOil	P-SPARE # 7	OCB Patrol Inspection	Tank Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Tank Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0727	BreakerOil	P-1383-A	OCB Patrol Inspection	Bushing Oil Level	Good	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	General Comments		
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	General Comments		
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Follow-up Action Required?	n	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	9 Months Operations	7	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Amps A Ø	50.0	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Amps B Ø	25.0	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Amps C Ø	25.0	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Fault Operations A Ø	0	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Fault Operations B Ø	0	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Fault Operations C Ø	0	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Fault Operations Ground	0	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Follow-up Action Required?	n	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Patrol Inspection	General Comments		
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	General Comments		
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Maintenance Operations	0	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Operations Counter AF	870	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Operations Counter AL	870	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Operations This Read AM	1	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Switching Operations	1	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0439	BreakerAirMagnetic	HL-1155	AMCB Readings	Unknown Operations	0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Fault Operations A Ø	0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Fault Operations B Ø	0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Fault Operations C Ø	0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Fault Operations Ground	0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Follow-up Action Required?	n	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Patrol Inspection	General Comments		
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	General Comments		
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Maintenance Operations	0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Operations Counter AF	358	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Operations Counter AL	358	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Operations This Read AM	0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Switching Operations	0	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	FE000421	Fence	408-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Bushing Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Bushing Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	9 Months Operations	42	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Amps A Ø	200.0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Amps B Ø	280.0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Amps C Ø	280.0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Tank Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0723	BreakerOil	P-1381-A	OCB Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Switching Operations	0	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Operations This Read Vac	0	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Operations Counter AL	172	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Operations Counter AF	172	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Maintenance Operations	0	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Maintenance Operations	0	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Operations Counter AF	655	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Operations Counter AL	655	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Operations This Read Vac	0	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Switching Operations	0	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Unknown Operations	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1074	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Counter Readings	LTC Min Tap Position	13L	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Counter Readings	LTC Max Tap Position	Neutral	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Counter Readings	LTC Current Tap Position	9L	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Counter Readings	LTC As Left Counter	120002	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Counter Readings	LTC As Found Counter	120002	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Mechanism Patrol Inspection	General Comments	oil guage shows low on ltc	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Counter Readings	General Comments		
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LT0059	LTCMechanism	CO-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	9 Months Operations	24	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Amps A Ø	210.0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Amps B Ø	100.0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Amps C Ø	220.0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Fault Operations A Ø	0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Fault Operations B Ø	0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Fault Operations C Ø	0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Fault Operations Ground	0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Follow-up Action Required?	n	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	General Comments		
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	9 Months Operations	4	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	FE000350	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	9 Month Operations	4	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Amps A Ø	12.0	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Amps B Ø	24.0	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Amps C Ø	24.0	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Bushing Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Fault Operations A Ø	0	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Fault Operations B Ø	0	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Fault Operations C Ø	0	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Fault Operations Ground	0	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	Follow-up Action Required?	n	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	General Comments		
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Readings	General Comments		
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	CB0229	BreakerVacuum	642-2233	VCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	General Comments		
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	9 Months Operations	3	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Amps A Ø	0.0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Amps B Ø	0.0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Amps C Ø	0.0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations A Ø	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations B Ø	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations C Ø	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations Ground	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Follow-up Action Required?	n	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Patrol Inspection	General Comments		
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	General Comments	Actual counter	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Maintenance Operations	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AF	790	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0228	BreakerAirMagnetic	CO-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AL	790	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0784	BreakerOil	P-SPARE # 8	OCB Patrol Inspection	Tank 3 Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0784	BreakerOil	P-SPARE # 8	OCB Patrol Inspection	Tank Leaks	None	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	9 Months Operations	26	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0783	BreakerOil	P-SPARE # 7	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0783	BreakerOil	P-SPARE # 7	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0783	BreakerOil	P-SPARE # 7	OCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0783	BreakerOil	P-SPARE # 7	OCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0783	BreakerOil	P-SPARE # 7	OCB Patrol Inspection	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0783	BreakerOil	P-SPARE # 7	OCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0441	BreakerAirMagnetic	HL-1157	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Maintenance Operations	0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Operations Counter AF	99969	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Operations Counter AL	99969	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Operations This Read AM	0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Switching Operations	0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0173	BreakerAirMagnetic	CF-1202	AMCB Readings	Unknown Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Tank Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Bushing Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0750	BreakerOil	P-1394-B	OCB Patrol Inspection	Bushing Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0784	BreakerOil	P-SPARE # 8	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0784	BreakerOil	P-SPARE # 8	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0784	BreakerOil	P-SPARE # 8	OCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0784	BreakerOil	P-SPARE # 8	OCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0784	BreakerOil	P-SPARE # 8	OCB Patrol Inspection	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0784	BreakerOil	P-SPARE # 8	OCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0784	BreakerOil	P-SPARE # 8	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0784	BreakerOil	P-SPARE # 8	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	ST000567	Structure	765-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	General Comments		
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Vegetation	None	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	General Comments		
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	General Comments		
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Bushing Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Bushing Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Air Pressure OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Air Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LT0088	WithLTC	HL-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	YD000512	Yard	580-Yard	Yard Patrol Inspection	Ambient Temp	77	°F

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	General Comments		
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	*F
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	BCH001237	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	General Comments		
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	BCH001237	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	BCH001237	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	BCH001237	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	BCH001237	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	BCH001237	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	BCH001237	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Vegetation	None	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	General Comments		
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0779	BreakerOil	P-SPARE # 13	OCB Patrol Inspection	Tank Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0779	BreakerOil	P-SPARE # 13	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0779	BreakerOil	P-SPARE # 13	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0779	BreakerOil	P-SPARE # 13	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0779	BreakerOil	P-SPARE # 13	OCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0779	BreakerOil	P-SPARE # 13	OCB Patrol Inspection	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0779	BreakerOil	P-SPARE # 13	OCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0779	BreakerOil	P-SPARE # 13	OCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0779	BreakerOil	P-SPARE # 13	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0779	BreakerOil	P-SPARE # 13	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	YD000563	Yard	765-Yard	Yard Patrol Inspection	Ambient Temp	77	*F
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	WithLTC	716-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Tank Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Pressure Vessel Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	ST000517	Structure	580-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Bushing Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Bushing Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Air Pressure OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0742	BreakerOil	P-1390-B	OCB Patrol Inspection	Air Leaks	None	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Positive DC Ground	25.0	VDC
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	BAT001301	Battery	642-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Air Pressure OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Air Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Air Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Air Pressure OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Bushing Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Bushing Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Cabinet Paint Condition	Bad	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Pressure Vessel Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Tank Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0724	BreakerOil	P-1381-B	OCB Patrol Inspection	Tank Paint Condition	Bad	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0780	BreakerOil	P-SPARE # 2	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0780	BreakerOil	P-SPARE # 2	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0780	BreakerOil	P-SPARE # 2	OCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0780	BreakerOil	P-SPARE # 2	OCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0780	BreakerOil	P-SPARE # 2	OCB Patrol Inspection	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0780	BreakerOil	P-SPARE # 2	OCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0780	BreakerOil	P-SPARE # 2	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0780	BreakerOil	P-SPARE # 2	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0780	BreakerOil	P-SPARE # 2	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0780	BreakerOil	P-SPARE # 2	OCB Patrol Inspection	Tank Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Tank Leaks	None	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0174	BreakerAirMagnetic	CF-1203	AMCB Readings	Unknown Operations	0	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Fault Operations Ground	0	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Fault Operations C ∅	0	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Fault Operations B ∅	0	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Fault Operations A ∅	0	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Amps C Ø	43.0	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Amps B Ø	55.0	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Amps A Ø	35.0	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	BK001121	BreakerVacuum	784-2211	VCB Readings	9 Month Operations	4	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	PF001133	PowerFuse	P-1394 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	PF001133	PowerFuse	P-1394 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Tank Paint Condition	Bad	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Tank Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Pressure Vessel Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Cabinet Paint Condition	Bad	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Bushing Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Bushing Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0726	BreakerOil	P-1382-B	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	General Comments		
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	General Comments		
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2845.44	kw
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	Totalizer Meter Reading	.2964	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	General Comments		
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	FE000504	Fence	407-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Pressure Vessel Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0741	BreakerOil	P-1390-A	OCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	9 Month Operations	11	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	SWG000019	Switchgear	CF-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Amps A Ø	110.0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Amps B Ø	120.0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Amps C Ø	120.0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Fault Operations A Ø	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Fault Operations B Ø	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Fault Operations C Ø	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Fault Operations Ground	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Follow-up Action Required?	n	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Patrol Inspection	General Comments		
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	General Comments		
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Maintenance Operations	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Operations Counter AF	457	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Operations Counter AL	457	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Operations This Read Vac	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0224	BreakerVacuum	CO-1197	VCB Readings	Switching Operations	0	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	S0046	NonLTC	407-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	General Comments		
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Regulator As Left Counter	123108	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	PF000094	PowerFuse	CO-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	PF000093	PowerFuse	CO-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	PF000093	PowerFuse	CO-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	PF000092	PowerFuse	CO-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	PF000092	PowerFuse	CO-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	PF000091	PowerFuse	CO-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	PF000091	PowerFuse	CO-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0782	BreakerOil	P-SPARE # 6	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0782	BreakerOil	P-SPARE # 6	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0782	BreakerOil	P-SPARE # 6	OCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0782	BreakerOil	P-SPARE # 6	OCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0782	BreakerOil	P-SPARE # 6	OCB Patrol Inspection	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0782	BreakerOil	P-SPARE # 6	OCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0782	BreakerOil	P-SPARE # 6	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0782	BreakerOil	P-SPARE # 6	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0782	BreakerOil	P-SPARE # 6	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0782	BreakerOil	P-SPARE # 6	OCB Patrol Inspection	Tank Leaks	None	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	ANN000018	Annunciator	CF-Annunciator Panel	Annunciator Patrol Inspection	All Lights Functioning?	y	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	ANN000018	Annunciator	CF-Annunciator Panel	Annunciator Patrol Inspection	Control House Alarm Audible?	y	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	ANN000018	Annunciator	CF-Annunciator Panel	Annunciator Patrol Inspection	ESOC Received Alarm Test?	y	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	ANN000018	Annunciator	CF-Annunciator Panel	Annunciator Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	ANN000018	Annunciator	CF-Annunciator Panel	Annunciator Patrol Inspection	General Comments		
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Unknown Operations	0	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Switching Operations	0	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Operations This Read Vac	0	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Operations Counter AL	149	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Bushing Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Bushing Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Vegetation	None	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0153	GroundTransformer	P-GND TR 2A	Ground Transformer Patrol Inspection	Bushing Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0153	GroundTransformer	P-GND TR 2A	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0153	GroundTransformer	P-GND TR 2A	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0153	GroundTransformer	P-GND TR 2A	Ground Transformer Patrol Inspection	Follow-up Action Required?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0153	GroundTransformer	P-GND TR 2A	Ground Transformer Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0153	GroundTransformer	P-GND TR 2A	Ground Transformer Patrol Inspection	General Comments	oil is leaking/seeping at oil level gauge	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0153	GroundTransformer	P-GND TR 2A	Ground Transformer Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0153	GroundTransformer	P-GND TR 2A	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0153	GroundTransformer	P-GND TR 2A	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0153	GroundTransformer	P-GND TR 2A	Ground Transformer Patrol Inspection	Radiator Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0153	GroundTransformer	P-GND TR 2A	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0153	GroundTransformer	P-GND TR 2A	Ground Transformer Patrol Inspection	Tank Leaks	Seeping	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0153	GroundTransformer	P-GND TR 2A	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Bushing Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Bushing Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1128	Regulator	765-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Operations Counter AF	64	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Maintenance Operations	0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	General Comments		
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Patrol Inspection	General Comments		
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Follow-up Action Required?	n	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Fault Operations Ground	0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Fault Operations C ∅	0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Fault Operations B ∅	0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Fault Operations A ∅	0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Amps C ∅	100.0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Amps B ∅	100.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Amps A Ø	100.0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	9 Months Operations	48	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Maintenance Operations	0	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Patrol Inspection	Grounds in Place?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	General Comments		
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Patrol Inspection	General Comments		
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Patrol Inspection	Foundation Condition	Good	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Follow-up Action Required?	n	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Fault Operations Ground	0	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Fault Operations C Ø	0	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Fault Operations B Ø	0	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Fault Operations A Ø	0	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Operations Counter AF	149	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Maintenance Operations	0	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Patrol Inspection	Grounds in Place?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	General Comments		
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Patrol Inspection	Foundation Condition	Good	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Follow-up Action Required?	n	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Fault Operations Ground	0	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Fault Operations C Ø	0	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Fault Operations B Ø	0	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Fault Operations A Ø	0	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Patrol Inspection	Bushing Condition	Good	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Amps C Ø	36.0	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Amps B Ø	43.0	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Amps A Ø	30.0	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001425	BreakerVacuum	408-2223	VCB Readings	9 Month Operations	1	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Unknown Operations	0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Switching Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Cabinet Paint Condition	Bad	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Unknown Operations	0	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Switching Operations	0	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Operations This Read Vac	0	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Operations Counter AL	170	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Operations Counter AF	170	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Operations This Read AM	0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LB0172	BreakerAirMagnetic	CF-1201	AMCB Readings	Operations Counter AL	64	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Bushing Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Cabinet Paint Condition	Adequate	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Follow-up Action Required?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	General Comments	Strip heater not functioning. 350W 240V	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Pressure Vessel Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0755	BreakerOil	P-SPARE 15	OCB Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0755	BreakerOil	P-SPARE 15	OCB Patrol Inspection	Tank Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0755	BreakerOil	P-SPARE 15	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0755	BreakerOil	P-SPARE 15	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0755	BreakerOil	P-SPARE 15	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0755	BreakerOil	P-SPARE 15	OCB Readings	Operations This Read Oil	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0755	BreakerOil	P-SPARE 15	OCB Readings	Operations Counter AL	1262	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0755	BreakerOil	P-SPARE 15	OCB Readings	Operations Counter AF	1262	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0755	BreakerOil	P-SPARE 15	OCB Readings	Number of Ops last 9 Months	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0755	BreakerOil	P-SPARE 15	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0755	BreakerOil	P-SPARE 15	OCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0755	BreakerOil	P-SPARE 15	OCB Patrol Inspection	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0755	BreakerOil	P-SPARE 15	OCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0755	BreakerOil	P-SPARE 15	OCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0755	BreakerOil	P-SPARE 15	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0755	BreakerOil	P-SPARE 15	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0755	BreakerOil	P-SPARE 15	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0755	BreakerOil	P-SPARE 15	OCB Patrol Inspection	Bushing Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Tank Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Tank Paint Condition	Bad	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	Amps C Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	Amps B Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	Amps A Ø	0.0	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	Maintenance Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	General Comments	Compressor drain valve is completely clogged. Could not drain compressor tank of water.	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	Amps B Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Readings	Amps A Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0004	BreakerVacuum	642-2229	VCB Readings	9 Month Operations	3	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Air Pressure OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Air Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0730	BreakerOil	P-1384-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Follow-up Action Required?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Readings	Fault Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Bushing Condition	Good	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Foundation Condition	Good	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	General Comments		
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Grounds in Place?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK000910	BreakerVacuum	408-2222	VCB Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Bushing Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0774	BreakerOil	P-SEC TIE 1-B	OCB Patrol Inspection	Bushing Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Air Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Air Pressure OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0768	BreakerOil	P-GND TR 2-B	OCB Patrol Inspection	Bushing Condition	Good	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	PF000108	PowerFuse	CF-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	PF000108	PowerFuse	CF-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	PF000108	PowerFuse	CF-12KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	PF000107	PowerFuse	CF-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	PF000107	PowerFuse	CF-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	PF000107	PowerFuse	CF-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Tank Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Bushing Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	PF000094	PowerFuse	CO-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Bushing Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	LTCC000618	LTCControl	642-1 B	LTC Control Insp	All Connections OK?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	LTCC000618	LTCControl	642-1 B	LTC Control Insp	Follow-up Action Required?	n	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	LTCC000618	LTCControl	642-1 B	LTC Control Insp	General Comments		
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	LTCC000618	LTCControl	642-1 B	LTC Control Insp	LTC Operation Checked?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	LTCC000618	LTCControl	642-1 B	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	LTCC000618	LTCControl	642-1 B	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	LTCC000618	LTCControl	642-1 B	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	LTCC000618	LTCControl	642-1 B	LTC Control Insp	VRR Time Delay	30	Seconds
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Air Leaks	None	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Ambient Temp	63	°F
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	YD000356	Yard	716-Yard	Yard Patrol Inspection	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Air Pressure OK?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0075	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0725	BreakerOil	P-1382-A	OCB Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Air Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Air Pressure OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Bushing Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Bushing Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Pressure Vessel Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Tank Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0745	BreakerOil	P-1392-A	OCB Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	SWG000119	Switchgear	CO-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Unknown Operations	0	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Switching Operations	0	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Operations This Read Vac	1	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Operations Counter AL	128	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Operations Counter AF	128	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Maintenance Operations	1	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	General Comments	ok	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	General Comments	ok	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Tank Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Pressure Vessel Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Bushing Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Bushing Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Air Pressure OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Air Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0749	BreakerOil	P-1394-A	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	PF000180	PowerFuse	HL-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	PF000180	PowerFuse	HL-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	PF000180	PowerFuse	HL-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Amps C Ø	5.0	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Amps B Ø	48.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Amps A Ø	30.0	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	9 Month Operations	2	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	9 Months Operations	25	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Amps A Ø	370.0	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Amps B Ø	380.0	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Amps C Ø	380.0	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Fault Operations A Ø	0	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Fault Operations B Ø	0	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Fault Operations C Ø	0	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Fault Operations Ground	0	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Follow-up Action Required?	n	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Patrol Inspection	General Comments		
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	General Comments		
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Maintenance Operations	0	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Operations Counter AF	1305	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Operations Counter AL	1305	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Operations This Read AM	0	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Switching Operations	0	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0440	BreakerAirMagnetic	HL-1156	AMCB Readings	Unknown Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	PF000283	PowerFuse	P-14KV TR 4-A POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	PF000283	PowerFuse	P-14KV TR 4-A POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	PF000282	PowerFuse	P-1383 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	PF000282	PowerFuse	P-1383 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	General Comments		
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Current Tap Position	4L	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Bushing Condition	Good	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Amps C Ø	65.0	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Amps B Ø	66.0	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Amps A Ø	72.0	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	9 Month Operations	3	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Switching Operations	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Operations This Read AM	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Operations Counter AL	814	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Operations Counter AF	814	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Maintenance Operations	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	General Comments		
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Patrol Inspection	General Comments		
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Follow-up Action Required?	n	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Fault Operations Ground	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Fault Operations C Ø	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Fault Operations B Ø	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Fault Operations A Ø	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Amps C Ø	0.0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Amps B Ø	0.0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Amps A Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0223	BreakerAirMagnetic	CO-1194	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	General Comments		
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Tank Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Radiator Leaks	None	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Follow-up Action Required?	n	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Fault Operations Ground	0	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Fault Operations C Ø	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.8	psi
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Fault Operations B Ø	0	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Fault Operations A Ø	0	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	LTCC000626	LTCControl	408-1	LTC Control Insp	All Connections OK?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	LTCC000626	LTCControl	408-1	LTC Control Insp	Follow-up Action Required?	n	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	LTCC000626	LTCControl	408-1	LTC Control Insp	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LT0160	GroundTransformer	P-GND TR 2B	Ground Transformer Patrol Inspection	Bushing Condition	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	ST000359	Structure	716-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	LTCC000626	LTCControl	408-1	LTC Control Insp	LTC Operation Checked?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	LTCC000626	LTCControl	408-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	LTCC000626	LTCControl	408-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	LTCC000626	LTCControl	408-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	LTCC000626	LTCControl	408-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	LTCC000626	LTCControl	408-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0183	BreakerVacuum	753-1320	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	Fault Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	Maintenance Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	Number of Ops last 9 Months	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	Operations Counter AF	1244	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	Operations Counter AL	1244	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	General Comments		
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Battery Overall Condition	Good	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BAT001027	Battery	CO-Battery Bank 1	Battery Patrol Inspection	All Connections OK?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Unknown Operations	0	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Switching Operations	0	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Operations This Read Vac	1	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Operations Counter AL	229	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Operations Counter AF	229	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Maintenance Operations	1	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	General Comments	ok	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	General Comments	1 trip check	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Follow-up Action Required?	n	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Fault Operations Ground	0	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Fault Operations C Ø	0	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Fault Operations B Ø	0	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Fault Operations A Ø	0	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Patrol Inspection	Bushing Condition	Good	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Amps C Ø	20.0	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Amps B Ø	15.0	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Amps A Ø	16.0	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BK001424	BreakerVacuum	408-2221	VCB Readings	9 Month Operations	1	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	General Comments		
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	FE000507	Fence	580-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Pressure Vessel Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Tank Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0729	BreakerOil	P-1384-A	OCB Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LTCC000536	LTCControl	CF-TRANS 1	LTC Control Insp	All Connections OK?	y	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LTCC000536	LTCControl	CF-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Tank Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0728	BreakerOil	P-1383-B	OCB Patrol Inspection	Tank Paint Condition	Bad	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LTCC000536	LTCControl	CF-TRANS 1	LTC Control Insp	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	Amps A Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	Amps B Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	Amps C Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Bushing Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Bushing Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Operations This Read AM	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Operations Counter AL	537	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Operations Counter AF	537	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Maintenance Operations	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	General Comments	Actual counter	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Patrol Inspection	General Comments		
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Amps C Ø	200.0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Amps B Ø	200.0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Amps A Ø	220.0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	9 Months Operations	1	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Vegetation	None	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	General Comments		
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	YD000509	Yard	407-Yard	Yard Patrol Inspection	Ambient Temp	67	°F
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Bushing Condition	Good	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	K0141	BreakerVacuum	753-1322	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	Operations This Read Oil	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Readings	Switching Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Tank Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0721	BreakerOil	P-1380-A	OCB Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Tank Leaks	None	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Regulator As Left Counter	50513	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	General Comments		
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Min Tap Position	7L	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0011	Regulator	642-2 B	Regulator Patrol Inspection	Max Tap Position	4R	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	ST000512	Structure	407-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0230	BreakerAirMagnetic	CO-12KV TR 2	AMCB Readings	Switching Operations	0	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	Oil Temp Present	37	°C
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Amps A Ø	50.0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Amps B Ø	40.0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Amps C Ø	90.0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BAT001444	Battery	408-Battery Bank	Battery Patrol Inspection	General Comments		
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1828.80	kw
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	General Comments		
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	General Comments		
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BCH000125	Charger	Retired Distribution	Battery Charger Patrol Insp	Ground Lights	None	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BAT001456	Battery	580-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.0	VDC
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BAT001456	Battery	580-Battery Bank	Battery Patrol Inspection	Positive DC Ground	24.0	VDC
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BAT001456	Battery	580-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	BAT001486	Battery	407-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	BAT001486	Battery	407-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Regulator As Left Counter	129013	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	°F
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	General Comments		
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Negative DC Ground	38.0	VDC
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Positive DC Ground	35.0	VDC
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	BAT001069	Battery	784-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BAT001444	Battery	408-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	9 Months Operations	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	BAT001486	Battery	407-Battery Bank	Battery Patrol Inspection	Positive DC Ground	12.0	VDC
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	BAT001486	Battery	407-Battery Bank	Battery Patrol Inspection	Negative DC Ground	14.0	VDC
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	BAT001486	Battery	407-Battery Bank	Battery Patrol Inspection	General Comments		
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	BAT001486	Battery	407-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	BAT001486	Battery	407-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	BAT001486	Battery	407-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	BAT001486	Battery	407-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	BAT001486	Battery	407-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	BAT001486	Battery	407-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	BAT001486	Battery	407-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	BAT001486	Battery	407-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	General Comments	Actual counter	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Maintenance Operations	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Operations Counter AF	1395	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Operations Counter AL	1395	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Operations This Read AM	0	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	Oil Temp Present	40	°C
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	Oil Temp Max	55	°C
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	7902.72	kw
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	General Comments		
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	General Comments		
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	General Comments		
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	PF000280	PowerFuse	P-14KV BUS SEC 2-B POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	PF000280	PowerFuse	P-14KV BUS SEC 2-B POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Trash Emptied?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BCH000125	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BCH000125	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BCH000125	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BCH000125	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	5.0	amps
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BCH000125	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.9	VDC
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BCH000125	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.9	VDC
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BCH000125	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.600	millivolts
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Pressure Vessel Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Bushing Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Bushing Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Air Pressure OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Air Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	Winding Temp Present	50	°C
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	Winding Temp Max	65	°C
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	Totalizer Meter Reading	.8232	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KT0005	NonLTC	642-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	FE000558	Fence	765-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Fault Operations A Ø	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Fault Operations B Ø	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Fault Operations C Ø	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Fault Operations Ground	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Readings	Follow-up Action Required?	n	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0221	BreakerAirMagnetic	CO-1192	AMCB Patrol Inspection	General Comments		
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Regulator As Left Counter	117694	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Min Tap Position	12L	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	General Comments		
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	BCH001419	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	Ground Lights	None	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	BCH001419	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	General Comments		
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	BCH001419	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	BCH001419	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	BCH001419	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	BCH001419	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	BCH001419	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	BCH001419	Charger	920-Offline-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1363	Regulator	407-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	General Comments	ok	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	General Comments	ok	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Regulator As Left Counter	48588	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Regulator As Left Counter	9934	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Min Tap Position	4L	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	General Comments		
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1400	Regulator	580-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Follow-up Action Required?	n	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Fault Operations Ground	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Fault Operations C Ø	0	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Fault Operations B Ø	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Fault Operations A Ø	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Amps C Ø	90.0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Amps B Ø	70.0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Amps A Ø	80.0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Current Tap Position	1R	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	General Comments		
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Max Tap Position	5R	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1129	Regulator	765-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BAT001456	Battery	580-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BAT001456	Battery	580-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	77	°F
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BAT001456	Battery	580-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BAT001456	Battery	580-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BAT001456	Battery	580-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BAT001456	Battery	580-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BAT001456	Battery	580-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BAT001456	Battery	580-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BAT001456	Battery	580-Battery Bank	Battery Patrol Inspection	General Comments		
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Regulator As Left Counter	8132	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0028	Regulator	753-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	PF000301	PowerFuse	P-1380 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	PF000301	PowerFuse	P-1380 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	PF000179	PowerFuse	HL-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Tank Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0737	BreakerOil	P-1388-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	Winding Temp Present	30	°C
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	Winding Temp Max	40	°C
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	Totalizer Meter Reading	.2540	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Pressure Vessel Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	PF000179	PowerFuse	HL-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	PF000179	PowerFuse	HL-12KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	S0051	NonLTC	642-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Tank Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Tank Paint Condition	Bad	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BAT001444	Battery	408-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BAT001444	Battery	408-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	77	*F
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BAT001444	Battery	408-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BAT001444	Battery	408-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BAT001444	Battery	408-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BAT001444	Battery	408-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BAT001444	Battery	408-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BAT001444	Battery	408-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Switching Operations	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Operations This Read AM	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Operations Counter AL	771	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Operations Counter AF	771	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Maintenance Operations	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	General Comments		
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Patrol Inspection	General Comments		
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Bushing Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Amps C Ø	65.0	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Amps B Ø	56.0	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Amps A Ø	65.0	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	9 Month Operations	5	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Readings	Amps A Ø	0.0	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BAT001444	Battery	408-Battery Bank	Battery Patrol Inspection	Negative DC Ground	25.0	VDC
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BAT001444	Battery	408-Battery Bank	Battery Patrol Inspection	Positive DC Ground	21.0	VDC
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BAT001444	Battery	408-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BAT001444	Battery	408-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Readings	9 Month Operations	3	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	Unknown Operations	0	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	Switching Operations	0	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	Operations This Read Vac	0	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	Operations Counter AL	196	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	Operations Counter AF	196	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	Maintenance Operations	0	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	General Comments		
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Patrol Inspection	General Comments		
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	Follow-up Action Required?	n	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	Fault Operations Ground	0	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	Fault Operations C Ø	0	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	Fault Operations B Ø	0	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	Fault Operations A Ø	0	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	General Comments		
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Follow-up Action Required?	n	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Patrol Inspection	Cabinet Heaters Functioning?		
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Fault Operations Ground	0	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Fault Operations C Ø	0	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Fault Operations B Ø	0	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Current Tap Position	4L	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	General Comments		
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Max Tap Position	4R	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Min Tap Position	6L	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Regulator As Left Counter	48498	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Tank Leaks	None	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Fault Operations A Ø	0	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Patrol Inspection	Bushing Condition	Good	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Readings	Amps C Ø	0.0	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Readings	Amps B Ø	0.0	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Amps A Ø	12.0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Readings	General Comments		
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	10	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	General Comments		
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	General Comments	Transformer needs nitrogen	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	799	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	Oil Temp Max	65	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	Oil Temp Present	25	°C
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	30.00	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	65	°C
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	35	°C
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	70	°C
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	25	°C
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	65	°C
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LT0059	WithLTC	CO-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	20	°C
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Patrol Inspection	Bushing Condition	Good	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	Amps C Ø	63.0	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	Amps B Ø	70.0	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	Amps A Ø	57.0	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001571	BreakerVacuum	580-2104	VCB Readings	9 Month Operations	0	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Operations Counter	934	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	General Comments		
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	799	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	CB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Amps C Ø	12.0	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	CX0137	RecloserElectronic	765-0551	Recloser Electronic Patrol Inspection	Amps B Ø	10.0	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Min Tap Position	12L	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Max Tap Position	1L	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	Number of Ops last 9 Months	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	Operations Counter AF	1193	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	Operations Counter AL	1193	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	Operations This Read Oil	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Pressure Vessel Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	Switching Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	General Comments		
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Tank Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Tank Paint Condition	Bad	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Readings	Unknown Operations	0	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	0.0	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	0.0	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	0.0	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Regulator As Left Counter	112778	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LB0226	BreakerAirMagnetic	CO-1195	AMCB Readings	9 Months Operations	3	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BAT001456	Battery	580-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Min Tap Position	12L	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	General Comments		
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1365	Regulator	407-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	General Comments	Strip heaters not working. 2 x 240V 350W	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	Maintenance Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	LTCC000289	LTCControl	784-1	LTC Control Insp	All Connections OK?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	LTCC000289	LTCControl	784-1	LTC Control Insp	Follow-up Action Required?	n	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	LTCC000289	LTCControl	784-1	LTC Control Insp	General Comments		
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	LTCC000289	LTCControl	784-1	LTC Control Insp	LTC Operation Checked?	y	
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	LTCC000289	LTCControl	784-1	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	LTCC000289	LTCControl	784-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	LTCC000289	LTCControl	784-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	LTCC000289	LTCControl	784-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/8/2020 11:07	Distribution	Columbia Quarterly Inspection	LTCC000289	LTCControl	784-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	R1364	Regulator	407-1 C	Regulator Patrol Inspection	Regulator As Left Counter	113022	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	Totalizer Meter Reading	.7944	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Patrol Inspection	General Comments		
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	General Comments		
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	8	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Broom on Site?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	CH000155	ControlHouse	HL-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Readings	Follow-up Action Required?	n	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Readings	Fault Operations Ground	0	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Readings	Fault Operations C Ø	0	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Readings	Fault Operations B Ø	0	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Readings	Fault Operations A Ø	0	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0012	Regulator	642-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	75	*F
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	BAT000127	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Maintenance Operations	0	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Readings	Switching Operations	0	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Readings	Operations This Read Vac	0	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Unknown Operations	0	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Switching Operations	0	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Operations This Read Vac	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	General Comments		
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Operations Counter AL	271	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KB0016	BreakerVacuum	642-2228	VCB Readings	Operations Counter AF	271	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	General Comments		
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	5719.68	kw
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	FE000573	Fence	HL-Fence	Fence Patrol Inspection	General Comments		
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Readings	Operations Counter AL	164	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Readings	Operations Counter AF	164	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Readings	Maintenance Operations	0	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BK001572	BreakerVacuum	580-2105	VCB Readings	General Comments		
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	M0070	NonLTC	765-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Cabinet Paint Condition	Adequate	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Bushing Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Bushing Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Air Pressure OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Air Leaks	None	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/8/2020 11:56	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Tank Leaks	None	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Regulator As Left Counter	44501	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	General Comments		
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1489	Regulator	642-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Regulator As Left Counter	39284	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	General Comments		
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Amps B Ø	453.0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Amps A Ø	430.0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	9 Month Operations	0	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Readings	Number of Ops last 9 Months	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Readings	Operations Counter AF	645	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Readings	Operations Counter AL	645	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0778	BreakerOil	P-SPARE # 12	OCB Patrol Inspection	Tank Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0778	BreakerOil	P-SPARE # 12	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0778	BreakerOil	P-SPARE # 12	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0778	BreakerOil	P-SPARE # 12	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0778	BreakerOil	P-SPARE # 12	OCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0778	BreakerOil	P-SPARE # 12	OCB Patrol Inspection	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0778	BreakerOil	P-SPARE # 12	OCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0778	BreakerOil	P-SPARE # 12	OCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0778	BreakerOil	P-SPARE # 12	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0778	BreakerOil	P-SPARE # 12	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Readings	Operations This Read Oil	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Readings	Switching Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Bushing Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Bushing Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Tank Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Pressure Vessel Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Tank Paint Condition	Adequate	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Tank Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Pressure Vessel Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	General Comments	Drain valve on compressor tank is draining slow. Starting to get clogged.	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0758	BreakerOil	P-14KV TR 4-B	OCB Patrol Inspection	Follow-up Action Required?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BCH001364	Charger	408-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BCH001364	Charger	408-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BCH001364	Charger	408-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BCH001364	Charger	408-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.1	amps

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BCH001364	Charger	408-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BCH001364	Charger	408-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BCH001364	Charger	408-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	BCH001364	Charger	408-Battery Charger	Battery Charger Patrol Insp	408-Battery Charger	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Bushing Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Unknown Operations	0	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Bushing Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Bushing Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Air Pressure OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Air Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Fault Operations B Ø	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Fault Operations A Ø	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Switching Operations	0	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Operations This Read Vac	0	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Operations Counter AL	281	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Operations Counter AF	281	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	BCH001076	Charger	HL-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	BCH001076	Charger	HL-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.4	VDC
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Pressure Vessel Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Tank Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	BCH001076	Charger	HL-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.4	VDC
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	BCH001076	Charger	HL-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.2	amps
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	BCH001076	Charger	HL-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Amps C Ø	90.0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Amps B Ø	40.0	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1488	Regulator	642-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Current Tap Position	Neutral	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0757	BreakerOil	P-14KV TR 4-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Switching Operations	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Operations This Read Vac	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Operations Counter AL	143	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Operations Counter AF	143	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Maintenance Operations	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	General Comments	Actual counter	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Patrol Inspection	General Comments		
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Follow-up Action Required?	n	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Fault Operations Ground	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Fault Operations C Ø	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Air Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Air Pressure OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0738	BreakerOil	P-1388-B	OCB Patrol Inspection	Bushing Condition	Good	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Regulator As Left Counter	28009	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	Fault Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Bushing Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Bushing Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	Amps C Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	Amps B Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	Amps A Ø	0.0	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	General Comments		
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Ambient Temp	75	°F

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Max Tap Position	5L	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	General Comments		
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	Operations This Read Oil	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	Operations Counter AL	1927	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	Operations Counter AF	1927	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	Number of Ops last 9 Months	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	Maintenance Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Readings	General Comments		
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Regulator As Left Counter	43750	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	3217	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0773	BreakerOil	P-SEC TIE 1-A	OCB Patrol Inspection	General Comments		
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	31	°C
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	51	°C
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	LTC Min Tap Position	13L	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	LTC Max Tap Position	6R	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	BCH000431	Charger	753-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	BCH000431	Charger	753-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	BCH000431	Charger	753-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	BCH000431	Charger	753-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	BCH000431	Charger	753-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	LTC Current Tap Position	10L	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	LTC As Left Counter	75711	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LT0088	LTCMechanism	HL-TRANS 1	LTC Counter Readings	LTC As Found Counter	75711	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Vegetation	None	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	General Comments		
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	YD000484	Yard	642-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	R1402	Regulator	580-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	R1490	Regulator	642-1 C	Regulator Patrol Inspection	General Comments		
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1125	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Counter Readings	LTC Min Tap Position	13L	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Counter Readings	LTC Max Tap Position	2L	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Counter Readings	LTC Current Tap Position	10L	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Counter Readings	LTC As Left Counter	22676	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Counter Readings	LTC As Found Counter	22676	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Counter Readings	General Comments		
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Readings	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Readings	Maintenance Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Regulator As Left Counter	122643	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 15:20	Distribution	Liberty Quarterly Inspection	R1130	Regulator	765-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Switching Operations	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Operations This Read Vac	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Operations Counter AL	171	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Operations Counter AF	171	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Maintenance Operations	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	General Comments	HSI A and B phase	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Patrol Inspection	General Comments		
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Fault Operations Ground	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Fault Operations C ∅	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Fault Operations B ∅	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Fault Operations A ∅	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BK000684	BreakerVacuum	CO-12KV TR 1	VCB Readings	Amps C ∅	444.0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	Oil Temp Present	35	°C
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	Oil Temp Max	55	°C
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	600	psi
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	General Comments		
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BCH001357	Charger	580-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BCH001357	Charger	580-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BCH001357	Charger	580-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BCH001357	Charger	580-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BCH001357	Charger	580-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BCH001357	Charger	580-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Bushing Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Bushing Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BCH001357	Charger	580-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BCH001357	Charger	580-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Tank Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0760	BreakerOil	P-BUS TIE REA 2	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0770	BreakerOil	P-RES AUX 1-2-3	OCB Readings	Fault Operations	0	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	70	°C
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	30	°C
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	60	°C
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	30	°C
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	65	°C
10/8/2020 11:56	Distribution	Centerfield Quarterly Inspection	LT0051	WithLTC	CF-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	30	°C
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	LTCM000055	LTCMechanism	CO-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Amps A Ø	75.0	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	164	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	164	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	General Comments		
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Max Tap Position	3R	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Min Tap Position	8L	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1300	psi
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	Oil Temp Max	54	°C
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	Oil Temp Present	32	°C
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	58	°C
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	33	°C
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Follow-up Action Required?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	57	°C
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	33	°C
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	57	°C
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	33	°C
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	General Comments	ok	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	9 Months Operations	10	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Bushing Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Bushing Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	Amps C Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	Amps B Ø	0.0	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Unknown Operations	0	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Switching Operations	0	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Operations This Read AM	0	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Operations Counter AL	838	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Operations Counter AF	838	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Maintenance Operations	0	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	General Comments		
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Patrol Inspection	General Comments		
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	Amps A Ø	0.0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Air Pressure OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Air Leaks	None	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	General Comments		
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	General Comments		
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Foundation Condition	Good	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Follow-up Action Required?	n	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Cabinet Paint Condition	Adequate	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Readings	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0722	BreakerOil	P-1380-B	OCB Readings	Fault Operations	0	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	TX000122	WithLTC	CO-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Fault Operations Ground	0	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Fault Operations C Ø	0	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Fault Operations B Ø	0	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Fault Operations A Ø	0	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Current Tap Position	5L	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Fault Operations Ground	0	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Fault Operations C Ø	0	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Fault Operations B Ø	0	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Fault Operations A Ø	0	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Amps C Ø	100.0	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	LB0442	BreakerAirMagnetic	HL-1158	AMCB Readings	Amps B Ø	100.0	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Regulator As Left Counter	10165	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	General Comments		
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	LTC Totalizer Reading	4435.20	kw
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Bushing Condition	Good	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Amps C Ø	10.0	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Amps B Ø	10.0	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Amps A Ø	10.0	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	Oil Temp Max	45	°C
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	Oil Temp Present	45	°C
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	Totalizer Meter Reading	.4620	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Regulator As Left Counter	47290	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000916	LTCControl	716-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000916	LTCControl	716-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000916	LTCControl	716-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000916	LTCControl	716-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000916	LTCControl	716-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000916	LTCControl	716-1	LTC Control Insp	LTC Operation Checked?	y	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Mechanism Patrol Inspection	General Comments		
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	B0433	LTCMechanism	716-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 16:02	Distribution	Buena Vista Quarterly Inspection	BB0352	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000916	LTCControl	716-1	LTC Control Insp	General Comments		
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000916	LTCControl	716-1	LTC Control Insp	Follow-up Action Required?	n	
10/9/2020 8:33	Distribution	Higby Mill Distribution Quarterly Inspection	LTCC000916	LTCControl	716-1	LTC Control Insp	All Connections OK?	y	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Tank Leaks	None	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Bushing Oil Level	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Bushing Condition	Good	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Air Pressure OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Air Leaks	None	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Maintenance Operations	0	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	BCH001076	Charger	HL-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	9 Month Operations	5	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	BCH001076	Charger	HL-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0026	Regulator	753-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 12:45	Distribution	Harmony Landing Quarterly Inspection	BCH001076	Charger	HL-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	9 Month Operations	0	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 15:37	Distribution	Paddys Run Quarterly Inspection	LB0746	BreakerOil	P-1392-B	OCB Patrol Inspection	Cabinet Paint Condition	Adequate	
10/8/2020 12:59	Distribution	Union Underwear Quarterly Inspection	KR0010	Regulator	642-2 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/8/2020 10:44	Distribution	Columbia South Quarterly Inspection	K0050	BreakerVacuum	407-2209	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/9/2020 17:40	Distribution	Collins Quarterly Inspection	BK000683	BreakerVacuum	CO-1196	VCB Readings	Amps A Ø	40.0	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	General Comments		
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/9/2020 6:18	Distribution	Russell Springs Quarterly Inspection	B0325	WithLTC	408-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/8/2020 9:35	Distribution	Forrestdale Quarterly Inspection	KR0027	Regulator	753-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	BCH000845	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	BCH000845	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	BCH000845	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	BCH000407	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	BCH000407	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	BCH000407	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	BCH000449	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	BCH000449	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	BCH000449	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	BCH000449	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Fault Operations A Ø	0	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Fault Operations B Ø	0	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Fault Operations C Ø	0	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Fault Operations Ground	0	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Unknown Operations	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Switching Operations	4	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Operations This Read Vac	4	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Operations Counter AL	159	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Operations Counter AF	159	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Maintenance Operations	0	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Grounds in Place?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	General Comments		
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	General Comments		
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Foundation Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Bushing Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Amps C Ø	200.0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Amps B Ø	180.0	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Max Tap Position	4L	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Amps A Ø	120.0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Follow-up Action Required?	n	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	9 Month Operations	4	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	General Comments		
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	LTCM000096	LTCMechanism	664-3	LTC Counter Readings	Follow-up Action Required?	n	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Current Tap Position	10L	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	LTCM000096	LTCMechanism	664-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LTCC000226	LTCControl	AB-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LTCC000226	LTCControl	AB-TRANS 2	LTC Control Insp	General Comments		
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	LTCC000689	LTCControl	535-3	LTC Control Insp	All Connections OK?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LTCC000226	LTCControl	AB-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	LTCC000688	LTCControl	535-2	LTC Control Insp	VRR Time Delay	45	Seconds
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	LTCC000688	LTCControl	535-2	LTC Control Insp	VRR Base Voltage AL	113.5	VAC
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	LTCC000688	LTCControl	535-2	LTC Control Insp	VRR Base Voltage AF	113.5	VAC
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Counter Readings	Follow-up Action Required?	n	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Counter Readings	General Comments		
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Mechanism Patrol Inspection	General Comments		
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Counter Readings	LTC As Found Counter	294935	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Counter Readings	LTC As Left Counter	294942	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	LTCC000688	LTCControl	535-2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	LTCC000688	LTCControl	535-2	LTC Control Insp	LTC Output Voltage Level	114.0	VAC
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	LTCC000688	LTCControl	535-2	LTC Control Insp	LTC Operation Checked?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	General Comments		
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	General Comments		
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	FE000203	Fence	758-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Counter Readings	LTC Current Tap Position	3R	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	General Comments		
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	FE000450	Fence	417-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	LTCM000096	LTCMechanism	664-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	LTCM000096	LTCMechanism	664-3	LTC Counter Readings	General Comments		
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	LTCM000096	LTCMechanism	664-3	LTC Mechanism Patrol Inspection	General Comments		
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	LTCM000096	LTCMechanism	664-3	LTC Counter Readings	LTC As Found Counter	9095	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Min Tap Position	15L	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	LTCM000096	LTCMechanism	664-3	LTC Counter Readings	LTC As Left Counter	9095	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	LTCM000096	LTCMechanism	664-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	LTCM000096	LTCMechanism	664-3	LTC Counter Readings	LTC Current Tap Position	4L	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	LTCM000096	LTCMechanism	664-3	LTC Counter Readings	LTC Max Tap Position	4R	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	LTCC000689	LTCControl	535-3	LTC Control Insp	VRR Time Delay	45	Seconds
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	LTCM000096	LTCMechanism	664-3	LTC Counter Readings	LTC Min Tap Position	6L	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R1188	Regulator	852-1 C	Regulator Patrol Inspection	Regulator As Left Counter	70365	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	LTCC000689	LTCControl	535-3	LTC Control Insp	VRR Base Voltage AL	113.5	VAC
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Counter Readings	LTC Operations Since Last Insp	147	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Counter Readings	LTC Min Tap Position	4L	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Counter Readings	LTC Max Tap Position	8R	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	LTCC000689	LTCControl	535-3	LTC Control Insp	VRR Base Voltage AF	113.5	VAC
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	C0449	LTCMechanism	195-5	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	LTCC000689	LTCControl	535-3	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	LTCC000689	LTCControl	535-3	LTC Control Insp	LTC Output Voltage Level	115.0	VAC
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	LTCC000689	LTCControl	535-3	LTC Control Insp	LTC Operation Checked?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	LTCC000689	LTCControl	535-3	LTC Control Insp	General Comments		
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	LTCC000689	LTCControl	535-3	LTC Control Insp	Follow-up Action Required?	n	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	LTCM000096	LTCMechanism	664-3	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	LTCM000096	LTCMechanism	664-3	LTC Counter Readings	LTC Operations Since Last Insp	255	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	LTCM000096	LTCMechanism	664-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	LTCM000096	LTCMechanism	664-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	General Comments		
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Unknown Operations	0	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Switching Operations	0	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	General Comments		
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	FE000406	Fence	735-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	FE000429	Fence	587-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	FE000429	Fence	587-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	FE000429	Fence	587-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	FE000429	Fence	587-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	FE000429	Fence	587-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	FE000429	Fence	587-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	FE000429	Fence	587-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	FE000429	Fence	587-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	FE000429	Fence	587-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	FE000429	Fence	587-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	FE000429	Fence	587-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	FE000429	Fence	587-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	FE000429	Fence	587-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	FE000429	Fence	587-Fence	Fence Patrol Inspection	General Comments		
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	FE000429	Fence	587-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	28.2	VDC
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.9	VDC
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	80	°F

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	General Comments		
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	Negative DC Ground	.2	VDC
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	Positive DC Ground	.6	VDC
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	BAT001406	Battery	822-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	Totalizer Meter Reading	.1900	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	Oil Temp Present	30	°C
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	Oil Temp Max	50	°C
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	LTC Totalizer Reading	608.00	kw
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Readings	General Comments		
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	B0248	WithLTC	769-1	LTC Transformer Patrol Inspection	General Comments		
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Operations This Read Vac	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Operations Counter AL	312	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Operations Counter AF	312	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Maintenance Operations	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Grounds in Place?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	General Comments		
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	LTCC000232	LTCControl	159-5	LTC Control Insp	VRR Time Delay	30	Seconds
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	LTCC000232	LTCControl	159-5	LTC Control Insp	VRR Base Voltage AL	115.0	VAC
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	LTCC000232	LTCControl	159-5	LTC Control Insp	VRR Base Voltage AF	115.0	VAC
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	LTCC000232	LTCControl	159-5	LTC Control Insp	LTC Output Voltage Level	115.0	VAC
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	LTCC000232	LTCControl	159-5	LTC Control Insp	LTC Operation Checked?	y	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	LTCC000232	LTCControl	159-5	LTC Control Insp	General Comments		
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	LTCC000232	LTCControl	159-5	LTC Control Insp	Follow-up Action Required?	n	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	LTCC000232	LTCControl	159-5	LTC Control Insp	All Connections OK?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	Follow-up Action Required?	n	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	General Comments		
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Mechanism Patrol Inspection	General Comments		
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	General Comments		
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Foundation Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Follow-up Action Required?	n	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	LTC As Found Counter	8001	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Fault Operations Ground	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Fault Operations C ∅	0	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	LTC As Left Counter	8001	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Fault Operations B Ø	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Fault Operations A Ø	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0040	BreakerVacuum	664-0030	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	LTC Current Tap Position	5L	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	LTC Max Tap Position	2R	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	LTC Min Tap Position	8L	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	LTC Operations Since Last Insp	508	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0341	LTCMechanism	808-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	General Comments		
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	General Comments		
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	BAT001081	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	ST000436	Structure	587-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	YD000433	Yard	587-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	YD000433	Yard	587-Yard	Yard Patrol Inspection	Vegetation	None	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	YD000433	Yard	587-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	YD000433	Yard	587-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	ST000413	Structure	735-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	YD000433	Yard	587-Yard	Yard Patrol Inspection	General Comments		
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	YD000433	Yard	587-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	YD000433	Yard	587-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	YD000433	Yard	587-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	YD000433	Yard	587-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	YD000433	Yard	587-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	YD000433	Yard	587-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	YD000433	Yard	587-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	63	*F
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BAT001125	Battery	808-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	YD000433	Yard	587-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	YD000433	Yard	587-Yard	Yard Patrol Inspection	Ambient Temp	68	*F
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	General Comments		
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	ST000208	Structure	758-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Clear of Trash?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Ambient Temp	68	*F
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	General Comments		
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	LTCC000327	LTCControl	671-1	LTC Control Insp	Follow-up Action Required?	n	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Unknown Operations	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Switching Operations	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Operations This Read Vac	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Operations Counter AL	349	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Operations Counter AF	349	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Maintenance Operations	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Grounds in Place?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	General Comments		
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Foundation Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Follow-up Action Required?	n	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Fault Operations Ground	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Fault Operations C Ø	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Fault Operations B Ø	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Fault Operations A Ø	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	General Comments		
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	General Comments		
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	LTC Totalizer Reading	4560.00	kw
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	n	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	General Comments	Entrance drive washing out at culvert	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Vegetation	None	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	General Comments		
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	ST000224	Structure	862-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	LTCC000327	LTCControl	671-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	LTCC000327	LTCControl	671-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Regulator As Left Counter	16966	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	LTCC000327	LTCControl	671-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	LTCC000327	LTCControl	671-1	LTC Control Insp	LTC Output Voltage Level	124.8	VAC
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	LTCC000327	LTCControl	671-1	LTC Control Insp	LTC Operation Checked?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	LTCC000327	LTCControl	671-1	LTC Control Insp	General Comments		
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Max Tap Position	14R	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	General Comments		
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	General Comments	Drag hands move with steps	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	LTCC000717	LTCControl	664-2	LTC Control Insp	VRR Time Delay	30	Seconds
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	LTCC000717	LTCControl	664-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	LTCC000717	LTCControl	664-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	LTCC000717	LTCControl	664-2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	LTCC000717	LTCControl	664-2	LTC Control Insp	LTC Operation Checked?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	LTCC000717	LTCControl	664-2	LTC Control Insp	General Comments		
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	LTCC000717	LTCControl	664-2	LTC Control Insp	Follow-up Action Required?	n	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	LTCC000717	LTCControl	664-2	LTC Control Insp	All Connections OK?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	9 Month Operations	11	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Amps A Ø	120.0	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Amps B Ø	120.0	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Amps C Ø	120.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Bushing Condition	Good	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Fault Operations A Ø	0	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Fault Operations B Ø	0	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Fault Operations C Ø	0	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Fault Operations Ground	0	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Follow-up Action Required?	n	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	LTC000327	LTCControl	671-1	LTC Control Insp	All Connections OK?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Foundation Condition	Good	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	General Comments		
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	General Comments		
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Grounds in Place?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Maintenance Operations	0	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Operations Counter AF	396	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Operations Counter AL	396	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Operations This Read Vac	0	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Switching Operations	0	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Unknown Operations	0	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Patrol Inspection	Bushing Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Amps C Ø	165.0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Amps B Ø	150.0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Amps A Ø	140.0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0126	BreakerVacuum	664-0067	VCB Readings	9 Month Operations	7	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	Oil Temp Max	60	°C
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	Oil Temp Present	30	°C
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	Totalizer Meter Reading	.5700	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0341	WithLTC	808-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000023	Regulator	862-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Regulator As Left Counter	16483	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	General Comments		
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000022	Regulator	862-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	FE000474	Fence	742-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Regulator As Left Counter	16237	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Min Tap Position	4L	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	RG000021	Regulator	862-1 A	Regulator Patrol Inspection	Max Tap Position	4L	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Switching Operations	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Unknown Operations	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations B Ø	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations C Ø	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations Ground	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Follow-up Action Required?	n	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Patrol Inspection	General Comments		
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	General Comments	OPEN	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Maintenance Operations	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AF	99985	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AL	99985	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Operations This Read AM	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Switching Operations	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Unknown Operations	0	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Unknown Operations	0	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Switching Operations	0	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Operations This Read Vac	1	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Operations Counter AL	90	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Operations Counter AF	90	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Maintenance Operations	1	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Grounds in Place?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	General Comments		
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	General Comments		
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Foundation Condition	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Follow-up Action Required?	n	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Fault Operations Ground	0	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Fault Operations C Ø	0	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Fault Operations B Ø	0	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Fault Operations A Ø	0	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Patrol Inspection	Bushing Condition	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Amps C Ø	480.0	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Amps B Ø	500.0	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Amps A Ø	500.0	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0173	BreakerVacuum	5351-0112	VCB Readings	9 Month Operations	2	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Amps A Ø	62.0	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Amps B Ø	66.0	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Amps C Ø	55.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Unknown Operations	0	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	LTCC000024	LTCControl	581-1	LTC Control Insp	LTC Operation Checked?	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	LTCC000024	LTCControl	581-1	LTC Control Insp	General Comments		
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	LTCC000024	LTCControl	581-1	LTC Control Insp	Follow-up Action Required?	n	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	LTCC000024	LTCControl	581-1	LTC Control Insp	All Connections OK?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Fault Operations A Ø	0	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Fault Operations B Ø	0	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Fault Operations C Ø	0	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Fault Operations Ground	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	9 Months Operations	2	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Follow-up Action Required?	n	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Foundation Condition	Good	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	General Comments		
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	General Comments		
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Grounds in Place?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Maintenance Operations	0	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Operations Counter AF	43	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Operations Counter AL	43	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Operations This Read Vac	0	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Switching Operations	0	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Unknown Operations	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	9 Months Operations	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Amps A Ø	0.0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Amps B Ø	0.0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Amps C Ø	0.0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0060	BreakerAirMagnetic	AB-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations A Ø	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Amps A Ø	140.0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Amps B Ø	120.0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Amps C Ø	100.0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Fault Operations A Ø	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Fault Operations B Ø	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Fault Operations C Ø	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Fault Operations Ground	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Follow-up Action Required?	n	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Patrol Inspection	General Comments		
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	General Comments		
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Maintenance Operations	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Operations Counter AF	878	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Operations Counter AL	878	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0054	BreakerAirMagnetic	AB-1204	AMCB Readings	Operations This Read AM	0	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	LTCMechanism	587-1	LTC Counter Readings	LTC As Left Counter	202724	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	LTCMechanism	587-1	LTC Counter Readings	LTC As Found Counter	202720	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	LTCMechanism	587-1	LTC Mechanism Patrol Inspection	General Comments		
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	LTCMechanism	587-1	LTC Counter Readings	General Comments		
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	LTCMechanism	587-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	LTCMechanism	587-1	LTC Counter Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BCH000287	Charger	535-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BCH000287	Charger	535-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BCH000287	Charger	535-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BCH000287	Charger	535-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.7	amps
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BCH000287	Charger	535-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	134.0	VDC
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BCH000287	Charger	535-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	134.0	VDC
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Vegetation	None	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	General Comments		
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	YD000481	Yard	742-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Unknown Operations	0	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Switching Operations	0	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Operations This Read Vac	1	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Operations Counter AL	501	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Operations Counter AF	501	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Maintenance Operations	0	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Grounds in Place?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	General Comments		
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Foundation Condition	Good	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Follow-up Action Required?	n	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Fault Operations Ground	0	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Fault Operations C Ø	0	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Fault Operations B Ø	0	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Fault Operations A Ø	1	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Fault Adjusted Amps A Phase V	24.13	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Patrol Inspection	Bushing Condition	Good	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Amps C Ø	220.0	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Amps B Ø	220.0	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Amps A Ø	220.0	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0431	BreakerVacuum	808-0111	VCB Readings	9 Month Operations	5	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Ambient Temp	72	*F
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	YD000219	Yard	862-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	General Comments		
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Operations Counter	92	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	X0336	RecloserElectronic	581-1316	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	General Comments		
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	ST000456	Structure	417-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	9 Months Operations	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Amps A Ø	580.0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Amps B Ø	580.0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Amps C Ø	580.0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Fault Operations A Ø	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Fault Operations B Ø	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Fault Operations C Ø	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Fault Operations Ground	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Follow-up Action Required?	n	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Patrol Inspection	General Comments		
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	General Comments		
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Maintenance Operations	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Operations Counter AF	669	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Operations Counter AL	669	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Operations This Read AM	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Switching Operations	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0061	BreakerAirMagnetic	AB-12KV TR 1	AMCB Readings	Unknown Operations	0	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	LTCMechanism	587-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	LTCMechanism	587-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	LTCMechanism	587-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	LTCMechanism	587-1	LTC Counter Readings	LTC Operations Since Last Insp	267	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	LTCMechanism	587-1	LTC Counter Readings	LTC Min Tap Position	11L	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	LTCMechanism	587-1	LTC Counter Readings	LTC Max Tap Position	8L	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	LTCMechanism	587-1	LTC Counter Readings	LTC Current Tap Position	11L	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	LTCMechanism	587-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	LTCC000420	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	LTCC000420	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	LTCC000420	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	LTCC000420	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	9 Month Operations	3	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Amps A Ø	70.0	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Unknown Operations	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Amps B Ø	75.0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Amps C Ø	80.0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Patrol Inspection	Bushing Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Fault Operations A Ø	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Fault Operations B Ø	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Fault Operations C Ø	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Fault Operations Ground	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Follow-up Action Required?	n	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Patrol Inspection	Foundation Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Patrol Inspection	General Comments		
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Patrol Inspection	Grounds in Place?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Maintenance Operations	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Operations Counter AF	195	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Operations Counter AL	195	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Operations This Read Vac	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Switching Operations	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001047	BreakerVacuum	664-0863	VCB Readings	Unknown Operations	0	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	9 Month Operations	4	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Amps A Ø	130.0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Amps B Ø	125.0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Amps C Ø	130.0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Patrol Inspection	Bushing Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Fault Operations A Ø	0	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Grounds in Place?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	General Comments		
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	General Comments		
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Foundation Condition	Good	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Follow-up Action Required?	n	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Fault Operations Ground	0	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Fault Operations C Ø	0	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Fault Operations B Ø	0	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Fault Operations A Ø	0	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Bushing Condition	Good	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Amps C Ø	220.0	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Amps B Ø	220.0	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Amps A Ø	200.0	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	9 Month Operations	5	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	9 Month Operations	8	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Fault Operations Ground	0	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Follow-up Action Required?	n	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Foundation Condition	Good	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	General Comments		
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	General Comments		
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Grounds in Place?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	General Comments		
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	FE000334	Fence	664-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Maintenance Operations	0	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Operations Counter AF	99999	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Operations Counter AL	99999	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Operations This Read Vac	2	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Switching Operations	2	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	LTCC000420	LTCControl	930-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	LTCC000420	LTCControl	930-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	LTCC000420	LTCControl	930-Offline-Distribution	LTC Control Insp	General Comments		
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	LTCC000420	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3600	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5292	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	Totalizer Meter Reading	.8148	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	Totalizer Meter Multiplier	2400	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	Oil Temp Present	40	°C
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	Oil Temp Max	40	°C
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	LTC Totalizer Reading	1955.52	kw
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	General Comments		
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	General Comments		
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	S0014	WithLTC	401-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	LTCC000111	LTCControl	195-5	LTC Control Insp	VRR Time Delay	30	Seconds
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	LTCC000111	LTCControl	195-5	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	LTCC000111	LTCControl	195-5	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	LTCC000111	LTCControl	195-5	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	LTCC000111	LTCControl	195-5	LTC Control Insp	LTC Operation Checked?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	LTCC000111	LTCControl	195-5	LTC Control Insp	General Comments		
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	LTCC000111	LTCControl	195-5	LTC Control Insp	Follow-up Action Required?	n	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	LTCC000111	LTCControl	195-5	LTC Control Insp	All Connections OK?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	YD000201	Yard	758-Yard	Yard Patrol Inspection	Vegetation	None	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	LTCC000687	LTCControl	535-1	LTC Control Insp	All Connections OK?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	LTCC000687	LTCControl	535-1	LTC Control Insp	Follow-up Action Required?	n	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	LTCC000687	LTCControl	535-1	LTC Control Insp	General Comments		
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	LTCC000687	LTCControl	535-1	LTC Control Insp	LTC Operation Checked?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	LTCC000687	LTCControl	535-1	LTC Control Insp	LTC Output Voltage Level	114.0	VAC
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	LTCC000687	LTCControl	535-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	LTCC000687	LTCControl	535-1	LTC Control Insp	VRR Base Voltage AF	113.5	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	LTCC000687	LTCControl	535-1	LTC Control Insp	VRR Base Voltage AL	113.5	VAC
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	LTCC000687	LTCControl	535-1	LTC Control Insp	VRR Time Delay	45	Seconds
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	LTCC000688	LTCControl	535-2	LTC Control Insp	All Connections OK?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	LTCC000688	LTCControl	535-2	LTC Control Insp	Follow-up Action Required?	n	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	LTCC000688	LTCControl	535-2	LTC Control Insp	General Comments		
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Fault Operations B Ø	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Fault Operations C Ø	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Fault Operations Ground	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Follow-up Action Required?	n	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Patrol Inspection	Foundation Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Patrol Inspection	General Comments		
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	General Comments		
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Patrol Inspection	Grounds in Place?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Maintenance Operations	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Operations Counter AF	195	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Regulator As Left Counter	10173	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	122.0	volts
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Operations Counter AL	195	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Operations This Read Vac	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Switching Operations	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK001048	BreakerVacuum	664-0031	VCB Readings	Unknown Operations	0	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	General Comments		
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Fans Operational?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Fans Condition	Good	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000013	Regulator	735-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	General Comments		
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	General Comments		
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1905.12	kw
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	Oil Temp Max	63	°C
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	W0241	NonLTC	852-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	General Comments		
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Vegetation	None	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	General Comments		
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	LTCC000320	LTCControl	664-1	LTC Control Insp	All Connections OK?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	LTCC000320	LTCControl	664-1	LTC Control Insp	Follow-up Action Required?	n	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	LTCC000320	LTCControl	664-1	LTC Control Insp	General Comments		
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	LTCC000320	LTCControl	664-1	LTC Control Insp	LTC Operation Checked?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	LTCC000320	LTCControl	664-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	LTCC000320	LTCControl	664-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	LTCC000320	LTCControl	664-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	LTCC000320	LTCControl	664-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	LTCC000320	LTCControl	664-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	YD000419	Yard	808-Yard	Yard Patrol Inspection	Ambient Temp	63	*F
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	General Comments		
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	FE000417	Fence	808-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Switching Operations	0	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Operations This Read Vac	2	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Operations Counter AL	207	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Operations Counter AF	207	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Maintenance Operations	2	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Grounds in Place?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	General Comments		
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Foundation Condition	Good	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Follow-up Action Required?	n	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Fault Operations Ground	0	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Fault Operations C Ø	0	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Fault Operations B Ø	0	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Fault Operations A Ø	0	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Patrol Inspection	Bushing Condition	Good	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Amps C Ø	79.0	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Amps B Ø	69.0	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Vegetation	None	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	General Comments		
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Amps A Ø	65.0	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	KB0133	BreakerVacuum	195-1311	VCB Readings	9 Month Operations	8	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0477	BreakerVacuum	808-0048	VCB Readings	Unknown Operations	0	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	YD000421	Yard	627-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	LTCC000205	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	LTCC000205	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	LTCC000205	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	LTCC000205	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	LTCC000205	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	LTCC000205	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	LTCC000205	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	LTCC000205	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	ST000421	Structure	808-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Operating Linkage OK?	y	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Bushing Condition	Good	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Amps C Ø	20.0	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Amps B Ø	20.0	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Amps A Ø	20.0	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Fault Operations A Ø	0	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Fault Operations B Ø	0	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Fault Operations C Ø	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Trash Emptied?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Restroom Clean & OK?	n	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	General Comments		
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Broom on Site?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	CH000147	ControlHouse	AB-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Unknown Operations	0	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Switching Operations	1	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Operations This Read Vac	1	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Operations Counter AL	453	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Operations Counter AF	453	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Readings	Maintenance Operations	0	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0432	BreakerVacuum	808-0049	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	General Comments		
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	ST000429	Structure	742-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	9 Month Operations	10	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Amps A Ø	10.0	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Amps B Ø	10.0	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Amps C Ø	10.0	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Unknown Operations	0	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Switching Operations	4	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Operations This Read Vac	4	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Bushing Condition	Good	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	CB0233	BreakerVacuum	587-2138	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Operations Counter AL	168	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Operations Counter AF	168	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Maintenance Operations	0	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Grounds in Place?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	General Comments		
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	General Comments		
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Foundation Condition	Good	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Fault Operations Ground	0	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Fault Operations C Ø	0	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Fault Operations B Ø	0	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Fault Operations A Ø	0	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0277	BreakerVacuum	590-0168	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	All Identified and Legible?	y	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Foundation Condition	Good	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	General Comments		
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Ground Connections Intact?	y	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	ST000715	Structure	003-Structure 34.5	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Current Tap Position	7L	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	General Comments	needs wildlife protection	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Regulator As Left Counter	61239	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1447	Regulator	822-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	General Comments		
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	ST000256	Structure	852-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	General Comments		
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	FE000251	Fence	852-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	General Comments		
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	CH000070	ControlHouse	535-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	Totalizer Meter Reading	.1360	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	326.40	kw
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	General Comments		
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	General Comments		
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	C0367	NonLTC	627-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Current Tap Position	9L	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	General Comments		
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Maintenance Operations	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Operations Counter AF	135	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Operations Counter AL	135	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Operations This Read AM	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Switching Operations	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0057	BreakerAirMagnetic	AB-1207	AMCB Readings	Unknown Operations	0	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Unknown Operations	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Switching Operations	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Operations This Read AM	0	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	General Comments		
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	FE000418	Fence	627-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
8/4/2020 13:32	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
8/4/2020 13:32	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	120.00	
8/4/2020 13:32	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Readings	Oil Temp Max	75	°C
8/4/2020 13:32	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Readings	General Comments		
8/4/2020 13:32	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	n	
8/4/2020 13:32	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Operations Counter AL	112	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Operations Counter AF	112	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Maintenance Operations	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	General Comments		
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Patrol Inspection	General Comments		
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Fault Operations C ∅	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Fault Operations B ∅	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Fault Operations A ∅	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	General Comments		
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	BCH000238	Charger	401-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	BCH000238	Charger	401-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	BCH000238	Charger	401-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	BCH000238	Charger	401-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	BCH000238	Charger	401-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	BCH000238	Charger	401-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	10.000	millivolts
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	.3	VDC
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	.3	VDC
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	BAT000859	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	SWG000103	Switchgear	AB-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Fault Operations A Ø	0	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Fault Operations B Ø	0	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Fault Operations C Ø	0	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Fault Operations Ground	0	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Follow-up Action Required?	n	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Foundation Condition	Good	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	General Comments		
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	General Comments		
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Grounds in Place?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Maintenance Operations	0	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Operations Counter AF	99940	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Operations Counter AL	99940	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Operations This Read Vac	0	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	General Comments		
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Switching Operations	0	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Unknown Operations	0	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	ST000141	Structure	401-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Fault Operations A Ø	0	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Fault Operations B Ø	0	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Fault Operations C Ø	0	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Fault Operations Ground	0	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Follow-up Action Required?	n	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Foundation Condition	Good	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	General Comments		
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	General Comments		
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Grounds in Place?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Maintenance Operations	2	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Operations Counter AF	82	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Operations Counter AL	82	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Operations This Read Vac	3	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Switching Operations	1	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Unknown Operations	0	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Vegetation	None	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	General Comments		
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Amps A Ø	33.0	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Amps B Ø	31.0	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Amps C Ø	39.0	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	General Comments		
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Operations Counter	112	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	KX0165	RecloserElectronic	852-1502	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	YD000205	Yard	535-Yard	Yard Patrol Inspection	Ambient Temp	60	*F
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	General Comments		
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	FE000207	Fence	535-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	General Comments		
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	General Comments		
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	LTC Totalizer Reading	3996.00	kw
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	Oil Temp Max	50	*C
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	Oil Temp Present	40	*C
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	Totalizer Meter Reading	.2220	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	Winding Temp Max	35	*C
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	Winding Temp Present	32	*C
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	C0527	WithLTC	590-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	General Comments		
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	ST000211	Structure	581-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	9 Month Operations	7	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Amps A Ø	200.0	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Amps B Ø	180.0	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Amps C Ø	200.0	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Bushing Condition	Good	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BB0430	BreakerVacuum	808-0050	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	Fault Operations C Ø	0	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	Fault Operations Ground	0	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	Follow-up Action Required?	n	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	Foundation Condition	Good	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	General Comments		
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	General Comments		
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	Grounds in Place?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	Maintenance Operations	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LTCC000401	LTCCControl	AB-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LTCC000401	LTCCControl	AB-TRANS 1	LTC Control Insp	General Comments		
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LTCC000401	LTCCControl	AB-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	Operations Counter AF	193	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	Operations Counter AL	193	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	Operations This Read Vac	0	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	Switching Operations	0	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	Unknown Operations	0	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Readings	9 Month Operations	2	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Readings	Amps A Ø	0.0	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Readings	Amps B Ø	0.0	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Readings	Amps C Ø	0.0	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Patrol Inspection	Bushing Condition	Good	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	LTCC000395	LTCCControl	587-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	LTCC000395	LTCCControl	587-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	LTCC000395	LTCCControl	587-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	LTCC000395	LTCCControl	587-1	LTC Control Insp	LTC Output Voltage Level	123.4	VAC
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	LTCC000395	LTCCControl	587-1	LTC Control Insp	LTC Operation Checked?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	LTCC000395	LTCCControl	587-1	LTC Control Insp	General Comments		
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	LTCC000395	LTCCControl	587-1	LTC Control Insp	Follow-up Action Required?	n	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	LTCC000395	LTCCControl	587-1	LTC Control Insp	All Connections OK?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Readings	Fault Operations A Ø	0	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Readings	Fault Operations B Ø	0	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Readings	Fault Operations C Ø	0	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Readings	Fault Operations Ground	0	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Readings	Follow-up Action Required?	n	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Patrol Inspection	Foundation Condition	Good	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Amps C Ø	34.0	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Amps B Ø	36.0	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Amps A Ø	39.0	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	9 Month Operations	3	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	General Comments		
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	General Comments		
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	LTC Totalizer Reading	1981.76	kw
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	Oil Temp Max	60	°C
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	Oil Temp Present	45	°C
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	Totalizer Meter Reading	.6193	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	BCH000453	Charger	822-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	BCH000453	Charger	822-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	BCH000453	Charger	822-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.6	VDC
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	General Comments		
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	71	*F
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	BAT000494	Battery	735-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	General Comments		
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	General Comments		
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Grounds in Place?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Maintenance Operations	0	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Operations Counter AF	1653	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Operations Counter AL	1653	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Operations This Read Vac	3	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Readings	Operations Counter AF	172	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Readings	Operations Counter AL	172	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Readings	Operations This Read Vac	1	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Readings	Switching Operations	1	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000534	BreakerVacuum	417-2135	VCB Readings	Unknown Operations	0	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Switching Operations	3	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	K0051	BreakerVacuum	417-2132	VCB Readings	Unknown Operations	0	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Unknown Operations	0	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Switching Operations	1	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Operations This Read Vac	1	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Operations Counter AL	239	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Operations Counter AF	239	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Maintenance Operations	0	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Grounds in Place?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	General Comments		
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Operations Counter	6	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	General Comments		
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	General Comments		
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Foundation Condition	Good	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Follow-up Action Required?	n	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Fault Operations Ground	0	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Fault Operations C Ø	0	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Fault Operations B Ø	0	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Fault Operations A Ø	0	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	W0362	WithLTC	159-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Patrol Inspection	Bushing Condition	Good	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Amps C Ø	165.0	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Amps B Ø	150.0	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	KB0086	BreakerVacuum	808-0187	VCB Readings	Amps A Ø	205.0	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	RC001268	RecloserElectronic	852-1501	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Fault Operations Ground	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Fault Operations C Ø	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Fault Operations B Ø	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Fault Operations A Ø	0	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	LTC Operations Since Last Insp	329	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	LTC Min Tap Position	3L	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	LTC Max Tap Position	11R	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	LTC Current Tap Position	3L	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	LTC As Left Counter	75182	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	LTC As Found Counter	75175	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Mechanism Patrol Inspection	General Comments		
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	General Comments		
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	W0362	LTCMechanism	159-5	LTC Counter Readings	Follow-up Action Required?	n	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Patrol Inspection	Bushing Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Amps C Ø	45.0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Amps B Ø	35.0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Amps A Ø	35.0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	9 Month Operations	4	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Ambient Temp	71	°F
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	Follow-up Action Required?	n	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	General Comments		
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Mechanism Patrol Inspection	General Comments		
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	LTC As Found Counter	121435	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	LTC As Left Counter	121440	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	LTC Current Tap Position	3R	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	LTC Max Tap Position	2R	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	LTC Min Tap Position	5L	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	LTC Operations Since Last Insp	512	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	S0014	LTCMechanism	401-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	General Comments		
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Patrol Inspection	Bushing Condition	Good	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Amps C Ø	27.0	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Amps B Ø	34.0	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Amps A Ø	38.0	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	BK000080	BreakerVacuum	401-1324	VCB Readings	9 Month Operations	3	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Unknown Operations	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Switching Operations	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Operations This Read Vac	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Operations Counter AL	190	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Operations Counter AF	190	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Maintenance Operations	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Patrol Inspection	Grounds in Place?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	General Comments		
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Patrol Inspection	General Comments		
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Patrol Inspection	Foundation Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Follow-up Action Required?	n	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Fault Operations Ground	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Fault Operations C Ø	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Fault Operations B Ø	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Fault Operations A Ø	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Patrol Inspection	Bushing Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Amps C Ø	80.0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Amps B Ø	75.0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Amps A Ø	80.0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000079	BreakerVacuum	664-0139	VCB Readings	9 Month Operations	3	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Unknown Operations	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Switching Operations	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Operations This Read Vac	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Operations Counter AL	177	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Operations Counter AF	177	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Patrol Inspection	Grounds in Place?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	General Comments		
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Patrol Inspection	General Comments		
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Patrol Inspection	Foundation Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000078	BreakerVacuum	664-0138	VCB Readings	Follow-up Action Required?	n	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	General Comments		
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Readings	General Comments		
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Readings	LTC Totalizer Reading	2574.72	kw
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Counter Readings	LTC Operations Since Last Insp	725	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Counter Readings	LTC Min Tap Position	4L	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Counter Readings	LTC Max Tap Position	2R	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Counter Readings	LTC Current Tap Position	4L	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Counter Readings	LTC As Left Counter	128074	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Counter Readings	LTC As Found Counter	128065	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Mechanism Patrol Inspection	General Comments		
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Counter Readings	General Comments		
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0353	LTCMechanism	535-3	LTC Counter Readings	Follow-up Action Required?	n	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Readings	Oil Temp Max	35	°C
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Readings	Oil Temp Present	35	°C
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Readings	Totalizer Meter Reading	.2682	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	General Comments		
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	FE000138	Fence	401-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	9 Month Operations	1	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	Amps A Ø	40.0	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	Amps B Ø	34.0	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BK000533	BreakerVacuum	417-2133	VCB Readings	Amps C Ø	43.0	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Vegetation	None	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	YD000411	Yard	735-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	KB0119	BreakerVacuum	735-0017	VCB Readings	9 Month Operations	3	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	General Comments		
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Max Tap Position	5L	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Min Tap Position	14L	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Regulator As Left Counter	15737	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R1453	Regulator	852-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Amps C Ø	329.0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Amps B Ø	300.0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Amps A Ø	281.0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0062	BreakerAirMagnetic	AB-12KV TR 2	AMCB Readings	9 Months Operations	0	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Counter Readings	Follow-up Action Required?	n	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Counter Readings	General Comments		
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Mechanism Patrol Inspection	General Comments		
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Counter Readings	LTC As Found Counter	274125	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Counter Readings	LTC As Left Counter	274132	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Counter Readings	LTC Current Tap Position	5R	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Counter Readings	LTC Max Tap Position	6R	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Counter Readings	LTC Min Tap Position	4L	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Counter Readings	LTC Operations Since Last Insp	721	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0290	LTCMechanism	535-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Vegetation	None	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	General Comments		
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	YD000251	Yard	852-Yard	Yard Patrol Inspection	Ambient Temp	67	*F
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	C0463	WithLTC	671-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Amps B Ø	34.0	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Amps A Ø	35.0	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Regulator As Left Counter	89051	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Current Tap Position	Neutral	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	General Comments		
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Regulator As Left Counter	83006	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0495	Regulator	758-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	Winding Temp Present	70	°C
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	Winding Temp Max	70	°C
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	Oil Temp Present	65	°C
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	Oil Temp Max	70	°C
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.5	psi
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	General Comments		
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	General Comments		
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	Follow-up Action Required?	n	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Ambient Temp	71	°F
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Positive DC Ground	20.0	VDC
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Negative DC Ground	22.0	VDC
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	General Comments		
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BAT000950	Battery	417-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	General Comments		
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Max Tap Position	3L	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0494	Regulator	758-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Operations Counter	8	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	General Comments		
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	RC000125	RecloserElectronic	742-2150	Recloser Electronic Patrol Inspection	Amps C Ø	37.0	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	LTC Operations Since Last Insp	665	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	Winding Temp Present	30	*C
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	Winding Temp Max	40	*C
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	Totalizer Meter Reading	.2950	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	Oil Temp Present	32	*C
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	Oil Temp Max	32	*C
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1416.00	kw
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	General Comments		
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	General Comments		
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	S0066	NonLTC	742-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	.8	VDC
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	.8	VDC
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	BAT001091	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	BCH001055	Charger	862-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.3	VDC
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	BCH000530	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	BCH000530	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	BCH000530	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	BCH000530	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	BCH000530	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	BCH000530	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0353	WithLTC	535-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Ambient Temperature	60	°F
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Readings	Fault Operations	0	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Readings	Follow-up Action Required?	n	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Foundation Condition	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Gauge(s) Condition	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Readings	General Comments		
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	General Comments	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Grounds in Place?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Heaters (All) Functioning?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Readings	Maintenance Operations	7	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Readings	Num Operations Last 9 Months	7	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Readings	Operations Counter AF	80	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Readings	Operations Counter AL	80	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Readings	Operations This Read SF6	7	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	SF6 Bushing Condition	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	SF6 Compressor Belt Condition	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	SF6 Pressure	65	psi
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Readings	Switching Operations	0	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BK001133	BreakerSF6	535-628	GCB Readings	Unknown Operations	0	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	General Comments		
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Regulator As Left Counter	30315	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1525	Regulator	742-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	Follow-up Action Required?	n	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	General Comments		
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Mechanism Patrol Inspection	General Comments		
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	LTC As Found Counter	527430	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	LTC As Left Counter	527449	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	LTC Current Tap Position	3R	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	LTC Max Tap Position	2R	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	W0296	LTCMechanism	581-1	LTC Counter Readings	LTC Min Tap Position	6L	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Counter Readings	Follow-up Action Required?	n	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Counter Readings	General Comments		
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Mechanism Patrol Inspection	General Comments		
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Counter Readings	LTC As Found Counter	2438	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Counter Readings	LTC As Left Counter	2438	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Counter Readings	LTC Current Tap Position	7L	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Counter Readings	LTC Max Tap Position	1L	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Counter Readings	LTC Min Tap Position	9L	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Counter Readings	LTC Operations Since Last Insp	609	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	B0253	LTCMechanism	735-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Vegetation	None	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	General Comments		
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	YD000136	Yard	401-Yard	Yard Patrol Inspection	Ambient Temp	71	°F
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	9 Month Operations	8	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Counter Readings	Follow-up Action Required?	n	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Counter Readings	General Comments		
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Mechanism Patrol Inspection	General Comments		
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Counter Readings	LTC As Found Counter	104012	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Counter Readings	LTC As Left Counter	104015	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Counter Readings	LTC Current Tap Position	3L	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Counter Readings	LTC Max Tap Position	4L	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Counter Readings	LTC Min Tap Position	Neutral	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Counter Readings	LTC Operations Since Last Insp	231	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	C0527	LTCMechanism	590-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Amps A Ø	5.0	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Amps B Ø	5.0	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Amps C Ø	5.0	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Bushing Condition	Good	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	9 Month Operations	2	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Amps A Ø	110.0	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Amps B Ø	125.0	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Amps C Ø	45.0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	54	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	68	°C
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	55	°C
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	75	°C
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	55	°C
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	68	°C
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	Oil Temp Present	52	°C
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	Oil Temp Max	67	°C
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.5	psi
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	General Comments		
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0015	WithLTC	AB-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Patrol Inspection	Bushing Condition	Good	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Amps C Ø	5.0	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Amps B Ø	5.0	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Amps A Ø	5.0	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0278	BreakerVacuum	590-0167	VCB Readings	9 Month Operations	9	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	General Comments		
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	ST000343	Structure	664-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Readings	Oil Temp Present	40	°C
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Fault Operations B Ø	0	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Fault Operations C Ø	0	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Fault Operations Ground	0	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Follow-up Action Required?	n	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Foundation Condition	Good	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Readings	Oil Temp Max	60	°C
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	3.0	VDC
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	3.0	VDC
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	BAT001088	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Vegetation	None	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	YD000340	Yard	664-Yard	Yard Patrol Inspection	General Comments		
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Readings	LTC Totalizer Reading	2845.44	kw
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Readings	General Comments		
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	General Comments		
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Bushing Condition	Good	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Fault Operations A Ø	0	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Fault Operations B Ø	0	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Fault Operations C Ø	0	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Fault Operations Ground	0	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Follow-up Action Required?	n	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Foundation Condition	Good	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	General Comments		
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	General Comments		
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Grounds in Place?	y	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Maintenance Operations	0	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Operations Counter AF	181	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Operations Counter AL	181	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Operations This Read Vac	0	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Switching Operations	0	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	BK001120	BreakerVacuum	769-0027	VCB Readings	Unknown Operations	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	46	°C
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	78	°C
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	55	°C
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	62	°C
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	55	°C
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	60	°C
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	Oil Temp Present	45	°C
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	Oil Temp Max	65	°C
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.3	psi
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0014	WithLTC	AB-TRANS 2	LTC Transformer Readings	General Comments		
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Fault Operations A Ø	0	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Readings	Totalizer Meter Reading	.5928	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	B0385	WithLTC	587-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	LTCC000381	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	LTCC000381	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	LTCC000381	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	LTCC000381	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	LTCC000381	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	General Comments		
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Vegetation	None	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	General Comments		
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	YD000267	Yard	671-Yard	Yard Patrol Inspection	Ambient Temp	70	*F
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	General Comments		
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	FE000265	Fence	671-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	9 Month Operations	3	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Bushing Condition	Good	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	General Comments		
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Readings	Oil Temp Max	55	°C
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Readings	Oil Temp Present	45	°C
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Readings	Totalizer Meter Reading	.4200	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	General Comments		
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	General Comments		
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1964.80	kw
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	117.50	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	110.00	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6140	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	ST000274	Structure	671-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	LTCC000381	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	LTCC000381	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	LTCC000381	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	CH000049	ControlHouse	Retired Distribution	Control House Patrol Inspection	Acceptable Building Appearance?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	CH000049	ControlHouse	Retired Distribution	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	CH000049	ControlHouse	Retired Distribution	Control House Patrol Inspection	Evidence of Insects	None	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	CH000049	ControlHouse	Retired Distribution	Control House Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	CH000049	ControlHouse	Retired Distribution	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	CH000049	ControlHouse	Retired Distribution	Control House Patrol Inspection	General Comments		
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	CH000049	ControlHouse	Retired Distribution	Control House Patrol Inspection	Panel Lights OK?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	CH000049	ControlHouse	Retired Distribution	Control House Patrol Inspection	Panels Dusted?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	CH000049	ControlHouse	Retired Distribution	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Readings	Oil Temp Max	50	°C
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Readings	Oil Temp Present	50	°C
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Ambient Temp	73	°F
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	General Comments		under frequency has been disabled
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Vegetation	None	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	YD000135	Yard	195-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	ST000140	Structure	195-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	Winding Temp Present	45	°C
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	Winding Temp Max	50	°C
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	Top Oil Temperature Present	30	°C
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	Top Oil Temperature Max	40	°C
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	55.00	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	60.00	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	2500	psi
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	General Comments		0 nitro at arrival, replaced bottle

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	General Comments		
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	T0171	NonLTC	003-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Fault Adjusted Amps A Phase V	2.22	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Fault Adjusted Amps B Phase V	2.22	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	68	*F
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Fault Adjusted Amps C Phase V	2.22	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Fault Operations A Ø	0	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Fault Operations B Ø	0	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Fault Operations C Ø	0	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Fault Operations Ground	0	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Follow-up Action Required?	n	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Foundation Condition	Good	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	General Comments		
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	General Comments		
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Grounds in Place?	y	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Maintenance Operations	0	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Operations Counter AF	231	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Operations Counter AL	231	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Operations This Read Vac	1	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Switching Operations	0	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 13:57	Distribution	Princeton Quarterly Inspection	BK000008	BreakerVacuum	003-3423	VCB Readings	Unknown Operations	1	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	9 Month Operations	2	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Amps A Ø	90.0	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Amps B Ø	105.0	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Readings	Amps C Ø	90.0	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Bushing Condition	Good	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	WB0167	BreakerVacuum	758-1315	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	General Comments		
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Readings	General Comments		
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	W0290	WithLTC	535-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	LTC As Left Counter	187709	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	LTC As Found Counter	187709	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	General Comments		
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	General Comments	Wildlife protection needed	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Max Tap Position	6R	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Regulator As Left Counter	40527	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1446	Regulator	822-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	General Comments		
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Readings	General Comments		
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Readings	LTC Totalizer Reading	3714.00	kw
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Readings	Oil Temp Max	60	°C
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Readings	Oil Temp Present	45	°C
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Readings	Totalizer Meter Reading	.6190	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Amps B Ø	355.0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Amps C Ø	355.0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	BCH001055	Charger	862-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.3	VDC
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	BCH001055	Charger	862-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	BCH001055	Charger	862-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	BCH001055	Charger	862-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	BCH001055	Charger	862-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	General Comments		
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	General Comments		
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Grounds in Place?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Maintenance Operations	0	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Operations Counter AF	156	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	589	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	3.5	psi
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	LTC Min Tap Position	11L	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	LTC Max Tap Position	7L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	LTC Current Tap Position	11L	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	LTC As Left Counter	94902	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	LTC As Found Counter	94902	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	General Comments		
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0015	LTCMechanism	AB-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Operations Counter AL	156	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Operations This Read Vac	4	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Switching Operations	4	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0280	BreakerVacuum	590-0169	VCB Readings	Unknown Operations	0	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	*F
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	662	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	9 Months Operations	7	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	LTC Min Tap Position	12L	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	LTC Max Tap Position	6L	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Counter Readings	LTC Current Tap Position	12L	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LT0014	LTCMechanism	AB-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	General Comments		
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Negative DC Ground	129.0	VDC
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Positive DC Ground	5.0	VDC
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BAT000445	Battery	535-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Amps A Ø	400.0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0297	WithLTC	664-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Readings	LTC Totalizer Reading	3114.00	kw
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Readings	Oil Temp Max	55	°C
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Readings	Oil Temp Present	45	°C
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Readings	Totalizer Meter Reading	.5190	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Vegetation	None	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	General Comments		
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	BAT000587	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Readings	Follow-up Action Required?	n	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	General Comments		
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Readings	General Comments		
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Readings	LTC Totalizer Reading	4032.00	kw
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0418	WithLTC	664-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	YD000416	Yard	769-Yard	Yard Patrol Inspection	Ambient Temp	58	°F
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	FE000409	Fence	769-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Switching Operations	0	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	SF6 Pressure	65	psi
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	SF6 Bushing Condition	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Operations This Read SF6	2	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Operations Counter AL	68	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Operations Counter AF	68	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Num Operations Last 9 Months	6	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Maintenance Operations	2	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Heaters (All) Functioning?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Grounds in Place?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	General Comments		
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	General Comments		
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Gauge(s) Condition	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Foundation Condition	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Follow-up Action Required?	n	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Readings	Fault Operations	0	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	BK000191	BreakerSF6	535-638	GCB Patrol Inspection	Ambient Temperature	61	°F
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Fault Operations A Ø	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Fault Operations B Ø	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Fault Operations C Ø	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Fault Operations Ground	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Follow-up Action Required?	n	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Patrol Inspection	General Comments		
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	General Comments		
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Maintenance Operations	0	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	M0037	NonLTC	735-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Operations Counter AF	134	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Operations Counter AL	134	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Operations This Read AM	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Switching Operations	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0055	BreakerAirMagnetic	AB-1205	AMCB Readings	Unknown Operations	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Patrol Inspection	General Comments		
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	C0423	WithLTC	664-1	LTC Transformer Readings	General Comments		
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Switching Operations	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Operations This Read AM	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Operations Counter AL	40	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Operations Counter AF	151	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Operations Counter AL	151	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Operations This Read Vac	1	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Switching Operations	0	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Unknown Operations	1	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	LTCC000742	LTCControl	808-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Ambient Temp	70	*F
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	General Comments		
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Operations Counter AF	40	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Maintenance Operations	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Vegetation	None	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	General Comments		
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Patrol Inspection	General Comments		
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	YD000625	Yard	AB-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Follow-up Action Required?	n	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Fault Operations Ground	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Fault Operations C ∅	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Fault Operations B ∅	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Fault Operations A ∅	0	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	Follow-up Action Required?	n	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	General Comments		
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Mechanism Patrol Inspection	General Comments		
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	LTC As Found Counter	37260	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	9 Month Operations	3	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Amps A Ø	160.0	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Amps B Ø	185.0	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Amps C Ø	160.0	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	LTC As Left Counter	37266	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	LTC Current Tap Position	6R	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	LTC Max Tap Position	7R	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	LTC Min Tap Position	4L	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	LTC Operations Since Last Insp	771	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	C0523	LTCMechanism	535-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Amps C Ø	0.0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	LTCMechanism	417-1	LTC Counter Readings	LTC Max Tap Position	8L	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Ambient Temp	55	*F
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	9 Month Operations	3	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Amps A Ø	10.0	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Amps B Ø	10.0	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	LTCC000742	LTCControl	808-2	LTC Control Insp	VRR Time Delay	30	Seconds
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Amps C Ø	10.0	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Bushing Condition	Good	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	9 Month Operations	4	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Fault Adjusted Amps A Phase V	2.83	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Fault Adjusted Amps B Phase V	2.83	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Fault Adjusted Amps C Phase V	2.83	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Fault Operations A Ø	0	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Fault Operations B Ø	0	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Fault Operations C Ø	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	General Comments		
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	LTCMechanism	417-1	LTC Counter Readings	LTC Current Tap Position	7L	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	LTCMechanism	417-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	LTCMechanism	417-1	LTC Counter Readings	LTC As Left Counter	9807	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	LTCMechanism	417-1	LTC Counter Readings	LTC As Found Counter	9804	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	LTCMechanism	417-1	LTC Mechanism Patrol Inspection	General Comments		
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	LTCMechanism	417-1	LTC Counter Readings	General Comments		
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	LTCMechanism	417-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	LTCMechanism	417-1	LTC Counter Readings	Follow-up Action Required?	n	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Fault Operations Ground	0	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Follow-up Action Required?	n	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Foundation Condition	Good	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	General Comments		
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	General Comments		
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Readings	Maintenance Operations	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	ST000609	Structure	AB-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	CB0254	BreakerVacuum	671-1504	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Unknown Operations	0	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Foundation Condition	Good	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	General Comments		
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	General Comments		
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Grounds in Place?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Maintenance Operations	0	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Operations Counter AF	184	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Operations Counter AL	184	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Operations This Read Vac	0	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Switching Operations	0	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Unknown Operations	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Operations Counter AL	299	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Operations Counter AF	299	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Maintenance Operations	0	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	General Comments		
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Regulator As Left Counter	87748	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	General Comments		
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	General Comments		
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1216	Regulator	742-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	General Comments		
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	General Comments		
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Amps B Ø	0.0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Amps A Ø	0.0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0051	BreakerAirMagnetic	AB-1201	AMCB Readings	9 Months Operations	1	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Ambient Temperature	60	*F
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Fault Operations	0	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Follow-up Action Required?	n	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Foundation Condition	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	General Comments		
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Bushing Condition	Good	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Fault Operations A Ø	0	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Fault Operations B Ø	0	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Fault Operations C Ø	0	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	General Comments		
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Grounds in Place?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Heaters (All) Functioning?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Maintenance Operations	0	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Num Operations Last 9 Months	4	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Fault Operations Ground	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Operations Counter AF	47	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Operations Counter AL	47	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Operations This Read SF6	0	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	SF6 Pressure	65	psi
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Switching Operations	0	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	TB1478	BreakerSF6	535-618	GCB Readings	Unknown Operations	0	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	LTCC000742	LTCControl	808-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	LTCC000742	LTCControl	808-2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	LTCC000742	LTCControl	808-2	LTC Control Insp	LTC Operation Checked?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	LTCC000742	LTCControl	808-2	LTC Control Insp	General Comments		
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	LTCC000742	LTCControl	808-2	LTC Control Insp	Follow-up Action Required?	n	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	LTCC000742	LTCControl	808-2	LTC Control Insp	All Connections OK?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Unknown Operations	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Switching Operations	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Operations This Read AM	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	BK000419	BreakerVacuum	735-0018	VCB Readings	Follow-up Action Required?	n	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	9 Month Operations	4	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	BAT001421	Battery	401-Battery Bank	Battery Patrol Inspection	Positive DC Ground	10.0	VDC
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	BAT001421	Battery	401-Battery Bank	Battery Patrol Inspection	Negative DC Ground	9.0	VDC
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	BAT001421	Battery	401-Battery Bank	Battery Patrol Inspection	General Comments		
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	General Comments		
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	General Comments		
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Maintenance Operations	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	General Comments	DNO	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Patrol Inspection	General Comments		
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Follow-up Action Required?	n	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	9 Month Operations	15	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Fault Operations Ground	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Fault Operations C Ø	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Fault Operations B Ø	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Fault Operations A Ø	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Amps C Ø	0.0	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	BAT001421	Battery	401-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	BAT001421	Battery	401-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	BAT001421	Battery	401-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	BAT001421	Battery	401-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	BAT001421	Battery	401-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Operations Counter	9	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	General Comments		
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	BAT001421	Battery	401-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	BAT001421	Battery	401-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Amps C Ø	36.0	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Amps B Ø	35.0	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	KX0065	RecloserElectronic	587-2137	Recloser Electronic Patrol Inspection	Amps A Ø	36.0	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Fault Operations Ground	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Operations Counter AL	204	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Operations This Read Vac	2	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Switching Operations	2	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Unknown Operations	0	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	BAT001421	Battery	401-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	BAT001421	Battery	401-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Fault Operations C Ø	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Fault Operations B Ø	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Fault Operations A Ø	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Battery Overall Condition	Good	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	All Connections OK?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	Follow-up Action Required?	n	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	General Comments		
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Mechanism Patrol Inspection	General Comments		
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	LTC As Found Counter	274124	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	LTC As Left Counter	27124	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	LTC Current Tap Position	4L	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	LTC Max Tap Position	4R	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	LTC Min Tap Position	6L	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	LTC Operations Since Last Insp	611	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	B0248	LTCMechanism	769-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	9 Months Operations	7	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.1	VDC
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Bushing Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Amps C Ø	135.0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Amps B Ø	155.0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Amps A Ø	170.0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	General Comments		
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	58	*F
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	BAT001227	Battery	769-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	BCH001157	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	BCH001157	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	BCH001157	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	BCH001157	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	BCH001157	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	BCH001157	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.000	millivolts
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	YD000454	Yard	417-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	YD000454	Yard	417-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	YD000454	Yard	417-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	YD000454	Yard	417-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Vegetation	None	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	General Comments		
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	SWG000021	Switchgear	AB-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Operations Counter	71	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	General Comments		
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	YD000318	Yard	581-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Amps C Ø	31.0	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Amps B Ø	33.0	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	KX0147	RecloserElectronic	627-2151	Recloser Electronic Patrol Inspection	Amps A Ø	41.0	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	LTCMechanism	417-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	LTCMechanism	417-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	LTCMechanism	417-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	LTCMechanism	417-1	LTC Counter Readings	LTC Operations Since Last Insp	501	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	LTCMechanism	417-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	LTCMechanism	417-1	LTC Counter Readings	LTC Min Tap Position	2L	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	FE000623	Fence	AB-Fence	Fence Patrol Inspection	General Comments		
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	LTCC000767	LTCCControl	808-1	LTC Control Insp	All Connections OK?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	LTCC000767	LTCCControl	808-1	LTC Control Insp	Follow-up Action Required?	n	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	LTCC000767	LTCCControl	808-1	LTC Control Insp	General Comments		
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	LTCC000767	LTCCControl	808-1	LTC Control Insp	LTC Operation Checked?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	LTCC000767	LTCCControl	808-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	LTCC000767	LTCCControl	808-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	LTCC000767	LTCCControl	808-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	75	*F
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	BAT000250	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	LTCC000767	LTCControl	808-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BCH000468	Charger	417-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Amps A Ø	400.0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Amps B Ø	315.0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Amps C Ø	310.0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Fault Operations A Ø	0	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	YD000454	Yard	417-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Fault Operations B Ø	0	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	YD000454	Yard	417-Yard	Yard Patrol Inspection	Vegetation	None	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Fault Operations C Ø	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Fault Operations Ground	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Readings	Follow-up Action Required?	n	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0056	BreakerAirMagnetic	AB-1206	AMCB Patrol Inspection	General Comments		
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Regulator As Left Counter	30855	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.1	volts
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	BCH001157	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	General Comments		
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Max Tap Position	1L	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Amps B Ø	0.0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Amps A Ø	0.0	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	YD000454	Yard	417-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	YD000454	Yard	417-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	YD000454	Yard	417-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	YD000454	Yard	417-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	YD000454	Yard	417-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	YD000454	Yard	417-Yard	Yard Patrol Inspection	General Comments		
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	YD000454	Yard	417-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	YD000454	Yard	417-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	YD000454	Yard	417-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	YD000454	Yard	417-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	YD000454	Yard	417-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	YD000454	Yard	417-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	9 Months Operations	0	
10/7/2020 17:00	Distribution	Salvisa Quarterly Inspection	R1523	Regulator	742-1 C	Regulator Patrol Inspection	General Comments		
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.0	volts
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Regulator As Left Counter	11156	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Switching Operations	0	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Ambient Temp	70	*F
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	General Comments		
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	General Comments		
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Amps B Ø	28.0	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Amps A Ø	32.0	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	ST000418	Structure	769-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Unknown Operations	0	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Operations Counter	117	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	General Comments		
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	BCH000428	Charger	671-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Fault Operations A Ø	0	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Fault Operations B Ø	0	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Fault Operations Ground	0	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Maintenance Operations	1	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Operations Counter AF	162	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Operations Counter AL	162	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Operations This Read Vac	1	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Follow-up Action Required?	n	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Foundation Condition	Good	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	BCH000428	Charger	671-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	BCH000428	Charger	671-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	BCH000428	Charger	671-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	BCH000428	Charger	671-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	General Comments		
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	General Comments		
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Grounds in Place?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Maintenance Operations	2	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Operations Counter AF	153	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Operations Counter AL	153	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Operations This Read Vac	2	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Switching Operations	0	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Unknown Operations	0	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Amps C Ø	33.0	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	General Comments		
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Max Tap Position	3R	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000067	Regulator	735-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Follow-up Action Required?	n	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Foundation Condition	Good	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	General Comments		
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	General Comments		
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Maintenance Operations	0	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Grounds in Place?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	General Comments	top valve leaking	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	KT0047	NonLTC	862-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	LTCC000759	LTCCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	LTCC000759	LTCCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	LTCC000759	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	LTCC000759	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	LTCC000759	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.7	VAC
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	LTCC000759	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	LTCC000759	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	LTCC000759	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Unknown Operations	0	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Switching Operations	0	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Operations This Read Vac	1	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Operations Counter AL	164	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Operations Counter AF	164	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Maintenance Operations	1	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Grounds in Place?	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	General Comments		
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	General Comments		
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Foundation Condition	Good	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Follow-up Action Required?	n	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Fault Operations Ground	0	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Fault Operations C Ø	0	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Fault Operations B Ø	0	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Fault Operations A Ø	0	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Patrol Inspection	Bushing Condition	Good	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Amps C Ø	20.0	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Amps B Ø	20.0	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Amps A Ø	20.0	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	WB0180	BreakerVacuum	581-1318	VCB Readings	9 Month Operations	2	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	FE000553	Fence	590-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	General Comments		
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Unknown Operations	0	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Counter Readings	Follow-up Action Required?	n	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Counter Readings	General Comments		
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Mechanism Patrol Inspection	General Comments		
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Counter Readings	LTC As Found Counter	6603	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Counter Readings	LTC As Left Counter	6603	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Counter Readings	LTC Current Tap Position	3L	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Counter Readings	LTC Max Tap Position	2R	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Counter Readings	LTC Min Tap Position	6L	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Counter Readings	LTC Operations Since Last Insp	321	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	B0297	LTCMechanism	664-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Switching Operations	0	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Operations This Read Vac	0	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Operations Counter AL	401	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Operations Counter AF	401	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Regulator As Left Counter	10173	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	122.0	volts
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/7/2020 13:17	Distribution	Scott Street Quarterly Inspection	RG000068	Regulator	735-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Amps A Ø	100.0	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Amps B Ø	100.0	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Amps C Ø	100.0	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	General Comments		
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Bushing Condition	Good	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Fault Operations A Ø	0	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Fault Operations B Ø	0	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Fault Operations C Ø	0	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Readings	Fault Operations Ground	0	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	K0025	BreakerVacuum	417-2134	VCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	ST000423	Structure	627-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Amps A Ø	0.0	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Amps B Ø	0.0	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Amps C Ø	0.0	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Bushing Condition	Good	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	LTCC000666	LTCControl	769-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	LTCC000666	LTCControl	769-1	LTC Control Insp	LTC Operation Checked?	y	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	LTCC000666	LTCControl	769-1	LTC Control Insp	General Comments		
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	LTCC000666	LTCControl	769-1	LTC Control Insp	Follow-up Action Required?	n	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	LTCC000666	LTCControl	769-1	LTC Control Insp	All Connections OK?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Amps A Ø	32.0	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Amps B Ø	43.0	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Amps C Ø	22.0	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	General Comments		
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Operations Counter	218	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	WX0177	RecloserHydraulic	822-1515	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	9 Month Operations	9	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Amps A Ø	5.0	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Amps B Ø	5.0	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Amps C Ø	5.0	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Bushing Condition	Good	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Readings	Oil Temp Present	45	°C
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Readings	Oil Temp Max	55	°C
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Fault Operations A Ø	0	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Fault Operations B Ø	0	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Readings	General Comments		
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	General Comments		
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	10.00	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	FE000219	Fence	862-Fence	Fence Patrol Inspection	General Comments		
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	LTCC000666	LTCControl	769-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	LTCC000666	LTCControl	769-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	LTCC000666	LTCControl	769-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	W0268	NonLTC	758-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Current Tap Position	7L	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	General Comments	Secondary of xfmr needs wildlife protection	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1271.52	kw
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	70.00	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Readings	Oil Temp Present	45	°C
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	C0275	NonLTC	822-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5298	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Readings	Winding Temp Present	60	°C
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Readings	Winding Temp Max	70	°C
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	9 Month Operations	7	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	BCH000590	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	BCH000590	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	BCH000590	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	General Comments		
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	General Comments		
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	LTC Totalizer Reading	3263.04	kw
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	Oil Temp Max	35	°C
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	Oil Temp Present	30	°C
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	Totalizer Meter Reading	.6798	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	General Comments		
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.6	VDC
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.6	VDC
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	BAT001417	Battery	862-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	General Comments		
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	9 Month Operations	4	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Amps A Ø	10.0	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	BCH000590	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	BCH000590	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Amps B Ø	10.0	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Readings	Amps C Ø	10.0	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Bushing Condition	Good	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0166	BreakerVacuum	195-1310	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Operations This Read Vac	5	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Switching Operations	5	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Unknown Operations	0	
10/7/2020 10:48	Distribution	Wickliffe City Quarterly Inspection	X0334	RecloserElectronic	401-1325	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	C0523	WithLTC	535-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Fault Operations A Ø	0	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Fault Operations B Ø	0	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Fault Operations C Ø	0	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Fault Operations Ground	0	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	Follow-up Action Required?	n	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Foundation Condition	Good	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	General Comments		
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Readings	General Comments		
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	K0046	BreakerVacuum	195-1312	VCB Patrol Inspection	Grounds in Place?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Fault Operations C Ø	0	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Fault Operations Ground	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BCH001156	Charger	664-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BCH001156	Charger	664-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BCH001156	Charger	664-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BCH001156	Charger	664-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BCH001156	Charger	664-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.7	amps
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BCH001156	Charger	664-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BCH001156	Charger	664-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BCH001156	Charger	664-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	General Comments	Drag hand lower didnt reset only raise did	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Min Tap Position	11L	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Regulator As Left Counter	51819	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Follow-up Action Required?	n	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Foundation Condition	Good	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	R1445	Regulator	822-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	BCH000590	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	ST000564	Structure	590-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	YD000560	Yard	590-Yard	Yard Patrol Inspection	Vegetation	None	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	General Comments		
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	General Comments		
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Grounds in Place?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Maintenance Operations	0	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Operations Counter AF	342	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0281	BreakerVacuum	590-0166	VCB Readings	Operations Counter AL	342	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	W0296	WithLTC	581-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Bushing Condition	Good	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Amps C Ø	5.0	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Amps C Ø	10.0	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Amps B Ø	5.0	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Amps A Ø	5.0	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Fault Operations C Ø	0	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Fault Operations Ground	0	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Follow-up Action Required?	n	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	9 Month Operations	2	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Amps A Ø	100.0	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Amps B Ø	120.0	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Amps C Ø	120.0	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Foundation Condition	Good	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	General Comments		
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	General Comments		
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Grounds in Place?	y	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Maintenance Operations	1	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Operations Counter AF	120	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Amps B Ø	10.0	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Amps A Ø	10.0	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Operations Counter AL	120	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Operations This Read Vac	1	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Switching Operations	0	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Unknown Operations	0	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	9 Month Operations	5	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Vegetation	None	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	General Comments		
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Bushing Condition	Good	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Amps A Ø	0.0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Amps B Ø	0.0	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Bushing Condition	Good	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Follow-up Action Required?	n	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Fault Operations Ground	0	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Fault Operations C Ø	0	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Fault Operations B Ø	0	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Amps C Ø	0.0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Fault Operations A Ø	0	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Fault Adjusted Amps C Phase V	5.66	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Fault Adjusted Amps B Phase V	5.66	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Fault Adjusted Amps A Phase V	5.66	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Bushing Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Fault Operations A Ø	0	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Fault Operations B Ø	0	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Unknown Operations	1	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Switching Operations	0	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Operations This Read Vac	1	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Operations Counter AL	197	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Operations Counter AF	197	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Maintenance Operations	0	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Grounds in Place?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	General Comments		
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	General Comments		
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Fault Operations A Ø	1	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Fault Operations B Ø	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Fault Operations C Ø	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Fault Operations Ground	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Follow-up Action Required?	n	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Patrol Inspection	General Comments		
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	General Comments	A phase IOC, NO VC CHANGE	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Unknown Operations	0	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Switching Operations	0	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Operations This Read Vac	0	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Operations Counter AL	10	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Operations Counter AF	10	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Maintenance Operations	0	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Foundation Condition	Good	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Follow-up Action Required?	n	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Fault Operations Ground	0	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Fault Operations C Ø	0	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Fault Operations B Ø	0	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Fault Operations A Ø	0	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Fault Adjusted Amps C Phase V	2.83	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Fault Adjusted Amps B Phase V	2.83	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Fault Adjusted Amps A Phase V	2.83	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Current Tap Position	8L	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Regulator As Left Counter	74156	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Max Tap Position	4L	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	PF000030	PowerFuse	AB-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	PF000030	PowerFuse	AB-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	PF000029	PowerFuse	AB-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	PF000029	PowerFuse	AB-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	PF000028	PowerFuse	AB-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	PF000028	PowerFuse	AB-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	General Comments		
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	General Comments		
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	FE000315	Fence	581-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Current Tap Position	8L	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	9 Month Operations	0	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Amps A Ø	60.0	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Amps B Ø	60.0	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Amps C Ø	60.0	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Bushing Condition	Good	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	9 Months Operations	44	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Amps A Ø	340.0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Amps B Ø	360.0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Amps C Ø	370.0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Amps A Ø	25.0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Amps B Ø	45.0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Amps C Ø	15.0	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	General Comments		
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	Follow-up Action Required?	n	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	LTC Operations Since Last Insp	532	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	General Comments		
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BAT001215	Battery	664-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Counter Readings	LTC As Left Counter	76940	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Counter Readings	LTC As Found Counter	76931	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Mechanism Patrol Inspection	General Comments		
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Counter Readings	General Comments		
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Counter Readings	Follow-up Action Required?	n	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Amps A Ø	39.0	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Amps B Ø	37.0	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Amps C Ø	37.0	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Readings	Totalizer Meter Reading	.6485	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Follow-up Action Required?	n	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Foundation Condition	Good	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	General Comments		
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	General Comments		
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Grounds in Place?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Maintenance Operations	0	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Operations Counter AF	317	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Operations Counter AL	317	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Operations This Read Vac	4	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Switching Operations	4	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Unknown Operations	0	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	Oil Temp Present	50	°C
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Maintenance Operations	0	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Operations Counter AF	213	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Operations Counter AL	213	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Operations This Read Vac	2	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Switching Operations	0	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	Unknown Operations	2	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	Oil Temp Max	60	°C
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Readings	Oil Temp Present	42	°C
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Readings	Oil Temp Max	60	°C
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	9 Months Operations	15	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	LTC Totalizer Reading	3913.92	kw
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	General Comments		
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Readings	LTC Totalizer Reading	6225.60	kw
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Readings	General Comments		
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	O0229	WithLTC	417-1	LTC Transformer Patrol Inspection	General Comments		
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Counter Readings	LTC Current Tap Position	1L	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Counter Readings	LTC Max Tap Position	3R	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Counter Readings	LTC Min Tap Position	5L	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	General Comments		
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Counter Readings	LTC Operations Since Last Insp	525	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	C0463	LTCMechanism	671-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	9 Month Operations	7	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Grounds in Place?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Readings	General Comments		
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	General Comments		
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0098	BreakerVacuum	862-1505	VCB Patrol Inspection	Foundation Condition	Good	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	9 Month Operations	1	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Amps A Ø	260.0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Counter Readings	Follow-up Action Required?	n	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Counter Readings	General Comments		
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Operations Counter	58	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Mechanism Patrol Inspection	General Comments		
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Counter Readings	LTC As Found Counter	210827	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Counter Readings	LTC As Left Counter	210827	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Counter Readings	LTC Current Tap Position	3L	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Counter Readings	LTC Max Tap Position	4R	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Counter Readings	LTC Min Tap Position	7L	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Counter Readings	LTC Operations Since Last Insp	513	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	C0423	LTCMechanism	664-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Amps B Ø	260.0	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 10:30	Distribution	Wickliffe Quarterly Inspection	WB0179	BreakerVacuum	159-1309	VCB Readings	Amps C Ø	260.0	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Max Tap Position	5L	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	General Comments		
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Current Tap Position	8L	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	LTC Min Tap Position	9L	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	LTC Max Tap Position	2R	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	LTC Current Tap Position	6L	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	LTC As Left Counter	113557	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	LTC As Found Counter	113557	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Mechanism Patrol Inspection	General Comments		
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	General Comments		
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0390	LTCMechanism	808-2	LTC Counter Readings	Follow-up Action Required?	n	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	KX0148	RecloserElectronic	627-2152	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Regulator As Left Counter	68588	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0949	Regulator	627-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Fault Operations A Ø	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Fault Operations B Ø	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Fault Operations C Ø	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Fault Operations Ground	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Follow-up Action Required?	n	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Patrol Inspection	General Comments		
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	General Comments		
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Maintenance Operations	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Operations Counter AF	963	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Operations Counter AL	963	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Operations This Read AM	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Switching Operations	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0053	BreakerAirMagnetic	AB-1203	AMCB Readings	Unknown Operations	0	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Fault Operations Ground	0	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Fault Operations C Ø	0	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Fault Operations B Ø	0	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Fault Operations A Ø	0	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	Totalizer Meter Reading	.5436	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	C0449	WithLTC	195-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Unknown Operations	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Switching Operations	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Operations This Read AM	0	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Maintenance Operations	0	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	BCH001176	Charger	769-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	BCH001176	Charger	769-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	BCH001176	Charger	769-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	BCH001176	Charger	769-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	BCH001176	Charger	769-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	BCH001176	Charger	769-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	BCH001176	Charger	769-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/7/2020 9:18	Distribution	Mount Tabor Quarterly Inspection	BCH001176	Charger	769-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Operations Counter AF	156	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Operations Counter AL	156	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Operations This Read Vac	0	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Switching Operations	0	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Ambient Temp	80	*F
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Unknown Operations	0	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0959	Regulator	627-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/7/2020 17:16	Distribution	Kentucky State Hospital Quarterly Inspection	K0036	BreakerVacuum	587-2136	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	LTCC000024	LTCControl	581-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	LTCC000678	LTCControl	417-1	LTC Control Insp	All Connections OK?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	LTCC000678	LTCControl	417-1	LTC Control Insp	Follow-up Action Required?	n	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	LTCC000678	LTCControl	417-1	LTC Control Insp	General Comments		
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	LTCC000678	LTCControl	417-1	LTC Control Insp	LTC Operation Checked?	y	
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	LTCC000024	LTCControl	581-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	LTCC000024	LTCControl	581-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/7/2020 8:16	Distribution	Clinton 12kV Quarterly Inspection	LTCC000024	LTCControl	581-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Regulator As Left Counter	69897	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Operations Counter AL	99996	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0058	BreakerAirMagnetic	AB-1208	AMCB Readings	Operations Counter AF	99996	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Regulator As Left Counter	188911	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Min Tap Position	12L	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Max Tap Position	5L	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	BCH001179	Charger	590-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	BCH001179	Charger	590-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	BCH001179	Charger	590-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	BCH001179	Charger	590-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	BCH001179	Charger	590-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	BCH001179	Charger	590-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	BCH001179	Charger	590-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	BCH001179	Charger	590-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	General Comments		
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Fault Operations A Ø	0	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Current Tap Position	9L	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	General Comments		
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	PF000031	PowerFuse	AB-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	PF000031	PowerFuse	AB-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Fault Operations B Ø	0	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Fault Operations C Ø	0	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Fault Operations Ground	0	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Follow-up Action Required?	n	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Foundation Condition	Good	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	General Comments		
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	General Comments		
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Grounds in Place?	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	LTCC000678	LTCControl	417-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	LTCC000678	LTCControl	417-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Fault Operations B Ø	0	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Operations Counter AL	191	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Operations Counter AF	191	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Maintenance Operations	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Grounds in Place?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	General Comments		
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	Totalizer Meter Reading	.5220	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Maintenance Operations	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Operations Counter AF	839	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Operations Counter AL	839	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Operations This Read AM	1	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	Oil Temp Present	30	°C
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	Oil Temp Max	60	°C
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	B0390	WithLTC	808-2	LTC Transformer Readings	LTC Totalizer Reading	3132.00	kw
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Fault Operations C Ø	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Fault Operations Ground	0	
10/7/2020 13:39	Distribution	Ashby Quarterly Inspection	LB0052	BreakerAirMagnetic	AB-1202	AMCB Readings	Switching Operations	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Follow-up Action Required?	n	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Patrol Inspection	General Comments		
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	General Comments		
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Maintenance Operations	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Operations Counter AF	204	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	BAT001231	Battery	590-DC System	Battery Patrol Inspection	General Comments		
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	General Comments		
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Foundation Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Follow-up Action Required?	n	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Unknown Operations	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Switching Operations	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000501	BreakerVacuum	664-0015	VCB Readings	Operations This Read Vac	0	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BCH000541	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BCH000541	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BCH000541	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BCH000541	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BCH000541	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/7/2020 10:36	Distribution	Ashland Avenue Quarterly Inspection	BCH000541	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	General Comments		
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	ST000166	Structure	535-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Min Tap Position	8L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	BK000425	BreakerVacuum	664-BT1-2	VCB Readings	Fault Operations A Ø	0	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	General Comments		
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
10/7/2020 8:55	Distribution	Bardwell Quarterly Inspection	R0493	Regulator	758-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	General Comments		
10/7/2020 11:18	Distribution	Barlow Quarterly Inspection	FE000137	Fence	195-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	LTCC000678	LTCControl	417-1	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	LTCC000678	LTCControl	417-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Unknown Operations	1	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Fault Operations A Ø	0	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Fault Operations B Ø	0	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Fault Operations C Ø	0	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Fault Operations Ground	0	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Follow-up Action Required?	n	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Foundation Condition	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	General Comments		
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	General Comments		
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Grounds in Place?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Maintenance Operations	1	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Operations Counter AF	74	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Operations Counter AL	74	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Operations This Read Vac	1	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Switching Operations	0	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Unknown Operations	0	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	General Comments		
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	ST000236	Structure	822-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	General Comments		
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Max Tap Position	5L	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BCH000468	Charger	417-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BCH000468	Charger	417-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BCH000468	Charger	417-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BCH000468	Charger	417-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BCH000468	Charger	417-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/7/2020 16:55	Distribution	Harrodsburg Industrial Quarterly Inspection	BCH000468	Charger	417-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	9 Month Operations	3	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Grounds in Place?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	General Comments		
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	General Comments		
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Foundation Condition	Good	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Unknown Operations	0	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Fault Adjusted Amps A Phase V	2.83	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Fault Adjusted Amps B Phase V	2.83	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Fault Adjusted Amps C Phase V	2.83	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Fault Operations A Ø	0	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Fault Operations B Ø	0	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Fault Operations C Ø	0	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Fault Operations Ground	0	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Follow-up Action Required?	n	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Foundation Condition	Good	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	YD000229	Yard	822-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	General Comments		
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	General Comments		
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Grounds in Place?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Maintenance Operations	0	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Operations Counter AF	272	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Operations Counter AL	272	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Operations This Read Vac	1	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Patrol Inspection	Bushing Condition	Good	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Amps C Ø	63.0	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Amps B Ø	70.0	
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Amps A Ø	57.0	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Readings	Switching Operations	0	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	FE000230	Fence	822-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	9 Month Operations	2	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/7/2020 11:25	Distribution	Eddyville Prison Quarterly Inspection	KB0118	BreakerVacuum	671-1503	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	WB0159	BreakerVacuum	862-0560	VCB Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Amps A Ø	200.0	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Amps B Ø	200.0	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Readings	Amps C Ø	200.0	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Bushing Condition	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 9:53	Distribution	Westvaco Quarterly Inspection	WB0174	BreakerVacuum	5351-0102	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	9 Month Operations	0	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 16:43	Distribution	Danville West Quarterly Inspection	CB0275	BreakerVacuum	590-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	9 Month Operations	0	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Amps A Ø	15.0	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Amps B Ø	15.0	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Amps C Ø	20.0	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Bushing Condition	Good	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	General Comments		
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	General Comments		
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Foundation Condition	Good	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Follow-up Action Required?	n	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Fault Operations Ground	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Fault Operations C Ø	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Fault Operations B Ø	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Fault Operations A Ø	0	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 14:41	Distribution	Cedar Bluff Quarterly Inspection	K0117	BreakerVacuum	822-1514	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 10:18	Distribution	Kuttawa Quarterly Inspection	R0857	Regulator	852-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Bushing Condition	Good	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Regulator As Left Counter	210360	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/7/2020 17:06	Distribution	Shakertown Quarterly Inspection	R0960	Regulator	627-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Amps C Ø	140.0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Amps B Ø	200.0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Amps A Ø	180.0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	9 Month Operations	4	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Fault Operations Ground	0	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Fault Operations C Ø	0	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Fault Operations A Ø	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Grounds in Place?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Fault Operations B Ø	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Switching Operations	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Maintenance Operations	0	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Operations This Read Vac	0	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Operations Counter AL	332	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Readings	Operations Counter AF	332	
10/7/2020 14:33	Distribution	Race Street Quarterly Inspection	K0125	BreakerVacuum	664-0014	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Patrol Inspection	Bushing Condition	Good	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Amps C Ø	30.0	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Amps A Ø	90.0	
10/7/2020 12:16	Distribution	Eddyville Quarterly Inspection	K0067	BreakerVacuum	862-1506	VCB Readings	Amps B Ø	30.0	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	3L	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	5R	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments		
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	R0788	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	BCH000306	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	135.0	VDC
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Fault Operations Ground	0	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Fault Operations C Ø	0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000795	BreakersSF6	507-618	GCB Patrol Inspection	Foundation Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000795	BreakersSF6	507-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000795	BreakersSF6	507-618	GCB Readings	General Comments		
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Fault Operations B Ø	0	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Fault Operations A Ø	0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000795	BreakersSF6	507-618	GCB Patrol Inspection	General Comments	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000795	BreakersSF6	507-618	GCB Patrol Inspection	Grounds in Place?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000795	BreakersSF6	507-618	GCB Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000795	BreakersSF6	507-618	GCB Readings	Maintenance Operations	0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000795	BreakersSF6	507-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000795	BreakersSF6	507-618	GCB Readings	Num Operations Last 9 Months	0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000795	BreakersSF6	507-618	GCB Readings	Operations Counter AF	70	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000795	BreakersSF6	507-618	GCB Readings	Operations Counter AL	70	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000795	BreakersSF6	507-618	GCB Readings	Operations This Read SF6	0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000795	BreakersSF6	507-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000795	BreakersSF6	507-618	GCB Patrol Inspection	SF6 Pressure Indicator	good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000795	BreakersSF6	507-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000795	BreakersSF6	507-618	GCB Readings	Switching Operations	0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000795	BreakersSF6	507-618	GCB Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Unknown Operations	0	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Unknown Operations	0	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Switching Operations	1	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Regulator As Left Counter	57033	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000795	BreakersSF6	507-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000795	BreakersSF6	507-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000795	BreakersSF6	507-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000795	BreakersSF6	507-618	GCB Readings	Fault Operations	0	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Operations Counter AL	204	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Operations Counter AF	204	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Current Tap Position	11L	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Current Tap Position	3L	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000795	BreakersSF6	507-618	GCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000795	BreakersSF6	507-618	GCB Readings	Follow-up Action Required?	n	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Unknown Operations	0	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Switching Operations	2	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Operations This Read Vac	2	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Operations Counter AL	452	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Operations Counter AF	452	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Maintenance Operations	0	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Grounds in Place?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	General Comments		
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	General Comments		
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Foundation Condition	Good	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Follow-up Action Required?	n	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Grounds in Place?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	General Comments		
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	General Comments		
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Operations This Read Vac	1	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Operations Counter AL	158	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Operations Counter AF	158	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Maintenance Operations	0	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Grounds in Place?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	General Comments		
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Max Tap Position	8R	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Readings	Winding Temp Present	25	°C
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Readings	Winding Temp Max	50	°C
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Readings	Top Oil Temperature Present	30	°C
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Readings	Top Oil Temperature Max	75	°C
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	200	psi
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Min Tap Position	4L	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Max Tap Position	7R	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	120.0	volts
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Patrol Inspection	Bushing Condition	Good	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Amps C Ø	100.0	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Amps B Ø	102.0	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Amps A Ø	103.0	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	WB0151	BreakerVacuum	574-1710	VCB Readings	9 Month Operations	4	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	General Comments		
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Max Tap Position	13R	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Min Tap Position	3L	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	W0323	WithLTC	Retired Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	1L	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Regulator As Left Counter	32521	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	FE000425	Fence	726-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Max Tap Position	16L	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Fault Operations A Ø	0	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5058	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	General Comments		
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	General Comments		
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Ambient Temp	67	*F
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	General Comments		
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Vegetation	None	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	YD000258	Yard	827-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Amps A Ø	20.0	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Amps B Ø	20.0	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Amps C Ø	20.0	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Bushing Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	Follow-up Action Required?	n	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	General Comments		
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Mechanism Patrol Inspection	General Comments		
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	LTC As Found Counter	157493	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	LTC As Left Counter	157493	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	LTC Current Tap Position	6L	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	LTC Max Tap Position	Neutral	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	LTC Min Tap Position	12L	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	LTC Operations Since Last Insp	683	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0363	LTCMechanism	060-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Regulator As Left Counter	35601	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	FE000255	Fence	827-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1524	Regulator	775-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Fault Operations B Ø	0	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Fault Operations C Ø	0	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Fault Operations Ground	0	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Follow-up Action Required?	n	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Foundation Condition	Good	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	General Comments		
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	General Comments		
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Grounds in Place?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Maintenance Operations	0	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Operations Counter AF	252	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Operations Counter AL	252	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Operations This Read Vac	4	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	Switching Operations	4	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Readings	Num Operations Last 9 Months	1	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Readings	Operations Counter AF	65	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Readings	Operations Counter AL	65	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Readings	Operations This Read SF6	0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	SF6 Bushing Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	SF6 Pressure Indicator	good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Readings	Switching Operations	0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Ambient Temperature	50	°F
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000795	BreakerSF6	507-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Switching Operations	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Operations This Read Vac	0	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	General Comments		
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Readings	Fault Operations	0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Readings	Follow-up Action Required?	n	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Foundation Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	ST000265	Structure	827-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Readings	General Comments		
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	General Comments	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Grounds in Place?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Readings	Maintenance Operations	0	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	4855.68	kw
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Readings	General Comments		
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	S0006	NonLTC	726-1	NonLTC Transformer Patrol Inspection	General Comments		
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	278809	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Bushing Condition	Good	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Current Tap Position	3R	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Amps C Ø	3.0	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Amps B Ø	5.0	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Amps A Ø	11.0	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	9 Month Operations	2	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Tank Leaks	None	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Regulator As Left Counter	72191	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	General Comments		
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Foundation Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Follow-up Action Required?	n	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Fault Operations Ground	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Fault Operations C Ø	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Fault Operations B Ø	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Fault Operations A Ø	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Vegetation	None	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Amps A Ø	74.0	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	9 Month Operations	5	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments		
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Bushing Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Amps C Ø	425.0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Amps B Ø	410.0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Amps A Ø	420.0	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	12R	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	General Comments		
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	6L	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Foundation Condition	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	General Comments		
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Bushing Condition	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	KB0024	BreakerVacuum	116-0685	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1043	Regulator	607-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	Oil Temp Present	29	°C
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	ST000049	Structure	116-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	Oil Temp Max	29	°C
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	9 Month Operations	1	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Regulator As Left Counter	183598	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Vegetation	None	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R0804	Regulator	726-1 A	Regulator Patrol Inspection	General Comments		
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	YD000439	Yard	884-Yard	Yard Patrol Inspection	Ambient Temp	66	*F
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	General Comments		
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	FE000435	Fence	884-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	W0323	WithLTC	Retired Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	W0323	WithLTC	Retired Distribution	LTC Transformer Readings	Totalizer Meter Reading	.1680	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	W0323	WithLTC	Retired Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	W0323	WithLTC	Retired Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	General Comments		
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Follow-up Action Required?	n	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Fault Operations Ground	0	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Readings	General Comments		
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	General Comments		
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1514	Regulator	082-1 C	Regulator Patrol Inspection	General Comments		
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	General Comments		
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	Maintenance Operations	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Patrol Inspection	Grounds in Place?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	W0323	WithLTC	Retired Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments		
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	W0323	WithLTC	Retired Distribution	LTC Transformer Readings	General Comments		
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	W0323	WithLTC	Retired Distribution	LTC Transformer Readings	LTC Totalizer Reading	537.60	kw
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	R0739	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Unknown Operations	0	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Switching Operations	1	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Operations This Read Vac	1	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Operations Counter AL	150	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Operations Counter AF	150	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Maintenance Operations	0	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Grounds in Place?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	General Comments		
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	General Comments		
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Foundation Condition	Good	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	W0323	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Max	55	°C
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	ST000442	Structure	884-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	W0323	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Present	25	°C
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	W0323	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Bushing Condition	Good	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Amps C Ø	72.0	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Amps B Ø	82.0	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	General Comments		
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	Follow-up Action Required?	n	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	FE000154	Fence	861-Fence	Fence Patrol Inspection	General Comments		
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000832	BreakerVacuum	060-5	VCB Readings	General Comments		
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	General Comments		
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	General Comments		
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	LTC Totalizer Reading	4152.96	kw
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Ambient Temp	52	°F
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	YD000263	Yard	574-Yard	Yard Patrol Inspection	General Comments	SPR removed	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	T0168	NonLTC	113-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Fault Operations C Ø	0	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Fault Operations B Ø	0	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Fault Operations A Ø	0	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	FE000261	Fence	574-Fence	Fence Patrol Inspection	Fence Has 911 Info On Sign?	n	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	General Comments		
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Foundation Condition	Good	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Follow-up Action Required?	n	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Fault Operations Ground	0	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Fault Operations C Ø	0	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Fault Operations B Ø	0	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Fault Operations A Ø	0	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	BK000750	BreakerVacuum	775-2108	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R0746	Regulator	448-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK000798	BreakerVacuum	848-0154	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	General Comments		
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Grounds in Place?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Maintenance Operations	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Operations Counter AF	164	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Operations Counter AL	164	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Operations This Read Vac	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Switching Operations	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Unknown Operations	0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Bushing Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Amps C Ø	65.0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Amps B Ø	65.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Ambient Temp	66	*F
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Amps A Ø	65.0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	9 Month Operations	4	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	General Comments		
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KR00086	Regulator	803-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KR00086	Regulator	803-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KR00086	Regulator	803-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KR00086	Regulator	803-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	General Comments		
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	General Comments		
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1991.52	kw
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	30.00	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	Totalizer Meter Reading	.8298	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Unknown Operations	0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Switching Operations	0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Operations This Read Vac	0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Operations Counter AL	184	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Operations Counter AF	184	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Maintenance Operations	0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Grounds in Place?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	General Comments		
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	General Comments		
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Foundation Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Follow-up Action Required?	n	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Fault Operations Ground	0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Fault Operations C Ø	0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Fault Operations B Ø	0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000783	BreakerVacuum	507-0020	VCB Readings	Fault Operations A Ø	0	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	All Identified and Legible?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Vegetation	None	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	General Comments		
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	YD000222	Yard	437-Yard	Yard Patrol Inspection	Ambient Temp	67	*F
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	General Comments		
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	ST000227	Structure	574-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Vegetation	None	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	YD000543	Yard	775-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Regulator As Left Counter	56575	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	120.0	volts
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Min Tap Position	11L	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Max Tap Position	8R	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	General Comments		
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	General Comments		
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Current Tap Position	7L	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1045	Regulator	607-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Regulator As Left Counter	26278	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	ST000228	Structure	437-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Follow-up Action Required?	n	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	Foundation Condition	Good	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	General Comments		
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	General Comments		
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	Grounds in Place?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Maintenance Operations	1	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Operations Counter AF	176	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Operations Counter AL	176	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Operations This Read Vac	2	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Switching Operations	0	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Unknown Operations	1	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	General Comments		
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Max Tap Position	7R	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Regulator As Left Counter	31700	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Mechanism Patrol Inspection	General Comments		
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0231	LTCMechanism	116-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	9 Month Operations	4	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	BCH001132	Charger	072-Battery Charger Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	BCH001132	Charger	072-Battery Charger Distribution	Battery Charger Patrol Insp	As Found Float Voltage	134.2	VDC
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	BCH001132	Charger	072-Battery Charger Distribution	Battery Charger Patrol Insp	As Left Float Voltage	134.2	VDC
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	BCH001132	Charger	072-Battery Charger Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.6	amps
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	BCH001132	Charger	072-Battery Charger Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	BCH001132	Charger	072-Battery Charger Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	BCH001132	Charger	072-Battery Charger Distribution	Battery Charger Patrol Insp	General Comments		
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Fault Operations Ground	0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Fault Operations C Ø	0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Fault Operations B Ø	0	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R1455	Regulator	764-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Fault Operations A Ø	0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Bushing Condition	Good	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	9 Month Operations	3	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Amps A Ø	30.0	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Amps B Ø	27.0	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Amps C Ø	31.0	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	Bushing Condition	Good	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Fault Adjusted Amps A Phase V	1.93	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Fault Adjusted Amps B Phase V	1.93	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Fault Adjusted Amps C Phase V	1.93	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Fault Operations A Ø	0	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Fault Operations B Ø	0	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Fault Operations C Ø	0	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	BK001266	BreakerVacuum	764-1530	VCB Readings	Fault Operations Ground	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Fault Operations A Ø	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Fault Operations B Ø	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Fault Operations C Ø	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Fault Operations Ground	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Follow-up Action Required?	n	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Bushing Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Amps C Ø	120.0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Amps B Ø	115.0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Amps A Ø	110.0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	9 Month Operations	4	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Foundation Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	General Comments		
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	General Comments		
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Max Tap Position	6R	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	General Comments		
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	M0001	NonLTC	425-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KR0086	Regulator	803-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Amps C Ø	110.0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Amps B Ø	70.0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Amps A Ø	60.0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	9 Month Operations	4	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	ST000219	Structure	421-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Unknown Operations	0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Switching Operations	0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Operations This Read Vac	0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Operations Counter AL	190	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Operations Counter AF	190	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Maintenance Operations	0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Grounds in Place?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	General Comments		
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	General Comments		
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Foundation Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Follow-up Action Required?	n	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Fault Operations Ground	0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Fault Operations C Ø	0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Fault Operations B Ø	0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Fault Operations A Ø	0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000784	BreakerVacuum	507-0864	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	9 Month Operations	3	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Amps A Ø	360.0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Amps B Ø	380.0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Readings	Amps C Ø	400.0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Bushing Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0184	BreakerVacuum	060-6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Regulator As Left Counter	50507	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	120.0	volts
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Min Tap Position	11L	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Max Tap Position	7R	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	General Comments		
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Current Tap Position	7L	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	2	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	0.0	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	0.0	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	0.0	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	1	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	167	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	167	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	General Comments	lower position arm drags before resetting	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	50	°C
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	35	°C
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Very Low	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Reading	.3600	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Regulator As Left Counter	93431	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R1434	Regulator	421-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5382	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3600	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	Oil Temp Present	20	°C
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	97.50	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1937.52	kw
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	5.0	psi
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	General Comments		
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	General Comments		
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	B0218	NonLTC	764-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	General Comments	Top fan does not work	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	LTC Totalizer Reading	1359.36	kw
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	Oil Temp Max	54	°C
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	Oil Temp Present	35	°C
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	1R	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments	Head not operating	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	1R	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	1R	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	32938	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R1038	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	General Comments		
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	172	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	172	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000536	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	1	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000536	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	W0355	WithLTC	673-1	LTC Transformer Readings	Totalizer Meter Reading	.2832	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	Totalizer Meter Reading	.2418	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	General Comments		
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	ST000024	Structure	351-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Readings	Non LTC Totalizer Reading	432.00	kw
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	W0115	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	10.00	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	2	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	Follow-up Action Required?	n	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	General Comments		
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	General Comments		
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	LTC Totalizer Reading	16200.00	kw
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	Oil Temp Max	75	°C
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	Oil Temp Present	40	°C
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	Totalizer Meter Reading	.9000	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	Winding Temp Max	90	°C
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	Winding Temp Present	45	°C
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0363	WithLTC	060-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	General Comments		
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	General Comments		
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	773.76	kw
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	Oil Temp Max	48	°C
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	B0176	NonLTC	421-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	General Comments		
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	Vegetation	None	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	General Comments		
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	YD000343	Yard	507-Yard	Yard Patrol Inspection	Ambient Temp	50	*F
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	R1044	Regulator	607-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	9.0	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	12.0	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000535	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	11.0	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BK000535	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	9 Month Operations	2	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Amps A Ø	4.0	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Amps B Ø	5.0	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Amps C Ø	7.0	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Patrol Inspection	Bushing Condition	Good	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Fault Operations A Ø	0	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Fault Operations B Ø	0	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Fault Operations C Ø	0	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Fault Operations Ground	0	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Follow-up Action Required?	n	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Patrol Inspection	Foundation Condition	Good	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Patrol Inspection	General Comments		
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	General Comments	BFTC	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Patrol Inspection	Grounds in Place?	y	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Maintenance Operations	0	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Operations Counter AF	163	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Operations Counter AL	164	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Operations This Read Vac	1	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Switching Operations	1	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	BK001284	BreakerVacuum	351-0689	VCB Readings	Unknown Operations	0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	ST000346	Structure	507-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	General Comments		
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Ambient Temp	72	*F
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	General Comments		
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	ST000258	Structure	448-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	General Comments		
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Unknown Operations	0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Switching Operations	0	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	74	*F
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	General Comments		
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.9	VDC
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.6	VDC
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Regulator As Left Counter	81108	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Min Tap Position	15L	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	General Comments		
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	Vegetation	None	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	YD000253	Yard	438-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Bushing Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Amps C Ø	175.0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Amps B Ø	130.0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Amps A Ø	105.0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	9 Month Operations	1	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	General Comments		
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Foundation Condition	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Follow-up Action Required?	n	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Fault Operations Ground	0	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Fault Operations C Ø	0	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Fault Operations B Ø	0	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Fault Operations A Ø	0	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Bushing Condition	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Amps C Ø	9.0	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Amps B Ø	4.0	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Amps A Ø	5.0	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	9 Month Operations	9	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Unknown Operations	0	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Switching Operations	0	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Operations This Read Vac	1	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Operations Counter AL	183	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Operations Counter AF	183	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Operations This Read Vac	0	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Unknown Operations	0	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Switching Operations	0	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Operations This Read Vac	1	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Operations Counter AL	193	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Operations Counter AF	193	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	Maintenance Operations	1	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Patrol Inspection	Grounds in Place?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000553	BreakerVacuum	437-1801	VCB Readings	General Comments		
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Operations Counter AL	157	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Operations Counter AF	157	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Maintenance Operations	0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Grounds in Place?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	General Comments		
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Foundation Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Follow-up Action Required?	n	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Fault Operations Ground	0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Fault Operations C Ø	0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Fault Operations B Ø	0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Fault Operations A Ø	0	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	General Comments		
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	FE000250	Fence	438-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000789	BreakerVacuum	507-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	General Comments		
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	LTCC000753	LTCControl	507-2	LTC Control Insp	VRR Time Delay	30	Seconds
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	LTCC000753	LTCControl	507-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	LTCC000753	LTCControl	507-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	LTCC000753	LTCControl	507-2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	LTCC000753	LTCControl	507-2	LTC Control Insp	LTC Operation Checked?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	LTCC000753	LTCControl	507-2	LTC Control Insp	General Comments		
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	LTCC000753	LTCControl	507-2	LTC Control Insp	Follow-up Action Required?	n	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	LTCC000753	LTCControl	507-2	LTC Control Insp	All Connections OK?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Current Tap Position	8L	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Counter Readings	LTC Operations Since Last Insp	679	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	°C
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	45	°C
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Counter Readings	LTC Min Tap Position	7L	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Counter Readings	LTC Max Tap Position	12R	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Counter Readings	LTC Current Tap Position	2L	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Counter Readings	LTC As Left Counter	8520	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Counter Readings	LTC As Found Counter	8520	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Mechanism Patrol Inspection	General Comments		
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Counter Readings	General Comments		
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	LTCM000074	LTCMechanism	507-2	LTC Counter Readings	Follow-up Action Required?	n	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	LTCC000156	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	LTCC000156	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	LTCC000156	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	LTCC000156	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	LTCC000156	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	LTCC000156	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	CB0291	BreakerVacuum	726-0768	VCB Readings	9 Month Operations	8	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000794	BreakerSF6	507-608	GCB Patrol Inspection	Ambient Temperature	50	*F
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	General Comments		
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	ST000210	Structure	419-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Regulator As Left Counter	163127	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	General Comments		
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	BAT001186	Battery	825-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Min Tap Position	14L	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1100	psi
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	LTC Totalizer Reading	5371.20	kw
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	General Comments		
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	General Comments		
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1693.44	kw
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3528	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	General Comments		
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	General Comments		
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	ST000157	Structure	861-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	BAT001358	Battery	438-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	LTCC000156	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	LTCC000156	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1239	Regulator	782-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Regulator As Left Counter	64632	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R1307	Regulator	726-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	BCH001270	Charger	438-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.1	VDC
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	BCH001270	Charger	438-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.1	VDC
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	BCH001270	Charger	438-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	BCH001270	Charger	438-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	BCH001270	Charger	438-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	General Comments	Nitrogen blanket gauge not accurate	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	W0181	NonLTC	827-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-3.5	psi
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	Winding Temp Present	20	°C
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	Winding Temp Max	50	°C
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	Totalizer Meter Reading	.3730	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	Oil Temp Present	20	°C
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	TX000192	WithLTC	507-2	LTC Transformer Readings	Oil Temp Max	45	°C
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Operating Linkage OK?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Amps C Ø	0.0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Amps B Ø	0.0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Amps A Ø	0.0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	9 Month Operations	4	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Unknown Operations	0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Switching Operations	0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Operations This Read Vac	0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Operations Counter AL	146	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Operations Counter AF	146	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	General Comments		
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	FE000193	Fence	764-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Vegetation	None	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	General Comments		
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Maintenance Operations	0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Grounds in Place?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	General Comments		
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	General Comments		
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Foundation Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Follow-up Action Required?	n	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Fault Operations C Ø	0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Fault Operations B Ø	0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Fault Operations A Ø	0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Bushing Condition	Good	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	All Identified and Legible?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Counter Readings	Follow-up Action Required?	n	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Counter Readings	General Comments		
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Mechanism Patrol Inspection	General Comments		
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Counter Readings	LTC As Found Counter	57953	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Counter Readings	LTC As Left Counter	57953	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Counter Readings	LTC Current Tap Position	2L	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Counter Readings	LTC Max Tap Position	14R	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Counter Readings	LTC Min Tap Position	6L	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Counter Readings	LTC Operations Since Last Insp	875	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	S0011	LTCMechanism	507-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Foundation Condition	Good	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	General Comments		
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Ground Connections Intact?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	ST000197	Structure	Retired Distribution	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	LTC Max Tap Position	4L	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	LTC Min Tap Position	12L	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	LTC Operations Since Last Insp	574	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	General Comments		
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	ST000151	Structure	425-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Vegetation	None	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	General Comments		
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	YD000147	Yard	425-Yard	Yard Patrol Inspection	Ambient Temp	74	°F
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Bushing Condition	Good	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Amps C Ø	42.0	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Amps B Ø	42.0	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Amps A Ø	35.0	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	YD000152	Yard	861-Yard	Yard Patrol Inspection	Ambient Temp	37	°F
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Maintenance Operations	0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Grounds in Place?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	General Comments		
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	General Comments		
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Patrol Inspection	Foundation Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000785	BreakerVacuum	507-0865	VCB Readings	Follow-up Action Required?	n	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Unknown Operations	0	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Switching Operations	0	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Operations This Read Vac	1	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Operations Counter AL	208	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Operations Counter AF	208	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Maintenance Operations	1	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Grounds in Place?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	General Comments		
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	General Comments		
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Foundation Condition	Good	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Follow-up Action Required?	n	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Fault Operations Ground	0	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Fault Operations C Ø	0	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Fault Operations B Ø	0	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Fault Operations A Ø	0	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000551	BreakerVacuum	498-1541	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	Follow-up Action Required?	n	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Mechanism Patrol Inspection	General Comments		
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	General Comments	124.3	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	LTC As Found Counter	7190	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	LTC As Left Counter	7201	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	W0355	LTCMechanism	673-1	LTC Counter Readings	LTC Current Tap Position	7L	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	General Comments		
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	General Comments		
5/29/2020 12:27	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Readings	Oil Temp Max	60	°C
5/29/2020 12:27	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Readings	General Comments		
5/29/2020 12:27	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	n	
5/29/2020 12:27	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	Follow-up Action Required?	n	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	General Comments		
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Mechanism Patrol Inspection	General Comments		
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	LTC As Found Counter	170205	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	LTC As Left Counter	170208	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	LTC Current Tap Position	Neutral	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	LTC Max Tap Position	1R	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	LTC Min Tap Position	5L	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	LTC Operations Since Last Insp	224	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0230	LTCMechanism	116-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Follow-up Action Required?	n	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Fault Operations Ground	0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Fault Operations C Ø	0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Fault Operations B Ø	0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Fault Operations A Ø	0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Amps C Ø	0.0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Amps B Ø	0.0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Amps A Ø	0.0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	9 Month Operations	11	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Maintenance Operations	1	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Grounds in Place?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	General Comments		
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	General Comments		
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Foundation Condition	Good	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Follow-up Action Required?	n	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Fault Operations Ground	0	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Fault Operations C Ø	0	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Fault Operations B Ø	0	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Fault Operations A Ø	0	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Patrol Inspection	Bushing Condition	Good	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Amps C Ø	20.0	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Amps B Ø	28.0	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Amps A Ø	23.0	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BK000552	BreakerVacuum	498-1544	VCB Readings	9 Month Operations	3	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Regulator As Left Counter	25775	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R1449	Regulator	421-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
5/29/2020 12:27	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
5/29/2020 12:27	Distribution	Canal Quarterly Inspection	LT0029	WithLTC	C-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	120.00	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Switching Operations	0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Operations This Read Vac	0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Operations Counter AL	180	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Operations Counter AF	180	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Readings	Maintenance Operations	0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000788	BreakerVacuum	507-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Bushing Condition	Good	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Current Tap Position	10L	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Amps C Ø	125.0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Amps B Ø	120.0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Amps A Ø	115.0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	9 Month Operations	1	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Current Tap Position	9L	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	General Comments		
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Min Tap Position	16L	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1238	Regulator	782-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Regulator As Left Counter	94694	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	R1237	Regulator	782-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Unknown Operations	0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Switching Operations	0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Operations This Read Vac	0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Operations Counter AL	192	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000786	BreakerVacuum	507-0882	VCB Readings	Operations Counter AF	192	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	48.6	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	33.2	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	33.6	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	687	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	WX0344	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Unknown Operations	0	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Switching Operations	0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Operations This Read Vac	0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Operations Counter AL	148	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Operations Counter AF	148	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Maintenance Operations	0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Grounds in Place?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	General Comments		
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	General Comments		
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Foundation Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Follow-up Action Required?	n	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Fault Operations Ground	0	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	FE000235	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Fault Operations C Ø	0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Fault Operations B Ø	0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Fault Operations A Ø	0	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BK000787	BreakerVacuum	507-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Unknown Operations	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Switching Operations	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Operations This Read Vac	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Operations Counter AL	227	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Operations Counter AF	227	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Maintenance Operations	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Grounds in Place?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	General Comments		
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	General Comments		
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Foundation Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Follow-up Action Required?	n	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Fault Operations Ground	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Fault Operations C Ø	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Fault Operations B Ø	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Fault Operations A Ø	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Min Tap Position	11L	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Max Tap Position	5L	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	General Comments		
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	LTCC000805	LTCControl	401-1	LTC Control Insp	All Connections OK?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	General Comments		
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Readings	General Comments		
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	288.72	kw
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Readings	Oil Temp Max	50	°C
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Readings	Oil Temp Present	20	°C
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.2406	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Max Tap Position	10R	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Regulator As Left Counter	29241	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Regulator As Left Counter	117863	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Amps A Ø	50.0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	9 Month Operations	6	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	LTCC000709	LTCControl	060-5	LTC Control Insp	VRR Time Delay	30	Seconds
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	LTCC000709	LTCControl	060-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Counter Readings	Follow-up Action Required?	n	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Counter Readings	General Comments		
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Mechanism Patrol Inspection	General Comments		
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Counter Readings	LTC As Found Counter	260157	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Counter Readings	LTC As Left Counter	260157	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Counter Readings	LTC Current Tap Position	5L	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Counter Readings	LTC Max Tap Position	8R	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Counter Readings	LTC Min Tap Position	10L	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Counter Readings	LTC Operations Since Last Insp	920	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	LTCM000093	LTCMechanism	607-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	LTCC000709	LTCControl	060-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	LTCC000709	LTCControl	060-5	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	LTCC000709	LTCControl	060-5	LTC Control Insp	LTC Operation Checked?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	LTCC000709	LTCControl	060-5	LTC Control Insp	General Comments		
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	LTCC000709	LTCControl	060-5	LTC Control Insp	Follow-up Action Required?	n	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	LTCC000709	LTCControl	060-5	LTC Control Insp	All Connections OK?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	General Comments		
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Foundation Condition	Good	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Follow-up Action Required?	n	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Tank Leaks	None	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Regulator As Left Counter	175878	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Fault Operations Ground	0	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Fault Operations C Ø	0	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Fault Operations B Ø	0	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Fault Operations A Ø	0	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	LTCC000805	LTCControl	401-1	LTC Control Insp	Follow-up Action Required?	n	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	LTCC000805	LTCControl	401-1	LTC Control Insp	General Comments		
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	LTCC000805	LTCControl	401-1	LTC Control Insp	LTC Operation Checked?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	LTCC000805	LTCControl	401-1	LTC Control Insp	LTC Output Voltage Level	123.8	VAC
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	LTCC000805	LTCControl	401-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	LTCC000805	LTCControl	401-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	LTCC000805	LTCControl	401-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Min Tap Position	11L	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Max Tap Position	1L	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	General Comments		
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Unknown Operations	0	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Switching Operations	0	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Operations This Read Vac	0	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Operations Counter AL	294	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Operations Counter AF	294	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Maintenance Operations	0	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Grounds in Place?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	General Comments		
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Current Tap Position	9L	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	LTCC000806	LTCControl	438-1	LTC Control Insp	All Connections OK?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	LTCC000806	LTCControl	438-1	LTC Control Insp	Follow-up Action Required?	n	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	LTCC000806	LTCControl	438-1	LTC Control Insp	General Comments		
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	LTCC000806	LTCControl	438-1	LTC Control Insp	LTC Operation Checked?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	LTCC000806	LTCControl	438-1	LTC Control Insp	LTC Output Voltage Level	124.6	VAC
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	LTCC000806	LTCControl	438-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	LTCC000806	LTCControl	438-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	LTCC000806	LTCControl	438-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Patrol Inspection	Bushing Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Amps C Ø	60.0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000921	BreakerVacuum	060-0038	VCB Readings	Amps B Ø	60.0	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	9 Month Operations	8	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Amps A Ø	160.0	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Amps B Ø	160.0	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Amps C Ø	160.0	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Bushing Condition	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	67	*F
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	Retired Distribution	y	If no, which cells in comments
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Fault Operations A Ø	0	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Fault Operations B Ø	0	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Fault Operations C Ø	0	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Fault Operations Ground	0	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Follow-up Action Required?	n	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Foundation Condition	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	General Comments		
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	General Comments		
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	0.0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	0.0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	0.0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Regulator As Left Counter	38318	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Min Tap Position	Neutral	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Max Tap Position	5L	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	General Comments		
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	FE000415	Fence	607-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	General Comments		
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	R1350	Regulator	726-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	29.0	VDC
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	28.0	VDC
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BAT001137	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BCH001098	Charger	498-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	57.0	VDC
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BCH001098	Charger	498-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	57.0	VDC
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BCH001098	Charger	498-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	BCH001098	Charger	498-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R0831	Regulator	848-1 B	Regulator Patrol Inspection	Regulator As Left Counter	204808	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	General Comments	Found Reg at 131V and control fuse blown. Adjusted and repaired	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	R0254	Regulator	708-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Regulator As Left Counter	19415	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	General Comments		
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	C0205	NonLTC	419-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Grounds in Place?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Maintenance Operations	0	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Operations Counter AF	185	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	28.8	VDC
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	27.5	VDC
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BAT001136	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BCH001097	Charger	437-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.9	VDC
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BCH001097	Charger	437-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.9	VDC
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BCH001097	Charger	437-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Operations Counter AL	189	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Current Tap Position	7L	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	General Comments		
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Max Tap Position	3L	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Operations This Read Vac	4	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Switching Operations	4	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0173	BreakerVacuum	116-5	VCB Readings	Unknown Operations	0	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R0802	Regulator	848-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KR0085	Regulator	803-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BCH001097	Charger	437-Battery Charger	Battery Charger Patrol Insp	General Comments	Actual 56.4 at batt	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	General Comments		
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Operations Counter	248	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6756	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Readings	Oil Temp Present	25	°C
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	110.00	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	117.50	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2161.92	kw
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	General Comments	Needs Wildlife protection	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Readings	General Comments		
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	W0166	NonLTC	782-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Amps A Ø	22.0	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Amps B Ø	26.0	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Amps C Ø	28.0	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	General Comments		
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Operations Counter	3	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	KX0005	RecloserElectronic	775-2107	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Amps A Ø	26.0	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Regulator As Left Counter	343986	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Grounds in Place?	n	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	General Comments		
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Amps B Ø	26.0	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Amps C Ø	26.0	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	X0329	RecloserElectronic	082-3425	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	General Comments		
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	General Comments	Winding temp max may have vibrated up	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	LTC Totalizer Reading	2350.08	kw
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	Oil Temp Max	26	°C
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	Oil Temp Present	26	°C
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	Totalizer Meter Reading	.2448	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	Winding Temp Max	150	°C
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	Winding Temp Present	21	°C
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	117304	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Unknown Operations	0	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Switching Operations	0	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Operations This Read Vac	1	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Operations Counter AL	187	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Operations Counter AF	187	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Maintenance Operations	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Grounds in Place?	y	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Current Tap Position	5L	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Readings	General Comments		
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	General Comments	nitro gauge is broke	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Readings	Oil Temp Max	55	°C
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Readings	Oil Temp Present	20	°C
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	C0204	NonLTC	419-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1004	Regulator	351-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Readings	Follow-up Action Required?	n	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0231	WithLTC	116-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Amps C Ø	10.0	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Amps B Ø	10.0	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Amps A Ø	10.0	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	9 Month Operations	8	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Current Tap Position	7L	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Foundation Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	General Comments		
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	General Comments		
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Grounds in Place?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1091	Regulator	419-1 C	Regulator Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Maintenance Operations	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Operations Counter AF	279	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Operations Counter AL	279	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Operations This Read Vac	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Switching Operations	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Unknown Operations	0	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	LTCC000705	LTCCControl	060-6	LTC Control Insp	VRR Time Delay	30	Seconds
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	LTCC000705	LTCCControl	060-6	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	LTCC000705	LTCCControl	060-6	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	LTCC000705	LTCCControl	060-6	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	LTCC000705	LTCCControl	060-6	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	LTCC000705	LTCCControl	060-6	LTC Control Insp	LTC Operation Checked?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	LTCC000705	LTCCControl	060-6	LTC Control Insp	General Comments		
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	LTCC000705	LTCCControl	060-6	LTC Control Insp	Follow-up Action Required?	n	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	LTCC000705	LTCCControl	060-6	LTC Control Insp	All Connections OK?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Min Tap Position	1R	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Max Tap Position	16R	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	General Comments		
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Current Tap Position	4R	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	9 Month Operations	8	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Amps A Ø	220.0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Amps B Ø	220.0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Amps C Ø	220.0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Bushing Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Fault Operations A Ø	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Fault Operations B Ø	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Fault Operations C Ø	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Fault Operations Ground	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	K0041	BreakerVacuum	060-0106	VCB Readings	Follow-up Action Required?	n	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BB0484	BreakerVacuum	884-2176	VCB Patrol Inspection	Bushing Condition	Good	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	General Comments		
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	General Comments		
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	LTC Totalizer Reading	6675.84	kw
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	Oil Temp Max	60	°C
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	Oil Temp Present	35	°C
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	General Comments		
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	Totalizer Meter Reading	.6954	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Operations Counter	948	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	General Comments		
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Current Tap Position	1R	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	R0751	Regulator	448-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Regulator As Left Counter	305427	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	40	°C
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	28	°C
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Min Tap Position	5L	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1006	Regulator	351-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps A Ø	0.0	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps B Ø	0.0	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps C Ø	0.0	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	WX0242	RecloserElectronic	912-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	B0143	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	S0042	WithLTC	574-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Follow-up Action Required?	n	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Fault Operations Ground	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Fault Operations C Ø	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Fault Operations B Ø	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Fault Operations A Ø	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Bushing Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Amps C Ø	120.0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Amps B Ø	120.0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Amps A Ø	120.0	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Readings	Totalizer Meter Reading	.7728	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	600	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Regulator As Left Counter	27371	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	463.68	kw
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	General Comments	Gauges unreadable/broken	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Min Tap Position	12L	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Amps C Ø	155.0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Bushing Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Fault Operations A Ø	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Fault Operations B Ø	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Fault Operations C Ø	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Follow-up Action Required?	n	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Foundation Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	General Comments		
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	General Comments		
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Grounds in Place?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Maintenance Operations	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Operations Counter AF	213	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Operations Counter AL	213	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Operations This Read Vac	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Switching Operations	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Unknown Operations	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Unknown Operations	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Switching Operations	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Operations This Read Vac	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Operations Counter AL	317	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Operations Counter AF	317	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Maintenance Operations	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Grounds in Place?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	General Comments		
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	General Comments		
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Patrol Inspection	Foundation Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	General Comments		
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	9 Month Operations	2	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Amps A Ø	10.0	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Amps B Ø	10.0	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Amps C Ø	10.0	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Bushing Condition	Good	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Readings	Totalizer Meter Reading	.0576	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Readings	Oil Temp Present	32	°C
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	chg 1st quarter
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	Follow-up Action Required?	n	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Readings	General Comments		
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0466	BreakerVacuum	060-0033	VCB Readings	9 Month Operations	10	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	B0173	NonLTC	708-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	General Comments		
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	FE000503	Fence	775-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	DB0043	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	FE000833	Fence	507-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Regulator As Left Counter	111687	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Min Tap Position	14L	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Max Tap Position	5L	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	General Comments		
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Current Tap Position	11L	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	General Comments		
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Max Tap Position	6R	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Current Tap Position	7L	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	General Comments		
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Regulator As Left Counter	128845	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1089	Regulator	419-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Amps A Ø	76.0	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Amps B Ø	74.0	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Amps C Ø	84.0	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	General Comments		
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Operations Counter	229	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	KX0127	RecloserElectronic	574-1712	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	R1090	Regulator	419-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Bushing Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Fault Operations A Ø	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Fault Operations B Ø	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Fault Operations C Ø	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Fault Operations Ground	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Follow-up Action Required?	n	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Foundation Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	General Comments		
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	General Comments		
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Grounds in Place?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Maintenance Operations	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Operations Counter AF	191	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Operations Counter AL	191	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Operations This Read Vac	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Switching Operations	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Unknown Operations	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	9 Month Operations	4	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Amps A Ø	160.0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000985	BreakerVacuum	060-0126	VCB Readings	Amps B Ø	165.0	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Current Tap Position	9L	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	General Comments		
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	R1158	Regulator	848-1 C	Regulator Patrol Inspection	Max Tap Position	6L	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Readings	Oil Temp Present	30	°C
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Readings	Oil Temp Max	90	°C
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Readings	General Comments		
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	General Comments		
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	General Comments		
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BAT001248	Battery	507-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0128	NonLTC	448-2 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	9 Month Operations	7	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Amps A Ø	90.0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Amps B Ø	95.0	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Regulator As Left Counter	14153	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	RG000133	Regulator	803-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BK000984	BreakerVacuum	060-0118	VCB Readings	Amps C Ø	95.0	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	224	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Operations Counter	0	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	General Comments		
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Regulator As Left Counter	66455	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Max Tap Position	16L	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	General Comments		
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	LTCC000798	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	LTCC000798	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	LTCC000798	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	LTCC000798	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	LTCC000798	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	LTCC000798	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	LTCC000798	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	LTCC000798	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Current Tap Position	13L	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	173	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	202	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Amps C Ø	15.4	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Unknown Operations	0	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	LTCC000785	LTCControl	673-1	LTC Control Insp	Follow-up Action Required?	n	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	LTCC000785	LTCControl	673-1	LTC Control Insp	All Connections OK?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Regulator As Left Counter	33113	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Regulator As Left Counter	39544	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Min Tap Position	4L	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Max Tap Position	16L	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	General Comments		
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Current Tap Position	12L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1537	Regulator	775-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	General Comments		
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	253	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	186	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Amps C Ø	20.3	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Amps B Ø	14.6	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	WX0439	RecloserHydraulic	425-1509	Recloser Hydraulic Patrol Inspection	Amps A Ø	23.2	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	LTC000203	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	46	*F
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	29.4	VDC
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	28.0	VDC
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	BAT001277	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	BCH001219	Charger	782-Battery Bank	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.200	millivolts
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	BCH001219	Charger	782-Battery Bank	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	BCH001219	Charger	782-Battery Bank	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	BCH001219	Charger	782-Battery Bank	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	BCH001219	Charger	782-Battery Bank	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	BCH001219	Charger	782-Battery Bank	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	BCH001219	Charger	782-Battery Bank	Battery Charger Patrol Insp	General Comments	Actual 57.5Vdc	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	BCH001222	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	BCH001222	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	BCH001222	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	BCH001222	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	BCH001222	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	BCH001222	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	9 Month Operations	1	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	82	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	82	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0307	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	R1535	Regulator	775-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Switching Operations	0	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Operations This Read Vac	0	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Operations Counter AL	192	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Operations Counter AF	192	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Maintenance Operations	0	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Grounds in Place?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	General Comments		
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Foundation Condition	Good	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Follow-up Action Required?	n	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Fault Operations Ground	0	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Fault Operations C Ø	0	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Fault Operations B Ø	0	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Fault Operations A Ø	0	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Patrol Inspection	Bushing Condition	Good	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Amps C Ø	122.0	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Amps B Ø	114.0	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Amps A Ø	112.0	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	BK000648	BreakerVacuum	726-0767	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Amps B Ø	15.7	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	Amps A Ø	17.9	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	WX0422	RecloserHydraulic	425-1508	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	189	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	LTCC000203	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	LTCC000203	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	LTCC000203	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	LTCC000203	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	LTCC000203	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	LTCC000203	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	LTCC000203	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	LTCC000203	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Max Tap Position	7R	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	General Comments		
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Current Tap Position	3R	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Fault Operations A Ø	0	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Fault Operations B Ø	0	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Fault Operations C Ø	0	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Fault Operations Ground	0	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Follow-up Action Required?	n	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BCH001189	Charger	507-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BCH001189	Charger	507-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BCH001189	Charger	507-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BCH001189	Charger	507-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BCH001189	Charger	507-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.2	amps
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BCH001189	Charger	507-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BCH001189	Charger	507-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	General Comments		
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	General Comments		
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	LTC Totalizer Reading	1236.60	kw
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	Oil Temp Max	65	°C
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	Oil Temp Present	55	°C
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	Totalizer Meter Multiplier	1800	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	Totalizer Meter Reading	.6870	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	138.24	kw
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	Winding Temp Max	70	°C
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	Winding Temp Present	30	°C
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0403	WithLTC	060-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Readings	General Comments		
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	General Comments		
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	0985	NonLTC	351-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Regulator As Left Counter	36043	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	R1151	Regulator	637-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	General Comments	bus needs wildlife protection and existing wildlife protection needs to be reworked.	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Vegetation	None	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	General Comments		
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	YD000236	Yard	803-Yard	Yard Patrol Inspection	Ambient Temp	67	*F
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	General Comments		
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	FE000238	Fence	803-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	LTCC000785	LTCControl	673-1	LTC Control Insp	LTC Operation Checked?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	LTCC000785	LTCControl	673-1	LTC Control Insp	General Comments		
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	General Comments		
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Max Tap Position	6R	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Min Tap Position	4L	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1513	Regulator	082-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	BCH001189	Charger	507-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Foundation Condition	Good	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	General Comments		
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	General Comments		
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Grounds in Place?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Maintenance Operations	0	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Operations Counter AF	212	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Operations Counter AL	212	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Operations This Read Vac	0	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Switching Operations	0	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	FE000205	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	LTCC000785	LTCControl	673-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	LTCC000785	LTCControl	673-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0169	BreakerVacuum	803-0818	VCB Readings	Unknown Operations	0	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	LTCC000785	LTCControl	673-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	LTCC000785	LTCControl	673-1	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	ST000243	Structure	803-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Vegetation	None	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	YD000233	Yard	782-Yard	Yard Patrol Inspection	Ambient Temp	46	*F
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Regulator As Left Counter	21863	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Min Tap Position	12L	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Max Tap Position	2L	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	General Comments		
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Current Tap Position	9L	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1394	Regulator	498-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	General Comments		
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BCH001249	Charger	607-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BCH001249	Charger	607-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BCH001249	Charger	607-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BCH001249	Charger	607-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BCH001249	Charger	607-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BCH001249	Charger	607-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BCH001249	Charger	607-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	9 Month Operations	4	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Amps A Ø	92.0	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Amps B Ø	115.0	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Amps C Ø	56.0	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Bushing Condition	Good	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Fault Adjusted Amps A Phase V	5.59	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Regulator As Left Counter	45396	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Max Tap Position	5R	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	General Comments		
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R1395	Regulator	764-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	General Comments		
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	LTC Totalizer Reading	6451.20	kw
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	Oil Temp Max	20	°C
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	Oil Temp Present	20	°C
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	Totalizer Meter Reading	.4480	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Switching Operations	1	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Unknown Operations	1	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Min Tap Position	13L	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Max Tap Position	8R	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	General Comments		
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	Winding Temp Max	30	°C
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	Winding Temp Present	30	°C
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Unknown Operations	0	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Switching Operations	0	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Regulator As Left Counter	37722	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Fault Adjusted Amps B Phase V	5.59	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Fault Adjusted Amps C Phase V	5.59	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Fault Operations A Ø	0	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Fault Operations B Ø	0	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Fault Operations C Ø	0	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Fault Operations Ground	0	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Follow-up Action Required?	n	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Foundation Condition	Good	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	General Comments		
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	General Comments	needs some varmint guardng 3 hoods missing on breaker	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Grounds in Place?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Maintenance Operations	1	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Operations Counter AF	176	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Operations Counter AL	176	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Readings	Operations This Read Vac	3	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	BK000725	BreakerVacuum	421-1526	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Readings	Oil Temp Present	22	°C
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/6/2020 11:40	Distribution	West Hickman Quarterly Inspection	S0011	WithLTC	507-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	General Comments		
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	General Comments		
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	LTC Totalizer Reading	5817.60	kw
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	Oil Temp Max	10	°C
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	Oil Temp Present	10	°C
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	Totalizer Meter Reading	.6060	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	Follow-up Action Required?	n	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	General Comments	Barbed wire rusted no strands broken	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	Oil Temp Present	30	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	General Comments		
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	General Comments		
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	Oil Temp Max	45	°C
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	Oil Temp Present	23	°C
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1746.72	kw
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-5	psi
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	Winding Temp Max	25	°C
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	General Comments		
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	Winding Temp Present	25	°C
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	General Comments		
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	C0445	WithLTC	607-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	General Comments		
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	FE000148	Fence	425-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	55	°F
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	General Comments		
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BAT001310	Battery	607-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	ST000241	Structure	782-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	General Comments		
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Mechanism Patrol Inspection	General Comments		
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	LTC As Found Counter	122659	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	LTC As Left Counter	122659	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	LTC Current Tap Position	7L	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	LTC Max Tap Position	1L	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	LTC Min Tap Position	12L	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	LTC Operations Since Last Insp	1313	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	B0403	LTCMechanism	060-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	Amps A Ø	22.8	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	General Comments		
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	Operations Counter	95	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	KX0140	RecloserHydraulic	637-0812 A	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Maintenance Operations	0	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Operations Counter AF	185	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Operations Counter AL	185	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Operations This Read Vac	0	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Switching Operations	0	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Unknown Operations	0	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	FE000237	Fence	448-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	TX000069	NonLTC	912-Offline-Distribution	NonLTC Transformer Readings	General Comments		
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	9 Month Operations	4	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	General Comments		
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Min Tap Position	11L	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Regulator As Left Counter	57872	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	General Comments		
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Regulator As Left Counter	63607	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Regulator As Left Counter	60830	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1262	Regulator	425-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Switching Operations	1	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Operations This Read Vac	1	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Operations Counter AL	162	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Operations Counter AF	161	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Maintenance Operations	0	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Grounds in Place?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	General Comments		
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Foundation Condition	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Follow-up Action Required?	n	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Fault Operations Ground	0	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Fault Operations C ∅	0	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Fault Operations B ∅	0	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Fault Operations A ∅	0	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Patrol Inspection	Bushing Condition	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Amps C ∅	35.0	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Amps B ∅	54.0	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Amps A ∅	33.0	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	General Comments		
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Amps A Ø	51.0	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Amps B Ø	33.0	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Amps C Ø	35.0	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	General Comments		
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Operations Counter	155	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	KX0128	RecloserElectronic	574-1711	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	30.00	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	Winding Temp Present	21	°C
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	Winding Temp Max	80	°C
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	Totalizer Meter Reading	.4326	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	O0230	WithLTC	116-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	FE000229	Fence	673-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1263	Regulator	425-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Amps A Ø	105.0	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	9 Month Operations	2	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	WX0180	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	WX0180	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	1L	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments		
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	10R	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	7L	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	177429	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	R1031	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	WX0180	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	1354	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	WX0180	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	WX0180	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments	off-line	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	WX0180	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	WX0180	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	WX0180	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	WX0180	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	WX0180	RecloserHydraulic	SSC-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	ST000547	Structure	775-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3790	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	Oil Temp Max	35	°C
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	909.60	kw
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	General Comments		
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	General Comments		
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	S0067	NonLTC	775-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Operations Counter AF	186	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Maintenance Operations	1	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Grounds in Place?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	General Comments		
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	General Comments		
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Foundation Condition	Good	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Operations This Read Vac	1	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Operations Counter AL	186	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Current Tap Position	8L	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Current Tap Position	7L	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1393	Regulator	498-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	General Comments		
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	ST000172	Structure	113-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	General Comments		
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Max Tap Position	2L	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Min Tap Position	13L	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Regulator As Left Counter	43768	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	R1452	Regulator	498-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	General Comments		
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Ambient Temp	67	*F
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Amps A Ø	15.0	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	General Comments	found at 170.2V adj needed for hi band	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Max Tap Position	7R	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Regulator As Left Counter	479830	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Current Tap Position	6L	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	BK000197	BreakerVacuum	116-0686	VCB Readings	Unknown Operations	0	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	General Comments		
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	R1261	Regulator	425-1 A	Regulator Patrol Inspection	Min Tap Position	10L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Follow-up Action Required?	n	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Fault Operations Ground	0	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Fault Operations C Ø	0	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Fault Operations B Ø	0	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Fault Operations A Ø	0	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	LTCC000553	LTCControl	884-1	LTC Control Insp	All Connections OK?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	LTCC000553	LTCControl	884-1	LTC Control Insp	Follow-up Action Required?	n	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	LTCC000553	LTCControl	884-1	LTC Control Insp	General Comments		
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	LTCC000553	LTCControl	884-1	LTC Control Insp	LTC Operation Checked?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	LTCC000553	LTCControl	884-1	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	LTCC000553	LTCControl	884-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	LTCC000553	LTCControl	884-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	LTCC000553	LTCControl	884-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Patrol Inspection	Bushing Condition	Good	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Amps C Ø	65.0	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	K0071	BreakerVacuum	438-1714	VCB Readings	Amps B Ø	65.0	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BCH001057	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BCH001057	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BCH001057	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BCH001057	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BCH001057	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BCH001057	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Vegetation	None	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	General Comments		
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	YD000324	Yard	637-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	R1258	Regulator	708-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	WX0478	RecloserHydraulic	861-1524 A	Recloser Hydraulic Patrol Inspection	Operations Counter	293	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	General Comments		
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	General Comments		
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2612.40	kw
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	27.50	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	Totalizer Meter Reading	2.1770	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Regulator As Left Counter	154257	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Min Tap Position	4L	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Max Tap Position	3R	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	General Comments		
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Current Tap Position	1R	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	9 Month Operations	2	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	W0323	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	W0323	LTCMechanism	Retired Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	W0323	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	W0323	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Operations Since Last Insp	2954	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	W0323	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Min Tap Position	13L	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	W0323	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Max Tap Position	Neutral	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	W0323	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Current Tap Position	4L	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	W0323	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	W0323	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Left Counter	27466	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	W0323	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Found Counter	27455	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	W0323	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	General Comments		
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	W0323	LTCMechanism	Retired Distribution	LTC Counter Readings	General Comments		
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	W0323	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	W0323	LTCMechanism	Retired Distribution	LTC Counter Readings	Follow-up Action Required?	n	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Ambient Temp	38	*F
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	General Comments		
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Vegetation	None	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	YD000191	Yard	764-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	R1338	Regulator	351-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	B0201	NonLTC	607-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	General Comments		
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	General Comments		
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Ambient Temp	55	*F
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	High	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	207.36	kw
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	105.00	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Readings	Oil Temp Present	30	°C
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Readings	Oil Temp Max	40	°C
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	110.00	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	115.00	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Readings	General Comments		
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	General Comments		
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0129	NonLTC	448-2 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	9 Month Operations	3	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Amps A Ø	115.0	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Amps B Ø	100.0	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Unknown Operations	0	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Switching Operations	0	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Operations This Read Vac	1	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Operations Counter AL	170	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Operations Counter AF	170	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Maintenance Operations	1	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Grounds in Place?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	General Comments	1- trip check	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	General Comments		
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Current Tap Position	6L	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	General Comments		
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Min Tap Position	12L	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Foundation Condition	Good	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Follow-up Action Required?	n	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Fault Operations Ground	0	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Fault Operations C Ø	0	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Fault Operations B Ø	0	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Fault Operations A Ø	0	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol I Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	Neutral	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	Neutral	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Unknown Operations	0	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Switching Operations	0	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Operations This Read Vac	1	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Operations Counter AL	210	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Operations Counter AF	210	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Maintenance Operations	1	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Grounds in Place?	y	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	General Comments	1- OSD XFMR	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	General Comments		
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Foundation Condition	Good	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Follow-up Action Required?	n	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Fault Operations Ground	0	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Fault Operations C Ø	0	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Fault Operations B Ø	0	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Fault Operations A Ø	0	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Patrol Inspection	Bushing Condition	Good	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Amps C Ø	23.0	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Amps B Ø	18.0	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments	Head not operational	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	Neutral	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Amps A Ø	18.0	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	General Comments		
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Max Tap Position	6R	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Min Tap Position	8L	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	General Comments		
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	General Comments		
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Foundation Condition	Good	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Follow-up Action Required?	n	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Fault Operations Ground	0	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Fault Operations C Ø	0	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Fault Operations B Ø	0	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Fault Operations A Ø	0	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Regulator As Left Counter	60034	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Tank Leaks	None	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	R1368	Regulator	861-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Patrol Inspection	Bushing Condition	Good	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Amps C Ø	37.0	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Amps B Ø	28.0	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Amps A Ø	24.0	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	KB0137	BreakerVacuum	764-1531	VCB Readings	9 Month Operations	2	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	General Comments		
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Unknown Operations	0	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Switching Operations	0	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Operations This Read Vac	1	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Operations Counter AL	165	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Operations Counter AF	165	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Maintenance Operations	1	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Grounds in Place?	y	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	General Comments	1- OSD XFMR	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	General Comments		
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Foundation Condition	Good	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Follow-up Action Required?	n	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Fault Operations Ground	0	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Fault Operations C Ø	0	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	9 Month Operations	7	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Fault Operations B Ø	0	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Fault Operations A Ø	0	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Patrol Inspection	Bushing Condition	Good	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Amps C Ø	34.0	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Amps B Ø	42.0	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Amps A Ø	33.0	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000907	BreakerVacuum	673-1703	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Unknown Operations	3	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Switching Operations	0	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Operations This Read Vac	4	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Operations Counter AL	168	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Operations Counter AF	168	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Maintenance Operations	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Grounds in Place?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	General Comments		
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	General Comments		
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Foundation Condition	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Follow-up Action Required?	n	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Fault Operations Ground	0	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Fault Operations C Ø	0	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Fault Operations B Ø	0	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Fault Operations A Ø	0	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Fault Adjusted Amps C Phase V	3.00	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Fault Adjusted Amps B Phase V	3.00	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Fault Adjusted Amps A Phase V	3.00	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Patrol Inspection	Bushing Condition	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Amps C Ø	57.0	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Amps B Ø	41.0	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Amps A Ø	41.0	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	BK000610	BreakerVacuum	437-1802	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BK000908	BreakerVacuum	673-1704	VCB Readings	9 Month Operations	2	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	R0252	Regulator	708-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	R0998	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Positive DC Ground	23.0	VDC
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.0	VDC
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	General Comments		
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	66	*F
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	BAT001112	Battery	775-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	General Comments		
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	9 Month Operations	2	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	9 Month Operations	1	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Amps A Ø	84.0	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Amps B Ø	86.0	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Amps C Ø	89.0	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Bushing Condition	Good	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Fault Operations A Ø	0	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3770	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Fence Ties Intact?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	General Comments		
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000212	Fence	421-Fence 4kv	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	Totalizer Meter Reading	.9246	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	Totalizer Meter Multiplier	2400	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	Oil Temp Present	55	°C
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	Oil Temp Max	62	°C
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	LTC Totalizer Reading	2219.04	kw
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	General Comments		
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	General Comments		
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	C0394	WithLTC	884-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	General Comments		
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	27.9	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.8	VDC
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	BCH001053	Charger	082-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.3	VDC
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	BCH001053	Charger	082-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.3	VDC
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	BCH001053	Charger	082-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	BCH001053	Charger	082-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	BCH001053	Charger	082-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	S0062	NonLTC	082-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	Totalizer Meter Reading	.7278	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	W0361	NonLTC	498-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	63	*F
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	BAT001083	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Fault Operations B Ø	0	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Fault Operations C Ø	0	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Fault Operations Ground	0	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	Follow-up Action Required?	n	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Foundation Condition	Good	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	General Comments		
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Readings	General Comments		
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Grounds in Place?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	BK000719	BreakerVacuum	782-0822	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Amps A Ø	12.7	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Amps B Ø	10.1	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Amps C Ø	5.8	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	General Comments		
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Operations Counter	790	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/6/2020 11:10	Distribution	St Charles KU Quarterly Inspection	WX0333	RecloserHydraulic	827-1553	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	877	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Amps A Ø	15.4	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Amps B Ø	18.7	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Amps C Ø	15.1	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	804	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	1220	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	General Comments		
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/6/2020 14:03	Distribution	Fredonia Quarterly Inspection	WX0420	RecloserHydraulic	425-1507	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	ST000260	Structure	438-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Fault Operations A Ø	0	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Fault Operations B Ø	0	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Fault Operations C Ø	0	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Fault Operations Ground	0	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Follow-up Action Required?	n	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	General Comments		
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	General Comments		
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Grounds in Place?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Maintenance Operations	0	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Operations Counter AF	186	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Operations Counter AL	188	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Operations This Read Vac	2	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Switching Operations	2	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Unknown Operations	0	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	Oil Temp Max	0	°C
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	Oil Temp Present	30	°C
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Bad	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	B0074	NonLTC	637-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.0864	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Patrol Inspection	Bushing Condition	Good	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Regulator As Left Counter	24502	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	R0714	Regulator	421-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Amps C Ø	167.0	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Amps B Ø	183.0	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Amps A Ø	173.0	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	199	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Amps A Ø	8.1	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Amps B Ø	8.0	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Amps C Ø	90.0	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Bushing Condition	Good	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Fault Operations A Ø	0	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Fault Operations B Ø	0	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Fault Operations C Ø	0	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Fault Operations Ground	0	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Follow-up Action Required?	n	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Foundation Condition	Good	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	General Comments		
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	General Comments		
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Grounds in Place?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Maintenance Operations	0	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Operations Counter AF	191	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Operations Counter AL	193	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Operations This Read Vac	3	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Switching Operations	3	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001100	BreakerVacuum	607-0142	VCB Readings	Unknown Operations	0	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	9 Month Operations	2	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Amps A Ø	25.0	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Amps B Ø	25.0	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Amps C Ø	15.0	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	BK001101	BreakerVacuum	607-0143	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	General Comments		
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Vegetation	None	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	General Comments		
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	General Comments		
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	3619.20	kw
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	C0481	NonLTC	848-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Amps C Ø	7.3	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	232	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	194	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	WX0453	RecloserHydraulic	448-1546	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6102	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	4393.44	kw
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.5	psi
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	General Comments		
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	General Comments		
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	BK000492	BreakerVacuum	438-1715	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	LTCC000233	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	LTCC000233	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	LTCC000233	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	LTCC000233	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	LTCC000233	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	LTCC000233	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	LTCC000233	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	LTCC000233	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	KT0037	NonLTC	803-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	YD000354	Yard	607-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Vegetation	None	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Yard Lights Working?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	DB0045	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	CAP000025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	CAP000025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Cap bank CT in Good Condition?	y	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	CAP000025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	CAP000025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Bushing Condition	Good	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	CAP000025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	All Connections OK?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	CAP000023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Warning Signs OK?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	CAP000023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	CAP000023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Tank Leaks	None	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	CAP000023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	General Comments		
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	CH000057	ControlHouse	113-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Vegetation	None	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	General Comments		
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Operations Counter AF	153	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Operations Counter AL	153	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Operations This Read Vac	0	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Switching Operations	0	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	YD000430	Yard	848-Yard	Yard Patrol Inspection	Ambient Temp	66	*F
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	General Comments		
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	FE000426	Fence	848-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Unknown Operations	0	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	General Comments		
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Amps A Ø	0.0	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	9 Month Operations	15	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	BCH000619	Charger	775-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	BCH000619	Charger	775-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	BCH000619	Charger	775-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	BCH000619	Charger	775-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	BCH000619	Charger	775-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Ambient Temp	66	*F
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	General Comments		
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Ambient Temp	55	*F
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BAT001415	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BAT001415	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	50	*F
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BAT001415	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BAT001415	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BAT001415	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	25	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	CAP000023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	CAP000023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	n	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	General Comments		
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Vegetation	None	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	YD000161	Yard	113-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	RC001331	RecloserHydraulic	861-1523 A	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BAT001415	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BAT001415	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BAT001415	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BAT001415	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BAT001415	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	26.0	VDC
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BAT001415	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	27.0	VDC
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BAT001415	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	BAT001415	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	RC001331	RecloserHydraulic	861-1523 A	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	RC001331	RecloserHydraulic	861-1523 A	Recloser Hydraulic Patrol Inspection	Operations Counter	36	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	CAP000023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Foundation Condition	Good	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	CAP000023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	CAP000023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Grounds in Place?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	CAP000023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	General Comments		Caps need attention, rusting at ground connections on many caps and around bushings
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	BAT001416	Battery	351-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	BAT001416	Battery	351-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	78	*F
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	General Comments		
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	ST000432	Structure	726-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Vegetation	None	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	General Comments		
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	FE000164	Fence	113-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	YD000429	Yard	726-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BAT000548	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BAT000548	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BAT000548	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BAT000548	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BAT001381	Battery	884-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BAT001381	Battery	884-Battery Bank	Battery Patrol Inspection	Positive DC Ground	25.0	VDC
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	CAP000025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	CAP000025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	CAP000025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Grounds in Place?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	CAP000025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	General Comments	1 fuse blown on middle phase	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	CAP000025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Fuses Blown? Y / N		
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	CAP000025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	BAT001493	Battery	726-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	General Comments		
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Platform/Walkway/Railing OK?	y	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	CAP000025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Current Tap Position	3R	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	CAP000025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	CAP000025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	CAP000025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Capacitor Condition	Good	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	General Comments	123.7	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Max Tap Position	7R	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Min Tap Position	3L	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	BAT001493	Battery	726-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	BAT001493	Battery	726-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	BAT001493	Battery	726-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	BAT001493	Battery	726-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	BAT001493	Battery	726-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	BAT001493	Battery	726-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Mechanism Patrol Inspection	General Comments		
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Counter Readings	General Comments		
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Counter Readings	Follow-up Action Required?	n	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Fault Operations A Ø	0	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Fault Operations B Ø	0	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Fault Operations C Ø	0	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Fault Operations Ground	0	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Fault Operations B Ø	0	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Fault Operations A Ø	0	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Counter Readings	Follow-up Action Required?	n	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	BCH000310	Charger	421-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	56.0	VDC
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	BAT001493	Battery	726-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	66	*F
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	BCH000310	Charger	421-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	BCH000310	Charger	421-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	CAP000025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Warning Signs OK?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	CAP000025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	CAP000025	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Tank Leaks	None	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	General Comments		
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BAT000548	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BAT000548	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	66	*F
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BAT000548	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BCH001309	Charger	884-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BCH001309	Charger	884-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.9	amps
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BCH001309	Charger	884-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BCH001309	Charger	884-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BCH001309	Charger	884-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BAT000548	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BAT000548	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BAT000548	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BAT001381	Battery	884-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BAT000548	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	General Comments		
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Bushing Condition	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Amps C Ø	0.0	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Amps B Ø	0.0	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Ambient Temp	38	*F
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Clear of Obstacles?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Clear of Trash?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000212	Yard	421-Yard 4kv	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT000472	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT000472	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT000472	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Follow-up Action Required?	n	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Patrol Inspection	Foundation Condition	Good	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Patrol Inspection	General Comments		
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	General Comments		
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Patrol Inspection	Grounds in Place?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Maintenance Operations	0	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Regulator As Left Counter	35896	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	General Comments		
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	ST000198	Structure	764-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	LTCC000110	LTCControl	607-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	LTCC000110	LTCControl	607-2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	LTCC000110	LTCControl	607-2	LTC Control Insp	LTC Operation Checked?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	LTCC000110	LTCControl	607-2	LTC Control Insp	General Comments		
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	LTCC000110	LTCControl	607-2	LTC Control Insp	Follow-up Action Required?	n	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	LTCC000110	LTCControl	607-2	LTC Control Insp	All Connections OK?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT000472	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 16:33	Distribution	Crab Orchard Quarterly Inspection	BCH000619	Charger	775-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	ST000433	Structure	848-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Vegetation	None	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	General Comments		
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BAT000548	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BAT000548	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	Totalizer Meter Reading	.5614	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	300	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	Oil Temp Present	20	°C
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	Oil Temp Max	45	°C
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	General Comments	2 washouts under fence left of entrance and back	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	General Comments		
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	General Comments		
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Ambient Temp	72	°F
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	General Comments		
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BAT001381	Battery	884-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BAT001381	Battery	884-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	66	°F
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BAT001381	Battery	884-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	Follow-up Action Required?	n	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	General Comments		
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Mechanism Patrol Inspection	General Comments		
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	ST000206	Structure	708-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	YD000199	Yard	708-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	General Comments	counter not counting every step	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	LTC As Found Counter	2014	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	LTC As Left Counter	2014	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	LTC Current Tap Position	11L	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	LTC Max Tap Position	7L	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	LTC Min Tap Position	16L	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	LTC Operations Since Last Insp	294	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	W0289	LTCMechanism	438-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	General Comments		
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	LTC Totalizer Reading	2592.00	kw
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	Oil Temp Max	60	°C
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	Oil Temp Present	50	°C
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BCH001365	Charger	848-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BCH001365	Charger	848-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BCH001365	Charger	848-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BCH001365	Charger	848-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BCH001365	Charger	848-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BCH001365	Charger	848-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BCH001365	Charger	848-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BCH001365	Charger	848-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	Totalizer Meter Reading	.8100	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	20.0	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	BCH001333	Charger	351-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	BCH001333	Charger	351-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	General Comments		
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Vegetation	None	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/6/2020 12:17	Distribution	Claxton Quarterly Inspection	FE000200	Fence	708-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	ST000232	Structure	498-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Vegetation	None	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	General Comments		
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	YD000225	Yard	498-Yard	Yard Patrol Inspection	Ambient Temp	57	°F
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	168.42	kw
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	General Comments		
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	General Comments		
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	General Comments		
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	0944	NonLTC	861-2 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Ambient Temp	75	°F
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	20.0	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	20.0	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	YD000214	Yard	448-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	BCH001333	Charger	351-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	BCH001333	Charger	351-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	BCH001333	Charger	351-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT000472	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT000472	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT000472	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	General Comments		
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	FE000204	Fence	419-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	YD000203	Yard	579-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	YD000203	Yard	579-Yard	Yard Patrol Inspection	General Comments		
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	YD000203	Yard	579-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Ambient Temp	62	°F
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	ST000330	Structure	637-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	BCH000423	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	BCH000423	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	55.1	VDC
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	YD000203	Yard	579-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT000472	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	YD000203	Yard	579-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	YD000203	Yard	579-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	YD000203	Yard	579-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	YD000203	Yard	579-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	YD000203	Yard	579-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	YD000203	Yard	579-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	YD000203	Yard	579-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	YD000203	Yard	579-Yard	Yard Patrol Inspection	Ambient Temp	39	*F
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Vegetation	None	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	9 Month Operations	8	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Amps A Ø	120.0	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Amps B Ø	120.0	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Amps C Ø	120.0	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	CAP000023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	CAP000023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	CAP000023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	CAP000023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Capacitor Condition	Good	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	BAT001416	Battery	351-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	CAP000023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	CAP000023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Cap bank CT in Good Condition?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	CAP000023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	CAP000023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Bushing Condition	Good	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	CAP000023	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	All Connections OK?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BAT001381	Battery	884-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BAT001381	Battery	884-Battery Bank	Battery Patrol Inspection	General Comments		
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BAT001381	Battery	884-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BAT001381	Battery	884-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	RC001331	RecloserHydraulic	861-1523 A	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	RC001331	RecloserHydraulic	861-1523 A	Recloser Hydraulic Patrol Inspection	General Comments		
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	RC001331	RecloserHydraulic	861-1523 A	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	RC001331	RecloserHydraulic	861-1523 A	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	RC001331	RecloserHydraulic	861-1523 A	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	RC001331	RecloserHydraulic	861-1523 A	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/6/2020 6:55	Distribution	Sunset Quarterly Inspection	RC001331	RecloserHydraulic	861-1523 A	Recloser Hydraulic Patrol Inspection	Amps A Ø	5.0	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BAT001381	Battery	884-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	BAT001416	Battery	351-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	BAT001416	Battery	351-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	BAT001416	Battery	351-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	BAT001416	Battery	351-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Vegetation	None	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	General Comments		
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	YD000203	Yard	579-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	YD000203	Yard	579-Yard	Yard Patrol Inspection	Vegetation	None	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	YD000203	Yard	579-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	YD000228	Yard	673-Yard	Yard Patrol Inspection	Ambient Temp	64	*F
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	BCH000423	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	BAT001416	Battery	351-Battery Bank	Battery Patrol Inspection	General Comments		
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	BAT001416	Battery	351-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	BAT001416	Battery	351-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	BAT001416	Battery	351-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	BAT001416	Battery	351-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	BCH001333	Charger	351-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	BCH001333	Charger	351-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	BCH001333	Charger	351-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	General Comments		
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Patrol Inspection	General Comments		
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Patrol Inspection	Foundation Condition	Good	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Follow-up Action Required?	n	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Fault Operations Ground	0	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Fault Operations C Ø	0	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Fault Operations B Ø	0	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Fault Operations A Ø	0	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Patrol Inspection	Bushing Condition	Good	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Amps C Ø	36.0	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Amps B Ø	25.0	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Amps A Ø	18.0	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	9 Month Operations	13	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BAT001381	Battery	884-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BAT001381	Battery	884-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BAT001381	Battery	884-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	ST000235	Structure	673-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 13:12	Distribution	Marion 4kV Quarterly Inspection	W0289	WithLTC	438-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Bushing Condition	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Fault Operations A Ø	0	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Fault Operations B Ø	0	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Fault Operations C Ø	0	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Fault Operations Ground	0	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Follow-up Action Required?	n	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Foundation Condition	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	General Comments		
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	General Comments		
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Grounds in Place?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Maintenance Operations	0	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Operations Counter AF	233	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Operations Counter AL	237	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Operations This Read Vac	4	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	General Comments		
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Switching Operations	4	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	MB0174	BreakerVacuum	116-6	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT000472	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT000472	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	11.8	VDC
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT000472	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	12.5	VDC
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	BAT000472	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	YD000202	Yard	419-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Unknown Operations	0	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Switching Operations	2	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Operations This Read Vac	2	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Operations Counter AL	215	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Operations Counter AF	215	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001431	BreakerVacuum	848-0156	VCB Readings	Maintenance Operations	0	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/6/2020 10:17	Distribution	Sixth Vein Quarterly Inspection	FE000225	Fence	498-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Operations This Read Vac	0	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Switching Operations	0	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Unknown Operations	0	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	277.92	kw
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	115.00	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	110.00	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	Oil Temp Max	55	°C
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BCH000259	Charger	673-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BCH000259	Charger	673-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	General Comments		
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Negative DC Ground	136.0	VDC
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	9 Month Operations	0	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BCH000259	Charger	673-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.7	amps
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Vegetation	None	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	General Comments		
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	Oil Temp Present	40	°C
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Amps A Ø	100.0	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Amps B Ø	120.0	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Amps C Ø	120.0	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	Vegetation	None	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	600	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	Totalizer Meter Reading	.4632	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	General Comments		
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	General Comments		
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	General Comments		
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	9 Month Operations	2	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Amps A Ø	15.0	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Amps B Ø	20.0	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Amps C Ø	25.0	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Bushing Condition	Good	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Fault Operations A Ø	0	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Fault Operations B Ø	0	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Fault Operations C Ø	0	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Fault Operations Ground	0	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Follow-up Action Required?	n	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Foundation Condition	Good	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	General Comments		
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	General Comments		
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Grounds in Place?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Maintenance Operations	0	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Operations Counter AF	353	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	WB0168	BreakerVacuum	803-0819	VCB Readings	Operations Counter AL	353	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Switching Operations	0	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Unknown Operations	0	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Bushing Condition	Good	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Fault Operations A Ø	0	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Fault Operations B Ø	0	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Fault Operations C Ø	0	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	LTCC000110	LTCControl	607-2	LTC Control Insp	VRR Time Delay	30	Seconds
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	LTCC000110	LTCControl	607-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	3	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	9 Month Operations	32	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Amps A Ø	0.0	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Amps B Ø	0.0	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Amps C Ø	0.0	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	67	°F
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Patrol Inspection	Bushing Condition	Good	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Fault Operations Ground	0	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Follow-up Action Required?	n	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Foundation Condition	Good	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	General Comments		
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	General Comments		
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Grounds in Place?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Maintenance Operations	0	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Operations Counter AF	267	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Operations Counter AL	267	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Operations This Read Vac	0	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BCH000259	Charger	673-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.1	VDC
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BCH000259	Charger	673-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.1	VDC
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	9 Month Operations	12	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Bushing Condition	Good	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Fault Operations A Ø	0	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Fault Operations B Ø	0	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Fault Operations C Ø	0	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Fault Operations Ground	0	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Follow-up Action Required?	n	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.5	VDC
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.9	VDC
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	General Comments		
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/6/2020 11:37	Distribution	Salem 12kV Quarterly Inspection	BAT001402	Battery	673-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Foundation Condition	Good	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	General Comments		
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	General Comments		
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Grounds in Place?	y	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Maintenance Operations	1	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Operations Counter AF	236	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Operations Counter AL	236	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Readings	Operations This Read Vac	1	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	BK000007	BreakerVacuum	113-3413	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	BAT001404	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	BAT001404	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	67	*F
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	BAT001404	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Fence Gates Aligned?	n	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	Clear of Trash?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	20.0	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	20.0	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT000468	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	General Comments		
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT000468	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	45	*F
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT000468	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT000468	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	20.0	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT000468	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT000468	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT000468	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT000468	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT000468	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT000468	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	8.3	VDC
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT000468	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	9.5	VDC
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	BAT000468	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/6/2020 14:53	Distribution	Beargrass Quarterly Inspection	PF000017	PowerFuse	BG-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
10/6/2020 14:53	Distribution	Beargrass Quarterly Inspection	PF000017	PowerFuse	BG-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/6/2020 14:53	Distribution	Beargrass Quarterly Inspection	PF000017	PowerFuse	BG-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	BAT001404	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	1.3	VDC
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	BAT001404	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	1.6	VDC
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	BAT001404	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	BAT001404	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	BAT001404	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	BAT001404	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	BAT001404	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	BCH000448	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	50.0	VDC
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	BCH000448	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/6/2020 7:49	Distribution	Dawson Springs 12kV Quarterly Inspection	BCH000448	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	BAT001404	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	BAT001404	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/6/2020 8:37	Distribution	Nortonville Quarterly Inspection	BAT001404	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	Clear of Obstacles?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	YD000818	Yard	421-Yard 34.5	Yard Patrol Inspection	Ambient Temp	38	*F
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	11	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	General Comments		
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Fence Ties Intact?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	General Comments		
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	CH000043	ControlHouse	082-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Ambient Temp	60	*F
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	111	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	111	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	WB0172	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	1	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2020 9:56	Distribution	Dawson Springs Industrial Quarterly Inspection	WB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	General Comments		
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Vegetation	Needs Attention	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	YD000131	Yard	082-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	ST000134	Structure	082-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	General Comments		
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 9:13	Distribution	Crossroads Quarterly Inspection	FE000321	Fence	637-Fence	Fence Patrol Inspection	General Comments		
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/6/2020 13:21	Distribution	Ashland Pipe Quarterly Inspection	ST000355	Structure	607-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	Evidence of Insects	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	General Comments		
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/6/2020 14:18	Distribution	Virginia City Distribution Quarterly Inspection	CH000484	ControlHouse	351-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.5	VDC
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.9	VDC
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	General Comments		
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	55	*F
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	BAT001403	Battery	574-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 13:07	Distribution	Outwood Quarterly Inspection	W0127	NonLTC	448-2 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 inches?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	509	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Counter Readings	LTC As Left Counter	101620	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Patrol Inspection	Bushing Condition	Good	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Counter Readings	LTC As Found Counter	101617	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	R1512	Regulator	082-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Fault Operations A Ø	0	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Fault Operations B Ø	0	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Fault Operations C Ø	0	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Fault Operations Ground	0	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Follow-up Action Required?	n	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Patrol Inspection	Foundation Condition	Good	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Patrol Inspection	General Comments		
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	General Comments		
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Tank Leaks	None	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Unknown Operations	0	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	General Comments		
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Fence Ties Intact?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	FE000858	Fence	116-Yard	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	1366	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Switching Operations	29	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Unknown Operations	0	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	9 Month Operations	0	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Amps A Ø	140.0	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Amps B Ø	128.0	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Amps C Ø	140.0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	1366	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	General Comments	Tree on fence. Perimeter needs attention with dead rotting trees	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Maintenance Operations	0	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Grounds in Place?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	General Comments		
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	General Comments		
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Foundation Condition	Good	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Counter Readings	LTC Operations Since Last Insp	1059	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Counter Readings	LTC Min Tap Position	11L	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Counter Readings	LTC Max Tap Position	2R	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Counter Readings	LTC Current Tap Position	3L	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Follow-up Action Required?	n	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Follow-up Action Required?	n	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Fault Operations Ground	0	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Fault Operations C Ø	0	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Amps A Ø	11.0	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Amps B Ø	33.0	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Amps C Ø	4.0	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Patrol Inspection	Bushing Condition	Good	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Counter Readings	LTC As Left Counter	20270	
10/6/2020 9:45	Distribution	Marion South Quarterly Inspection	S0042	LTCMechanism	574-1	LTC Counter Readings	LTC As Found Counter	20260	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	BCH001424	Charger	726-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	BCH001424	Charger	726-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	BCH001424	Charger	726-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	BCH001424	Charger	726-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	BCH001424	Charger	726-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	BCH001424	Charger	726-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	BCH001424	Charger	726-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	BCH001424	Charger	726-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	BAT001493	Battery	726-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	BAT001493	Battery	726-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	BAT001493	Battery	726-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	BAT001493	Battery	726-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	BAT001493	Battery	726-Battery Bank	Battery Patrol Inspection	General Comments		
10/6/2020 16:48	Distribution	Stanford North Quarterly Inspection	BAT001493	Battery	726-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Patrol Inspection	Grounds in Place?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Maintenance Operations	0	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Operations Counter AF	178	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Operations Counter AL	178	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Operations This Read Vac	0	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Switching Operations	0	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001563	BreakerVacuum	884-2142	VCB Readings	Unknown Operations	0	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Mechanism Patrol Inspection	General Comments		
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Counter Readings	General Comments		
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	FE000129	Fence	082-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	9 Month Operations	20	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BK001564	BreakerVacuum	884-2143	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BCH001309	Charger	884-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BCH001309	Charger	884-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	BCH001309	Charger	884-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Unknown Operations	0	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Switching Operations	10	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Operations This Read Vac	10	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Operations Counter AL	254	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Readings	Operations Counter AF	244	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	K0142	BreakerVacuum	116-BT6-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/6/2020 10:22	Distribution	Mannington Quarterly Inspection	FE000222	Fence	437-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	509	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Fault Operations A Ø	0	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Fault Operations B Ø	0	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Fault Operations C Ø	0	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Readings	Oil Temp Max	55	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Readings	Oil Temp Present	30	°C
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Fault Operations Ground	0	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Operations This Read Vac	29	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Operations Counter AL	173	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Fault Operations	0	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Follow-up Action Required?	n	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Patrol Inspection	Foundation Condition	Good	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Patrol Inspection	General Comments		
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	General Comments		
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Patrol Inspection	Grounds in Place?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Maintenance Operations	0	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	BK001551	BreakerVacuum	848-0157	VCB Readings	Operations Counter AF	173	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
10/6/2020 17:24	Distribution	Stanford Quarterly Inspection	CB0225	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Air Compressor Oil Status	Good	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Air Leaks	None	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Air Pressure OK?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Bushing Oil Level	Good	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Bushing Condition	Good	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Counter Readings	LTC Current Tap Position	3L	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Counter Readings	LTC Max Tap Position	8L	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Counter Readings	LTC Min Tap Position	5R	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Switching Operations	0	
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Patrol Inspection	Tank Paint Condition	Good	
10/7/2020 5:23	Distribution	St Paul Quarterly Inspection	YD000046	Yard	116-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
10/6/2020 7:47	Distribution	Mortons Gap Quarterly Inspection	K0070	BreakerVacuum	782-0823	VCB Readings	Unknown Operations	0	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/6/2020 15:12	Distribution	Lansdowne Quarterly Inspection	BB0303	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Follow-up Action Required?	n	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Foundation Condition	Good	
10/6/2020 10:00	Distribution	Hardesty Quarterly Inspection	BAT000464	Battery	113-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	General Comments		
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	General Comments		
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Grounds in Place?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Heaters (All) Functioning?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Maintenance Operations	0	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Number of Ops last 9 Months	0	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Operations Counter AF	99991	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Readings	General Comments		
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	General Comments		
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/6/2020 9:52	Distribution	Daniel Boone Quarterly Inspection	0919	NonLTC	419-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Operations Counter AL	99991	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/6/2020 16:07	Distribution	Lancaster 2 Quarterly Inspection	C0394	LTCMechanism	884-1	LTC Counter Readings	LTC Operations Since Last Insp	1077	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Switching Operations	0	
10/6/2020 7:27	Distribution	Dawson Springs 4kV Quarterly Inspection	FE000777	Fence	421-Fence 34.5	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Pressure Vessel Condition	Good	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Patrol Inspection	Pop-off Valve Tested Date	2020-10-06 00:00:00.000000	
10/6/2020 10:47	Distribution	Salem Quarterly Inspection	TB0099	BreakerOil	082-614	OCB Readings	Operations This Read Oil	0	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	75	*F
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	69.1	VDC
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	65.9	VDC
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	BAT000453	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Regulator As Left Counter	149834	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	General Comments	Control is GE 779C345AA P21	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	BCH000032	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Bushing Condition	Good	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	40	*C
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Operations Counter AL	99976	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	9 Month Operations	11	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Foundation Condition	Good	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Maintenance Operations	0	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Operations Counter AF	99976	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	H2 Winding Temp Present	45	*C
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	H2 Winding Temp Max	65	*C
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Tank Leaks	None	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Ambient Temp	60	*F
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Vegetation	None	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Amps C Ø	50.0	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Fault Operations A Ø	0	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Fault Operations B Ø	0	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Fault Operations C Ø	0	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Fault Operations Ground	0	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Follow-up Action Required?	n	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	General Comments	vines are still grwoing from the abandoned sub, getting closer to bus work	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	YD000093	Yard	493-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Amps B Ø	50.0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Amps A Ø	50.0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	BCH000032	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	BCH000032	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	BCH000032	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	BCH000032	Charger	Retired Distribution	Battery Charger Patrol Insp	Ground Lights	None	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	30.00	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Regulator As Left Counter	261237	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	BCH001146	Charger	191-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	134.0	VDC
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	BCH001146	Charger	191-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	134.0	VDC
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Amps C Ø	118.0	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Patrol Inspection	General Comments		
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	General Comments		
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	BCH000032	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	3.0	amps
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	BCH000032	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	135.0	VDC
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	BCH000032	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	135.0	VDC
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	Oil Temp Present	45	°C
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	BCH001146	Charger	191-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	BCH001146	Charger	191-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	Oil Temp Max	65	°C
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	BCH001146	Charger	191-Battery Charger	Battery Charger Patrol Insp	General Comments	135.2Vdc Actual	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	70	°C
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Foundation Condition	Good	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Current Tap Position	Neutral	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Bushing Condition	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Operations Counter AL	255	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	General Comments		
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	General Comments		
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Operations This Read Vac	0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Switching Operations	0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	PF000027	PowerFuse	AS-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	OK	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	PF000027	PowerFuse	AS-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	PF000027	PowerFuse	AS-STA SER NO 4	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	PF000026	PowerFuse	AS-14KV TR 4 POT	Disconnect Powerfuse Inspection	General Comments	OK	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	PF000026	PowerFuse	AS-14KV TR 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	PF000026	PowerFuse	AS-14KV TR 4 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	PF000025	PowerFuse	AS-14KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	OK	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Vegetation	None	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	PF000025	PowerFuse	AS-14KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	PF000025	PowerFuse	AS-14KV TR 3 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Unknown Operations	0	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Switching Operations	2	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Operations This Read Vac	2	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Follow-up Action Required?	n	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	General Comments		
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Grounds in Place?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Tank Leaks	None	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0241	GroundTransformer	AS-GND TR 4	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	General Comments		
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Fault Operations A Ø	0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Fault Operations B Ø	0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Fault Operations C Ø	0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Fault Operations Ground	0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Min Tap Position	15L	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Max Tap Position	1R	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	General Comments		
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Current Tap Position	8L	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1024	Regulator	493-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Tank Leaks	None	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Reg Oil Level	Good	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	Grounds in Place?	y	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	R0499	Regulator	577-1 [AC]	Regulator Patrol Inspection	General Comments		
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	General Comments		
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	ST000171	Structure	191-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R0873	Regulator	707-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Ambient Temp	73	*F
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	YD000164	Yard	191-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Ambient Temp	56	*F
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	200.0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	200.0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	200.0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Oil Status	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	Totalizer Meter Reading	.3384	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	Oil Temp Present	30	°C
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	Oil Temp Max	50	°C
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	LTC Totalizer Reading	2436.48	kw
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	General Comments		
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	General Comments		
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	9 Month Operations	0	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Amps A Ø	0.0	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Amps B Ø	0.0	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Amps C Ø	0.0	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Fault Operations A Ø	0	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Fault Operations B Ø	0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1251	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1251	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	10	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	9 Month Operations	34	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Readings	General Comments		
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Fault Operations C Ø	0	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Fault Operations Ground	0	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Follow-up Action Required?	n	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Patrol Inspection	General Comments		
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	General Comments	Not in service	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Maintenance Operations	0	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Operations Counter AF	1167	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Operations Counter AL	1167	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Operations This Read Vac	0	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Switching Operations	0	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0548	BreakerVacuum	LO-1194	VCB Readings	Unknown Operations	0	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	30	°C
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Max	60	°C
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	10.00	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	C0265	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	PF000195	PowerFuse	LO-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	PF000195	PowerFuse	LO-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	OK	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	PF000196	PowerFuse	LO-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments		
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	4L	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	PF000196	PowerFuse	LO-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Amps A Ø	29.0	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Amps B Ø	35.0	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Amps C Ø	7.0	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Operations Counter	11	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	General Comments	Batt was 27.2/26.5	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	MX0286	RecloserElectronic	707-0419	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	General Comments		
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	ST000452	Structure	719-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	C0462	WithLTC	719-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	LTC Operations Since Last Insp	22	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	LTC Min Tap Position	3L	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	LTC Max Tap Position	10L	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	LTC Current Tap Position	3L	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	LTC As Left Counter	435969	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	LTC As Found Counter	435964	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Mechanism Patrol Inspection	General Comments		
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	General Comments		
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	C0462	LTCMechanism	719-1	LTC Counter Readings	Follow-up Action Required?	n	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	General Comments		
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	FE000441	Fence	719-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	75603	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	8L	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	11R	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0699	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	General Comments	corner of foundation next to battery house is crumbling	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	ST000100	Structure	493-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	General Comments	Top rail is rusty	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Follow-up Action Required?	n	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Fault Operations Ground	0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Fault Operations C ∅	0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Fault Operations B ∅	0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Fault Operations A ∅	0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	FE000202	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Regulator As Left Counter	146545	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Max Tap Position	5R	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	General Comments		
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	MX0248	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	26.0	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	MX0248	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	19.0	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	MX0248	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	20.0	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	MX0248	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	MX0248	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	MX0248	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	MX0248	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	MX0248	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	MX0248	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	MX0248	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Unknown Operations	0	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Switching Operations	0	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Operations This Read Vac	0	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Operations Counter AL	222	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Operations Counter AF	222	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Maintenance Operations	0	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	General Comments		
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Vegetation	None	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	YD000445	Yard	719-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	FE000167	Fence	191-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Amps B Ø	115.0	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Amps A Ø	125.0	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0544	BreakerVacuum	LO-1190	VCB Readings	9 Month Operations	3	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	LTCC000326	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	LTCC000326	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	LTCC000326	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	LTCC000326	LTCControl	920-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	123.7	VAC
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	LTCC000326	LTCControl	920-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	LTCC000326	LTCControl	920-Offline-Distribution	LTC Control Insp	General Comments		
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	General Comments		
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	CH000059	ControlHouse	191-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	LTCC000326	LTCControl	920-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	LTCC000326	LTCControl	920-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	FE000115	Fence	707-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Broom on Site?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	General Comments		
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Trash Emptied?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	CH000156	ControlHouse	LO-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	SWG000037	Switchgear	LO-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	461	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Amps A Ø	7.0	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Amps B Ø	5.0	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Amps C Ø	4.0	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	89	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	79	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	General Comments		
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	DX0108	RecloserHydraulic	577-0467	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	General Comments		
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Patrol Inspection	General Comments		
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	MX0248	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	505	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	MX0248	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	MX0248	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	MX0250	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	57.0	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	MX0250	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	31.0	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	MX0250	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	43.0	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	MX0250	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	MX0250	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	MX0250	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	MX0250	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	MX0250	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	MX0250	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	MX0250	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	MX0250	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	489	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	MX0250	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	MX0250	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Amps C Ø	0.0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Amps B Ø	0.0	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	R0867	Regulator	573-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0041	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Fault Operations Ground	0	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Amps C Ø	400.0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Amps A Ø	0.0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	9 Month Operations	15	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Amps B Ø	375.0	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Amps A Ø	350.0	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0550	BreakerVacuum	LO-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	128	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	LTC Min Tap Position	19R	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	LTC Max Tap Position	23R	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	LTC Current Tap Position	18R	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	LTC As Left Counter	15650	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	LTC As Found Counter	15650	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0013	LTCMechanism	AS-TRANS 3	LTC Counter Readings	General Comments		
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	56	°F
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	BCH001332	Charger	719-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	BCH001332	Charger	719-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	BCH001332	Charger	719-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	BCH001332	Charger	719-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	BCH001332	Charger	719-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	BCH001332	Charger	719-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	BCH001332	Charger	719-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	BCH001332	Charger	719-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	205513	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	9L	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	5R	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	1L	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Operations Counter AF	352	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Operations Counter AL	352	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Switching Operations	0	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Min Tap Position	16L	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Readings	General Comments		
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	General Comments		
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	General Comments		
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Maintenance Operations	0	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	R0762	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Bushing Condition	Good	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Current Tap Position	1L	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Foundation Condition	Good	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Grounds in Place?	y	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Max Tap Position	8R	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Positive DC Ground	23.0	VDC
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Negative DC Ground	25.0	VDC
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	General Comments		
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	BAT001413	Battery	719-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	95.00	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	Oil Temp Max	40	°C
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	Oil Temp Present	25	°C
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	20.0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	20.0	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Adequate	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	600	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.1076	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	PF000024	PowerFuse	AS-GND TR 3	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	PF000024	PowerFuse	AS-GND TR 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	PF000024	PowerFuse	AS-GND TR 3	Disconnect Powerfuse Inspection	General Comments	OK	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	General Comments		
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Readings	General Comments		
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Readings	Oil Temp Max	40	°C
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Readings	Oil Temp Present	27	°C
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Reg Oil Level	Good	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Reg Output Voltage Level	122.0	volts
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Tank Leaks	None	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	R0498	Regulator	577-1 [AB]	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	20.0	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	General Comments		
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0119	NonLTC	577-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	64.56	kw
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	General Comments		
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Maintenance Operations	0	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	General Comments		
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Patrol Inspection	General Comments		
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Follow-up Action Required?	n	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Fault Operations Ground	0	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Fault Operations C Ø	0	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Fault Operations B Ø	0	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Fault Operations A Ø	0	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Amps C Ø	120.0	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Amps B Ø	120.0	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Amps A Ø	120.0	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	9 Month Operations	17	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	PF000022	PowerFuse	AS-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	PF000022	PowerFuse	AS-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	PF000022	PowerFuse	AS-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	General Comments		
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1209	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1209	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Unknown Operations	0	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Switching Operations	0	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Operations This Read Vac	0	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Operations Counter AL	386	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Operations Counter AF	386	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Maintenance Operations	0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Ambient Temp	70	*F
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Vegetation	None	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	YD000116	Yard	707-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	BCH000981	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	BCH000981	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	BCH000981	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	BCH000981	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	BCH000981	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	133.5	VDC
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	BCH000981	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	133.5	VDC
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Evidence of Insects	None	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	BCH000981	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	5.400	millivolts
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Unknown Operations	0	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Switching Operations	0	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Operations This Read Vac	0	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Operations Counter AL	659	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0547	BreakerVacuum	LO-1193	VCB Readings	Operations Counter AF	659	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Fault Operations A ∅	0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Fault Operations B ∅	0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Fault Operations C ∅	0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Fault Operations Ground	0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Follow-up Action Required?	n	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Foundation Condition	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	General Comments		
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	General Comments		
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Maintenance Operations	0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Operations Counter AF	68	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Operations Counter AL	68	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Operations This Read Vac	0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Switching Operations	0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LTCC000419	LTCControl	AS-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LTCC000419	LTCControl	AS-TRANS 3	LTC Control Insp	General Comments		
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LTCC000419	LTCControl	AS-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	9 Month Operations	20	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps A ∅	290.0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps B ∅	280.0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps C ∅	280.0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0049	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations A ∅	0	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	General Comments		
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Patrol Inspection	General Comments		
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Follow-up Action Required?	n	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Fault Operations Ground	0	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Fault Operations C ∅	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Fault Operations B Ø	0	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Fault Operations A Ø	0	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Amps C Ø	100.0	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Amps B Ø	100.0	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Amps A Ø	100.0	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	ST000120	Structure	707-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0545	BreakerVacuum	LO-1191	VCB Readings	9 Month Operations	9	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	BAT000887	Battery	LO-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	9 Month Operations	1	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Amps A Ø	8.0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Amps B Ø	8.0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Readings	Amps C Ø	8.0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001046	BreakerVacuum	AS-1421	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	General Comments		
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Vegetation	None	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	General Comments		
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Oil Status	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Fault Operations Ground	0	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Fault Operations C Ø	0	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	General Comments	rusty fence	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	FE000062	Fence	493-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	General Comments		
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	FE000583	Fence	LO-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	YD000588	Yard	LO-Yard	Yard Patrol Inspection	Ambient Temp	45	°F
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	9 Month Operations	5	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps A Ø	345.0	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	BCH000450	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	BCH000450	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	BCH000450	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	BCH000450	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	BCH000450	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	60.0	VDC
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	BCH000450	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	60.0	VDC
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	BCH000450	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.870	millivolts
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps B Ø	245.0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Amps C Ø	240.0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Patrol Inspection	General Comments		
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	General Comments		
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Maintenance Operations	0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Operations Counter AF	369	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Operations Counter AL	369	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0043	BreakerVacuum	SSC-Offline-Distribution	VCB Readings	Switching Operations	0	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	ST000584	Structure	LO-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Regulator As Left Counter	48223	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Fault Operations B Ø	0	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Fault Operations A Ø	0	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Amps C Ø	80.0	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Amps B Ø	80.0	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Amps A Ø	80.0	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	9 Month Operations	8	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Readings	Oil Temp Present	29	°C
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Readings	Oil Temp Max	35	°C
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	70.00	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Readings	General Comments		
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	General Comments		
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	0948	NonLTC	031-5 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Amps C Ø	39.0	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	General Comments	Batt was 26.9/26.2	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Operations Counter	36	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	45	°C
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	50	°C
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	45	°C
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	50	°C
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	45	°C
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	55	°C
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	Oil Temp Present	30	°C
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	Oil Temp Max	30	°C
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.8	psi
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0118	NonLTC	577-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	General Comments		
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	General Comments		
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1742.40	kw
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	Oil Temp Present	30	°C
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	M0067	NonLTC	707-1	NonLTC Transformer Readings	Totalizer Meter Reading	.2420	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Oil Status	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Amps A Ø	40.0	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	MX0310	RecloserElectronic	707-0418	Recloser Electronic Patrol Inspection	Amps B Ø	39.0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Readings	Winding Temp Present	25	°C
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Readings	Winding Temp Max	50	°C
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Readings	Top Oil Temperature Present	28	°C
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Readings	Top Oil Temperature Max	52	°C
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	10.00	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	17.50	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	2000	psi
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	General Comments	Placed new Nitro Bottle	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Readings	General Comments		
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	T0157	NonLTC	191-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	450.0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	450.0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	450.0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	General Comments		
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LT0104	WithLTC	LO-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	General Comments	Control is GE Model VR-1 Serial is 1200V30687.	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Unknown Operations	0	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Switching Operations	1	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Operations This Read Vac	1	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R1392	Regulator	707-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Operations Counter AL	78	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Operations Counter AF	778	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Maintenance Operations	0	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	General Comments		
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Patrol Inspection	General Comments		
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Readings	Follow-up Action Required?	n	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LB0546	BreakerVacuum	LO-1192	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	551	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	551	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	1	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0048	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	Totalizer Meter Reading	.9810	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	General Comments	Control is 3951C407AA P21 Rev A	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Maintenance Operations	1	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Max Tap Position	2L	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Operations Counter AF	201	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Operations Counter AL	201	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Operations This Read Vac	1	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Regulator As Left Counter	98160	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Readings	Oil Temp Present	39	°C
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Readings	Oil Temp Max	58	°C
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	9 Month Operations	2	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Amps A Ø	100.0	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Amps B Ø	20.0	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Amps C Ø	20.0	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	General Comments		
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	General Comments		
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	Non LTC Totalizer Reading	4708.80	kw
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	Oil Temp Max	56	°C
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	Oil Temp Present	49	°C
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Fault Operations A Ø	0	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Fault Operations B Ø	0	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Fault Operations C Ø	0	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Fault Operations Ground	0	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Foundation Condition	Good	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	General Comments		
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	General Comments		
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	Oil Temp Present	37	°C
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	Oil Temp Max	52	°C
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	Non LTC Totalizer Reading	708.00	kw
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	General Comments		
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	General Comments		
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Readings	Oil Temp Present	39	°C
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Readings	Oil Temp Max	81	°C
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	40.00	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	45.00	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Readings	General Comments		
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	General Comments		
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	General Comments		
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0312	NonLTC	493-2 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Counter Readings	General Comments		
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Counter Readings	LTC As Found Counter	20769	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Counter Readings	LTC As Left Counter	20769	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Counter Readings	LTC Current Tap Position	11L	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Counter Readings	LTC Max Tap Position	16R	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Counter Readings	LTC Min Tap Position	16L	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1279	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/5/2020 11:34	Distribution	Locust Quarterly Inspection	LTCM000041	LTCMechanism	LO-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	Totalizer Meter Reading	.2950	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0313	NonLTC	493-2 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Patrol Inspection	General Comments		
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Patrol Inspection	Foundation Condition	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Follow-up Action Required?	n	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	8L	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	8R	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments		
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Patrol Inspection	General Comments		
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	General Comments		
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Maintenance Operations	0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Operations Counter AF	634	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Operations Counter AL	634	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Operations This Read Vac	2	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0042	BreakerVacuum	AS-1417	VCB Readings	Switching Operations	2	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	5L	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Patrol Inspection	General Comments		
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	General Comments		
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Maintenance Operations	0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Operations Counter AF	157	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Operations Counter AL	157	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Operations This Read Vac	0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0050	BreakerVacuum	AS-GND TR 4	VCB Readings	Switching Operations	0	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	9 Month Operations	10	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Amps A Ø	100.0	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Amps B Ø	100.0	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Amps C Ø	100.0	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	Y2 Winding Temp Max	60	°C
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0013	WithLTC	AS-TRANS 3	LTC Transformer Readings	Y2 Winding Temp Present	40	°C
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	.3	VDC
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	.1	VDC
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	BAT000388	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Operations Counter AF	255	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Maintenance Operations	0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	General Comments		
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Patrol Inspection	General Comments		
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Unknown Operations	0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Switching Operations	5	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Follow-up Action Required?	n	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Fault Operations Ground	0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Operations This Read Vac	5	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Operations Counter AL	331	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Operations Counter AF	331	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	138485	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0706	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Maintenance Operations	0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	General Comments		
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Fault Operations A Ø	0	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Fault Operations B Ø	0	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Fault Operations C Ø	0	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Fault Operations Ground	0	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Follow-up Action Required?	n	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Foundation Condition	Good	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	General Comments		
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	General Comments		
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Maintenance Operations	0	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Operations Counter AF	725	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Operations Counter AL	725	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Operations This Read Vac	2	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Switching Operations	2	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Unknown Operations	0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Tank Leaks	None	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Grounds in Place?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	General Comments		
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Foundation Condition	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0240	GroundTransformer	AS-GND TR 3	Ground Transformer Patrol Inspection	Bushing Condition	Good	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2020 12:59	Distribution	Cawood Quarterly Inspection	R0872	Regulator	707-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	0272	NonLTC	031-5 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Fault Operations Ground	0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Fault Operations C Ø	0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Fault Operations B Ø	0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Fault Operations A Ø	0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Amps C Ø	0.0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Amps B Ø	0.0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Amps A Ø	0.0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	BK001523	BreakerVacuum	AS-14KV BUS TIE SEC 3 & 4	VCB Readings	9 Month Operations	15	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Fault Operations C Ø	0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Fault Operations B Ø	0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Fault Operations A Ø	0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Amps C Ø	0.0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Amps B Ø	0.0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Amps A Ø	0.0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0045	BreakerVacuum	AS-1418	VCB Readings	9 Month Operations	32	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 16:46	Distribution	Lebanon Industrial Quarterly Inspection	CB0234	BreakerVacuum	719-2236	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Readings	General Comments		
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	General Comments		
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Unknown Operations	0	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Switching Operations	0	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Operations This Read Vac	1	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Operations Counter AL	188	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Operations Counter AF	188	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Maintenance Operations	0	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Ambient Temp	66	*F
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	General Comments	9-22 A-B Op	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	General Comments		
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Foundation Condition	Good	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Follow-up Action Required?	n	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Fault Operations Ground	0	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Fault Operations C Ø	0	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Fault Operations B Ø	0	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Fault Operations A Ø	1	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Fault Adjusted Amps A Phase V	2.41	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Counter Readings	Follow-up Action Required?	n	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Readings	Oil Temp Present	24	°C
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	General Comments		
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	ST000200	Structure	770-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Vegetation	Light	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	General Comments		
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	YD000193	Yard	770-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Readings	Oil Temp Max	40	°C
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	W0211	NonLTC	577-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	95.00	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	9 Month Operations	3	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	9 Month Operations	4	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Panels Dusted?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LB0044	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	General Comments		
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Readings	Percent Thermal Load Y2 Max	60	%
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Readings	Percent Thermal Load X2 Max	-60	%
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Readings	Oil Temp Present	45	°C
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Readings	Oil Temp Max	60	°C
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.7	psi
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LTCC000473	LTCControl	AS-TRANS 4	LTC Control Insp	Follow-up Action Required?	n	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LTCC000473	LTCControl	AS-TRANS 4	LTC Control Insp	General Comments		
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LTCC000473	LTCControl	AS-TRANS 4	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	General Comments	NEEDS NITRO	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Readings	General Comments		
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	n	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	SWG000004	Switchgear	AS-Swgr Sec 4	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Amps C Ø	36.0	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Amps B Ø	33.0	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Amps A Ø	35.0	
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Operations Counter AL	158	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Operations Counter AF	158	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Maintenance Operations	1	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Grounds in Place?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	General Comments	51-N T target	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	General Comments		
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Foundation Condition	Good	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Follow-up Action Required?	n	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Fault Operations Ground	1	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Fault Operations C Ø	0	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Fault Operations B Ø	0	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Fault Operations A Ø	0	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Fault Adjusted Amps C Phase V	4.44	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Fault Adjusted Amps B Phase V	4.44	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Fault Adjusted Amps A Phase V	4.44	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Bushing Condition	Good	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Amps C Ø	60.0	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Amps B Ø	30.0	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Amps A Ø	20.0	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/5/2020 14:15	Distribution	Oak Hill Quarterly Inspection	KB0089	BreakerVacuum	191-3418	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	274347	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	10L	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	11R	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments		
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	5L	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	R0685	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Readings	Oil Temp Present	35	°C
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Readings	Oil Temp Max	49	°C
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2020 12:02	Distribution	Lynch Quarterly Inspection	M0004	NonLTC	031-5 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	General Comments		
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	FE000055	Fence	577-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Ambient Temp	58	°F
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	General Comments		
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Vegetation	None	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	YD000054	Yard	577-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	General Comments		
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/5/2020 10:41	Distribution	Black Mountain Quarterly Inspection	ST000059	Structure	577-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	General Comments		
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Max Tap Position	2L	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Min Tap Position	15L	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Regulator As Left Counter	157685	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Unknown Operations	0	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Switching Operations	0	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0118	BreakerVacuum	770-1492	VCB Readings	Operations This Read Vac	2	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Patrol Inspection	Tank Paint Condition	Good	
10/5/2020 13:32	Distribution	Crofton Quarterly Inspection	K0155	BreakerVacuum	770-1491	VCB Readings	Unknown Operations	0	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Tank Leaks	None	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0012	WithLTC	AS-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Counter Readings	LTC Operations Since Last Insp	327	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Counter Readings	LTC Current Tap Position	5R	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Counter Readings	LTC As Left Counter	58373	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Counter Readings	LTC As Found Counter	58373	
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Mechanism Patrol Inspection	General Comments		
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Counter Readings	General Comments		
10/5/2020 12:48	Distribution	Ashbottom Quarterly Inspection	LT0012	LTCMechanism	AS-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Current Tap Position	9L	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	General Comments		
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Max Tap Position	1R	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Min Tap Position	15L	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	General Comments		
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	B0311	NonLTC	493-2 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Regulator As Left Counter	146920	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Tank Leaks	None	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1025	Regulator	493-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Current Tap Position	10L	
10/5/2020 12:30	Distribution	Benham Quarterly Inspection	R1026	Regulator	493-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Readings	Fault Operations	0	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Readings	Follow-up Action Required?	n	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Readings	General Comments		
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Readings	Maintenance Operations	0	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Readings	Num Operations Last 9 Months	9	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Readings	Operations Counter AF	661	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Readings	Operations Counter AL	665	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Readings	Operations This Read SF6	4	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Readings	Switching Operations	4	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Ambient Temperature	55	*F
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Foundation Condition	Good	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Gauge(s) Condition	Good	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	General Comments		
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Grounds in Place?	y	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Heaters (All) Functioning?	y	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	SF6 Bushing Condition	Good	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	SF6 Pressure Indicator	good	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	TB0760	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	6	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	80.0	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	70.0	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Regulator As Left Counter	119885	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Min Tap Position	13L	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	General Comments		
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1328	Regulator	783-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	6.41	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	6.41	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	6.41	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	General Comments		
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Regulator As Left Counter	105929	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Min Tap Position	4L	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Max Tap Position	8R	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	General Comments		
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	General Comments		
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	LTC Totalizer Reading	1484.64	kw
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	Oil Temp Max	65	°C
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	Oil Temp Present	30	°C
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	BCH000583	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	BCH000583	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	BCH000583	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	BCH000583	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	BCH000583	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	BCH000583	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	BCH000583	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	Totalizer Meter Multiplier	2400	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	Totalizer Meter Reading	.6186	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	55.00	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Counter Readings	LTC Operations Since Last Insp	533	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Counter Readings	LTC Min Tap Position	7L	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Counter Readings	LTC Max Tap Position	1R	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Counter Readings	LTC Current Tap Position	6L	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Counter Readings	LTC As Left Counter	27976	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Counter Readings	LTC As Found Counter	27972	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Mechanism Patrol Inspection	General Comments		
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Counter Readings	General Comments		
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0342	LTCMechanism	028-6	LTC Counter Readings	Follow-up Action Required?	n	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	General Comments		
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	General Comments		
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	92	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	77	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Amps C Ø	20.4	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Amps B Ø	15.9	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	Amps A Ø	12.0	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	RC000195	RecloserHydraulic	365-0666	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	88	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Operations Counter AL	299	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Operations Counter AF	299	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Maintenance Operations	0	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Grounds in Place?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	General Comments		
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	General Comments		
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Foundation Condition	Good	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Follow-up Action Required?	n	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	General Comments		
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	FE000757	Fence	362-2 Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Ambient Temp	50	*F
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	General Comments		
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	BCH001331	Charger	783-Battery Charger	Battery Charger Patrol Insp	General Comments	53	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	BCH001331	Charger	783-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	BCH001331	Charger	783-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	BCH001331	Charger	783-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	BCH001331	Charger	783-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	BCH001331	Charger	783-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Vegetation	None	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Positive DC Ground	23.0	VDC
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Negative DC Ground	25.0	VDC
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	General Comments		
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BCH001384	Charger	768-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BCH001384	Charger	768-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BCH001384	Charger	768-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BCH001384	Charger	768-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.0	amps
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BCH001384	Charger	768-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BCH001384	Charger	768-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BCH001384	Charger	768-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BCH001384	Charger	768-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Unknown Operations	0	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Switching Operations	0	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Operations This Read Vac	3	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	BAT001412	Battery	783-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	YD000798	Yard	362-2 Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Fault Operations Ground	0	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Fault Operations C ∅	0	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Fault Operations B ∅	0	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Fault Operations A ∅	0	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	General Comments	Counter counts twice each step	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	R0407	Regulator	383-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	FE000511	Fence	783-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	ST000348	Structure	526-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	157	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	157	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0289	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	1	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	LTCC000799	LTCControl	028-5	LTC Control Insp	All Connections OK?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	LTCC000799	LTCControl	028-5	LTC Control Insp	Follow-up Action Required?	n	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	LTCC000799	LTCControl	028-5	LTC Control Insp	General Comments		
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	LTCC000799	LTCControl	028-5	LTC Control Insp	LTC Operation Checked?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	Follow-up Action Required?	n	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	General Comments		
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Mechanism Patrol Inspection	General Comments		
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	LTC As Found Counter	62286	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	LTCC000799	LTCControl	028-5	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	LTCC000799	LTCControl	028-5	LTC Control Insp	VRR Base Voltage AF	124	VAC
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	LTCC000799	LTCControl	028-5	LTC Control Insp	VRR Base Voltage AL	124	VAC
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	LTCC000799	LTCControl	028-5	LTC Control Insp	VRR Time Delay	30	Seconds
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	LTCC000800	LTCControl	526-1	LTC Control Insp	All Connections OK?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	LTCC000800	LTCControl	526-1	LTC Control Insp	Follow-up Action Required?	n	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	LTCC000800	LTCControl	526-1	LTC Control Insp	General Comments		
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	LTCC000800	LTCControl	526-1	LTC Control Insp	LTC Operation Checked?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	LTCC000800	LTCControl	526-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	LTCC000800	LTCControl	526-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	LTCC000800	LTCControl	526-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	LTCC000800	LTCControl	526-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	LTCC000229	LTCControl	842-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	LTCC000229	LTCControl	842-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	LTCC000229	LTCControl	842-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	LTCC000229	LTCControl	842-1	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	LTCC000229	LTCControl	842-1	LTC Control Insp	LTC Operation Checked?	y	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	LTCC000229	LTCControl	842-1	LTC Control Insp	General Comments		
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	LTCC000229	LTCControl	842-1	LTC Control Insp	Follow-up Action Required?	n	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	LTCC000229	LTCControl	842-1	LTC Control Insp	All Connections OK?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Unknown Operations	0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	LTC As Left Counter	62291	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	LTC Current Tap Position	4L	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	LTC Max Tap Position	12L	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	LTC Min Tap Position	1L	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	LTC Operations Since Last Insp	1281	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Switching Operations	0	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Operations This Read Vac	0	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Follow-up Action Required?	n	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Foundation Condition	Good	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	General Comments		
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	General Comments		
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Grounds in Place?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Maintenance Operations	0	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	Oil Temp Present	38	°C
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	Oil Temp Max	55	°C
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	LTC Totalizer Reading	1728.00	kw
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	General Comments		
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	General Comments		
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Vegetation	None	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	General Comments		
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Operations Counter AF	256	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Operations Counter AL	256	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Operations This Read Vac	2	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Switching Operations	2	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	LTCC000745	LTCControl	127-5	LTC Control Insp	VRR Time Delay	30	Seconds
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	LTCC000745	LTCControl	127-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	LTCC000745	LTCControl	127-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	LTCC000745	LTCControl	127-5	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	LTCC000745	LTCControl	127-5	LTC Control Insp	LTC Operation Checked?	y	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	LTCC000745	LTCControl	127-5	LTC Control Insp	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	LTCC000745	LTCControl	127-5	LTC Control Insp	Follow-up Action Required?	n	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	LTCC000745	LTCControl	127-5	LTC Control Insp	All Connections OK?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	YD000638	Yard	CT-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Amps A Ø	50.0	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	LTCC000739	LTCControl	028-6	LTC Control Insp	VRR Time Delay	30	Seconds
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	LTCC000739	LTCControl	028-6	LTC Control Insp	VRR Base Voltage AL	125	VAC
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	LTCC000739	LTCControl	028-6	LTC Control Insp	VRR Base Voltage AF	125	VAC
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	LTCC000739	LTCControl	028-6	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	LTCC000739	LTCControl	028-6	LTC Control Insp	LTC Operation Checked?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	LTCC000739	LTCControl	028-6	LTC Control Insp	General Comments		
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	LTCC000739	LTCControl	028-6	LTC Control Insp	Follow-up Action Required?	n	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	LTC Min Tap Position	15L	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	LTC Operations Since Last Insp	1324	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	Follow-up Action Required?	n	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	General Comments		
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	General Comments		
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Readings	Oil Temp Present	30	°C
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Readings	Oil Temp Max	49	°C
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	10.00	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	15.00	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.6	psi
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Readings	General Comments		
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	General Comments		
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0167	NonLTC	362-2-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	LTC Totalizer Reading	2838.60	kw
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	Oil Temp Max	60	°C
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	Oil Temp Present	40	°C
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	Totalizer Meter Reading	.1577	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	Winding Temp Max	57	°C
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	9 Month Operations	6	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Amps A Ø	10.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Amps B Ø	10.0	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Amps C Ø	10.0	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Bushing Condition	Good	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Fault Operations A Ø	0	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Fault Operations B Ø	0	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Fault Operations C Ø	0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	Winding Temp Present	40	°C
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Fault Operations Ground	0	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	Oil Temp Max	51	°C
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	Oil Temp Present	30	°C
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	Totalizer Meter Reading	.3390	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Readings	Winding Temp Present	45	°C
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Readings	Winding Temp Max	50	°C
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Readings	Totalizer Meter Reading	.3558	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Readings	Oil Temp Present	25	°C
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Readings	Oil Temp Max	30	°C
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Readings	LTC Totalizer Reading	6404.40	kw
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Readings	General Comments		
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	General Comments		
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	C0485	WithLTC	472-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Readings	Totalizer Meter Reading	.1368	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Readings	Oil Temp Present	35	°C
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Readings	Oil Temp Max	60	°C
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Readings	Non LTC Totalizer Reading	164.16	kw
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	B0209	NonLTC	012-Offline-Distribution	NonLTC Transformer Readings	General Comments		
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	0988	WithLTC	842-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	LTCC000739	LTCControl	028-6	LTC Control Insp	All Connections OK?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Amps B Ø	50.0	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Amps C Ø	50.0	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Fault Operations A Ø	0	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Fault Operations B Ø	0	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Fault Operations C Ø	0	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Fault Operations Ground	0	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Follow-up Action Required?	n	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Patrol Inspection	General Comments		
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	General Comments		
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0138	BreakerVacuum	783-2213	VCB Readings	Unknown Operations	0	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Maintenance Operations	0	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Operations Counter AF	297	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Operations Counter AL	297	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Operations This Read AM	0	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Switching Operations	0	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Unknown Operations	0	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Free of Audible Arcing?	n	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	General Comments		
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	ST000116	Structure	383-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	FE000835	Fence	879-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	Follow-up Action Required?	n	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	General Comments		
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	General Comments		
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Readings	LTC Totalizer Reading	3254.40	kw
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	B0309	WithLTC	080-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	General Comments		
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	FE000070	Fence	629-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	120	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	120	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	120	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Regulator As Left Counter	45006	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.9	volts
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Max Tap Position	3R	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	General Comments		
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Wood Structures OK?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	BCH000800	Charger	362-1 Charger 1	Battery Charger Patrol Insp	As Found Float Voltage	52.9	VDC
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	BCH000800	Charger	362-1 Charger 1	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	BCH000800	Charger	362-1 Charger 1	Battery Charger Patrol Insp	General Comments		
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	BCH000801	Charger	362-2 Charger 2	Battery Charger Patrol Insp	As Found Float Voltage	52.6	VDC
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	BCH000801	Charger	362-2 Charger 2	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	BCH000801	Charger	362-2 Charger 2	Battery Charger Patrol Insp	General Comments		
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	9 Month Operations	9	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Amps A Ø	10.0	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Amps B Ø	10.0	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Amps C Ø	10.0	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Bushing Condition	Good	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Fault Operations A Ø	0	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	92	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Fault Adjusted Amps C Phase V	8.76	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Fault Adjusted Amps B Phase V	8.76	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Patrol Inspection	Bushing Condition	Good	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Amps C Ø	86.0	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	92	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	6	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Readings	General Comments		
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Amps B Ø	114.0	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Amps A Ø	106.0	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Fault Operations A Ø	0	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Fault Operations B Ø	0	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Fault Operations C Ø	0	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Fault Operations Ground	0	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Follow-up Action Required?	n	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Foundation Condition	Good	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	General Comments		
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	General Comments		
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Grounds in Place?	y	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Maintenance Operations	6	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Operations Counter AF	186	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Operations Counter AL	193	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Operations This Read Vac	7	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Switching Operations	1	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Unknown Operations	0	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Regulator As Left Counter	43150	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	9 Month Operations	4	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0194	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	122.8	volts
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1304	Regulator	362-1 C	Regulator Patrol Inspection	General Comments		
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	General Comments		
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Unknown Operations	0	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Switching Operations	0	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Unknown Operations	0	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Switching Operations	0	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Operations This Read Vac	0	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Operations Counter AL	168	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Operations Counter AF	168	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Maintenance Operations	0	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Patrol Inspection	Grounds in Place?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	General Comments		
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Patrol Inspection	General Comments		
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Patrol Inspection	Foundation Condition	Good	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Follow-up Action Required?	n	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Fault Operations Ground	0	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Fault Operations C ∅	0	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Fault Operations B ∅	0	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Fault Operations A ∅	0	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Patrol Inspection	General Comments		
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Follow-up Action Required?	n	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Fault Operations Ground	0	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Fault Operations C ∅	0	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Fault Operations B ∅	0	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Fault Operations A ∅	0	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Amps C ∅	0.0	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Amps B ∅	0.0	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Amps A ∅	0.0	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	9 Months Operations	0	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Readings	Totalizer Meter Reading	0.0000	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Unknown Operations	0	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Patrol Inspection	Bushing Condition	Good	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Amps C Ø	86.0	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Amps B Ø	107.0	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Amps A Ø	99.0	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001331	BreakerVacuum	691-0458	VCB Readings	9 Month Operations	5	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	BAT001440	Battery	362-1 Battery Bank 1	Battery Patrol Inspection	All Connections OK?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1303	Regulator	362-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Fault Operations A Ø	0	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Fault Operations B Ø	0	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Fault Operations C Ø	0	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Fault Operations Ground	0	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Follow-up Action Required?	n	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Foundation Condition	Good	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	General Comments		
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Grounds in Place?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	9 Month Operations	3	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Amps A Ø	19.0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Amps B Ø	34.0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Amps C Ø	27.0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Bushing Condition	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Fault Operations A Ø	0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Fault Operations B Ø	0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Fault Operations C Ø	0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Fault Operations Ground	0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Follow-up Action Required?	n	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Foundation Condition	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	General Comments		
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Maintenance Operations	0	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Operations Counter AF	700	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Operations Counter AL	700	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Readings	Operations This Read Vac	0	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	CB0228	BreakerVacuum	472-0208	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	SWG000107	Switchgear	CT-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Grounds in Place?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Maintenance Operations	0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Operations Counter AF	392	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Operations Counter AL	392	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Operations This Read Vac	1	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Readings	Switching Operations	1	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0267	BreakerVacuum	768-2203	VCB Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Unknown Operations	0	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Switching Operations	0	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Operations This Read AM	0	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Operations Counter AL	523	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Operations Counter AF	523	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Readings	Maintenance Operations	0	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0168	BreakerAirMagnetic	CT-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Fault Operations Ground	1	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Fault Operations C Ø	0	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Fault Operations B Ø	1	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Fault Operations A Ø	1	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Fault Adjusted Amps C Phase V	4.56	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Fault Adjusted Amps B Phase V	9.12	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Fault Adjusted Amps A Phase V	9.12	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	9 Month Operations	4	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Unknown Operations	0	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Switching Operations	10	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Operations This Read Vac	10	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Operations Counter AL	250	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Operations Counter AF	240	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Maintenance Operations	0	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Grounds in Place?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	General Comments		
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	General Comments		
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Foundation Condition	Good	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Follow-up Action Required?	n	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Fault Operations Ground	0	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Fault Operations C Ø	0	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Fault Operations B Ø	0	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Fault Operations A Ø	0	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Bushing Condition	Good	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Amps C Ø	33.0	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Amps B Ø	30.0	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Amps A Ø	35.0	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Patrol Inspection	Bushing Condition	Good	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Amps C Ø	0.0	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Amps B Ø	0.0	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Amps A Ø	0.0	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0116	BreakerVacuum	362-4628	VCB Readings	9 Month Operations	18	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	50	*F
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Operations Counter AL	205	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Operations Counter AF	205	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	Ambient Temp	67	*F
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Maintenance Operations	0	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Grounds in Place?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	General Comments		
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	Vegetation	None	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	YD000531	Yard	472-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	General Comments		
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	General Comments		
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Foundation Condition	Good	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	Follow-up Action Required?	n	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	C0492	LTCMechanism	768-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BAT001424	Battery	768-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BAT001424	Battery	768-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BAT001424	Battery	768-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BAT001424	Battery	768-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BAT001424	Battery	768-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BAT001424	Battery	768-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BAT001424	Battery	768-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BAT001424	Battery	768-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BAT001424	Battery	768-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BAT001424	Battery	768-Battery Bank	Battery Patrol Inspection	General Comments		
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BAT001424	Battery	768-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.0	VDC
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BAT001424	Battery	768-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.0	VDC
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BAT001424	Battery	768-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	General Comments		
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	ST000535	Structure	472-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Patrol Inspection	Bushing Condition	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BAT001424	Battery	768-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Amps C Ø	7.0	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Amps B Ø	10.0	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	K0134	BreakerVacuum	783-2212	VCB Readings	Amps A Ø	7.0	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Amps A Ø	47.0	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	9 Month Operations	9	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Ambient Temp	55	*F
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	General Comments		
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Vegetation	None	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	YD000027	Yard	656-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Fault Operations A Ø	0	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Fault Operations B Ø	0	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Fault Operations C Ø	0	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Fault Operations Ground	0	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Follow-up Action Required?	n	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Foundation Condition	Good	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	General Comments		
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	General Comments		
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Grounds in Place?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Maintenance Operations	0	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Operations Counter AF	536	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Operations Counter AL	536	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Operations This Read Vac	0	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Unknown Operations	0	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Switching Operations	0	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Operations This Read Vac	2	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Operations Counter AL	161	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Operations Counter AF	1612	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Switching Operations	0	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Maintenance Operations	0	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Patrol Inspection	Grounds in Place?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	General Comments	B-C target	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Patrol Inspection	General Comments		
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Patrol Inspection	Foundation Condition	Good	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Follow-up Action Required?	n	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	9 Month Operations	19	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Fault Operations Ground	0	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Fault Operations C Ø	1	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BK001332	BreakerVacuum	691-0459	VCB Readings	Fault Operations B Ø	1	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Amps A Ø	180.0	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Amps B Ø	170.0	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Readings	Amps C Ø	195.0	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Bushing Condition	Good	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000490	BreakerVacuum	127-0060	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Unknown Operations	0	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	General Comments		
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	BAT001295	Battery	CT-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	General Comments		
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	CH000452	ControlHouse	CT-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	9 Month Operations	6	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Accumulated Fault Duty A Ph V	1.93	%
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Accumulated Fault Duty B Ph V	1.93	%
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000734	BreakerVacuum	879-4480	VCB Readings	9 Month Operations	5	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Unknown Operations	0	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Switching Operations	0	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Operations This Read Vac	3	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Operations Counter AL	150	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Operations Counter AF	159	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Maintenance Operations	0	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Grounds in Place?	y	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	General Comments		
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	General Comments		
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Foundation Condition	Good	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Follow-up Action Required?	n	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Fault Operations Ground	1	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Fault Operations C Ø	1	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Fault Operations B Ø	1	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Fault Operations A Ø	0	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Fault Adjusted Amps C Phase V	9.12	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Fault Adjusted Amps B Phase V	9.12	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Fault Adjusted Amps A Phase V	4.56	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Accumulated Fault Duty C Ph V	1.93	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Amps A Ø	220	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	General Comments		
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	ST000771	Structure	362-2 Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Amps B Ø	230	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Readings	Amps C Ø	240	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Bushing Condition	Good	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0438	BreakerVacuum	028-0003	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Vegetation	Needs Attention	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	General Comments	Driveway from bottom gate up to station is overgrown. Brush is scraping the trucks	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	YD000007	Yard	365-Yard	Yard Patrol Inspection	Ambient Temp	55	°F
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Patrol Inspection	Bushing Condition	Good	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Amps C Ø	48.0	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BK000733	BreakerVacuum	879-4479	VCB Readings	Amps B Ø	30.0	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	LTCC000761	LTCControl	879-1	LTC Control Insp	LTC Operation Checked?	y	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	LTCC000761	LTCControl	879-1	LTC Control Insp	General Comments		
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	LTCC000761	LTCControl	879-1	LTC Control Insp	Follow-up Action Required?	n	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	LTCC000761	LTCControl	879-1	LTC Control Insp	All Connections OK?	y	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	LTCC000760	LTCControl	499-1	LTC Control Insp	VRR Time Delay	60	Seconds
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	LTCC000760	LTCControl	499-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	LTCC000760	LTCControl	499-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	LTCC000760	LTCControl	499-1	LTC Control Insp	LTC Output Voltage Level	123.3	VAC
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	LTCC000760	LTCControl	499-1	LTC Control Insp	LTC Operation Checked?	y	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	LTCC000760	LTCControl	499-1	LTC Control Insp	General Comments		
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	LTCC000760	LTCControl	499-1	LTC Control Insp	Follow-up Action Required?	n	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	LTCC000760	LTCControl	499-1	LTC Control Insp	All Connections OK?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	General Comments	Fence has been repaired since vehicle ran through it but need to be fixed permanatly	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	FE000116	Fence	691-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	General Comments		
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	9 Month Operations	6	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Accumulated Fault Duty A Ph V	5.79	%
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Accumulated Fault Duty B Ph V	3.86	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps A Ø	5.0	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps B Ø	5.0	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps C Ø	5.0	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	General Comments		
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Operations Counter	2333	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	CX0118	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Accumulated Fault Duty C Ph V	3.86	%
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	BCH000842	Charger	CT-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	BCH000842	Charger	CT-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.8	VDC
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	BCH000842	Charger	CT-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.8	VDC
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	BCH000842	Charger	CT-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	BCH000842	Charger	CT-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	BCH000842	Charger	CT-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	BCH000842	Charger	CT-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Counter Readings	LTC Current Tap Position	7L	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Counter Readings	LTC As Left Counter	73652	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Counter Readings	LTC As Found Counter	73641	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Mechanism Patrol Inspection	General Comments		
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Counter Readings	General Comments		
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Counter Readings	Follow-up Action Required?	n	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	544	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	412	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	11.2	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	7.6	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	1.7	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	DX0041	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	571	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	LTC Operations Since Last Insp	1173	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	LTC Min Tap Position	8L	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	LTC Max Tap Position	3R	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	LTC Current Tap Position	1L	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	LTC As Left Counter	76830	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	LTC As Found Counter	76827	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	General Comments		
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	General Comments		
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	LTCM000025	LTCMechanism	472-1	LTC Counter Readings	Follow-up Action Required?	n	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	General Comments		
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	FE000032	Fence	656-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	ST000027	Structure	656-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	LTCC000761	LTCControl	879-1	LTC Control Insp	VRR Time Delay	45	Seconds
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	LTCC000761	LTCControl	879-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	LTCC000761	LTCControl	879-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	LTCC000761	LTCControl	879-1	LTC Control Insp	Parallel / Ind. Sw Position	parallellND	Position
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	LTCC000761	LTCControl	879-1	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3240	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Fault Operations A ∅	0	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Fault Operations B ∅	0	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Fault Operations C ∅	0	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Fault Operations Ground	0	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Follow-up Action Required?	n	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Foundation Condition	Good	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	General Comments		
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	General Comments		
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Grounds in Place?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Maintenance Operations	0	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Operations Counter AF	245	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Operations Counter AL	245	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	2182	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	LTC Min Tap Position	6L	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1L	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6L	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	LTC As Left Counter	474985	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	LTC As Found Counter	474972	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	General Comments	T.C. at L6 120.1 volt. AC breaker to T.C. was triped. 16 hours later it has operated 13 times.	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN53	LTCMechanism	CT-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Operations This Read Vac	0	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	Oil Temp Max	70	°C
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	777.60	kw
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Switching Operations	0	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Unknown Operations	0	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	General Comments	-1 psi as found. adding nitrgoen to make positive 2psi	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	2516	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	LTC Min Tap Position	9L	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	General Comments		
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	LTC Max Tap Position	2L	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	LTC Current Tap Position	8L	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	LTC As Left Counter	482531	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	LTC As Found Counter	482531	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	General Comments		
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Amps A Ø	125	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Amps B Ø	130	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Readings	Amps C Ø	115	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0082	BreakerVacuum	028-0006	VCB Patrol Inspection	Bushing Condition	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000572	LTCControl	768-2	LTC Control Insp	All Connections OK?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000572	LTCControl	768-2	LTC Control Insp	Follow-up Action Required?	n	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000572	LTCControl	768-2	LTC Control Insp	General Comments		
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000572	LTCControl	768-2	LTC Control Insp	LTC Operation Checked?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000572	LTCControl	768-2	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000572	LTCControl	768-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000572	LTCControl	768-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000572	LTCControl	768-2	LTC Control Insp	VRR Time Delay	30	Seconds
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	General Comments	counter not working	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BCH001334	Charger	691-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BCH001334	Charger	691-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BCH001334	Charger	691-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BCH001334	Charger	691-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BCH001334	Charger	691-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BCH001334	Charger	691-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Regulator As Left Counter	375611	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	MR0079	Regulator	383-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	9 Month Operations	3	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Amps A Ø	135.0	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Amps B Ø	110.0	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Amps C Ø	125.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Bushing Condition	Good	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Fault Adjusted Amps A Phase V	6.41	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Fault Adjusted Amps B Phase V	6.41	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Fault Adjusted Amps C Phase V	6.41	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Fault Operations A Ø	0	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Fault Operations B Ø	0	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Fault Operations C Ø	0	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Fault Operations Ground	0	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Follow-up Action Required?	n	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Foundation Condition	Good	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	General Comments		
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	General Comments		
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Grounds in Place?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Maintenance Operations	0	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Operations Counter AF	197	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Operations Counter AL	197	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Operations This Read Vac	1	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Switching Operations	0	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BK000924	BreakerVacuum	526-0129	VCB Readings	Unknown Operations	1	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Unknown Operations	0	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Switching Operations	0	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Operations This Read AM	0	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Operations Counter AL	618	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Operations Counter AF	618	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Maintenance Operations	0	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	General Comments		
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Patrol Inspection	General Comments		
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Follow-up Action Required?	n	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Fault Operations Ground	0	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Fault Operations C Ø	0	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Fault Operations B Ø	0	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Fault Operations A Ø	0	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Readings	General Comments		
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Readings	LTC Totalizer Reading	6733.6	kw
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000085	LTCControl	768-3	LTC Control Insp	All Connections OK?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000085	LTCControl	768-3	LTC Control Insp	Follow-up Action Required?	n	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000085	LTCControl	768-3	LTC Control Insp	General Comments		
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000085	LTCControl	768-3	LTC Control Insp	LTC Operation Checked?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000085	LTCControl	768-3	LTC Control Insp	LTC Output Voltage Level	123.4	VAC
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000085	LTCControl	768-3	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000085	LTCControl	768-3	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	LTCC000085	LTCControl	768-3	LTC Control Insp	VRR Time Delay	30	Seconds
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Counter Readings	LTC Operations Since Last Insp	611	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Counter Readings	LTC Min Tap Position	8L	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Counter Readings	LTC Max Tap Position	Neutral	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Counter Readings	LTC Current Tap Position	8L	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Counter Readings	LTC As Left Counter	14232	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Counter Readings	LTC As Found Counter	14228	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Mechanism Patrol Inspection	General Comments		
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Counter Readings	General Comments		
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0345	LTCMechanism	028-5	LTC Counter Readings	Follow-up Action Required?	n	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Counter Readings	Follow-up Action Required?	n	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Mechanism Patrol Inspection	General Comments		
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Counter Readings	General Comments	LTC is off	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Counter Readings	LTC As Found Counter	407686	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Counter Readings	LTC As Left Counter	407686	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Counter Readings	LTC Current Tap Position	9L	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Counter Readings	LTC Max Tap Position	1L	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Counter Readings	LTC Min Tap Position	16L	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Counter Readings	LTC Operations Since Last Insp	0	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	C0406	LTCMechanism	629-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Broom on Site?	n	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Door Alarms OK?	n	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Readings	Oil Temp Max	60	°C
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Readings	Oil Temp Present	35	°C
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	n	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Floor Swept?	n	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	General Comments	Heater not working/ made work order to install heater.	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Trash Emptied?	n	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	CH000406	ControlHouse	691-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Readings	Totalizer Meter Reading	.8417	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	General Comments		
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/2/2020 12:40	Distribution	Kentonia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/2/2020 12:40	Distribution	Kentonia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	General Comments	trees over hang right side of fence	
10/2/2020 12:40	Distribution	Kentonia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/2/2020 12:40	Distribution	Kentonia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
10/2/2020 12:40	Distribution	Kentonia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/2/2020 12:40	Distribution	Kentonia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
10/2/2020 12:40	Distribution	Kentonia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 12:40	Distribution	Kentonia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/2/2020 12:40	Distribution	Kentonia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/2/2020 12:40	Distribution	Kentonia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/2/2020 12:40	Distribution	Kentonia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/2/2020 12:40	Distribution	Kentonia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/2/2020 12:40	Distribution	Kentonia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/2/2020 12:40	Distribution	Kentonia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
10/2/2020 12:40	Distribution	Kentonia Quarterly Inspection	FE000084	Fence	499-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/2/2020 12:40	Distribution	Kentonia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 12:40	Distribution	Kentonia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	FE000526	Fence	472-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Operations Counter	11	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	General Comments		
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Amps C Ø	63.0	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Amps B Ø	55.0	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	DX0128	RecloserElectronic	499-0422	Recloser Electronic Patrol Inspection	Amps A Ø	48.0	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	General Comments		
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Vegetation	None	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	YD000085	Yard	564-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Readings	Follow-up Action Required?	n	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0345	WithLTC	028-5	LTC Transformer Patrol Inspection	General Comments		
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Operations Counter	16	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	General Comments		
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	Oil Temp Present	30	°C
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	Oil Temp Max	45	°C
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	General Comments		
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	General Comments		
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Amps C Ø	23.0	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Amps B Ø	14.0	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	MX0470	RecloserElectronic	499-0423	Recloser Electronic Patrol Inspection	Amps A Ø	9.0	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	General Comments		
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Counter Readings	LTC Operations Since Last Insp	577	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Counter Readings	LTC Min Tap Position	4L	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	B0309	LTCMechanism	080-5	LTC Counter Readings	LTC Max Tap Position	2R	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Regulator As Left Counter	10090	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	General Comments		
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Readings	Totalizer Meter Multiplier	2800	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Counter Readings	Follow-up Action Required?	n	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Counter Readings	General Comments		
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Mechanism Patrol Inspection	General Comments		
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Counter Readings	LTC As Found Counter	254170	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Counter Readings	LTC As Left Counter	254179	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	General Comments		
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	ST000091	Structure	564-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	380	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	343	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	21.0	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	39.0	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	26.0	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	MX0167	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	408	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	52	*F
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BAT000530	Battery	526-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Operations Counter	432	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	General Comments		
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Counter Readings	LTC Current Tap Position	6L	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Counter Readings	LTC Max Tap Position	2R	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Counter Readings	LTC Min Tap Position	11L	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	MX0471	RecloserHydraulic	629-0469	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Counter Readings	LTC Operations Since Last Insp	736	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	0988	LTCMechanism	842-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	C0406	WithLTC	629-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	SWG000027	Switchgear	CT-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Follow-up Action Required?	n	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Foundation Condition	Good	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	General Comments		
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	General Comments		
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Grounds in Place?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Maintenance Operations	0	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Ambient Temp	60	*F
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	General Comments		
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Vegetation	None	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	YD000068	Yard	879-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	All Identified and Legible?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	General Comments		
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Operations Counter AF	300	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Operations Counter AL	309	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Operations This Read Vac	9	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Switching Operations	9	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Unknown Operations	0	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	ST000076	Structure	879-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Current Tap Position	9L	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Current Tap Position	9L	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Amps A Ø	0.0	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Amps B Ø	0.0	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Amps C Ø	0.0	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	General Comments	wire on top of fence is rusty, trees over hanging fence.	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Fault Operations A Ø	0	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Fault Operations B Ø	0	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Fault Operations C Ø	0	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Fault Operations Ground	0	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Follow-up Action Required?	n	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Patrol Inspection	General Comments		
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	FE000087	Fence	564-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Unknown Operations	0	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Switching Operations	0	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Operations This Read Vac	0	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Operations Counter AL	202	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Operations Counter AF	202	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Maintenance Operations	0	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Grounds in Place?	y	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	General Comments		
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	General Comments		
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Maintenance Operations	0	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Operations Counter AF	327	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Operations Counter AL	327	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Operations This Read AM	0	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Switching Operations	0	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Unknown Operations	0	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Vegetation	None	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	General Comments	A little bit of vegetation is starting to grow in the station.	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	YD000008	Yard	629-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	9 Month Operations	19	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Amps A Ø	0.0	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Amps B Ø	0.0	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Amps C Ø	0.0	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Bushing Condition	Good	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Fault Operations A Ø	0	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Fault Operations B Ø	0	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Fault Operations C Ø	0	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	K0121	BreakerVacuum	362-3622	VCB Readings	Fault Operations Ground	0	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2020 12:40	Distribution	Kentonia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/2/2020 12:40	Distribution	Kentonia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	General Comments		
10/2/2020 12:40	Distribution	Kentonia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/2/2020 12:40	Distribution	Kentonia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
10/2/2020 12:40	Distribution	Kentonia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/2/2020 12:40	Distribution	Kentonia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/2/2020 12:40	Distribution	Kentonia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/2/2020 12:40	Distribution	Kentonia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
10/2/2020 12:40	Distribution	Kentonia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Fault Operations A Ø	0	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Bushing Condition	Good	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Amps C Ø	150.0	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Amps B Ø	140.0	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Amps A Ø	180.0	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	9 Month Operations	10	
10/2/2020 12:40	Distribution	Kentonia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/2/2020 12:40	Distribution	Kentonia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/2/2020 12:40	Distribution	Kentonia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/2/2020 12:40	Distribution	Kentonia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/2/2020 12:40	Distribution	Kentonia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
10/2/2020 12:40	Distribution	Kentonia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/2/2020 12:40	Distribution	Kentonia Quarterly Inspection	ST000088	Structure	499-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	Totalizer Meter Reading	.2160	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	M0091	WithLTC	691-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	9 Months Operations	0	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0167	BreakerAirMagnetic	CT-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	B0444	WithLTC	768-3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/2/2020 12:40	Distribution	Kentonia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	Follow-up Action Required?	n	
10/2/2020 12:40	Distribution	Kentonia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 12:40	Distribution	Kentonia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	General Comments		
10/2/2020 12:40	Distribution	Kentonia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Mechanism Patrol Inspection	General Comments		
10/2/2020 12:40	Distribution	Kentonia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	LTC As Found Counter	279775	
10/2/2020 12:40	Distribution	Kentonia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	LTC As Left Counter	279788	
10/2/2020 12:40	Distribution	Kentonia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/2/2020 12:40	Distribution	Kentonia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	LTC Current Tap Position	9L	
10/2/2020 12:40	Distribution	Kentonia Quarterly Inspection	M0054	LTCMechanism	499-1	LTC Counter Readings	LTC Max Tap Position	4L	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	General Comments		
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Max Tap Position	6L	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Min Tap Position	14L	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	General Comments	25 foot wood arm, that is the backside of the double arm of the line is rotten and needs replaced. Cross arm is now broken and hangi	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Follow-up Action Required?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	ST000009	Structure	365-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	General Comments		
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	FE000009	Fence	365-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	Totalizer Meter Reading	.2460	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Regulator As Left Counter	163690	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1175	Regulator	365-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	Oil Temp Present	45	°C
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2361.60	kw
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	General Comments		
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Foundation Condition	Good	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Follow-up Action Required?	n	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Fault Operations Ground	0	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Fault Operations C Ø	0	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0187	BreakerVacuum	842-0454	VCB Readings	Fault Operations B Ø	0	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	General Comments		
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	General Comments		
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	S0020	NonLTC	783-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Amps A Ø	55.0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	9 Month Operations	0	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Current Tap Position	9L	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	LTCC000824	LTCControl	691-1	LTC Control Insp	VRR Time Delay	60	Seconds
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	LTCC000824	LTCControl	691-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	LTCC000824	LTCControl	691-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	LTCC000824	LTCControl	691-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	LTCC000824	LTCControl	691-1	LTC Control Insp	LTC Operation Checked?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	LTCC000824	LTCControl	691-1	LTC Control Insp	General Comments		
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	LTCC000824	LTCControl	691-1	LTC Control Insp	Follow-up Action Required?	n	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	LTCC000824	LTCControl	691-1	LTC Control Insp	All Connections OK?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	9 Month Operations	2	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Amps A Ø	33.0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Amps B Ø	37.0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Amps C Ø	29.0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Bushing Condition	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Fault Operations A Ø	0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Fault Operations B Ø	0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Fault Operations C Ø	0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Fault Operations Ground	0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Follow-up Action Required?	n	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Foundation Condition	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	General Comments		
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	General Comments		
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Grounds in Place?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Maintenance Operations	0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Operations Counter AF	339	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Operations Counter AL	339	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Operations This Read Vac	0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Switching Operations	0	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	91	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	8	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	General Comments		
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Readings	General Comments		
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN38	LTCMechanism	CT-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Switching Operations	0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Operations This Read Vac	0	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	91	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Operations Counter AL	162	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Operations Counter AF	162	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Maintenance Operations	0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	Grounds in Place?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	M0003	NonLTC	564-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Amps C Ø	150.0	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Amps B Ø	130.0	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Amps A Ø	220.0	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0166	BreakerAirMagnetic	CT-2	AMCB Readings	9 Months Operations	0	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Regulator As Left Counter	4948	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Min Tap Position	14L	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Max Tap Position	5L	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	General Comments		
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	General Comments		
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	General Comments		
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	Foundation Condition	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Follow-up Action Required?	n	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1105	Regulator	365-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Fault Operations Ground	0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Fault Operations C Ø	0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Fault Operations B Ø	0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Fault Operations A Ø	0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Patrol Inspection	Bushing Condition	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Amps C Ø	66.0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001341	BreakerVacuum	768-3	VCB Readings	Amps B Ø	66.0	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	679	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	49	*F
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Fault Operations A Ø	0	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Fault Operations B Ø	0	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Fault Operations C Ø	0	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Fault Operations Ground	0	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Follow-up Action Required?	n	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Foundation Condition	Good	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	General Comments		
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	General Comments		
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Grounds in Place?	y	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Maintenance Operations	2	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Operations Counter AF	161	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Operations Counter AL	164	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Operations This Read Vac	3	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Exp/Missing Not Repl	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	General Comments		
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	BAT001243	Battery	842-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Switching Operations	1	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Unknown Operations	0	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Regulator As Left Counter	113742	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	9 Months Operations	0	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0171	BreakerAirMagnetic	CT-5	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Max Tap Position	12L	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	General Comments		
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	General Comments		
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	BAT001056	Battery	691-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0923	Regulator	564-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Current Tap Position	1R	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0795	Regulator	564-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	FE000110	Fence	383-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	120	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	140	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0195	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	120	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0268	BreakerVacuum	768-2204	VCB Readings	Unknown Operations	0	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	9 Month Operations	3	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Amps A Ø	735.0	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Amps B Ø	720.0	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Amps C Ø	770.0	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Bushing Condition	Good	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	General Comments		
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	General Comments		
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	LTC Totalizer Reading	4660.80	kw
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	Oil Temp Max	56	°C
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	Oil Temp Present	33	°C
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	Totalizer Meter Reading	.9710	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	M0054	WithLTC	499-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK000246	BreakerVacuum	127-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	General Comments		
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	92	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	310	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	MX0349	RecloserHydraulic	365-0665	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Fault Operations A Ø	0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Patrol Inspection	Bushing Condition	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Amps C Ø	63.0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Amps B Ø	69.0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Amps A Ø	75.0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	9 Month Operations	0	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Patrol Inspection	Bushing Condition	Good	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Amps C Ø	75.0	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Amps B Ø	65.0	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	9 Month Operations	1	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Amps A Ø	144.0	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Amps B Ø	140.0	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Amps C Ø	153.0	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Bushing Condition	Good	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Counter Readings	Follow-up Action Required?	n	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Counter Readings	General Comments		
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Mechanism Patrol Inspection	General Comments		
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Counter Readings	LTC As Found Counter	69955	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Counter Readings	LTC As Left Counter	69961	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Counter Readings	LTC Current Tap Position	6L	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Counter Readings	LTC Min Tap Position	8L	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Counter Readings	LTC Operations Since Last Insp	1245	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	M0081	LTCMechanism	879-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Fault Operations A Ø	0	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Fault Operations B Ø	0	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Fault Operations C Ø	0	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Follow-up Action Required?	n	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Foundation Condition	Good	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	General Comments		
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	General Comments		
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Patrol Inspection	Grounds in Place?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	BK000574	BreakerVacuum	472-0206	VCB Readings	Maintenance Operations	0	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	General Comments		
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Ambient Temp	55	*F
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Fault Adjusted Amps B Phase V	9.07	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Fault Operations A Ø	0	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Fault Operations B Ø	1	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Fault Operations C Ø	0	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Fault Operations Ground	0	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Follow-up Action Required?	n	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Foundation Condition	Good	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	General Comments		
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	General Comments	B-C Timed targets reset.	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Grounds in Place?	y	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Maintenance Operations	0	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Operations Counter AF	338	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Operations Counter AL	338	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Operations This Read Vac	1	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Switching Operations	0	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Unknown Operations	0	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	General Comments		
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Vegetation	None	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	YD000117	Yard	691-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	FE000078	Fence	362-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Unknown Operations	0	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Switching Operations	1	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Operations This Read Vac	4	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Operations Counter AL	181	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Operations Counter AF	177	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Maintenance Operations	3	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Patrol Inspection	Grounds in Place?	y	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	General Comments		
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Patrol Inspection	General Comments		
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Patrol Inspection	Foundation Condition	Good	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Follow-up Action Required?	n	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Fault Operations Ground	0	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Fault Operations C Ø	0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Fault Operations B Ø	0	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Fault Operations A Ø	0	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Unknown Operations	0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Switching Operations	0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Operations This Read Vac	0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Operations Counter AL	165	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Operations Counter AF	165	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Patrol Inspection	Grounds in Place?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	General Comments		
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Patrol Inspection	General Comments		
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Patrol Inspection	Foundation Condition	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Follow-up Action Required?	n	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Fault Operations Ground	0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Fault Operations C Ø	0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001278	BreakerVacuum	768-2234	VCB Readings	Fault Operations B Ø	0	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK001606	BreakerVacuum	127-0059	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	9 Month Operations	0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Bushing Condition	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Amps C Ø	83.0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Amps B Ø	77.0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Amps A Ø	91.0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Counter Readings	LTC Operations Since Last Insp	684	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Counter Readings	LTC Min Tap Position	16L	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Counter Readings	LTC Max Tap Position	7L	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Counter Readings	LTC Current Tap Position	7L	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	9 Month Operations	1	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Fault Operations A Ø	0	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Patrol Inspection	Bushing Condition	Good	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Amps C Ø	270.0	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Amps B Ø	255.0	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Amps A Ø	250.0	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Counter Readings	LTC As Left Counter	50321	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Counter Readings	LTC As Found Counter	50321	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Mechanism Patrol Inspection	General Comments		
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Counter Readings	General Comments		
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	B0397	LTCMechanism	526-1	LTC Counter Readings	Follow-up Action Required?	n	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Counter Readings	Follow-up Action Required?	n	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Counter Readings	General Comments		
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Mechanism Patrol Inspection	General Comments		
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Counter Readings	LTC As Found Counter	7604	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Counter Readings	LTC As Left Counter	7613	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Counter Readings	LTC Current Tap Position	6L	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Counter Readings	LTC Max Tap Position	2R	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Counter Readings	LTC Min Tap Position	13L	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Unknown Operations	0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Switching Operations	1	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Operations This Read Vac	1	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Operations Counter AL	152	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Maintenance Operations	0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Grounds in Place?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	General Comments		
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	General Comments		
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Foundation Condition	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Follow-up Action Required?	n	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Fault Operations Ground	0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Fault Operations C Ø	0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Fault Operations B Ø	0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001277	BreakerVacuum	768-2205	VCB Readings	Fault Operations A Ø	0	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Patrol Inspection	Bushing Condition	Good	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Amps C Ø	160.0	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Amps B Ø	160.0	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	CB0191	BreakerVacuum	472-1	VCB Readings	Amps A Ø	160.0	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	Follow-up Action Required?	n	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	General Comments		
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	General Comments		
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	LTC Totalizer Reading	23814.00	kw
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	General Comments		
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	Oil Temp Max	60	°C
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	Oil Temp Present	40	°C
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	69	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	69	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	416	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	1	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Fault Operations A Ø	0	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Fault Operations B Ø	0	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Fault Operations C Ø	0	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Fault Operations Ground	0	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Follow-up Action Required?	n	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Foundation Condition	Good	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	General Comments		
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	General Comments		
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Grounds in Place?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Maintenance Operations	0	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Operations Counter AF	217	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Operations Counter AL	217	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Operations This Read Vac	0	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Switching Operations	0	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Unknown Operations	0	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	RO882	Regulator	564-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Amps A Ø	14.0	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Amps B Ø	15.0	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Amps C Ø	15.0	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	General Comments	27.2/24.9	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Operations Counter	11	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	General Comments		
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/2/2020 14:59	Distribution	Totz Quarterly Inspection	KX0237	RecloserElectronic	656-0468	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Regulator As Left Counter	478312	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Min Tap Position	3L	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	General Comments		
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 9:24	Distribution	Bailey Creek Quarterly Inspection	R0882	Regulator	564-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	General Comments		
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	BCH000262	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.270	millivolts
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	BCH000262	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	BCH000262	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	BCH000262	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	BCH000262	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	BCH000262	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Vegetation	None	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	General Comments		
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	YD000523	Yard	783-Yard	Yard Patrol Inspection	Ambient Temp	65	*F
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	BCH000262	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
10/2/2020 10:26	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2020 10:26	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2020 10:26	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	9 Month Operations	225	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Ambient Temp	67	*F
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	General Comments		
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Vegetation	None	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	YD000111	Yard	383-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Vegetation	None	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	General Comments		
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	9 Month Operations	10	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Amps A Ø	30.0	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Amps B Ø	30.0	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Amps C Ø	60.0	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Bushing Condition	Good	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	FE000531	Fence	768-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	K0089	BreakerVacuum	842-0455	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	YD000078	Yard	362-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	ST000121	Structure	691-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	Totalizer Meter Reading	1.3230	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	Winding Temp Max	60	°C
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	Winding Temp Present	40	°C
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	B0376	WithLTC	127-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/2/2020 10:26	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Unknown Operations	0	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	General Comments		
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/2/2020 10:26	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 10:26	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Switching Operations	0	
10/2/2020 10:26	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/2/2020 10:26	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Operations This Read Vac	223	
10/2/2020 10:26	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Operations Counter AL	223	
10/2/2020 10:26	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Operations Counter AF	223	
10/2/2020 10:26	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 10:26	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Maintenance Operations	223	
10/2/2020 10:26	Distribution	Evarts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Heaters (All) Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Grounds in Place?	y	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	General Comments		
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	General Comments		
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Foundation Condition	Good	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Follow-up Action Required?	n	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Fault Operations Ground	0	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Fault Operations C Ø	0	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Fault Operations B Ø	0	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Fault Operations A Ø	0	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	ST000528	Structure	783-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Patrol Inspection	Bushing Condition	Good	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Amps C Ø	17.0	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Amps B Ø	24.0	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Amps A Ø	39.0	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	KB0038	BreakerVacuum	080-4476	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	ST000540	Structure	768-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	General Comments		
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Vegetation	None	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	General Comments		
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	YD000101	Yard	842-Yard	Yard Patrol Inspection	Ambient Temp	49	°F
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Trash Emptied?	n	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	General Comments	Several Wasp in the house, did not have any spray with me. Heater was off and turned on.	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Floor Swept?	n	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Evidence of Insects	Yes_needs_sprayed	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	CH000025	ControlHouse	842-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Current Tap Position	11L	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	General Comments		
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Max Tap Position	7L	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Min Tap Position	14L	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	9 Month Operations	5	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	General Comments		
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	Oil Temp Present	30	°C
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	Oil Temp Max	40	°C
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Unknown Operations	0	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Switching Operations	0	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Operations This Read AM	0	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Operations Counter AL	378	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Operations Counter AF	378	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Maintenance Operations	0	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	General Comments		
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Patrol Inspection	General Comments		
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Follow-up Action Required?	n	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Fault Operations Ground	0	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Fault Operations C ∅	0	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Fault Operations B ∅	0	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Fault Operations A ∅	0	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Amps C ∅	200.0	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Amps B ∅	200.0	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Amps A ∅	200.0	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	LB0165	BreakerAirMagnetic	CT-1	AMCB Readings	9 Months Operations	0	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	General Comments		
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	General Comments		
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Max Tap Position	13L	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Min Tap Position	2R	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Regulator As Left Counter	98536	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1326	Regulator	783-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	ST000107	Structure	842-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Patrol Inspection	General Comments		
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Patrol Inspection	Foundation Condition	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Follow-up Action Required?	n	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Fault Operations Ground	0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Fault Operations C ∅	0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Fault Operations B ∅	0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Fault Operations A ∅	0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	Follow-up Action Required?	n	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	General Comments		
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Mechanism Patrol Inspection	General Comments		
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	LTC As Found Counter	36780	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	LTC As Left Counter	36784	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	LTC Current Tap Position	4R	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	LTC Max Tap Position	12L	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	LTC Min Tap Position	1R	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	LTC Operations Since Last Insp	153	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	B0444	LTCMechanism	768-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	9 Month Operations	2	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Accumulated Fault Duty A Ph V	0	%
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Accumulated Fault Duty B Ph V	0	%
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Accumulated Fault Duty C Ph V	0	%
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Amps A ∅	0	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Amps B ∅	0	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Amps C ∅	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Bushing Condition	Good	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Fault Operations A Ø	0	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Patrol Inspection	Bushing Condition	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Amps C Ø	209.0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Amps B Ø	224.0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Amps A Ø	258.0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Fault Operations B Ø	0	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Fault Operations C Ø	0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	9 Month Operations	1	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Unknown Operations	0	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Switching Operations	0	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Operations This Read Vac	0	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Operations Counter AL	334	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Operations Counter AF	334	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Maintenance Operations	0	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Grounds in Place?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	General Comments		
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	General Comments		
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Foundation Condition	Good	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Follow-up Action Required?	n	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	K0081	BreakerVacuum	028-0002	VCB Readings	Fault Operations Ground	0	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Vegetation	None	
10/2/2020 12:40	Distribution	Kentenia Quarterly Inspection	YD000082	Yard	499-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	127	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	199	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	445	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Regulator As Left Counter	204831	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	R1173	Regulator	365-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Amps A Ø	0.0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Amps B Ø	0.0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Amps C Ø	0.0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Bushing Condition	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Fault Operations A Ø	0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Fault Operations B Ø	0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Fault Operations C Ø	0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Fault Operations Ground	0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Foundation Condition	Good	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	General Comments		
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	General Comments		
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	General Comments		
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Grounds in Place?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Maintenance Operations	0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Operations Counter AF	267	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Operations Counter AL	267	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Operations This Read Vac	1	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Switching Operations	1	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	LTCC000592	LTCControl	472-1	LTC Control Insp	All Connections OK?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	LTCC000592	LTCControl	472-1	LTC Control Insp	Follow-up Action Required?	n	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	LTCC000592	LTCControl	472-1	LTC Control Insp	General Comments		
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	LTCC000592	LTCControl	472-1	LTC Control Insp	LTC Operation Checked?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	LTCC000592	LTCControl	472-1	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	LTCC000592	LTCControl	472-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	LTCC000592	LTCControl	472-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	FE000635	Fence	CT-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Unknown Operations	0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Switching Operations	1	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Operations This Read Vac	1	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	LTCC000592	LTCControl	472-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Operations Counter AL	178	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	CB0266	BreakerVacuum	768-BT3-2	VCB Readings	Unknown Operations	0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Operations Counter AF	178	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	Maintenance Operations	0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Patrol Inspection	Grounds in Place?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001264	BreakerVacuum	768-2	VCB Readings	General Comments		
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Current Tap Position	7L	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	General Comments		
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Max Tap Position	14L	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Min Tap Position	1R	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Regulator As Left Counter	103896	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	LTCC000314	LTCControl	629-1	LTC Control Insp	All Connections OK?	y	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	LTCC000314	LTCControl	629-1	LTC Control Insp	Follow-up Action Required?	n	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	LTCC000314	LTCControl	629-1	LTC Control Insp	General Comments	LTC is off	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	LTCC000314	LTCControl	629-1	LTC Control Insp	LTC Operation Checked?	n	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	LTCC000314	LTCControl	629-1	LTC Control Insp	LTC Output Voltage Level	0.0	VAC
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	LTCC000314	LTCControl	629-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	LTCC000314	LTCControl	629-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	LTCC000314	LTCControl	629-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	LTCC000314	LTCControl	629-1	LTC Control Insp	VRR Time Delay	60	Seconds
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	LTCC000396	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	LTCC000396	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	LTCC000396	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	LTCC000396	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	LTCC000396	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.2	VAC
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	LTCC000396	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	LTCC000396	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	LTCC000396	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	LTCC000396	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	60	Seconds
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	59	*F
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	General Comments		
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Negative DC Ground	12.4	VDC
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Positive DC Ground	12.6	VDC
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BAT000156	Battery	879-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	9 Month Operations	3	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Amps A Ø	100.0	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Amps B Ø	81.0	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Amps C Ø	80.0	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Bushing Condition	Good	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Fault Operations A Ø	0	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Fault Operations B Ø	0	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Fault Operations C Ø	0	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Fault Operations Ground	0	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Follow-up Action Required?	n	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Foundation Condition	Good	
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	General Comments		
10/2/2020 10:26	Distribution	Everts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	General Comments	one settings change and matest on 9/30/20	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Patrol Inspection	Bushing Condition	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Amps C Ø	56.0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Amps B Ø	71.0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Amps A Ø	87.0	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	BK001276	BreakerVacuum	768-0233	VCB Readings	9 Month Operations	1	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Counter Readings	LTC Operations Since Last Insp	850	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/2/2020 11:59	Distribution	Cloverlick Quarterly Inspection	M0091	LTCMechanism	691-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	FE000853	Fence	842-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	FE000853	Fence	842-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	FE000853	Fence	842-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	FE000853	Fence	842-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	FE000853	Fence	842-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	FE000853	Fence	842-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	FE000853	Fence	842-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	FE000853	Fence	842-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	FE000853	Fence	842-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	FE000853	Fence	842-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	FE000853	Fence	842-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	FE000853	Fence	842-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	FE000853	Fence	842-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	FE000853	Fence	842-Fence	Fence Patrol Inspection	General Comments		
10/2/2020 10:40	Distribution	Cumberland Quarterly Inspection	FE000853	Fence	842-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BK001605	BreakerVacuum	127-0055	VCB Readings	9 Month Operations	35	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Vegetation	None	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	General Comments		
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	YD000536	Yard	768-Yard	Yard Patrol Inspection	Ambient Temp	65	*F
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	General Comments		
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/2/2020 12:23	Distribution	Jacks Creek Quarterly Inspection	ST000033	Structure	629-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 12:39	Distribution	Greensburg Quarterly Inspection	R1327	Regulator	783-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	Totalizer Meter Reading	.5780	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	Winding Temp Max	42	°C
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	Winding Temp Present	36	°C
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	110.00	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	40	°C
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	60	°C
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	Winding Temp Present	30	°C
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	Winding Temp Max	50	°C
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	Totalizer Meter Reading	.8250	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Positive DC Ground	23.0	VDC
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Negative DC Ground	33.0	VDC
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	General Comments		
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	BAT001126	Battery	472-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	Oil Temp Present	30	°C
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	Oil Temp Max	65	°C
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	LTC Totalizer Reading	11880.00	kw
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	General Comments		
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	General Comments		
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	B0397	WithLTC	526-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	40	°C
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	60	°C
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	40	°C
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	60	°C
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN38	WithLTC	CT-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 10:26	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Grounds in Place?	y	
10/2/2020 10:26	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Maintenance Operations	1	
10/2/2020 10:26	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 10:26	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Operations Counter AF	226	
10/2/2020 10:26	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Operations Counter AL	226	
10/2/2020 10:26	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Operations This Read Vac	1	
10/2/2020 10:26	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Switching Operations	0	
10/2/2020 10:26	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 10:26	Distribution	Evarts Quarterly Inspection	BK000589	BreakerVacuum	080-4475	VCB Readings	Unknown Operations	0	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Ambient Temp	52	°F
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Clear of Trash?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	General Comments		
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Vegetation	None	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	YD000345	Yard	526-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	Percent Thermal Load C Ø Max	-60	%
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	Percent Thermal Load B Ø Max	-60	%
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	Percent Thermal Load A Ø Max	-60	%
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	General Comments	Recloser is open along with line side disconnects	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	MX0059	RecloserHydraulic	383-4631	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	Oil Temp Present	25	°C
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	General Comments		
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/2/2020 8:32	Distribution	Carter Quarterly Inspection	PN53	WithLTC	CT-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	General Comments		
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	General Comments		
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	LTC Totalizer Reading	10404.00	kw
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	Oil Temp Max	45	°C
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Readings	Oil Temp Present	35	°C
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/2/2020 13:18	Distribution	Campbellsville 1 Quarterly Inspection	C0492	WithLTC	768-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	LTC As Found Counter	16504	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	LTC As Left Counter	16509	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	LTC Current Tap Position	2L	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	LTC Max Tap Position	16R	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	LTC Min Tap Position	5L	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.5	psi

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	LTC Operations Since Last Insp	29	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	Totalizer Meter Reading	.0894	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Foundation Condition	Good	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Follow-up Action Required?	n	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	Oil Temp Present	32	°C
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	310.0	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	290.0	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	280.0	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	Oil Temp Max	47	°C
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0290	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	0	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	214.56	kw
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	General Comments	Added Nitrogen	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	General Comments		
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	General Comments		
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Fault Operations B Ø	0	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Fault Operations C Ø	0	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Fault Operations Ground	0	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Follow-up Action Required?	n	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Foundation Condition	Good	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	General Comments		
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	General Comments		
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Grounds in Place?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Maintenance Operations	0	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Operations Counter AF	76	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Operations Counter AL	76	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Operations This Read Vac	0	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Unknown Operations	0	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	General Comments		
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	LTC Totalizer Reading	2203.20	kw
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	Oil Temp Present	33	°C
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	General Comments		
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	General Comments		
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	Totalizer Meter Reading	.0060	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Maintenance Operations	14	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Grounds in Place?	y	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	General Comments		
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BCH000206	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BCH000206	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	General Comments		
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	Follow-up Action Required?	n	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	General Comments		
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Mechanism Patrol Inspection	General Comments		
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BCH000206	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.1	amps
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BCH000206	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	45	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Readings	Totalizer Meter Reading	.224	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BCH000206	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	BCH000206	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	66.000	millivolts
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Bushing Condition	Good	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Amps C Ø	250.0	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Amps B Ø	240.0	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Amps A Ø	245.0	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	9 Month Operations	20	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	B0376	LTCMechanism	127-5	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Readings	Oil Temp Present	30	°C
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Readings	Oil Temp Max	45	°C
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BCH000372	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BCH000372	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BCH000372	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BCH000372	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BCH000372	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BCH000372	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Readings	LTC Totalizer Reading	1792	kw
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Readings	Follow-up Action Required?	n	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	General Comments		
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Readings	General Comments		
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	B0342	WithLTC	028-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	B0263	NonLTC	383-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	437.40	kw
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	General Comments		
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	General Comments		
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	General Comments		
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	ST000066	Structure	362-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	Totalizer Meter Reading	.2430	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1800	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	FE000341	Fence	526-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.1	volts
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	General Comments		
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Current Tap Position	Neutral	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Fault Operations Ground	0	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Fault Operations C Ø	0	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Fault Operations B Ø	0	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Fault Operations A Ø	0	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	416	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	General Comments		
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Readings	General Comments		
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.7	psi
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	0.00	kw
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	General Comments		
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	General Comments		
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.8	psi
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	9.60	kw
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	Oil Temp Max	47	°C
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	Oil Temp Present	25	°C
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0169	NonLTC	362-2-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1600	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Readings	Oil Temp Present	29	°C
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	100.0	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Amps B Ø	27.0	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Amps A Ø	26.0	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	100.0	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	100.0	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	9 Month Operations	2	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	6.41	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	6.41	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	6.41	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Readings	Amps C Ø	33.0	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Bushing Condition	Good	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	9 Month Operations	6	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Accumulated Fault Duty A Ph V	1.93	%
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Accumulated Fault Duty B Ph V	1.93	%
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Unknown Operations	0	
10/2/2020 11:34	Distribution	Belt Line Quarterly Inspection	BB0478	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2020 12:16	Distribution	Campbellsville Industrial Quarterly Inspection	KB0106	BreakerVacuum	472-0207	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	O0170	NonLTC	362-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Regulator As Left Counter	43255	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Fault Operations A Ø	0	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Fault Adjusted Amps C Phase V	0	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Fault Adjusted Amps B Phase V	0	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Fault Adjusted Amps A Phase V	0	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	Totalizer Meter Reading	.3060	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	Oil Temp Max	50	°C
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Readings	Oil Temp Present	30	°C
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	BAT001440	Battery	362-1 Battery Bank 1	Battery Patrol Inspection	Battery Overall Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	BAT001440	Battery	362-1 Battery Bank 1	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Switching Operations	1	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Operations This Read Vac	15	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	BAT001440	Battery	362-1 Battery Bank 1	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	BAT001440	Battery	362-1 Battery Bank 1	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	BAT001440	Battery	362-1 Battery Bank 1	Battery Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Patrol Inspection	Bushing Condition	Good	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	BAT001440	Battery	362-1 Battery Bank 1	Battery Patrol Inspection	General Comments		
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	BAT001440	Battery	362-1 Battery Bank 1	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Operations Counter AL	462	
10/2/2020 12:05	Distribution	Haefling Quarterly Inspection	BB0470	BreakerVacuum	127-0089	VCB Readings	Operations Counter AF	447	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	BAT001440	Battery	362-1 Battery Bank 1	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	BAT001441	Battery	362-2 Battery Bank 2	Battery Patrol Inspection	All Connections OK?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	BAT001441	Battery	362-2 Battery Bank 2	Battery Patrol Inspection	Battery Overall Condition	Good	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	BAT001441	Battery	362-2 Battery Bank 2	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	R1302	Regulator	362-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	BAT001441	Battery	362-2 Battery Bank 2	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Accumulated Fault Duty C Ph V	0	%
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Amps A Ø	140	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/2/2020 15:19	Distribution	White Oak Quarterly Inspection	O0227	NonLTC	365-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	BAT001441	Battery	362-2 Battery Bank 2	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/2/2020 15:18	Distribution	Lipps Quarterly Inspection	MR0081	Regulator	383-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	BAT001441	Battery	362-2 Battery Bank 2	Battery Patrol Inspection	General Comments		
10/2/2020 11:35	Distribution	Verda Quarterly Inspection	M0081	WithLTC	879-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	BAT001441	Battery	362-2 Battery Bank 2	Battery Patrol Inspection	Follow-up Action Required?	n	
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	BAT001441	Battery	362-2 Battery Bank 2	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/2/2020 15:18	Distribution	Guest River Quarterly Inspection	BAT001441	Battery	362-2 Battery Bank 2	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Amps B Ø	180	
10/2/2020 14:42	Distribution	Lexington Plant Quarterly Inspection	BB0469	BreakerVacuum	028-0007	VCB Readings	Amps C Ø	200	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	LTCC000725	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	LTCC000725	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	LTCC000725	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	LTCC000725	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	LTCC000725	LTCControl	930-Offline-Distribution	LTC Control Insp	General Comments		
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	LTCC000725	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	LTCC000725	LTCControl	930-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	LTCC000725	LTCControl	930-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	941	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	941	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	5	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BB0356	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BB0348	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	LTCC000818	LTCControl	930-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	LTCC000818	LTCControl	930-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	LTCC000818	LTCControl	930-Offline-Distribution	LTC Control Insp	General Comments		
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	LTCC000818	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	LTCC000818	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	LTCC000818	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	LTCC000818	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	LTCC000818	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Maintenance Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	General Comments	Actual counter	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	LTC Totalizer Reading	13392.00	kw
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	Oil Temp Max	55	°C
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	Oil Temp Present	40	°C
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Fault Operations Ground	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Fault Operations C Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	PF000133	PowerFuse	FV-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	BAT000165	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	BAT000165	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	PF000132	PowerFuse	FV-GND TR 1	Disconnect Powerfuse Inspection	General Comments	ok	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	Totalizer Meter Reading	.7440	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Fault Operations A Ø	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Fault Operations B Ø	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Fault Operations C Ø	0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	BAT000165	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	60	°F
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	BAT000165	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	Oil Temp Max	54	°C
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Fault Operations B Ø	0	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	Oil Temp Present	36	°C
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	LTC Operations Since Last Insp	1467	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	Follow-up Action Required?	n	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Fault Operations A Ø	0	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	PF000132	PowerFuse	FV-GND TR 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Operations Counter AF	947	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Maintenance Operations	0	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	LTC As Left Counter	27192	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	LTC As Found Counter	27182	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Mechanism Patrol Inspection	General Comments		
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	General Comments		
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	Follow-up Action Required?	n	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Operations This Read Vac	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Operations Counter AL	13	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Operations Counter AF	13	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Maintenance Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	9 Months Operations	2	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Accumulated Fault Duty A Ph AM	1.21	%
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Accumulated Fault Duty B Ph AM	1.21	%
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Amps A Ø	81.0	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Regulator As Left Counter	157901	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Tank Leaks	None	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Amps B Ø	92.0	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	LTC Totalizer Reading	2023.20	kw
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	General Comments		
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	General Comments		
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Fault Operations Ground	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Fault Operations C Ø	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Fault Operations B Ø	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Fault Operations A Ø	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Amps C Ø	0.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Amps C Ø	95.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Fault Adjusted Amps A Phase AM	11.18	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Amps B Ø	0.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Amps A Ø	0.0	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Fault Adjusted Amps C Phase AM	11.18	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	General Comments	GE, VR1, Model- B004G04, Serial- 1001V31851	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Fault Operations Ground	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	PF000133	PowerFuse	FV-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	PF000133	PowerFuse	FV-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	PF000134	PowerFuse	FV-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	PF000134	PowerFuse	FV-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	PF000134	PowerFuse	FV-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	Ok	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	PF000135	PowerFuse	FV-14KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	PF000135	PowerFuse	FV-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	PF000135	PowerFuse	FV-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	PF000136	PowerFuse	FV-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	PF000136	PowerFuse	FV-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	PF000136	PowerFuse	FV-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	K	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Unknown Operations	1	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Switching Operations	0	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Current Tap Position	1L	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	General Comments	Control is GE 3951C407AA P21RevA	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Max Tap Position	5R	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Min Tap Position	6L	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	R0871	Regulator	557-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	LTC Min Tap Position	5L	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Operations Counter AF	80	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Operations Counter AL	80	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Operations This Read Vac	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Switching Operations	0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	General Comments		
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	General Comments		
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Unknown Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	9 Month Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Accumulated Fault Duty A Ph V	10.36	%
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1431	Regulator	544-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Accumulated Fault Duty B Ph V	10.36	%
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Accumulated Fault Duty C Ph V	10.36	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Operations This Read AM	1	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	LTC Max Tap Position	4R	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	W0281	LTCMechanism	403-1	LTC Counter Readings	LTC Current Tap Position	1L	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Readings	Operations Counter AL	947	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	277	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C ∅	0	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B ∅	0	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A ∅	0	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	530.0	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	520.0	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	500.0	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	2	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	158	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	158	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	General Comments	Vegetation growing through fence behind transformer	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Exp Boom Corrected	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	9 Month Operations	6	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	770	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	770	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	195.0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	203.0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	201.0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0488	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	9 Month Operations	1	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Unknown Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Switching Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Operations This Read Vac	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Operations Counter AL	82	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Operations Counter AF	82	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Vegetation	Light	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Maintenance Operations	0	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0380	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	277	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	LTCC000390	LTCControl	710-1	LTC Control Insp	VRR Time Delay	30	Seconds
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	LTCC000390	LTCControl	710-1	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	LTCC000390	LTCControl	710-1	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	LTCC000390	LTCControl	710-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	122.5	volts
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	114120	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Fault Operations C Ø	0	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	2L	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	9.71	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	14.56	%
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Fault Operations B Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	10.92	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments	Control is Beckwith M-0356A	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	8R	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	8L	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	103570	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0605	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	General Comments		
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	ST000105	Structure	311-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	PF000132	PowerFuse	FV-GND TR 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Readings	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1098	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1098	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Fault Operations Ground	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	2L	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments	Control is Beckwith M-0356A	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	13R	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	16L	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0604	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Amps A Ø	48.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Accumulated Fault Duty C Ph V	.8	%
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Accumulated Fault Duty B Ph V	.8	%
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Unknown Operations	0	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Switching Operations	0	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Operations This Read Vac	0	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Operations Counter AL	233	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Operations Counter AF	233	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Maintenance Operations	0	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Grounds in Place?	y	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	General Comments		
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	General Comments		
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Foundation Condition	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Follow-up Action Required?	n	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Fault Operations Ground	0	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Fault Operations C Ø	0	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Fault Operations B Ø	0	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Fault Operations A Ø	0	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Trash Emptied?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Amps C Ø	47.0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	20	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	LTC Min Tap Position	13L	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	LTC Max Tap Position	8R	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	LTC Current Tap Position	12L	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	LTC As Left Counter	252320	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	LTC As Found Counter	252320	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	General Comments		
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0173	LTCMechanism	SY-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Follow-up Action Required?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	General Comments	Vegetation needs trimmed around station	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	FE000099	Fence	311-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Ambient Temp	50	*F
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Amps B Ø	43.0	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	SWG000032	Switchgear	HC-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	9 Month Operations	3	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Bushing Condition	Good	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Amps C Ø	40.0	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Amps B Ø	56.0	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Amps A Ø	48.0	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	9 Month Operations	26	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	84.0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	82.0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	84.0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0483	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	General Comments	Tree limbs over fence	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	FE000020	Fence	328-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	YD000099	Yard	311-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	General Comments		
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Patrol Inspection	Bushing Condition	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Amps C Ø	52.0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Broom on Site?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	CH000153	ControlHouse	HC-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Unknown Operations	0	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Switching Operations	0	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Operations This Read Vac	0	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Operations Counter AL	225	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Operations Counter AF	225	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Maintenance Operations	0	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Grounds in Place?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	General Comments		
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	General Comments		
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Foundation Condition	Good	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Follow-up Action Required?	n	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Fault Operations Ground	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Fault Operations C Ø	0	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Fault Operations B Ø	0	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Fault Operations A Ø	0	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	K0027	BreakerVacuum	328-0674	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Amps B Ø	52.0	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Amps A Ø	59.0	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0101	BreakerVacuum	032-4411	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	LTCC000654	LTCControl	444-3	LTC Control Insp	Follow-up Action Required?	n	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	LTCC000654	LTCControl	444-3	LTC Control Insp	General Comments		
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	LTCC000654	LTCControl	444-3	LTC Control Insp	LTC Operation Checked?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	LTCC000654	LTCControl	444-3	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	LTCC000654	LTCControl	444-3	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	LTCC000654	LTCControl	444-3	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	LTCC000654	LTCControl	444-3	LTC Control Insp	VRR Base Voltage AL	124.0	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	LTCC000654	LTCControl	444-3	LTC Control Insp	VRR Time Delay	60	Seconds
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Regulator As Left Counter	377107	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.6	volts
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	General Comments		
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.8	psi
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Unknown Operations	2	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Fault Adjusted Amps B Phase V	16.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Fault Adjusted Amps C Phase V	16.00	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Fault Operations A Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Fault Operations B Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Fault Operations C Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Fault Operations Ground	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	General Comments		
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Maintenance Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Operations Counter AF	84	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Operations Counter AL	84	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Operations This Read Vac	2	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Switching Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Unknown Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Switching Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Operations This Read AM	0	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	BAT000152	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	BAT000152	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	BAT000152	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	BAT000152	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Operations Counter AL	627	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Operations Counter AF	627	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Maintenance Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Fault Operations Ground	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Fault Operations C Ø	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Fault Operations B Ø	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Fault Operations A Ø	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Amps C Ø	408.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Amps B Ø	456.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Amps A Ø	431.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Accumulated Fault Duty B Ph AM	3.09	%
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	Accumulated Fault Duty A Ph AM	3.09	%
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Readings	9 Months Operations	11	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	LTCC000654	LTCControl	444-3	LTC Control Insp	All Connections OK?	y	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Operations Counter	86	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	General Comments		
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	9 Months Operations	4	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Amps A Ø	50.0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Amps B Ø	40.0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Amps C Ø	30.0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Fault Operations A Ø	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Fault Operations B Ø	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Fault Operations C Ø	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Fault Operations Ground	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Follow-up Action Required?	n	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Amps C Ø	0.0	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Amps B Ø	0.0	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Amps A Ø	0.0	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Regulator As Left Counter	25952	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Tank Leaks	None	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0260	GroundTransformer	HC-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	General Comments		
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Ambient Temp	65	*F
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	General Comments		
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Vegetation	None	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	YD000667	Yard	HC-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Current Tap Position	7L	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	General Comments	Control is cooper CL-6B GA17452	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Max Tap Position	3R	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Min Tap Position	14L	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0095	Regulator	032-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	X0325	RecloserElectronic	606-0424	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Current Tap Position	15R	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	General Comments		
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Reg Operation Checked?	n	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	0.0	volts
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Regulator As Left Counter	848902	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	R0884	Regulator	353-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Vegetation	None	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	General Comments		
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Operations This Read AM	0	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Ambient Temp	67	*F
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	General Comments		
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Vegetation	None	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	YD000414	Yard	710-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	46	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	46	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	Totalizer Meter Reading	.5994	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Operations Counter	183	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	General Comments		
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	X0113	RecloserHydraulic	544-0429	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Regulator As Left Counter	13215	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	72	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	49	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	11.0	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	48	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	BAT000152	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	BAT000152	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	BAT000152	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	BAT000152	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	BAT000152	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	BAT000152	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	BAT000152	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	BAT000152	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	YD000044	Yard	224-Yard	Yard Patrol Inspection	Ambient Temp	66	°F
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	General Comments	Barbed wire rusting behind cap bank	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	FE000047	Fence	224-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	BAT000152	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	9 Month Operations	13	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Accumulated Fault Duty A Ph V	.55	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Accumulated Fault Duty C Ph V	.55	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Amps A Ø	112.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Amps B Ø	120.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Amps C Ø	118.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Readings	Fault Adjusted Amps A Phase V	16.00	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	General Comments		
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Operations Counter AL	882	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Operations Counter AF	882	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Maintenance Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Fault Operations Ground	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Fault Operations C Ø	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Fault Operations B Ø	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Fault Operations A Ø	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Amps C Ø	174.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Amps B Ø	202.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Amps A Ø	205.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Accumulated Fault Duty C Ph AM	6.07	%
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Accumulated Fault Duty B Ph AM	7.28	%
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Accumulated Fault Duty A Ph AM	6.07	%
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	9 Months Operations	8	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	ST000416	Structure	710-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	DX0059	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	5.71	%
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	5.71	%
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	3.8	%
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Operations Counter AL	83	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Operations Counter AF	83	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Maintenance Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Fault Operations Ground	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Fault Operations C Ø	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Fault Operations B Ø	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Fault Operations A Ø	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Amps C Ø	92.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Amps B Ø	83.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Amps A Ø	86.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Accumulated Fault Duty C Ph V	.8	%
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Accumulated Fault Duty B Ph V	3.19	%
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Accumulated Fault Duty A Ph V	.8	%
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	9 Month Operations	4	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	BCH001320	Charger	444-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	BCH001320	Charger	444-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	BCH001320	Charger	444-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	BCH001320	Charger	444-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	BCH001320	Charger	444-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	General Comments		
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Amps B Ø	12.0	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Amps A Ø	12.0	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	9 Month Operations	10	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	LTCC000849	LTCControl	369-1	LTC Control Insp	All Connections OK?	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	LTCC000849	LTCControl	369-1	LTC Control Insp	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	PF000139	PowerFuse	FV-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	PF000139	PowerFuse	FV-STA SER NO 3	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	LTCC000849	LTCControl	369-1	LTC Control Insp	General Comments		
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	LTCC000849	LTCControl	369-1	LTC Control Insp	LTC Operation Checked?	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	LTCC000849	LTCControl	369-1	LTC Control Insp	LTC Output Voltage Level	120.6	VAC
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	LTCC000849	LTCControl	369-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	LTCC000849	LTCControl	369-1	LTC Control Insp	VRR Base Voltage AF	121.0	VAC
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Unknown Operations	0	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Switching Operations	0	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Operations This Read AM	0	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	BCH001320	Charger	444-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.150	millivolts
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	BCH001320	Charger	444-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	BCH001320	Charger	444-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Operations Counter AL	323	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Operations Counter AF	323	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	LTCC000849	LTCControl	369-1	LTC Control Insp	VRR Base Voltage AL	121.0	VAC
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1897	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1897	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	120.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	124.0	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	LTCC000849	LTCControl	369-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Unknown Operations	1	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Switching Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Readings	Operations This Read Vac	1	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	122.0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	n	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	General Comments	Unit heaters are turned off in Breaker box	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Operations Counter	37	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	BAT000165	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	26.7	VDC
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	General Comments		
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	BAT000165	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	BAT000165	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	BAT000165	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	BAT000165	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	BAT000165	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	BAT000165	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Unknown Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Readings	Switching Operations	0	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Amps C Ø	16.0	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Amps B Ø	24.0	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	RC000420	RecloserElectronic	311-0691	Recloser Electronic Patrol Inspection	Amps A Ø	25.0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	Winding Temp Present	40	°C
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	B0445	WithLTC	853-1	LTC Transformer Readings	Winding Temp Max	60	°C
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	ST000349	Structure	853-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Maintenance Operations	0	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	General Comments		
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Patrol Inspection	General Comments		
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Follow-up Action Required?	n	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Fault Operations Ground	0	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Fault Operations C Ø	0	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Fault Operations B Ø	0	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Fault Operations A Ø	0	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Amps C Ø	100.0	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Amps B Ø	100.0	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Amps A Ø	40.0	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0179	BreakerAirMagnetic	CK-0001	AMCB Readings	9 Months Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	185	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	185	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	Totalizer Meter Reading	.2810	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Readings	Totalizer Meter Multiplier	7200	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	C0411	WithLTC	444-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	BAT000165	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	BAT000165	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	BAT000165	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.8	VDC
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	SWG000184	Switchgear	SY-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Operations Counter AL	176	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Operations This Read AM	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Switching Operations	0	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Unknown Operations	0	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Switching Operations	1	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Operations This Read Vac	2	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Operations Counter AL	1293	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Operations Counter AF	1292	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Maintenance Operations	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Ambient Temp	62	*F
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Amps A Ø	60.0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Amps B Ø	60.0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Amps C Ø	57.0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Fault Operations A Ø	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Fault Operations B Ø	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Fault Operations C Ø	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Fault Operations Ground	0	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Grounds in Place?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	General Comments	51 N-I	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	General Comments	2 blown arrestors	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Follow-up Action Required?	n	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Patrol Inspection	General Comments		
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Foundation Condition	Good	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Follow-up Action Required?	n	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Fault Operations Ground	0	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Fault Operations C Ø	0	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Fault Operations B Ø	0	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Fault Operations A Ø	1	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	PF000142	PowerFuse	FV-12KV TR 4 POT	Disconnect Powerfuse Inspection	General Comments	k	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	PF000142	PowerFuse	FV-12KV TR 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	PF000142	PowerFuse	FV-12KV TR 4 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0625	Regulator	311-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	9 Month Operations	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Readings	Follow-up Action Required?	n	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	General Comments		
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Readings	General Comments		
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Readings	LTC Totalizer Reading	2361.60	kw
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Readings	Oil Temp Max	40	°C
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Readings	Oil Temp Present	39	°C
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1576	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Operations Counter	7	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	General Comments		
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Amps C Ø	26.0	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Amps B Ø	26.0	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	DX0124	RecloserElectronic	369-0670	Recloser Electronic Patrol Inspection	Amps A Ø	23.0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Patrol Inspection	General Comments		
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	General Comments		
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Maintenance Operations	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0877	BreakerAirMagnetic	SY-1254	AMCB Readings	Operations Counter AF	176	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	2.44	%
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	General Comments		
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	General Comments		
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	ST000069	Structure	606-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Patrol Inspection	Bushing Condition	Good	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Amps C Ø	12.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	PF000141	PowerFuse	FV-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	k	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	PF000141	PowerFuse	FV-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	PF000141	PowerFuse	FV-STA SER NO 4	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	PF000140	PowerFuse	FV-12KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	k	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	PF000140	PowerFuse	FV-12KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	PF000140	PowerFuse	FV-12KV TR 3 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	PF000139	PowerFuse	FV-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	k	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	General Comments		
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1576	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	MB0124	BreakerVacuum	403-0415	VCB Readings	Fault Adjusted Amps A Phase V	3.04	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Vegetation	None	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	YD000668	Yard	SY-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	General Comments		
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Readings	Totalizer Meter Reading	.2460	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	M0098	WithLTC	032-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Maintenance Operations	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Operations Counter AF	255	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BAT001300	Battery	557-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	General Comments		
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Ambient Temp	58	*F
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	General Comments		
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	733	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	FE000034	Fence	859-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Amps C Ø	20.0	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Amps B Ø	20.0	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Amps A Ø	20.0	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	9 Month Operations	8	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	General Comments		
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	BAT001257	Battery	HC-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	BCH001208	Charger	HC-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	BCH001208	Charger	HC-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	BCH001208	Charger	HC-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	BCH001208	Charger	HC-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	8.9	amps
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	BCH001208	Charger	HC-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	BCH001208	Charger	HC-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	BCH001208	Charger	HC-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	General Comments		
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	ST000031	Structure	859-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	YD000030	Yard	859-Yard	Yard Patrol Inspection	Vegetation	None	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Readings	Oil Temp Max	44	°C
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Fault Operations A Ø	0	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Fault Operations B Ø	0	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Fault Operations C Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Fault Operations Ground	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Maintenance Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Operations Counter AF	49	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Operations Counter AL	49	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Operations This Read Vac	1	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Switching Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Unknown Operations	1	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Fault Operations Ground	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Readings	Fault Operations		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Readings	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	1	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1645	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1645	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	BCH000124	Charger	CK-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Ambient Temp	78	*F
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Switching Operations	0	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Unknown Operations	0	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	General Comments		
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	SWG000030	Switchgear	HC-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Unknown Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Switching Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Operations This Read AM	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Operations Counter AL	300	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Operations Counter AF	300	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Maintenance Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Fault Operations Ground	0	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	BCH000124	Charger	CK-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Fault Operations C Ø	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Fault Operations B Ø	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Amps C Ø	0.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Amps B Ø	0.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Amps A Ø	0.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Accumulated Fault Duty C Ph AM	1.67	%
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Accumulated Fault Duty B Ph AM	1.67	%
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	Accumulated Fault Duty A Ph AM	1.67	%
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Readings	9 Months Operations	0	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	BCH000124	Charger	CK-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	General Comments		
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Readings	General Comments		
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1258.56	kw
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	56.67	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	27.50	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1242.72	kw
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	9 Month Operations	2	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Amps A Ø	0.0	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Amps B Ø	0.0	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Amps C Ø	0.0	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Bushing Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	General Comments		
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	General Comments		
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Fault Operations B Ø	0	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Fault Operations A Ø	0	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Patrol Inspection	Bushing Condition	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Amps C Ø	0.0	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Amps B Ø	0.0	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Amps A Ø	0.0	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	3	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Min Tap Position	13L	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Max Tap Position	1L	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	General Comments		
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Fault Adjusted Amps C Phase V	11.18	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Fault Operations A Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Fault Operations B Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Fault Operations C Ø	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	733	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Maintenance Operations	0	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Patrol Inspection	Grounds in Place?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	General Comments	Open	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Patrol Inspection	General Comments		
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Patrol Inspection	Foundation Condition	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Follow-up Action Required?	n	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Fault Operations Ground	0	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Fault Operations C Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	General Comments	ARC SENSE indication	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	BCH000124	Charger	CK-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	BCH000124	Charger	CK-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.7	VDC
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	BCH000124	Charger	CK-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.7	VDC
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	BCH000124	Charger	CK-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5178	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	BCH000271	Charger	403-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	BCH000271	Charger	403-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	BCH000271	Charger	403-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Maintenance Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Operations Counter AF	53	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Operations Counter AL	53	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Operations This Read Vac	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Switching Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Unknown Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	9 Month Operations	26	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Accumulated Fault Duty A Ph V	.8	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Accumulated Fault Duty C Ph V	2.39	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Amps A Ø	137.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Amps B Ø	146.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Amps C Ø	130.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	BCH000271	Charger	403-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	51.0	VDC
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	BCH000271	Charger	403-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	51.0	VDC
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	B0213	NonLTC	444-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Regulator As Left Counter	27406	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	Winding Temp Present	29	°C
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Amps A Ø	0.0	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Amps B Ø	0.0	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Amps C Ø	0.0	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Bushing Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Amps A Ø	3.0	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	9 Month Operations	23	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Switching Operations	0	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Operations This Read Vac	0	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Operations Counter AL	650	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Operations Counter AF	650	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Grounds in Place?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	General Comments		
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	General Comments		
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Foundation Condition	Good	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Follow-up Action Required?	n	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Fault Operations Ground	0	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Counter Readings	LTC Operations Since Last Insp	1069	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Counter Readings	LTC Min Tap Position	14L	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Counter Readings	LTC Max Tap Position	Neutral	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Counter Readings	LTC Current Tap Position	7L	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Counter Readings	LTC As Left Counter	139134	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Counter Readings	LTC As Found Counter	139127	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Mechanism Patrol Inspection	General Comments		
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Counter Readings	General Comments		
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Counter Readings	Follow-up Action Required?	n	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Fault Operations C Ø	0	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Fault Operations B Ø	0	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Fault Operations A Ø	0	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Patrol Inspection	Bushing Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Current Tap Position	10L	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	9 Month Operations	3	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0143	BreakerVacuum	444-4401	VCB Readings	Unknown Operations	0	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Unknown Operations	0	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Switching Operations	1	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Operations This Read Vac	2	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Operations Counter AL	168	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Operations Counter AF	168	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Maintenance Operations	0	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Patrol Inspection	Grounds in Place?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	General Comments		
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Patrol Inspection	General Comments		
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Patrol Inspection	Foundation Condition	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Follow-up Action Required?	n	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Fault Operations Ground	0	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Fault Operations C Ø	0	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Fault Operations B Ø	0	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Fault Operations A Ø	1	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Fault Adjusted Amps A Phase V	5.07	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	M0098	LTCMechanism	032-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Patrol Inspection	Bushing Condition	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Amps C Ø	3.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001400	BreakerVacuum	557-4407	VCB Readings	Amps B Ø	8.0	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BAT000091	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BAT000091	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BAT000091	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	9 Month Operations	2	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Regulator As Left Counter	64336	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Min Tap Position	16L	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Max Tap Position	6L	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	9 Month Operations	1	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Accumulated Fault Duty A Ph V	.55	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Accumulated Fault Duty B Ph V	.55	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Accumulated Fault Duty C Ph V	.55	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Amps A Ø	470.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Amps B Ø	480.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Amps C Ø	460.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Fault Operations A Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Fault Operations B Ø	0	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	General Comments		
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Readings	Totalizer Meter Reading	.5244	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Unknown Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Switching Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Operations This Read Vac	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Operations Counter AL	333	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Operations Counter AF	333	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Maintenance Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Fault Operations Ground	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Readings	Fault Operations C Ø	0	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Current Tap Position	10L	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Vegetation	None	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	General Comments		
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Clear of Trash?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	YD000015	Yard	328-Yard	Yard Patrol Inspection	Ambient Temp	60	*F
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	93.0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	81.0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	80.0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	318	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	318	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0481	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	Oil Temp Max	39	°C
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	Oil Temp Present	29	°C
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	66	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	66	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Grounds in Place?	y	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	General Comments		
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	General Comments		
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Foundation Condition	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Follow-up Action Required?	n	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Fault Operations Ground	0	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Fault Operations C Ø	0	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Fault Operations B Ø	0	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Fault Operations A Ø	0	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Bushing Condition	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Amps C Ø	12.0	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Amps B Ø	12.0	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Amps A Ø	12.0	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	9 Month Operations	6	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	55.0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	60.0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	58.0	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1533	Regulator	606-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Fault Operations C Ø	0	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Fault Operations B Ø	0	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Fault Operations A Ø	0	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	148	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	148	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Switching Operations	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Operations This Read AM	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Operations Counter AL	114	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Operations Counter AF	114	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Maintenance Operations	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	General Comments		
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Patrol Inspection	General Comments		
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Follow-up Action Required?	n	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Fault Operations Ground	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Fault Operations C Ø	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Fault Operations B Ø	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Fault Operations A Ø	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	4	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	29.12	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	29.12	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	13.35	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	107.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	102.0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Amps C Ø	0.0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Amps B Ø	0.0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Amps A Ø	0.0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0879	BreakerAirMagnetic	SY-1256	AMCB Readings	9 Months Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	103.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0478	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Readings	Oil Temp Present	20	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Fault Operations Ground	0	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Readings	Oil Temp Max	42	°C
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Readings	General Comments		
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	3	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	General Comments		
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Ambient Temp	61	°F
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	136.0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	132.0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	134.0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Follow-up Action Required?	n	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Foundation Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Unknown Operations	0	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Switching Operations	0	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Operations This Read Vac	0	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Operations Counter AL	250	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Operations Counter AF	250	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Vegetation	None	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	YD000049	Yard	883-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Maintenance Operations	0	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	General Comments		
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	General Comments		
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Grounds in Place?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Maintenance Operations	0	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	General Comments		
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	ST000118	Structure	353-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Operations Counter AF	217	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Operations Counter AL	217	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Operations This Read Vac	0	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Switching Operations	0	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0026	BreakerVacuum	710-0524	VCB Readings	Unknown Operations	0	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Grounds in Place?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	General Comments		
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	General Comments		
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Foundation Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Readings	Follow-up Action Required?	n	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KB0025	BreakerVacuum	710-BT3-1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	FE000342	Fence	853-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	LTC Max Tap Position	13L	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	LTC Current Tap Position	7R	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	LTC As Left Counter	79227	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	LTC As Found Counter	79227	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	General Comments		
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	Winding Temp Max	33	°C
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	Totalizer Meter Reading	0.0000	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Vegetation	None	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	General Comments		
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	S0018	NonLTC	328-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	YD000080	Yard	606-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	General Comments	trees over hanging fence	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	FE000080	Fence	606-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	SWG000016	Switchgear	CK-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C ∅	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	281	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	281	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0480	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	12	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	#3252	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	3090	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	3090	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	1	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0485	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	1	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	General Comments		
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Vegetation	None	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	YD000346	Yard	853-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1518	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0176	LTCMechanism	SY-TRANS 1	LTC Counter Readings	LTC Min Tap Position	13L	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	General Comments		
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	LTC Totalizer Reading	811.20	kw
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	Oil Temp Max	50	°C
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	Oil Temp Present	35	°C
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	ST000053	Structure	883-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Amps A Ø	10.0	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Amps B Ø	0.0	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Amps C Ø	10.0	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Bushing Condition	Good	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	9 Month Operations	6	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Accumulated Fault Duty A Ph V	1.59	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Accumulated Fault Duty B Ph V	1.59	%
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Clear of Trash?	n	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Regulator As Left Counter	121301	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	General Comments	GE, VR-1A, Model- B001G04, Serial- 698V22459	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Current Tap Position	6L	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	4	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Readings	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	70.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	68.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	73.0	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Fans Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	General Comments		
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Tank Leaks	None	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Regulator As Left Counter	30121	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Min Tap Position	13L	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Max Tap Position	1L	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	General Comments		
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Current Tap Position	9L	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	General Comments		
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	n	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	FE000005	Fence	544-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	18	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	General Comments	Lots of trash in station from school dumpsters.	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Vegetation	None	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Floor Swept?	n	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Accumulated Fault Duty C Ph V	.8	%
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	Totalizer Meter Reading	.1690	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	W0281	WithLTC	403-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	200.00	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	General Comments		
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Trash Emptied?	n	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Unknown Operations	0	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Switching Operations	0	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Operations This Read Vac	0	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Operations Counter AL	451	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Operations Counter AF	451	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0166	BreakerVacuum	032-0413	VCB Readings	Maintenance Operations	0	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Broom on Site?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	YD000014	Yard	444-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	99298	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	LTCC000390	LTCControl	710-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	LTCC000390	LTCControl	710-1	LTC Control Insp	LTC Operation Checked?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	LTCC000390	LTCControl	710-1	LTC Control Insp	General Comments		
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	LTCC000390	LTCControl	710-1	LTC Control Insp	Follow-up Action Required?	n	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	LTCC000390	LTCControl	710-1	LTC Control Insp	All Connections OK?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Fault Operations A Ø	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Amps C Ø	134.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Amps B Ø	123.0	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Broom on Site?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Amps A Ø	97.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Accumulated Fault Duty B Ph V	5.58	%
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	9 Month Operations	1	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Amps A Ø	193.0	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Amps B Ø	186.0	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Amps C Ø	174.0	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Bushing Condition	Good	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Fault Operations A Ø	0	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Fault Operations B Ø	0	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Fault Operations C Ø	0	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Fault Operations Ground	0	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Follow-up Action Required?	n	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Foundation Condition	Good	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	General Comments		
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	General Comments		
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Grounds in Place?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Maintenance Operations	0	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	3L	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	7	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	61.0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	54.0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	66.0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	155	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	155	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0479	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	64	*F
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	General Comments		
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	BAT001242	Battery	328-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments	Control is Beckwith M-0356A	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	4R	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	3L	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	R0606	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	General Comments		
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	General Comments		
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	General Comments		
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Counter Readings	LTC Operations Since Last Insp	554	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	°C
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	30	°C
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Counter Readings	LTC Min Tap Position	8L	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Counter Readings	LTC Max Tap Position	4R	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Counter Readings	LTC Current Tap Position	7L	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Trash Emptied?	n	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	959	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	959	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Counter Readings	LTC As Left Counter	21476	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Counter Readings	LTC As Found Counter	21476	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Mechanism Patrol Inspection	General Comments		
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Counter Readings	General Comments		
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0020	LTCMechanism	710-3	LTC Counter Readings	Follow-up Action Required?	n	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Broom on Site?	n	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	CH000237	ControlHouse	557-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1430	Regulator	544-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	SWG000078	Switchgear	SY-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	Winding Temp Present	32	°C
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	Winding Temp Max	40	°C
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	Totalizer Meter Reading	.6258	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	Oil Temp Present	33	°C
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	Oil Temp Max	41	°C
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	10.00	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	15.00	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	4505.76	kw
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KT0040	NonLTC	032-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Evidence of Insects	None	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Floor Swept?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	General Comments		
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Contol House	Control House Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Control House	Control House Patrol Inspection	Trash Emptied?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Operations Counter AF	184	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Operations Counter AL	184	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Operations This Read Vac	0	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Switching Operations	0	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	BK001090	BreakerVacuum	444-4400	VCB Readings	Unknown Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	Accumulated Fault Duty A Ph V	5.58	%
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Readings	9 Month Operations	3	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	CH000233	ControlHouse	328-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	CH000235	ControlHouse	403-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	General Comments	same as previous comments. busted high voltage warning sign outside of fence far side of fence	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	19.41	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	54	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Tank Leaks	None	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Fault Operations B Ø	0	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Fault Operations C Ø	0	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Fault Operations Ground	0	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Follow-up Action Required?	n	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Foundation Condition	Good	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	General Comments		
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	General Comments		
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	General Comments		
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	CH000454	ControlHouse	CK-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	CH000454	ControlHouse	CK-Battery Control House	Control House Patrol Inspection	General Comments		
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	CH000454	ControlHouse	CK-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	CH000454	ControlHouse	CK-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	CH000454	ControlHouse	CK-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	CH000454	ControlHouse	CK-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	CH000454	ControlHouse	CK-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	CH000454	ControlHouse	CK-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Regulator As Left Counter	22948	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	General Comments		
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Operations Counter AL	255	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Operations This Read Vac	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	BK000267	BreakerVacuum	HC-1435	VCB Readings	Switching Operations	0	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	General Comments		
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	FE000015	Fence	369-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BAT000091	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BAT000091	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BAT000091	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	Electrolyte is low in batteries	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BAT000091	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BAT000091	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BAT000091	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Low	If low,note cell #'s
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BAT000091	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BAT000091	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	148.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	161.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	153.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	13.35	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	26.69	%
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	FE000054	Fence	403-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Fault Operations A Ø	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Fault Operations B Ø	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Fault Operations C Ø	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Fault Operations Ground	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Follow-up Action Required?	n	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Patrol Inspection	General Comments		
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	General Comments	Actual counter	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Maintenance Operations	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Operations Counter AF	325	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Operations Counter AL	325	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Operations This Read AM	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Switching Operations	0	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Operations Counter AF	16	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Operations Counter AL	16	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Operations This Read Vac	0	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	PN35	WithLTC	CK-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	9 Month Operations	11	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Accumulated Fault Duty A Ph V	2.39	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Accumulated Fault Duty B Ph V	2.39	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Accumulated Fault Duty C Ph V	2.39	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Amps A Ø	120.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Amps B Ø	109.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Amps C Ø	127.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Fault Operations A Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Fault Operations B Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Fault Operations C Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Fault Operations Ground	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Readings	Follow-up Action Required?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Unknown Operations	0	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Switching Operations	0	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Operations This Read Vac	0	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Operations Counter AL	179	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Readings	Operations Counter AF	179	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001404	BreakerVacuum	557-4410	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	CH000454	ControlHouse	CK-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Min Tap Position	15L	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	General Comments		
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Tank Leaks	None	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0009	Regulator	710-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Current Tap Position	9L	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0007	Regulator	710-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BAT000091	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	9 Months Operations	17	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	General Comments		
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Grounds in Place?	y	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Maintenance Operations	0	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Amps A Ø	80.0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Amps B Ø	90.0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Amps C Ø	80.0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0878	BreakerAirMagnetic	SY-1255	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	n	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.8	psi
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	S0064	NonLTC	606-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	0.00	kw
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	General Comments		
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	CH000358	ControlHouse	853-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	General Comments		
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Trash Emptied?	n	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	General Comments		
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A \emptyset	15.0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B \emptyset	14.0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C \emptyset	14.0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A \emptyset	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B \emptyset	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C \emptyset	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0484	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Readings	Amps A \emptyset	0.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Readings	Amps B \emptyset	0.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Readings	Amps C \emptyset	0.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Readings	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1424	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1424	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Regulator As Left Counter	56451	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A \emptyset	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B \emptyset	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C \emptyset	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	459	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	459	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0490	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	General Comments		
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	ST000013	Structure	444-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	ST000014	Structure	328-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KR0008	Regulator	710-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Site Service Trans Condition	Exterior Stains	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	CH000238	ControlHouse	444-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Vegetation	None	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Exp Boom Needs Corr	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	General Comments	ARC SENSE indication	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Maintenance Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Operations Counter AF	78	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Operations Counter AL	78	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Operations This Read Vac	4	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Switching Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Unknown Operations	4	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Readings	Fault Operations A Ø	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	UG Pothead Condition Good?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	General Comments		
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Current Tap Position	10L	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	YD000071	Yard	544-Yard	Yard Patrol Inspection	Ambient Temp	76	*F
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Min Tap Position	16L	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1534	Regulator	606-1 C	Regulator Patrol Inspection	Max Tap Position	6L	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	General Comments		
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	MB0133	BreakerVacuum	859-0432	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Amps A Ø	129.0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	ST000643	Structure	HC-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Amps B Ø	142.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Amps C Ø	138.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Fault Adjusted Amps A Phase V	44.72	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Fault Adjusted Amps B Phase V	44.72	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Fault Adjusted Amps C Phase V	44.72	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Fault Operations A Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Fault Operations B Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Fault Operations C Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Fault Operations Ground	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001358	BreakerVacuum	FV-1139	VCB Readings	Follow-up Action Required?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Ambient Temp	70	*F
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	ST000078	Structure	544-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	General Comments		
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Vegetation	None	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	YD000053	Yard	403-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	General Comments	2 arresters blown on cir 414 and one blown on cir 415. mentioned in pevious inspection	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	ST000058	Structure	403-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Operations Counter AF	165	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Maintenance Operations	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	General Comments		
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Patrol Inspection	General Comments		
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Follow-up Action Required?	n	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Fault Operations Ground	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Fault Operations C Ø	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Fault Operations B Ø	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Fault Operations A Ø	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Amps C Ø	30.0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Amps B Ø	10.0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Amps A Ø	20.0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	9 Month Operations	1	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	PF000307	PowerFuse	SY-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	PF000307	PowerFuse	SY-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	PF000306	PowerFuse	SY-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	PF000306	PowerFuse	SY-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	PF000305	PowerFuse	SY-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	9 Month Operations	9	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Amps A Ø	0.0	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Amps B Ø	0.0	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Amps C Ø	0.0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	PF000305	PowerFuse	SY-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	PF000304	PowerFuse	SY-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	PF000304	PowerFuse	SY-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Unknown Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Switching Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Operations This Read Vac	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Operations Counter AL	40	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Operations Counter AF	40	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Maintenance Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Fault Operations Ground	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Fault Operations C Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Fault Operations B Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Fault Operations A Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Amps C Ø	150.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Amps B Ø	140.0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Fault Operations C Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Unknown Operations	0	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Operations Counter	2336	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	General Comments		
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Switching Operations	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Fault Operations B Ø	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Fault Operations A Ø	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Amps C Ø	40.0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Amps B Ø	100.0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Amps A Ø	50.0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	758	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	LTC Min Tap Position	14L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	LTC Max Tap Position	5L	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Battery Load Check OK?	n	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Amps C Ø	0.0	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Amps B Ø	0.0	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	MX0357	RecloserElectronic	544-0435	Recloser Electronic Patrol Inspection	Amps A Ø	0.0	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	LTC Current Tap Position	9L	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	LTC As Left Counter	423256	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	LTC As Found Counter	423256	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	General Comments		
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	PN35	LTCMechanism	CK-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	9 Month Operations	8	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Switching Operations	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Operations This Read Vac	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000686	BreakerVacuum	SY-1250	VCB Readings	Operations Counter AL	165	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	1464.00	kw
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	Oil Temp Max	30	°C
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	Oil Temp Present	30	°C
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Switching Operations	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Operations This Read Vac	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Operations Counter AL	151	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Operations Counter AF	151	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Maintenance Operations	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	General Comments		
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Patrol Inspection	General Comments		
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Fault Operations Ground	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Amps C Ø	240.0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Amps B Ø	260.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Unknown Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Switching Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Operations This Read Vac	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Operations Counter AL	25	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Operations Counter AF	25	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Maintenance Operations	0	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	Totalizer Meter Reading	.3050	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	Winding Temp Max	20	°C
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	Winding Temp Present	20	°C
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Fault Operations A Ø	0	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Fault Operations B Ø	0	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Fault Operations C Ø	0	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Fault Operations Ground	0	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Follow-up Action Required?	n	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Foundation Condition	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Amps A Ø	150.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Accumulated Fault Duty B Ph V	1.59	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	Accumulated Fault Duty A Ph V	1.59	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Readings	9 Month Operations	16	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Unknown Operations	2	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Switching Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Operations This Read Vac	2	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Operations Counter AL	35	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Operations Counter AF	35	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Maintenance Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Fault Operations Ground	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Fault Operations C Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Fault Operations B Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Fault Operations A Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Fault Adjusted Amps C Phase V	22.36	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Fault Adjusted Amps B Phase V	22.36	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Fault Adjusted Amps A Phase V	22.36	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Amps C Ø	108.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Amps B Ø	111.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Amps A Ø	115.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Readings	9 Month Operations	20	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Bushing Condition	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Readings	General Comments		
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0006	NonLTC	710-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Operations Counter AF	213	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Counter Readings	LTC Operations Since Last Insp	1127	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Counter Readings	LTC Min Tap Position	16L	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Counter Readings	LTC Max Tap Position	4L	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Counter Readings	LTC Current Tap Position	7L	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Counter Readings	LTC As Left Counter	60084	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Counter Readings	LTC As Found Counter	60081	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Counter Readings	General Comments	Transmission voltage is high. May need to look into moving DETC from tap 2 to tap 1.	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Mechanism Patrol Inspection	General Comments		
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Maintenance Operations	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	General Comments		
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Patrol Inspection	General Comments		
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Follow-up Action Required?	n	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BCH001347	Charger	557-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BCH001347	Charger	557-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BCH001347	Charger	557-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BCH001347	Charger	557-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BCH001347	Charger	557-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.9	amps
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BCH001347	Charger	557-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BCH001347	Charger	557-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BCH001347	Charger	557-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.200	millivolts
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Regulator As Left Counter	89496	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	122.8	volts
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	General Comments	GE, VR1, Model- B004G04, Serial- 0602V32850	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	R1432	Regulator	544-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Counter Readings	Follow-up Action Required?	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	M0051	LTCMechanism	369-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	35	°C
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	80	°C
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	Oil Temp Present	25	°C
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	Oil Temp Max	60	°C
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-3.0	psi
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	General Comments	Transformer needs nitrogen	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	General Comments		
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	LTCC000895	LTCControl	859-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	LTCC000895	LTCControl	859-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	LTCC000895	LTCControl	859-1	LTC Control Insp	VRR Time Delay	60	Seconds
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Fault Operations A Ø	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Fault Operations B Ø	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Fault Operations C Ø	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Maintenance Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Operations Counter AF	599	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Operations Counter AL	599	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Operations This Read AM	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Switching Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Unknown Operations	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Switching Operations	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Operations This Read Vac	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Operations Counter AL	213	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	LTC As Left Counter	96086	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	LTC As Found Counter	96086	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Mechanism Patrol Inspection	General Comments	needs screw on desiccant filter	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	General Comments		
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Fault Operations Ground	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Fault Operations C Ø	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Fault Operations B Ø	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Fault Operations A Ø	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Amps C Ø	50.0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Amps B Ø	90.0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Amps A Ø	100.0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000688	BreakerVacuum	SY-1252	VCB Readings	9 Month Operations	7	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Operations Counter	9	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	General Comments		
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Amps C Ø	18.0	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Amps B Ø	16.0	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	MX0312	RecloserElectronic	883-4428	Recloser Electronic Patrol Inspection	Amps A Ø	14.0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Switching Operations	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Operations This Read Vac	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Operations Counter AL	159	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Operations Counter AF	159	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Maintenance Operations	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	General Comments	Actual counter	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Patrol Inspection	General Comments		
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Follow-up Action Required?	n	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000687	BreakerVacuum	SY-1251	VCB Readings	Fault Operations Ground	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	129	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	129	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	200.0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	180.0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	182.0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0477	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Current Tap Position	12L	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	General Comments		
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Max Tap Position	6L	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Min Tap Position	16L	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Regulator As Left Counter	60696	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/1/2020 13:29	Distribution	Forester Creek Quarterly Inspection	R1532	Regulator	606-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Needs Replaced	check oil cup
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1333	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	LTC Min Tap Position	16L	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	LTC Max Tap Position	5R	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0094	LTCMechanism	HC-TRANS 2	LTC Counter Readings	LTC Current Tap Position	13L	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Readings	Follow-up Action Required?	n	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Readings	Fault Operations	0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Ambient Temperature	61	*F
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Regulator As Left Counter	89043	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Current Tap Position	7L	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	General Comments		
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Max Tap Position	4L	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.1	volts
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Regulator As Left Counter	120078	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Tank Leaks	None	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1319	Regulator	328-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	FV-GND TR 1	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Operations Counter AL	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Operations Counter AF	363	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Number of Ops last 9 Months	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Maintenance Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Fault Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Amps C Ø	0.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Amps B Ø	0.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Readings	Amps A Ø	0.0	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Amps A Ø	1.0	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Amps B Ø	0.0	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Amps C Ø	1.0	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Fault Operations Ground	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Fault Operations C Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Fault Operations B Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Fault Operations A Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Amps C Ø	126.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Amps B Ø	156.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Amps A Ø	115.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Accumulated Fault Duty C Ph V	3.99	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Accumulated Fault Duty B Ph V	3.99	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	9 Month Operations	23	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Counter Readings	LTC Min Tap Position	5L	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Counter Readings	LTC Max Tap Position	8R	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Counter Readings	LTC Current Tap Position	4L	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Counter Readings	LTC As Left Counter	621	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Counter Readings	LTC As Found Counter	621	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Mechanism Patrol Inspection	General Comments		
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Counter Readings	General Comments		
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Counter Readings	Follow-up Action Required?	n	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	General Comments		
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Max Tap Position	4L	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Readings	Switching Operations	1	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	SF6 Pressure Indicator	good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	SF6 Bushing Condition	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Readings	Operations This Read SF6	1	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Readings	Operations Counter AL	67	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Readings	Operations Counter AF	66	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Readings	Num Operations Last 9 Months	1	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Readings	Maintenance Operations	0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Heaters (All) Functioning?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Grounds in Place?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	General Comments	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Readings	General Comments		
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Gauge(s) Condition	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000663	BreakerSF6	853-618	GCB Patrol Inspection	Foundation Condition	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Regulator As Left Counter	29652	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.1	volts
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Min Tap Position	12L	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Max Tap Position	3R	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	General Comments	Control is Cooper CL-6B GA17455	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Current Tap Position	5L	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	General Comments		
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	General Comments		
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	LTC Totalizer Reading	781.92	kw
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	Oil Temp Max	46	°C
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	Oil Temp Present	35	°C
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	Totalizer Meter Reading	.1086	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	General Comments		
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Operations Counter	0	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	RC900711	RecloserElectronic	224-0240	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	42	°C
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	80	°C
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	47	°C
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	87	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	45	°C
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	87	°C
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	30.00	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	Oil Temp Present	40	°C
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	Oil Temp Max	60	°C
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1000	psi
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.8	psi
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	General Comments		
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0094	WithLTC	HC-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0094	Regulator	032-5 B	Regulator Patrol Inspection	Tank Leaks	None	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Accumulated Fault Duty B Ph V	1.59	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Accumulated Fault Duty A Ph V	1.59	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	9 Month Operations	15	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	Totalizer Meter Reading	.2350	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Current Tap Position	6L	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	Oil Temp Present	29	°C
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	Oil Temp Max	42	°C
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	LTC Totalizer Reading	1128.00	kw
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	General Comments		
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	General Comments		
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0040	WithLTC	557-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	General Comments		
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Max Tap Position	3L	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	General Comments		
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Grounds in Place?	y	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Maintenance Operations	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Amps A Ø	240.0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BK000685	BreakerVacuum	SY-12KV TR 1	VCB Readings	9 Month Operations	1	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Tank Leaks	None	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Operations Counter AF	341	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Operations Counter AL	341	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Operations This Read Vac	1	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Switching Operations	1	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	MB0165	BreakerVacuum	032-BT6-5	VCB Readings	Unknown Operations	0	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Regulator As Left Counter	817756	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Min Tap Position	12L	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Max Tap Position	7R	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	General Comments	Control is Cooper CL-6B , serial is GA04386	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Current Tap Position	4L	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	KR0120	Regulator	557-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	General Comments	ARC SENSE indication	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Follow-up Action Required?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Fault Operations Ground	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Fault Operations C Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Fault Operations B Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Fault Operations A Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Amps C Ø	138.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Amps B Ø	152.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Amps A Ø	167.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Readings	Accumulated Fault Duty C Ph V	.8	%
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Readings	LTC Totalizer Reading	4830.00	kw
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Readings	Oil Temp Max	45	°C
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Readings	Oil Temp Present	35	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Readings	Totalizer Meter Reading	.8050	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Current Tap Position	15R	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	General Comments		
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Reg Operation Checked?	n	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	0.0	volts
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Regulator As Left Counter	424080	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Tank Leaks	None	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Regulator As Left Counter	103691	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	B0287	LTCMechanism	710-1	LTC Counter Readings	LTC Operations Since Last Insp	51	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Unknown Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Switching Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Operations This Read Vac	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Operations Counter AL	32	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Operations Counter AF	32	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	Maintenance Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Readings	General Comments		
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1317	Regulator	328-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Current Tap Position	7L	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	R1318	Regulator	328-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Readings	Totalizer Meter Reading	1.1694	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Readings	Oil Temp Present	41	°C
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Readings	Oil Temp Max	57	°C
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Readings	LTC Totalizer Reading	5613.12	kw
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Readings	General Comments		
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	General Comments		
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	M0051	WithLTC	369-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	R0744	Regulator	353-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	General Comments		
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Readings	General Comments		
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	B0287	WithLTC	710-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Mechanism Patrol Inspection	General Comments		
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Counter Readings	General Comments		
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Counter Readings	Follow-up Action Required?	n	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Current Tap Position	14L	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Amps A Ø	0.0	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Amps B Ø	0.0	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Amps C Ø	0.0	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	9 Months Operations	16	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Amps A Ø	20.0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Amps B Ø	20.0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Amps C Ø	20.0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Fault Operations A Ø	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Fault Operations B Ø	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Fault Operations C Ø	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Fault Operations Ground	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Follow-up Action Required?	n	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Patrol Inspection	General Comments		
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	General Comments		
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Maintenance Operations	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Operations Counter AF	105	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Operations Counter AL	105	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Operations This Read AM	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0876	BreakerAirMagnetic	SY-1253	AMCB Readings	Switching Operations	0	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	General Comments		
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	BCH000202	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	BCH000202	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	BCH000202	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Counter Readings	LTC Operations Since Last Insp	1403	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	LTCC000673	LTCCControl	883-1	LTC Control Insp	VRR Time Delay	40	Seconds
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	LTCC000673	LTCCControl	883-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	LTCC000673	LTCCControl	883-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	LTCC000673	LTCCControl	883-1	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	LTCC000673	LTCCControl	883-1	LTC Control Insp	LTC Operation Checked?	y	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	LTCC000673	LTCCControl	883-1	LTC Control Insp	General Comments		
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	LTCC000673	LTCCControl	883-1	LTC Control Insp	Follow-up Action Required?	n	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	LTCC000673	LTCCControl	883-1	LTC Control Insp	All Connections OK?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	25	°C
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	45	°C
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	4	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Counter Readings	LTC Min Tap Position	8L	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Counter Readings	LTC Max Tap Position	5R	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Counter Readings	LTC Current Tap Position	4L	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	192	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	192	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Counter Readings	LTC As Left Counter	20858	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	LTCM000065	LTCMechanism	853-2	LTC Counter Readings	LTC As Found Counter	20858	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	General Comments		
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Patrol Inspection	General Comments		
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Follow-up Action Required?	n	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Fault Operations Ground	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	9 Months Operations	2	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Amps A Ø	0.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	16	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	41.25	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	44.9	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	18.2	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	109.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	91.0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Amps B Ø	0.0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Amps C Ø	0.0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Unknown Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Switching Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Operations This Read Vac	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Operations Counter AL	157	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Operations Counter AF	157	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Maintenance Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Fault Operations Ground	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Fault Operations C Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Fault Operations B Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Fault Operations A Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Amps C Ø	103.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Amps B Ø	100.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Amps A Ø	115.0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations A Ø	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations B Ø	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations C Ø	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations Ground	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Follow-up Action Required?	n	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Patrol Inspection	General Comments		
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	General Comments		
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Maintenance Operations	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AF	64	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AL	64	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Operations This Read AM	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0881	BreakerAirMagnetic	SY-12KV BUS TIE SEC 2	AMCB Readings	Switching Operations	0	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Operations Counter	0	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	RC900700	RecloserElectronic	224-0228	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	General Comments		
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Reg Operation Checked?	n	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	0.0	volts
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Regulator As Left Counter	10332	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	RC900703	RecloserElectronic	977-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps A Ø	2.5	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	RC900703	RecloserElectronic	977-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps B Ø	2.5	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	RC900703	RecloserElectronic	977-Offline-Distribution	Recloser Electronic Patrol Inspection	Amps C Ø	2.3	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	RC900703	RecloserElectronic	977-Offline-Distribution	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	RC900703	RecloserElectronic	977-Offline-Distribution	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	R0569	Regulator	353-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	67	°F
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	General Comments		
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BAT001174	Battery	710-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	General Comments		
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Negative DC Ground	.7	VDC
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Positive DC Ground	.9	VDC
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	BAT000196	Battery	403-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Unknown Operations	0	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Switching Operations	0	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Operations This Read AM	0	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Operations Counter AL	269	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Operations Counter AF	269	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Maintenance Operations	0	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	General Comments	Trash bad outside of gate/fence	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Unknown Operations	0	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Switching Operations	0	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Operations This Read Vac	2	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Operations Counter AL	698	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Operations Counter AF	698	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Maintenance Operations	0	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Grounds in Place?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	General Comments		
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	FE000821	Fence	444-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	General Comments		
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Foundation Condition	Good	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Follow-up Action Required?	n	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Fault Operations Ground	0	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Fault Operations C ∅	0	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Fault Operations B ∅	1	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Fault Operations A ∅	1	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4932	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	BAT001427	Battery	CK-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Fault Adjusted Amps B Phase V	3.04	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Fault Adjusted Amps A Phase V	3.04	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	General Comments		
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	LTC As Found Counter	69833	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	LTC As Left Counter	69833	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	LTC Current Tap Position	10L	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	LTC Max Tap Position	Neutral	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	LTC Min Tap Position	12L	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	567	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	LTCC000733	LTCControl	403-1	LTC Control Insp	VRR Time Delay	60	Seconds
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0093	LTCMechanism	HC-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	LTCC000733	LTCControl	403-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	LTCC000733	LTCControl	403-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	LTCC000733	LTCControl	403-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	LTCC000733	LTCControl	403-1	LTC Control Insp	LTC Operation Checked?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	LTCC000733	LTCControl	403-1	LTC Control Insp	General Comments		
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	LTCC000733	LTCControl	403-1	LTC Control Insp	Follow-up Action Required?	n	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	LTCC000733	LTCControl	403-1	LTC Control Insp	All Connections OK?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LTCC000328	LTCControl	SY-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LTCC000328	LTCControl	SY-TRANS 1	LTC Control Insp	General Comments		
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LTCC000328	LTCControl	SY-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LTCC000328	LTCControl	SY-TRANS 1	LTC Control Insp	All Connections OK?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LTCC000520	LTCControl	HC-TRANS 1	LTC Control Insp	All Connections OK?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LTCC000520	LTCControl	HC-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LTCC000520	LTCControl	HC-TRANS 1	LTC Control Insp	General Comments		
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LTCC000520	LTCControl	HC-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Follow-up Action Required?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	General Comments	bushes coming through fence pics sent to Stinson	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	FE000560	Fence	SY-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	General Comments		
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	General Comments		
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	BAT001427	Battery	CK-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	BAT001427	Battery	CK-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	BAT001427	Battery	CK-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	64	*F
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	BAT001427	Battery	CK-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	LTCC000676	LTCControl	557-1	LTC Control Insp	VRR Time Delay	60	Seconds
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	LTCC000676	LTCControl	557-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	LTCC000676	LTCControl	557-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	LTCC000676	LTCControl	557-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelloff	Position
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	LTCC000676	LTCControl	557-1	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	LTCC000676	LTCControl	557-1	LTC Control Insp	LTC Operation Checked?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	LTCC000676	LTCControl	557-1	LTC Control Insp	General Comments		
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	LTCC000676	LTCControl	557-1	LTC Control Insp	Follow-up Action Required?	n	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	LTCC000676	LTCControl	557-1	LTC Control Insp	All Connections OK?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	40.0	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	60.0	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	30.0	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BB0150	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	General Comments		
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Foundation Condition	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	ST000034	Structure	557-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	PF000137	PowerFuse	FV-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	K	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	PF000137	PowerFuse	FV-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	PF000137	PowerFuse	FV-12KV TR 2 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	PF000167	PowerFuse	HC-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	PF000167	PowerFuse	HC-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	PF000167	PowerFuse	HC-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Vegetation	None	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	General Comments		
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	General Comments		
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	General Comments	Added Nitrogen	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	0.00	kw
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	115.00	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	110.00	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	Oil Temp Max	52	°C
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	O0211	NonLTC	353-1	NonLTC Transformer Readings	Totalizer Meter Reading	0.0000	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	BAT001427	Battery	CK-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	BAT001427	Battery	CK-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	BAT001427	Battery	CK-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	BAT001427	Battery	CK-Battery Bank	Battery Patrol Inspection	General Comments		
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	BAT001427	Battery	CK-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	BAT001427	Battery	CK-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	BAT001427	Battery	CK-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	BAT001427	Battery	CK-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Patrol Inspection	Bushing Condition	Good	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Amps C Ø	60.0	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Amps B Ø	100.0	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Amps A Ø	60.0	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	MB0144	BreakerVacuum	444-4402	VCB Readings	9 Month Operations	10	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	BAT001427	Battery	CK-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	Oil Temp Present	29	°C
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	Oil Temp Max	35	°C
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	591.84	kw
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	O0213	NonLTC	311-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Follow-up Action Required?	n	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Foundation Condition	Good	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	General Comments		
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	General Comments		
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Grounds in Place?	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Maintenance Operations	0	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Operations Counter AF	187	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Operations Counter AL	187	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Operations This Read Vac	1	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Switching Operations	1	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Unknown Operations	0	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	BCH001131	Charger	859-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.200	millivolts
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	BCH001131	Charger	859-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	BCH001131	Charger	859-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	BCH001131	Charger	859-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	BCH001131	Charger	859-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	BCH001131	Charger	859-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	BCH001131	Charger	859-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	9 Month Operations	12	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Accumulated Fault Duty A Ph V	.55	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Accumulated Fault Duty B Ph V	.55	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Accumulated Fault Duty C Ph V	.55	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Amps A Ø	127.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Amps B Ø	121.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Amps C Ø	122.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Fault Adjusted Amps A Phase V	32.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Fault Adjusted Amps B Phase V	32.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Fault Adjusted Amps C Phase V	32.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Fault Operations A Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Fault Operations B Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Fault Operations C Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Fault Operations Ground	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Maintenance Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Operations Counter AF	177	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Operations Counter AL	177	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Operations This Read Vac	4	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Switching Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Readings	Unknown Operations	4	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	9 Months Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Accumulated Fault Duty A Ph AM	3.38	%
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Accumulated Fault Duty B Ph AM	3.38	%
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Accumulated Fault Duty C Ph AM	3.38	%
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Amps A Ø	571.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Amps B Ø	591.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Amps C Ø	530.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LTO176	WithLTC	SY-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	45	°C
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	Oil Temp Present	35	°C
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	Oil Temp Max	50	°C
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1300	psi
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	LTC Totalizer Reading	12600.00	kw
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	General Comments		
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	General Comments		
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	Follow-up Action Required?	n	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Unknown Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Switching Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Operations This Read Vac	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Operations Counter AL	513	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Operations Counter AF	513	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Maintenance Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Fault Operations Ground	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Fault Operations C Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Fault Operations B Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Fault Operations A Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Amps C Ø	144.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Amps B Ø	146.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Amps A Ø	144.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Accumulated Fault Duty C Ph V	20.51	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Accumulated Fault Duty B Ph V	41.57	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	Accumulated Fault Duty A Ph V	28.26	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Readings	9 Month Operations	0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Fault Operations A Ø	0	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Fault Operations B Ø	0	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Fault Operations C Ø	0	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Fault Operations Ground	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Tank Leaks	None	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Regulator As Left Counter	91900	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	122.6	volts
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Max Tap Position	1R	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	General Comments	Counter not operational	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0516	Regulator	311-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	LTCC000894	LTCControl	032-6	LTC Control Insp	All Connections OK?	y	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	LTCC000894	LTCControl	032-6	LTC Control Insp	Follow-up Action Required?	n	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	LTCC000894	LTCControl	032-6	LTC Control Insp	General Comments		
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	LTCC000894	LTCControl	032-6	LTC Control Insp	LTC Operation Checked?	y	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	LTCC000894	LTCControl	032-6	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	LTCC000894	LTCControl	032-6	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	LTCC000894	LTCControl	032-6	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	LTCC000894	LTCControl	032-6	LTC Control Insp	VRR Time Delay	60	Seconds
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	LTCC000895	LTCControl	859-1	LTC Control Insp	All Connections OK?	y	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	LTCC000895	LTCControl	859-1	LTC Control Insp	Follow-up Action Required?	n	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	LTCC000895	LTCControl	859-1	LTC Control Insp	General Comments		
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	LTCC000895	LTCControl	859-1	LTC Control Insp	LTC Operation Checked?	y	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	LTCC000895	LTCControl	859-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	LTCC000895	LTCControl	859-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	25	°C
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	65	°C
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	30	°C
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0173	WithLTC	SY-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	70	°C
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	70	°C
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	36	°C
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	78	°C
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	40	°C
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	74	°C
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Leaks	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1400	psi
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Unknown Operations	0	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Switching Operations	0	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Operations This Read AM	0	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Operations Counter AL	316	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Operations Counter AF	316	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Maintenance Operations	0	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	General Comments		
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Patrol Inspection	General Comments		
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Follow-up Action Required?	n	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Fault Operations Ground	0	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Fault Operations C ∅	0	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Fault Operations B ∅	0	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Fault Operations A ∅	0	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Amps C ∅	200.0	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Amps B ∅	180.0	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Amps A ∅	200.0	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0180	BreakerAirMagnetic	CK-0002	AMCB Readings	9 Months Operations	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	General Comments	pump is seeping oil. pic sent to Stinson	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LT0176	WithLTC	SY-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	General Comments	Barbed wire is rusty on side facing the road.	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Ambient Temp	60	°F
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	143	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	143	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	General Comments		
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Vegetation	None	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	LTCC000300	LTCControl	710-3	LTC Control Insp	VRR Time Delay	30	Seconds
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	LTCC000300	LTCControl	710-3	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	LTCC000300	LTCControl	710-3	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	LTCC000300	LTCControl	710-3	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	LTCC000300	LTCControl	710-3	LTC Control Insp	LTC Operation Checked?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	LTCC000300	LTCControl	710-3	LTC Control Insp	General Comments		
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	LTCC000300	LTCControl	710-3	LTC Control Insp	Follow-up Action Required?	n	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	LTCC000300	LTCControl	710-3	LTC Control Insp	All Connections OK?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	YD000032	Yard	557-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	YD000114	Yard	353-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	4.85	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	9 Month Operations	31	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Amps A Ø	700.0	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	Winding Temp Present	30	°C
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	Winding Temp Max	35	°C
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	Totalizer Meter Reading	965.0000	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	3	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Accumulated Fault Duty C Ph V	50.43	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Accumulated Fault Duty B Ph V	51.54	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	Accumulated Fault Duty A Ph V	55.42	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Readings	9 Month Operations	0	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Fault Operations C Ø	0	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Fault Operations B Ø	0	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Fault Operations A Ø	0	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	RC900703	RecloserElectronic	977-Offline-Distribution	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	RC900703	RecloserElectronic	977-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	RC900703	RecloserElectronic	977-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	RC900703	RecloserElectronic	977-Offline-Distribution	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	RC900703	RecloserElectronic	977-Offline-Distribution	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	RC900703	RecloserElectronic	977-Offline-Distribution	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	RC900703	RecloserElectronic	977-Offline-Distribution	Recloser Electronic Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	RC900703	RecloserElectronic	977-Offline-Distribution	Recloser Electronic Patrol Inspection	General Comments		
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	RC900703	RecloserElectronic	977-Offline-Distribution	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	RC900703	RecloserElectronic	977-Offline-Distribution	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	RC900703	RecloserElectronic	977-Offline-Distribution	Recloser Electronic Patrol Inspection	Operations Counter	0	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	RC900703	RecloserElectronic	977-Offline-Distribution	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	RC900703	RecloserElectronic	977-Offline-Distribution	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Amps C Ø	150.0	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Amps B Ø	100.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Amps A Ø	50.0	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	LB0181	BreakerAirMagnetic	CK-0003	AMCB Readings	9 Months Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	89.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	33.54	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	3	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	FE000113	Fence	353-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	General Comments	Control is GE 779C345AA P21	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Current Tap Position	Neutral	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Readings	Follow-up Action Required?	n	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	General Comments		
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Readings	General Comments		
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Readings	LTC Totalizer Reading	244.80	kw
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	Winding Temp Present	35	°C
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	Winding Temp Max	55	°C
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	Totalizer Meter Reading	.5250	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Readings	Totalizer Meter Multiplier	24000	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Readings	Oil Temp Max	46	°C
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Readings	Oil Temp Present	39	°C
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Readings	Totalizer Meter Multiplier	2400	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Readings	Totalizer Meter Reading	.1020	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	B0257	WithLTC	859-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	TX000132	WithLTC	853-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	Oil Temp Present	30	°C
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	Oil Temp Max	30	°C
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	LTC Totalizer Reading	7720000.00	kw
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	General Comments		
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	General Comments		
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	Follow-up Action Required?	n	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	KT0020	WithLTC	710-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Amps B Ø	700.0	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Amps C Ø	700.0	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LTCC000485	LTCControl	SY-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LTCC000485	LTCControl	SY-TRANS 2	LTC Control Insp	General Comments		
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LTCC000485	LTCControl	SY-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LTCC000485	LTCControl	SY-TRANS 2	LTC Control Insp	All Connections OK?	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	K0182	BreakerVacuum	369-0681	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Tank Leaks	None	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Regulator As Left Counter	140584	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Min Tap Position	8L	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	R0805	Regulator	557-2 B	Regulator Patrol Inspection	Max Tap Position	3R	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	9 Months Operations	0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	General Comments		
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Amps C Ø	280.0	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	General Comments		
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Bushing Condition	Good	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Counter Readings	Follow-up Action Required?	n	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	Oil Temp Max	48	°C
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	220.00	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	°F
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	225.00	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	0.00	kw
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Readings	Switching Operations	1	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	SF6 Pressure Indicator	good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	General Comments		
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	CH000430	ControlHouse	853-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	9 Month Operations	6	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Amps A Ø	12.0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	SF6 Bushing Condition	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Readings	Operations This Read SF6	1	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Readings	Operations Counter AL	48	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Amps B Ø	12.0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Fault Operations Ground	0	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Fault Operations C Ø	0	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Fault Operations B Ø	0	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Fault Operations A Ø	0	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Patrol Inspection	Bushing Condition	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Amps C Ø	84.0	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Amps B Ø	100.0	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Amps A Ø	101.0	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	General Comments	Recloser is open. No station load	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BCH001161	Charger	853-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	FE000050	Fence	883-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BCH001161	Charger	853-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Switching Operations	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Operations This Read AM	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Operations Counter AL	20	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Operations Counter AF	20	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Maintenance Operations	0	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	BCH001166	Charger	328-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	BCH001166	Charger	328-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	52.9	VDC
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	BCH001166	Charger	328-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	52.9	VDC
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	BCH001166	Charger	328-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	BCH001166	Charger	328-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	BCH001166	Charger	328-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	BCH001166	Charger	328-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/1/2020 15:32	Distribution	Sandy Ridge Quarterly Inspection	BCH001166	Charger	328-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	General Comments		
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Patrol Inspection	General Comments		
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BCH001161	Charger	853-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.0	amps
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BCH001161	Charger	853-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BCH001161	Charger	853-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Amps C Ø	297.0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Amps B Ø	291.0	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Amps A Ø	285.0	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	9 Month Operations	27	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BCH001161	Charger	853-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BAT001217	Battery	853-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Counter Readings	LTC As Found Counter	6543	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Mechanism Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Counter Readings	General Comments		
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	LB0883	BreakerAirMagnetic	SY-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Operations Counter AF	99999	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Operations Counter AL	0	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Operations This Read Vac	2	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Switching Operations	1	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Unknown Operations	0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	9 Month Operations	7	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Amps A Ø	115.0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Amps B Ø	130.0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Amps C Ø	120.0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Bushing Condition	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Readings	Maintenance Operations	0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Heaters (All) Functioning?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Grounds in Place?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Unknown Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Readings	Switching Operations	0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	General Comments		
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	.95	%
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	.95	%
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	87.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	88.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	85.0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Fault Adjusted Amps A Phase V	24.75	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Fault Adjusted Amps B Phase V	24.75	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Fault Adjusted Amps C Phase V	12.37	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Fault Operations A Ø	1	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Fault Operations B Ø	1	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Fault Operations C Ø	0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Fault Operations Ground	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	General Comments	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Readings	General Comments		
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Gauge(s) Condition	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Foundation Condition	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Readings	Follow-up Action Required?	n	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Readings	Fault Operations	0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Ambient Temperature	61	*F
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	9 Months Operations	8	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Accumulated Fault Duty A Ph AM	1.23	%
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Fault Operations B Ø	0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Fault Operations C Ø	0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Fault Operations Ground	0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Follow-up Action Required?	n	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	LTC Operations Since Last Insp	1295	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	LTC Min Tap Position	12L	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	LTC Max Tap Position	2L	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	LTC Current Tap Position	2L	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	LTC As Left Counter	370578	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Foundation Condition	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	General Comments		
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	LTC As Found Counter	370569	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Mechanism Patrol Inspection	General Comments		
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	General Comments		
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0040	LTCMechanism	557-1	LTC Counter Readings	Follow-up Action Required?	n	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Amps A Ø	2.0	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Amps B Ø	6.0	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Amps C Ø	2.0	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Readings	Operations Counter AF	47	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000631	BreakerSF6	853-608	GCB Patrol Inspection	Num Operations Last 9 Months	1	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	General Comments		
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Grounds in Place?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Maintenance Operations	0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Operations Counter AF	166	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Operations Counter AL	168	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Operations This Read Vac	2	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Switching Operations	2	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Unknown Operations	0	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Amps C Ø	12.0	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Bushing Condition	Good	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	General Comments		
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Operations Counter	11	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Tank Leaks	None	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	MX0351	RecloserElectronic	883-4427	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Fault Adjusted Amps B Phase V	3.04	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Fault Operations A Ø	0	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Fault Operations B Ø	1	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Fault Operations Ground	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Follow-up Action Required?	n	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Foundation Condition	Good	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	General Comments		
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	General Comments	51 B-I	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Patrol Inspection	Grounds in Place?	y	
10/1/2020 12:19	Distribution	Dayhoit Quarterly Inspection	DB0057	BreakerVacuum	403-0414	VCB Readings	Maintenance Operations	0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	.5	psi
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Grounds in Place?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Broom on Site?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Control House Lighting OK?	n	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Floor Swept?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Follow-up Action Required?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Unknown Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Switching Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Operations This Read AM	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Operations Counter AL	898	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Operations Counter AF	898	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Maintenance Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Fault Operations Ground	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Fault Operations C Ø	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Fault Operations B Ø	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Fault Operations A Ø	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Amps C Ø	46.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Amps B Ø	48.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Amps A Ø	39.0	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	General Comments		
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	General Comments		
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Foundation Condition	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Counter Readings	LTC Min Tap Position	6L	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Counter Readings	LTC Max Tap Position	7R	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Counter Readings	LTC Current Tap Position	5L	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Counter Readings	LTC As Left Counter	51056	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Counter Readings	LTC As Found Counter	52056	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Accumulated Fault Duty C Ph AM	6.07	%
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	General Comments	2 4ft bulbs not working replaced bulbs still didnt work	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Panels Dusted?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Trash Emptied?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	CH000180	ControlHouse	SY-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	9 Month Operations	1	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Mechanism Patrol Inspection	General Comments		
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Counter Readings	General Comments		
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Counter Readings	Follow-up Action Required?	n	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Amps A Ø	0.0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Amps B Ø	0.0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Amps C Ø	0.0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	61.0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	66.0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	65.0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	General Comments		
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	Oil Temp Max	45	°C
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	PF000144	PowerFuse	FV-STA SER NO 8	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	PF000144	PowerFuse	FV-STA SER NO 8	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	PF000144	PowerFuse	FV-STA SER NO 8	Disconnect Powerfuse Inspection	General Comments	ok	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	PF000145	PowerFuse	FV-14KV TR 8 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	PF000145	PowerFuse	FV-14KV TR 8 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	PF000145	PowerFuse	FV-14KV TR 8 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	55	°C
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	40	°C
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	PF000143	PowerFuse	FV-STA SER NO 6	Disconnect Powerfuse Inspection	General Comments	k	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	166	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	166	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Unknown Operations	0	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Switching Operations	0	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Operations This Read Vac	1	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Operations Counter AL	216	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Operations Counter AF	216	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Maintenance Operations	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	65	°C
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BCH000098	Charger	SY-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.400	millivolts
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BCH000098	Charger	SY-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	134.1	VDC
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BCH000098	Charger	SY-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	134.1	VDC
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	55	°C
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	55	°C
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LT0093	WithLTC	HC-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	42	°C
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	PF000166	PowerFuse	HC-14KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	PF000166	PowerFuse	HC-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	PF000166	PowerFuse	HC-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	PF000168	PowerFuse	HC-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	PF000168	PowerFuse	HC-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	PF000168	PowerFuse	HC-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BCH000098	Charger	SY-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.0	amps
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	B0445	LTCMechanism	853-1	LTC Counter Readings	LTC Operations Since Last Insp	139	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Fault Operations C Ø	0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Fault Operations Ground	0	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Follow-up Action Required?	n	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	General Comments		
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	General Comments		
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	General Comments		
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Ambient Temp	64	*F
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	General Comments		
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Accumulated Fault Duty B Ph AM	9.71	%
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	Accumulated Fault Duty A Ph AM	6.07	%
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Readings	9 Months Operations	3	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Maintenance Operations	0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Operations Counter AF	191	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Operations Counter AL	192	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Operations This Read Vac	1	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Switching Operations	1	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	PF000169	PowerFuse	HC-12KV TR 1 POT	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	PF000169	PowerFuse	HC-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	PF000169	PowerFuse	HC-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	FE000628	Fence	CK-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Unknown Operations	0	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	9 Month Operations	2	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	Totalizer Meter Reading	0.0000	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Amps A Ø	280.0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000640	BreakerVacuum	853-2	VCB Readings	Amps B Ø	300.0	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
10/1/2020 15:33	Distribution	Herald Quarterly Inspection	MX0195	RecloserHydraulic	353-0672	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Unknown Operations	0	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Switching Operations	0	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Operations This Read Vac	0	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Operations Counter AL	163	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Operations Counter AF	163	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Maintenance Operations	0	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Patrol Inspection	Grounds in Place?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	General Comments		
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Patrol Inspection	Foundation Condition	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Readings	Follow-up Action Required?	n	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK001441	BreakerVacuum	557-4406	VCB Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0486	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	4	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Follow-up Action Required?	n	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Fault Operations Ground	0	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Fault Operations C Ø	0	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Fault Operations B Ø	0	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Fault Operations A Ø	1	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Fault Adjusted Amps A Phase V	5.33	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Patrol Inspection	Bushing Condition	Good	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BCH000098	Charger	SY-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BCH000098	Charger	SY-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BCH000098	Charger	SY-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/8/2020 10:36	Distribution	Smyrna Quarterly Inspection	BCH000098	Charger	SY-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Amps C Ø	64.0	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Amps B Ø	95.0	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Amps A Ø	80.0	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KB0102	BreakerVacuum	032-4412	VCB Readings	9 Month Operations	4	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	PF000143	PowerFuse	FV-STA SER NO 6	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	Follow-up Action Required?	n	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	General Comments		
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Mechanism Patrol Inspection	General Comments		
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	LTC As Found Counter	3300	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	LTC As Left Counter	3300	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	LTC Current Tap Position	10L	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	LTC Max Tap Position	4L	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	LTC Min Tap Position	15L	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	LTC Operations Since Last Insp	0	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	W0308	LTCMechanism	883-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	PF000143	PowerFuse	FV-STA SER NO 6	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Counter Readings	LTC Operations Since Last Insp	1327	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Fault Operations A Ø	0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000639	BreakerVacuum	853-BT1-2	VCB Readings	Fault Operations B Ø	0	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Counter Readings	LTC Min Tap Position	12L	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Counter Readings	LTC Max Tap Position	1R	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Counter Readings	LTC Current Tap Position	4L	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	C0411	LTCMechanism	444-3	LTC Counter Readings	LTC As Left Counter	6553	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	General Comments		
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	Vegetation	None	
10/1/2020 11:17	Distribution	Clarks Lane Quarterly Inspection	YD000629	Yard	CK-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	FE000410	Fence	710-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Unknown Operations	0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	9 Month Operations	2	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Amps A Ø	80.0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Amps B Ø	70.0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Amps C Ø	65.0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Bushing Condition	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	9 Month Operations	16	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Fault Operations A Ø	0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Fault Operations B Ø	0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Fault Operations C Ø	0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Fault Operations Ground	0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Follow-up Action Required?	n	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Foundation Condition	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	General Comments		
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	General Comments		
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Grounds in Place?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Maintenance Operations	0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Operations Counter AF	218	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Operations Counter AL	218	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Operations This Read Vac	0	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	Follow-up Action Required?	n	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	General Comments		
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Mechanism Patrol Inspection	General Comments		
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Broom on Site?	n	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Evidence of Insects	None	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Floor Swept?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	General Comments		
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Panels Dusted?	n	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	n	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Trash Emptied?	n	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	CH000486	ControlHouse	859-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	LTC As Found Counter	429251	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	LTC As Left Counter	429260	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Operations Counter AL	205	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Operations Counter AF	205	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	9 Month Operations	0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Amps A Ø	100.0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Amps B Ø	100.0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Amps C Ø	105.0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Bushing Condition	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Maintenance Operations	0	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Grounds in Place?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	General Comments		
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Fault Operations A Ø	0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Fault Operations B Ø	0	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	General Comments		
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Foundation Condition	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Follow-up Action Required?	n	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Fault Operations Ground	0	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Fault Operations C Ø	0	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Fault Operations B Ø	0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Fault Operations C Ø	0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Fault Operations Ground	0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Follow-up Action Required?	n	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Foundation Condition	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	General Comments		
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	General Comments		
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Grounds in Place?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Fault Operations A Ø	0	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Bushing Condition	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Amps C Ø	96.0	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Amps B Ø	89.0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Maintenance Operations	0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Amps A Ø	116.0	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Operations Counter AF	216	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Operations Counter AL	216	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Operations This Read Vac	0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000646	BreakerVacuum	853-0152	VCB Readings	Switching Operations	0	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	General Comments		
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	4315.68	kw
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	Oil Temp Max	52	°C
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	Oil Temp Present	42	°C
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	General Comments	Steel plates on pallets in front of gates	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Clear of Obstacles?	n	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Ambient Temp	64	°F
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Current Tap Position	6L	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	General Comments		
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	General Comments		
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	General Comments	Control is Cooper CL-6B GA17454	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
10/1/2020 10:20	Distribution	Shawnee Gas Quarterly Inspection	BAT001394	Battery	444-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Max Tap Position	3R	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Min Tap Position	12L	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Regulator As Left Counter	26234	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Tank Leaks	None	
10/1/2020 14:06	Distribution	Harlan Y Quarterly Inspection	KR0093	Regulator	032-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/1/2020 15:08	Distribution	Catrons Creek Quarterly Inspection	W0308	WithLTC	883-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	LTC Current Tap Position	8L	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	LTC Max Tap Position	2L	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	LTC Min Tap Position	15L	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000647	BreakerVacuum	853-0195	VCB Readings	Unknown Operations	0	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BCH001042	Charger	710-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BCH001042	Charger	710-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	LTC Operations Since Last Insp	937	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
10/1/2020 10:16	Distribution	Turtle Creek Quarterly Inspection	B0257	LTCMechanism	859-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BCH001042	Charger	710-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BCH001042	Charger	710-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	General Comments		
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BCH001042	Charger	710-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BCH001042	Charger	710-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	ST000041	Structure	369-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Vegetation	None	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/1/2020 15:32	Distribution	Toms Creek 2 Quarterly Inspection	YD000037	Yard	369-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BCH001042	Charger	710-Battery Charger	Battery Charger Patrol Insp	General Comments		
10/1/2020 14:08	Distribution	Kentucky River Quarterly Inspection	BCH001042	Charger	710-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	General Comments		
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Max Tap Position	6L	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Min Tap Position	3R	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
10/1/2020 15:33	Distribution	Newtown Switching Quarterly Inspection	ST000047	Structure	224-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	M0074	NonLTC	557-2	NonLTC Transformer Patrol Inspection	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Operations Counter AF	754	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Maintenance Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	General Comments	ARC sense	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Fault Operations Ground	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LTCC000433	LTCControl	HC-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LTCC000433	LTCControl	HC-TRANS 2	LTC Control Insp	All Connections OK?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Accumulated Fault Duty B Ph AM	1.23	%
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Fault Operations B Ø	0	
10/1/2020 15:33	Distribution	Dwina Quarterly Inspection	R0696	Regulator	311-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Fault Operations A Ø	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Amps C Ø	125.0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Accumulated Fault Duty C Ph AM	2.47	%
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Follow-up Action Required?	n	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Foundation Condition	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1252	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1252	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	General Comments		
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Grounds in Place?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Heaters (All) Functioning?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Maintenance Operations	0	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Moisture and Leak Free?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Operations Counter AF	193	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Operations Counter AL	193	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Operations This Read Vac	3	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Amps A Ø	138.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Amps B Ø	142.0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Unknown Operations	1	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 11:57	Distribution	Lakeshore Quarterly Inspection	BK000641	BreakerVacuum	853-0132	VCB Readings	Switching Operations	0	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Readings	General Comments		
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	General Comments		
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Unknown Operations	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Operations This Read Vac	0	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Switching Operations	0	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Patrol Inspection	Tank Paint Condition	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	BK000830	BreakerVacuum	557-0409	VCB Readings	Unknown Operations	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	519.0	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	480.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Operations This Read AM	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	508.0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Switching Operations	0	
10/1/2020 12:15	Distribution	Liggett Quarterly Inspection	O0181	NonLTC	544-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
10/1/2020 11:52	Distribution	Harlan Quarterly Inspection	FE000035	Fence	557-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LB0482	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LTCC000433	LTCControl	HC-TRANS 2	LTC Control Insp	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Readings	Operations Counter AL	754	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	FE000661	Fence	HC-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/1/2020 14:32	Distribution	Hillcrest Quarterly Inspection	LTCC000433	LTCControl	HC-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	9 Month Operations	4	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	General Comments		
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	605	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BCH001372	Charger	531-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BCH001372	Charger	531-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BCH001372	Charger	531-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BCH001372	Charger	531-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BCH001372	Charger	531-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BCH001372	Charger	531-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BCH001372	Charger	531-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BCH001372	Charger	531-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	220.00	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	605	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	Totalizer Meter Reading	.4344	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Fault Operations B Ø	0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Fault Operations A Ø	0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Fault Adjusted Amps C Phase V	0	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	LTCC000851	LTCControl	692-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	LTCC000851	LTCControl	692-1	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Switching Operations	2	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Tank Paint Condition	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Unknown Operations	0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Fault Operations C Ø	0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Fault Operations Ground	0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Follow-up Action Required?	n	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	LTCC000851	LTCControl	692-1	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	LTCC000851	LTCControl	692-1	LTC Control Insp	LTC Output Voltage Level	122.0	VAC
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	LTCC000851	LTCControl	692-1	LTC Control Insp	LTC Operation Checked?	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	LTCC000851	LTCControl	692-1	LTC Control Insp	General Comments		
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	LTCC000851	LTCControl	692-1	LTC Control Insp	Follow-up Action Required?	n	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	LTCC000851	LTCControl	692-1	LTC Control Insp	All Connections OK?	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Fault Adjusted Amps B Phase V	0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Fault Adjusted Amps A Phase V	0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Bushing Condition	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Amps C Ø	144.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Amps B Ø	161.0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Amps A Ø	170.0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Accumulated Fault Duty C Ph V	1.4	%
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Accumulated Fault Duty B Ph V	.35	%
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Accumulated Fault Duty A Ph V	0	%
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	9 Month Operations	13	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Follow-up Action Required?	n	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0	%
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	1.5	%
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0	%
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	90.0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	100.0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	90.0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Foundation Condition	Good	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	LTC000707	LTCControl	531-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	Totalizer Meter Reading	.8760	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	General Comments		
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Ambient Temp	77	°F
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	ST000409	Structure	531-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	General Comments		
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Vegetation	None	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	YD000313	Yard	692-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Vegetation	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	General Comments		
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	YD000407	Yard	531-Yard	Yard Patrol Inspection	Ambient Temp	70	*F
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	Oil Temp Present	45	*C
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	Oil Temp Max	45	*C
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	LTC Totalizer Reading	9884.16	kw
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	General Comments		
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BCH000495	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0378	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Unknown Operations	0	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Tank Paint Condition	Good	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Switching Operations	4	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Operations This Read Vac	4	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Operations Counter AL	552	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Operations Counter AF	548	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Maintenance Operations	0	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Grounds in Place?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	General Comments		
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	65	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	Totalizer Meter Reading	1.0296	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	General Comments		
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Foundation Condition	Good	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Follow-up Action Required?	n	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Follow-up Action Required?	n	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Fault Operations Ground	0	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Fault Operations C Ø	0	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Fault Operations B Ø	0	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Fault Operations A Ø	0	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Patrol Inspection	Bushing Condition	Good	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Amps C Ø	20.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Amps B Ø	20.0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Amps A Ø	20.0	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0376	BreakerVacuum	531-0908	VCB Readings	9 Month Operations	8	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	Follow-up Action Required?	n	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	General Comments		
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	General Comments		
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	LTC Totalizer Reading	8409.60	kw
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	Oil Temp Max	50	°C
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	Oil Temp Present	50	°C
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	C0503	WithLTC	091-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	45	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	LTCC000707	LTCControl	531-1	LTC Control Insp	All Connections OK?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	LTCC000707	LTCControl	531-1	LTC Control Insp	Follow-up Action Required?	n	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	LTCC000707	LTCControl	531-1	LTC Control Insp	General Comments		
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	LTCC000707	LTCControl	531-1	LTC Control Insp	LTC Operation Checked?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	LTCC000707	LTCControl	531-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	LTCC000707	LTCControl	531-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	LTCC000707	LTCControl	531-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	LTC Totalizer Reading	2940.00	kw
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	General Comments		
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	General Comments		
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Grounds in Place?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	General Comments		
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	General Comments		
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Foundation Condition	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Follow-up Action Required?	n	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Follow-up Action Required?	n	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Fault Operations Ground	0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Fault Operations C Ø	0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Fault Operations B Ø	0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Fault Operations A Ø	0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Fault Adjusted Amps C Phase V	0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Fault Adjusted Amps B Phase V	0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Fault Adjusted Amps A Phase V	0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	Follow-up Action Required?	n	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	General Comments		
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Mechanism Patrol Inspection	General Comments		
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	LTC As Found Counter	84425	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	LTC As Left Counter	84425	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	LTC Current Tap Position	10L	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Operations This Read Vac	9	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Switching Operations	3	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Tank Paint Condition	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Unknown Operations	0	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	LTC Max Tap Position	6L	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	LTC Min Tap Position	10L	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	LTC Operations Since Last Insp	665	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	LTC Operations Since Last Insp	693	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	LTC Min Tap Position	9L	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	LTC Max Tap Position	2L	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	LTC Current Tap Position	5L	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	LTC As Left Counter	73708	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	LTC As Found Counter	73708	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Mechanism Patrol Inspection	General Comments		
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Operations Counter AL	199	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Operations Counter AF	196	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Maintenance Operations	6	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BCH000495	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BCH000495	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BCH000495	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Fault Operations A ∅	0	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Fault Operations B ∅	0	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Fault Operations C ∅	0	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Fault Operations Ground	0	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Follow-up Action Required?	n	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Follow-up Action Required?	n	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Foundation Condition	Good	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	General Comments		
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	General Comments		
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Grounds in Place?	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Maintenance Operations	0	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Operations Counter AF	203	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Operations Counter AL	205	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Operations This Read Vac	2	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Switching Operations	2	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Tank Paint Condition	Good	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Unknown Operations	0	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	9 Month Operations	5	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Amps A Ø	45.0	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Amps B Ø	50.0	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Amps C Ø	50.0	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Bushing Condition	Good	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Fault Operations A Ø	0	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Fault Operations B Ø	0	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Fault Operations C Ø	0	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Fault Operations Ground	0	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Follow-up Action Required?	n	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Follow-up Action Required?	n	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Foundation Condition	Good	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	General Comments		
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	General Comments		
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Grounds in Place?	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Maintenance Operations	0	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Operations Counter AF	188	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Operations Counter AL	190	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Operations This Read Vac	2	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Switching Operations	2	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Patrol Inspection	Tank Paint Condition	Good	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001097	BreakerVacuum	692-0914	VCB Readings	Unknown Operations	0	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	Oil Temp Present	45	°C
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	Oil Temp Max	50	°C
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Maintenance Operations	8	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	Follow-up Action Required?	n	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Grounds in Place?	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	General Comments		
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BCH000495	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BCH000495	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Mechanism Patrol Inspection	General Comments		
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	LTC As Found Counter	81819	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	LTC As Left Counter	81819	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	LTC Current Tap Position	10L	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	LTC Max Tap Position	8L	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	LTC Min Tap Position	13L	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	LTC Operations Since Last Insp	444	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BCH000495	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	General Comments		
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	General Comments		
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	LTC Totalizer Reading	3475.20	kw
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	Oil Temp Max	40	°C
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Readings	Oil Temp Present	35	°C
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Bushing Condition	Good	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Amps C Ø	60.0	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Amps B Ø	55.0	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Amps A Ø	65.0	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	B0295	LTCMechanism	692-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Grounds in Place?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	General Comments		
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	General Comments		
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	77	°F
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BAT000433	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Maintenance Operations	9	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Operations Counter AF	176	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Operations Counter AL	187	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Operations This Read Vac	11	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	B0366	WithLTC	531-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	General Comments		
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	C0503	LTCMechanism	091-5	LTC Counter Readings	Follow-up Action Required?	n	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	B0366	LTCMechanism	531-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	9 Month Operations	14	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Accumulated Fault Duty A Ph V	0	%
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	B0295	WithLTC	692-1	LTC Transformer Readings	Totalizer Meter Reading	.4900	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Patrol Inspection	Bushing Condition	Good	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Amps C Ø	295.0	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Amps B Ø	250.0	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Amps A Ø	180.0	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001096	BreakerVacuum	692-0913	VCB Readings	9 Month Operations	5	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Unknown Operations	0	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Tank Paint Condition	Good	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Switching Operations	2	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Operations This Read Vac	2	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Operations Counter AL	199	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Operations Counter AF	197	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Maintenance Operations	0	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Grounds in Place?	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	General Comments		
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Accumulated Fault Duty B Ph V	.35	%
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Accumulated Fault Duty C Ph V	0	%
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Amps A Ø	169.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	General Comments		
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Amps B Ø	153.0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Amps C Ø	158.0	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Foundation Condition	Good	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Follow-up Action Required?	n	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Follow-up Action Required?	n	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Fault Operations Ground	0	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Fault Operations C Ø	0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Bushing Condition	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Operations Counter AF	188	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Operations Counter AL	190	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Operations This Read Vac	10	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Switching Operations	2	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Patrol Inspection	Tank Paint Condition	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000729	BreakerVacuum	091-0920	VCB Readings	Unknown Operations	0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	9 Month Operations	11	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Accumulated Fault Duty A Ph V	1.75	%
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Accumulated Fault Duty B Ph V	3.84	%
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	General Comments		
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	General Comments		
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0339	WithLTC	091-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Foundation Condition	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Follow-up Action Required?	n	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Follow-up Action Required?	n	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Fault Operations Ground	0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Accumulated Fault Duty C Ph V	.7	%
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Amps A Ø	111.0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Amps B Ø	145.0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Readings	Amps C Ø	93.0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000730	BreakerVacuum	091-0921	VCB Patrol Inspection	Bushing Condition	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Fault Operations C Ø	0	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Fault Operations A Ø	0	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	BK001095	BreakerVacuum	692-0912	VCB Readings	Fault Operations B Ø	0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Fault Operations B Ø	0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Fault Operations A Ø	0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Fault Adjusted Amps C Phase V	0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Fault Adjusted Amps B Phase V	0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Readings	Fault Adjusted Amps A Phase V	0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BK000731	BreakerVacuum	091-0923	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Maintenance Operations	5	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Operations Counter AF	256	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Operations Counter AL	258	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Operations This Read Vac	7	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Switching Operations	2	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Tank Paint Condition	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Unknown Operations	0	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Unknown Operations	0	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Tank Paint Condition	Good	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Switching Operations	4	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Operations This Read Vac	4	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Unknown Operations	0	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Tank Paint Condition	Good	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Switching Operations	2	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Operations This Read Vac	2	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Operations Counter AL	116	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Operations Counter AF	114	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	9 Month Operations	8	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Operations Counter AL	416	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Operations Counter AF	412	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Maintenance Operations	0	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Grounds in Place?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Maintenance Operations	0	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Grounds in Place?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	General Comments		
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Foundation Condition	Good	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Follow-up Action Required?	n	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Follow-up Action Required?	n	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Fault Operations Ground	0	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Fault Operations C Ø	0	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Fault Operations B Ø	0	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Fault Operations A Ø	0	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BAT001451	Battery	531-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	9 Month Operations	8	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Unknown Operations	0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Tank Paint Condition	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Switching Operations	2	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Operations This Read Vac	2	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Operations Counter AL	379	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Operations Counter AF	377	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Maintenance Operations	0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Grounds in Place?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	General Comments		
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Bushing Condition	Good	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Amps C Ø	120.0	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Amps B Ø	100.0	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Amps A Ø	100.0	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	General Comments		
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Foundation Condition	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Follow-up Action Required?	n	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Follow-up Action Required?	n	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Fault Operations Ground	0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Fault Operations C Ø	0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Follow-up Action Required?	n	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Follow-up Action Required?	n	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Foundation Condition	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	General Comments		
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	General Comments		
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Grounds in Place?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Bushing Condition	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Amps C Ø	0.0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Amps B Ø	0.0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Amps A Ø	0.0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Accumulated Fault Duty C Ph V	0	%
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Accumulated Fault Duty B Ph V	0	%
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Accumulated Fault Duty A Ph V	0	%
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	9 Month Operations	4	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	LTC Operations Since Last Insp	852	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	LTC Min Tap Position	9L	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	LTC Max Tap Position	1L	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	LTC Current Tap Position	6L	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	LTC As Left Counter	38887	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	LTC As Found Counter	38887	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	General Comments		
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	General Comments		
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	LTCM000022	LTCMechanism	091-6	LTC Counter Readings	Follow-up Action Required?	n	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	General Comments		
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Patrol Inspection	Bushing Condition	Good	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Amps C Ø	90.0	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Amps B Ø	105.0	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Amps A Ø	80.0	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BK000642	BreakerVacuum	531-0909	VCB Readings	9 Month Operations	4	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	General Comments		
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	FE000830	Fence	531-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Fault Operations B Ø	0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Fault Operations A Ø	0	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	General Comments		
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Foundation Condition	Good	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Follow-up Action Required?	n	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Follow-up Action Required?	n	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Fault Operations Ground	0	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Fault Operations C Ø	0	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Fault Operations B Ø	0	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Fault Operations A Ø	0	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Fault Adjusted Amps C Phase V	0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Fault Adjusted Amps B Phase V	0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Readings	Fault Adjusted Amps A Phase V	0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	BB0463	BreakerVacuum	091-BT6-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Maintenance Operations	0	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Operations Counter AF	158	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Operations Counter AL	162	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Operations This Read Vac	4	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Switching Operations	4	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Patrol Inspection	Bushing Condition	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0339	LTCMechanism	091-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Amps C Ø	100.0	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Amps B Ø	100.0	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0339	LTCMechanism	091-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0339	LTCMechanism	091-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Tank Paint Condition	Good	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Amps A Ø	100.0	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0339	LTCMechanism	091-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0339	LTCMechanism	091-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	General Comments		
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Fault Operations C Ø	0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Fault Operations Ground	0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Fault Operations B Ø	0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Fault Operations A Ø	0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Fault Adjusted Amps C Phase V	0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Fault Adjusted Amps B Phase V	0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Fault Adjusted Amps A Phase V	0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Patrol Inspection	Bushing Condition	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Amps C Ø	158.0	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Fault Operations A Ø	0	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Fault Operations B Ø	0	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Fault Operations C Ø	0	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Fault Operations Ground	0	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Follow-up Action Required?	n	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Follow-up Action Required?	n	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Foundation Condition	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	Follow-up Action Required?	n	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	General Comments		
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	General Comments		
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	LTCC000872	LTCControl	091-6	LTC Control Insp	All Connections OK?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	LTCC000872	LTCControl	091-6	LTC Control Insp	Follow-up Action Required?	n	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	LTCC000872	LTCControl	091-6	LTC Control Insp	General Comments		
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	LTCC000872	LTCControl	091-6	LTC Control Insp	LTC Operation Checked?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	LTCC000872	LTCControl	091-6	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	LTCC000872	LTCControl	091-6	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	LTCC000872	LTCControl	091-6	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	LTCC000872	LTCControl	091-6	LTC Control Insp	VRR Time Delay	30	Seconds
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	LTCC000873	LTCControl	091-5	LTC Control Insp	All Connections OK?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	LTCC000873	LTCControl	091-5	LTC Control Insp	Follow-up Action Required?	n	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	LTCC000873	LTCControl	091-5	LTC Control Insp	General Comments		
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	LTCC000873	LTCControl	091-5	LTC Control Insp	LTC Operation Checked?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	LTCC000873	LTCControl	091-5	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Amps B Ø	153.0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Amps A Ø	169.0	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Accumulated Fault Duty C Ph V	1.05	%
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Accumulated Fault Duty B Ph V	1.05	%
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	LTCC000873	LTCControl	091-5	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	LTCC000873	LTCControl	091-5	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	LTCC000873	LTCControl	091-5	LTC Control Insp	VRR Time Delay	30	Seconds
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	Accumulated Fault Duty A Ph V	0	%
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	KB0111	BreakerVacuum	091-0924	VCB Readings	9 Month Operations	9	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	General Comments		
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	ST000320	Structure	692-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	General Comments		
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0320	BreakerVacuum	531-0906	VCB Readings	Unknown Operations	0	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/29/2020 8:03	Distribution	Kenton Quarterly Inspection	B0463	WithLTC	091-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/29/2020 7:36	Distribution	Maysville East Quarterly Inspection	FE000308	Fence	692-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/29/2020 20:25	Distribution	Maysville Mid Quarterly Inspection	BB0429	BreakerVacuum	531-0907	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	LTCC000636	LTCControl	930-Offline-Distribution	LTC Control Insp	General Comments		
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	LTCC000636	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	LTCC000636	LTCControl	930-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	LTCC000636	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	LTCC000636	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	LTCC000636	LTCControl	930-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	LTCC000636	LTCControl	930-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	LTCC000636	LTCControl	930-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BCH000539	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BCH000539	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BCH000539	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Max Tap Position	5R	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	General Comments		
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Grounds in Place?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	General Comments		
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	80	*F
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	General Comments		
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	General Comments		
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Foundation Condition	Good	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BCH000539	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	General Comments		
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BAT001213	Battery	824-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	9 Month Operations	8	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Bushing Condition	Good	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Amps C Ø	20.0	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Amps B Ø	20.0	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Amps A Ø	20.0	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BCH000539	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	132.0	VDC
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BCH000539	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	132.0	VDC
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	78	*F
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Regulator As Left Counter	2641	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000110	Regulator	872-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BAT001214	Battery	696-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	72.50	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	General Comments		
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Vegetation	None	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	LTCC000511	LTCCControl	697-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	LTCC000511	LTCCControl	697-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	LTCC000511	LTCCControl	697-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	General Comments		
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	General Comments		
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	ST000373	Structure	872-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	LTCC000511	LTCControl	697-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	LTCC000511	LTCControl	697-1	LTC Control Insp	LTC Operation Checked?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	LTCC000511	LTCControl	697-1	LTC Control Insp	General Comments		
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	LTCC000511	LTCControl	697-1	LTC Control Insp	Follow-up Action Required?	n	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	LTCC000511	LTCControl	697-1	LTC Control Insp	All Connections OK?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Regulator As Left Counter	2167	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Follow-up Action Required?	n	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Follow-up Action Required?	n	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Fault Operations Ground	0	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Fault Operations C ∅	0	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Fault Operations B ∅	0	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Fault Operations A ∅	0	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	9 Month Operations	8	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Amps A Ø	120.0	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Amps B Ø	60.0	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Amps C Ø	60.0	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Bushing Condition	Good	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Bushing Condition	Good	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Amps C Ø	20.0	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Amps B Ø	20.0	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Amps A Ø	20.0	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	9 Month Operations	8	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	General Comments		
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Ambient Temp	80	*F
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	YD000289	Yard	824-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	0964	NonLTC	872-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	FE000857	Fence	697-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	General Comments		
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Readings	General Comments		
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	205.00	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	200.00	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Readings	Oil Temp Max	35	°C
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Readings	Oil Temp Present	30	°C
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	132.0	VDC
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	132.0	VDC
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BCH001154	Charger	824-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Vegetation	None	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	All Identified and Legible?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	General Comments		
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Ambient Temp	68	*F
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	General Comments		
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	YD000086	Yard	375-Yard	Yard Patrol Inspection	Vegetation	None	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Unknown Operations	0	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Tank Paint Condition	Good	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Switching Operations	2	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Operations This Read Vac	4	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Operations Counter AL	43	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Operations Counter AF	41	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Maintenance Operations	0	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Grounds in Place?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	General Comments		
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Foundation Condition	Good	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Follow-up Action Required?	n	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Follow-up Action Required?	n	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Fault Operations Ground	0	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Fault Operations C Ø	2	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Fault Operations B Ø	0	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Fault Operations A Ø	0	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Fault Adjusted Amps C Phase V	2.96	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Unknown Operations	0	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Tank Paint Condition	Good	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Tank Leaks	None	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Tank 3 Oil Level	Good	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Tank 2 Oil level	Good	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Tank 1 Oil Level	Good	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Switching Operations	0	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Pressure Vessel Condition	Good	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Pop-off Valve Tested Date	2020-04-08 00:00:00.000000	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Operations This Read Oil	0	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Operations Counter AL	426	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Operations Counter AF	426	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Number of Ops last 9 Months	7	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Moisture and Leak Free?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Maintenance Operations	0	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Heaters (All) Functioning?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Grounds in Place?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	General Comments		
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	General Comments		
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Gauge(s) Condition	Good	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Foundation Condition	Good	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Follow-up Action Required?	n	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Readings	Fault Operations	0	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Equipment Properly Labeled?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Cabinet Paint Condition	Good	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Bushings Connection/Risers	Good	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Bushing Oil Level	Good	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Bushing Condition	Good	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Air Pressure OK?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Air Leaks	None	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Air Compressor Oil Status	Good	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TB0237	BreakerOil	824-708	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	General Comments		
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Patrol Inspection	Bushing Condition	Good	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Amps C Ø	10.0	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Amps B Ø	10.0	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Amps A Ø	10.0	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0358	BreakerVacuum	696-0965	VCB Readings	9 Month Operations	9	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	ST000400	Structure	697-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	General Comments		
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	ST000092	Structure	375-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	C0327	NonLTC	375-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	Follow-up Action Required?	n	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	General Comments		
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Mechanism Patrol Inspection	General Comments		
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	LTC As Found Counter	178361	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	LTC As Left Counter	178361	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	LTC Max Tap Position	2R	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	LTC Min Tap Position	6L	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	LTC Operations Since Last Insp	550	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	B0245	LTCMechanism	697-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Operations Counter	34	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Switching Operations	4	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Tank Paint Condition	Good	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Unknown Operations	0	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Maintenance Operations	0	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Operations Counter AF	113	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Operations Counter AL	117	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Readings	Operations This Read Vac	4	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0400	BreakerVacuum	697-0902	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	General Comments		
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Regulator As Left Counter	2192	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000111	Regulator	872-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Amps A Ø	0.0	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Amps B Ø	10.0	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Amps C Ø	0.0	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Battery Load Check OK?	n	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	KX0078	RecloserElectronic	872-0941	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Unknown Operations	0	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	76	*F
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BCH001399	Charger	697-Battery Bank	Battery Charger Patrol Insp	Ground Lights	None	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BCH001399	Charger	697-Battery Bank	Battery Charger Patrol Insp	General Comments		
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BCH001399	Charger	697-Battery Bank	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BCH001399	Charger	697-Battery Bank	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BCH001399	Charger	697-Battery Bank	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BCH001399	Charger	697-Battery Bank	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BCH001399	Charger	697-Battery Bank	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BCH001399	Charger	697-Battery Bank	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Ambient Temp	76	*F
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	General Comments		
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	Follow-up Action Required?	n	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	General Comments		
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Mechanism Patrol Inspection	General Comments		
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	LTC As Found Counter	38851	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	LTC As Left Counter	38851	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	LTC Current Tap Position	3R	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	LTC Max Tap Position	8R	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	LTC Min Tap Position	3R	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	LTC Operations Since Last Insp	1201	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	LTCM000098	LTCMechanism	696-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	YD000397	Yard	697-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	General Comments		
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	General Comments		
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	FE000829	Fence	824-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BAT001462	Battery	697-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	FE000088	Fence	375-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Fault Operations A Ø	0	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Fault Operations B Ø	0	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Fault Operations C Ø	0	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Fault Operations Ground	0	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Follow-up Action Required?	n	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Follow-up Action Required?	n	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Foundation Condition	Good	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	General Comments		
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	General Comments		
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Grounds in Place?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Maintenance Operations	0	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Operations Counter AF	298	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Operations Counter AL	302	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Operations This Read Vac	4	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Readings	Switching Operations	4	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0227	BreakerVacuum	696-0966	VCB Patrol Inspection	Tank Paint Condition	Good	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	LTCC000648	LTCControl	824-1	LTC Control Insp	LTC Operation Checked?	y	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Patrol Inspection	General Comments		
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Readings	NonLTC Transformer Readings		
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Patrol Inspection	NonLTC Trn Health	60.00	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	55.00	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Readings	Oil Temp Max	42	°C
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Readings	Oil Temp Present	31	°C
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	LTCC000648	LTCControl	824-1	LTC Control Insp	General Comments		
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	LTCC000648	LTCControl	824-1	LTC Control Insp	Follow-up Action Required?	n	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	LTCC000648	LTCControl	824-1	LTC Control Insp	All Connections OK?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	LTC Operations Since Last Insp	911	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	°C
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	40	°C
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	LTC Min Tap Position	6L	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	LTC Max Tap Position	2R	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	LTC Current Tap Position	1L	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	LTC As Left Counter	12492	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	LTC As Found Counter	12492	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	General Comments		
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	General Comments		
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	LTCM000037	LTCMechanism	824-1	LTC Counter Readings	Follow-up Action Required?	n	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Ambient Temp	78	°F
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	General Comments		
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	General Comments		
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	LTC Totalizer Reading	3525.12	kw
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1600	psi
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	Oil Temp Max	40	°C
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	Oil Temp Present	30	°C
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	General Comments		
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	Totalizer Meter Reading	.7344	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	Winding Temp Max	30	°C
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	Winding Temp Present	30	°C
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	TX000055	WithLTC	824-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	General Comments		
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	Totalizer Meter Reading	.7104	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Fault Operations B Ø	0	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Fault Operations A Ø	0	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Bushing Condition	Good	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Amps C Ø	102.0	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Amps B Ø	91.0	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Amps A Ø	100.0	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	9 Month Operations	5	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Ambient Temp	78	°F
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	W0210	NonLTC	375-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	LTCC000648	LTCControl	824-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	LTCC000648	LTCControl	824-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	LTCC000648	LTCControl	824-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	LTCC000648	LTCControl	824-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	General Comments		
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	General Comments		
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	LTC Totalizer Reading	3409.92	kw
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	Oil Temp Max	50	°C
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Readings	Oil Temp Present	40	°C
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	B0365	WithLTC	696-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	9 Month Operations	8	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Vegetation	None	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	YD000371	Yard	872-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Fault Operations A Ø	0	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Unknown Operations	0	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Tank Paint Condition	Good	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Switching Operations	4	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Operations This Read Vac	4	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Operations Counter AL	157	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	General Comments		
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Free of Audible Arcing?	n	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Operations Counter AF	153	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Maintenance Operations	0	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Grounds in Place?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	General Comments		
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	General Comments		
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Foundation Condition	Good	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Follow-up Action Required?	n	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Follow-up Action Required?	n	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Fault Operations Ground	0	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Fault Operations C Ø	0	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Fault Operations B Ø	0	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Fault Operations A Ø	0	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Bushings Connection/Risers	Good	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Bushing Oil Level	Good	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Operations Counter AF	161	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Maintenance Operations	0	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Grounds in Place?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	General Comments		
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Bushing Condition	Good	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Air Pressure OK?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Air Leaks	None	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Operations Counter AL	163	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Operations This Read Vac	2	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Switching Operations	2	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Tank Paint Condition	Good	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Unknown Operations	0	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	General Comments		
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Air Compressor Oil Status	Good	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	General Comments		
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Foundation Condition	Good	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Follow-up Action Required?	n	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Follow-up Action Required?	n	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Fault Operations Ground	0	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Fault Operations C Ø	0	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Fault Operations B Ø	0	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	FE000864	Fence	872-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Patrol Inspection	Bushing Condition	Good	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Amps C Ø	60.0	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Amps B Ø	90.0	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Amps A Ø	90.0	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0319	BreakerVacuum	697-0900	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Maintenance Operations	0	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Grounds in Place?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	General Comments		
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Foundation Condition	Good	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Follow-up Action Required?	n	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Follow-up Action Required?	n	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Fault Operations Ground	0	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Fault Operations C Ø	0	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	General Comments		
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Patrol Inspection	Bushing Condition	Good	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Amps C Ø	50.0	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Amps B Ø	57.0	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Amps A Ø	74.0	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000918	BreakerVacuum	824-0961	VCB Readings	9 Month Operations	4	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Unknown Operations	0	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Patrol Inspection	Tank Paint Condition	Good	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Switching Operations	2	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Operations This Read Vac	2	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Operations Counter AL	164	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	BK000917	BreakerVacuum	824-0960	VCB Readings	Operations Counter AF	162	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	General Comments		
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	CH000349	ControlHouse	824-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Vegetation	None	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	General Comments		
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	YD000314	Yard	696-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Operations Counter AL	110	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Operations This Read Vac	4	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Switching Operations	4	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Tank Paint Condition	Good	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Unknown Operations	0	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	9 Month Operations	54	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Acceptable Building Appearance?		
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Unknown Operations	0	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Tank Paint Condition	Good	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Switching Operations	4	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Operations This Read Vac	4	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Operations Counter AL	27	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Operations Counter AF	23	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Maintenance Operations	0	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Grounds in Place?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	General Comments		
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	General Comments		
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Foundation Condition	Good	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Follow-up Action Required?	n	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Patrol Inspection	Follow-up Action Required?	n	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Fault Operations Ground	0	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Amps A Ø	20.0	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Amps B Ø	20.0	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Amps C Ø	20.0	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Bushing Condition	Good	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	Oil Temp Present	30	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	Oil Temp Max	35	°C
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	220.00	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	225.00	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	21.24	kw
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	General Comments		
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	General Comments		
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Pressure Vessel Condition	Good	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Fault Operations A ∅	0	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Fault Operations B ∅	0	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Fault Operations C ∅	0	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Fault Operations Ground	0	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Switching Operations	0	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Tank 1 Oil Level	Good	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Tank 2 Oil level	Good	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Tank 3 Oil Level	Good	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Follow-up Action Required?	n	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Follow-up Action Required?	n	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Foundation Condition	Good	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	General Comments		
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	General Comments		
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Grounds in Place?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Maintenance Operations	0	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Operations Counter AF	106	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Maintenance Operations	39	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Operations Counter AF	991	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Operations Counter AL	995	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Operations This Read Vac	46	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Switching Operations	4	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Tank Paint Condition	Good	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Unknown Operations	0	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	Totalizer Meter Reading	.5132	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	Totalizer Meter Multiplier	8000	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	Oil Temp Present	40	°C
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	Oil Temp Max	40	°C
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	LTC Totalizer Reading	4105.60	kw
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	General Comments		
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	General Comments		
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Fault Adjusted Amps C Phase V	4.45	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Fault Operations A Ø	0	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Fault Operations B Ø	0	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Fault Operations C Ø	3	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Fault Operations Ground	0	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Follow-up Action Required?	n	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	Follow-up Action Required?	n	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Foundation Condition	Good	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	General Comments		
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Readings	General Comments		
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Amps A Ø	34.0	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Amps B Ø	35.0	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Amps C Ø	37.0	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Battery Load Check OK?	n	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	General Comments		
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Operations Counter	94	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Fault Operations C Ø	0	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Fault Operations B Ø	0	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0206	BreakerVacuum	697-0903	VCB Readings	Fault Operations A Ø	0	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Tank Leaks	None	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Tank Paint Condition	Good	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Unknown Operations	0	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	KX0077	RecloserElectronic	872-0940	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	B0245	WithLTC	697-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/28/2020 14:09	Distribution	Flemingsburg Quarterly Inspection	ST000297	Structure	824-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Grounds in Place?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	BB0379	BreakerVacuum	696-0967	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Equipment Properly Labeled?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Fault Operations	0	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Follow-up Action Required?	n	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Follow-up Action Required?	n	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	300	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	9 Month Operations	8	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.0708	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Foundation Condition	Good	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Gauge(s) Condition	Good	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Bushing Condition	Good	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Amps C Ø	90.0	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	General Comments		
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	General Comments		
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Grounds in Place?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Heaters (All) Functioning?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Maintenance Operations	0	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/28/2020 15:40	Distribution	Bens Branch Quarterly Inspection	C0328	NonLTC	375-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Cabinet Paint Condition	Good	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Pop-off Valve Tested Date	2020-03-19 00:00:00.000000	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	ST000321	Structure	696-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Amps A Ø	120.0	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Readings	Amps B Ø	100.0	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Operations This Read Oil	0	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Operations Counter AL	1091	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Operations Counter AF	1091	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Readings	Number of Ops last 9 Months	0	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	TB0238	BreakerOil	696-708	OCB Patrol Inspection	Moisture and Leak Free?	y	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/28/2020 12:00	Distribution	Maysville West Quarterly Inspection	BB0234	BreakerVacuum	697-0901	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	General Comments		
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
9/28/2020 11:50	Distribution	Sardis Quarterly Inspection	RG000109	Regulator	872-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	CH000379	ControlHouse	696-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/28/2020 12:12	Distribution	Wedonia Quarterly Inspection	FE000309	Fence	696-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	5.0	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	0	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	5.0	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	5.0	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	162	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	0	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	0	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	GX0203	RecloserHydraulic	930-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	342	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	20.0	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	20.0	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	20.0	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	342	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	0	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Unknown Operations	0	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	174	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	170	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	0	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	240.0	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	11	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Amps A Ø	30.0	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	General Comments		
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	26.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	B0262	NonLTC	932-Offline Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	General Comments		
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Unknown Operations	0	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Tank Paint Condition	Good	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Switching Operations	0	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Operations This Read Vac	0	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments	HAS DESSICANT DRYER ON LTC	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	10433	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	10433	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	6L	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Max Tap Position	3R	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Min Tap Position	12L	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Operations Counter AL	147	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Operations Counter AF	145	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Maintenance Operations	0	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Tank Paint Condition	Good	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Switching Operations	0	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	251	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	256	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	5	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Operations This Read Vac	0	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Operations Counter AL	200	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Operations Counter AF	200	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Maintenance Operations	0	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Grounds in Place?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	General Comments		
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	General Comments		
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Foundation Condition	Good	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Follow-up Action Required?	n	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Fault Operations Ground	0	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Fault Operations C Ø	0	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Fault Operations B Ø	0	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0318	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Ambient Temp	74	*F
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Bushing Condition	Good	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Amps C Ø	30.0	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Amps B Ø	40.0	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Vegetation	None	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	LTCC000710	LTCControl	633-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	LTC As Left Counter	224450	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	LTC Current Tap Position	4L	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	1	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	5.99	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	General Comments		
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	100.0	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	LTCC000710	LTCControl	633-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	LTCC000710	LTCControl	633-1	LTC Control Insp	LTC Operation Checked?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	LTCC000710	LTCControl	633-1	LTC Control Insp	General Comments		
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	LTCC000710	LTCControl	633-1	LTC Control Insp	Follow-up Action Required?	n	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	LTCC000710	LTCControl	633-1	LTC Control Insp	All Connections OK?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Foundation Condition	Good	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	General Comments		
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	General Comments		
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	217	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	221	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Follow-up Action Required?	n	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	General Comments		
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	FE000288	Fence	766-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Fault Operations Ground	0	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Fault Operations C Ø	0	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Fault Operations B Ø	0	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Fault Operations A Ø	0	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	LTC Operations Since Last Insp	1276	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	General Comments		
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	LTCC000710	LTCControl	633-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	300.0	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	280.0	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	General Comments		
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	LTC As Found Counter	224450	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	LTCC000710	LTCControl	633-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	70.0	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0292	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	80.0	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	9 Month Operations	29	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	LTCC000710	LTCControl	633-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Grounds in Place?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Maintenance Operations	0	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Operations Counter AF	155	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Operations Counter AL	157	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Operations This Read Vac	2	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Switching Operations	2	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	General Comments		
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Patrol Inspection	Tank Paint Condition	Good	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001398	BreakerVacuum	633-0640	VCB Readings	Unknown Operations	0	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	ST000363	Structure	839-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	Follow-up Action Required?	n	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BB0278	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	LTC Max Tap Position	16R	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	YD000360	Yard	839-Yard	Yard Patrol Inspection	Ambient Temp	71	°F
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	B0276	LTCMechanism	839-1	LTC Counter Readings	LTC Min Tap Position	10L	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments		
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Readings	General Comments		
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Readings	LTC Totalizer Reading	10389.60	kw
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Max	60	°C
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Present	40	°C
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Readings	Totalizer Meter Reading	.5772	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Readings	Winding Temp Max	60	°C
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Readings	Winding Temp Present	50	°C
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	220.00	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	Totalizer Meter Reading	.5256	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	LTCC000247	LTCControl	839-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	LTCC000247	LTCControl	839-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	LTCC000247	LTCControl	839-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	LTCC000247	LTCControl	839-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelloff	Position
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	LTCC000247	LTCControl	839-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	LTCC000247	LTCControl	839-1	LTC Control Insp	LTC Operation Checked?	y	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	LTCC000247	LTCControl	839-1	LTC Control Insp	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	LTCC000247	LTCControl	839-1	LTC Control Insp	Follow-up Action Required?	n	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	LTCC000247	LTCControl	839-1	LTC Control Insp	All Connections OK?	y	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	9 Month Operations	8	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	74	°F
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Battery Bank Amps	1.5	AMPS
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Battery Bank Volts	53.0	VDC
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	Winding Temp Max	40	°C
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	Winding Temp Present	40	°C
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BCH001400	Charger	633-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BCH001400	Charger	633-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BCH001400	Charger	633-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Bushing Condition	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Follow-up Action Required?	n	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Foundation Condition	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	General Comments		
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Grounds in Place?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	K0143	BreakerVacuum	556-2465	VCB Patrol Inspection	Tank Paint Condition	Good	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BCH001400	Charger	633-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BCH001400	Charger	633-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BCH001400	Charger	633-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BCH001400	Charger	633-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BCH001400	Charger	633-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	General Comments		
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	General Comments		
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	LTC Totalizer Reading	1681.92	kw
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	Oil Temp Max	50	°C
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	B0276	WithLTC	839-1	LTC Transformer Readings	Oil Temp Present	40	°C
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Vegetation	None	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	B0420	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Grounds in Place?	y	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Maintenance Operations	0	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	General Comments		
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Operations Counter AF	325	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Operations Counter AL	329	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Operations This Read Vac	4	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Switching Operations	4	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Tank Paint Condition	Good	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Unknown Operations	0	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	BCH001014	Charger	839-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	BCH001014	Charger	839-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	BCH001014	Charger	839-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	BCH001014	Charger	839-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	Follow-up Action Required?	n	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	General Comments		
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Mechanism Patrol Inspection	LTC As Found Counter	11643	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	LTC As Left Counter	11643	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	General Comments		
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BAT001463	Battery	633-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	LTC Current Tap Position	3L	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	LTC Max Tap Position	6R	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	LTC Min Tap Position	7L	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	LTC Operations Since Last Insp	1672	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	B0386	LTCMechanism	633-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Amps A Ø	65.0	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Amps B Ø	65.0	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Amps C Ø	65.0	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Bushing Condition	Good	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BAT001039	Battery	766-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	General Comments		
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	R1027	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	ST000299	Structure	766-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Fault Operations A Ø	0	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Fault Operations B Ø	0	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Fault Operations C Ø	0	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Fault Operations Ground	0	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Follow-up Action Required?	n	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	Follow-up Action Required?	n	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	Foundation Condition	Good	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Patrol Inspection	General Comments		
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	K0170	BreakerVacuum	839-0636	VCB Readings	General Comments		
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Fault Operations Ground	0	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Fault Operations C Ø	0	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Fault Operations B Ø	0	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	Follow-up Action Required?	n	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	General Comments		
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	General Comments		
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	LTC Totalizer Reading	9527.04	kw
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	Oil Temp Max	40	°C
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	Oil Temp Present	30	°C
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	9 Month Operations	0	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Fault Operations A Ø	0	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	FE000361	Fence	633-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	General Comments		
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	2149	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	B0420	LTCMechanism	930-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Bushing Condition	Good	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Amps C Ø	260.0	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Amps B Ø	240.0	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Unknown Operations	0	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Tank Paint Condition	Good	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Switching Operations	2	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Operations This Read Vac	2	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Operations Counter AL	201	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Operations Counter AF	199	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Grounds in Place?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	General Comments		
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	General Comments		
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Foundation Condition	Good	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Maintenance Operations	0	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Fault Operations A Ø	0	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	9 Month Operations	29	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Grounds in Place?	y	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	General Comments		
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	General Comments		
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Foundation Condition	Good	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Follow-up Action Required?	n	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Follow-up Action Required?	n	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Follow-up Action Required?	n	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Fault Operations Ground	0	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Fault Operations C Ø	0	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Fault Operations B Ø	0	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Fault Operations A Ø	0	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Amps A Ø	55.0	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Amps B Ø	55.0	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Amps C Ø	35.0	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Patrol Inspection	Bushing Condition	Good	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Amps C Ø	450.0	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Amps B Ø	500.0	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Amps A Ø	450.0	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK000576	BreakerVacuum	433-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	Bushing Condition	Good	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	General Comments		
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	WB0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	General Comments		
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	General Comments		
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	LTCC000199	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	LTCC000199	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	LTCC000199	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	LTCC000199	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	LTCC000199	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	LTCC000199	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	LTCC000199	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	LTC Totalizer Reading	10281.60	kw
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	Oil Temp Max	40	°C
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	Oil Temp Present	40	°C
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	Totalizer Meter Reading	.7140	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Unknown Operations	0	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Ambient Temp	77	°F
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Vegetation	None	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	General Comments		
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	YD000402	Yard	433-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	Totalizer Meter Reading	.9924	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	Winding Temp Max	40	°C
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	Winding Temp Present	40	°C
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	S0005	WithLTC	766-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	YD000291	Yard	766-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	LTCC000199	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Patrol Inspection	Bushing Condition	Good	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Amps C Ø	75.0	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Amps B Ø	70.0	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Fault Operations B Ø	0	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Fault Operations C Ø	0	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Fault Operations Ground	0	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	Follow-up Action Required?	n	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Amps A Ø	260.0	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	BK001462	BreakerVacuum	633-1	VCB Readings	9 Month Operations	0	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Follow-up Action Required?	n	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	Foundation Condition	Good	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	General Comments		
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	General Comments		
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	Grounds in Place?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Maintenance Operations	0	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Operations Counter AF	165	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Operations Counter AL	165	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Operations This Read Vac	0	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Readings	Switching Operations	0	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001439	BreakerVacuum	433-0626	VCB Patrol Inspection	Tank Paint Condition	Good	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Amps A Ø	65.0	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	BK000502	BreakerVacuum	839-0637	VCB Readings	9 Month Operations	7	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	R1029	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	B0386	WithLTC	633-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	General Comments		
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Fault Operations Ground	0	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Fault Operations C Ø	0	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Fault Operations B Ø	0	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Fault Operations A Ø	0	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	Battery Bank Volts	54.0	VDC
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	BAT001362	Battery	839-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	9 Month Operations	6	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Amps A Ø	110.0	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Unknown Operations	0	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Amps B Ø	90.0	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Amps C Ø	115.0	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Bushing Condition	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Tank Paint Condition	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Switching Operations	3	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	General Comments		
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	General Comments		
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	LTCC000842	LTCControl	433-2	LTC Control Insp	VRR Time Delay	30	Seconds
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	LTCC000842	LTCControl	433-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	LTCC000842	LTCControl	433-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	LTCC000842	LTCControl	433-2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	LTCC000842	LTCControl	433-2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	LTCC000842	LTCControl	433-2	LTC Control Insp	LTC Operation Checked?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	LTCC000842	LTCControl	433-2	LTC Control Insp	General Comments		
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	LTCC000842	LTCControl	433-2	LTC Control Insp	Follow-up Action Required?	n	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	LTCC000842	LTCControl	433-2	LTC Control Insp	All Connections OK?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Grounds in Place?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Maintenance Operations	0	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Operations Counter AF	160	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Operations Counter AL	160	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Operations This Read Vac	1	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Switching Operations	1	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Tank Paint Condition	Good	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Vegetation	None	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	General Comments		
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	YD000367	Yard	633-Yard	Yard Patrol Inspection	Ambient Temp	64	*F
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Unknown Operations	0	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	General Comments		
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Follow-up Action Required?	n	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Follow-up Action Required?	n	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Fault Operations Ground	0	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Fault Operations C Ø	0	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Fault Operations B Ø	0	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Fault Operations A Ø	0	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Bushing Condition	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Amps C Ø	175.0	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Amps B Ø	185.0	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Amps A Ø	140.0	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	9 Month Operations	7	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Operations Counter AF	192	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Operations Counter AL	194	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Operations This Read Vac	3	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Switching Operations	3	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Tank Paint Condition	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Unknown Operations	0	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BCH001248	Charger	433-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
9/25/2020 11:17	Distribution	Winchester South Quarterly Inspection	FE000354	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Bushing Condition	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Amps C Ø	320.0	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Amps B Ø	320.0	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Amps A Ø	320.0	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Operations This Read Vac	3	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	9 Month Operations	1	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Fault Operations A Ø	0	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Fault Operations B Ø	0	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Fault Operations C Ø	0	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Fault Operations Ground	0	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Follow-up Action Required?	n	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Follow-up Action Required?	n	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Foundation Condition	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	General Comments		
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	General Comments		
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Operations Counter AL	201	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Operations Counter AF	199	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	Maintenance Operations	0	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Grounds in Place?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Patrol Inspection	Grounds in Place?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Readings	General Comments		
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	General Comments		
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK000254	BreakerVacuum	766-0849	VCB Patrol Inspection	Foundation Condition	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001286	BreakerVacuum	766-0847	VCB Readings	Maintenance Operations	0	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	R0938	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	77	*F
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	General Comments		
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BAT001309	Battery	433-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Amps A Ø	7.0	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Amps B Ø	7.0	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	9 Month Operations	5	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Bushing Condition	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Amps C Ø	7.0	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	Follow-up Action Required?	n	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	General Comments		
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Mechanism Patrol Inspection	General Comments		
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	LTC As Found Counter	58592	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BCH001316	Charger	766-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	General Comments		
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	ST000377	Structure	433-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	LTC As Left Counter	58592	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	LTC Current Tap Position	9L	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	LTC Max Tap Position	1L	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	LTC Min Tap Position	12L	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	LTC Operations Since Last Insp	1115	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	S0005	LTCMechanism	766-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Operations Counter AF	66	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Operations Counter AL	66	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Operations This Read Vac	0	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Switching Operations	0	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Tank Paint Condition	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Unknown Operations	0	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BCH001316	Charger	766-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BCH001316	Charger	766-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	General Comments		
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Foundation Condition	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Unknown Operations	0	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Tank Paint Condition	Good	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Follow-up Action Required?	n	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Follow-up Action Required?	n	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Fault Operations Ground	0	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Fault Operations C Ø	0	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Fault Operations B Ø	0	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Fault Operations A Ø	0	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	FE000837	Fence	433-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Switching Operations	3	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Operations This Read Vac	3	
9/25/2020 10:31	Distribution	Boone Avenue Quarterly Inspection	ST000369	Structure	633-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Operations Counter AL	176	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BCH001316	Charger	766-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BCH001316	Charger	766-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BCH001316	Charger	766-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BCH001316	Charger	766-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Follow-up Action Required?	n	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Foundation Condition	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	General Comments		
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	General Comments		
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Grounds in Place?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Readings	Maintenance Operations	0	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	K0009	BreakerVacuum	766-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Amps C Ø	180.0	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BCH001316	Charger	766-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Operations Counter AF	174	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Maintenance Operations	0	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Grounds in Place?	y	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	General Comments		
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	General Comments		
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Foundation Condition	Good	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Follow-up Action Required?	n	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Patrol Inspection	Follow-up Action Required?	n	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Fault Operations Ground	0	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Fault Operations C Ø	0	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Fault Operations B Ø	0	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Amps B Ø	185.0	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Amps A Ø	165.0	
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/25/2020 14:11	Distribution	Rockwell Quarterly Inspection	BK001285	BreakerVacuum	433-0627	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	9 Month Operations	6	
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/25/2020 13:12	Distribution	Sylvania Quarterly Inspection	BK001275	BreakerVacuum	766-0848	VCB Readings	Fault Operations A Ø	0	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Battery Bank Amps	.5	AMPS
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Battery Bank Volts	53.5	VDC
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BAT001326	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Readings	General Comments		
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Operations This Read Vac	3	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Switching Operations	3	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Tank Paint Condition	Good	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Unknown Operations	0	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Grounds in Place?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	General Comments	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	LTC As Found Counter	77050	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Mechanism Patrol Inspection	General Comments		
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	General Comments		
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	Follow-up Action Required?	n	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	LTC Operations Since Last Insp	1823	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	40	°C
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	40	°C
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	LTC Min Tap Position	11L	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	LTC Max Tap Position	6R	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	LTC Current Tap Position	3L	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	LTC As Left Counter	67131	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	LTC As Found Counter	67128	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	General Comments		
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	General Comments		
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Amps A Ø	0.0	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	LTCMechanism	593-2	LTC Counter Readings	Follow-up Action Required?	n	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Grounds in Place?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	General Comments		
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	General Comments		
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Readings	Maintenance Operations	0	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Moisture and Leak Free?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Readings	Num Operations Last 9 Months	20	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Readings	Operations Counter AF	95	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Readings	Operations Counter AL	95	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Readings	Operations This Read SF6	0	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	SF6 Bushing Condition	Good	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	SF6 Pressure Indicator	good	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Readings	Switching Operations	0	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Tank Paint Condition	Good	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Foundation Condition	Good	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Follow-up Action Required?	n	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Fault Operations Ground	0	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Fault Operations C Ø	0	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Fault Operations B Ø	0	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Fault Operations A Ø	0	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	9 Month Operations	11	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Amps A Ø	340.0	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Amps B Ø	340.0	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Amps C Ø	340.0	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Bushing Condition	Good	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	9 Month Operations	45	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Maintenance Operations	0	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Operations Counter AF	216	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Operations Counter AL	216	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Ambient Temperature	77	*F
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Bushings Connection/Risers	Good	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Cabinet Paint Condition	Good	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Equipment Properly Labeled?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Readings	Fault Operations	0	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Readings	Follow-up Action Required?	n	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Foundation Condition	Good	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001038	BreakerSF6	828-608	GCB Patrol Inspection	Gauge(s) Condition	Good	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Amps B Ø	209.0	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Amps A Ø	222.0	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	BCH000559	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	9 Month Operations	29	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Operations Counter AF	384	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Operations Counter AL	388	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	77	*F
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Ambient Temp	75	*F
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	General Comments		
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Vegetation	None	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	YD000372	Yard	728-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	General Comments		
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Fault Operations A Ø	0	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Fault Operations B Ø	0	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Fault Operations C Ø	0	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Fault Operations Ground	0	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Follow-up Action Required?	n	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	General Comments		
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	General Comments		
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Grounds in Place?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Maintenance Operations	0	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Fault Operations C Ø	0	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Fault Operations B Ø	0	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Fault Operations A Ø	0	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Bushing Condition	Good	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Amps C Ø	210.0	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	General Comments		
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Foundation Condition	Good	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Bushing Condition	Good	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Amps C Ø	640.0	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Amps B Ø	620.0	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Amps A Ø	620.0	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Follow-up Action Required?	n	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Fault Operations Ground	0	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Fault Operations C Ø	0	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Fault Operations B Ø	0	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Fault Operations A Ø	0	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BCH001018	Charger	WP-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BCH001018	Charger	WP-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BCH001018	Charger	WP-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BCH001018	Charger	WP-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BCH001018	Charger	WP-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BCH001018	Charger	WP-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BCH001018	Charger	WP-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	LTC Operations Since Last Insp	1872	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	LTC Min Tap Position	8L	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	LTC Max Tap Position	10R	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	LTC Current Tap Position	1R	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	B0424	LTCMechanism	728-1	LTC Counter Readings	LTC As Left Counter	77050	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	9 Month Operations	0	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000645	LTCControl	593-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000645	LTCControl	593-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000645	LTCControl	593-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000645	LTCControl	593-1	LTC Control Insp	LTC Output Voltage Level	123.1	VAC
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000645	LTCControl	593-1	LTC Control Insp	LTC Operation Checked?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000645	LTCControl	593-1	LTC Control Insp	General Comments		
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000645	LTCControl	593-1	LTC Control Insp	Follow-up Action Required?	n	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000645	LTCControl	593-1	LTC Control Insp	All Connections OK?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Bushing Condition	Good	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Amps C Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Amps B Ø	0.0	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	77	*F
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	BAT000621	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	General Comments		
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	General Comments		
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Operations This Read Vac	4	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	BCH000559	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	ST000374	Structure	728-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	General Comments		
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	BCH000559	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	BCH000559	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	BCH000559	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	BCH000559	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Unknown Operations	0	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Tank Paint Condition	Good	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Switching Operations	2	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Operations This Read Vac	2	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Operations Counter AL	185	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Switching Operations	4	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Tank Paint Condition	Good	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Unknown Operations	0	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Operations Counter AF	185	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	Maintenance Operations	0	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Patrol Inspection	Grounds in Place?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001173	BreakerVacuum	828-2201	VCB Readings	General Comments		
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Operations Counter AL	171	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Operations This Read Vac	0	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Switching Operations	0	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Tank Paint Condition	Good	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Unknown Operations	0	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000030	LTCControl	593-2	LTC Control Insp	General Comments		
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000030	LTCControl	593-2	LTC Control Insp	LTC Operation Checked?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000030	LTCControl	593-2	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000030	LTCControl	593-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000030	LTCControl	593-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000030	LTCControl	593-2	LTC Control Insp	VRR Time Delay	30	Seconds
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	General Comments		
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Readings	General Comments		
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Readings	LTC Totalizer Reading	4363.20	kw
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Readings	Oil Temp Max	46	°C
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Readings	Oil Temp Present	32	°C
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Readings	Totalizer Meter Reading	.3030	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Readings	Winding Temp Max	46	°C
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Readings	Winding Temp Present	36	°C
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	TX000223	WithLTC	828-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	PF001255	PowerFuse	WP-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	PF001255	PowerFuse	WP-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Operations Counter AF	368	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Operations Counter AL	372	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Operations This Read Vac	4	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Switching Operations	4	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Tank Paint Condition	Good	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Unknown Operations	0	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCControl	728-1	LTC Control Insp	General Comments		
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCControl	728-1	LTC Control Insp	Follow-up Action Required?	n	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCControl	728-1	LTC Control Insp	All Connections OK?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000030	LTCControl	593-2	LTC Control Insp	All Connections OK?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	Oil Temp Present	60	°C
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	Oil Temp Max	75	°C
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	LTC Totalizer Reading	14227.20	kw
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	General Comments		
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	General Comments		
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	LTCC000030	LTCControl	593-2	LTC Control Insp	Follow-up Action Required?	n	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BAT001308	Battery	728-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Amps A Ø	379.0	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Amps B Ø	364.0	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Amps C Ø	370.0	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Bushing Condition	Good	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	LTO135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	LTC As Left Counter	214133	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Fault Operations A Ø	0	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Fault Operations B Ø	0	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Fault Operations C Ø	0	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Fault Operations Ground	0	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Follow-up Action Required?	n	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Foundation Condition	Good	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	General Comments		
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	General Comments		
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Grounds in Place?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Maintenance Operations	0	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Operations Counter AF	211	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	LTO135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	LTO135	LTCMechanism	MU-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Operations Counter AL	211	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Operations This Read Vac	0	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Switching Operations	0	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Patrol Inspection	Tank Paint Condition	Good	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	LTO135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	LTC As Found Counter	214133	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	LTO135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	General Comments		
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	LTO135	LTCMechanism	MU-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Counter Readings	LTC Operations Since Last Insp	950	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	38	°C
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	34	°C
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Counter Readings	LTC Min Tap Position	4L	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Counter Readings	LTC Max Tap Position	4R	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Counter Readings	LTC Current Tap Position	4L	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Counter Readings	LTC As Left Counter	3438	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Counter Readings	LTC As Found Counter	3434	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	General Comments		
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Counter Readings	General Comments		
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	LTCM000092	LTCMechanism	828-1	LTC Counter Readings	Follow-up Action Required?	n	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	LTO135	WithLTC	MU-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	LTO135	WithLTC	MU-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	LTO135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	LTO135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	LTO135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	LTO135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	LTO135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	LTO135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	LTO135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	LTO135	WithLTC	MU-TRANS 1	LTC Transformer Readings	Oil Temp Present	35	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Readings	Oil Temp Max	45	°C
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Readings	General Comments		
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	LT0135	WithLTC	MU-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	LTCC000808	LTCControl	828-1	LTC Control Insp	All Connections OK?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	LTCC000808	LTCControl	828-1	LTC Control Insp	Follow-up Action Required?	n	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	LTCC000808	LTCControl	828-1	LTC Control Insp	General Comments		
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	LTCC000808	LTCControl	828-1	LTC Control Insp	LTC Operation Checked?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	LTCC000808	LTCControl	828-1	LTC Control Insp	LTC Output Voltage Level	123.2	VAC
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	LTCC000808	LTCControl	828-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	LTCC000808	LTCControl	828-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	LTCC000808	LTCControl	828-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	LTCC000808	LTCControl	828-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Unknown Operations	0	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	166	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	LTC Min Tap Position	8L	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	LTC Max Tap Position	3R	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Counter Readings	LTC Current Tap Position	7L	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	LT0135	LTCMechanism	MU-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	9 Month Operations	3	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KB0011	BreakerVacuum	593-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	General Comments		
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	General Comments		
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Amps A Ø	240.0	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Amps B Ø	240.0	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Amps C Ø	240.0	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Bushing Condition	Good	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Fault Operations A Ø	0	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Fault Operations B Ø	0	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Fault Operations C Ø	0	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Fault Operations Ground	0	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Follow-up Action Required?	n	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Foundation Condition	Good	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	General Comments		
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Grounds in Place?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Maintenance Operations	0	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Operations Counter AF	278	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Operations Counter AL	282	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Operations This Read Vac	4	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Switching Operations	4	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Patrol Inspection	Tank Paint Condition	Good	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Unknown Operations	0	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Patrol Inspection	Bushing Condition	Good	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Amps C \emptyset	203.0	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Amps B \emptyset	211.0	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Amps A \emptyset	215.0	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001172	BreakerVacuum	828-2202	VCB Readings	9 Month Operations	41	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Fault Operations A \emptyset	0	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Fault Operations B \emptyset	0	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Fault Operations C \emptyset	0	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Fault Operations Ground	0	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Follow-up Action Required?	n	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Foundation Condition	Good	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	General Comments		
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	General Comments		
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Grounds in Place?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	Totalizer Meter Reading	.2832	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	9 Month Operations	8	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0417	BreakerVacuum	728-0644	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	Oil Temp Present	35	°C
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	Oil Temp Max	55	°C
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	72.50	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	906.24	kw
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	B0231	NonLTC	199-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Operations Counter AF	171	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Amps A Ø	0.0	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Amps B Ø	0.0	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Amps C Ø	0.0	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Bushing Condition	Good	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	250.00	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	General Comments		
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	FE000585	Fence	MU-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	Winding Temp Present	60	°C
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	Winding Temp Max	75	°C
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	Totalizer Meter Reading	.9880	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	B0424	WithLTC	728-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Fault Operations A Ø	0	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Fault Operations B Ø	0	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Fault Operations C Ø	0	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Fault Operations Ground	0	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Follow-up Action Required?	n	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Foundation Condition	Good	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	General Comments		
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	General Comments		
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Grounds in Place?	y	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Maintenance Operations	0	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Readings	Maintenance Operations	0	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	CB0249	BreakerVacuum	593-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	General Comments		
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	FE000605	Fence	WP-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	Follow-up Action Required?	n	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	General Comments		
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Mechanism Patrol Inspection	General Comments		
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	LTC As Found Counter	122356	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	LTC As Left Counter	122360	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	LTC Current Tap Position	2L	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	LTC Max Tap Position	10R	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	LTC Min Tap Position	10L	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	LTC Operations Since Last Insp	2314	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	C0517	LTCMechanism	619-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCControl	728-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCControl	728-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCControl	728-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCControl	728-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	LTCC000374	LTCControl	728-1	LTC Control Insp	LTC Operation Checked?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	General Comments		
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	FE000366	Fence	728-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	PF001197	PowerFuse	WP-33KV TR 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	PF001197	PowerFuse	WP-33KV TR 1	Disconnect Powerfuse Inspection	General Comments	ok	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	9 Month Operations	8	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0086	BreakerVacuum	199-0633	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BCH001247	Charger	728-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	General Comments		
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Current Tap Position	4L	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Ambient Temp	64	*F
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	General Comments		
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	General Comments		
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Max Tap Position	3R	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Min Tap Position	8L	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Regulator As Left Counter	14683	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Tank Leaks	None	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	Follow-up Action Required?	n	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	Oil Temp Present	32	°C
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	LTC Totalizer Reading	11313.00	kw
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	General Comments		
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	General Comments		
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	LTCC000286	LTCControl	920-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	LTCC000286	LTCControl	920-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	LTCC000286	LTCControl	920-Offline-Distribution	LTC Control Insp	General Comments		
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	LTCC000286	LTCControl	920-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	LTCC000286	LTCControl	920-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	LTCC000286	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Ambient Temp	77	°F
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	General Comments		
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Vegetation	None	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Ambient Temp	77	°F
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	LTCC000286	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	LTCC000286	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Vegetation	None	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	YD000608	Yard	WP-Yard	Yard Patrol Inspection	General Comments		
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Switching Operations	0	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Operations This Read Vac	0	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Operations Counter AL	158	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Operations Counter AF	158	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Maintenance Operations	0	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Vegetation	None	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	77	*F
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Bushing Condition	Good	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Amps C Ø	360.0	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Amps B Ø	365.0	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Grounds in Place?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	General Comments		
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	General Comments		
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Foundation Condition	Good	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Follow-up Action Required?	n	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Fault Operations Ground	0	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Fault Operations C Ø	0	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	General Comments		
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	Oil Temp Max	43	°C
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Min	0.00	MegaWatts
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Max	0.00	MegaWatts
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Min	0.00	MegaVars
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BCH001380	Charger	828-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BCH001380	Charger	828-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BCH001380	Charger	828-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BCH001380	Charger	828-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.0	amps
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BCH001380	Charger	828-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BCH001380	Charger	828-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Vegetation	None	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	General Comments		
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Unknown Operations	0	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	YD000493	Yard	828-Yard	Yard Patrol Inspection	Ambient Temp	77	°F
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Max	0.00	MegaVars
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	General Comments	Satec not working	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Follow-up Action Required?	n	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Foundation Condition	Good	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	General Comments		
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Grounds in Place?	y	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Amps A Ø	5.0	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Maintenance Operations	0	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Operations Counter AF	188	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Operations Counter AL	190	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Operations This Read Vac	2	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Switching Operations	2	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Tank Paint Condition	Good	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Unknown Operations	0	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	Follow-up Action Required?	n	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	General Comments		
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	General Comments		
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Bushing Condition	Good	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Amps C Ø	27.0	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Clear of Trash?	y	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Ambient Temp	77	°F
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Amps B Ø	34.0	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Amps A Ø	30.0	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	9 Month Operations	32	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	General Comments		
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	General Comments		
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Grounds in Place?	y	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Foundation Condition	Good	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Follow-up Action Required?	n	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Maintenance Operations	0	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Operations Counter AF	224	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Operations Counter AL	224	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Operations This Read Vac	0	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Switching Operations	0	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Tank Paint Condition	Good	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Unknown Operations	0	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Fault Operations Ground	0	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Current Tap Position	2L	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Fault Operations C Ø	0	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Fault Operations B Ø	0	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Fault Operations C Ø	0	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Fault Operations B Ø	0	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Fault Operations A Ø	0	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Patrol Inspection	Bushing Condition	Good	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Amps C Ø	2.0	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Amps B Ø	10.0	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Fault Operations A Ø	0	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	BK001430	BreakerVacuum	WP-1104	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Fault Operations Ground	0	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Min Tap Position	7L	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Regulator As Left Counter	18369	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Tank Leaks	None	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	Winding Temp Present	45	°C
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	Winding Temp Max	45	°C
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	Totalizer Meter Reading	.6285	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Current Tap Position	4L	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	General Comments		
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Max Tap Position	2R	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Min Tap Position	4L	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Regulator As Left Counter	16101	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Tank Leaks	None	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000055	Regulator	199-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000056	Regulator	199-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	Oil Temp Present	40	°C
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	Oil Temp Max	65	°C
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	LTC Totalizer Reading	15273.00	kw
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	11	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	Oil Temp Max	80	°C
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	Oil Temp Present	40	°C
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Operations Counter AF	19	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	FE000544	Fence	619-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Maintenance Operations	0	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	BK001288	BreakerVacuum	199-0632	VCB Readings	9 Month Operations	4	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	General Comments		
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Grounds in Place?	y	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	General Comments		
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	General Comments		
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Foundation Condition	Good	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Follow-up Action Required?	n	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Fault Operations Ground	0	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Fault Operations C Ø	0	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Fault Operations B Ø	0	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Fault Operations A Ø	0	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	KT0015	WithLTC	593-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	RG000054	Regulator	199-5 A	Regulator Patrol Inspection	Max Tap Position	5R	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	Totalizer Meter Reading	.8485	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	Winding Temp Max	85	°C
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	C0517	WithLTC	619-2	LTC Transformer Readings	Winding Temp Present	45	°C
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Bushing Condition	Good	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Amps C Ø	120.0	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Amps B Ø	120.0	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Operations Counter AL	19	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Operations This Read Vac	0	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Switching Operations	0	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Patrol Inspection	Tank Paint Condition	Good	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Unknown Operations	0	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Amps A Ø	120.0	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	9 Month Operations	10	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	BCH000600	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	BCH000600	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	BCH000600	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Fault Operations A Ø	0	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	General Comments		
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	General Comments		
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Filters Condition OK?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	General Comments		
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	CH000502	ControlHouse	828-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	LTC As Left Counter	168349	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	LTC Current Tap Position	5L	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	LTC Max Tap Position	2L	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	LTC Min Tap Position	6L	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	152	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	General Comments		
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	General Comments		
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Foundation Condition	Good	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Follow-up Action Required?	n	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Fault Operations Ground	0	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Amps A Ø	300.0	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Amps B Ø	300.0	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Amps C Ø	300.0	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	FE000547	Fence	593-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	20.0	VDC
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	22.0	VDC
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	BAT000624	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Patrol Inspection	Bushing Condition	Good	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	ST000555	Structure	619-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Switch Stick Next Test Date	2021-03-15 00:00:00.000000	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Vegetation	None	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
10/16/2020 7:18	Distribution	Bardstown City Customer Quarterly Inspection	YD000551	Yard	619-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	General Comments		
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	PF000254	PowerFuse	MU-33KV TR 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	PF000254	PowerFuse	MU-33KV TR 1	Disconnect Powerfuse Inspection	General Comments	ok	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	FE000557	Fence	828-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	573	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	580	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	7	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	7	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	9 Month Operations	8	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0476	BreakerVacuum	728-0649	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Unknown Operations	0	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Tank Paint Condition	Good	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Switching Operations	0	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Operations This Read Vac	0	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Operations Counter AL	151	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Operations Counter AF	151	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	Maintenance Operations	0	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Patrol Inspection	Grounds in Place?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BK001174	BreakerVacuum	828-1	VCB Readings	General Comments		
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	General Comments		
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	PN71	LTCMechanism	WP-TRANS 1	LTC Counter Readings	LTC As Found Counter	168349	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Switch Stick Next Test Date	2021-03-08 00:00:00.000000	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Vegetation	None	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	General Comments		
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	ST000558	Structure	593-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Maintenance Operations	0	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Grounds in Place?	y	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	General Comments		
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Foundation Condition	Good	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Follow-up Action Required?	n	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Amps A Ø	350.0	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	Oil Temp Present	38	°C
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	Oil Temp Max	56	°C
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	BAT001422	Battery	828-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	General Comments		
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	Winding Temp Present	44	°C
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	Winding Temp Max	58	°C
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	Totalizer Meter Reading	.5023	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/24/2020 11:20	Distribution	Muldraugh Quarterly Inspection	YD000591	Yard	MU-Yard	Yard Patrol Inspection	Ambient Temp	64	°F
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	90.0	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Unknown Operations	0	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Tank Paint Condition	Good	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Switching Operations	4	
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Operations This Read Vac	4	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Operations Counter AL	276	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Operations Counter AF	272	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/24/2020 15:11	Distribution	Bardstown Industrial Customer Quarterly Inspection	YD000554	Yard	593-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	Follow-up Action Required?	n	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	General Comments		
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Mechanism Patrol Inspection	General Comments		
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	LTC As Found Counter	160232	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	LTC As Left Counter	160235	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	LTC Current Tap Position	3L	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	LTC Max Tap Position	4R	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	LTC Min Tap Position	10L	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	32	°C
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	38	°C
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	LTC Operations Since Last Insp	1242	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	General Comments		
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	General Comments		
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Fault Operations Ground	0	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Fault Operations C Ø	0	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Fault Operations B Ø	0	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Fault Operations A Ø	0	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	S0053	LTCMechanism	593-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	BCH000600	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/24/2020 12:44	Distribution	Winchester Quarterly Inspection	K0085	BreakerVacuum	199-0634	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0419	BreakerVacuum	728-1	VCB Readings	Fault Operations B Ø	0	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	BCH000600	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	BCH000600	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	BCH000600	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
9/24/2020 10:49	Distribution	West Point Quarterly Inspection	PN71	WithLTC	WP-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Readings	LTC Totalizer Reading	9041.40	kw
9/24/2020 13:58	Distribution	Bardstown City Quarterly Inspection	CB0248	BreakerVacuum	619-2200	VCB Readings	9 Month Operations	0	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	100.0	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	90.0	
9/24/2020 14:59	Distribution	Bardstown Industrial Quarterly Inspection	S0053	WithLTC	593-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	General Comments		
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/24/2020 14:34	Distribution	Barton Quarterly Inspection	ST000851	Structure	828-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/24/2020 7:39	Distribution	Winchester Industrial Quarterly Inspection	BB0418	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	General Comments		
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	LTC Totalizer Reading	10281.60	kw
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	Oil Temp Max	60	°C
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	Oil Temp Present	30	°C
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	Totalizer Meter Reading	1.0710	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	105.0	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	100.0	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	100.0	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	2	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	2	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	576	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	574	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BB0426	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	379	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	381	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	2	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	2	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	15	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	70.0	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	40.0	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	45.0	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	CB0255	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	LTCC000911	LTCControl	667-1	LTC Control Insp	All Connections OK?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	LTCC000911	LTCControl	667-1	LTC Control Insp	Follow-up Action Required?	n	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	LTCC000911	LTCControl	667-1	LTC Control Insp	General Comments		
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	LTCC000911	LTCControl	667-1	LTC Control Insp	LTC Operation Checked?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	LTCC000911	LTCControl	667-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	LTCC000911	LTCControl	667-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	LTCC000911	LTCControl	667-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	LTCC000911	LTCControl	667-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	LTC Operations Since Last Insp	1963	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	Follow-up Action Required?	n	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	General Comments		
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	LTC As Found Counter	93600	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	LTC As Left Counter	93600	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	LTC Current Tap Position	7L	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	LTC Max Tap Position	6R	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Counter Readings	LTC Min Tap Position	12L	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Mechanism Patrol Inspection	General Comments		
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	C0526	LTCMechanism	667-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	General Comments	NO BANK SWITCH	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	C0526	WithLTC	667-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Regulator As Left Counter	30242	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations This Read Vac	4	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR R Compensation AF	0	Position
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR R Compensation AL	0	Position
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR Counter AL	119541	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR Counter AF	119541	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR Base Voltage AL	124.0	VAC
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR Base Voltage AF	124.0	VAC
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR Time Delay	45	Seconds
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Amps A Ø	0.0	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR Bandwidth AL	3.0	VAC
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	VRR Bandwidth AF	3.0	VAC
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	Reset Tap Drag Hands	Reset	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	Min Tap Position	4R	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Amps B Ø	0.0	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Amps C Ø	0.0	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	All Connections OK?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Operations This Read Vac	1	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	General Comments		
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Grounds in Place?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Maintenance Operations	0	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Operations Counter AF	243	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Maintenance Operations	0	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Operations Counter AL	243	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	9 Month Operations	5	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	Follow-up Action Required?	n	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	Current Tap Position	7R	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	All Connections OK?	y	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	General Comments		
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/24/2020 7:31	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0235	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 7:31	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0235	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
9/24/2020 7:31	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0235	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	Max Tap Position	3R	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	Min Tap Position	1R	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	Reset Tap Drag Hands	Reset	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	VRR Bandwidth AF	3.0	VAC
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	VRR Bandwidth AL	3.0	VAC
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	VRR Base Voltage AF	124.0	VAC
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	VRR Base Voltage AL	124.0	VAC
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	VRR R Compensation AF	0	Position
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	VRR R Compensation AL	0	Position
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	VRR Time Delay	45	Seconds
9/24/2020 7:31	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0235	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/24/2020 7:31	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0235	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/24/2020 7:31	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0235	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/24/2020 7:31	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0194	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Low	
9/24/2020 7:31	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0194	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/24/2020 7:31	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0194	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/24/2020 7:31	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0194	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Ambient Temp	77	*F
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	General Comments		
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	General Comments		
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Foundation Condition	Good	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Tank Leaks	None	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	3	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Grounds in Place?	y	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Vegetation	None	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	Max Tap Position	9R	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	KRC000626	RegulatorControl	791-2402 B	Regulator Annual Control Inspection	General Comments		
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	YD000848	Yard	791-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Fault Operations A Ø	0	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Fault Operations B Ø	0	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Fault Operations C Ø	0	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Fault Operations Ground	0	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Follow-up Action Required?	n	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	General Comments		
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	General Comments		
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Maintenance Operations	0	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Operations Counter AF	452	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Operations Counter AL	452	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Operations This Read Vac	3	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Switching Operations	3	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0088	BreakerVacuum	423-BT1-2	VCB Readings	Unknown Operations	0	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	Current Tap Position	3R	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	Follow-up Action Required?	n	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	KRC000499	RegulatorControl	791-2402 A	Regulator Annual Control Inspection	General Comments		
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	1	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	4.31	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Operations Counter AF	217	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Operations Counter AL	217	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Follow-up Action Required?	n	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Fault Operations Ground	0	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Fault Operations C Ø	0	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Fault Operations A Ø	0	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	80.0	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	40.0	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	45.0	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/24/2020 7:31	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0217	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/24/2020 7:31	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0217	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/24/2020 7:31	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0217	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/24/2020 7:31	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0217	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
9/24/2020 7:31	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0217	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments	No longer here	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Operations This Read Vac	1	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Switching Operations	1	
9/24/2020 7:31	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0217	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	6	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	9 Month Operations	5	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Amps A Ø	332.0	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Amps B Ø	340.0	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Amps C Ø	325.0	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Bushing Condition	Good	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Unknown Operations	0	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Tank Paint Condition	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	LTCC000912	LTCControl	656-1	LTC Control Insp	All Connections OK?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	LTCC000912	LTCControl	656-1	LTC Control Insp	Follow-up Action Required?	n	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	Totalizer Meter Reading	.6620	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	Oil Temp Present	30	°C
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	Oil Temp Max	30	°C
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	LTC Totalizer Reading	6355.20	kw
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	General Comments	NO BANK SWITCH	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	General Comments		
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	General Comments		
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Foundation Condition	Good	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Follow-up Action Required?	n	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Min Tap Position	1R	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Max Tap Position	4R	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	General Comments		
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	478	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	S0047	WithLTC	656-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BCH001314	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BCH001314	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BCH001314	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BCH001314	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.9	amps
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BCH001314	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BCH001314	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BCH001314	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	General Comments		
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BCH001314	Charger	930-Offline-Distribution	Battery Charger Patrol Insp	Ground Lights	None	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	474	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Current Tap Position	3R	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0586	Regulator	791-2402 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	K0169	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	Winding Temp Max	22	°C
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	Winding Temp Present	20	°C
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
9/24/2020 7:31	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0195	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Low	
9/24/2020 7:31	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0195	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/24/2020 7:31	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0195	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/24/2020 7:31	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0195	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
9/24/2020 7:31	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0195	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/24/2020 7:31	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0195	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
9/24/2020 7:31	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0195	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 7:31	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0237	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/24/2020 7:31	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0237	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/24/2020 7:31	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0237	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/24/2020 7:31	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0237	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
9/24/2020 7:31	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0237	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments	No longer here	
9/24/2020 7:31	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0237	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Amps A Ø	68.0	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Amps B Ø	58.0	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Amps C Ø	555.0	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	LTC Operations Since Last Insp	1386	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	46	°C
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	18	°C
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	LTC Min Tap Position	9L	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Bushing Condition	Good	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Amps C Ø	37.0	
9/24/2020 7:31	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0236	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/24/2020 7:31	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0236	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/24/2020 7:31	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0236	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/24/2020 7:31	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0236	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/24/2020 7:31	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0236	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
9/24/2020 7:31	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0236	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Amps B Ø	46.0	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Amps A Ø	44.0	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	9 Month Operations	3	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	LTC Max Tap Position	1R	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	LTC Current Tap Position	2L	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	LTC As Left Counter	63954	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	LTC As Found Counter	63950	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	General Comments		
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	General Comments		
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	General Comments		
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	General Comments		
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	General Comments		
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	Follow-up Action Required?	n	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	General Comments		
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	General Comments		
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	Oil Temp Max	34	°C
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	Oil Temp Present	20	°C
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	FE000380	Fence	805-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	General Comments		
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0072	WithLTC	423-2	LTC Transformer Readings	Totalizer Meter Multiplier	0	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	LTC Max Tap Position	2L	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	LTC Current Tap Position	2L	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	LTC As Left Counter	4317	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	LTC As Found Counter	4317	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Mechanism Patrol Inspection	General Comments		
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	General Comments		
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	Follow-up Action Required?	n	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	LTCC000163	LTCControl	423-1	LTC Control Insp	General Comments		
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	LTCC000163	LTCControl	423-1	LTC Control Insp	Follow-up Action Required?	n	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	LTCC000163	LTCControl	423-1	LTC Control Insp	All Connections OK?	y	
9/24/2020 7:31	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0162	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 7:31	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0162	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
9/24/2020 7:31	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0162	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	ST000388	Structure	805-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	General Comments		
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	FE000470	Fence	513-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/24/2020 7:31	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0162	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
9/24/2020 7:31	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0162	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/24/2020 7:31	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0162	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	General Comments		
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/24/2020 7:31	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0162	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Low	
9/24/2020 7:31	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0194	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/24/2020 7:31	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0194	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
9/24/2020 7:31	Distribution	Big Stone Gap Storeroom Spare Transformer Quarterly Inspection	O0194	NonLTC	977-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	ST000836	Structure	791-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Fault Operations A Ø	0	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Fault Operations C Ø	0	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Fault Operations Ground	0	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Patrol Inspection	Follow-up Action Required?	n	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0196	BreakerVacuum	423-2402	VCB Readings	Follow-up Action Required?	n	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Operations Counter	2026	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	CX0123	RecloserElectronic	513-2231	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0071	LTCMechanism	423-1	LTC Counter Readings	Follow-up Action Required?	n	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	LTCC000163	LTCControl	423-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	LTCC000163	LTCControl	423-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Unknown Operations	0	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Patrol Inspection	Tank Paint Condition	Good	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0197	BreakerVacuum	423-2403	VCB Readings	Switching Operations	1	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	LTCC000163	LTCControl	423-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	LTCC000163	LTCControl	423-1	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	LTCC000163	LTCControl	423-1	LTC Control Insp	LTC Operation Checked?	y	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	FE000802	Fence	791-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Unknown Operations	0	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Tank Paint Condition	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Switching Operations	2	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Operations This Read Vac	2	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Operations Counter AL	196	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Operations Counter AF	194	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Maintenance Operations	0	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Grounds in Place?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	General Comments		
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	General Comments		
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Foundation Condition	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Follow-up Action Required?	n	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Follow-up Action Required?	n	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Fault Operations Ground	0	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Fault Operations C Ø	0	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Fault Operations B Ø	0	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	LTC Operations Since Last Insp	0	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0072	LTCMechanism	423-2	LTC Counter Readings	LTC Min Tap Position	2L	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Fault Operations A Ø	0	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Patrol Inspection	Bushing Condition	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Amps C Ø	90.0	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Amps B Ø	85.0	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Amps A Ø	100.0	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK000081	BreakerVacuum	848-0155	VCB Readings	9 Month Operations	4	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	Oil Temp Max	40	°C
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	General Comments		
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	Oil Temp Present	40	°C
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	Follow-up Action Required?	n	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Bushing Condition	Good	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Amps C Ø	368.0	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Amps B Ø	386.0	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Amps A Ø	395.0	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	9 Month Operations	0	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Ambient Temperature	77	°F
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Trash Emptied?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Ambient Temp	77	°F
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	BCH001421	Charger	423-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	BCH001421	Charger	423-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	BCH001421	Charger	423-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	BCH001421	Charger	423-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	BCH001421	Charger	423-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	BCH001421	Charger	423-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	BCH001421	Charger	423-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	BCH001421	Charger	423-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	General Comments		
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Operations This Read Vac	0	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Operations Counter AL	73	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Operations Counter AF	73	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Maintenance Operations	0	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Grounds in Place?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	General Comments		
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Foundation Condition	Good	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Follow-up Action Required?	n	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Fault Operations Ground	0	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Fault Operations C Ø	0	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Fault Operations B Ø	0	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Fault Operations A Ø	0	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	General Comments		
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	FE000494	Fence	423-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	General Comments		
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	General Comments		
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Ambient Temp	77	°F
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Bushings Connection/Risers	Good	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	LTC Totalizer Reading	3997.44	kw
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	LTCC000457	LTCControl	423-2	LTC Control Insp	VRR Time Delay	30	Seconds
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	LTCC000457	LTCControl	423-2	LTC Control Insp	VRR Base Voltage AL	0.0	VAC
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	LTCC000457	LTCControl	423-2	LTC Control Insp	VRR Base Voltage AF	0.0	VAC
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	LTCC000457	LTCControl	423-2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	LTCC000457	LTCControl	423-2	LTC Control Insp	LTC Output Voltage Level	0.0	VAC
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	LTCC000457	LTCControl	423-2	LTC Control Insp	LTC Operation Checked?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	LTCC000457	LTCControl	423-2	LTC Control Insp	General Comments		
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	LTCC000457	LTCControl	423-2	LTC Control Insp	Follow-up Action Required?	n	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	LTCC000457	LTCControl	423-2	LTC Control Insp	All Connections OK?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Vegetation	None	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	General Comments		
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	General Comments		
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Current Tap Position	7R	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	LTC Totalizer Reading	10060.80	kw
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	Oil Temp Max	60	°C
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	Oil Temp Present	38	°C
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	Totalizer Meter Reading	1.0480	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	Winding Temp Max	62	°C
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	Winding Temp Present	40	°C
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	ST000503	Structure	423-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	General Comments		
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	BAT001490	Battery	423-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Vegetation	None	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	YD000476	Yard	513-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	Totalizer Meter Reading	.4164	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	Winding Temp Max	0	°C
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	Winding Temp Present	0	°C
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	W0358	WithLTC	513-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	General Comments		
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Mechanism Patrol Inspection	General Comments		
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	LTC As Found Counter	23460	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Tank Leaks	None	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Moisture and Leak Free?	y	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Regulator As Left Counter	119541	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Reg Output Voltage Level	126.3	volts
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Reg Operation Checked?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Min Tap Position	4R	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Num Operations Last 9 Months	1	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Operations Counter AF	51	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Operations Counter AL	51	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Operations This Read SF6	0	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Max Tap Position	9R	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	YD000501	Yard	423-Yard	Yard Patrol Inspection	General Comments		
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	General Comments		
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0652	Regulator	791-2402 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	LTC As Left Counter	23464	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	LTC Current Tap Position	2L	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	LTC Max Tap Position	8R	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	LTC Min Tap Position	8L	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	LTC Operations Since Last Insp	1616	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	W0358	LTCMechanism	513-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	SF6 Bushing Condition	Good	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	SF6 Pressure	70	psi
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Tank Paint Condition	Good	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Switching Operations	0	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Max Tap Position	1R	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Min Tap Position	3R	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Fault Operations C Ø	0	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Fault Operations Ground	0	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Follow-up Action Required?	n	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Follow-up Action Required?	n	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Foundation Condition	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	General Comments		
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	General Comments		
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Grounds in Place?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Maintenance Operations	0	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Operations Counter AF	184	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Operations Counter AL	186	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Operations This Read Vac	2	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Switching Operations	2	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Tank Paint Condition	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Unknown Operations	0	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Amps A Ø	68.0	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Amps B Ø	58.0	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Amps C Ø	55.0	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	General Comments		
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Operations Counter	2	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	KX0058	RecloserElectronic	513-2232	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Regulator As Left Counter	0	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Tank Leaks	None	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	General Comments		
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Broom on Site?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	LTCC000912	LTCControl	656-1	LTC Control Insp	General Comments		
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	LTCC000912	LTCControl	656-1	LTC Control Insp	LTC Operation Checked?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	LTCC000912	LTCControl	656-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	LTCC000912	LTCControl	656-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	LTCC000912	LTCControl	656-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	LTCC000912	LTCControl	656-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Ambient Temp	65	°F
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Clear of Obstacles?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Clear of Trash?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Follow-up Action Required?	n	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	General Comments		
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Vegetation	None	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	YD000385	Yard	805-Yard Distribution	Yard Patrol Inspection	Yard Lights Working?	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Heaters (All) Functioning?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Grounds in Place?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	General Comments		
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	General Comments		
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Current Tap Position	3R	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Gauge(s) Condition	Good	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Foundation Condition	Good	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Follow-up Action Required?	n	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Follow-up Action Required?	n	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Fault Operations	0	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	9 Month Operations	5	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Amps A Ø	80.0	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Amps B Ø	85.0	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Amps C Ø	60.0	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Bushing Condition	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Equipment Properly Labeled?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Cabinet Paint Condition	Good	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Fault Operations A Ø	0	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BK001254	BreakerVacuum	526-0036	VCB Readings	Fault Operations B Ø	0	
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	General Comments		
9/23/2020 15:03	Distribution	Boston Quarterly Inspection	R0502	Regulator	791-2402 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	TB0900	BreakerSF6	423-808	GCB Readings	Maintenance Operations	0	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	General Comments		
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	65	*F
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	S0071	WithLTC	423-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	ST000478	Structure	513-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	BAT000418	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	Follow-up Action Required?	n	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	General Comments		
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	LTC As Found Counter	7836	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	LTC As Left Counter	7836	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	LTC Current Tap Position	9L	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	LTC Max Tap Position	3R	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	LTC Min Tap Position	14L	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Unknown Operations	0	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Patrol Inspection	Tank Paint Condition	Good	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	K0198	BreakerVacuum	423-1	VCB Readings	Switching Operations	0	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	LTCC000695	LTCControl	513-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	LTCC000695	LTCControl	513-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	LTC Operations Since Last Insp	1875	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/23/2020 15:17	Distribution	Lebanon Junction Quarterly Inspection	CH000106	ControlHouse	423-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/23/2020 12:25	Distribution	Camargo Quarterly Inspection	S0047	LTCMechanism	656-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	LTCC000695	LTCControl	513-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	LTCC000695	LTCControl	513-1	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	LTCC000695	LTCControl	513-1	LTC Control Insp	LTC Operation Checked?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	LTCC000695	LTCControl	513-1	LTC Control Insp	General Comments		
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	LTCC000695	LTCControl	513-1	LTC Control Insp	Follow-up Action Required?	n	
9/23/2020 16:01	Distribution	Woodlawn Quarterly Inspection	LTCC000695	LTCControl	513-1	LTC Control Insp	All Connections OK?	y	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	40.0	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	50.0	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	227	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	227	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0039	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	General Comments		
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Vegetation	None	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BCH001355	Charger	539-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BCH001355	Charger	539-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BCH001356	Charger	605-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BCH001356	Charger	605-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BCH001356	Charger	605-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BCH001356	Charger	605-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BCH001355	Charger	539-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BCH001355	Charger	539-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BCH001356	Charger	605-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BCH001356	Charger	605-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BCH001356	Charger	605-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BCH001356	Charger	605-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Operations Counter	0	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	General Comments		
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Switching Operations	0	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BCH001355	Charger	539-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BCH001355	Charger	539-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BCH001355	Charger	539-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Operations This Read Vac	0	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Operations Counter AL	280	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Operations Counter AF	280	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Maintenance Operations	0	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Foundation Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Switching Operations	1	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	General Comments		
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Operations This Read Vac	1	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Operations Counter AL	990	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Fault Operations A Ø	0	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Fault Operations B Ø	0	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Ambient Temp	77	*F
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Unknown Operations	0	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	62	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Amps A Ø	3.5	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Fault Operations C Ø	0	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Fault Operations Ground	0	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Amps B Ø	.6	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Amps C Ø	.2	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	6	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Follow-up Action Required?	n	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BCH001355	Charger	539-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.4	amps
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Operations Counter AF	990	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	FE000437	Fence	698-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	MX0092	RecloserHydraulic	346-0760	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	69	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	YD000441	Yard	698-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Switching Operations	1	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Unknown Operations	0	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	LTCC000250	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	LTCC000250	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124	VAC
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	LTCC000250	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124	VAC
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	LTCC000250	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	LTCC000250	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.8	VAC
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	LTC Operations Since Last Insp	1898	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	LTC Min Tap Position	11L	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	LTC Max Tap Position	11R	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	LTC Current Tap Position	2R	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	LTC As Left Counter	130767	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	LTC As Found Counter	130767	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Mechanism Patrol Inspection	General Comments		
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	General Comments		
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	C0518	LTCMechanism	663-2	LTC Counter Readings	Follow-up Action Required?	n	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	60.0	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	30.0	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	30.0	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Readings	General Comments		
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	6	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	247	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	LTCC000250	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	LTCC000250	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	LTCC000250	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	LTCC000250	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	249	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	2	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	2	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Foundation Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Follow-up Action Required?	n	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Fault Operations Ground	0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Fault Operations C Ø	0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Fault Operations B Ø	0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Fault Operations A Ø	0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Bushing Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Amps C Ø	70.0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Amps B Ø	75.0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Amps A Ø	82.0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	9 Month Operations	3	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	LTCC000612	LTCControl	456-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	LTCC000612	LTCControl	456-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	LTCC000612	LTCControl	456-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	LTCC000612	LTCControl	456-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	LTCC000612	LTCControl	456-1	LTC Control Insp	LTC Operation Checked?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	LTCC000612	LTCControl	456-1	LTC Control Insp	General Comments		
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	LTCC000612	LTCControl	456-1	LTC Control Insp	Follow-up Action Required?	n	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	LTCC000612	LTCControl	456-1	LTC Control Insp	All Connections OK?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	LTC Operations Since Last Insp	1846	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	25	°C
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	40	°C
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	LTC Min Tap Position	16L	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	LTC Current Tap Position	10L	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	LTC As Left Counter	30784	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	LTC As Found Counter	30784	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	General Comments		
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	General Comments		
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	LTCM000017	LTCMechanism	456-1	LTC Counter Readings	Follow-up Action Required?	n	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.0	amps
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BCH001253	Charger	767-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Operations Counter AF	160	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Operations Counter AL	160	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Operations This Read Vac	1	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Mechanism Patrol Inspection	General Comments		
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	General Comments		
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	Follow-up Action Required?	n	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	Winding Temp Present	35	°C
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	Winding Temp Max	50	°C
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	Totalizer Meter Reading	.5196	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	Oil Temp Present	35	°C
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	Oil Temp Max	40	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1300	psi
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	5.0	psi
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	LTC Totalizer Reading	9352.80	kw
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Operations This Read Vac	0	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Switching Operations	0	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Unknown Operations	0	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Readings	General Comments		
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	TX000022	WithLTC	456-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Fault Operations A Ø	0	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Fault Operations B Ø	0	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Fault Operations C Ø	0	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Fault Operations Ground	0	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Follow-up Action Required?	n	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Foundation Condition	Good	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	General Comments		
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	General Comments		
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Grounds in Place?	y	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Unknown Operations	0	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Switching Operations	1	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Operations This Read Vac	1	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Operations Counter AL	165	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Operations Counter AF	165	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Maintenance Operations	0	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Grounds in Place?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	General Comments		
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	General Comments		
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0035	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	9 Month Operations	0	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Amps A Ø	280.0	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Amps B Ø	280.0	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Amps C Ø	295.0	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Bushing Condition	Good	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Fault Operations A Ø	0	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Fault Operations B Ø	0	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Fault Operations C Ø	0	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Fault Operations Ground	0	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Follow-up Action Required?	n	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Foundation Condition	Good	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	General Comments		
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	General Comments		
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	General Comments		
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	FE000304	Fence	456-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Grounds in Place?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Maintenance Operations	0	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Operations Counter AF	168	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0108	BreakerVacuum	456-1	VCB Readings	Operations Counter AL	168	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Amps A Ø	50.0	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Amps B Ø	50.0	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Amps C Ø	50.0	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Bushing Condition	Good	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	LTC Current Tap Position	8L	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	LTC As Left Counter	10017	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	LTC As Found Counter	10014	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	BCH001319	Charger	361-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	1	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	Totalizer Meter Reading	.4620	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	BCH001319	Charger	361-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	BCH001319	Charger	361-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	BCH001319	Charger	361-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	BCH001319	Charger	361-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	Oil Temp Present	40	°C
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	Oil Temp Max	60	°C
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	LTC Totalizer Reading	4435.20	kw
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	General Comments		
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	General Comments		
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	WithLTC	527-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	General Comments		
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	0	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	160.0	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	160.0	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	160.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	Follow-up Action Required?	n	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	General Comments		
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	General Comments		
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	General Comments		
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	BCH000512	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	159	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	159	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	1	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	ST000405	Structure	539-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Bushing Condition	Good	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Amps C Ø	25.0	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Amps B Ø	19.0	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Amps A Ø	18.0	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	9 Month Operations	8	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	General Comments		
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	77	*F
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	BAT001233	Battery	594-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	BCH001319	Charger	361-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	BCH001319	Charger	361-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.3	VDC
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	BCH001319	Charger	361-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.3	VDC
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	9 Month Operations	20	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	140.00	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	Winding Temp Present	55	*C
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	Winding Temp Max	75	*C
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	Totalizer Meter Reading	1.8168	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Ambient Temp	45	*F
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Clear of Obstacles?	n	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Follow-up Action Required?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	General Comments	Driveway coming in is horribly overgrown Yard light needs repaired	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	Oil Temp Present	50	*C
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	Oil Temp Max	70	*C
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	LTC Totalizer Reading	17441.28	kw
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	General Comments		
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	Follow-up Action Required?	n	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Unknown Operations	0	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Switching Operations	1	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Operations This Read Vac	1	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Vegetation	None	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	YD000165	Yard	361-Yard	Yard Patrol Inspection	Yard Lights Working?	n	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Unknown Operations	0	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Operations Counter AL	144	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Operations Counter AF	144	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Maintenance Operations	0	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Grounds in Place?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	General Comments		
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	General Comments		
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Foundation Condition	Good	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Follow-up Action Required?	n	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Fault Operations Ground	0	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Fault Operations C Ø	0	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Fault Operations B Ø	0	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	22	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	22	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Fault Operations A Ø	0	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	LTC As Found Counter	194347	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	9 Month Operations	0	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	General Comments		
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	77	*F
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	BAT001190	Battery	608-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Amps A Ø	560.0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	LTC As Left Counter	194347	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	LTC Current Tap Position	3L	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	LTC Max Tap Position	8R	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	LTC Min Tap Position	10L	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	0	°C
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	0	°C
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Counter Readings	LTC Operations Since Last Insp	1827	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	77	*F
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BAT000571	Battery	698-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	General Comments		
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Bushing Condition	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Amps C Ø	235.0	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	LTCM000056	LTCMechanism	539-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	702	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	702	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0177	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Amps B Ø	230.0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Amps A Ø	225.0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	LTC Current Tap Position	6L	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Fault Operations C Ø	0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Fault Operations Ground	0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Foundation Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	General Comments		
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	General Comments		
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Grounds in Place?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Maintenance Operations	0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Operations Counter AF	99988	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Operations Counter AL	99988	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Operations This Read Vac	1	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Switching Operations	1	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Unknown Operations	0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	9 Month Operations	4	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Vegetation	None	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	General Comments		
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	YD000403	Yard	539-Yard	Yard Patrol Inspection	Ambient Temp	69	°F
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Unknown Operations	0	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Switching Operations	0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	LTC As Left Counter	117473	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	LTC As Found Counter	117470	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Mechanism Patrol Inspection	General Comments		
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	General Comments		
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Operations This Read Vac	0	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Operations Counter AL	214	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Operations Counter AF	214	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Maintenance Operations	0	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Grounds in Place?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	General Comments		
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	General Comments		
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Foundation Condition	Good	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Follow-up Action Required?	n	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Fault Operations Ground	0	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Fault Operations C ∅	0	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Fault Operations B ∅	0	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Fault Operations A ∅	0	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	Follow-up Action Required?	n	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	BCH001180	Charger	594-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	BCH001180	Charger	594-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	BCH001180	Charger	594-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	BCH001180	Charger	594-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	Follow-up Action Required?	n	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	General Comments		
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	General Comments		
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Patrol Inspection	Bushing Condition	Good	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Amps C ∅	53.0	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Amps B ∅	46.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Amps A Ø	54.0	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001114	BreakerVacuum	527-2422	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	LTC Totalizer Reading	14346.00	kw
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1400	psi
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BCH001363	Charger	698-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BCH001363	Charger	698-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BCH001363	Charger	698-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BCH001363	Charger	698-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.3	amps
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BCH001363	Charger	698-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BCH001363	Charger	698-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BCH001363	Charger	698-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BCH001363	Charger	698-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	Oil Temp Max	70	°C
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	Oil Temp Present	40	°C
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	Totalizer Meter Reading	.7970	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	Winding Temp Max	75	°C
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	Winding Temp Present	40	°C
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KT0026	WithLTC	539-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	9 Month Operations	2	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Amps A Ø	127.0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Amps B Ø	133.0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Amps C Ø	120.0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Bushing Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Fault Operations A Ø	0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0205	BreakerVacuum	767-2411	VCB Readings	Fault Operations B Ø	0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	LTC Operations Since Last Insp	1515	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	LTC Min Tap Position	11L	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	LTCMechanism	767-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	BCH000512	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	BCH000512	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Fault Operations Ground	0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Fault Operations C Ø	0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Fault Operations B Ø	0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Fault Operations A Ø	0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	BCH000512	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	LTCC000176	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	60	Seconds
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	LTCC000176	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	LTCC000176	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	LTCC000176	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	125.4	VAC
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	LTCC000176	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	LTCC000176	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	LTCC000176	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	LTCC000176	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	BCH000512	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Switching Operations	1	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Operations This Read Vac	1	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Operations Counter AL	188	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Operations Counter AF	188	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Maintenance Operations	0	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Grounds in Place?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	General Comments		
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	General Comments		
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Foundation Condition	Good	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Follow-up Action Required?	n	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Fault Operations Ground	0	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Fault Operations C Ø	0	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Fault Operations B Ø	0	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Fault Operations A Ø	0	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001113	BreakerVacuum	527-2423	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Maintenance Operations	0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Grounds in Place?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	General Comments		
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Foundation Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Follow-up Action Required?	n	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Fault Operations Ground	0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Fault Operations C Ø	0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Fault Operations B Ø	0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Fault Operations A Ø	0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Patrol Inspection	Bushing Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Amps C Ø	1.0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Amps B Ø	5.0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Amps A Ø	1.0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0207	BreakerVacuum	767-2412	VCB Readings	9 Month Operations	2	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	BCH001180	Charger	594-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	BCH001180	Charger	594-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	BCH001180	Charger	594-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Patrol Inspection	Bushing Condition	Good	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Amps C Ø	41.0	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Amps B Ø	52.0	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Amps A Ø	37.0	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0104	BreakerVacuum	452-2334	VCB Readings	9 Month Operations	4	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Unknown Operations	0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Switching Operations	0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Operations This Read Vac	0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Operations Counter AL	217	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Operations Counter AF	217	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Maintenance Operations	0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Grounds in Place?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	1	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	84.0	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	65.0	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	84.0	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	4.19	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	4.19	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	4.19	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	General Comments		
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	General Comments		
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Foundation Condition	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Readings	Follow-up Action Required?	n	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BB0458	BreakerVacuum	539-0647	VCB Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	BCH000512	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	BCH000512	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BCH001368	Charger	456-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BCH001368	Charger	456-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BCH001368	Charger	456-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BCH001368	Charger	456-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BCH001368	Charger	456-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BCH001368	Charger	456-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BCH001368	Charger	456-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BCH001368	Charger	456-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0049	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Unknown Operations	0	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	General Comments		
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	General Comments	Added nitrogen	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	LTC Totalizer Reading	5898.96	kw
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	Oil Temp Max	58	°C
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	Oil Temp Present	42	°C
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	Totalizer Meter Reading	.8193	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Regulator As Left Counter	11281	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Min Tap Position	12L	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Max Tap Position	1L	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	General Comments		
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Current Tap Position	8L	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000172	Regulator	346-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	9 Month Operations	2	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	9 Month Operations	8	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	LTCC000882	LTCControl	663-1	LTC Control Insp	General Comments		
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	LTCC000882	LTCControl	663-1	LTC Control Insp	LTC Operation Checked?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	LTCC000882	LTCControl	663-1	LTC Control Insp	LTC Output Voltage Level	0.0	VAC
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Regulator As Left Counter	8206	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Bushing Condition	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Amps C Ø	105.0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Amps B Ø	105.0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Amps A Ø	95.0	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Min Tap Position	4R	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Max Tap Position	4L	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	General Comments		
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	RG000145	Regulator	452-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	LTCC000882	LTCControl	663-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	LTCC000882	LTCControl	663-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	LTCC000882	LTCControl	663-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	9 Month Operations	17	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Amps A Ø	123.0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Amps B Ø	122.0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Amps C Ø	120.0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Bushing Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Fault Operations A Ø	0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Fault Operations B Ø	0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Fault Operations C Ø	0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Fault Operations Ground	0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Follow-up Action Required?	n	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Foundation Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	General Comments		
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	General Comments		
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Grounds in Place?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Maintenance Operations	2	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Operations Counter AF	195	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Operations Counter AL	195	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Operations This Read Vac	17	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK000421	BreakerVacuum	767-2409	VCB Readings	Switching Operations	15	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Operations Counter AF	177	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Maintenance Operations	0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Grounds in Place?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	General Comments		
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	General Comments		
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Foundation Condition	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Follow-up Action Required?	n	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Fault Operations Ground	0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Fault Operations C Ø	0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Fault Operations B Ø	0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Fault Operations A Ø	0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Low	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1600	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6576	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	General Comments		
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	General Comments		
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.2	psi
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	518.40	kw
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	72.50	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	Oil Temp Max	47	°C
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	Oil Temp Present	32	°C
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Bushing Condition	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Amps C Ø	40.0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Amps B Ø	40.0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Amps A Ø	40.0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	9 Month Operations	14	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	Follow-up Action Required?	n	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	General Comments		
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Amps A Ø	105.0	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Amps B Ø	122.0	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Amps C Ø	127.0	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Patrol Inspection	Bushing Condition	Good	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Regulator As Left Counter	3283	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Current Tap Position	8L	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	General Comments		
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	General Comments		
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	General Comments	There is a work order for adding oil to this transformer	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1052.16	kw
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	General Comments		
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Max Tap Position	3L	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Regulator As Left Counter	65271	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	Oil Temp Max	49	°C
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	O0176	NonLTC	323-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1211	Regulator	323-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Unknown Operations	0	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000171	Regulator	346-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Switching Operations	5	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Operations This Read Vac	5	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK000799	BreakerVacuum	539-0646	VCB Readings	Operations Counter AL	182	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	LTC Max Tap Position	9L	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	LTC Current Tap Position	7L	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	LTC As Left Counter	254395	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	LTC As Found Counter	254392	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Mechanism Patrol Inspection	General Comments		
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	General Comments		
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	Follow-up Action Required?	n	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Maintenance Operations	0	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Grounds in Place?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	General Comments		
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Operations Counter AF	214	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	General Comments		
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Foundation Condition	Good	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Follow-up Action Required?	n	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Fault Operations Ground	0	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Fault Operations C ∅	0	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Fault Operations B ∅	0	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Fault Operations A ∅	0	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Trash Emptied?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	General Comments		
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Fault Operations B Ø	0	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Fault Operations C Ø	0	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Fault Operations Ground	0	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Operations Counter AL	214	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Follow-up Action Required?	n	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Foundation Condition	Good	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Operations This Read Vac	2	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Switching Operations	2	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Unknown Operations	0	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	General Comments		
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	General Comments		
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Grounds in Place?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	General Comments		
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Maintenance Operations	0	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Operations Counter AF	232	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	LTC Operations Since Last Insp	830	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Patrol Inspection	Bushing Condition	Good	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Amps C Ø	41.0	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Amps B Ø	52.0	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Amps A Ø	37.0	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BCH001315	Charger	737-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BCH001315	Charger	737-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BCH001315	Charger	737-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BCH001315	Charger	737-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BCH001315	Charger	737-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BCH001315	Charger	737-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BCH001315	Charger	737-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Regulator As Left Counter	67699	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Min Tap Position	11L	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Max Tap Position	3L	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	LTC Operations Since Last Insp	991	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	LTC Min Tap Position	11L	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	LTC Max Tap Position	6R	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	LTC Current Tap Position	7L	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	LTC As Left Counter	16452	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	LTC As Found Counter	16448	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Mechanism Patrol Inspection	General Comments		
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	Follow-up Action Required?	n	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	LTCM000077	LTCMechanism	361-1	LTC Counter Readings	Follow-up Action Required?	n	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	General Comments		
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Current Tap Position	8L	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1214	Regulator	323-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Fault Operations A Ø	0	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	LTC Operations Since Last Insp	1043	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	C0393	LTCMechanism	608-1	LTC Counter Readings	LTC Min Tap Position	2L	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Maintenance Operations	0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Grounds in Place?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	General Comments		
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	General Comments		
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Foundation Condition	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Follow-up Action Required?	n	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	Totalizer Meter Multiplier	0	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	Winding Temp Max	0	°C
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	Winding Temp Present	0	°C
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Unknown Operations	0	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Operations Counter AF	239	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Operations Counter AL	239	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Operations This Read Vac	0	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Switching Operations	0	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Unknown Operations	0	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Bushing Condition	Good	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Amps C Ø	180.0	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Amps B Ø	140.0	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Amps A Ø	180.0	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Counter Readings	Follow-up Action Required?	n	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Counter Readings	General Comments		
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Mechanism Patrol Inspection	General Comments	DIGITAL NOT IN SERVICE	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Counter Readings	LTC As Left Counter	1855	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Counter Readings	LTC Min Tap Position	Neutral	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	0	°C
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	0	°C
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	LTCM000112	LTCMechanism	663-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	LTCC000882	LTCControl	663-1	LTC Control Insp	All Connections OK?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	LTCC000882	LTCControl	663-1	LTC Control Insp	Follow-up Action Required?	n	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Fault Operations Ground	0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Fault Operations C ∅	0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Fault Operations B ∅	0	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	General Comments		
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	O0196	WithLTC	361-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Fault Operations A ∅	0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	LTC Min Tap Position	9L	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	LTC Max Tap Position	12R	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	LTC Current Tap Position	3L	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	LTC As Left Counter	85492	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	LTC As Found Counter	85490	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Mechanism Patrol Inspection	General Comments		
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	General Comments		
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	General Comments		
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KB0105	BreakerVacuum	452-2335	VCB Readings	9 Month Operations	6	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	O0234	LTCMechanism	343-1	LTC Counter Readings	Follow-up Action Required?	n	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	9 Month Operations	6	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Amps A ∅	80.0	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Amps B ∅	50.0	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Amps C ∅	90.0	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Bushing Condition	Good	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Fault Operations A ∅	0	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Fault Operations B ∅	0	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Fault Operations C ∅	0	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Fault Operations Ground	0	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Follow-up Action Required?	n	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Operations Counter AL	232	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Operations This Read Vac	4	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Readings	Switching Operations	4	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1800	psi
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	Oil Temp Max	0	°C
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Readings	Oil Temp Present	0	°C
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	TX000265	WithLTC	663-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	CH000231	ControlHouse	361-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	K0107	BreakerVacuum	608-2459	VCB Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Foundation Condition	Good	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	General Comments		
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	General Comments		
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Grounds in Place?	y	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0285	BreakerVacuum	594-2470	VCB Readings	Maintenance Operations	0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Unknown Operations	0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Switching Operations	0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Operations This Read Vac	0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Operations Counter AL	163	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BK001410	BreakerVacuum	539-0969	VCB Readings	Operations Counter AF	163	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	9 Month Operations	1	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Amps A Ø	45.0	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Amps B Ø	47.0	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Amps C Ø	54.0	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	Bushing Condition	Good	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	General Comments		
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	General Comments		
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Vegetation	None	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Fault Operations A Ø	0	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Fault Operations B Ø	0	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	General Comments		
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	ST000101	Structure	343-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	General Comments		
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Maintenance Operations	0	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Grounds in Place?	y	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	General Comments		
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	General Comments		
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Foundation Condition	Good	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Follow-up Action Required?	n	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Fault Operations Ground	0	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Fault Operations C Ø	0	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Fault Operations B Ø	0	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Fault Adjusted Amps A Phase V	0	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Fault Adjusted Amps B Phase V	0	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Fault Adjusted Amps C Phase V	0	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Fault Operations A Ø	0	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Fault Operations B Ø	0	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Fault Operations C Ø	0	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Fault Operations Ground	0	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Follow-up Action Required?	n	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Foundation Condition	Good	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	General Comments		
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	General Comments		
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Grounds in Place?	y	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Maintenance Operations	0	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Ambient Temp	65	*F
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Operations Counter AF	241	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Operations Counter AL	243	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Operations This Read Vac	2	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	YD000094	Yard	343-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Fault Operations A Ø	0	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Switching Operations	2	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Unknown Operations	0	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Fault Adjusted Amps C Phase V	0	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Fault Adjusted Amps B Phase V	0	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Fault Adjusted Amps A Phase V	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Bushing Condition	Good	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Amps C Ø	170	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	9 Month Operations	7	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	CB0286	BreakerVacuum	594-2471	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Amps B Ø	150	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Amps A Ø	155	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Accumulated Fault Duty C Ph V	0	%
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Accumulated Fault Duty B Ph V	0	%
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Accumulated Fault Duty A Ph V	0	%
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	9 Month Operations	5	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	62	*F
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	BAT001391	Battery	361-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	LTCC000375	LTCControl	698-1	LTC Control Insp	All Connections OK?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	LTCC000375	LTCControl	698-1	LTC Control Insp	Follow-up Action Required?	n	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	LTCC000375	LTCControl	698-1	LTC Control Insp	General Comments		
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	LTCC000375	LTCControl	698-1	LTC Control Insp	LTC Operation Checked?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	LTCC000375	LTCControl	698-1	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	LTCC000375	LTCControl	698-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	LTCC000375	LTCControl	698-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	LTCC000375	LTCControl	698-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	LTCC000375	LTCControl	698-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	LTCC000616	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	LTCC000616	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Follow-up Action Required?	n	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	Foundation Condition	Good	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	General Comments		
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	General Comments		
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	LTCC000616	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	LTCC000616	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	LTCC000616	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	LTCC000616	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	LTCC000616	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	LTCC000616	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BCH001255	Charger	527-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	LTC Operations Since Last Insp	1402	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	LTC Min Tap Position	9L	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	LTCM000023	LTCMechanism	767-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	Grounds in Place?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Maintenance Operations	0	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Unknown Operations	0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Switching Operations	1	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Operations This Read Vac	1	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Operations Counter AL	314	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Operations Counter AF	314	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	Maintenance Operations	0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	Grounds in Place?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Readings	General Comments		
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	K0150	BreakerVacuum	767-2413	VCB Patrol Inspection	General Comments		
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	ST000444	Structure	698-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	FE000398	Fence	539-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	General Comments		
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	General Comments		
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	LTC Totalizer Reading	1475.20	kw
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	Oil Temp Max	50	°C
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	Oil Temp Present	35	°C
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	Totalizer Meter Reading	.4610	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	Winding Temp Max	60	°C
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	Winding Temp Present	37	°C
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	C0393	WithLTC	608-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	75	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	Totalizer Meter Reading	1.069	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	Oil Temp Present	40	°C
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	Oil Temp Max	55	°C
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	LTC Totalizer Reading	10262.4	kw
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	General Comments		
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	General Comments		
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Fault Operations C Ø	0	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Readings	Fault Operations Ground	0	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001421	BreakerVacuum	698-2449	VCB Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	S0022	WithLTC	737-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Fault Operations A Ø	0	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Fault Operations B Ø	0	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Unknown Operations	0	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Switching Operations	2	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	Follow-up Action Required?	n	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Operations This Read Vac	2	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Operations Counter AL	217	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Operations Counter AF	215	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	25.0	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	25.0	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	General Comments		
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	LTCC000620	LTCCControl	527-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	LTCC000620	LTCCControl	527-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	General Comments		
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	FE000094	Fence	343-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	General Comments		
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Mechanism Patrol Inspection	General Comments		
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	LTC As Found Counter	200002	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	LTC As Left Counter	200005	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	LTC Current Tap Position	6L	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	LTC Max Tap Position	6L	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	LTC Min Tap Position	11L	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	LTC Operations Since Last Insp	616	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	B0272	LTCMechanism	527-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	4	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations This Read Vac	15	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	65	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	49	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	11	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	25.0	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	O0173	NonLTC	346-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4320	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	ST000050	Structure	346-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Fault Operations A Ø	0	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Fault Operations B Ø	0	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Fault Operations C Ø	0	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Fault Operations Ground	0	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Follow-up Action Required?	n	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Patrol Inspection	Foundation Condition	Good	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Patrol Inspection	General Comments		
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	General Comments		
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Patrol Inspection	Grounds in Place?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Maintenance Operations	0	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Operations Counter AF	171	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Operations Counter AL	171	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Operations This Read Vac	2	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Readings	Switching Operations	2	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001419	BreakerVacuum	698-2447	VCB Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Patrol Inspection	Grounds in Place?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Maintenance Operations	0	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Operations Counter AF	157	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Operations Counter AL	157	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Operations This Read Vac	1	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Switching Operations	1	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	BK001420	BreakerVacuum	698-2448	VCB Readings	Unknown Operations	0	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Unknown Operations	0	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Switching Operations	2	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Operations This Read Vac	2	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Operations Counter AL	209	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001153	BreakerVacuum	737-0601	VCB Readings	Operations Counter AF	207	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	ST000530	Structure	527-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	Maintenance Operations	0	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Grounds in Place?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	LTCC000620	LTCControl	527-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	General Comments		
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	69	*F
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	BAT001207	Battery	539-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	27	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Readings	General Comments		
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	General Comments		
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001154	BreakerVacuum	737-0602	VCB Patrol Inspection	Foundation Condition	Good	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	LTCC000620	LTCControl	527-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	LTCC000620	LTCControl	527-1	LTC Control Insp	LTC Output Voltage Level	123.2	VAC
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	LTCC000620	LTCControl	527-1	LTC Control Insp	LTC Operation Checked?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	LTCC000620	LTCControl	527-1	LTC Control Insp	General Comments		
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	LTCC000620	LTCControl	527-1	LTC Control Insp	Follow-up Action Required?	n	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	General Comments		
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	General Comments		
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	LTC Totalizer Reading	15087.60	kw
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	Oil Temp Max	67	*C
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	Oil Temp Present	50	*C
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	LTCC000620	LTCControl	527-1	LTC Control Insp	All Connections OK?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	FE000066	Fence	361-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	General Comments		
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	793	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	0	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Amps C Ø	21.8	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Amps B Ø	23.3	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	Totalizer Meter Reading	.8382	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	Winding Temp Max	90	°C
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	Winding Temp Present	60	°C
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	C0505	WithLTC	767-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	Amps A Ø	19.9	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	MX0189	RecloserHydraulic	346-0762	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	0	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	9 Month Operations	5	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Accumulated Fault Duty A Ph V	0	%
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Accumulated Fault Duty B Ph V	0	%
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Accumulated Fault Duty C Ph V	0	%
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BK001170	BreakerVacuum	737-0600	VCB Readings	Amps A Ø	45	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Grounds in Place?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Maintenance Operations	5	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Operations Counter AF	258	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Operations Counter AL	266	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Operations This Read Vac	8	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Switching Operations	3	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Unknown Operations	0	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	General Comments		
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	LTCC000699	LTCControl	361-1	LTC Control Insp	All Connections OK?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	LTCC000699	LTCControl	361-1	LTC Control Insp	Follow-up Action Required?	n	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	LTCC000699	LTCControl	361-1	LTC Control Insp	General Comments		
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	LTCC000699	LTCControl	361-1	LTC Control Insp	LTC Operation Checked?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	LTCC000699	LTCControl	361-1	LTC Control Insp	LTC Output Voltage Level	123.4	VAC
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	LTCC000699	LTCControl	361-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	LTCC000699	LTCControl	361-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	LTCC000699	LTCControl	361-1	LTC Control Insp	VRR Time Delay	45	Seconds
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	General Comments		
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Vegetation	None	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	General Comments		
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	ST000833	Structure	452-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	77	*F
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	71	*F
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Ambient Temp	77	*F
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000639	LTCControl	767-1	LTC Control Insp	General Comments		
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000639	LTCControl	767-1	LTC Control Insp	Follow-up Action Required?	n	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000639	LTCControl	767-1	LTC Control Insp	All Connections OK?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	560.0	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	Totalizer Meter Reading	.8964	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	560.0	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	560.0	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	12	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	Oil Temp Present	40	*C
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	Oil Temp Max	60	*C
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	LTC Totalizer Reading	4302.72	kw
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	General Comments		
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	General Comments		
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	O0186	WithLTC	594-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	9 Month Operations	11	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Amps A Ø	30.0	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Amps B Ø	35.0	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Amps C Ø	40.0	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Fault Operations A Ø	0	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Fault Operations B Ø	0	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Fault Operations C Ø	0	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Fault Operations Ground	0	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	Follow-up Action Required?	n	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	Foundation Condition	Good	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Patrol Inspection	General Comments		
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	KB0092	BreakerVacuum	456-0609	VCB Readings	General Comments		
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Vegetation	None	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	General Comments		
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	1	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	10	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	1678	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	1678	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	General Comments	Line lightning arrestor blown on C phase 0756	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Ambient Temp	77	*F
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	General Comments		
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Vegetation	None	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	YD000526	Yard	527-Yard	Yard Patrol Inspection	Yard Lights Working?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	9	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	37.73	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	YD000525	Yard	767-Yard	Yard Patrol Inspection	Ambient Temp	77	°F
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	General Comments		
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	General Comments		
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Vegetation	None	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	YD000485	Yard	605-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	General Comments		
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	ST000529	Structure	767-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	General Comments		
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BAT001449	Battery	456-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BAT001111	Battery	527-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	9 Month Operations	3	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Amps A Ø	289.0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Amps B Ø	290.0	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	General Comments		
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	ST000489	Structure	608-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	120.0	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	180.0	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	160.0	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments	COUNTER BROKE	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	29	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	29	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations This Read Vac	4	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	4	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Bushing Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Amps C Ø	35.0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Amps B Ø	37.0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Amps A Ø	49.0	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	624	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	624	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	Totalizer Meter Reading	.4794	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	Oil Temp Present	36	°C
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	Oil Temp Max	62	°C
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.7	psi
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	LTC Totalizer Reading	4602.24	kw
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	General Comments		
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	General Comments		
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	General Comments		
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	General Comments		
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Foundation Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Follow-up Action Required?	n	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Fault Operations Ground	0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Fault Operations C ∅	0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Fault Operations B ∅	0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Fault Operations A ∅	0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000009	LTCControl	767-2	LTC Control Insp	VRR Time Delay	30	Seconds
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000009	LTCControl	767-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000009	LTCControl	767-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000009	LTCControl	767-2	LTC Control Insp	LTC Output Voltage Level	123.8	VAC
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000009	LTCControl	767-2	LTC Control Insp	LTC Operation Checked?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000009	LTCControl	767-2	LTC Control Insp	General Comments		
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000009	LTCControl	767-2	LTC Control Insp	Follow-up Action Required?	n	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000009	LTCControl	767-2	LTC Control Insp	All Connections OK?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Fault Operations Ground	0	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Vegetation	None	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	LTCC000135	LTCControl	663-2	LTC Control Insp	All Connections OK?	y	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	General Comments		
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	LTCC000135	LTCControl	663-2	LTC Control Insp	Follow-up Action Required?	n	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	LTCC000135	LTCControl	663-2	LTC Control Insp	General Comments		
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Fault Operations C ∅	0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Fault Operations B ∅	0	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	LTCC000135	LTCControl	663-2	LTC Control Insp	LTC Operation Checked?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	LTCC000135	LTCControl	663-2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	LTCC000135	LTCControl	663-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	LTCC000135	LTCControl	663-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Fault Operations A ∅	0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	LTCC000135	LTCControl	663-2	LTC Control Insp	VRR Time Delay	30	Seconds
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	YD000396	Yard	737-Yard	Yard Patrol Inspection	Ambient Temp	25	*F
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Bushing Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Amps C Ø	400.0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Amps B Ø	400.0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Amps A Ø	400.0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	9 Month Operations	1	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	8	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	LTC Max Tap Position	3R	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	LTC Min Tap Position	4L	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	LTC Operations Since Last Insp	728	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Switching Operations	5	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Operations This Read Vac	5	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Operations Counter AL	2034	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Operations Counter AF	2034	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Maintenance Operations	0	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Grounds in Place?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	General Comments		
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	General Comments		
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Foundation Condition	Good	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Follow-up Action Required?	n	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Fault Operations Ground	0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000639	LTCControl	767-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000639	LTCControl	767-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000639	LTCControl	767-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Fault Operations C Ø	0	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Fault Operations B Ø	0	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Fault Operations A Ø	0	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Patrol Inspection	Bushing Condition	Good	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Amps C Ø	120.0	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Amps B Ø	120.0	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Amps A Ø	120.0	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	General Comments		
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	6	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations This Read Vac	11	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	12	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	9 Month Operations	9	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	Follow-up Action Required?	n	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	General Comments		
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Mechanism Patrol Inspection	General Comments		
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	LTC As Found Counter	85485	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	LTC As Left Counter	85490	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	LTC Current Tap Position	6L	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	LTC Max Tap Position	9L	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	LTC Min Tap Position	2L	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	LTC Operations Since Last Insp	750	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	B0470	LTCMechanism	605-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	1	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	5	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000639	LTCControl	767-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000639	LTCControl	767-1	LTC Control Insp	LTC Output Voltage Level	122.7	VAC
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	LTCC000639	LTCControl	767-1	LTC Control Insp	LTC Operation Checked?	y	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	9 Month Operations	3	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	O0234	WithLTC	343-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Unknown Operations	0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Switching Operations	6	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Operations This Read Vac	6	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Operations Counter AL	259	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Operations Counter AF	257	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Maintenance Operations	0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Grounds in Place?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	General Comments		
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	General Comments		
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Foundation Condition	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Follow-up Action Required?	n	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Fault Operations Ground	0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Fault Operations C Ø	0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Fault Operations B Ø	0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Fault Operations A Ø	0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Patrol Inspection	Bushing Condition	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Amps C Ø	10.0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Amps B Ø	9.0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Amps A Ø	10.0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0037	BreakerVacuum	539-0968	VCB Readings	9 Month Operations	19	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	FE000856	Fence	605-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	CB0139	BreakerVacuum	608-2460	VCB Readings	Unknown Operations	0	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0269	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	6	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	Follow-up Action Required?	n	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	General Comments		
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Mechanism Patrol Inspection	General Comments		
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	LTC As Found Counter	233558	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	LTC As Left Counter	233561	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	O0186	LTCMechanism	594-1	LTC Counter Readings	LTC Current Tap Position	1L	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Regulator As Left Counter	24795	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	122.6	volts
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Fault Operations C Ø	0	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Fault Operations Ground	0	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Follow-up Action Required?	n	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Foundation Condition	Good	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	General Comments		
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	General Comments		
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Grounds in Place?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Maintenance Operations	0	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Operations Counter AF	281	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Operations Counter AL	281	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Switching Operations	0	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Operations This Read Vac	18	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Operations Counter AL	499	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Operations This Read Vac	1	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Switching Operations	1	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Unknown Operations	0	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Min Tap Position	2R	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Max Tap Position	5L	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	General Comments		
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Current Tap Position	4L	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	77	°F
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Operations Counter AF	499	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Yard Lights Working?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Maintenance Operations	0	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	FE000013	Fence	346-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Vegetation	None	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	General Comments		
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	YD000842	Yard	452-Yard	Yard Patrol Inspection	Ambient Temp	77	°F
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	9 Month Operations	8	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	General Comments		
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Foundation Condition	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Follow-up Action Required?	n	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Fault Operations Ground	0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Fault Operations C ∅	0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Fault Operations B ∅	0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Fault Operations A ∅	0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	LTC Operations Since Last Insp	2127	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	LTC Min Tap Position	10L	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	LTC Max Tap Position	7R	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	LTC Current Tap Position	4L	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	LTC As Left Counter	6907	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	LTC As Found Counter	6903	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Mechanism Patrol Inspection	General Comments		
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	General Comments		
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	S0022	LTCMechanism	737-1	LTC Counter Readings	Follow-up Action Required?	n	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	LTCC000716	LTCControl	594-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	LTCC000716	LTCControl	594-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	LTCC000716	LTCControl	594-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	LTCC000716	LTCControl	594-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	LTCC000716	LTCControl	594-1	LTC Control Insp	LTC Output Voltage Level	122.7	VAC
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	LTCC000716	LTCControl	594-1	LTC Control Insp	LTC Operation Checked?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Bushing Condition	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Amps C ∅	495.0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Amps B ∅	490.0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Amps A ∅	465.0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	9 Month Operations	21	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	LTCC000716	LTCControl	594-1	LTC Control Insp	General Comments		
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	LTCC000716	LTCControl	594-1	LTC Control Insp	Follow-up Action Required?	n	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	LTCC000716	LTCControl	594-1	LTC Control Insp	All Connections OK?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Unknown Operations	0	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Min Tap Position	4R	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Max Tap Position	5L	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	General Comments		
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KR0116	Regulator	452-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	LTCC000061	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	LTCC000061	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	LTCC000061	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	LTCC000061	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	LTCC000061	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Fault Adjusted Amps C Phase V	9.62	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Fault Adjusted Amps B Phase V	48.11	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Fault Adjusted Amps A Phase V	48.11	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	LTCC000061	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	LTCC000061	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	LTCC000061	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	LTC Operations Since Last Insp	4329	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	LTC Min Tap Position	12L	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	LTC Max Tap Position	8R	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	LTC Current Tap Position	6L	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	LTC As Left Counter	64478	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	LTC As Found Counter	64478	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Mechanism Patrol Inspection	General Comments		
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	General Comments		
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KT0026	LTCMechanism	539-2	LTC Counter Readings	Follow-up Action Required?	n	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	Totalizer Meter Reading	.2030	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	55.00	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	60.00	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1948.80	kw
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	General Comments		
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	S0035	NonLTC	452-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	9 Month Operations	26	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Amps A Ø	84.0	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Amps B Ø	115.0	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Amps C Ø	96.0	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Bushing Condition	Good	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	General Comments		
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Amps A Ø	40.0	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Amps B Ø	40.0	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BAT001455	Battery	605-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Indicator Zone	OK	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Bushing Condition	Good	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Grounds in Place?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	General Comments		
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Foundation Condition	Good	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	CS000004	CircuitSwitcher	456-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Ambient Temperature	71	*F
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Trip-energy Supply Verified	y	LED lights?
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Amps C Ø	40.0	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Bushing Condition	Good	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Fault Operations A Ø	0	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Fault Operations B Ø	0	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Fault Operations C Ø	0	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Fault Operations Ground	0	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Follow-up Action Required?	n	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Foundation Condition	Good	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	General Comments		
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Grounds in Place?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Maintenance Operations	0	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Operations Counter AF	221	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Operations Counter AL	221	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Operations This Read Vac	4	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Grounds in Place?	y	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	General Comments	Line crew replaced a bad insulator	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	General Comments		
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Foundation Condition	Good	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Follow-up Action Required?	n	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Switching Operations	4	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	CB0183	BreakerVacuum	605-2455	VCB Readings	Unknown Operations	0	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Fault Operations Ground	2	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Fault Operations C Ø	0	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Fault Operations B Ø	8	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	DB0040	BreakerVacuum	343-0752	VCB Readings	Fault Operations A Ø	8	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Indicator Zone	OK	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Bushing Condition	Good	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Grounds in Place?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	General Comments		
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Foundation Condition	Good	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	CS000003	CircuitSwitcher	452-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Ambient Temperature	77	*F
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Amps C Ø	280.0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Bushing Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Fault Operations A Ø	0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Fault Operations B Ø	0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Fault Operations C Ø	0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Fault Operations Ground	0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Follow-up Action Required?	n	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Foundation Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	General Comments		
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	General Comments		
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Grounds in Place?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Vegetation	None	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	General Comments		
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	YD000112	Yard	323-Yard	Yard Patrol Inspection	Ambient Temp	52	*F
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	YD000537	Yard	594-Yard	Yard Patrol Inspection	Ambient Temp	77	*F
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Maintenance Operations	0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Operations Counter AF	280	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Operations Counter AL	280	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Operations This Read Vac	1	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Switching Operations	1	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	WB0182	BreakerVacuum	767-2414	VCB Readings	Unknown Operations	0	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	General Comments		
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	180.0	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	130.0	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	130.0	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	FE000519	Fence	767-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Vegetation	None	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	General Comments		
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	YD000488	Yard	608-Yard	Yard Patrol Inspection	Ambient Temp	75	*F
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	General Comments		
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	FE000483	Fence	608-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	General Comments		
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	FE000865	Fence	608-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	100.0	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	84.0	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	DB0050	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	10	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	General Comments		
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	ST000486	Structure	605-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	Winding Temp Present	37	°C
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	Winding Temp Max	60	°C
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	Totalizer Meter Reading	.4610	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	Oil Temp Present	35	°C
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	Oil Temp Max	50	°C
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	LTC Totalizer Reading	8298.00	kw
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	General Comments		
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	General Comments		
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	General Comments		
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Vegetation	None	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	General Comments		
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	YD000011	Yard	346-Yard	Yard Patrol Inspection	Ambient Temp	75	*F
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Unknown Operations	0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Switching Operations	5	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Operations This Read Vac	5	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Operations Counter AL	306	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Operations Counter AF	303	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	Maintenance Operations	0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Patrol Inspection	Grounds in Place?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0001	BreakerVacuum	539-0970	VCB Readings	General Comments		
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	25	*F
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #"'s
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	General Comments		
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	BAT001124	Battery	737-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	CH000383	ControlHouse	698-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	General Comments		
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Retired Distribution	Good	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	General Comments		
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	5	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	658	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	660	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	2	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	2	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	FE000799	Fence	452-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	BB0036	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Regulator As Left Counter	26431	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.7	volts
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	KR0117	Regulator	452-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	9 Month Operations	30	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Amps A Ø	34.0	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Amps B Ø	42.0	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Amps C Ø	38.0	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Bushing Condition	Good	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Fault Operations A Ø	0	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	K0048	BreakerVacuum	605-2453	VCB Readings	Fault Operations B Ø	0	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	BAT001121	Battery	550-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	B0470	WithLTC	605-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	BAT001325	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	58	*F
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	BAT001325	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Fault Operations Ground	0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Follow-up Action Required?	n	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Patrol Inspection	Foundation Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Patrol Inspection	General Comments		
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Operations This Read Vac	0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Operations Counter AL	207	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Operations Counter AF	207	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Current Tap Position	8L	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	General Comments		
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Patrol Inspection	Grounds in Place?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Maintenance Operations	0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	BAT001325	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	BAT001325	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Operations Counter AF	145	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Operations Counter AL	145	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Operations This Read Vac	1	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Switching Operations	1	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Unknown Operations	0	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	BAT001325	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	General Comments		
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Max Tap Position	3L	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Min Tap Position	11L	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Ambient Temp	71	*F
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	9 Month Operations	5	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	General Comments		
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	BAT001325	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	BAT001325	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	BAT001325	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	BAT001325	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Unknown Operations	0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Switching Operations	0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Operations This Read Vac	0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Operations Counter AL	64	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Operations Counter AF	64	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Maintenance Operations	0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Grounds in Place?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	General Comments		
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	General Comments		
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Foundation Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Follow-up Action Required?	n	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Fault Operations A Ø	0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Fault Operations B Ø	0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Fault Operations C Ø	0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Fault Operations Ground	0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Fault Operations C Ø	0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Fault Operations B Ø	0	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Unknown Operations	0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Switching Operations	0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Fault Operations A Ø	0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Patrol Inspection	Bushing Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Amps C Ø	410.0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Amps B Ø	400.0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Amps A Ø	400.0	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	BCH001267	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	BCH001267	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	BCH001267	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	BCH001267	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	BCH001267	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	BAT001325	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	77	*F
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0153	BreakerVacuum	767-1	VCB Readings	9 Month Operations	1	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Maintenance Operations	0	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Amps A Ø	47.0	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Amps B Ø	50.0	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Amps C Ø	50.0	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Bushing Condition	Good	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Unknown Operations	0	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Switching Operations	0	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Operations This Read Vac	0	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Operations Counter AL	203	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Operations Counter AF	203	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Maintenance Operations	0	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	General Comments		
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Follow-up Action Required?	n	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Fault Operations Ground	0	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Fault Operations C Ø	0	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Fault Operations B Ø	0	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Grounds in Place?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	General Comments		
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	General Comments		
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Foundation Condition	Good	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Fault Operations A Ø	0	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Fault Operations B Ø	0	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Fault Operations C Ø	0	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Fault Operations Ground	0	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	BAT001325	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	BAT001325	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	BAT001325	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Vegetation	None	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	BAT001325	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	BCH000934	Charger	452-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	YD000308	Yard	456-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Regulator As Left Counter	66063	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	BCH000934	Charger	452-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	BCH000934	Charger	452-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.7	amps
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	R1212	Regulator	323-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	LTCC000347	LTCControl	539-2	LTC Control Insp	LTC Operation Checked?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	LTCC000347	LTCControl	539-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	LTCC000347	LTCControl	539-2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	LTCC000347	LTCControl	539-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	LTCC000347	LTCControl	539-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	General Comments		
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/22/2020 15:33	Distribution	A O Smith Quarterly Inspection	ST000315	Structure	456-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	BCH000934	Charger	452-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	BCH000934	Charger	452-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	BCH000934	Charger	452-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	General Comments		
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/22/2020 17:41	Distribution	Rineyville Quarterly Inspection	BAT000882	Battery	452-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	74	*F
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	General Comments		
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	BAT001101	Battery	343-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	BCH001062	Charger	343-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	BCH001062	Charger	343-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	BCH001062	Charger	343-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	BCH001062	Charger	343-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	BCH001062	Charger	343-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/22/2020 12:22	Distribution	Poor Valley Quarterly Inspection	BCH001062	Charger	343-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	General Comments		
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	General Comments		
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	ST000399	Structure	737-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	General Comments		
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	Follow-up Action Required?	n	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	General Comments		
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/22/2020 9:40	Distribution	Hamblin Quarterly Inspection	ST000065	Structure	361-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	FE000520	Fence	527-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	9 Month Operations	23	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Amps A Ø	177.0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Amps B Ø	175.0	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Readings	Amps C Ø	177.0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Patrol Inspection	Bushing Condition	Good	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Regulator As Left Counter	777	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Min Tap Position	5L	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	General Comments		
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	General Comments		
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 13:59	Distribution	St Charles ODP Quarterly Inspection	RG000178	Regulator	346-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BK001110	BreakerVacuum	767-2410	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	General Comments		
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	Grounds in Place?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	LTC Totalizer Reading	6879.60	kw
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	ST000541	Structure	594-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Mechanism Patrol Inspection	General Comments		
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	LTC As Found Counter	253026	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	Oil Temp Max	60	°C
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	Oil Temp Present	40	°C
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	Totalizer Meter Reading	.3822	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	LTC As Left Counter	253026	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	LTC Current Tap Position	7L	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	LTC Max Tap Position	8L	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	LTC Min Tap Position	2L	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	LTC Operations Since Last Insp	1587	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	C0478	LTCMechanism	698-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	LTCC000347	LTCCControl	539-2	LTC Control Insp	All Connections OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	LTCC000347	LTCControl	539-2	LTC Control Insp	Follow-up Action Required?	n	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	LTCC000347	LTCControl	539-2	LTC Control Insp	General Comments		
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	General Comments		
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	Winding Temp Max	50	°C
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	Winding Temp Present	47	°C
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	C0478	WithLTC	698-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/22/2020 15:42	Distribution	Mount Sterling Quarterly Inspection	FE000390	Fence	737-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Switching Operations	4	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Unknown Operations	0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	General Comments		
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	9 Month Operations	8	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Amps A Ø	13.0	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Amps B Ø	10.0	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Amps C Ø	7.0	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Bushing Condition	Good	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	Totalizer Meter Reading	1.1784	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCControl	539-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCControl	539-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Fault Operations A Ø	0	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Fault Operations B Ø	0	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Fault Operations C Ø	0	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Fault Operations Ground	0	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Follow-up Action Required?	n	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Foundation Condition	Good	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	General Comments		
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	General Comments		
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Grounds in Place?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Maintenance Operations	0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCControl	539-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCControl	539-1	LTC Control Insp	Parallel / Ind. Sw Position	parallellIND	Position
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCControl	539-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCControl	539-1	LTC Control Insp	LTC Operation Checked?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Fault Operations B Ø	0	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	160.0	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	160.0	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	160.0	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Fault Operations C Ø	0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	Oil Temp Present	40	°C
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	Oil Temp Max	70	°C
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	LTC Totalizer Reading	15530.40	kw
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	General Comments		
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Fault Operations Ground	0	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Follow-up Action Required?	n	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Foundation Condition	Good	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	General Comments		
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	General Comments		
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Grounds in Place?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Maintenance Operations	0	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Operations Counter AF	169	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Operations Counter AL	169	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Operations This Read Vac	4	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	77	°F
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low, note cell #'s
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BAT000596	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Unknown Operations	0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Switching Operations	0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Operations This Read Vac	0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Operations Counter AL	214	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Operations Counter AF	214	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Amps C Ø	30.0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Unknown Operations	0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Switching Operations	1	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Operations This Read Vac	1	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Operations Counter AL	896	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Operations Counter AF	896	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Readings	Maintenance Operations	0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	CB0203	BreakerVacuum	767-2415	VCB Patrol Inspection	Grounds in Place?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Bushing Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Maintenance Operations	0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Grounds in Place?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	General Comments		
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Foundation Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Readings	Follow-up Action Required?	n	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	BB0381	BreakerVacuum	767-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCCControl	539-1	LTC Control Insp	General Comments		
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCCControl	539-1	LTC Control Insp	Follow-up Action Required?	n	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	LTCC000512	LTCCControl	539-1	LTC Control Insp	All Connections OK?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	Oil Temp Present	40	°C
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	Oil Temp Max	40	°C
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	LTC Totalizer Reading	8484.48	kw
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	General Comments		
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	General Comments		
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Operations Counter AF	166	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Operations Counter AL	166	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Operations This Read Vac	4	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000752	BreakerVacuum	605-2454	VCB Readings	Switching Operations	4	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	BCH000930	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	BCH000930	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	BCH000930	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	BCH000930	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	BCH000930	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/22/2020 15:05	Distribution	Vine Grove Quarterly Inspection	BCH000930	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	B0460	WithLTC	539-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Amps A Ø	84.0	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Amps B Ø	100.0	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Amps C Ø	60.0	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	9 Month Operations	4	
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	3	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Bushing Condition	Good	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2020 16:52	Distribution	Radcliff Quarterly Inspection	CB0172	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	9 Month Operations	5	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Fault Operations A Ø	0	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Fault Operations B Ø	0	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Fault Operations C Ø	0	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Fault Operations Ground	0	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Follow-up Action Required?	n	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Amps A Ø	63.0	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Amps C Ø	800.0	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Amps B Ø	79.0	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Amps C Ø	79.0	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Amps B Ø	800.0	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Amps A Ø	800.0	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Foundation Condition	Good	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	General Comments		
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Bushing Condition	Good	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/22/2020 17:02	Distribution	Rogersville City Quarterly Inspection	BK000751	BreakerVacuum	605-2452	VCB Readings	Fault Operations A Ø	0	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	General Comments		
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Follow-up Action Required?	n	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Foundation Condition	Good	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	General Comments		
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	General Comments		
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Grounds in Place?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Maintenance Operations	0	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Operations Counter AF	163	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Operations Counter AL	163	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Operations This Read Vac	1	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Switching Operations	1	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001111	BreakerVacuum	527-2421	VCB Readings	Unknown Operations	0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Follow-up Action Required?	n	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Fault Operations Ground	0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Fault Operations C Ø	0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Fault Operations B Ø	0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Fault Operations A Ø	0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Fault Operations A Ø	0	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/22/2020 15:14	Distribution	Radcliff South Quarterly Inspection	FE000532	Fence	594-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	9 Month Operations	8	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Patrol Inspection	Bushing Condition	Good	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Amps C Ø	575.0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	KB0018	BreakerVacuum	539-2	VCB Readings	Amps B Ø	580.0	
9/22/2020 15:05	Distribution	Ewington Quarterly Inspection	LTCC000347	LTCControl	539-2	LTC Control Insp	VRR Time Delay	30	Seconds
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	BCH001438	Charger	663-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	BCH001438	Charger	663-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	BCH001438	Charger	663-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	BCH001438	Charger	663-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	BCH001438	Charger	663-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	BCH001438	Charger	663-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	BCH001438	Charger	663-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	Totalizer Meter Reading	.8628	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Amps B Ø	26.0	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Amps A Ø	27.0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/22/2020 17:15	Distribution	Elizabethtown 5 Quarterly Inspection	BK001112	BreakerVacuum	527-2424	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	Winding Temp Present	50	°C
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Readings	Winding Temp Max	80	°C
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	General Comments	Fence is rusty along with barbed wire	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	FE000111	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	9 Month Operations	2	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Unknown Operations	0	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Switching Operations	0	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/22/2020 17:33	Distribution	Elizabethtown 2 Quarterly Inspection	B0421	WithLTC	767-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Operations This Read Vac	0	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Operations Counter AL	259	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Operations Counter AF	259	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Readings	Maintenance Operations	0	
9/22/2020 11:17	Distribution	Pennington Gap Quarterly Inspection	MB0179	BreakerVacuum	323-0755	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	X3 Winding Temp Present	34	°C
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Present	29	°C
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Max	62	°C
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	General Comments		
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	X3 Winding Temp Max	70	°C
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	X2 Winding Temp Present	34	°C
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	X2 Winding Temp Max	70	°C
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	X1 Winding Temp Present	34	°C
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Readings	X1 Winding Temp Max	70	°C
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0016	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	FE000311	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	General Comments		
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments	ok	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	230437	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Floor Swept?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	General Comments		
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Fault Operations A Ø	0	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Fault Operations B Ø	0	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Fault Operations C Ø	0	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Fault Operations Ground	0	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Panels Dusted?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	230437	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	9L	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	LTC Max Tap Position	4R	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	LTC Min Tap Position	12L	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	48	°C
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Readings	Switching Operations	1	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	PF000018	PowerFuse	BI-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	PF000018	PowerFuse	BI-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	General Comments		
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	2184	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	29	°C
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Operations Counter AL	280	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Operations Counter AF	280	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Maintenance Operations	0	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	General Comments		
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	General Comments		
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Readings	General Comments		
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Readings	Maintenance Operations	0	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Readings	Operations Counter AF	206	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Readings	Operations Counter AL	206	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Readings	Operations This Read Vac	1	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	General Comments		
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Unknown Operations	0	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0016	LTCMechanism	SSC-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0232	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0232	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0232	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001429	BreakerVacuum	920-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001429	BreakerVacuum	920-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001429	BreakerVacuum	920-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001429	BreakerVacuum	920-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001429	BreakerVacuum	920-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001429	BreakerVacuum	920-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001429	BreakerVacuum	920-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Operations This Read AM	0	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	General Comments		
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	FE000626	Fence	BI-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	General Comments		
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	ST000612	Structure	BI-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Operations Counter AL	99965	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Operations Counter AF	99965	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Maintenance Operations	0	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	General Comments		
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Patrol Inspection	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Accumulated Fault Duty B Ph V	0	%
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Accumulated Fault Duty C Ph V	.47	%
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Amps A Ø	115	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Amps B Ø	133	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Evidence of Insects	None	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Fault Adjusted Amps C Phase V	0	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Fault Adjusted Amps B Phase V	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Fault Adjusted Amps A Phase V	0	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Control House Lighting OK?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	Acceptable Building Appearance?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	CH000344	ControlHouse	Retired Distribution	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Readings	Unknown Operations	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001295	BreakerVacuum	AL-14KV BUS TIE 1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000883	BreakerVacuum	AL-1443	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Operations Counter	1451	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	9 Month Operations	2	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Accumulated Fault Duty A Ph V	.47	%
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Switching Operations	0	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001429	BreakerVacuum	920-Offline-Distribution	VCB Readings	9 Month Operations	1	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001429	BreakerVacuum	920-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0	%
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001429	BreakerVacuum	920-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0	%
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001429	BreakerVacuum	920-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0	%
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001429	BreakerVacuum	920-Offline-Distribution	VCB Readings	Amps A Ø	147	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001429	BreakerVacuum	920-Offline-Distribution	VCB Readings	Amps B Ø	135	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001429	BreakerVacuum	920-Offline-Distribution	VCB Readings	Amps C Ø	133	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001429	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001429	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001429	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001429	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001429	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001429	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001429	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Readings	9 Month Operations	2	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0	%
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0	%
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Amps C Ø	465	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	General Comments		
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Heaters (All) Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	General Comments		
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Amps B Ø	475	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Amps A Ø	459	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Accumulated Fault Duty C Ph V	0	%
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Accumulated Fault Duty B Ph V	.47	%
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Accumulated Fault Duty A Ph V	0	%
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	9 Month Operations	1	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Amps C Ø	5	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Amps B Ø	5	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Amps A Ø	5	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	LTCC000627	LTCControl	552-1	LTC Control Insp	LTC Output Voltage Level	124	VAC
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	LTCC000627	LTCControl	552-1	LTC Control Insp	LTC Operation Checked?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	LTCC000627	LTCControl	552-1	LTC Control Insp	General Comments		
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	LTCC000627	LTCControl	552-1	LTC Control Insp	Follow-up Action Required?	n	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	LTCC000627	LTCControl	552-1	LTC Control Insp	All Connections OK?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Switching Operations	1	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	LTCC000627	LTCControl	552-1	LTC Control Insp	VRR Base Voltage AF	124	VAC
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	LTCC000627	LTCControl	552-1	LTC Control Insp	VRR Base Voltage AL	124	VAC
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	LTCC000627	LTCControl	552-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	LTCC000385	LTCControl	738-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	LTCC000385	LTCControl	738-1	LTC Control Insp	VRR Base Voltage AL	124.5	VAC
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	LTCC000385	LTCControl	738-1	LTC Control Insp	VRR Base Voltage AF	124.5	VAC
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	LTCC000385	LTCControl	738-1	LTC Control Insp	LTC Output Voltage Level	123	VAC
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	LTCC000385	LTCControl	738-1	LTC Control Insp	LTC Operation Checked?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	LTCC000385	LTCControl	738-1	LTC Control Insp	General Comments		
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	LTCC000385	LTCControl	738-1	LTC Control Insp	Follow-up Action Required?	n	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	LTCC000385	LTCControl	738-1	LTC Control Insp	All Connections OK?	y	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Fault Adjusted Amps C Phase V	0	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Fault Adjusted Amps B Phase V	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Fault Adjusted Amps A Phase V	0	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000567	BreakerVacuum	AL-1444	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0232	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0232	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0232	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	ST000516	Structure	886-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	General Comments		
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	CH000345	ControlHouse	809-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Operations This Read Vac	1	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	General Comments		
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	CH000388	ControlHouse	455-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	FE000873	Fence	663-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	General Comments		
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	ST000563	Structure	552-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK000882	BreakerVacuum	AL-1442	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Counter Readings	LTC Operations Since Last Insp	1275	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0	psi
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Counter Readings	LTC Min Tap Position	Neutral	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Counter Readings	LTC Max Tap Position	11L	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Counter Readings	LTC Current Tap Position	6L	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Counter Readings	LTC As Left Counter	315730	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Counter Readings	LTC As Found Counter	315725	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Mechanism Patrol Inspection	General Comments		
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	CH000501	ControlHouse	663-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0	%
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Readings	Amps A Ø	0	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Counter Readings	General Comments		
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	LTCMechanism	552-1	LTC Counter Readings	Follow-up Action Required?	n	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Readings	Amps B Ø	0	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Readings	Amps C Ø	0	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001428	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Amps C Ø	50.0	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Amps B Ø	50.0	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Amps B Ø	0.0	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	*F
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Amps C Ø	0.0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	LTCC000697	LTCControl	636-1	LTC Control Insp	All Connections OK?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	LTCC000697	LTCControl	636-1	LTC Control Insp	Follow-up Action Required?	n	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	LTCC000697	LTCControl	636-1	LTC Control Insp	General Comments		
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	LTCC000697	LTCControl	636-1	LTC Control Insp	LTC Operation Checked?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Readings	Operations This Read SF6	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Amps C Ø	50.0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Amps B Ø	50.0	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Amps A Ø	50.0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Readings	Operations Counter AL	47	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Readings	Operations Counter AF	47	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	9 Month Operations	2	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	General Comments		
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Follow-up Action Required?	n	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Fault Operations Ground	0	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Fault Operations C Ø	0	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Fault Operations B Ø	0	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Fault Operations A Ø	0	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Ambient Temp	77	*F
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	9 Month Operations	5	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	General Comments		
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Readings	Switching Operations	0	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	SF6 Pressure	83	psi
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	SF6 Bushing Condition	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26	VDC
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27	VDC
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Readings	Fault Operations	0	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Readings	Follow-up Action Required?	n	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Foundation Condition	Good	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Gauge(s) Condition	Good	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	General Comments		
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BAT000617	Battery	809-Battery Bank	Battery Patrol Inspection	General Comments		
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	9 Month Operations	2	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Accumulated Fault Duty A Ph V	.15	%
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Accumulated Fault Duty B Ph V	.07	%
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Accumulated Fault Duty C Ph V	.07	%
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Amps A Ø	241	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Amps B Ø	246	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Amps C Ø	250	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	LTC As Found Counter	181063	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	LTC As Left Counter	181063	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	LTC Current Tap Position	11L	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	LTC Max Tap Position	1R	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	LTC Min Tap Position	13L	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Amps A Ø	0.0	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1070	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Fault Adjusted Amps A Phase V	0	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Fault Adjusted Amps B Phase V	0	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Fault Adjusted Amps C Phase V	0	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Fault Operations A Ø	0	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Fault Operations B Ø	0	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Fault Operations C Ø	0	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Fault Operations Ground	0	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Follow-up Action Required?	n	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Fault Operations A Ø	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Fault Operations B Ø	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Fault Operations C Ø	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Fault Operations Ground	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Maintenance Operations	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Operations Counter AF	349	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Operations Counter AL	349	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	General Comments		
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Maintenance Operations	0	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Operations Counter AF	180	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Operations Counter AL	180	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Operations This Read Vac	1	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Switching Operations	1	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000889	BreakerVacuum	455-2479	VCB Readings	Unknown Operations	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Operations This Read Vac	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Switching Operations	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Amps A Ø	50.0	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Readings	Num Operations Last 9 Months	0	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Readings	Maintenance Operations	0	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Grounds in Place?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Readings	General Comments		
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	LTCC000697	LTCControl	636-1	LTC Control Insp	LTC Output Voltage Level	124.1	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	LTCC000697	LTCControl	636-1	LTC Control Insp	VRR Base Voltage AF	124	VAC
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	LTCC000697	LTCControl	636-1	LTC Control Insp	VRR Base Voltage AL	124	VAC
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	LTCC000697	LTCControl	636-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001290	BreakerVacuum	AL-14KV TR 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0067	BreakerAirMagnetic	BI-1221	AMCB Readings	9 Months Operations	2	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001429	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001429	BreakerVacuum	920-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001429	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001429	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	General Comments		
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001429	BreakerVacuum	920-Offline-Distribution	VCB Readings	General Comments		
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001429	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	SWG000175	Switchgear	BI-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001429	BreakerVacuum	920-Offline-Distribution	VCB Readings	Maintenance Operations	0	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001429	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001429	BreakerVacuum	920-Offline-Distribution	VCB Readings	Operations Counter AF	172	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001429	BreakerVacuum	920-Offline-Distribution	VCB Readings	Operations Counter AL	172	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001429	BreakerVacuum	920-Offline-Distribution	VCB Readings	Operations This Read Vac	1	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001429	BreakerVacuum	920-Offline-Distribution	VCB Readings	Switching Operations	1	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0239	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushing Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001429	BreakerVacuum	920-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BK001429	BreakerVacuum	920-Offline-Distribution	VCB Readings	Unknown Operations	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001291	BreakerVacuum	AL-14KV TR 3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Fault Adjusted Amps B Phase V	0	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Fault Adjusted Amps C Phase V	0	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Fault Operations A Ø	0	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Fault Operations B Ø	0	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Fault Operations C Ø	0	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Fault Operations Ground	0	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Follow-up Action Required?	n	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	General Comments		
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	General Comments		
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	BCH001256	Charger	552-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	BCH001256	Charger	552-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53	VDC
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	BCH001256	Charger	552-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53	VDC
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	BCH001256	Charger	552-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.1	amps
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	BCH001256	Charger	552-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	BCH001256	Charger	552-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Vegetation	None	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BCH001257	Charger	636-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BCH001257	Charger	636-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53	VDC
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BCH001257	Charger	636-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53	VDC
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BCH001257	Charger	636-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.1	amps
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Maintenance Operations	0	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Operations Counter AF	172	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Operations Counter AL	172	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Operations This Read Vac	1	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Switching Operations	1	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BCH001257	Charger	636-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BCH001257	Charger	636-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Unknown Operations	0	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	Oil Temp Present	28	°C
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Amps C Ø	122	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	Oil Temp Max	52	°C
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	General Comments		
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0192	BreakerVacuum	809-2332	VCB Readings	Fault Adjusted Amps A Phase V	0	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	H3 Winding Temp Present	68	°C
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	H3 Winding Temp Max	30	°C
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	28	°C
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	58	°C
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	H1 Winding Temp Present	28	°C
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	H1 Winding Temp Max	70	°C
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Amps C Ø	20	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Amps B Ø	25	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0128	RecloserElectronic	738-2406	Recloser Electronic Patrol Inspection	Amps A Ø	20	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	General Comments		
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	PN42	WithLTC	VE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Amps C Ø	214	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Amps B Ø	226	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0017	LTCMechanism	BI-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Unknown Operations	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Switching Operations	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Operations This Read Vac	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Operations Counter AL	352	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Operations Counter AF	352	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Maintenance Operations	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Fault Operations Ground	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Fault Operations C Ø	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Fault Operations B Ø	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Fault Operations A Ø	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001294	BreakerVacuum	AL-1372	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Amps A Ø	248	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Accumulated Fault Duty C Ph V	0	%
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Accumulated Fault Duty B Ph V	.48	%
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	Accumulated Fault Duty A Ph V	.48	%
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0073	BreakerVacuum	552-2463	VCB Readings	9 Month Operations	2	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LTCC000403	LTCControl	BI-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LTCC000403	LTCControl	BI-TRANS 2	LTC Control Insp	General Comments		
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Ambient Temperature	70	*F
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000186	BreakerSF6	455-708	GCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LTCC000403	LTCControl	BI-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	YD000843	Yard	455-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	Winding Temp Present	75	*C
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	Winding Temp Max	75	*C
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	Totalizer Meter Reading	.757	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	Oil Temp Present	65	°C
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	Oil Temp Max	65	°C
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	LTC Totalizer Reading	13626	kw
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	General Comments		
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	General Comments		
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	ST000837	Structure	455-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	C0500	WithLTC	636-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	General Comments		
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	FE000803	Fence	455-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	PF000007	PowerFuse	AL-GND TR 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	General Comments		
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	75	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Readings	Winding Temp Present	0	°C
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Readings	Winding Temp Max	0	°C
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Readings	Totalizer Meter Reading	.125	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Readings	Totalizer Meter Multiplier	4000	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	General Comments	ok	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Operations This Read Vac	0	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Switching Operations	0	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Unknown Operations	0	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Readings	Oil Temp Present	37	°C
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Readings	Oil Temp Max	45	°C
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Fault Operations Ground	0	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	General Comments		
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	General Comments		
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Maintenance Operations	0	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Operations Counter AF	80	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Operations Counter AL	80	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Counter Readings	General Comments		
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Mechanism Patrol Inspection	General Comments		
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Counter Readings	LTC As Found Counter	33902	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Counter Readings	LTC As Left Counter	33907	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Counter Readings	LTC Current Tap Position	4L	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Counter Readings	LTC Max Tap Position	2R	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Counter Readings	LTC Min Tap Position	6L	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Counter Readings	LTC Operations Since Last Insp	914	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Oil Status	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	PF000007	PowerFuse	AL-GND TR 1	Disconnect Powerfuse Inspection	General Comments	ok	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	72	°F
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0234	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0234	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0234	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0234	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0234	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0234	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	General Comments	6 pack nitrogen bottles need nitrogen	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	LV Winding Temp Max	40	°C
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	LV Winding Temp Present	40	°C
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.8	psi
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	Oil Temp Max	40	°C
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	Oil Temp Present	40	°C
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	Follow-up Action Required?	n	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Switching Operations	0	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Operations This Read AM	4	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Operations Counter AL	942	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Operations Counter AF	942	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Maintenance Operations	4	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	General Comments		
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Patrol Inspection	General Comments		
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Follow-up Action Required?	n	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Fault Operations Ground	0	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Fault Operations C Ø	0	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Fault Operations B Ø	0	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Fault Operations A Ø	0	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Amps C Ø	25.0	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Amps B Ø	25.0	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Amps A Ø	25.0	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0070	BreakerAirMagnetic	BI-1224	AMCB Readings	9 Months Operations	4	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Readings	LTC Totalizer Reading	500	kw
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Readings	General Comments		
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	General Comments		
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001481	BreakerVacuum	AL-14KV BUS TIE 3-4	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	ST000218	Structure	866-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	C0407	WithLTC	886-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	LTCC000681	LTCControl	686-2	LTC Control Insp	VRR Time Delay	30	Seconds
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	LTCC000681	LTCControl	686-2	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	LTCC000681	LTCControl	686-2	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	LTCC000681	LTCControl	686-2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	LTCC000681	LTCControl	686-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	LTCC000681	LTCControl	686-2	LTC Control Insp	LTC Operation Checked?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	LTCC000681	LTCControl	686-2	LTC Control Insp	General Comments		
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	LTCC000681	LTCControl	686-2	LTC Control Insp	Follow-up Action Required?	n	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	LTCC000681	LTCControl	686-2	LTC Control Insp	All Connections OK?	y	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	BAT001429	Battery	VE-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations A Ø	0	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations B Ø	0	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations C Ø	0	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations Ground	0	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Follow-up Action Required?	n	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Patrol Inspection	General Comments		
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	General Comments		
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Maintenance Operations	0	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AF	31	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AL	31	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Operations This Read AM	0	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Switching Operations	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Readings	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	218	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	218	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Ambient Temp	77	*F
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Clear of Trash?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Maintenance Operations	0	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	General Comments		
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	General Comments		
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Follow-up Action Required?	n	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Fault Operations Ground	0	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Fault Operations C Ø	0	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Fault Operations B Ø	0	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Fault Operations A Ø	0	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Fault Adjusted Amps C Phase V	0	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Fault Adjusted Amps B Phase V	0	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Fault Adjusted Amps A Phase V	0	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Amps C Ø	217	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Amps B Ø	216	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Amps A Ø	215	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Accumulated Fault Duty C Ph V	.96	%
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Accumulated Fault Duty B Ph V	1.43	%
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Accumulated Fault Duty A Ph V	.96	%
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	9 Month Operations	4	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000161	LTCControl	809-2	LTC Control Insp	VRR Time Delay	30	Seconds
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000161	LTCControl	809-2	LTC Control Insp	VRR Base Voltage AL	125	VAC
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000161	LTCControl	809-2	LTC Control Insp	VRR Base Voltage AF	125	VAC
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000161	LTCControl	809-2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000161	LTCControl	809-2	LTC Control Insp	LTC Output Voltage Level	125.1	VAC
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000161	LTCControl	809-2	LTC Control Insp	LTC Operation Checked?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000161	LTCControl	809-2	LTC Control Insp	General Comments		
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000161	LTCControl	809-2	LTC Control Insp	Follow-up Action Required?	n	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000161	LTCControl	809-2	LTC Control Insp	All Connections OK?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	9 Months Operations	2	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Amps A Ø	0.0	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Amps B Ø	0.0	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Amps C Ø	0.0	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Equipment Properly Labeled?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0072	BreakerAirMagnetic	BI-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0040	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Accumulated Fault Duty A Ph V	0	%
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Accumulated Fault Duty B Ph V	0	%
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Accumulated Fault Duty C Ph V	0	%
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Amps A Ø	152	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Amps B Ø	158	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Amps C Ø	160	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	S0061	LTCMechanism	738-1	LTC Counter Readings	Follow-up Action Required?	n	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	General Comments		
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	ST000566	Structure	636-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0039	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Fault Adjusted Amps A Phase V	0	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Fault Adjusted Amps B Phase V	0	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Fault Adjusted Amps C Phase V	0	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Fault Operations A Ø	0	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Fault Operations B Ø	0	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	Fault Operations C Ø	0	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	General Comments		
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Vegetation	None	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	YD000559	Yard	552-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	609	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	LTC Min Tap Position	2L	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	LTC Max Tap Position	5R	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	LTC Current Tap Position	2L	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	LTC As Left Counter	17931	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	LTC As Found Counter	17931	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0010	LTCMechanism	AL-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	General Comments		
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	FE000556	Fence	636-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	78	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Counter Readings	LTC Current Tap Position	7R	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Counter Readings	LTC As Left Counter	59724	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Counter Readings	LTC As Found Counter	59724	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Counter Readings	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0003	LTCMechanism	AL-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0175	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0195	BreakerVacuum	809-2	VCB Readings	9 Month Operations	0	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BCH001369	Charger	686-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BCH001369	Charger	686-Battery Charger	Battery Charge Patrol Insp	Ground Lights	None	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition?	Good	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	General Comments		
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	General Comments		
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	LTC Totalizer Reading	15138	kw
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2	psi
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	Oil Temp Max	72	°C
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	Oil Temp Present	45	°C
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	Totalizer Meter Reading	.841	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	Winding Temp Max	67	°C
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	Winding Temp Present	67	°C
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	120	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	C0521	WithLTC	552-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	General Comments		
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	LTC As Left Counter	22990	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	LTC Current Tap Position	9L	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	LTC Max Tap Position	12L	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	LTC Min Tap Position	4L	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0	psi
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	37	°C
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	37	°C
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	LTC Operations Since Last Insp	2118	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCControl	455-1	LTC Control Insp	All Connections OK?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCControl	455-1	LTC Control Insp	Follow-up Action Required?	n	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCControl	455-1	LTC Control Insp	General Comments		
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCControl	455-1	LTC Control Insp	LTC Operation Checked?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCControl	455-1	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCControl	455-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCControl	455-1	LTC Control Insp	VRR Base Voltage AF	124	VAC
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCControl	455-1	LTC Control Insp	VRR Base Voltage AL	124	VAC
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	LTCC000609	LTCControl	455-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	General Comments		
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	General Comments		
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Ambient Temp	66	*F
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BCH001369	Charger	686-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BCH001369	Charger	686-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BCH001369	Charger	686-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BCH001369	Charger	686-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BCH001369	Charger	686-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	PF000019	PowerFuse	BI-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	PF000019	PowerFuse	BI-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BCH001369	Charger	686-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	135.00	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	130.00	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Vegetation	None	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	General Comments		
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	YD000312	Yard	686-Yard	Yard Patrol Inspection	Ambient Temp	62	°F
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001187	BreakerVacuum	AL-1441	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6576	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	ST000313	Structure	663-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Vegetation	None	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	General Comments		
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	0953	NonLTC	686-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	789.12	kw
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	General Comments		
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	YD000628	Yard	BI-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	ST000319	Structure	686-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	General Comments		
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	C0518	WithLTC	663-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Amps C Ø	130	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Amps B Ø	139	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Mechanism Patrol Inspection	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	Follow-up Action Required?	n	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Amps A Ø	125	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Accumulated Fault Duty C Ph V	0	%
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Accumulated Fault Duty B Ph V	1.03	%
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Accumulated Fault Duty A Ph V	2.06	%
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	9 Month Operations	2	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LTCC000494	LTCControl	AL-TRANS 4	LTC Control Insp	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LTCC000494	LTCControl	AL-TRANS 4	LTC Control Insp	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LTCC000494	LTCControl	AL-TRANS 4	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BCH001358	Charger	809-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BCH001358	Charger	809-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53	VDC
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BCH001358	Charger	809-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53	VDC
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BCH001358	Charger	809-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.3	amps
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BCH001358	Charger	809-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BCH001358	Charger	809-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BCH001358	Charger	809-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	BCH001358	Charger	809-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	PF000012	PowerFuse	AL-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	PF000012	PowerFuse	AL-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	LTC Operations Since Last Insp	298	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	LTC Min Tap Position	6R	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	LTC Max Tap Position	10R	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	LTC Current Tap Position	7R	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	General Comments		
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Mechanism Patrol Inspection	General Comments		
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	LTC As Found Counter	7819	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	LTC As Left Counter	7819	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	LTC Current Tap Position	12L	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	LTC Max Tap Position	5L	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	LTC Min Tap Position	13L	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	LTC Operations Since Last Insp	1062	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	C0430	LTCMechanism	686-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0003	WithLTC	AL-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	LTC As Left Counter	80031	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0009	LTCMechanism	AL-TRANS 4	LTC Counter Readings	LTC As Found Counter	80031	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Unknown Operations	0	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Switching Operations	1	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Operations This Read Vac	1	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Operations Counter AL	276	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Operations Counter AF	276	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Maintenance Operations	0	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	General Comments		
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	General Comments		
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Follow-up Action Required?	n	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Fault Operations Ground	0	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Fault Operations C Ø	0	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Fault Operations B Ø	0	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Fault Operations A Ø	0	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Fault Adjusted Amps C Phase V	0	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Fault Adjusted Amps B Phase V	0	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Readings	Fault Adjusted Amps A Phase V	0	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0257	BreakerVacuum	552-2464	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	General Comments		
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Max Tap Position	3R	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Regulator As Left Counter	50127	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	General Comments		
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Min Tap Position	5L	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Regulator As Left Counter	90883	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0488	Regulator	686-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	Follow-up Action Required?	n	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	General Comments		
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Mechanism Patrol Inspection	General Comments		
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	LTCM000015	LTCMechanism	455-1	LTC Counter Readings	LTC As Found Counter	22985	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	General Comments		
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Regulator As Left Counter	113266	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0486	Regulator	686-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	General Comments		
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	General Comments		
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	LTC Totalizer Reading	12458.88	kw
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1600	psi
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	2	psi
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	Oil Temp Max	36	°C
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	Oil Temp Present	33	°C
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	Totalizer Meter Reading	.8652	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	Winding Temp Max	33	°C
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	Winding Temp Present	33	°C
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	TX000010	WithLTC	455-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	R0487	Regulator	686-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Fault Operations Ground	0	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Fault Operations C ∅	0	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Fault Operations B ∅	0	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Fault Operations A ∅	0	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Amps C ∅	120.0	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Amps B ∅	90.0	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Amps A ∅	185.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	9 Months Operations	1	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	General Comments		
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Maintenance Operations	0	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Operations Counter AF	214	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Operations Counter AL	216	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Operations This Read Vac	2	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Switching Operations	2	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Unknown Operations	0	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Unknown Operations	0	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Switching Operations	1	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Operations This Read Vac	1	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Operations Counter AL	175	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Operations Counter AF	175	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Maintenance Operations	0	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	General Comments		
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	General Comments		
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Follow-up Action Required?	n	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Fault Operations Ground	0	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Fault Operations C Ø	0	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Fault Operations B Ø	0	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Fault Operations A Ø	0	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Fault Adjusted Amps C Phase V	0	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Fault Adjusted Amps B Phase V	0	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Fault Adjusted Amps A Phase V	0	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Amps B Ø	60.0	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Amps C Ø	45.0	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Fault Operations A Ø	0	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Unknown Operations	0	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Switching Operations	0	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Operations This Read AM	0	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Operations Counter AL	413	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Operations Counter AF	413	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Maintenance Operations	0	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	General Comments		
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	General Comments		
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	23975	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	PF001207	PowerFuse	AL-14KV TR 4 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	PF001207	PowerFuse	AL-14KV TR 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	PF001206	PowerFuse	AL-14KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	PF001206	PowerFuse	AL-14KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	23978	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	7L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	PF001205	PowerFuse	AL-14KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	PF001205	PowerFuse	AL-14KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Max Tap Position	12L	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Min Tap Position	4L	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	1301	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Fault Operations B Ø	0	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Fault Operations C Ø	0	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Fault Operations Ground	0	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Follow-up Action Required?	n	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Patrol Inspection	General Comments		
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Patrol Inspection	General Comments		
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Readings	Follow-up Action Required?	n	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1033	BreakerAirMagnetic	VE-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Counter Readings	LTC Operations Since Last Insp	1261	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Accumulated Fault Duty A Ph V	0	%
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Accumulated Fault Duty B Ph V	0	%
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Accumulated Fault Duty C Ph V	0	%
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Amps A Ø	433	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Amps B Ø	428	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Amps C Ø	444	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Fault Adjusted Amps A Phase V	0	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Fault Adjusted Amps B Phase V	0	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Fault Adjusted Amps C Phase V	0	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Fault Operations A Ø	0	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Fault Operations B Ø	0	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Fault Operations C Ø	0	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Fault Operations Ground	0	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Follow-up Action Required?	n	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	General Comments		
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	General Comments		
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Maintenance Operations	0	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Operations Counter AF	149	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Amps C Ø	55	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Amps B Ø	58	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Amps A Ø	60	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Accumulated Fault Duty C Ph V	0	%
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Accumulated Fault Duty B Ph V	0	%
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BCH000955	Charger	455-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133	VDC
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BCH000955	Charger	455-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0	millivolts
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	BCH000091	Charger	VE-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Counter Readings	Follow-up Action Required?	n	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Counter Readings	General Comments		
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Mechanism Patrol Inspection	General Comments		
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Counter Readings	LTC As Found Counter	47330	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Counter Readings	LTC As Left Counter	47333	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	Accumulated Fault Duty A Ph V	0	%
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	K0191	BreakerVacuum	809-2331	VCB Readings	9 Month Operations	2	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	General Comments		
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	BCH000091	Charger	VE-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	BCH000091	Charger	VE-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	BCH000091	Charger	VE-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	BCH000091	Charger	VE-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.8	VDC
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	BCH000091	Charger	VE-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.8	VDC
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	BCH000091	Charger	VE-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	9 Month Operations	0	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BAT000890	Battery	455-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001521	BreakerVacuum	AL-14KV BUS TIE 2-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Counter Readings	LTC Current Tap Position	6L	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Counter Readings	LTC Max Tap Position	9L	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Counter Readings	LTC Min Tap Position	2L	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	C0407	LTCMechanism	886-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0	psi
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Trash Emptied?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	General Comments		
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	*F
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BAT001070	Battery	636-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	45	*C
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	50	*C
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	55	*C
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	60	*C
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	60	*C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	65	°C
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	Oil Temp Present	45	°C
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	Oil Temp Max	50	°C
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	General Comments		
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Operations Counter	1776	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0130	RecloserElectronic	738-2408	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Amps A Ø	20	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Amps B Ø	21	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Amps C Ø	20	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	General Comments		
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Operations Counter	820	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	CX0136	RecloserElectronic	738-2407	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Broom on Site?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	General Comments		
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	CH000179	ControlHouse	BI-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Accumulated Fault Duty A Ph V	6.07	%
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Accumulated Fault Duty B Ph V	7.9	%
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Accumulated Fault Duty C Ph V	4.86	%
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Amps A Ø	53	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Amps B Ø	48	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Amps C Ø	51	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Fault Adjusted Amps A Phase V	0	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Fault Adjusted Amps B Phase V	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0237	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushing Condition	Good	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BCH000955	Charger	455-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133	VDC
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	9 Month Operations	4	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Fault Adjusted Amps C Phase V	0	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Fault Operations A Ø	0	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Fault Operations B Ø	0	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Fault Operations C Ø	0	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Fault Operations Ground	0	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Follow-up Action Required?	n	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	General Comments		
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	General Comments		
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Maintenance Operations	0	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Operations Counter AF	253	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Operations Counter AL	253	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Operations This Read Vac	1	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Switching Operations	1	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	Unknown Operations	0	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	KB0120	BreakerVacuum	686-0879	VCB Readings	Amps A Ø	75.0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0010	WithLTC	AL-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	9 Month Operations	2	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Accumulated Fault Duty A Ph V	0	%
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Accumulated Fault Duty B Ph V	0	%
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Accumulated Fault Duty C Ph V	0	%
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Amps A Ø	139	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Amps B Ø	137	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Amps C Ø	141	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Fault Adjusted Amps A Phase V	0	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Fault Adjusted Amps B Phase V	0	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Fault Adjusted Amps C Phase V	0	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Fault Operations A Ø	0	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Fault Operations B Ø	0	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Fault Operations C Ø	0	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Fault Operations Ground	0	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Follow-up Action Required?	n	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	General Comments		
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	General Comments		
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Maintenance Operations	0	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000313	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000313	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	122	VAC
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000313	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	122	VAC
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000313	LTCControl	920-Offline-Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000313	LTCControl	920-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	121.8	VAC
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000313	LTCControl	920-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000313	LTCControl	920-Offline-Distribution	LTC Control Insp	General Comments		
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000313	LTCControl	920-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	LTCC000313	LTCControl	920-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Operations Counter AF	178	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Operations Counter AL	178	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Operations This Read Vac	1	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Switching Operations	1	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000075	BreakerVacuum	455-2478	VCB Readings	Unknown Operations	0	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BCH000955	Charger	455-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BCH000955	Charger	455-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BCH000955	Charger	455-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BCH000955	Charger	455-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.7	amps
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000076	BreakerVacuum	455-2477	VCB Readings	9 Month Operations	2	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Amps C Ø	10.0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Amps B Ø	10.0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Amps A Ø	10.0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	9 Month Operations	0	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	62	*F
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	General Comments		
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	PF000011	PowerFuse	AL-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	PF000011	PowerFuse	AL-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	PF000013	PowerFuse	AL-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	PF000013	PowerFuse	AL-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	PF000054	PowerFuse	BI-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	PF000054	PowerFuse	BI-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	66	*F
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	BAT000107	Battery	BI-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	PF000055	PowerFuse	BI-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	PF000055	PowerFuse	BI-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Switching Operations	0	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Operations This Read Vac	0	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Operations Counter AL	205	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Operations Counter AF	205	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Maintenance Operations	0	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	General Comments		
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Follow-up Action Required?	n	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Fault Operations Ground	0	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Fault Operations C Ø	0	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Fault Operations B Ø	0	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Fault Operations A Ø	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0235	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0235	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0235	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0235	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0235	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Maintenance Operations	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	PF000008	PowerFuse	AL-GND TR 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	PF000008	PowerFuse	AL-GND TR 2	Disconnect Powerfuse Inspection	General Comments	ok	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	PF000009	PowerFuse	AL-GND TR 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	PF000009	PowerFuse	AL-GND TR 3	Disconnect Powerfuse Inspection	General Comments	ok	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LTCC000472	LTCControl	AL-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LTCC000472	LTCControl	AL-TRANS 3	LTC Control Insp	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	PF000010	PowerFuse	AL-GND TR 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	PF000010	PowerFuse	AL-GND TR 4	Disconnect Powerfuse Inspection	General Comments	ok	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LTCC000472	LTCControl	AL-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Fault Operations Ground	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Fault Operations C Ø	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Fault Operations B Ø	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Fault Operations A Ø	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	General Comments		
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	LTC As Found Counter	426709	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	LTC As Left Counter	426709	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	LTC Current Tap Position	12L	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	LTC Max Tap Position	5L	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	LTC Min Tap Position	12L	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	180	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	PN42	LTCMechanism	VE-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Bushing Condition	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	General Comments		
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	8	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	198	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	200	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	2	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	2	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Unknown Operations	0	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Switching Operations	3	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Operations This Read Vac	3	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Operations Counter AL	338	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Readings	Operations Counter AF	338	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	K0074	BreakerVacuum	552-2462	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Fault Adjusted Amps C Phase V	0	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Fault Adjusted Amps B Phase V	0	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Fault Adjusted Amps A Phase V	0	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Amps C Ø	500	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Amps B Ø	500	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Amps A Ø	500	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Accumulated Fault Duty C Ph V	1.15	%
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Accumulated Fault Duty B Ph V	1.15	%
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	Accumulated Fault Duty A Ph V	1.15	%
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	CB0208	BreakerVacuum	552-1	VCB Readings	9 Month Operations	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001238	BreakerVacuum	AL-14KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	Oil Temp Max	50	°C
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	LTC Totalizer Reading	4039.2	kw
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	General Comments		
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	General Comments		
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0176	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	30.0	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	30.0	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	30.0	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0025	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Switching Operations	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Operations This Read Vac	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Operations Counter AL	479	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Operations Counter AF	479	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	9 Month Operations	23	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Amps A Ø	225.0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Maintenance Operations	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Fault Operations Ground	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Fault Operations C Ø	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Fault Operations B Ø	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Fault Operations A Ø	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Amps B Ø	225.0	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Amps C Ø	230.0	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Fault Operations A Ø	0	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Fault Operations B Ø	0	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Fault Operations C Ø	0	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Fault Operations Ground	0	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Follow-up Action Required?	n	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	General Comments		
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB1275	BreakerVacuum	AL-1380	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Operations Counter AL	149	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Operations This Read Vac	0	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Switching Operations	0	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 16:45	Distribution	Black Branch Road Quarterly Inspection	BK000077	BreakerVacuum	455-1	VCB Readings	Unknown Operations	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001246	BreakerVacuum	AL-1378	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Switching Operations	0	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Operations This Read AM	0	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Operations Counter AL	623	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Operations Counter AF	623	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Maintenance Operations	0	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	General Comments		
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Patrol Inspection	General Comments		
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Follow-up Action Required?	n	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Fault Operations Ground	0	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Fault Operations C Ø	0	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Fault Operations B Ø	0	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Fault Operations A Ø	0	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Amps C Ø	20.0	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Amps B Ø	25.0	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Amps A Ø	20.0	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0069	BreakerAirMagnetic	BI-1223	AMCB Readings	9 Months Operations	0	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	General Comments		
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BAT001448	Battery	686-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	Oil Temp Present	40	°C
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	Oil Temp Max	55	°C
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1250	psi

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	General Comments		
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Switching Operations	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Operations This Read Vac	0	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	5.5	amps
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Operations Counter AL	416	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001244	BreakerVacuum	AL-1374	VCB Readings	Operations Counter AF	416	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LTCC000471	LTCControl	AL-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LTCC000471	LTCControl	AL-TRANS 2	LTC Control Insp	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	PF000006	PowerFuse	AL-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	PF000006	PowerFuse	AL-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LTCC000471	LTCControl	AL-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0235	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Amps C Ø	10.0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Amps B Ø	10.0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Amps A Ø	10.0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001245	BreakerVacuum	AL-1376	VCB Readings	9 Month Operations	1	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	40	°C
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	65	°C
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	40	°C
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	60	°C
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	40	°C
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	Winding Temp Present	26	°C
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	Winding Temp Max	50	°C
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	60	°C
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	Totalizer Meter Reading	.561	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	S0061	WithLTC	738-1	LTC Transformer Readings	Oil Temp Present	30	°C
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	BCH000114	Charger	BI-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Maintenance Operations	0	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Operations Counter AF	356	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Operations Counter AL	357	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Operations This Read Vac	1	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Switching Operations	1	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	K0149	BreakerVacuum	686-0876	VCB Readings	Unknown Operations	0	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LT0017	WithLTC	BI-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0238	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushing Condition	Good	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	General Comments		
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	ANN000010	Annunciator	BI-Annunciator Panel	Annunciator Patrol Inspection	General Comments		
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	ANN000010	Annunciator	BI-Annunciator Panel	Annunciator Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	ANN000010	Annunciator	BI-Annunciator Panel	Annunciator Patrol Inspection	ESOC Received Alarm Test?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	ANN000010	Annunciator	BI-Annunciator Panel	Annunciator Patrol Inspection	Control House Alarm Audible?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	ANN000010	Annunciator	BI-Annunciator Panel	Annunciator Patrol Inspection	All Lights Functioning?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	CAP000103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Grounds in Place?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	CAP000103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	CAP000103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	CAP000103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Tank Paint Condition	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Grounds in Place?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Floor Swept?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	General Comments		
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	LTCC000864	LTCControl	886-1	LTC Control Insp	Follow-up Action Required?	n	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Accumulated Fault Duty C Ph V	0	%
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Accumulated Fault Duty B Ph V	0	%
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	LTCC000864	LTCControl	886-1	LTC Control Insp	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	General Comments		
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	9 Months Operations	0	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	LTCC000864	LTCControl	886-1	LTC Control Insp	LTC Operation Checked?	y	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	LTCC000864	LTCControl	886-1	LTC Control Insp	LTC Output Voltage Level	119.6	VAC
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	LTCC000864	LTCControl	886-1	LTC Control Insp	VRR Base Voltage AF	120	VAC
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	LTCC000864	LTCControl	886-1	LTC Control Insp	VRR Base Voltage AL	120	VAC
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	LTCC000864	LTCControl	886-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Amps A Ø	20.0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Totalizer Meter Reading	.2046	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	FE000552	Fence	552-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Unknown Operations	0	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	CAP000103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	CAP000103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Amps C Ø	100.0	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Amps B Ø	75.0	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Amps A Ø	125.0	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Accumulated Fault Duty B Ph AM	8.54	%
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	General Comments	under construction	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Panel Lights OK?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Panels Dusted?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Station Ground Set On Site?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Amps B Ø	20.0	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Amps C Ø	20.0	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Fault Operations A Ø	0	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Fault Operations B Ø	0	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Fault Operations C Ø	0	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Accumulated Fault Duty A Ph AM	9.61	%
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	9 Months Operations	0	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	7	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	1498	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	1500	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	CH000462	ControlHouse	VE-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	2	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Vegetation	None	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	General Comments		
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	General Comments	vent fan turns on but Louvers dont open	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	n	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	SWG000015	Switchgear	BI-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	2	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	CAP000103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Foundation Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	CAP000103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	CAP000103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Ambient Temp	75	°F
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	General Comments		
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Foundation Condition	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	9 Months Operations	1	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Amps A Ø	230.0	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Amps B Ø	150.0	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Amps C Ø	120.0	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Fault Operations A Ø	0	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Fault Operations B Ø	0	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Fault Operations C Ø	0	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Fault Operations Ground	0	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Follow-up Action Required?	n	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Patrol Inspection	General Comments		
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	General Comments		
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Maintenance Operations	0	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Operations Counter AF	468	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Operations Counter AL	468	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Operations This Read AM	0	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Switching Operations	0	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1034	BreakerAirMagnetic	VE-2	AMCB Readings	Unknown Operations	0	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0174	BreakerVacuum	545-1	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Oil Temp Present	65	°C
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Oil Temp Max	65	°C
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1	psi
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	LTC Totalizer Reading	982.08	kw
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	General Comments		
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Vegetation	None	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0236	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushing Condition	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	30.0	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	YD000305	Yard	663-Yard	Yard Patrol Inspection	Ambient Temp	67	*F
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Maintenance Operations	0	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	General Comments		
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Amps B Ø	56	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Amps C Ø	57	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Patrol Inspection	General Comments		
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Follow-up Action Required?	n	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Fault Operations Ground	0	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Fault Operations C Ø	0	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Fault Operations B Ø	0	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Fault Operations A Ø	0	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Switching Operations	1	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Operations This Read Vac	1	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Operations Counter AL	173	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Operations Counter AF	172	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Unknown Operations	0	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Maintenance Operations	0	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	General Comments		
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	30.0	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	30.0	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	Oil Temp Max	60	°C
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	Oil Temp Present	20	°C
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	PF000016	PowerFuse	AL-14KV BUS SEC 4 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	CAP000103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Warning Signs OK?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	CAP000103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	CAP000103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Tank Leaks	None	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	PF000016	PowerFuse	AL-14KV BUS SEC 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	PF000015	PowerFuse	AL-14KV BUS SEC 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	9 Month Operations	5	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Accumulated Fault Duty A Ph V	2.34	%
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Accumulated Fault Duty B Ph V	1.4	%
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Accumulated Fault Duty C Ph V	.93	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	PF000015	PowerFuse	AL-14KV BUS SEC 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	PF000014	PowerFuse	AL-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	PF000014	PowerFuse	AL-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Amps A Ø	54	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Operations Counter AL	470	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Switching Operations	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	LB1035	BreakerAirMagnetic	VE-3	AMCB Readings	Operations Counter AF	470	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	Totalizer Meter Reading	.8022	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	ST000534	Structure	738-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001050	BreakerVacuum	AL-1375	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Foundation Condition	Good	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Follow-up Action Required?	n	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Grounds in Place?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.8	psi
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Radiator Leaks	None	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Unknown Operations	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LB0036	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Tank Leaks	None	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	LTCC000864	LTCControl	886-1	LTC Control Insp	All Connections OK?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Follow-up Action Required?	n	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Fault Operations Ground	0	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	General Comments		
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Fault Operations C Ø	0	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Fault Operations B Ø	0	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Fault Operations A Ø	0	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Fault Adjusted Amps C Phase V	0	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Fault Adjusted Amps B Phase V	0	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Fault Adjusted Amps A Phase V	0	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Amps C Ø	92	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Amps B Ø	88	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Amps A Ø	99	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Fault Adjusted Amps A Phase V	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Fault Adjusted Amps B Phase V	0	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Fault Adjusted Amps C Phase V	0	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	LTC Operations Since Last Insp	1369	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	35	°C
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Fault Operations A Ø	0	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Fault Operations B Ø	0	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Fault Operations C Ø	0	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Fault Operations Ground	0	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001049	BreakerVacuum	AL-1379	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	Follow-up Action Required?	n	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	General Comments		
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	General Comments		
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	LTC Totalizer Reading	3850.56	kw
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	Oil Temp Max	55	°C
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	Oil Temp Present	30	°C
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	SWG000039	Switchgear	VE-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	32	°C
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	LTC Min Tap Position	2L	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	LTC Max Tap Position	10L	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	LTC Current Tap Position	5L	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	LTC As Left Counter	52339	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	LTC As Found Counter	52335	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	General Comments		
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	General Comments		
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	LTCMechanism	809-2	LTC Counter Readings	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Bushing Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0008	GroundTransformer	AL-GND TR 4	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	General Comments		
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Operations This Read Vac	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Operations Counter AL	225	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Operations Counter AF	225	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Fault Adjusted Amps A Phase V	0	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Fault Adjusted Amps B Phase V	0	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Fault Adjusted Amps C Phase V	0	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Fault Operations A Ø	0	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Fault Operations B Ø	0	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Fault Operations C Ø	0	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Ambient Temp	52	°F
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	General Comments		
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Maintenance Operations	0	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Vegetation	None	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	YD000611	Yard	VE-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Fault Operations Ground	0	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Follow-up Action Required?	n	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	General Comments		
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	General Comments		
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Maintenance Operations	0	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Operations Counter AF	156	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Operations Counter AL	156	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Operations This Read Vac	1	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Switching Operations	1	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Unknown Operations	0	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	X2 Winding Temp Max	60	°C
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Evidence of Insects	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	General Comments		
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	General Comments		
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	9 Months Operations	1	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	Oil Temp Present	40	°C
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	Oil Temp Max	50	°C
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2	psi
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	LTC Totalizer Reading	4089.6	kw
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	General Comments		
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	General Comments		
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	Follow-up Action Required?	n	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	General Comments		
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0	VDC
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0	VDC
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Accumulated Fault Duty C Ph V	0	%
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Amps A Ø	55	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Amps B Ø	60	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Amps C Ø	57	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Switching Operations	0	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	FE000548	Fence	886-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Maintenance Operations	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	CAP000103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Capacitor Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	CAP000103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	CAP000103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Bushing Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	CAP000103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	All Connections OK?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	LT0009	WithLTC	AL-TRANS 4	LTC Transformer Readings	X2 Winding Temp Present	20	°C
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Vegetation	None	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Amps C Ø	640	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Amps B Ø	640	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Amps A Ø	640	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Accumulated Fault Duty C Ph V	0	%
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Accumulated Fault Duty B Ph V	0	%
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Ambient Temp	75	°F
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	General Comments		
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	YD000522	Yard	809-Yard	Yard Patrol Inspection	General Comments		
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Accumulated Fault Duty A Ph V	0	%
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	General Comments		
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	General Comments		
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Follow-up Action Required?	n	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Fault Operations Ground	0	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Fault Operations C Ø	0	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Fault Operations B Ø	0	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Fault Operations A Ø	0	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Operations This Read AM	0	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Operations Counter AL	325	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Operations Counter AF	325	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Follow-up Action Required?	n	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	General Comments		
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	General Comments		
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	FE000611	Fence	VE-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Maintenance Operations	0	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	General Comments		
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Patrol Inspection	General Comments		
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Fault Operations Ground	0	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	9 Month Operations	0	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Amps A Ø	200.0	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Amps B Ø	200.0	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Fault Operations C Ø	0	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Fault Operations B Ø	0	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Fault Operations A Ø	0	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Fault Adjusted Amps C Phase V	0	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Fault Adjusted Amps B Phase V	0	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	ST000527	Structure	809-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Readings	Fault Adjusted Amps A Phase V	0	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	CB0213	BreakerVacuum	636-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Amps C Ø	200.0	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0074	BreakerAirMagnetic	BI-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001051	BreakerVacuum	AL-1373	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	CAP000103	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	FE000524	Fence	809-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Accumulated Fault Duty A Ph V	0	%
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	Accumulated Fault Duty B Ph V	0	%
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Switching Operations	2	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Operations This Read Vac	2	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	General Comments		
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Vegetation	None	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Operations This Read AM	0	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Operations Counter AL	555	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Operations Counter AF	555	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Maintenance Operations	0	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	559	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1	psi
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Min Tap Position	1L	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Max Tap Position	8L	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	2L	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	18885	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	18882	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	General Comments		
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Patrol Inspection	General Comments		
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	C0500	LTCMechanism	920-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Follow-up Action Required?	n	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Switching Operations	0	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Vegetation	None	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Ambient Temp	77	*F
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	Accumulated Fault Duty A Ph V	0	%
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001117	BreakerVacuum	636-2426	VCB Readings	9 Month Operations	2	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	YD000562	Yard	636-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/22/2020 7:35	Distribution	Corporate Drive Quarterly Inspection	K0177	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Trash Emptied?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001388	BreakerVacuum	AL-1377	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	C0430	WithLTC	686-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Ambient Temp	69	*F
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	FE000525	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001119	BreakerVacuum	636-2425	VCB Readings	9 Month Operations	2	
9/21/2020 16:06	Distribution	Gates Rubber Quarterly Inspection	YD000524	Yard	886-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/21/2020 15:47	Distribution	Eastview Quarterly Inspection	YD000530	Yard	738-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/21/2020 15:56	Distribution	Elizabethtown Industrial Quarterly Inspection	BAT001414	Battery	552-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
9/21/2020 12:18	Distribution	Carlisle Quarterly Inspection	BB0128	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	CH000462	ControlHouse	VE-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	CH000462	ControlHouse	VE-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	CH000462	ControlHouse	VE-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	CH000462	ControlHouse	VE-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	CH000462	ControlHouse	VE-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	C0400	WithLTC	920-Offline-Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Unknown Operations	0	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Switching Operations	0	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Operations This Read Vac	0	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Operations Counter AL	164	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Readings	Operations Counter AF	163	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	General Comments		
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	KB0110	BreakerVacuum	636-2461	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Maintenance Operations	0	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Door Alarms OK?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Control House Lighting OK?	y	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Operations Counter AF	158	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	CH000462	ControlHouse	VE-Battery Control House	Control House Patrol Inspection	General Comments		
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/21/2020 9:34	Distribution	Vermont Quarterly Inspection	CH000462	ControlHouse	VE-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0	
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Unknown Operations	0	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Broom on Site?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	Acceptable Building Appearance?	y	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	CH000130	ControlHouse	AL-Control House 1	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	Winding Temp Present	30	*C
9/21/2020 16:18	Distribution	Elizabethtown West Quarterly Inspection	BK001118	BreakerVacuum	636-2427	VCB Readings	Operations Counter AL	158	
9/21/2020 14:01	Distribution	Algonquin Quarterly Inspection	BK001389	BreakerVacuum	AL-1440	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Readings	Fault Operations Ground	0	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/21/2020 12:56	Distribution	Bishop Quarterly Inspection	LB0068	BreakerAirMagnetic	BI-1222	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	Totalizer Meter Reading	.426	
9/21/2020 16:33	Distribution	Elizabethtown 3 Quarterly Inspection	S0069	WithLTC	809-2	LTC Transformer Readings	Winding Temp Max	30	*C
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	General Comments		
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Winding Temp Max	42	*C
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.2	psi
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1250	psi
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Totalizer Meter Reading	.0328	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	18000	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	590.40	kw
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Winding Temp Present	30	*C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Oil Temp Max	42	°C
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	General Comments	ok	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Oil Temp Present	32	°C
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Current Tap Position	1R	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	General Comments	ok	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	LTCC000782	LTCControl	576-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	LTCC000782	LTCControl	576-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	LTCC000782	LTCControl	576-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	LTCC000782	LTCControl	576-1	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	LTCC000782	LTCControl	576-1	LTC Control Insp	LTC Operation Checked?	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	LTCC000782	LTCControl	576-1	LTC Control Insp	General Comments	ok	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	LTCC000782	LTCControl	576-1	LTC Control Insp	Follow-up Action Required?	n	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	LTCC000782	LTCControl	576-1	LTC Control Insp	All Connections OK?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Min Tap Position	2L	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Max Tap Position	4R	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	General Comments		
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	125.8	volts
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Tank Leaks	None	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Amps A Ø	60.0	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Amps B Ø	60.0	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Amps C Ø	60.0	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Bushing Condition	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	General Comments	ok	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Mechanism Patrol Inspection	General Comments	ok	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	LTC As Found Counter	9144	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Current Tap Position	1R	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0420	Regulator	070-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Fault Operations A Ø	0	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	72	*F
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	BCH000257	Charger	576-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	BCH000257	Charger	576-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Unknown Operations	0	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Tank Paint Condition	Good	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Switching Operations	0	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Operations This Read Vac	0	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Operations Counter AL	388	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Operations Counter AF	388	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Maintenance Operations	0	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Ambient Temp	69	*F
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Grounds in Place?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	General Comments		
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	General Comments		
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Foundation Condition	Good	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	BCH000257	Charger	576-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Follow-up Action Required?	n	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Follow-up Action Required?	n	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Fault Operations Ground	0	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	General Comments	ok	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Fault Operations C Ø	0	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Fault Operations B Ø	0	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	BCH000257	Charger	576-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	BCH000257	Charger	576-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	27.8	VDC
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.6	VDC
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	BAT001144	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	General Comments		
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KT0043	NonLTC	070-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	LTC As Left Counter	9152	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	LTC Current Tap Position	3L	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	LTC Max Tap Position	5R	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	General Comments		
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	LTC Min Tap Position	7L	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	LTC Operations Since Last Insp	1317	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Ambient Temp	71	*F
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Max Tap Position	4R	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Min Tap Position	1L	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Vegetation	None	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.4	volts
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Tank Leaks	None	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0421	Regulator	070-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	General Comments	ok	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	YD000154	Yard	418-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	FE000233	Fence	480-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	FE000156	Fence	418-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	General Comments	station service xfmr and cut out needs wildlife protection	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	ST000159	Structure	418-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	LTCC000819	LTCControl	480-1	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	LTCC000819	LTCControl	480-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	LTCC000819	LTCControl	480-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	LTCC000819	LTCControl	480-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	LTCC000378	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	120.5	VAC
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	LTCC000378	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	120.5	VAC
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	LTCC000378	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	0	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Unknown Operations	0	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Tank Paint Condition	Good	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Switching Operations	0	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Operations This Read Vac	3	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Operations Counter AL	194	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Operations Counter AF	194	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Maintenance Operations	3	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	All Connections OK?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Bushing Condition	Good	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	750	psi
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	158789	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	5L	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	7R	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments	ok	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	Neutral	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Vegetation	Light	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Vegetation	None	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	General Comments		
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	General Comments	very light vegetation just inside fence opposite road.	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	LTCC000356	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	LTCC000356	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	LTCC000356	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Warning Signs OK?	y	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Tank Leaks	None	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Grounds in Place?	y	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	LTCC000356	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	LTCC000356	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	LTCC000356	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	General Comments		
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Foundation Condition	Good	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Follow-up Action Required?	n	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	LTCC000356	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	LTCC000356	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	CAP000036	CapacitorBank	Retired Distribution	Capacitor Patrol Inspection	Capacitor Condition	Good	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BCH001221	Charger	480-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BCH001221	Charger	480-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.9	VDC
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BCH001221	Charger	480-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.9	VDC
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BCH001221	Charger	480-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BCH001221	Charger	480-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BCH001221	Charger	480-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	YD000435	Yard	840-Yard	Yard Patrol Inspection	Ambient Temp	70	*F
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	LTCC000378	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	LTCC000378	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	LTCC000378	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	LTCC000378	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	LTCC000378	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	120.8	VAC
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Amps C Ø	122.0	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Amps B Ø	83.0	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Tank Leaks	None	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Amps A Ø	85.0	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	9 Month Operations	2	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Unknown Operations	0	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Switching Operations	0	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Current Tap Position	3R	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Operations This Read Vac	1	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Operations Counter AL	201	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Operations Counter AF	201	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Maintenance Operations	1	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	General Comments	ok	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	General Comments		
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	General Comments	1 trip check	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Follow-up Action Required?	n	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Fault Operations Ground	0	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Fault Operations C Ø	0	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Fault Operations B Ø	0	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Fault Operations A Ø	0	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Max Tap Position	3R	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Min Tap Position	3R	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Patrol Inspection	Bushing Condition	Good	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Amps C Ø	82.0	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Amps B Ø	76.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Amps A Ø	80.0	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Fault Operations C Ø	0	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Fault Operations Ground	0	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000721	BreakerVacuum	866-1617	VCB Readings	9 Month Operations	2	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	397	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	397	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	FE000438	Fence	556-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0261	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	R0422	Regulator	070-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	9 Month Operations	4	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Amps A Ø	30.0	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Amps B Ø	40.0	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Amps C Ø	0.0	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Bushing Condition	Good	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	General Comments	position indicator is faded out needs to be replaced	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	General Comments	ok	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Fault Operations A Ø	0	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Fault Operations B Ø	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Patrol Inspection	Foundation Condition	Good	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	K0068	BreakerVacuum	418-1329	VCB Readings	Follow-up Action Required?	n	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Unknown Operations	0	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Switching Operations	0	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Operations This Read Vac	1	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Operations Counter AL	188	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Operations Counter AF	188	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Maintenance Operations	1	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	General Comments	ok	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	General Comments	1 trip check	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Foundation Condition	Good	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Follow-up Action Required?	n	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Fault Operations Ground	0	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Fault Operations B Ø	0	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Fault Operations A Ø	0	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BK000722	BreakerVacuum	866-1618	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Maintenance Operations	2	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Grounds in Place?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	General Comments	ok	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	General Comments	2 trip checks.1 trip check was not noted on last inspection.	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Foundation Condition	Good	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Follow-up Action Required?	n	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Follow-up Action Required?	n	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Fault Operations Ground	0	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Fault Operations C Ø	0	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Fault Operations B Ø	0	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Fault Operations A Ø	0	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Bushing Condition	Good	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Amps C Ø	71.0	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Amps B Ø	81.0	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Amps A Ø	79.0	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	9 Month Operations	3	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Unknown Operations	0	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Tank Paint Condition	Good	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Switching Operations	0	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Operations This Read Vac	1	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Operations Counter AL	174	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Operations Counter AF	174	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Maintenance Operations	1	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Grounds in Place?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	General Comments	ok	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	General Comments	1 trip check	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Foundation Condition	Good	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Follow-up Action Required?	n	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Follow-up Action Required?	n	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Fault Operations Ground	0	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Fault Operations C Ø	0	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Fault Operations B Ø	0	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Fault Operations A Ø	0	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	General Comments	ok	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	General Comments	ok	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	LTC Totalizer Reading	3245.76	kw
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Unknown Operations	0	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Tank Paint Condition	Good	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Switching Operations	0	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Operations This Read Vac	1	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Operations Counter AL	179	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Operations Counter AF	179	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Maintenance Operations	1	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Grounds in Place?	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	General Comments	ok	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	General Comments	1 trip check	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Foundation Condition	Good	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Follow-up Action Required?	n	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Follow-up Action Required?	n	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Fault Operations Ground	0	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Fault Operations C Ø	0	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	W0322	LTCMechanism	576-1	LTC Counter Readings	Follow-up Action Required?	n	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	Oil Temp Max	45	°C
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	Oil Temp Present	30	°C
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Fault Operations B Ø	0	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Fault Operations A Ø	0	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Patrol Inspection	Bushing Condition	Good	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Amps C Ø	7.0	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Amps B Ø	0.0	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Amps A Ø	0.0	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	BK000903	BreakerVacuum	576-1614	VCB Readings	9 Month Operations	4	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	71	°F
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	BAT001089	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	Totalizer Meter Reading	.6762	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	W0295	WithLTC	480-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Unknown Operations	0	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Patrol Inspection	Tank Paint Condition	Good	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Operations This Read Vac	2	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Operations Counter AL	190	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000728	BreakerVacuum	480-1623	VCB Readings	Operations Counter AF	190	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	LTC Totalizer Reading	1200.00	kw
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	Oil Temp Max	50	°C
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	Oil Temp Present	30	°C
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	Totalizer Meter Reading	.2000	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	General Comments	ok	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	General Comments		
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Amps C Ø	13.0	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Amps B Ø	16.0	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Amps A Ø	17.0	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	95905	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	5L	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	7R	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments	ok	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	YD000211	Yard	866-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	FE000211	Fence	866-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	Neutral	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0585	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0583	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Patrol Inspection	Bushing Condition	Good	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Amps C Ø	68.0	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Amps B Ø	57.0	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Amps A Ø	57.0	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000727	BreakerVacuum	480-1621	VCB Readings	9 Month Operations	3	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	27.4	VDC
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.3	VDC
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BAT001276	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	General Comments	ok	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	ST000239	Structure	480-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Operations Counter	8	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	General Comments		
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	RC000288	RecloserElectronic	070-0770	Recloser Electronic Patrol Inspection	Operations Counter	16	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Amps C Ø	9.0	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Amps B Ø	9.0	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	RC900514	RecloserElectronic	070-3420	Recloser Electronic Patrol Inspection	Amps A Ø	8.0	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	LTCC000819	LTCControl	480-1	LTC Control Insp	LTC Operation Checked?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	LTCC000819	LTCControl	480-1	LTC Control Insp	General Comments	ok	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	LTCC000819	LTCControl	480-1	LTC Control Insp	Follow-up Action Required?	n	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	LTCC000819	LTCControl	480-1	LTC Control Insp	All Connections OK?	y	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	General Comments		
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Readings	General Comments		
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	WithLTC	840-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	LTC Min Tap Position	14L	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	LTC Operations Since Last Insp	1322	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	Follow-up Action Required?	n	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	Totalizer Meter Multiplier	2400	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	Oil Temp Present	40	°C
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	Oil Temp Max	60	°C
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	LTC Totalizer Reading	1379.52	kw
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	General Comments	secondary of xfmr needs wildlife protection	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	General Comments	ok	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	Totalizer Meter Reading	.6396	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	220.00	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	General Comments	ok	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Tank Paint Condition	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Operations This Read Vac	0	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Switching Operations	0	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Tank Paint Condition	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Unknown Operations	0	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Switching Operations	1	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Operations This Read Vac	2	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	General Comments	ok	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Vegetation	None	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	General Comments	ok	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Operations Counter AL	262	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Operations Counter AF	262	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	General Comments		
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	LTC Current Tap Position	9L	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	9 Month Operations	5	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	General Comments	ok	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	5R	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	6L	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	14808	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	LTCC000807	LTCControl	418-1	LTC Control Insp	All Connections OK?	y	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	LTCC000807	LTCControl	418-1	LTC Control Insp	Follow-up Action Required?	n	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	LTCC000807	LTCControl	418-1	LTC Control Insp	General Comments	ok	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	LTCC000807	LTCControl	418-1	LTC Control Insp	LTC Operation Checked?	y	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	LTCC000807	LTCControl	418-1	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	LTCC000807	LTCControl	418-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	LTCC000807	LTCControl	418-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	LTCC000807	LTCControl	418-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	General Comments		
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Fault Operations Ground	0	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Fault Operations C ∅	0	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Fault Operations B ∅	0	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Fault Operations A ∅	0	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Maintenance Operations	1	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Grounds in Place?	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	General Comments	ok	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	General Comments	1 trip check, 1 switching op for hot disconnect	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Foundation Condition	Good	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Follow-up Action Required?	n	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Follow-up Action Required?	n	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Fault Operations Ground	0	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Fault Operations C Ø	0	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Fault Operations B Ø	0	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Fault Operations A Ø	0	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	YD000145	Yard	576-Yard	Yard Patrol Inspection	Ambient Temp	71	*F
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Patrol Inspection	Bushing Condition	Good	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Amps C Ø	150.0	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Amps B Ø	96.0	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Amps A Ø	84.0	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	1L	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	R0632	Regulator	912-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	General Comments		
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	Oil Temp Present	43	*C
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Operations Counter AF	234	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	BAT001232	Battery	556-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Maintenance Operations	0	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Grounds in Place?	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	9 Month Operations	6	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Amps A Ø	10.0	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Amps B Ø	9.3	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Amps C Ø	10.4	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	General Comments		
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	General Comments		
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Foundation Condition	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Follow-up Action Required?	n	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Bushing Condition	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	General Comments	ok	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	General Comments	ok	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	General Comments	ok	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	LTC Totalizer Reading	6140.16	kw
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	Oil Temp Max	59	°C
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	2	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	2	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	82	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	80	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	2	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Unknown Operations	0	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Tank Paint Condition	Good	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	BCH000300	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments	ok	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	BCH000300	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	BCH000300	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	54.8	VDC
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Switching Operations	0	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Operations This Read Vac	0	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Operations Counter AL	0	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	General Comments		
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	Follow-up Action Required?	n	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	General Comments		
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Mechanism Patrol Inspection	General Comments		
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	LTC As Found Counter	301740	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	C0429	LTCMechanism	840-1	LTC Counter Readings	LTC As Left Counter	301745	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	Totalizer Meter Reading	.7014	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	All Connections OK?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	Battery Area Ambient Temp	72	°F
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	Battery Overall Condition	Good	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	General Comments	ok	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	Positive DC Ground	26.9	VDC
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BAT001508	Battery	866-Battery Bank 1	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BCH001439	Charger	866-Battery Charger 1	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BCH001439	Charger	866-Battery Charger 1	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BCH001439	Charger	866-Battery Charger 1	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	BCH001439	Charger	866-Battery Charger 1	Battery Charger Patrol Insp	General Comments	ok	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	WB0156	BreakerVacuum	576-1615	VCB Readings	Unknown Operations	0	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	LTC Operations Since Last Insp	98	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	LTC Min Tap Position	15L	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	LTC Max Tap Position	6L	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	LTC Current Tap Position	13L	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	LTC As Left Counter	610	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	LTC As Found Counter	609	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Mechanism Patrol Inspection	General Comments	ok	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	General Comments	counter stopped working at 610	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	ST000149	Structure	576-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	Totalizer Meter Reading	.5748	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Fault Operations A Ø	0	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	W0322	WithLTC	576-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/18/2020 12:11	Distribution	Greenville 12kV Quarterly Inspection	FE000146	Fence	576-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Fault Operations B Ø	0	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Fault Operations C Ø	0	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Fault Operations Ground	0	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Follow-up Action Required?	n	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Foundation Condition	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	General Comments		
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	General Comments		
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Grounds in Place?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Maintenance Operations	0	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Operations Counter AF	44	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	BK000483	BreakerVacuum	070-2	VCB Readings	Operations Counter AL	44	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	W0282	LTCMechanism	418-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	YD000328	Yard	480-Yard	Yard Patrol Inspection	Vegetation	Light	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	General Comments		
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	General Comments		
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	LTC Totalizer Reading	5212.80	kw

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	300.0	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	Oil Temp Max	53	°C
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	Oil Temp Present	35	°C
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	BCH001181	Charger	556-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	BCH001181	Charger	556-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	General Comments		
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	General Comments	Totalizer Meter multiplier label is faded	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-5	psi
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	179.52	kw
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	15.00	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	10.00	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	Oil Temp Max	45	°C
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	Oil Temp Present	30	°C
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	Totalizer Meter Reading	.2244	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	General Comments		
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Readings	General Comments		
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	Totalizer Meter Reading	.5430	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1683.36	kw
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	Oil Temp Max	62	°C
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	CB0262	BreakerVacuum	556-2466	VCB Readings	9 Month Operations	0	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Unknown Operations	0	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Tank Paint Condition	Good	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Switching Operations	0	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Operations This Read Vac	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Operations Counter AL	162	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Operations Counter AF	162	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Maintenance Operations	1	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Grounds in Place?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	General Comments	position indicator is faded and needs replaced.	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	Follow-up Action Required?	n	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	General Comments		
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	General Comments		
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	LTC As Found Counter	98265	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	LTC As Left Counter	98267	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	LTC Current Tap Position	7L	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	LTC Max Tap Position	1R	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	General Comments	1 trip check	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Foundation Condition	Good	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Follow-up Action Required?	n	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Follow-up Action Required?	n	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	LTC Min Tap Position	13L	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	LTC Operations Since Last Insp	1150	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	C0524	LTCMechanism	556-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	General Comments		
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Fault Operations Ground	0	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Fault Operations C Ø	0	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Fault Operations B Ø	0	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000070	NonLTC	070-5 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Fault Operations A Ø	0	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Patrol Inspection	Bushing Condition	Good	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Amps C Ø	61.0	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Amps B Ø	95.0	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Amps A Ø	65.0	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	BK000434	BreakerVacuum	480-1622	VCB Readings	9 Month Operations	3	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	300.0	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	ST000438	Structure	840-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	300.0	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	C0524	WithLTC	556-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	BCH001181	Charger	556-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-5	psi
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	60.00	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Readings	General Comments		
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	General Comments		
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	55.00	
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	CB0038	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Readings	Oil Temp Max	40	°C
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Readings	Oil Temp Present	27	°C
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000071	NonLTC	070-5 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Amps A Ø	10.0	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	9 Month Operations	0	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/18/2020 13:14	Distribution	Texas Gas Quarterly Inspection	W0282	WithLTC	418-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	General Comments		
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	YD000442	Yard	556-Yard	Yard Patrol Inspection	Vegetation	None	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	LTC Current Tap Position	3R	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	LTC Max Tap Position	4R	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	LTC As Left Counter	690864	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	LTC Min Tap Position	7L	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	LTC Operations Since Last Insp	464	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Readings	Oil Temp Present	50	°C
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-5	psi
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol I Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	60.00	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Amps C Ø	10.4	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	55.00	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Readings	Oil Temp Max	45	°C
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Readings	Oil Temp Present	30	°C
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Readings	Amps B Ø	9.3	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	BCH001181	Charger	556-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/18/2020 16:27	Distribution	Mid Valley Clarkson Quarterly Inspection	FE000431	Fence	840-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/21/2020 11:55	Distribution	Greenville West Quarterly Inspection	W0251	NonLTC	866-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	TX000072	NonLTC	070-5 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/18/2020 14:45	Distribution	Pocket Quarterly Inspection	KB0090	BreakerVacuum	070-BT2-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	LTC As Found Counter	690859	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Mechanism Patrol Inspection	General Comments	ok	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	General Comments	ok	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/18/2020 10:22	Distribution	Greenville Quarterly Inspection	W0295	LTCMechanism	480-1	LTC Counter Readings	Follow-up Action Required?	n	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	BCH001181	Charger	556-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	BCH001181	Charger	556-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	ST000462	Structure	556-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/18/2020 16:37	Distribution	Leitchfield East Quarterly Inspection	BCH001181	Charger	556-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	Switching Operations	1	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	Operations This Read SF6	23	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	Operations Counter AL	620	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	Operations Counter AF	620	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	Fault Operations	22	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	Follow-up Action Required?	n	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	General Comments	Lightning arrestor failed	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	Num Operations Last 9 Months	23	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Readings	Maintenance Operations	0	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	SF6 Bushing Condition	Good	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Moisture and Leak Free?	y	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Heaters (All) Functioning?	y	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Grounds in Place?	y	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	General Comments		
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Foundation Condition	Good	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Tank Paint Condition	Good	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Follow-up Action Required?	n	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Equipment Properly Labeled?	y	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Paint Condition	Good	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0754	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Bushings Connection/Risers	Good	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	Switching Operations	1	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	Fault Operations	0	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	Follow-up Action Required?	n	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	General Comments		
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	Maintenance Operations	0	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	Num Operations Last 9 Months	1	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	Operations Counter AL	664	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	Operations Counter AF	664	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Readings	Operations This Read SF6	1	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Moisture and Leak Free?	y	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	SF6 Bushing Condition	Good	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Equipment Properly Labeled?	y	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Paint Condition	Good	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Tank Paint Condition	Good	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Bushings Connection/Risers	Good	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Heaters (All) Functioning?	y	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Grounds in Place?	y	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Foundation Condition	Good	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0752	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Follow-up Action Required?	n	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Follow-up Action Required?	n	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Fault Operations	0	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Switching Operations	0	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Operations This Read SF6	0	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Operations Counter AL	421	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Operations Counter AF	421	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Num Operations Last 9 Months	0	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	Maintenance Operations	0	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Readings	General Comments		
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Cabinet Paint Condition	Good	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Equipment Properly Labeled?	y	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Bushings Connection/Risers	Good	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Tank Paint Condition	Good	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	General Comments		
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Foundation Condition	Good	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Grounds in Place?	y	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Heaters (All) Functioning?	y	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	SF6 Bushing Condition	Good	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Moisture and Leak Free?	y	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	TB0753	BreakerSF6	Retired Distribution	GCB Patrol Inspection	Follow-up Action Required?	n	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	LTCC000202	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	Oil Temp Max	30	°C
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	Oil Temp Present	25	°C
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments	Recloser is open and 0304L1 disconnects are open	
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Vegetation	None	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	General Comments		
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Max Tap Position	5R	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	BCH000093	Charger	WE-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Amps B Ø	25.0	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	LTCC000202	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Min Tap Position	1L	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	LTCC000202	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Amps A Ø	25.0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	LTCC000202	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
9/17/2020 13:21	Distribution	Western Quarterly Inspection	BCH000093	Charger	WE-Battery Charger	Battery Charger Patrol Insp	General Comments	.02 amps	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	LTCC000202	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	BCH000093	Charger	WE-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	LTCC000202	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	LTCC000202	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	122.7	volts
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	554	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Current Tap Position	2R	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Unknown Operations	0	
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Regulator As Left Counter	76068	
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Tank Paint Condition	Good	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Switching Operations	0	
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
9/17/2020 13:21	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Vegetation	None	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	General Comments		
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	LTCC000202	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Unknown Operations	0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Switching Operations	0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Operations This Read AM	0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Operations Counter AL	421	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Operations Counter AF	421	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	FE000011	Fence	318-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Maintenance Operations	0	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Bushing Condition	Good	
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	LTC Operations Since Last Insp	1433	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	LTC Min Tap Position	11L	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	LTC Max Tap Position	1L	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Amps C Ø	0.0	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Amps B Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	LTC Current Tap Position	7L	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	LTC As Left Counter	5289	
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	BCH000093	Charger	WE-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/17/2020 13:21	Distribution	Western Quarterly Inspection	BCH000093	Charger	WE-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.6	VDC
9/17/2020 13:21	Distribution	Western Quarterly Inspection	BCH000093	Charger	WE-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.6	VDC
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Amps A Ø	0.0	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	LTC As Found Counter	5289	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Follow-up Action Required?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Mechanism Patrol Inspection	General Comments		
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	General Comments		
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	DX0151	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	S0010	LTCMechanism	683-2	LTC Counter Readings	Follow-up Action Required?	n	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	BCH000093	Charger	WE-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	General Comments		
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Operations This Read Vac	0	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Operations Counter AL	185	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Operations Counter AF	185	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	General Comments		
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	ST000084	Structure	229-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1125	Regulator	341-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	YD000098	Yard	341-Yard	Yard Patrol Inspection	Ambient Temp	64	°F
9/17/2020 13:21	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	General Comments		
9/17/2020 13:21	Distribution	Western Quarterly Inspection	FE000607	Fence	WE-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	General Comments	Address sign is missing from fence	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Maintenance Operations	0	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	9 Month Operations	0	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Grounds in Place?	y	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	General Comments		
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	General Comments		
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Foundation Condition	Good	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Follow-up Action Required?	n	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Follow-up Action Required?	n	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Fault Operations Ground	0	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Fault Operations C Ø	0	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Fault Operations A Ø	0	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/17/2020 11:29	Distribution	Imboden Quarterly Inspection	BK000931	BreakerVacuum	071-3415	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Ambient Temp	58	*F
9/17/2020 13:21	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	YD000610	Yard	WE-Yard	Yard Patrol Inspection	General Comments		
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	General Comments		
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Ambient Temp	65	*F
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	General Comments		
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Operations Counter	60	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Vegetation	None	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	YD000066	Yard	318-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	General Comments		
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	General Comments		
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Max	.10	MegaVars
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Min	-.20	MegaVars
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Max	3.80	MegaWatts
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	General Comments		
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	LTC As Found Counter	236950	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	LTC As Left Counter	236950	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6L	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	LTC Max Tap Position	16L	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Min	1.60	MegaWatts
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN69	WithLTC	WE-TRANS 1	LTC Transformer Readings	Oil Temp Present	30	°C
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	LTC Min Tap Position	8L	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	297	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN69	LTCMechanism	WE-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Amps A Ø	14.0	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Amps B Ø	23.0	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Amps C Ø	14.0	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	KX0151	RecloserElectronic	341-0743	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Current Tap Position	2R	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	Totalizer Meter Reading	.7026	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	400	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	Oil Temp Present	34	°C
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	Oil Temp Max	48	°C
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	281.04	kw
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	General Comments		
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	General Comments		
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	B0233	NonLTC	318-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	69	°F
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BAT000429	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	FE000076	Fence	229-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/17/2020 13:21	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/17/2020 13:21	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/17/2020 13:21	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	General Comments		
9/17/2020 13:21	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/17/2020 13:21	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/17/2020 13:21	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/17/2020 13:21	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/17/2020 13:21	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/17/2020 13:21	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
9/17/2020 13:21	Distribution	Western Quarterly Inspection	BAT001293	Battery	WE-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	General Comments		
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	ST000074	Structure	318-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Regulator As Left Counter	206703	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	122.6	volts
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Min Tap Position	1L	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	General Comments		
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1110	Regulator	341-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Vegetation	None	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Regulator As Left Counter	202851	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.5	volts
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Min Tap Position	2L	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	General Comments		
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Current Tap Position	1R	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	9 Months Operations	0	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Unknown Operations	0	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Tank Paint Condition	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Switching Operations	4	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Operations This Read Vac	5	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Operations Counter AL	414	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Operations Counter AF	410	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Maintenance Operations	0	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Grounds in Place?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	General Comments		
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Foundation Condition	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Follow-up Action Required?	n	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Follow-up Action Required?	n	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Fault Operations Ground	0	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Fault Operations C Ø	0	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Fault Operations B Ø	1	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Fault Operations A Ø	0	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Fault Adjusted Amps B Phase V	4.44	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Patrol Inspection	Bushing Condition	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Amps C Ø	190.0	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1600	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	Totalizer Meter Reading	.1716	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	General Comments		
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	LTC As Found Counter	18030	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	LTC As Left Counter	18030	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	LTC Current Tap Position	8L	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	LTC Max Tap Position	3L	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	LTC Min Tap Position	9L	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	260	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN64	LTCMechanism	WE-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Current Tap Position	6L	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Follow-up Action Required?	y	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	General Comments	Drag hands and counter are inop.	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Max Tap Position	6L	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Ambient Temp	64	*F
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/17/2020 14:43	Distribution	Calvin Quarterly Inspection	YD000076	Yard	229-Yard	Yard Patrol Inspection	General Comments		
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	9 Month Operations	15	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	LTCC000400	LTCControl	683-1	LTC Control Insp	All Connections OK?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	LTCC000400	LTCControl	683-1	LTC Control Insp	Follow-up Action Required?	n	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	LTCC000400	LTCControl	683-1	LTC Control Insp	General Comments		
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	LTCC000400	LTCControl	683-1	LTC Control Insp	LTC Operation Checked?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	LTCC000400	LTCControl	683-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	LTCC000400	LTCControl	683-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	LTCC000400	LTCControl	683-1	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	LTCC000400	LTCControl	683-1	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	LTCC000400	LTCControl	683-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Amps C Ø	200.0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Amps B Ø	190.0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Amps A Ø	160.0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Regulator As Left Counter	297832	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	9 Months Operations	0	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	General Comments		
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0992	Regulator	318-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Amps B Ø	180.0	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Amps A Ø	180.0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Unknown Operations	0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	R1111	Regulator	341-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Regulator As Left Counter	79891	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0988	Regulator	318-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Current Tap Position	3L	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Operations This Read AM	0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Operations Counter AL	612	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Operations Counter AF	612	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Maintenance Operations	0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	General Comments		
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Patrol Inspection	General Comments		
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Follow-up Action Required?	n	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Fault Operations Ground	0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Fault Operations C Ø	0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Fault Operations B Ø	0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Fault Operations A Ø	0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1147	BreakerAirMagnetic	WE-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	General Comments		
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Min Tap Position	4L	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	R0990	Regulator	318-1 A	Regulator Patrol Inspection	Regulator As Left Counter	171356	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0004	BreakerVacuum	536-0236	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Unknown Operations	0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	CH000448	ControlHouse	WE-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	CH000448	ControlHouse	WE-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	CH000448	ControlHouse	WE-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	CH000448	ControlHouse	WE-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	CH000448	ControlHouse	WE-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	CH000448	ControlHouse	WE-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	CH000448	ControlHouse	WE-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	CH000448	ControlHouse	WE-Battery Control House	Control House Patrol Inspection	General Comments		
9/17/2020 13:21	Distribution	Western Quarterly Inspection	CH000448	ControlHouse	WE-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Unknown Operations	0	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Tank Paint Condition	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Switching Operations	2	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Operations This Read Vac	2	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Operations Counter AL	153	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Operations Counter AF	151	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Maintenance Operations	0	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Grounds in Place?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	General Comments		
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	General Comments		
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Foundation Condition	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Follow-up Action Required?	n	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Follow-up Action Required?	n	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Fault Operations Ground	0	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Fault Operations C Ø	0	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Fault Operations B Ø	0	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Fault Operations A Ø	0	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	General Comments		
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	ST000318	Structure	683-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Patrol Inspection	Bushing Condition	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Amps C Ø	75.0	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Amps B Ø	70.0	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Amps A Ø	120.0	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001397	BreakerVacuum	683-0619	VCB Readings	9 Month Operations	23	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Unknown Operations	0	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Tank Paint Condition	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Switching Operations	2	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Operations This Read Vac	2	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Operations Counter AL	163	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Operations Counter AF	161	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Maintenance Operations	0	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Fault Operations A Ø	3	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Fault Operations B Ø	3	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Ambient Temp	69	*F
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Fault Operations C Ø	0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	9 Months Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Amps A Ø	420.0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Amps B Ø	250.0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Amps C Ø	280.0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	General Comments		
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Vegetation	None	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	YD000311	Yard	683-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Fault Operations A Ø	0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Fault Operations B Ø	0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Fault Operations C Ø	0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Fault Operations Ground	0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Follow-up Action Required?	n	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Patrol Inspection	General Comments		
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	General Comments		
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Fault Operations Ground	0	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Follow-up Action Required?	n	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Follow-up Action Required?	n	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Foundation Condition	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	General Comments		
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	General Comments		
9/17/2020 13:21	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Maintenance Operations	0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Operations Counter AF	533	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Operations Counter AL	533	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Operations This Read AM	0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Unknown Operations	0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Switching Operations	0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Operations This Read AM	0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Operations Counter AL	1006	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Operations Counter AF	1006	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Maintenance Operations	0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1144	BreakerAirMagnetic	WE-1	AMCB Readings	Switching Operations	0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Fault Operations Ground	0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Fault Operations C Ø	0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Fault Operations B Ø	0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Fault Operations A Ø	0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Amps C Ø	100.0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Amps B Ø	180.0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Amps A Ø	170.0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	9 Months Operations	2	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/17/2020 13:21	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
9/17/2020 13:21	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	SWG000040	Switchgear	WE-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Grounds in Place?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Maintenance Operations	0	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Unknown Operations	0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Switching Operations	0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Operations This Read AM	0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Operations Counter AL	489	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Operations Counter AF	489	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Maintenance Operations	0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	General Comments		
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Patrol Inspection	General Comments		
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Follow-up Action Required?	n	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Fault Operations Ground	0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Fault Operations C Ø	0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Fault Operations B Ø	0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Fault Operations A Ø	0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Amps C Ø	260.0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Amps B Ø	300.0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Amps A Ø	200.0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1146	BreakerAirMagnetic	WE-3	AMCB Readings	9 Months Operations	2	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Grounds in Place?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	General Comments		
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	General Comments		
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Foundation Condition	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Follow-up Action Required?	n	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Follow-up Action Required?	n	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Fault Operations Ground	0	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Fault Operations C Ø	0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Fault Operations B Ø	0	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Fault Operations A Ø	0	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	FE000098	Fence	341-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Patrol Inspection	Heaters (All) Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	General Comments		
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Patrol Inspection	General Comments		
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Follow-up Action Required?	n	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Fault Operations Ground	0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Fault Operations C Ø	0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Fault Operations B Ø	0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Fault Operations A Ø	0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	PN64	WithLTC	WE-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
9/17/2020 13:21	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Unknown Operations	0	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Tank Paint Condition	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Switching Operations	4	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Operations This Read Vac	10	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Operations Counter AL	458	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Operations Counter AF	454	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	SWG000041	Switchgear	WE-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Unknown Operations	0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Switching Operations	0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Operations This Read AM	0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Operations Counter AL	421	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Operations Counter AF	421	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Maintenance Operations	0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	General Comments		
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	General Comments		
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	ST000104	Structure	341-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Patrol Inspection	General Comments		
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Readings	Follow-up Action Required?	n	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1145	BreakerAirMagnetic	WE-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	LTC Totalizer Reading	1724.40	kw
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Amps A Ø	20.1	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	Oil Temp Max	52	°C
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	Oil Temp Present	42	°C
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	Totalizer Meter Reading	.2874	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Amps A Ø	95.0	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	Oil Temp Present	40	°C
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	Oil Temp Max	60	°C
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Amps C Ø	50.0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	LTC Totalizer Reading	8231.04	kw
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	General Comments		
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Fault Operations A Ø	0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Fault Operations B Ø	0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Fault Operations C Ø	0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Fault Operations Ground	0	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	General Comments		
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	Follow-up Action Required?	n	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BCH000378	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BCH000378	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BCH000378	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BCH000378	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BCH000378	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BCH000378	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BCH000378	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	LTC Current Tap Position	2L	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	LTC Max Tap Position	4R	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	LTC Min Tap Position	6L	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	LTC As Left Counter	60873	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	LTC Operations Since Last Insp	729	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	LTC As Found Counter	60873	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Mechanism Patrol Inspection	General Comments		
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	General Comments		
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	B0335	LTCMechanism	683-1	LTC Counter Readings	Follow-up Action Required?	n	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Amps A Ø	50.0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Amps B Ø	50.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Amps B Ø	13.8	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Amps C Ø	25.4	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	General Comments		
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	Totalizer Meter Reading	.8574	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Operations Counter	452	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
9/17/2020 13:04	Distribution	Keokee Quarterly Inspection	MX0455	RecloserHydraulic	318-0738	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	General Comments		
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Readings	General Comments		
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	B0335	WithLTC	683-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	9 Month Operations	14	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	General Comments		
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Patrol Inspection	General Comments		
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	Follow-up Action Required?	n	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Amps C Ø	50.0	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	General Comments		
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	General Comments		
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Fault Adjusted Amps B Phase V	13.31	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Fault Adjusted Amps A Phase V	13.31	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	General Comments		
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	FE000307	Fence	683-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Amps A Ø	60.0	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Amps B Ø	80.0	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Readings	Amps C Ø	60.0	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	S0010	WithLTC	683-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1150	BreakerAirMagnetic	WE-5	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	K0003	BreakerVacuum	536-0235	VCB Patrol Inspection	Bushing Condition	Good	
9/17/2020 13:21	Distribution	Western Quarterly Inspection	LB1151	BreakerAirMagnetic	WE-6	AMCB Readings	9 Months Operations	0	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/17/2020 12:16	Distribution	Exeter Quarterly Inspection	0938	NonLTC	341-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	274.56	kw
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Amps B Ø	70.0	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	Amps C Ø	80.0	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Readings	9 Month Operations	21	
9/17/2020 11:42	Distribution	Morehead Quarterly Inspection	BK001396	BreakerVacuum	683-0618	VCB Patrol Inspection	Bushing Condition	Good	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Fault Operations B Ø	0	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Fault Operations C Ø	0	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Fault Operations Ground	0	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Follow-up Action Required?	n	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Foundation Condition	Good	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	General Comments		
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	General Comments		
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Grounds in Place?	y	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Maintenance Operations	0	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Operations Counter AF	171	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	9 Month Operations	1	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BCH001091	Charger	FM-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	General Comments		
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	General Comments		
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Amps C Ø	162.0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Amps B Ø	175.0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Amps A Ø	178.0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	9 Month Operations	8	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	General Comments		
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	72	*F
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	9 Month Operations	4	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Amps A Ø	10.0	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Amps B Ø	10.0	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Amps C Ø	10.0	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Bushing Condition	Good	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Fault Operations A Ø	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	General Comments		
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	BCH000011	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	26.6	VDC
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Fault Operations A Ø	0	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Fault Operations B Ø	0	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Fault Operations C Ø	0	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Fault Operations Ground	0	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Follow-up Action Required?	n	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Foundation Condition	Good	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	General Comments		
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	General Comments		
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Grounds in Place?	y	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Maintenance Operations	0	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	BCH000011	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	26.6	VDC
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Operations Counter AF	171	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Operations Counter AL	173	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Operations This Read Vac	2	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Switching Operations	2	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Tank Paint Condition	Good	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Unknown Operations	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	LTC Max Tap Position	5R	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	LTC Min Tap Position	13L	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1939	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	9 Month Operations	2	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	BCH000011	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	BCH000011	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	BCH000011	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	BCH000011	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments	.02 amps	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Patrol Inspection	General Comments		
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	General Comments		
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Operations Counter AF	567	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Amps A Ø	348.6	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Amps B Ø	375.4	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Amps C Ø	305.4	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Bushing Condition	Good	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Operations Counter AL	567	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Operations This Read AM	0	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Switching Operations	0	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Unknown Operations	0	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	General Comments		
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BCH001091	Charger	FM-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BCH001091	Charger	FM-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BCH001091	Charger	FM-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	4.9	amps
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BCH001091	Charger	FM-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BCH001091	Charger	FM-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Operations Counter AL	173	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Operations This Read Vac	2	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Switching Operations	2	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Patrol Inspection	Tank Paint Condition	Good	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BCH001091	Charger	FM-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001292	BreakerVacuum	023-0807	VCB Readings	Unknown Operations	0	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	General Comments		
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1	psi
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LTCC000360	LTCCControl	FM-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	9 Month Operations	4	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LTCC000360	LTCCControl	FM-TRANS 1	LTC Control Insp	General Comments		
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LTCC000360	LTCCControl	FM-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	Oil Temp Max	57	°C
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	Oil Temp Present	28	°C
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Amps A Ø	35.0	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Amps B Ø	40.0	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	Percent Thermal Load A Ø Max	60	%
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	Percent Thermal Load B Ø Max	60	%
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Readings	Amps C Ø	30.0	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Bushing Condition	Good	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	BK001293	BreakerVacuum	023-0808	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	Percent Thermal Load C Ø Max	60	%
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	FE000566	Fence	FM-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Vegetation	None	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1750	psi
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Follow-up Action Required?	n	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	BCH000011	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BAT000093	Battery	FM-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Bushing Condition	Good	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Vegetation	None	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Amps C Ø	25.0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Amps B Ø	50.0	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Amps A Ø	50.0	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	General Comments		
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	LTC As Found Counter	409425	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	LTC As Left Counter	409425	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	General Comments		
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	9 Month Operations	6	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Exp/Missing Not Repl	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	General Comments		
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	LTC Min Tap Position	7L	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	LTC Max Tap Position	7L	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	LTC Current Tap Position	7L	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Totalizer Meter Reading	.3930	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	General Comments		
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Winding Temp Max	40	°C
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	General Comments		
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Very Low	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	197	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	LTC Min Tap Position	4L	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4R	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	LTC Current Tap Position	3L	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	LTC As Left Counter	421172	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	LTC As Found Counter	421172	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	Totalizer Meter Reading	.2580	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Tank Oil Level	Low	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	General Comments	LTC has a oil leak	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	General Comments		
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	General Comments		
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	Oil Temp Present	49	°C
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	Oil Temp Max	50	°C
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	LTC Totalizer Reading	2476.80	kw
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	General Comments		
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN49	LTCMechanism	SN-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Winding Temp Present	30	°C
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Fault Adjusted Amps A Phase V	22.36	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Fault Adjusted Amps B Phase V	22.36	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Fault Operations A Ø	2	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Fault Operations B Ø	2	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Fault Operations C Ø	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Fault Operations Ground	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Follow-up Action Required?	n	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Foundation Condition	Good	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	General Comments		
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	General Comments	A&B Phase ioc	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Grounds in Place?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Maintenance Operations	0	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	FE000577	Fence	SN-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	M0060	WithLTC	370-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Readings	General Comments		
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	15.00	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	10.00	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Readings	Oil Temp Max	40	°C
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	TX000194	NonLTC	SL-Offline-Distribution	NonLTC Transformer Readings	Oil Temp Present	30	°C
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	General Comments		
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Maintenance Operations	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Operations Counter AF	403	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Operations Counter AL	403	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Operations This Read Vac	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Switching Operations	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Unknown Operations	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	LTC As Found Counter	56665	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	LTC As Left Counter	56665	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	LTC Current Tap Position	13L	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Exp/Missing Not Repl	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	YD000575	Yard	SS-Yard	Yard Patrol Inspection	Ambient Temp	50	°F
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	General Comments		
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	FE000565	Fence	SS-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	60	*F
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BAT001173	Battery	885-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Fault Operations A Ø	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Fault Operations B Ø	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Fault Operations C Ø	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Fault Operations Ground	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Readings	Follow-up Action Required?	n	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1223	BreakerVacuum	FM-1262	VCB Patrol Inspection	General Comments		
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	General Comments		
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	LTC Current Tap Position	10L	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	1886.40	kw
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN51	LTCMechanism	SN-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	0	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BCH001040	Charger	885-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	LTC As Left Counter	115445	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	LTC As Found Counter	115445	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0069	LTCMechanism	FM-TRANS 1	LTC Counter Readings	General Comments		
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Ambient Temp	60	*F
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Oil Temp Max	40	°C
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Oil Temp Present	30	°C
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	LTC Current Tap Position	5L	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	LTC Max Tap Position	2L	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	LTC Min Tap Position	7L	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	LTC Operations Since Last Insp	572	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	YD000309	Yard	885-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	*F
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BAT001197	Battery	370-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BAT001494	Battery	301-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Ambient Temp	65	*F
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Unknown Operations	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Tank Paint Condition	Good	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Switching Operations	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Operations This Read Vac	4	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Operations Counter AL	27	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Readings	Operations Counter AF	27	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001351	BreakerVacuum	FM-1259	VCB Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	LTCC000841	LTCControl	885-1	LTC Control Insp	General Comments		
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	General Comments		
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	LTC Max Tap Position	5R	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	LTC Min Tap Position	16L	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	41	°C
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	2661	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0292	LTCMechanism	FM-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	LTCC000841	LTCControl	885-1	LTC Control Insp	Follow-up Action Required?	n	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	LTCC000841	LTCControl	885-1	LTC Control Insp	All Connections OK?	y	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	General Comments		
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	Follow-up Action Required?	n	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	General Comments		
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Mechanism Patrol Inspection	General Comments		
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	LTC As Found Counter	73456	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0233	LTCMechanism	301-1	LTC Counter Readings	LTC As Left Counter	73458	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Readings	General Comments		
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	General Comments		
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Maintenance Operations	0	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.7	VDC
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.7	VDC
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	LTC Totalizer Reading	4656.96	kw
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	General Comments	added nitrogen	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	General Comments		
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	Follow-up Action Required?	n	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Grounds in Place?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	General Comments		
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	General Comments		
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	LTC Current Tap Position	8L	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	LTC As Left Counter	279516	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	LTC As Found Counter	279511	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Mechanism Patrol Inspection	General Comments		
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	General Comments		
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	Follow-up Action Required?	n	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	BCH001123	Charger	SN-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Interrupts/Puffrs Visual OK?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	General Comments		
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	Totalizer Meter Reading	.6468	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Switching Operations	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Operations This Read Vac	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Operations Counter AL	7	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Operations Counter AF	7	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Readings	Oil Temp Present	40	°C
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Readings	Oil Temp Max	53	°C
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	200.00	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	221.67	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0307	NonLTC	SL-TRANS 1A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	General Comments		
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	General Comments	Needs Nitro	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Bushing Condition	Good	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Amps C Ø	120.0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Amps B Ø	140.0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Amps A Ø	135.0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	9 Month Operations	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	50	°C
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	50	°C
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	Oil Temp Max	78	°C
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Operations Counter AL	248	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Foundation Condition	Good	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Follow-up Action Required?	n	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Fault Operations Ground	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Fault Operations C Ø	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Fault Operations B Ø	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Fault Operations A Ø	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Amps A Ø	91.0	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Amps B Ø	83.0	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Amps C Ø	107.0	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Bushing Condition	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Fault Operations A Ø	0	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Fault Operations B Ø	0	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Fault Operations C Ø	0	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Fault Operations Ground	0	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Follow-up Action Required?	n	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Foundation Condition	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	General Comments		
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	General Comments		
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Grounds in Place?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Maintenance Operations	0	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Operations Counter AF	248	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	General Comments		
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	9 Month Operations	9	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Current Tap Position	3L	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	General Comments		
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Max Tap Position	3R	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Min Tap Position	6L	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Regulator As Left Counter	63790	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Unknown Operations	0	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Switching Operations	0	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Operations This Read AM	0	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Operations Counter AL	295	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Operations Counter AF	295	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Maintenance Operations	0	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	General Comments		
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Follow-up Action Required?	n	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Fault Operations Ground	0	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Fault Operations C Ø	0	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Fault Operations B Ø	0	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Fault Operations A Ø	0	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Amps C Ø	100.0	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Amps B Ø	100.0	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Amps A Ø	25.0	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0885	BreakerAirMagnetic	SS-3	AMCB Readings	9 Months Operations	0	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	SWG000116	Switchgear	SN-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Current Tap Position	3L	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	General Comments		
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Max Tap Position	4R	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Min Tap Position	4L	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Regulator As Left Counter	67404	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Tank Leaks	None	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	Oil Temp Max	54	°C
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Readings	Oil Temp Present	40	°C
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1313	Regulator	023-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	ST000316	Structure	885-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	ST000600	Structure	FM-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	LTC Operations Since Last Insp	559	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	LTC Min Tap Position	14L	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	M0060	LTCMechanism	370-1	LTC Counter Readings	LTC Max Tap Position	4L	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Tank Leaks	None	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1311	Regulator	023-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	B0337	WithLTC	301-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Current Tap Position	3L	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	General Comments		
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Max Tap Position	1R	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Min Tap Position	7L	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Regulator As Left Counter	62379	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Tank Leaks	None	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	R1312	Regulator	023-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	SWG000109	Switchgear	FM-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Fault Operations Ground	0	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Follow-up Action Required?	n	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Foundation Condition	Good	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	General Comments		
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	General Comments		
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Grounds in Place?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Maintenance Operations	3	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Operations Counter AF	187	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Operations Counter AL	187	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Operations This Read Vac	4	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Switching Operations	1	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Follow-up Action Required?	n	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Tank Paint Condition	Good	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Unknown Operations	0	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Fault Operations Ground	0	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	General Comments	Oil leaking from temp gauge flange, sent pictures to maint.	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-8	psi
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	Oil Temp Max	45	°C
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	Oil Temp Present	28	°C
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	Percent Thermal Load A Ø Max	60	%
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	Percent Thermal Load B Ø Max	60	%
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	Percent Thermal Load C Ø Max	60	%
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Fault Operations C Ø	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Fault Operations B Ø	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Fault Operations A Ø	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Amps A Ø	27.0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Fault Operations Ground	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Fault Operations C Ø	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Fault Operations B Ø	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Fault Operations A Ø	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Amps B Ø	25.0	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Amps C Ø	25.0	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Fault Operations A Ø	0	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Fault Operations B Ø	0	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Fault Operations C Ø	0	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Amps C Ø	0.0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Amps B Ø	0.0	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Unknown Operations	0	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	9 Months Operations	1	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	80.00	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	75.00	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Readings	Oil Temp Max	50	°C
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Readings	Oil Temp Present	42	°C
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Amps A Ø	180.0	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Amps B Ø	280.0	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Amps C Ø	300.0	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Fault Operations A Ø	0	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Fault Operations B Ø	0	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Fault Operations C Ø	0	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Readings	Fault Operations Ground	0	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0847	BreakerAirMagnetic	SN-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Amps A Ø	0.0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	9 Month Operations	1	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Amps A Ø	43.0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Switching Operations	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Operations This Read Vac	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Operations Counter AL	209	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Operations Counter AF	209	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Maintenance Operations	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	General Comments		
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN51	WithLTC	SN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	PN49	WithLTC	SN-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	9 Month Operations	6	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Amps A Ø	28.0	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Amps B Ø	11.0	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Amps C Ø	13.0	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Bushing Condition	Good	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Amps C Ø	36.0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Amps B Ø	32.0	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Fault Operations A Ø	0	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Fault Operations B Ø	0	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Fault Operations C Ø	0	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Fault Operations Ground	0	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Follow-up Action Required?	n	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Foundation Condition	Good	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	General Comments		
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	General Comments		
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Grounds in Place?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Maintenance Operations	4	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Operations Counter AF	185	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Operations Counter AL	185	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Operations This Read Vac	5	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Readings	Switching Operations	1	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000543	BreakerVacuum	370-4732	VCB Patrol Inspection	Tank Paint Condition	Good	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	LTCC000279	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	LTCC000279	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	LTCC000279	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	122.6	VAC
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	LTCC000279	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	LTCC000279	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	LTCC000279	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	40	Seconds
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	0	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	General Comments		
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Readings	General Comments		
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	234	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	234	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	General Comments		
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Readings	General Comments		
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	General Comments		
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Operations This Read Vac	2	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	General Comments		
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	CH000447	ControlHouse	SN-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Switching Operations	2	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Patrol Inspection	Tank Paint Condition	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000291	BreakerVacuum	301-4702	VCB Readings	Unknown Operations	0	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	Yes_needs_sprayed	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	SWG000097	Switchgear	SS-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	Oil Temp Present	25	°C
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	85	°C
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	25	°C
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	30	°C
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	30	°C
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	75	°C
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0069	WithLTC	FM-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	58	°C
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Readings	Oil Temp Present	45	°C
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	LTCC000279	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	LTCC000279	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Readings	Oil Temp Max	55	°C
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	30.00	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	45.00	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	FE000668	Fence	SL-Fence	Fence Patrol Inspection	General Comments		
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Operations This Read Vac	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Operations Counter AL	152	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Operations Counter AF	152	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Maintenance Operations	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Patrol Inspection	General Comments		
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Follow-up Action Required?	n	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	9 Month Operations	5	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Amps A Ø	26.0	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Amps B Ø	27.0	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Amps C Ø	31.0	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Bushing Condition	Good	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Fault Operations A Ø	0	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Fault Operations B Ø	0	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Fault Operations C Ø	0	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Fault Operations Ground	0	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Follow-up Action Required?	n	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Foundation Condition	Good	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	General Comments		
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Grounds in Place?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Maintenance Operations	3	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Operations Counter AF	175	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Operations Counter AL	175	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Operations This Read Vac	4	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Switching Operations	1	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Patrol Inspection	Tank Paint Condition	Good	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000541	BreakerVacuum	370-4730	VCB Readings	Unknown Operations	0	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	9 Month Operations	6	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BK000542	BreakerVacuum	370-4731	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Patrol Inspection	Tank Paint Condition	Good	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	ST000647	Structure	SL-Structure	Structure Patrol Inspection	General Comments		
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0308	NonLTC	SL-TRANS 1B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1219	BreakerVacuum	FM-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	3	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001350	BreakerVacuum	FM-1257	VCB Readings	Unknown Operations	0	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	LT0309	NonLTC	SL-TRANS 1C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Unknown Operations	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Switching Operations	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Operations This Read Vac	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Operations Counter AL	214	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Operations Counter AF	214	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	Maintenance Operations	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Readings	General Comments		
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1222	BreakerVacuum	FM-1261	VCB Patrol Inspection	General Comments		
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Unknown Operations	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1220	BreakerVacuum	FM-1258	VCB Readings	Switching Operations	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	9 Month Operations	0	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Ambient Temp	75	*F
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	General Comments		
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Bushing Condition	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Amps C Ø	43.0	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Amps B Ø	42.0	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Amps A Ø	39.0	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	9 Month Operations	10	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Vegetation	None	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	YD000088	Yard	370-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Fault Operations B Ø	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Fault Operations A Ø	0	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	General Comments		
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Maintenance Operations	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Operations Counter AF	602	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Amps C Ø	150.0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Amps B Ø	163.0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Amps A Ø	156.0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Trash Emptied?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Restroom Clean & OK?	n	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Operations Counter AL	602	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Operations This Read Vac	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Switching Operations	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Unknown Operations	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	General Comments		
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Broom on Site?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Maintenance Operations	0	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Operations Counter AF	391	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Operations Counter AL	391	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Operations This Read AM	0	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Switching Operations	0	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Unknown Operations	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	PF000124	PowerFuse	FM-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	PF000124	PowerFuse	FM-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	PF000125	PowerFuse	FM-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	CH000140	ControlHouse	FM-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Unknown Operations	0	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Switching Operations	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Operations This Read Vac	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Operations Counter AL	206	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	LTCC000730	LTCCControl	370-1	LTC Control Insp	VRR Time Delay	60	Seconds
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	LTCC000730	LTCCControl	370-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	LTCC000730	LTCCControl	370-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	LTCC000730	LTCCControl	370-1	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	LTCC000730	LTCCControl	370-1	LTC Control Insp	LTC Operation Checked?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	Totalizer Meter Reading	.5220	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	LTCC000730	LTCCControl	370-1	LTC Control Insp	General Comments		
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	LTCC000730	LTCCControl	370-1	LTC Control Insp	Follow-up Action Required?	n	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	LTCC000730	LTCCControl	370-1	LTC Control Insp	All Connections OK?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Operations Counter AF	206	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Maintenance Operations	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	General Comments		
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Patrol Inspection	General Comments		
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Follow-up Action Required?	n	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	General Comments		
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	FE000305	Fence	885-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	9 Months Operations	0	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Amps A Ø	170.0	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Amps B Ø	200.0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Amps C Ø	280.0	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Operations A Ø	0	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Operations B Ø	0	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Operations C Ø	0	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Fault Operations Ground	0	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Readings	Follow-up Action Required?	n	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0845	BreakerAirMagnetic	SN-2	AMCB Patrol Inspection	General Comments		
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Fault Operations Ground	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Fault Operations C Ø	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Fault Operations B Ø	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Fault Operations A Ø	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Amps C Ø	0.0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Amps B Ø	0.0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Amps A Ø	0.0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1224	BreakerVacuum	FM-1263	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LTCC000406	LTCControl	FM-TRANS 2	LTC Control Insp	General Comments		
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LTCC000406	LTCControl	FM-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	General Comments		
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Patrol Inspection	General Comments		
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Follow-up Action Required?	n	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Fault Operations Ground	0	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Fault Operations C Ø	0	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Fault Operations B Ø	0	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Fault Operations A Ø	0	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Amps C Ø	160.0	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Amps B Ø	140.0	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Amps A Ø	180.0	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Unknown Operations	0	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Switching Operations	0	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Operations This Read AM	2	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Operations Counter AL	396	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Operations Counter AF	396	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Maintenance Operations	0	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	General Comments	A Phase IOC	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Patrol Inspection	General Comments		
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Follow-up Action Required?	n	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Operations Ground	0	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	General Comments		
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Ambient Temp	79	°F
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	9 Months Operations	0	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	14	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Follow-up Action Required?	n	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	20	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	54	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Operations C Ø	0	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	54	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	16	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	2	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	LTCC000727	LTCCControl	301-3	LTC Control Insp	VRR Time Delay	45	Seconds
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	LTCC000727	LTCCControl	301-3	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Patrol Inspection	General Comments		
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	LTCC000727	LTCCControl	301-3	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	LTCC000727	LTCCControl	301-3	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	LTCC000727	LTCCControl	301-3	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	LTCC000727	LTCCControl	301-3	LTC Control Insp	LTC Operation Checked?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Unknown Operations	0	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Tank Paint Condition	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Switching Operations	3	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Operations This Read Vac	16	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Operations Counter AL	167	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Operations Counter AF	167	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	LTCC000727	LTCCControl	301-3	LTC Control Insp	General Comments		
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Maintenance Operations	13	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Ambient Temp	78	°F
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	9 Month Operations	2	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Amps A Ø	112.0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Amps B Ø	100.0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Amps C Ø	94.0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Fault Operations A Ø	0	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	General Comments		
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	9 Month Operations	16	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	ST000094	Structure	370-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	PF000125	PowerFuse	FM-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	PF000126	PowerFuse	FM-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	PF000126	PowerFuse	FM-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	PF000127	PowerFuse	FM-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	PF000127	PowerFuse	FM-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Fault Operations B Ø	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Fault Operations C Ø	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Readings	Fault Operations Ground	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1221	BreakerVacuum	FM-1260	VCB Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	General Comments		
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Unknown Operations	0	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Switching Operations	0	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Operations This Read AM	0	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Operations Counter AL	254	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Operations Counter AF	254	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Readings	Maintenance Operations	0	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0884	BreakerAirMagnetic	SS-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LTCC000406	LTCControl	FM-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	CH000461	ControlHouse	SS-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	CH000461	ControlHouse	SS-Battery Control House	Control House Patrol Inspection	General Comments		
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	CH000461	ControlHouse	SS-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	CH000461	ControlHouse	SS-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	CH000461	ControlHouse	SS-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	CH000461	ControlHouse	SS-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	CH000461	ControlHouse	SS-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	CH000461	ControlHouse	SS-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BCH001344	Charger	370-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BCH001344	Charger	370-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BCH001344	Charger	370-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BCH001344	Charger	370-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BCH001344	Charger	370-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	BCH001344	Charger	370-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	Totalizer Meter Reading	.5448	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	LTC Operations Since Last Insp	416	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	LTC Min Tap Position	11L	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	LTC Max Tap Position	4L	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	LTC Current Tap Position	8L	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	LTC As Left Counter	21392	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	LTC As Found Counter	21392	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Mechanism Patrol Inspection	General Comments		
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	General Comments		
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	B0322	LTCMechanism	885-1	LTC Counter Readings	Follow-up Action Required?	n	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Fault Operations Ground	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Foundation Condition	Good	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	General Comments		
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Trash Emptied?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Grounds in Place?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Maintenance Operations	0	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Unknown Operations	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Switching Operations	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Operations This Read Vac	0	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Follow-up Action Required?	n	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Patrol Inspection	General Comments		
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	General Comments		
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Maintenance Operations	0	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Operations Counter AF	325	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	62	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	0.0	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Operations Counter AL	325	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Operations This Read AM	0	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Switching Operations	0	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Unknown Operations	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Operations Counter AF	68	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Operations Counter AL	68	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Operations This Read Vac	0	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BCH001345	Charger	301-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BCH001345	Charger	301-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	LTC Operations Since Last Insp	839	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	LTC Min Tap Position	12L	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	LTC Max Tap Position	5L	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	LTC Current Tap Position	9L	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	LTC As Left Counter	17610	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	LTC As Found Counter	17607	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Mechanism Patrol Inspection	General Comments		
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	Follow-up Action Required?	n	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	B0337	LTCMechanism	301-3	LTC Counter Readings	Follow-up Action Required?	n	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Fault Operations Ground	0	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Fault Operations C Ø	0	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Fault Operations B Ø	0	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Fault Operations A Ø	0	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Amps C Ø	0.0	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Amps B Ø	0.0	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Amps A Ø	0.0	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	LB0887	BreakerAirMagnetic	SS-1 SPARE	AMCB Readings	9 Months Operations	0	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	10.0	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	10.0	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	10.0	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	General Comments		
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Unknown Operations	0	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Tank Paint Condition	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Switching Operations	1	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0086	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Operations This Read Vac	7	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Broom on Site?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Operations Counter AL	189	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BCH001345	Charger	301-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BCH001345	Charger	301-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BCH001345	Charger	301-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.9	amps
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BCH001345	Charger	301-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BCH001345	Charger	301-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BCH001345	Charger	301-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Operations Counter AF	189	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Maintenance Operations	6	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Grounds in Place?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	General Comments		
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Foundation Condition	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Follow-up Action Required?	n	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Fault Operations Ground	0	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Fault Operations C Ø	0	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Fault Operations B Ø	0	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	CH000397	ControlHouse	370-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	76	*F
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	General Comments	NO LONGER IN SERVICE	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	87	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Fault Operations A Ø	0	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	87	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	General Comments		
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	General Comments	added nitrogen	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	LTC Totalizer Reading	3758.40	kw
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Fault Operations C Ø	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Fault Operations Ground	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	Follow-up Action Required?	n	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Patrol Inspection	General Comments		
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB0301	BreakerVacuum	FM-1256	VCB Readings	General Comments		
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	General Comments		
9/16/2020 15:30	Distribution	Appalachia Quarterly Inspection	FE000090	Fence	370-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	SWG000014	Switchgear	FM-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	Oil Temp Max	59	°C
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	Oil Temp Present	44	°C
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK000491	BreakerVacuum	301-4700	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	Oil Temp Present	40	°C
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Switching Operations	0	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	Oil Temp Max	50	°C
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	LTC Totalizer Reading	3922.56	kw
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	General Comments		
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	General Comments		
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Operations Counter AL	168	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Operations Counter AF	168	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Tank Paint Condition	Good	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Readings	Unknown Operations	0	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	B0322	WithLTC	885-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Maintenance Operations	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	General Comments		
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Patrol Inspection	General Comments		
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Fault Operations Ground	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Amps C Ø	271.0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Amps B Ø	301.0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Amps A Ø	318.0	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LB1171	BreakerVacuum	FM-12KV TR 2	VCB Readings	9 Month Operations	2	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	0.0	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	0.0	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Readings	Follow-up Action Required?	n	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0228	WithLTC	301-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	DB0056	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	General Comments		
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	BAT001434	Battery	SS-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Amps A Ø	150.0	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Amps B Ø	100.0	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Amps C Ø	50.0	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	General Comments		
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Mechanism Patrol Inspection	General Comments	gauge shows high	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	LTC As Found Counter	99691	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	LTC As Left Counter	99691	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	General Comments		
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	General Comments		
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Foundation Condition	Good	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	LTC Current Tap Position	12L	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	LTC Max Tap Position	11L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	LTC Min Tap Position	15L	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	General Comments		
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Vegetation	None	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Follow-up Action Required?	n	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Fault Operations Ground	0	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Fault Operations C ∅	0	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Fault Operations B ∅	0	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Fault Operations A ∅	0	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	YD000583	Yard	SN-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	52	°C
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	24	°C
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	53	°C
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	181	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	High	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	LTCMechanism	SS-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Fault Operations A ∅	0	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Fault Operations B ∅	0	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	BAT001292	Battery	SN-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	24	°C
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	53	°C
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	24	°C
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Fault Operations C ∅	0	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Fault Operations Ground	0	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Operations This Read AM	0	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	LTC Totalizer Reading	3576.96	kw
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Unknown Operations	0	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Tank Paint Condition	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Switching Operations	0	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Operations This Read Vac	21	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Operations Counter AL	171	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Operations Counter AF	171	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Maintenance Operations	21	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Grounds in Place?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	General Comments		
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	General Comments		
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Operations Counter AL	236	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Operations Counter AF	236	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Maintenance Operations	0	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	General Comments		
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Patrol Inspection	General Comments		
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Unknown Operations	0	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Adjusted Amps A Phase AM	19.09	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Unknown Operations	0	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Tank Paint Condition	Good	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Switching Operations	9	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Operations This Read Vac	9	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Operations Counter AL	262	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Operations Counter AF	262	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Maintenance Operations	0	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Grounds in Place?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	9 Months Operations	0	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Vegetation	None	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	9 Months Operations	3	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	LTC Operations Since Last Insp	959	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	LTC Min Tap Position	7L	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	LTC Max Tap Position	1R	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	LTC Current Tap Position	2L	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	9 Month Operations	24	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	LTC As Left Counter	14960	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	LTC As Found Counter	14957	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	Totalizer Meter Reading	.3726	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	Oil Temp Present	39	°C
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Mechanism Patrol Inspection	General Comments		
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Bushing Condition	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Amps C Ø	90.0	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	General Comments		
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0228	LTCMechanism	301-2	LTC Counter Readings	Follow-up Action Required?	n	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Amps A Ø	59.0	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Amps B Ø	80.0	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Follow-up Action Required?	n	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	Oil Temp Max	46	°C
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Readings	General Comments		
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	General Comments		
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/16/2020 9:14	Distribution	Southern Baptist Seminary Quarterly Inspection	PN28	WithLTC	SS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Patrol Inspection	Bushing Condition	Good	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Amps C Ø	130.0	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Amps B Ø	120.0	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Amps A Ø	100.0	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	BB0295	BreakerVacuum	885-0856	VCB Readings	9 Month Operations	16	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Amps C Ø	250.0	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Amps B Ø	300.0	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Amps A Ø	225.0	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	FE000059	Fence	301-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Foundation Condition	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Follow-up Action Required?	n	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	General Comments	SPR light is no longer installed at the sub	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Fault Operations Ground	0	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Fault Operations C Ø	0	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Fault Operations B Ø	0	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Fault Operations A Ø	0	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	YD000059	Yard	301-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001582	BreakerVacuum	301-4701	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Operations A Ø	0	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Switching Operations	0	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	LTCC000698	LTCControl	301-2	LTC Control Insp	LTC Output Voltage Level	125.1	VAC
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Vegetation	None	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	LTCC000698	LTCControl	301-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	General Comments		
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	LTCC000698	LTCControl	301-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	LTCC000698	LTCControl	301-2	LTC Control Insp	VRR Time Delay	45	Seconds
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Fault Operations A Ø	0	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	LTCC000727	LTCControl	301-3	LTC Control Insp	Follow-up Action Required?	n	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Vegetation	None	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Amps A Ø	138.0	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Amps B Ø	123.0	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Amps C Ø	160.0	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Bushing Condition	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	LTCC000727	LTCControl	301-3	LTC Control Insp	All Connections OK?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Patrol Inspection	General Comments		
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	O0233	WithLTC	301-1	LTC Transformer Readings	General Comments		
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Operations Ground	0	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Operations C Ø	0	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Operations B Ø	0	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	LTCC000841	LTCControl	885-1	LTC Control Insp	LTC Operation Checked?	y	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	LTCC000841	LTCControl	885-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	General Comments		
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/16/2020 15:44	Distribution	Millersburg Quarterly Inspection	TX000231	NonLTC	023-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	ST000064	Structure	301-Structure	Structure Patrol Inspection	All Identified and Legible?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	General Comments		
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	SWG000122	Switchgear	SN-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Fault Operations C Ø	0	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Fault Operations B Ø	0	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	LTCC000698	LTCControl	301-2	LTC Control Insp	All Connections OK?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Patrol Inspection	General Comments		
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Follow-up Action Required?	n	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	LTCC000698	LTCControl	301-2	LTC Control Insp	Follow-up Action Required?	n	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	Oil Temp Present	24	°C
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Readings	Oil Temp Max	51	°C
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	LTCC000841	LTCControl	885-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	LTCC000841	LTCControl	885-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Switching Operations	0	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0846	BreakerAirMagnetic	SN-3	AMCB Readings	Unknown Operations	0	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	LTCC000698	LTCControl	301-2	LTC Control Insp	General Comments		
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	9 Month Operations	20	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	LTCC000698	LTCControl	301-2	LTC Control Insp	LTC Operation Checked?	y	
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	LTCC000841	LTCControl	885-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Trash Emptied?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/16/2020 10:38	Distribution	Kawneer Quarterly Inspection	LTCC000841	LTCControl	885-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Grounds in Place?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	General Comments		
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	General Comments		
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Foundation Condition	Good	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	General Comments		
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Follow-up Action Required?	n	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	General Comments		
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Operations This Read AM	0	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Operations Counter AL	197	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	BK001352	BreakerVacuum	FM-12KV TR 1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	LT0292	WithLTC	FM-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Operations Counter AF	197	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Amps C Ø	0.0	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Amps B Ø	0.0	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Maintenance Operations	0	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Amps A Ø	0.0	
9/16/2020 14:25	Distribution	Solite Quarterly Inspection	YD000672	Yard	SL-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0849	BreakerAirMagnetic	SN-SEC 2 SPARE	AMCB Readings	9 Months Operations	0	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/16/2020 14:17	Distribution	Fairmount Quarterly Inspection	YD000612	Yard	FM-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	CH000013	ControlHouse	301-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Operations A Ø	2	
9/16/2020 13:59	Distribution	Shawnee Quarterly Inspection	LB0844	BreakerAirMagnetic	SN-1	AMCB Readings	Fault Operations B Ø	0	
9/16/2020 15:30	Distribution	Big Stone Gap Quarterly Inspection	BK001583	BreakerVacuum	301-4703	VCB Readings	Fault Operations Ground	0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Unknown Operations	0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Tank Paint Condition	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Switching Operations	4	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	General Comments		
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Grounds in Place?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Foundation Condition	Good	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Follow-up Action Required?	n	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BCH000580	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	LTC Current Tap Position	6L	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BCH000580	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	PF000087	PowerFuse	CL-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BCH000580	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BCH000580	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	PF000087	PowerFuse	CL-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Bushing Condition	Good	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	LTC As Left Counter	223331	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	LTC As Found Counter	223331	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	General Comments		
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Operations Counter AF	210	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Maintenance Operations	0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.7	amps
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	BCH001159	Charger	799-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Grounds in Place?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	General Comments		
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	General Comments		
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Foundation Condition	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Follow-up Action Required?	n	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Fault Operations Ground	0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Fault Operations C ∅	0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Fault Operations B ∅	0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Fault Operations A ∅	0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Patrol Inspection	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0220	BreakerAirMagnetic	CL-GND TR 3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	BCH000475	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	BCH000475	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Amps A ∅	730.0	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	BCH000475	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Amps B ∅	739.0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Amps C ∅	742.0	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	BCH000475	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Bushing Condition	Good	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Fault Operations A ∅	0	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Fault Operations B ∅	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Fault Operations C Ø	0	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Fault Operations Ground	0	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	LTC As Found Counter	197071	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	LTC As Left Counter	197071	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	LTC Current Tap Position	12L	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	LTC Max Tap Position	1L	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	LTC Min Tap Position	13L	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1397	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Unknown Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Switching Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Operations This Read AM	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Operations Counter AL	318	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Operations Counter AF	318	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Readings	General Comments		
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	3	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	Follow-up Action Required?	n	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	General Comments		
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	77	°F
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	9 Month Operations	26	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Mechanism Patrol Inspection	General Comments		
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Operations This Read Vac	4	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Operations Counter AL	204	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Operations Counter AF	200	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Patrol Inspection	General Comments		
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Switching Operations	1	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Maintenance Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Patrol Inspection	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Fault Operations Ground	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Fault Operations C Ø	0	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	LTC As Found Counter	5069	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	LTC As Left Counter	5069	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	LTC Current Tap Position	2L	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	LTC Max Tap Position	1L	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Fault Operations B Ø	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Fault Operations A Ø	0	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	LTC Min Tap Position	6L	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	LTC Operations Since Last Insp	529	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	9 Month Operations	24	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	General Comments		
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Maintenance Operations	0	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Operations Counter AF	147	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Operations Counter AL	147	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Operations This Read Vac	0	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Switching Operations	0	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	BCH000475	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	BCH000475	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	9 Month Operations	2	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	300.0	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	440.0	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	340.0	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	Oil Temp Present	50	°C
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	Oil Temp Max	60	°C
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	LTC Totalizer Reading	5817.60	kw
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CX0108	RecloserElectronic	611-2433	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	General Comments		
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	General Comments		
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	General Comments		
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Switching Operations	0	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Operations This Read AM	0	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Operations Counter AL	448	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Operations Counter AF	448	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Maintenance Operations	0	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	General Comments		
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	General Comments		
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Amps C Ø	250.0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Amps B Ø	260.0	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	General Comments		
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Patrol Inspection	General Comments		
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	5	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Follow-up Action Required?	n	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Amps A Ø	270.0	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	187	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	185	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	9	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Operations This Read Vac	5	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Operations Counter AL	184	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Operations Counter AF	179	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Maintenance Operations	0	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Maintenance Operations	0	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Grounds in Place?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Unknown Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Switching Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Operations This Read AM	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Operations Counter AL	318	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Operations Counter AF	318	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Maintenance Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Patrol Inspection	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Amps C Ø	307.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Amps B Ø	331.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Amps A Ø	321.0	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Foundation Condition	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Follow-up Action Required?	n	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Unknown Operations	0	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Fault Operations Ground	0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Operations Counter AF	18463	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Operations Counter AL	18463	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Operations This Read AM	0	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	General Comments		
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Vegetation	None	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Switching Operations	1	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	30.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Tank Paint Condition	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Switching Operations	5	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BCH000580	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	60	°C
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	80	°F
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	9 Month Operations	1	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	Oil Temp Present	55	°C
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	Oil Temp Max	70	°C
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1800	psi
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.4	psi
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	2	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	40	°C
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	66	°C
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	50	°C
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	60	°C
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	60	°C
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Tank Paint Condition	Good	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Unknown Operations	0	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	BAT001365	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Unknown Operations	0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Patrol Inspection	Tank Paint Condition	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Switching Operations	0	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	9 Months Operations	1	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Bushing Condition	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Amps C Ø	22.0	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Amps B Ø	24.0	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Amps A Ø	22.0	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	9 Month Operations	2	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Operations This Read Vac	0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Operations Counter AL	210	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	301	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Unknown Operations	0	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BCH000580	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	LTC Min Tap Position	9L	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BCH001343	Charger	690-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BCH001343	Charger	690-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BCH001343	Charger	690-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BCH001343	Charger	690-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BCH001343	Charger	690-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BCH001343	Charger	690-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BCH001343	Charger	690-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BCH001343	Charger	690-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Counter Readings	LTC Max Tap Position	4L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	General Comments	Pump 1 failure light on Ann in CCC is not working, changed bulb and still nothing	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Amps A Ø	98.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Amps B Ø	87.0	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Amps C Ø	86.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0057	WithLTC	CL-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	BB0220	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LTCC000658	LTCControl	CL-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LTCC000658	LTCControl	CL-TRANS 3	LTC Control Insp	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LTCC000658	LTCControl	CL-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	188	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	188	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	General Comments		
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	CH000443	ControlHouse	SE-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0842	BreakerAirMagnetic	SE-SEC-1 SPARE	AMCB Readings	9 Months Operations	0	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN66	LTCMechanism	SE-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Operations This Read Vac	1	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Operations Counter AL	169	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Operations Counter AF	168	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	9 Month Operations	1	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Fault Operations C Ø	0	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Fault Operations B Ø	0	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Fault Operations A Ø	0	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	1099	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	32	°C
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	51	°C
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	LTC Min Tap Position	3R	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	LTC Max Tap Position	12R	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	LTC Current Tap Position	2L	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	LTC As Left Counter	31246	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	LTC As Found Counter	31246	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	Totalizer Meter Reading	.6060	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LTCM000040	LTCMechanism	CL-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0010	BreakerVacuum	799-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BCH000580	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0207	BreakerAirMagnetic	CL-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Grounds in Place?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	General Comments		
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	General Comments		
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Fault Operations A Ø	0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Fault Operations B Ø	0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Fault Operations C Ø	0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Fault Operations Ground	0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Foundation Condition	Good	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Follow-up Action Required?	n	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Foundation Condition	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	General Comments		
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	General Comments		
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Grounds in Place?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Maintenance Operations	0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	General Comments		
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	FE000458	Fence	681-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Follow-up Action Required?	n	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Vegetation	None	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Fault Operations Ground	0	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Fault Operations C Ø	0	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	124	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Amps C Ø	460.0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Amps B Ø	450.0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Amps A Ø	450.0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000206	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.9	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	General Comments		
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Operations This Read Vac	1	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Operations Counter AL	182	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Vegetation	None	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Operations Counter AF	181	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Maintenance Operations	0	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Patrol Inspection	Bushing Condition	Good	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Amps C Ø	143.0	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Amps B Ø	140.0	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Amps A Ø	141.0	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	LTC As Left Counter	128286	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	LTC As Found Counter	128282	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	General Comments		
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	General Comments		
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	Follow-up Action Required?	n	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	General Comments		
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Vegetation	None	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	9 Month Operations	1	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Fault Operations B Ø	0	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Fault Operations A Ø	0	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001116	BreakerVacuum	811-2417	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Ambient Temp	76	°F
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	YD000464	Yard	681-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Ambient Temp	76	*F
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	LTC Operations Since Last Insp	1385	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	50	°C
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	50	°C
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	LTC Min Tap Position	2L	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	LTC Max Tap Position	10L	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	C0489	LTCMechanism	611-1	LTC Counter Readings	LTC Current Tap Position	2R	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	General Comments		
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	YD000362	Yard	690-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	9 Month Operations	8	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Amps A Ø	240.0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Amps B Ø	240.0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Amps C Ø	240.0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Bushing Condition	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	YD000556	Yard	811-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	LTC Operations Since Last Insp	1687	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	LTC Min Tap Position	2L	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	LTC Max Tap Position	8L	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	General Comments		
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Max Tap Position	Neutral	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Min Tap Position	5L	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	LTC Current Tap Position	1L	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	LTC As Left Counter	20051	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	LTC As Found Counter	20048	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Mechanism Patrol Inspection	General Comments		
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	General Comments		
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	BCH001362	Charger	681-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	BCH001362	Charger	681-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	BCH001362	Charger	681-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.2	amps
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	BCH001362	Charger	681-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	BCH001362	Charger	681-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	BCH001229	Charger	SE-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.6	VDC
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	BCH001362	Charger	681-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	BCH001229	Charger	SE-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.6	VDC
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	BCH001229	Charger	SE-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	BAT001286	Battery	SE-Battery Bank	Battery Patrol Inspection	General Comments		
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Regulator As Left Counter	10629	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000098	Regulator	690-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Grounds in Place?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	BCH001229	Charger	SE-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	BCH001229	Charger	SE-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	BCH001229	Charger	SE-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	General Comments		
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	General Comments		
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	LTC As Found Counter	319618	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	LTC As Left Counter	319618	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6L	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	LTC Max Tap Position	5L	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	LTC Min Tap Position	9L	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN63	LTCMechanism	SE-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	298	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	FE000363	Fence	796-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Ambient Temp	80	*F
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	General Comments		
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Min Tap Position	4L	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	General Comments		
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Bushing Condition	Good	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	ST000365	Structure	690-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	General Comments		
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	BAT001286	Battery	SE-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	BAT001286	Battery	SE-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	BAT001286	Battery	SE-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Regulator As Left Counter	14010	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	General Comments		
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	General Comments		
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Foundation Condition	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Follow-up Action Required?	n	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Fault Operations Ground	0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Fault Operations C Ø	0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Fault Operations B Ø	0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Fault Operations A Ø	0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000097	Regulator	690-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000206	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000206	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	B0307	LTCMechanism	681-1	LTC Counter Readings	Follow-up Action Required?	n	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000206	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000206	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	YD000513	Yard	799-Yard	Yard Patrol Inspection	Ambient Temp	78	*F
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	BAT001286	Battery	SE-Battery Bank	Battery Patrol Inspection	Battery Bank Volts	26.6	VDC
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	BAT001286	Battery	SE-Battery Bank	Battery Patrol Inspection	Battery Bank Amps	0.0	AMPS
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	LTC Min Tap Position	Neutral	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	45	*C
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	60	*C
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	LTC Operations Since Last Insp	872	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Unknown Operations	0	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Tank Paint Condition	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Switching Operations	0	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Operations This Read Vac	0	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Operations Counter AL	279	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Operations Counter AF	278	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	Follow-up Action Required?	n	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	Winding Temp Present	0	°C
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Maintenance Operations	0	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Grounds in Place?	y	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	General Comments		
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	General Comments		
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Foundation Condition	Good	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Follow-up Action Required?	n	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	Winding Temp Max	0	°C
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	Totalizer Meter Reading	1.1282	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Fault Operations Ground	0	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Fault Operations C Ø	0	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Fault Operations B Ø	0	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	Totalizer Meter Reading	.7548	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	C0489	WithLTC	611-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	9 Months Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Amps A Ø	0.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Amps B Ø	0.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Amps C Ø	0.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0197	BreakerAirMagnetic	CL-1225	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0057	LTCMechanism	CL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	Follow-up Action Required?	n	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	General Comments		
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	General Comments		
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	LTC As Found Counter	27630	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	LTC As Left Counter	27633	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	LTC Current Tap Position	Neutral	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	B0443	LTCMechanism	611-2	LTC Counter Readings	LTC Max Tap Position	Neutral	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	Totalizer Meter Reading	.7854	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	BCH001362	Charger	681-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Fault Operations A Ø	0	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Bushing Condition	Good	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Amps C Ø	51.0	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Amps B Ø	49.0	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Amps A Ø	44.0	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Operations This Read Vac	1	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Switching Operations	1	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Tank Paint Condition	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Unknown Operations	0	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Fault Operations B Ø	0	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Fault Operations C Ø	0	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Fault Operations Ground	0	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Follow-up Action Required?	n	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	124	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Amps A Ø	124.0	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Readings	Unknown Operations	0	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000386	BreakerVacuum	611-2435	VCB Patrol Inspection	Tank Paint Condition	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0372	LTCMechanism	690-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Fault Operations A Ø	0	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0163	BreakerVacuum	681-2442	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	Oil Temp Present	42	°C
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	Oil Temp Max	68	°C
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	General Comments		
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	General Comments		
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	LTC Totalizer Reading	7539.84	kw
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	LTC Totalizer Reading	5415.36	kw
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	General Comments		
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	General Comments		
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	Oil Temp Max	54	°C
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	Oil Temp Present	45	°C
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	B0307	WithLTC	681-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Amps B Ø	100.0	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Amps A Ø	100.0	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	9 Months Operations	40	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Maintenance Operations	0	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Grounds in Place?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Operations Counter AF	249	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Readings	Operations Counter AL	250	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	General Comments		
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Patrol Inspection	Tank Paint Condition	Good	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	General Comments		
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Fault Operations B Ø	0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Fault Operations C Ø	0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Fault Operations Ground	0	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Foundation Condition	Good	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Follow-up Action Required?	n	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Fault Operations Ground	0	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Fault Operations C Ø	0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Follow-up Action Required?	n	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Foundation Condition	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	General Comments		
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	General Comments		
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Bushing Condition	Good	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Fault Operations B Ø	0	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Fault Operations A Ø	0	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Bushing Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	BCH001362	Charger	681-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Foundation Condition	Good	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	BCH000477	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	BCH000477	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	BCH000477	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	BCH000477	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Fault Operations A Ø	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	PF000085	PowerFuse	CL-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	PF000085	PowerFuse	CL-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	General Comments		
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK001115	BreakerVacuum	811-2418	VCB Readings	Unknown Operations	0	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0295	BreakerVacuum	799-2468	VCB Readings	9 Month Operations	9	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	68	°F
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	BAT001172	Battery	569-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	ST000314	Structure	569-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000206	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000206	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000206	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000206	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Unknown Operations	0	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Tank Paint Condition	Good	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Switching Operations	1	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Operations This Read Vac	1	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Operations Counter AL	367	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Operations Counter AF	366	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0007	BreakerVacuum	799-2476	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0838	BreakerAirMagnetic	SE-3	AMCB Readings	Amps C Ø	80.0	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0218	BreakerAirMagnetic	CL-14KV TR 3	AMCB Patrol Inspection	General Comments		
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	General Comments		
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	FE000521	Fence	811-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	YD000369	Yard	796-Yard	Yard Patrol Inspection	Vegetation	None	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Patrol Inspection	Bushing Condition	Good	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Amps C Ø	132.0	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	K0164	BreakerVacuum	681-2443	VCB Readings	Amps B Ø	120.0	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	SWG000084	Switchgear	SE-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Grounds in Place?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Patrol Inspection	Heaters (All) Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0294	BreakerVacuum	799-2474	VCB Readings	Maintenance Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	General Comments		
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Grounds in Place?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Radiator Leaks	None	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	B0443	WithLTC	611-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Tank Leaks	None	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	Follow-up Action Required?	n	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	General Comments		
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	General Comments		
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	LTC Totalizer Reading	7246.08	kw
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	Oil Temp Max	65	°C
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0372	WithLTC	690-2	LTC Transformer Readings	Oil Temp Present	45	°C
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0297	GroundTransformer	CL-GND TR 3	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Amps C Ø	10.0	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Amps B Ø	10.0	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Amps A Ø	40.0	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	9 Months Operations	1	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Regulator As Left Counter	17590	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	General Comments		
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Unknown Operations	0	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Tank Paint Condition	Good	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Switching Operations	8	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Operations This Read Vac	8	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Operations Counter AL	273	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Operations Counter AF	265	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Maintenance Operations	0	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Grounds in Place?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	General Comments		
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Switching Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Operations This Read Vac	0	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	General Comments		
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BAT001464	Battery	690-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Operations Counter AL	69	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Operations Counter AF	69	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Maintenance Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Patrol Inspection	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Fault Operations Ground	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Fault Operations C Ø	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Fault Operations B Ø	0	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Fault Operations A Ø	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	General Comments		
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Vegetation	None	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	General Comments		
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Ambient Temp	68	*F
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	General Comments		
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Patrol Inspection	General Comments		
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0204	BreakerAirMagnetic	CL-1232	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Unknown Operations	0	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Switching Operations	0	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Operations This Read AM	0	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Operations Counter AL	431	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Operations Counter AF	431	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Maintenance Operations	0	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	General Comments		
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Patrol Inspection	General Comments		
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Follow-up Action Required?	n	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Fault Operations Ground	0	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Fault Operations C ∅	0	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Fault Operations B ∅	0	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Fault Operations A ∅	0	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0836	BreakerAirMagnetic	SE-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	FE000303	Fence	569-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	PF000083	PowerFuse	CL-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Min Tap Position	Neutral	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Max Tap Position	13R	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LTCC000540	LTCControl	CL-TRANS 5	LTC Control Insp	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LTCC000540	LTCControl	CL-TRANS 5	LTC Control Insp	General Comments	ok	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	General Comments		
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LTCC000541	LTCControl	CL-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LTCC000541	LTCControl	CL-TRANS 2	LTC Control Insp	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LTCC000541	LTCControl	CL-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	General Comments		
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Foundation Condition	Good	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Follow-up Action Required?	n	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Fault Operations Ground	0	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Fault Operations C ∅	0	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Fault Operations B ∅	0	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Fault Operations A ∅	0	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Unknown Operations	0	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Tank Paint Condition	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Switching Operations	1	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Operations This Read Vac	1	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Operations Counter AL	168	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Operations Counter AF	168	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Maintenance Operations	0	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Grounds in Place?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	PF000083	PowerFuse	CL-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	General Comments		
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	PF000084	PowerFuse	CL-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	PF000084	PowerFuse	CL-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Patrol Inspection	Bushing Condition	Good	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Amps C Ø	80.0	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Amps B Ø	80.0	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Amps A Ø	80.0	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	MegaVar Demand Meter Max	.10	MegaVars
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	MegaVar Demand Meter Min	-.10	MegaVars
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	MegaWatt Demand Meter Max	2.10	MegaWatts
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	MegaWatt Demand Meter Min	.40	MegaWatts
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Min Tap Position	2L	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Max Tap Position	9R	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	Oil Temp Max	45	°C
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	Oil Temp Present	25	°C
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BCH001254	Charger	811-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Amps C Ø	259.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Amps B Ø	237.0	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	General Comments		
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Current Tap Position	4R	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000008	Regulator	796-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Amps A Ø	227.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	General Comments		
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	76	*F
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BAT001115	Battery	611-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Regulator As Left Counter	21182	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Bushing Condition	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Amps C Ø	17.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Amps B Ø	0.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0217	BreakerAirMagnetic	CL-1407	AMCB Patrol Inspection	General Comments		
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Amps A Ø	17.0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	9 Month Operations	2	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000058	Switchgear	CL-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	9 Month Operations	4	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Amps A Ø	141.0	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Amps B Ø	140.0	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Amps C Ø	143.0	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Bushing Condition	Good	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Fault Operations A Ø	0	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Fault Operations B Ø	0	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Fault Operations C Ø	0	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Fault Operations Ground	0	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	General Comments		
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000266	LTCControl	799-2	LTC Control Insp	VRR Time Delay	30	Seconds
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000266	LTCControl	799-2	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000266	LTCControl	799-2	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000266	LTCControl	799-2	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000266	LTCControl	799-2	LTC Control Insp	LTC Output Voltage Level	124.7	VAC
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	LTCC000325	LTCControl	920-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	LTCC000325	LTCControl	920-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	LTCC000325	LTCControl	920-Offline-Distribution	LTC Control Insp	General Comments		
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	LTCC000325	LTCControl	920-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	LTCC000325	LTCControl	920-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000266	LTCControl	799-2	LTC Control Insp	LTC Operation Checked?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000266	LTCControl	799-2	LTC Control Insp	General Comments		
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000266	LTCControl	799-2	LTC Control Insp	Follow-up Action Required?	n	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	LTCC000266	LTCControl	799-2	LTC Control Insp	All Connections OK?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Vegetation	None	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	Need size info and qty
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	140.0	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	140.0	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	140.0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Operations Counter AF	177	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Maintenance Operations	0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	General Comments		
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Ambient Temp	70	*F
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Grounds in Place?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	General Comments		
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	General Comments		
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Foundation Condition	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Follow-up Action Required?	n	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Fault Operations Ground	0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Fault Operations C Ø	0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Fault Operations B Ø	0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Fault Operations A Ø	0	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Fault Operations A Ø	0	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Fault Operations B Ø	0	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Fault Operations C Ø	0	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Follow-up Action Required?	n	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Foundation Condition	Good	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	General Comments		
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	General Comments		
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Grounds in Place?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Maintenance Operations	0	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Operations Counter AF	179	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Operations Counter AL	183	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Operations This Read Vac	4	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Switching Operations	4	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	General Comments		
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Tank Paint Condition	Good	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Unknown Operations	0	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	General Comments		
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	6	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	465	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	467	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	2	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	2	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	YD000307	Yard	569-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	ST000467	Structure	681-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Follow-up Action Required?	n	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Foundation Condition	Good	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	General Comments		
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Grounds in Place?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Maintenance Operations	0	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Operations Counter AF	188	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Operations Counter AL	189	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Operations This Read Vac	1	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Switching Operations	1	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Patrol Inspection	Tank Paint Condition	Good	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BK000845	BreakerVacuum	811-2420	VCB Readings	Unknown Operations	0	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	9 Month Operations	5	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	60.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	60.0	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	60.0	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0203	BreakerAirMagnetic	CL-1231	AMCB Patrol Inspection	General Comments		
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0085	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Amps A Ø	76.0	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Amps B Ø	87.0	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Readings	Amps C Ø	62.0	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Bushing Condition	Good	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	KB0127	BreakerVacuum	811-2419	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	9 Months Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Amps A Ø	0.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Amps B Ø	0.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Amps C Ø	0.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Fault Operations A Ø	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Fault Operations B Ø	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Fault Operations C Ø	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Fault Operations Ground	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Patrol Inspection	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Maintenance Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Operations Counter AF	742	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Operations Counter AL	742	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Operations This Read AM	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Switching Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0216	BreakerAirMagnetic	CL-1406	AMCB Readings	Unknown Operations	0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	General Comments		
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	9 Month Operations	8	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	General Comments		
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	General Comments		
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2720.00	kw
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Unknown Operations	0	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Patrol Inspection	General Comments		
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	480.0	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	480.0	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	480.0	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	2	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001059	BreakerVacuum	CL-1230	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	X1 Winding Temp Max	65	°C
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	X1 Winding Temp Present	55	°C
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	X2 Winding Temp Max	70	°C
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	X2 Winding Temp Present	45	°C
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	X3 Winding Temp Max	70	°C
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	X3 Winding Temp Present	40	°C
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	LTC Operations Since Last Insp	1832	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	LTC Min Tap Position	16L	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	LTC Max Tap Position	1R	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	LTC Current Tap Position	13L	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	LTC As Left Counter	208112	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	LTC As Found Counter	208112	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Mechanism Patrol Inspection	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	General Comments		
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0056	LTCMechanism	CL-TRANS 5	LTC Counter Readings	Follow-up Action Required?	n	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Patrol Inspection	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001058	BreakerVacuum	CL-1228	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Patrol Inspection	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001057	BreakerVacuum	CL-1227	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CH000351	ControlHouse	799-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	Oil Temp Present	45	°C
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Fault Operations A Ø	0	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Fault Operations B Ø	0	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Fault Operations C Ø	0	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Fault Operations Ground	0	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Follow-up Action Required?	n	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Foundation Condition	Good	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	General Comments		
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	General Comments		
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Grounds in Place?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Maintenance Operations	0	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Operations Counter AF	225	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Operations Counter AL	229	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Operations This Read Vac	4	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Switching Operations	4	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Tank Paint Condition	Good	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Unknown Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Panels Dusted?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	9 Months Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Evidence of Insects	None	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000060	Switchgear	CL-Swgr Sec 5	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2830.08	kw
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	General Comments		
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	General Comments		
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1000	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Regulator As Left Counter	19644	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Min Tap Position	4L	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Max Tap Position	13R	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	General Comments		
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Operations This Read AM	0	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Operations Counter AL	99950	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Operations Counter AF	99950	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	General Comments		
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Patrol Inspection	General Comments		
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Follow-up Action Required?	n	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0843	BreakerAirMagnetic	SE-SEC-2 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Patrol Inspection	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Amps A Ø	10.0	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Amps B Ø	10.0	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Amps C Ø	10.0	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Current Tap Position	5R	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Bushing Condition	Good	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000006	Regulator	796-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	0982	NonLTC	796-1	NonLTC Transformer Readings	Totalizer Meter Reading	2.7200	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0045	BreakerVacuum	569-0880	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001056	BreakerVacuum	CL-1226	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	FE000508	Fence	799-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	Totalizer Meter Reading	.8844	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	B0230	NonLTC	690-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Unknown Operations	1	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Switching Operations	0	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	PF000089	PowerFuse	CL-STA SER NO 5	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	PF000089	PowerFuse	CL-STA SER NO 5	Disconnect Powerfuse Inspection	General Comments	ok	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	PF000090	PowerFuse	CL-12KV TR 5 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	PF000090	PowerFuse	CL-12KV TR 5 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	LTC Operations Since Last Insp	694	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	LTC Min Tap Position	11L	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	LTC Max Tap Position	4L	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	LTC Current Tap Position	8L	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	LTC As Left Counter	73392	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	LTC As Found Counter	73392	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Mechanism Patrol Inspection	General Comments		
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	General Comments		
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Counter Readings	Follow-up Action Required?	n	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Operations This Read Vac	1	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Operations Counter AL	71	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	LTCC000788	LTCControl	681-1	LTC Control Insp	General Comments		
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	LTCC000788	LTCControl	681-1	LTC Control Insp	LTC Operation Checked?	y	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	LTCC000788	LTCControl	681-1	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	LTCC000788	LTCControl	681-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	LTCC000788	LTCControl	681-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	LTCC000788	LTCControl	681-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Bushing Condition	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Amps C Ø	22.0	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Amps B Ø	24.0	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Amps A Ø	22.0	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Operations Counter AF	71	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Maintenance Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Patrol Inspection	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Fault Operations Ground	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Fault Operations C Ø	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Fault Operations B Ø	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Fault Operations A Ø	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps C Phase V	27.00	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	K0032	BreakerVacuum	569-0881	VCB Readings	9 Month Operations	8	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001061	BreakerVacuum	CL-12KV TR 5	VCB Readings	9 Month Operations	2	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	110.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	50.0	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	60.0	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	General Comments		
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	ST000518	Structure	799-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	General Comments		
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	LTC Totalizer Reading	2695.68	kw
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Follow-up Action Required?	n	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Fault Operations Ground	0	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Fault Operations C Ø	0	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Fault Operations B Ø	0	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Fault Operations A Ø	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	PF000086	PowerFuse	CL-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	Oil Temp Max	55	°C
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	Oil Temp Present	45	°C
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	PF000086	PowerFuse	CL-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	PF000088	PowerFuse	CL-14KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	PF000088	PowerFuse	CL-14KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	LTCC000788	LTCControl	681-1	LTC Control Insp	All Connections OK?	y	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	LTCC000788	LTCControl	681-1	LTC Control Insp	Follow-up Action Required?	n	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	B0416	LTCMechanism	569-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	B0416	WithLTC	569-1	LTC Transformer Readings	Totalizer Meter Reading	.2808	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	General Comments	CCC door seal needs to be replaced	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	9 Month Operations	0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Amps A Ø	640.0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Amps B Ø	640.0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Amps C Ø	640.0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Bushing Condition	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Fault Operations A Ø	0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Fault Operations B Ø	0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Fault Operations C Ø	0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Fault Operations Ground	0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Follow-up Action Required?	n	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Foundation Condition	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	General Comments		
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	General Comments		
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Grounds in Place?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Maintenance Operations	0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Operations Counter AF	99946	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Operations Counter AL	99946	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Operations This Read Vac	0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Readings	Switching Operations	0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	CB0263	BreakerVacuum	799-1	VCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	Oil Temp Max	60	°C
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	BK000412	BreakerVacuum	611-2432	VCB Readings	9 Month Operations	2	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	Oil Temp Present	45	°C
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	CB0181	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Current Tap Position	8R	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	RG000007	Regulator	796-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps B Phase V	27.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Fault Adjusted Amps A Phase V	27.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Amps C Ø	0.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Amps B Ø	0.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Amps A Ø	0.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	BK001060	BreakerVacuum	CL-12KV BUS TIE SEC 5	VCB Readings	9 Month Operations	4	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	General Comments		
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	General Comments		
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	General Comments		
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	LTC Totalizer Reading	14655.60	kw
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	Oil Temp Max	42	°C
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	Oil Temp Present	42	°C
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	Totalizer Meter Reading	.8142	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	Winding Temp Max	42	°C
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	Winding Temp Present	42	°C
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	WithLTC	799-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Readings	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0056	WithLTC	CL-TRANS 5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0215	BreakerAirMagnetic	CL-1405	AMCB Patrol Inspection	General Comments		
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	6	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	224	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	226	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	2	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	2	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0076	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	10.0	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	10.0	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	Oil Temp Max	75	°C
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	LTC Totalizer Reading	14072.40	kw
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	General Comments		
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	General Comments		
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	10.0	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Vegetation	None	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	100.00	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	Winding Temp Present	45	°C
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	Winding Temp Max	65	°C
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	Totalizer Meter Reading	.7818	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	Oil Temp Max	40	°C
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Max Tap Position	6R	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Min Tap Position	4L	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	291	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	295	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	WithLTC	811-1	LTC Transformer Readings	Oil Temp Present	45	°C
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Amps C Ø	0.0	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	Positive DC Ground	18.0	VDC
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	Negative DC Ground	40.0	VDC
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	General Comments		
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Bushing Condition	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	76	*F
9/15/2020 14:17	Distribution	Munfordville Quarterly Inspection	BAT001454	Battery	681-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	LTCC000770	LTCControl	690-2	LTC Control Insp	VRR Time Delay	30	Seconds
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	LTCC000770	LTCControl	690-2	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	LTCC000770	LTCControl	690-2	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	LTCC000770	LTCControl	690-2	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	LTCC000770	LTCControl	690-2	LTC Control Insp	LTC Operation Checked?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	LTCC000770	LTCControl	690-2	LTC Control Insp	General Comments		
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	LTCC000770	LTCControl	690-2	LTC Control Insp	Follow-up Action Required?	n	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	LTCC000770	LTCControl	690-2	LTC Control Insp	All Connections OK?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	LTCC000769	LTCControl	569-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	LTCC000769	LTCControl	569-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Regulator As Left Counter	18560	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	120.0	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	120.0	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	120.0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	LTC Operations Since Last Insp	3502	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	60	*C
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	60	*C
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	LTC Min Tap Position	Neutral	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	LTC Max Tap Position	16R	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	9 Month Operations	3	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Amps A Ø	0.0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Amps B Ø	0.0	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	General Comments		
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	Oil Temp Present	20	°C
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	General Comments		
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Maintenance Operations	0	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Operations Counter AF	312	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Operations Counter AL	312	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Operations This Read AM	0	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Switching Operations	0	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Unknown Operations	0	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	2	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	2	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	254	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	252	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	6	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Patrol Inspection	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0201	BreakerAirMagnetic	CL-1229	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	General Comments		
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	General Comments		
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Current Tap Position	2R	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	Percent Thermal Load B Ø Max	-60	%
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	RG000014	Regulator	690-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Follow-up Action Required?	n	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Patrol Inspection	General Comments		
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	General Comments		
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Maintenance Operations	0	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Operations Counter AF	302	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	76	°F
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Operations Counter AL	302	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Operations This Read AM	0	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Switching Operations	0	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	9 Months Operations	1	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Operations Ground	0	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Operations C Ø	0	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Operations B Ø	0	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	General Comments		
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Operations A Ø	0	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Negative DC Ground	23.0	VDC
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Positive DC Ground	22.0	VDC
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	BAT001386	Battery	811-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Amps C Ø	30.0	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Amps B Ø	40.0	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Amps A Ø	50.0	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	9 Months Operations	1	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Interrupts/Puffrs Visual OK?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Operations Ground	0	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	General Comments		
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Operations C Ø	0	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Operations A Ø	0	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Amps C Ø	50.0	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Amps B Ø	60.0	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Patrol Inspection	General Comments		
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0837	BreakerAirMagnetic	SE-2	AMCB Readings	Follow-up Action Required?	n	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	YD000434	Yard	611-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	LB0839	BreakerAirMagnetic	SE-4	AMCB Readings	Amps A Ø	50.0	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0019	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000059	Switchgear	CL-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	ST000560	Structure	811-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Fault Operations Ground	0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Unknown Operations	0	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	LTCC000714	LTCControl	611-2	LTC Control Insp	VRR Time Delay	30	Seconds
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	LTCC000714	LTCControl	611-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	LTCC000714	LTCControl	611-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	LTCC000714	LTCControl	611-2	LTC Control Insp	LTC Output Voltage Level	124.9	VAC
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	LTCC000714	LTCControl	611-2	LTC Control Insp	LTC Operation Checked?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	LTCC000714	LTCControl	611-2	LTC Control Insp	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Follow-up Action Required?	n	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Foundation Condition	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	General Comments		
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	General Comments		
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Grounds in Place?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000018	Switchgear	CL-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000018	Switchgear	CL-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000018	Switchgear	CL-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	LTC Max Tap Position	7R	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	Follow-up Action Required?	n	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	General Comments		
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Mechanism Patrol Inspection	General Comments		
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	LTC As Found Counter	68735	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	LTC As Left Counter	68739	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Operations Counter AF	265	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Operations Counter AL	266	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Operations This Read Vac	1	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	10.0	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	10.0	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	10.0	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	General Comments		
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/15/2020 7:41	Distribution	Falmouth Quarterly Inspection	ST000371	Structure	796-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Fault Operations A Ø	0	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	152	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	156	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Fault Operations B Ø	0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Fault Operations C Ø	0	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	LTCC000325	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	LTCC000325	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	LTCC000325	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	133	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	129	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	8	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	LTC Current Tap Position	2R	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	LTC As Left Counter	49825	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	LTC As Found Counter	49822	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	General Comments		
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	General Comments		
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	8	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	General Comments		
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	General Comments		
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Min	1.40	MegaWatts
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Max	1.00	MegaWatts
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Max	.20	MegaVars
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN63	WithLTC	SE-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Min	0.00	MegaVars
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	LTC Current Tap Position	7L	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	LTCC000714	LTCControl	611-2	LTC Control Insp	Follow-up Action Required?	n	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	LTCC000714	LTCControl	611-2	LTC Control Insp	All Connections OK?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	LTCC000713	LTCControl	611-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	LTCC000713	LTCControl	611-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	LTCC000713	LTCControl	611-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	Oil Temp Present	46	°C
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	Oil Temp Max	61	°C
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Patrol Inspection	Tank Paint Condition	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Switching Operations	1	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Operations This Read Vac	1	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0116	BreakerVacuum	799-2469	VCB Readings	Operations Counter AL	178	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	4	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	LTCC000713	LTCControl	611-1	LTC Control Insp	LTC Output Voltage Level	123.7	VAC
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	LTCC000713	LTCControl	611-1	LTC Control Insp	LTC Operation Checked?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	LTCC000713	LTCControl	611-1	LTC Control Insp	General Comments		
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	LTCC000713	LTCControl	611-1	LTC Control Insp	Follow-up Action Required?	n	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	LTCC000713	LTCControl	611-1	LTC Control Insp	All Connections OK?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	LTC Max Tap Position	11L	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Switching Operations	1	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Tank Paint Condition	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Unknown Operations	0	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	LTC Min Tap Position	Neutral	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	LTC Operations Since Last Insp	327	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/15/2020 14:05	Distribution	Elizabethtown 4 Quarterly Inspection	C0461	LTCMechanism	811-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	BAT001212	Battery	799-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	YD000574	Yard	SE-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	4	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	SWG000018	Switchgear	CL-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	LTC Current Tap Position	10R	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Grounds in Place?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Maintenance Operations	0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Operations Counter AF	267	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Operations Counter AL	268	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Operations This Read Vac	1	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Switching Operations	1	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Tank Paint Condition	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Unknown Operations	0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	LTC As Left Counter	115413	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Counter Readings	LTC Operations Since Last Insp	1560	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	9 Month Operations	2	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Amps A Ø	471.0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Amps B Ø	460.0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Amps C Ø	472.0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Bushing Condition	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	S0016	LTCMechanism	799-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	40	°C
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	LTC As Found Counter	115410	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	General Comments		
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	General Comments		
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	LTCC000769	LTCControl	569-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	LTCC000769	LTCControl	569-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	LTCC000769	LTCControl	569-1	LTC Control Insp	LTC Operation Checked?	y	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	LTCC000769	LTCControl	569-1	LTC Control Insp	General Comments		
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	LTCC000769	LTCControl	569-1	LTC Control Insp	Follow-up Action Required?	n	
9/15/2020 14:07	Distribution	Cynthiana South Quarterly Inspection	LTCC000769	LTCControl	569-1	LTC Control Insp	All Connections OK?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	SWG000178	Switchgear	SE-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Fault Operations A Ø	0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Fault Operations B Ø	0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Fault Operations C Ø	0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Fault Operations Ground	0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	Follow-up Action Required?	n	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	Foundation Condition	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Patrol Inspection	General Comments		
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0009	BreakerVacuum	799-BT1-2	VCB Readings	General Comments		
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0005	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	General Comments		
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	FE000564	Fence	SE-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	120.0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	Totalizer Meter Reading	.8934	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	Winding Temp Max	80	°C
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	Winding Temp Present	55	°C
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	51	°C
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	General Comments		
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	66	°C
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	51	°C
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	66	°C
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	51	°C
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	65	°C
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	TX000075	WithLTC	CL-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	FE000430	Fence	611-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0243	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	8	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	BB0242	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KB0008	BreakerVacuum	799-2473	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	General Comments		
9/15/2020 14:36	Distribution	Cynthiana Quarterly Inspection	FE000379	Fence	690-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	8	
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	CB0158	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/15/2020 14:39	Distribution	Horse Cave Quarterly Inspection	ST000437	Structure	611-Structure	Structure Patrol Inspection	General Comments		
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	LTCMechanism	799-2	LTC Counter Readings	Follow-up Action Required?	n	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/15/2020 10:57	Distribution	Seventh Street Quarterly Inspection	PN66	WithLTC	SE-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	Follow-up Action Required?	n	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	General Comments		
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	General Comments		
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	LTC Totalizer Reading	16081.20	kw
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	Oil Temp Max	65	°C
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Readings	Oil Temp Present	60	°C
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/15/2020 15:08	Distribution	Horse Cave Industrial Quarterly Inspection	KT0012	WithLTC	799-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	3	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LB0803	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	General Comments		
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BCH000528	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BCH000528	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BCH000528	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BCH000528	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BCH000528	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BCH000528	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
6/9/2020 5:20	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	Follow-up Action Required?	n	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	CH000442	ControlHouse	PI-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	CH000442	ControlHouse	PI-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Operations Counter	0	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	CH000442	ControlHouse	PI-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	General Comments		
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	72	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	CH000442	ControlHouse	PI-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	General Comments		
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	CH000442	ControlHouse	PI-Battery Control House	Control House Patrol Inspection	Panel Lights OK?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	CH000442	ControlHouse	PI-Battery Control House	Control House Patrol Inspection	General Comments		
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	CH000442	ControlHouse	PI-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Fault Operations Ground	0	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Fault Operations C Ø	0	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Fault Operations B Ø	0	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Fault Operations A Ø	0	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	LTC Operations Since Last Insp	989	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	LTC Min Tap Position	Neutral	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	LTC As Left Counter	245675	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	LTC As Found Counter	245664	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	General Comments	Counter must have been wrote down wrong last time. (JB corrected 6/8/2020 counter as left)	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	Follow-up Action Required?	n	
6/9/2020 5:20	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
6/9/2020 5:20	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	LTC Operations Since Last Insp	897	
6/9/2020 5:20	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	LTC Min Tap Position	Neutral	
6/9/2020 5:20	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
6/9/2020 5:20	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
6/9/2020 5:20	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	LTC As Left Counter	244675	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
6/9/2020 5:20	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	LTC As Found Counter	244675	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	General Comments	Restroom has no water	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Trash Emptied?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	LTC As Found Counter	27846	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	LTC As Left Counter	27846	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	LTC Current Tap Position	2R	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	LTC Max Tap Position	2R	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	LTC Min Tap Position	2R	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	751	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0055	LTCMechanism	CL-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	49	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Amps A Ø	28.0	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Amps B Ø	22.0	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	Amps C Ø	26.0	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	BX0444	RecloserHydraulic	064-2400	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	76	
6/9/2020 5:20	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Counter Readings	General Comments	theres an order to replace the drag hand cable	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	9 Months Operations	1	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	HV Winding Temp Max	0	°C
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	HV Winding Temp Present	0	°C
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	Kwh Reading	0	kWh
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	LV Winding Temp Max	0	°C
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	LV Winding Temp Present	0	°C
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	MegaVar Demand Meter Max	0.00	MegaVars
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	MegaVar Demand Meter Min	0.00	MegaVars
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	MegaWatt Demand Meter Max	0.00	MegaWatts
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	MegaWatt Demand Meter Min	0.00	MegaWatts
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	400	psi
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	Oil Temp Max	60	°C
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	Oil Temp Present	40	°C
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	Percent Thermal Load A Ø Max	0	%
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Operations Counter	0	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Fault Operations C Ø	0	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Fault Operations Ground	0	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Follow-up Action Required?	n	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Amps C Ø	25.0	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	9 Month Operations	8	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	PF000271	PowerFuse	PI-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	PF000271	PowerFuse	PI-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Patrol Inspection	General Comments		
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	General Comments		
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Maintenance Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	PF000082	PowerFuse	CL-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	PF000082	PowerFuse	CL-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Operations Counter AF	284	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Operations Counter AL	284	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Operations This Read AM	0	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Switching Operations	0	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Unknown Operations	0	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	9 Month Operations	0	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Amps A Ø	22.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Amps B Ø	36.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	PF000270	PowerFuse	PI-4KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	PF000270	PowerFuse	PI-4KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	Oil Temp Present	45	°C
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	LV Winding Temp Present	20	°C
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	LV Winding Temp Max	30	°C
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	120	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Amps A Ø	14.5	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Amps B Ø	17.0	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Amps C Ø	16.0	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	255	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	9 Months Operations	0	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Amps A Ø	0.0	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Amps B Ø	0.0	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Amps C Ø	0.0	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Fault Operations A Ø	0	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	287	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	General Comments		
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0055	WithLTC	CL-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	General Comments	Every reading that has a 0 in it needs to be removed from insp.	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	General Comments	There are no surge arrester's on TR-2, counters need to be removed from insp.	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	H1 Winding Temp Max	0	°C
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	H1 Winding Temp Present	0	°C
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	H2 Winding Temp Max	63	°C
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	H2 Winding Temp Present	40	°C
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	H3 Winding Temp Max	0	°C
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	H3 Winding Temp Present	0	°C
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0787	BreakerAirMagnetic	PI-SEC 1 SPARE	AMCB Readings	Fault Operations B Ø	0	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	BX0834	RecloserHydraulic	064-2401	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Amps C Ø	80.0	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Amps B Ø	110.0	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Amps A Ø	60.0	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Accumulated Fault Duty A Ph V	1.31	%
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Fault Operations A Ø	0	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Fault Operations B Ø	0	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Fault Operations C Ø	0	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Fault Operations Ground	0	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Follow-up Action Required?	n	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Patrol Inspection	General Comments		
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	General Comments		
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Low	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Readings	Oil Temp Present	0	°C
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Readings	Oil Temp Max	10	°C
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	General Comments	tank oil level low	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Readings	General Comments		
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Maintenance Operations	0	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	641	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	45	°C
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	55	°C
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	LTC Min Tap Position	9L	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	LTC Max Tap Position	1L	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	LTC Current Tap Position	6L	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	LTC As Left Counter	162415	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	LTC As Found Counter	162415	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	General Comments		
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
6/9/2020 5:20	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	Oil Temp Present	37	°C
6/9/2020 5:20	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
6/9/2020 5:20	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	Totalizer Meter Reading	.0390	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
6/9/2020 5:20	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	200	
6/9/2020 5:20	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LT0250	GroundTransformer	CL-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	PF001256	PowerFuse	PL-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	PF001256	PowerFuse	PL-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	General Comments		
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	LTC Totalizer Reading	132.48	kw
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	Oil Temp Max	45	°C
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	Oil Temp Present	38	°C
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	Totalizer Meter Reading	.0414	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	200	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	General Comments		
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	LTC As Found Counter	23377	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	LTC As Left Counter	23377	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	LTC Current Tap Position	9L	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	LTC Max Tap Position	2L	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	LTC Min Tap Position	11L	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	9 Months Operations	2	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Amps A Ø	40.0	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Amps B Ø	30.0	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Amps C Ø	60.0	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	904	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LTCM000035	LTCMechanism	PL-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	PF000081	PowerFuse	CL-GND TR 1	Disconnect Powerfuse Inspection	General Comments	ok	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	PF000081	PowerFuse	CL-GND TR 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Vegetation	None	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	General Comments		
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	YD000599	Yard	PI-Yard	Yard Patrol Inspection	Ambient Temp	80	°F
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	General Comments		
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LTCC000489	LTCControl	CL-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LTCC000489	LTCControl	CL-TRANS 1	LTC Control Insp	General Comments	ok	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	General Comments		
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	FE000593	Fence	PL-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Ambient Temp	67	°F
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	ST000590	Structure	PL-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Vegetation	None	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	General Comments	Rain knocked trech covers out of place	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	YD000597	Yard	PL-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LT0282	LTCMechanism	PI-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	SWG000057	Switchgear	PL-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	PN65	WithLTC	PI-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Tank Leaks	None	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Regulator As Left Counter	117621	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Min Tap Position	7L	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Max Tap Position	3R	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	General Comments		
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Current Tap Position	2R	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0847	Regulator	064-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Tank Leaks	None	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Regulator As Left Counter	115229	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Operations Counter AF	99963	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.5	volts
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Min Tap Position	9L	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Max Tap Position	2L	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Operations Counter AL	99963	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	General Comments		
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Current Tap Position	3L	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0846	Regulator	064-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Operations This Read AM	0	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Switching Operations	0	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0786	BreakerAirMagnetic	PI-1	AMCB Readings	Unknown Operations	0	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Tank Leaks	None	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Accumulated Fault Duty B Ph V	1.31	%
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Accumulated Fault Duty C Ph V	1.31	%
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Amps A Ø	10.0	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Amps B Ø	10.0	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Amps C Ø	10.0	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Fault Adjusted Amps B Phase V	8.76	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1299	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	LTC Min Tap Position	8L	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Fault Operations A Ø	0	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Fault Operations B Ø	1	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	LTCC000923	LTCControl	512-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	LTCC000923	LTCControl	512-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1L	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	LTC Current Tap Position	5L	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	LTCC000923	LTCControl	512-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	LTCC000923	LTCControl	512-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	LTCC000923	LTCControl	512-1	LTC Control Insp	LTC Operation Checked?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	LTC As Left Counter	386913	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	LTC As Found Counter	386913	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Fault Operations C Ø	0	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Regulator As Left Counter	130825	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.6	volts
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	General Comments		
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Fault Operations Ground	0	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Follow-up Action Required?	n	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	General Comments		
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Maintenance Operations	0	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Operations Counter AF	68	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	PN65	LTCMechanism	PI-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	LTCC000923	LTCControl	512-1	LTC Control Insp	General Comments		
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	LTCC000923	LTCControl	512-1	LTC Control Insp	Follow-up Action Required?	n	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	LTCC000923	LTCControl	512-1	LTC Control Insp	All Connections OK?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Min Tap Position	4L	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Max Tap Position	6R	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	General Comments	control changed to LTCC000371 with a as left counter reading of 161.	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	Percent Thermal Load B Ø Max	0	%
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	Percent Thermal Load C Ø Max	0	%
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	Percent Thermal Load H2 Max	0	%
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	Percent Thermal Load X2 Max	0	%
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	Percent Thermal Load Y2 Max	0	%
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	1386.72	kw
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Oil Temp Max	47	°C
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Oil Temp Present	40	°C
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Totalizer Meter Reading	.5778	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Winding Temp Max	47	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Fault Operations A Ø	0	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Fault Operations B Ø	0	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Fault Operations C Ø	0	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Fault Operations Ground	0	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Follow-up Action Required?	n	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Foundation Condition	Good	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	TX000057	NonLTC	064-5	NonLTC Transformer Readings	Winding Temp Present	40	°C
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	General Comments		
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	General Comments		
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	LTC Totalizer Reading	3936.96	kw
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	Oil Temp Max	50	°C
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	Oil Temp Present	40	°C
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	Totalizer Meter Reading	.8202	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	B0340	WithLTC	512-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0209	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	42	°C
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	43	°C
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	52	°C
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	80	°C
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	Oil Temp Present	48	°C
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	Oil Temp Max	65	°C
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.8	psi
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments	No Breaker	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Unknown Operations	0	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Switching Operations	0	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Operations This Read Vac	0	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Operations Counter AL	99848	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Operations Counter AF	99848	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Maintenance Operations	0	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	General Comments		
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	General Comments		
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Foundation Condition	Good	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Follow-up Action Required?	n	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Fault Operations Ground	0	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Fault Operations C Ø	0	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Fault Operations B Ø	0	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Fault Operations A Ø	0	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
6/9/2020 5:20	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
6/9/2020 5:20	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	Follow-up Action Required?	n	
6/9/2020 5:20	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	General Comments		
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Amps C Ø	122.0	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Amps B Ø	93.0	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Amps A Ø	93.0	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1166	BreakerVacuum	PI-2	VCB Readings	9 Month Operations	0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	Y1 Winding Temp Max	0	°C
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	Y1 Winding Temp Present	0	°C
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	Y2 Winding Temp Max	0	°C
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	Y2 Winding Temp Present	0	°C
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	Y3 Winding Temp Max	0	°C
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	Y3 Winding Temp Present	0	°C
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	General Comments		
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Switching Operations	0	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Unknown Operations	0	
6/9/2020 5:20	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	LTC Totalizer Reading	124.80	kw
6/9/2020 5:20	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Readings	Oil Temp Max	40	°C
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2020 14:48	Distribution	Bonnieville Quarterly Inspection	R0848	Regulator	064-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Counter A Ø	0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Counter B Ø	0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Counter C Ø	0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Operations Counter AL	68	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Operations This Read Vac	2	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Switching Operations	1	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	52	°C
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	75	°C
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000114	LTCControl	PL-TRANS 1	LTC Control Insp	General Comments	OK	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000114	LTCControl	PL-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0162	WithLTC	PL-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	Top Oil Temperature Max	0	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	Top Oil Temperature Present	0	°C
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	Totalizer Meter Multiplier	0	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Unknown Operations	0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	TV Winding Temp Max	0	°C
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	TV Winding Temp Present	0	°C
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	General Comments		
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	General Comments		
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	Winding Temp Max	0	°C
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	Winding Temp Present	0	°C
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	65	°C
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	35	°C
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	35	°C
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	35	°C
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	72	°C
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	WithLTC	PL-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	40	°C
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Grounds in Place?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0212	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Maintenance Operations	0	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Operations Counter AF	40	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Operations Counter AL	40	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB1167	BreakerVacuum	PI-4	VCB Readings	Operations This Read Vac	0	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	CH000340	ControlHouse	512-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	General Comments		
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Bushings Connection/Risers	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Bushing Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Amps C Ø	0.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Amps B Ø	0.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Amps A Ø	0.0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Counter Readings	LTC Current Tap Position	6L	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Counter Readings	LTC Max Tap Position	3L	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Counter Readings	LTC Min Tap Position	8L	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	8.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	7.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	7.0	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	General Comments		
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Air Compressor Oil Status	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Air Leaks	None	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Air Pressure OK?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	AirCompressor Heater Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0214	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	0	°C
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	0	°C
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	67	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Tank 3 Oil Level	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Tank Leaks	None	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Tank Oil Level	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Tank Paint Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Unknown Operations	0	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Bushing Condition	Good	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Bushing Oil Level	Good	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Fault Operations	0	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Follow-up Action Required?	n	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Foundation Condition	Good	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Gauge(s) Condition	Good	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	General Comments		
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	General Comments		
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Patrol Inspection	Bushing Condition	Good	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	General Comments		
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Patrol Inspection	Foundation Condition	Good	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	General Comments	Open	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments	The 12KV BUS TIE PCB, is not a outdoor breaker, it's a roll in PCB, in a SWGR	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Dry Cell Battery Install Date	2018-03-08 00:00:00.000000	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Battery Bank Volts	26.7	VDC
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Battery Bank Amps	.7	AMPS
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	80	*F
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Patrol Inspection	Grounds in Place?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	158	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	158	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Fault Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Equipment Properly Labeled?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Patrol Inspection	Tank Paint Condition	Good	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	0	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Bushing Condition	Good	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Amps C Ø	0.0	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Amps B Ø	0.0	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Amps A Ø	0.0	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	9 Month Operations	9	
6/9/2020 5:20	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	9 Month Operations	11	
6/9/2020 5:20	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
6/9/2020 5:20	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
6/9/2020 5:20	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
6/9/2020 5:20	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Amps A Ø	8.0	
6/9/2020 5:20	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Amps B Ø	8.0	
6/9/2020 5:20	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Amps C Ø	8.0	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	FE000596	Fence	PI-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BCH001410	Charger	565-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1	amps
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BCH001410	Charger	565-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BCH001410	Charger	565-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BCH001410	Charger	565-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Operations This Read Vac	5	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Switching Operations	1	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Tank Paint Condition	Good	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Unknown Operations	0	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	General Comments		
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Unknown Operations	0	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Pop-off Valve Tested Date	2020-03-24 00:00:00.000000	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	9 Month Operations	10	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Amps A Ø	130.0	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Amps B Ø	130.0	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Amps C Ø	130.0	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Bushing Condition	Good	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Pressure Vessel Condition	Good	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Switching Operations	0	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Tank 1 Oil Level	Good	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Tank 2 Oil level	Good	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Tank 3 Oil Level	Good	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Tank Leaks	None	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Tank Paint Condition	Good	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Unknown Operations	0	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Tank Paint Condition	Good	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Switching Operations	6	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Fault Operations A Ø	0	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Fault Operations B Ø	0	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Fault Operations C Ø	0	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Fault Operations Ground	0	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Follow-up Action Required?	n	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Foundation Condition	Good	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Operations This Read Vac	6	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	General Comments		
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	General Comments		
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Grounds in Place?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Operations Counter AL	460	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Operations Counter AF	454	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0444	BreakerVacuum	512-0950	VCB Readings	Maintenance Operations	0	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Grounds in Place?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Heaters (All) Functioning?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Maintenance Operations	0	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Patrol Inspection	Moisture and Leak Free?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Number of Ops last 9 Months	0	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Operations Counter AF	351	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Operations Counter AL	351	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	TB0163	BreakerOil	512-708	OCB Readings	Operations This Read Oil	0	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	LTC Operations Since Last Insp	836	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	LTC Min Tap Position	9L	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	LTC Max Tap Position	3L	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	LTC Current Tap Position	5L	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	LTC As Left Counter	8292	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	LTC As Found Counter	8292	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Mechanism Patrol Inspection	General Comments		
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	General Comments		
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	B0340	LTCMechanism	512-1	LTC Counter Readings	Follow-up Action Required?	n	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	79	*F
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BAT001123	Battery	512-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
6/9/2020 5:20	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Fault Adjusted Amps A Phase V	17.52	
6/9/2020 5:20	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Fault Adjusted Amps B Phase V	17.52	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
6/9/2020 5:20	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Fault Adjusted Amps C Phase V	17.52	
6/9/2020 5:20	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Fault Operations A Ø	0	
6/9/2020 5:20	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Fault Operations B Ø	0	
6/9/2020 5:20	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Fault Operations C Ø	0	
6/9/2020 5:20	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Fault Operations Ground	0	
6/9/2020 5:20	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Follow-up Action Required?	n	
6/9/2020 5:20	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	General Comments		
6/9/2020 5:20	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Maintenance Operations	0	
6/9/2020 5:20	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Operations Counter AF	62	
6/9/2020 5:20	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Operations Counter AL	66	
6/9/2020 5:20	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Operations This Read Vac	6	
6/9/2020 5:20	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Switching Operations	4	
6/9/2020 5:20	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Readings	Unknown Operations	2	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	VRR X Compensation AL	0	Position
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	VRR X Compensation AF	0	Position
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	VRR Time Delay	0	Seconds
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	VRR R Compensation AL	0	Position
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	VRR R Compensation AF	0	Position
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	VRR Base Voltage AL	0.0	VAC
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	VRR Base Voltage AF	0.0	VAC
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	VRR Bandwidth AL	0.0	VAC
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	VRR Bandwidth AF	0.0	VAC
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	Parallel / Ind. Sw Position	parallelIND	Position
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	Megger Trans Annun Pos.	0.0	Meg Ohms
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	Megger Trans Annun Neg.	0.0	Meg Ohms
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	General Comments	All of the readings do not belong on the quarterly insp, needs to be removed from insp.	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	Follow-up Action Required?	n	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	FCP Lower AL	0.0	VAC
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	FCP Lower AF	0.0	VAC
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	FCP Block Raise AL	0.0	VAC
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	FCP Block Raise AF	0.0	VAC
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	Fault Pressure Sw Position	In	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	Fault Pressure Relay Info	N/A	Model
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	Back Up Relay Block Raise AL	0.0	VAC
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	Back Up Relay Block Raise AF	0.0	VAC
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	Back Up Relay Block Low AL	0.0	VAC
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	Back Up Relay Block Low AF	0.0	VAC
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LTCC000096	LTCControl	PL-TRANS 2	LTC Annual Control Inspection	All Connections OK?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0211	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	PF000309	PowerFuse	PL-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	PF000309	PowerFuse	PL-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	PF000310	PowerFuse	PL-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	PF000310	PowerFuse	PL-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	ST000302	Structure	512-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BCH001410	Charger	565-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BCH001410	Charger	565-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Patrol Inspection	Grounds in Place?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	General Comments		
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Readings	General Comments		
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Patrol Inspection	General Comments		
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Patrol Inspection	Foundation Condition	Good	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Follow-up Action Required?	n	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Vegetation	None	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Follow-up Action Required?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Fault Operations Ground	0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Fault Operations C Ø	0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Fault Operations B Ø	0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Fault Operations A Ø	0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Amps A Ø	0.0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Amps B Ø	0.0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Amps C Ø	0.0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Patrol Inspection	Bushing Condition	Good	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Patrol Inspection	Bushing Condition	Good	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Amps C Ø	15.0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Amps B Ø	15.0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Amps A Ø	19.0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	9 Month Operations	15	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Fault Operations A Ø	0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Fault Operations B Ø	0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Fault Operations C Ø	0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Fault Operations Ground	0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Follow-up Action Required?	n	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Patrol Inspection	Foundation Condition	Good	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Patrol Inspection	General Comments		
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	General Comments		
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Follow-up Action Required?	n	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Patrol Inspection	General Comments		
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	General Comments		
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	SWG000053	Switchgear	PI-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Unknown Operations	0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Patrol Inspection	Tank Paint Condition	Good	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Switching Operations	0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Operations This Read Vac	0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Operations Counter AL	107	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	9 Month Operations	11	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	General Comments		
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Readings	Oil Temp Present	45	°C
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Readings	Oil Temp Max	55	°C
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1800	psi
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Operations Counter AF	107	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Readings	Maintenance Operations	0	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Ambient Temp	79	°F
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	SWG000125	Switchgear	PI-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001453	BreakerVacuum	PL-1276	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.2	psi
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LT0282	WithLTC	PI-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	General Comments		
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	YD000294	Yard	512-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	FE000291	Fence	512-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Patrol Inspection	Grounds in Place?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	General Comments		
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Patrol Inspection	General Comments		
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Patrol Inspection	Foundation Condition	Good	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Fault Operations Ground	0	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Operations Counter AL	472	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Operations Counter AF	467	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Maintenance Operations	4	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Broom on Site?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Grounds in Place?	y	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	General Comments		
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	General Comments		
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Foundation Condition	Good	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Follow-up Action Required?	n	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Fault Operations Ground	0	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Fault Operations C Ø	0	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Fault Operations B Ø	0	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Fault Operations A Ø	0	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2020 13:46	Distribution	Butler Quarterly Inspection	BB0445	BreakerVacuum	512-0951	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1481	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0213	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1481	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Patrol Inspection	Tank Paint Condition	Good	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Unknown Operations	0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	23	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Tank 2 Oil level	Good	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Counter Readings	General Comments		
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Mechanism Patrol Inspection	General Comments	LTC does not have have a nitrogen gauge & it does not have a oil Temp gauge, needs to be removed from insp.	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Counter Readings	LTC As Found Counter	7120	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Counter Readings	LTC As Left Counter	7120	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001457	BreakerVacuum	PL-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Patrol Inspection	Bushing Condition	Good	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Amps C Ø	15.0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Amps B Ø	15.0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Amps A Ø	19.0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	LT0179	LTCMechanism	PL-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	9 Month Operations	27	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.7	amps
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	26.7	VDC
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	26.7	VDC
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	BCH001225	Charger	PI-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	BAT001285	Battery	PI-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Patrol Inspection	Grounds in Place?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Unknown Operations	0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Patrol Inspection	Tank Paint Condition	Good	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Switching Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Follow-up Action Required?	n	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Foundation Condition	Good	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	General Comments		
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	General Comments	no vc	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Grounds in Place?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Maintenance Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Moisture and Leak Free?	y	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Number of Ops last 9 Months	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Operations Counter AF	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Operations Counter AL	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Operations This Read Oil	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Operations This Read Vac	0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Operations Counter AL	170	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Maintenance Operations	0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Operations Counter AF	170	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	CH000176	ControlHouse	PL-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Maintenance Operations	0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Patrol Inspection	Grounds in Place?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	General Comments		
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Maintenance Operations	0	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Operations Counter AF	354	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Operations Counter AL	354	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Operations This Read AM	0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Patrol Inspection	General Comments		
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Patrol Inspection	Foundation Condition	Good	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Follow-up Action Required?	n	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Fault Operations Ground	0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Operations Counter AF	105	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Operations Counter AL	105	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Operations This Read Vac	0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Fault Operations C ∅	0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Fault Operations B ∅	0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Fault Operations A ∅	0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Switching Operations	0	
9/14/2020 13:02	Distribution	Pirtle Quarterly Inspection	LB0788	BreakerAirMagnetic	PI-3	AMCB Readings	Unknown Operations	0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Patrol Inspection	Bushing Condition	Good	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Amps C ∅	0.0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Readings	Switching Operations	0	
9/21/2020 8:22	Distribution	Clifton Quarterly Inspection	LB0219	BreakerOil	CL-GND TR 1	OCB Patrol Inspection	Tank 1 Oil Level	Good	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Amps B ∅	0.0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Amps A ∅	0.0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001452	BreakerVacuum	PL-1275	VCB Readings	9 Month Operations	26	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Unknown Operations	0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Patrol Inspection	Tank Paint Condition	Good	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Switching Operations	0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Operations This Read Vac	0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Operations Counter AL	290	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Operations Counter AF	290	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Readings	Maintenance Operations	0	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001451	BreakerVacuum	PL-12KV TR 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/14/2020 13:22	Distribution	Pleasure Ridge Quarterly Inspection	BK001454	BreakerVacuum	PL-1277	VCB Readings	Switching Operations	0	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	General Comments		
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps A Ø	40.0	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps B Ø	40.0	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Operations Counter	1497	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Amps C Ø	40.0	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	CX0111	RecloserElectronic	Retired Distribution	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Evidence of Insects	None	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	n	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6L	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	LTC Max Tap Position	2R	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	LTC Min Tap Position	11L	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1775	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Floor Swept?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	9 Month Operations	1	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Amps A Ø	10.0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	LTC Max Tap Position	4R	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Amps B Ø	20.0	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Amps C Ø	20.0	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Bushing Condition	Good	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	General Comments	heater is not working	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	LTC Max Tap Position	Neutral	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	LTC Current Tap Position	6L	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	LTCC000903	LTCControl	774-1	LTC Control Insp	Follow-up Action Required?	n	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	LTCC000903	LTCControl	774-1	LTC Control Insp	All Connections OK?	y	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	LTCC000901	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	LTCC000901	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	LTCC000901	LTCControl	920-Offline-Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	LTCC000901	LTCControl	920-Offline-Distribution	LTC Control Insp	LTC Output Voltage Level	122.8	VAC
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	LTCC000901	LTCControl	920-Offline-Distribution	LTC Control Insp	LTC Operation Checked?	y	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	LTCC000901	LTCControl	920-Offline-Distribution	LTC Control Insp	General Comments		
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	LTCC000901	LTCControl	920-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	LTCC000901	LTCControl	920-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Acceptable Building Appearance?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Broom on Site?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Operations Counter AF	304	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Maintenance Operations	0	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Grounds in Place?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	General Comments		
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Control House Lighting OK?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	CH000335	ControlHouse	546-Control house	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	General Comments		
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	LTC As Found Counter	19923	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Counter Readings	LTC As Left Counter	19923	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LTCM000042	LTCMechanism	NA-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	45	°C
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	9 Month Operations	9	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Amps A Ø	120.0	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Amps B Ø	120.0	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Amps C Ø	135.0	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Bushing Condition	Good	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	90.0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	100.0	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	LTC Min Tap Position	10L	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Fault Operations A Ø	0	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Fault Operations B Ø	0	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Fault Operations C Ø	0	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Fault Operations B Ø	0	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Fault Operations Ground	0	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	74.0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Follow-up Action Required?	n	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Fault Operations A Ø	0	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Fault Operations B Ø	0	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Fault Operations C Ø	0	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Amps C Ø	130.0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Amps B Ø	150.0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Amps A Ø	140.0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	General Comments		
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Foundation Condition	Good	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	General Comments		
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	1	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	11.18	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	General Comments		
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	Oil Temp Max	62	°C
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	Oil Temp Present	45	°C
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	9 Month Operations	0	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Amps A Ø	128.0	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Amps B Ø	252.0	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Amps C Ø	216.0	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Bushing Condition	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Fault Operations A Ø	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	65	°C
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Regulator As Left Counter	82763	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Maintenance Operations	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	General Comments		
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Patrol Inspection	General Comments		
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Follow-up Action Required?	n	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Fault Operations Ground	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Fault Operations C Ø	0	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Ambient Temp	81	°F
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	General Comments		
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Fault Operations B Ø	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Fault Operations A Ø	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Amps C Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	LTCC000562	LTCControl	932-Offline Distribution	LTC Control Insp	All Connections OK?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	LTCC000562	LTCControl	932-Offline Distribution	LTC Control Insp	Follow-up Action Required?	n	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	LTCC000562	LTCControl	932-Offline Distribution	LTC Control Insp	General Comments		
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	LTCC000562	LTCControl	932-Offline Distribution	LTC Control Insp	LTC Operation Checked?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	FE000475	Fence	759-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Amps B Ø	0.0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Amps A Ø	0.0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	Totalizer Meter Reading	1.1590	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	1239.0	volts
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Regulator As Left Counter	24942	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AF	253	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	1	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	138	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	138	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	48	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	48	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	General Comments		
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Max Tap Position	12R	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	R0778	Regulator	759-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	General Comments		
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	General Comments		
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	LTC As Found Counter	58203	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	LTC As Left Counter	58203	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	LTC Current Tap Position	6L	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	LTCC000903	LTCControl	774-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	LTCC000903	LTCControl	774-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	LTCC000903	LTCControl	774-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	LTCC000903	LTCControl	774-1	LTC Control Insp	LTC Output Voltage Level	123.3	VAC
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	LTCC000903	LTCControl	774-1	LTC Control Insp	LTC Operation Checked?	y	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	LTCC000903	LTCControl	774-1	LTC Control Insp	General Comments		
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Unknown Operations	0	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Switching Operations	0	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Operations This Read Vac	0	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	K0029	BreakerVacuum	790-0529	VCB Readings	Operations Counter AL	304	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1080	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	LTC Min Tap Position	9L	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	LTCC000562	LTCControl	932-Offline Distribution	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	LTCC000562	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	LTCC000562	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	9 Month Operations	3	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	LTCC000562	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Vegetation	None	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	General Comments		
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	General Comments		
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Vegetation	None	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	YD000482	Yard	759-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	ST000483	Structure	759-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	LTC0000848	LTCControl	868-1	LTC Control Insp	VRR Time Delay	60	Seconds
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Ambient Temp	85	*F
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Ambient Temp	79	*F
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Min Tap Position	2R	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Max Tap Position	9L	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	General Comments		
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	General Comments		
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	YD000538	Yard	597-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	LTCC000848	LTCControl	868-1	LTC Control Insp	All Connections OK?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Bushing Condition	Good	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Amps C Ø	125.0	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Amps B Ø	104.0	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Amps A Ø	102.0	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	General Comments		
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	LTCC000848	LTCControl	868-1	LTC Control Insp	Follow-up Action Required?	n	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	LTCC000848	LTCControl	868-1	LTC Control Insp	General Comments		
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	LTCC000848	LTCControl	868-1	LTC Control Insp	LTC Operation Checked?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	LTCC000848	LTCControl	868-1	LTC Control Insp	LTC Output Voltage Level	123.2	VAC
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	65	°C
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	38	°C
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	70	°C
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	50	°C
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	LTCC000848	LTCControl	868-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	LTCC000848	LTCControl	868-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Current Tap Position	7L	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	General Comments		
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Max Tap Position	3L	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Min Tap Position	13L	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Regulator As Left Counter	37159	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1502	Regulator	680-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	78	°F
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	BAT000366	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	General Comments		
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	General Comments		
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Max Tap Position	Neutral	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Min Tap Position	11L	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Current Tap Position	3L	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	9 Month Operations	9	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	General Comments		
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Max Tap Position	1R	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Min Tap Position	10L	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Regulator As Left Counter	42449	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1500	Regulator	680-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Regulator As Left Counter	35632	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1487	Regulator	774-2 C	Regulator Patrol Inspection	Tank Leaks	None	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	ST000479	Structure	845-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	80	°F
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Foundation Condition	Good	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	General Comments		
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Grounds in Place?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	9 Month Operations	1	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	General Comments		
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.4	VDC
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	Positive DC Ground	24.2	VDC
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Regulator As Left Counter	34649	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	C0352	WithLTC	565-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	415.0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	450.0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	412.0	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Ambient Temp	80	°F
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Fault Operations Ground	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	LTC As Left Counter	76290	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0138	LTCMechanism	NA-TRANS 2	LTC Counter Readings	LTC As Found Counter	76290	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Fault Operations C Ø	0	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Fault Operations Ground	0	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Follow-up Action Required?	n	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Foundation Condition	Good	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	General Comments		
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	General Comments		
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Grounds in Place?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Maintenance Operations	0	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Operations Counter AF	315	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Operations Counter AL	315	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Operations This Read Vac	0	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0684	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	4	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Switching Operations	0	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0161	BreakerVacuum	779-4506	VCB Readings	Unknown Operations	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Follow-up Action Required?	n	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Foundation Condition	Good	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	General Comments		
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	General Comments		
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Grounds in Place?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Maintenance Operations	0	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Operations Counter AF	307	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Operations Counter AL	309	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Operations This Read Vac	2	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Switching Operations	2	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	BAT001496	Battery	546-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0151	BreakerVacuum	680-0641	VCB Readings	Unknown Operations	0	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Operations Counter	10	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Vegetation	None	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	KR0043	Regulator	759-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	FE000533	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	SWG000132	Switchgear	NA-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	53	°C
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	1617	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0136	LTCMechanism	NA-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	YD000039	Yard	802-Yard	Yard Patrol Inspection	Vegetation	None	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0696	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Unknown Operations	0	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Switching Operations	0	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	General Comments		
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	YD000477	Yard	845-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Amps A Ø	160.0	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Amps B Ø	125.0	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Amps C Ø	125.0	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Operations This Read Vac	0	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Operations Counter AL	155	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Operations Counter AF	155	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Maintenance Operations	0	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Grounds in Place?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	General Comments		
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	General Comments		
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Foundation Condition	Good	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Follow-up Action Required?	n	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Fault Operations C Ø	0	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Fault Operations B Ø	0	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	K0201	BreakerVacuum	868-4501	VCB Readings	Fault Operations A Ø	0	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	General Comments		
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	General Comments		
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	ST000542	Structure	597-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	CX0133	RecloserElectronic	774-2430	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Door Alarms OK?	n	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Operations Counter AF	3	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Operations Counter AL	3	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Operations This Read Vac	0	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Broom on Site?	n	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Switching Operations	0	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Unknown Operations	0	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	General Comments	Some brush growing on fence and also trees growing near fence.	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Ambient Temp	75	°F
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	9 Month Operations	0	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BCH001390	Charger	790-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BCH001390	Charger	790-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.9	amps
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BCH001390	Charger	790-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BCH001390	Charger	790-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BCH001390	Charger	790-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BCH001390	Charger	790-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	General Comments		
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Exp Boom Corrected	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	9 Month Operations	0	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	FE000021	Fence	779-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Operations Counter AL	283	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Operations This Read Vac	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Switching Operations	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Unknown Operations	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A ∅	0.0	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Fault Operations A ∅	0	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Fault Operations B ∅	0	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	LTCC000386	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	40	Seconds
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	LTCC000386	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	LTCC000386	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	LTCC000386	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.2	VAC
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	LTCC000386	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	LTCC000386	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	LTCC000386	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	LTCC000386	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B ∅	0.0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C ∅	0.0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Fault Operations C ∅	0	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Trash Emptied?	n	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	n	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	General Comments		
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Floor Swept?	n	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Fault Operations Ground	0	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Follow-up Action Required?	n	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Foundation Condition	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	General Comments		
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	General Comments		
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Grounds in Place?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Maintenance Operations	0	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	CH000477	ControlHouse	779-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	General Comments		
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Door Alarms OK?	n	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	General Comments		
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	PF000258	PowerFuse	NA-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	OK	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	PF000258	PowerFuse	NA-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	General Comments		
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	138	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	138	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	9 Month Operations	10	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Vegetation	None	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	General Comments		
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	BCH000136	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	5.0	amps
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Trash Emptied?	n	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	BCH000136	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	BCH000136	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	General Comments		
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Ambient Temp	74	°F
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Follow-up Action Required?	n	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Foundation Condition	Good	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	General Comments		
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	General Comments		
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Grounds in Place?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Maintenance Operations	0	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Operations Counter AF	335	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Operations Counter AL	335	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Operations This Read Vac	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	General Comments		
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Meter Array Visual Inspection	OK	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Broom on Site?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	CH000482	ControlHouse	802-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Switching Operations	0	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Unknown Operations	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	YD000653	Yard	NA-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Vegetation	Light	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	YD000016	Yard	779-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	144	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	144	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0695	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	BCH000136	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	BCH000136	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	133.5	VDC
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	BCH000136	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	133.5	VDC
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	FE000296	Fence	680-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Operations This Read Vac	0	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Operations Counter AL	747	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Operations Counter AF	747	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	LTC Operations Since Last Insp	1563	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	LTC Min Tap Position	9L	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	LTC Max Tap Position	4R	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	LTC As Left Counter	195959	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	LTC As Found Counter	195958	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Mechanism Patrol Inspection	General Comments		
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	General Comments		
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	C0435	LTCMechanism	546-1	LTC Counter Readings	Follow-up Action Required?	n	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Vegetation	None	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	General Comments		
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	Totalizer Meter Reading	.9094	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Mechanism Patrol Inspection	General Comments		
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	C0352	LTCMechanism	565-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Maintenance Operations	0	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Grounds in Place?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	General Comments		
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	General Comments		
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Foundation Condition	Good	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Follow-up Action Required?	n	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Fault Operations Ground	0	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Fault Operations C Ø	0	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Fault Operations B Ø	0	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Fault Operations A Ø	0	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	Oil Temp Max	62	°C
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	General Comments		
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	General Comments		
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	LTC Totalizer Reading	3648.00	kw
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	Oil Temp Max	56	°C
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	Oil Temp Present	50	°C
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	Totalizer Meter Reading	.6080	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	General Comments	trees overhang on transforme side	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	Oil Temp Present	47	°C
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	6547.68	kw
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	General Comments		
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	General Comments		
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Unknown Operations	0	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	S0031	NonLTC	774-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Switching Operations	0	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Yard Lights Working?	n	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Fault Operations C Ø	0	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Fault Operations B Ø	0	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Fault Operations A Ø	0	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	General Comments		
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	ST000025	Structure	868-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Bushing Condition	Good	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Amps C Ø	20.0	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Amps B Ø	60.0	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Amps A Ø	20.0	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Follow-up Action Required?	n	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Counter Readings	General Comments		
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Found Counter	59460	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Left Counter	59464	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Current Tap Position	Neutral	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Max Tap Position	11L	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Min Tap Position	3R	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Operations Since Last Insp	1122	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	C0405	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Amps A Ø	180.0	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Amps B Ø	180.0	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Amps C Ø	180.0	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Bushing Condition	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	FE000648	Fence	NA-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0133	BreakerVacuum	774-2428	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	B0310	WithLTC	779-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0156	BreakerVacuum	802-0523	VCB Readings	Fault Operations Ground	0	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	FE000030	Fence	868-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Patrol Inspection	Bushing Condition	Good	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Amps C Ø	15.0	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Amps B Ø	50.0	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Amps A Ø	120.0	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0147	BreakerVacuum	779-4507	VCB Readings	9 Month Operations	7	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	General Comments		
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	ST000022	Structure	546-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Ambient Temp	80	*F
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	YD000024	Yard	546-Yard	Yard Patrol Inspection	Ambient Temp	79	*F
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BCH001390	Charger	790-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.900	millivolts
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BCH001390	Charger	790-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	LTC Operations Since Last Insp	992	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	LTC Min Tap Position	13L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	LTC Max Tap Position	1L	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	LTC Current Tap Position	2L	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	LTC As Left Counter	61233	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	LTC As Found Counter	61233	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Mechanism Patrol Inspection	General Comments		
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	General Comments		
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	B0477	LTCMechanism	790-1	LTC Counter Readings	Follow-up Action Required?	n	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	General Comments	yard lights not working	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	YD000025	Yard	868-Yard	Yard Patrol Inspection	Vegetation	None	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	BCH001293	Charger	802-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.300	millivolts
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Operations Counter AF	283	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Maintenance Operations	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	General Comments		
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Patrol Inspection	General Comments		
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Follow-up Action Required?	n	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Fault Operations Ground	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0138	WithLTC	NA-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Fault Operations C ∅	0	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Tank Leaks	None	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	9 Month Operations	17	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Amps A ∅	79.0	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Amps B ∅	84.0	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Amps C ∅	78.0	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Bushing Condition	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Regulator As Left Counter	84609	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Min Tap Position	1R	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Max Tap Position	10L	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	General Comments		
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Fault Operations B ∅	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Fault Operations A ∅	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0688	BreakerVacuum	NA-1271	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Fault Operations A ∅	0	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Fault Operations B ∅	0	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Fault Operations C ∅	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Fault Operations Ground	0	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Follow-up Action Required?	n	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Foundation Condition	Good	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	General Comments		
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	LTC Current Tap Position	3L	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	LTC Max Tap Position	Neutral	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Amps A Ø	196.0	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Amps B Ø	136.0	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Amps C Ø	151.0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Bushing Condition	Good	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Fault Operations A Ø	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	50	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	50	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Fault Operations B Ø	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	1404	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	1404	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Fault Operations C Ø	0	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Fault Operations Ground	0	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Follow-up Action Required?	n	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Foundation Condition	Good	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	General Comments		
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	General Comments		
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Grounds in Place?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Maintenance Operations	0	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Operations Counter AF	213	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Operations Counter AL	213	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Operations This Read Vac	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Switching Operations	0	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	Unknown Operations	0	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	LTC Min Tap Position	12L	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	LTC Operations Since Last Insp	0	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Unknown Operations	0	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	BCH001293	Charger	802-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	BCH001293	Charger	802-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	BCH001293	Charger	802-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	BCH001293	Charger	802-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	BCH001293	Charger	802-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	BCH001293	Charger	802-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Present	55	°C
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Max	62	°C
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	LTC Totalizer Reading	1785.60	kw
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Bushing Condition	Good	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Amps C Ø	127.0	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Amps B Ø	162.0	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Amps A Ø	150.0	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	General Comments		
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	General Comments		
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	General Comments		
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	LTC Totalizer Reading	3708.80	kw
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	9 Month Operations	0	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	Oil Temp Max	60	°C
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Readings	Oil Temp Present	50	°C
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	C0439	WithLTC	774-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	General Comments		
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Grounds in Place?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Maintenance Operations	0	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Operations Counter AF	269	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Operations Counter AL	269	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Operations This Read Vac	0	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Switching Operations	0	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	MB0177	BreakerVacuum	546-0542	VCB Readings	Unknown Operations	0	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Unknown Operations	0	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Switching Operations	0	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Operations This Read Vac	0	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Operations Counter AL	196	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Operations Counter AF	196	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Current Tap Position	2L	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1485	Regulator	774-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Reading	.3720	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Maintenance Operations	0	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Grounds in Place?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	General Comments		
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	General Comments		
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Foundation Condition	Good	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Follow-up Action Required?	n	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Fault Operations Ground	0	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Fault Operations C Ø	0	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Fault Operations B Ø	0	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Fault Operations A Ø	0	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	General Comments		
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Max Tap Position	10L	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	R0776	Regulator	759-1 B	Regulator Patrol Inspection	Min Tap Position	2L	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	BK001192	BreakerVacuum	802-0521	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	C0405	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	BCH001293	Charger	802-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	88.0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	104.0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	75.0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BAT001476	Battery	565-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BAT001476	Battery	565-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BAT001476	Battery	565-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BAT001476	Battery	565-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Trash Emptied?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	General Comments		
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Broom on Site?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	CH000416	ControlHouse	790-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BAT001476	Battery	565-Battery Bank	Battery Patrol Inspection	General Comments		
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BAT001476	Battery	565-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BAT001476	Battery	565-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Exp/Missing Not Repl	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BAT001476	Battery	565-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BAT001476	Battery	565-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BAT001476	Battery	565-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BAT001476	Battery	565-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BAT001476	Battery	565-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	BCH000136	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	BCH000136	Charger	Retired Distribution	Battery Charger Patrol Insp	Ground Lights	None	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BAT001476	Battery	565-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BAT001476	Battery	565-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	*F
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BAT001476	Battery	565-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	BCH000405	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	BCH000405	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BCH000214	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	0.0	VDC
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	General Comments		
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Amps A Ø	0.0	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Amps B Ø	0.0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Amps C Ø	0.0	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	ST000308	Structure	680-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Trash Emptied?	n	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	n	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Station Ground Set On Site?	n	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Panels Dusted?	n	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Panel Lights OK?	n	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	General Comments		
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Floor Swept?	n	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Door Alarms OK?	n	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Broom on Site?	n	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	CH000493	ControlHouse	565-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Fault Operations A Ø	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Fault Operations B Ø	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Fault Operations C Ø	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Fault Operations Ground	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Follow-up Action Required?	n	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Patrol Inspection	General Comments		
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	General Comments		
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Maintenance Operations	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Operations Counter AF	168	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Operations Counter AL	168	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Operations This Read Vac	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0691	BreakerVacuum	NA-1274	VCB Readings	Switching Operations	0	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	ST000015	Structure	779-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0682	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	General Comments		
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	General Comments		
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	LTC Totalizer Reading	4384.80	kw
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	Oil Temp Max	65	°C
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	Oil Temp Present	47	°C
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	250.0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	360.0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	350.0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	Totalizer Meter Reading	.6090	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Follow-up Action Required?	n	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Counter Readings	General Comments		
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Found Counter	169385	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Left Counter	169388	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Current Tap Position	2L	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Max Tap Position	7L	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Min Tap Position	4R	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Operations Since Last Insp	1040	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	B0384	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	Follow-up Action Required?	n	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	General Comments		
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Mechanism Patrol Inspection	General Comments		
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	LTC As Found Counter	71819	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	B0310	LTCMechanism	779-1	LTC Counter Readings	LTC As Left Counter	71819	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	BK001333	BreakerVacuum	868-4502	VCB Readings	9 Month Operations	12	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BCH000214	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	0.0	VDC
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BCH000214	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BCH000214	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	ST000632	Structure	NA-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	BCH000405	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	BCH000405	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	BCH000405	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	BCH000405	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	LTCC000701	LTCControl	779-1	LTC Control Insp	All Connections OK?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	LTCC000701	LTCControl	779-1	LTC Control Insp	Follow-up Action Required?	n	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	LTCC000701	LTCControl	779-1	LTC Control Insp	General Comments		
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	LTCC000701	LTCControl	779-1	LTC Control Insp	LTC Operation Checked?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BCH000214	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments	Removed	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	LTCC000701	LTCControl	779-1	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0687	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	LTCC000701	LTCControl	779-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	LTCC000701	LTCControl	779-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	LTCC000701	LTCControl	779-1	LTC Control Insp	VRR Time Delay	45	Seconds
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	General Comments		
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	CH000381	ControlHouse	680-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0410	BreakerVacuum	565-4516	VCB Patrol Inspection	Bushing Condition	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	6	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	64.0	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	LTCC000921	LTCControl	790-1	LTC Control Insp	VRR Time Delay	60	Seconds
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	LTCC000921	LTCControl	790-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	LTCC000921	LTCControl	790-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	LTCC000921	LTCControl	790-1	LTC Control Insp	LTC Output Voltage Level	125.1	VAC
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	LTCC000921	LTCControl	790-1	LTC Control Insp	LTC Operation Checked?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	LTCC000921	LTCControl	790-1	LTC Control Insp	General Comments		
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	LTCC000921	LTCControl	790-1	LTC Control Insp	Follow-up Action Required?	n	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	LTCC000921	LTCControl	790-1	LTC Control Insp	All Connections OK?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	60.0	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	C0469	WithLTC	845-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0681	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	60.0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Fault Operations A Ø	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Fault Operations B Ø	1	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Fault Operations C Ø	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Fault Operations Ground	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Follow-up Action Required?	n	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Radiator Leaks	Seeping	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	General Comments		
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Patrol Inspection	General Comments		
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	General Comments	B PHASE IOC	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Maintenance Operations	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Operations Counter AF	330	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Operations Counter AL	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Operations This Read Vac	1	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	FE000827	Fence	845-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Reading	.4313	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Unknown Operations	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	894	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	894	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	Totalizer Meter Reading	.8376	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Switching Operations	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Unknown Operations	0	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	General Comments		
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Vegetation	None	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	General Comments		
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	General Comments		
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	LTC Totalizer Reading	8040.96	kw
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	General Comments		
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	ST000439	Structure	604-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	74	*F
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	Oil Temp Max	65	*C
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	Oil Temp Present	40	*C
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Operations Counter AF	319	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Operations Counter AL	319	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Operations This Read Vac	0	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Switching Operations	0	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Unknown Operations	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	9 Month Operations	3	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	200.00	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	Totalizer Meter Reading	.8060	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1800	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	General Comments		
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Operations Counter	15	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Switching Operations	0	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Operations This Read Vac	2	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Operations Counter AL	241	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Operations Counter AF	241	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Maintenance Operations	0	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Grounds in Place?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	General Comments		
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	PF000260	PowerFuse	NA-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	PF000260	PowerFuse	NA-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	PF000259	PowerFuse	NA-12KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	Oil Temp Present	45	°C
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	10.00	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Fault Operations A Ø	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Fault Operations B Ø	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Fault Operations C Ø	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Fault Operations Ground	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Follow-up Action Required?	n	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Patrol Inspection	General Comments		
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	General Comments		
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Maintenance Operations	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Operations Counter AF	194	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1450.80	kw
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Operations Counter AL	195	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Operations This Read Vac	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Switching Operations	0	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0693	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	2	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Amps A Ø	250.0	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	General Comments		
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	9 Month Operations	26	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Amps A Ø	53.0	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Amps B Ø	44.0	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Amps C Ø	38.0	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Bushing Condition	Good	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Amps A Ø	20.0	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Fault Operations A Ø	0	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Fault Operations B Ø	0	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Fault Operations C Ø	0	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Fault Operations Ground	0	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Present	45	°C
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Max	60	°C
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Readings	LTC Totalizer Reading	3105.36	kw
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Amps B Ø	17.0	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Amps C Ø	11.0	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	CX0612	RecloserHydraulic	759-2450	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments	low side bushing leak	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Readings	General Comments		
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Amps B Ø	280.0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Amps C Ø	180.0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	General Comments	lightning arrester still blown 522	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	General Comments		
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	General Comments		
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	*F
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	BAT001396	Battery	779-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	General Comments		
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	Winding Temp Max	55	°C
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	Totalizer Meter Reading	.7430	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Amps A Ø	34.0	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Amps B Ø	36.0	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Amps C Ø	32.0	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Evidence of Insects	None	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Exp/Missing Not Repl	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	General Comments		
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Negative DC Ground	23.9	VDC
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Positive DC Ground	24.3	VDC
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	General Comments		
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	ST000457	Structure	774-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	9 Month Operations	16	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Vegetation	None	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Operations This Read Vac	0	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Switching Operations	0	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Unknown Operations	0	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	General Comments		
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	General Comments		
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	YD000036	Yard	565-Yard	Yard Patrol Inspection	Ambient Temp	82	°F
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Panels Dusted?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	Winding Temp Present	40	°C
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	FE000825	Fence	774-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	General Comments		
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	General Comments		
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	LTC Totalizer Reading	2912.64	kw
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.5	psi
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	Oil Temp Max	45	°C
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	Oil Temp Present	40	°C
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	General Comments		
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	Totalizer Meter Multiplier	3200	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	Totalizer Meter Reading	.9102	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Amps A Ø	40.0	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Amps B Ø	38.0	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Amps C Ø	40.0	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Ambient Temp	77	°F
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	YD000436	Yard	604-Yard	Yard Patrol Inspection	General Comments		
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	7132.80	kw
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	S0057	NonLTC	680-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	C0435	WithLTC	546-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	General Comments		
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Operations Counter	3	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0097	RecloserElectronic	604-2446	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	General Comments		
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	SWG000123	Switchgear	NA-Swgr Sec 3	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Amps A Ø	120.0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Amps B Ø	100.0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Amps C Ø	150.0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	Oil Temp Max	65	°C
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	General Comments		
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0689	BreakerVacuum	NA-1272	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	FE000432	Fence	604-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	0981	WithLTC	802-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Maintenance Operations	0	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Operations Counter AF	180	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Operations Counter AL	180	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Operations This Read Vac	4	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Switching Operations	0	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Unknown Operations	0	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	LTCC000661	LTCControl	546-1	LTC Control Insp	VRR Time Delay	60	Seconds
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	LTCC000661	LTCControl	546-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	LTCC000661	LTCControl	546-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Unknown Operations	0	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	LTCC000661	LTCControl	546-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	LTCC000661	LTCControl	546-1	LTC Control Insp	LTC Output Voltage Level	123.9	VAC
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Switching Operations	2	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	LTCC000661	LTCControl	546-1	LTC Control Insp	LTC Operation Checked?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	LTCC000661	LTCControl	546-1	LTC Control Insp	General Comments		
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Operations This Read Vac	2	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Operations Counter AL	313	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Operations Counter AF	311	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Maintenance Operations	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	41	°C
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	LTCC000659	LTCControl	565-1	LTC Control Insp	All Connections OK?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	LTCC000659	LTCControl	565-1	LTC Control Insp	Follow-up Action Required?	n	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	LTCC000659	LTCControl	565-1	LTC Control Insp	General Comments		
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	LTCC000659	LTCControl	565-1	LTC Control Insp	LTC Operation Checked?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	LTCC000659	LTCControl	565-1	LTC Control Insp	LTC Output Voltage Level	123.4	VAC
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	LTCC000659	LTCControl	565-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	LTCC000659	LTCControl	565-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	LTCC000659	LTCControl	565-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	General Comments		
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Min Tap Position	12L	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	General Comments		
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	750	psi
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	Oil Temp Max	61	°C
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	Oil Temp Present	41	°C
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	65	°C
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	42	°C
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	66	°C
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	42	°C
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	64	°C
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Fault Operations A Ø	0	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Fault Operations B Ø	0	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Fault Operations C Ø	0	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Fault Operations C Ø	0	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Fault Operations Ground	0	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Unknown Operations	0	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Switching Operations	1	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Operations This Read Vac	1	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Operations Counter AL	489	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Operations Counter AF	489	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Maintenance Operations	0	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Grounds in Place?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	77	°F
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Fault Adjusted Amps B Phase V	9.37	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Fault Adjusted Amps C Phase V	9.37	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Fault Operations A Ø	0	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Fault Operations B Ø	2	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Fault Operations C Ø	2	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Fault Operations Ground	0	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Follow-up Action Required?	n	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Foundation Condition	Good	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	General Comments		
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	General Comments	BCT	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Grounds in Place?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	General Comments		
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Operations Counter	2	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Fault Operations Ground	0	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Fault Operations A Ø	0	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Operations Counter	13	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	General Comments		
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Amps A Ø	30.0	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Amps B Ø	35.0	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Amps C Ø	40.0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Bushing Condition	Good	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Amps A Ø	11.0	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Amps B Ø	17.0	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Amps C Ø	8.0	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Amps A Ø	230.0	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0096	RecloserElectronic	604-2445	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Unknown Operations	0	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Switching Operations	0	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Operations This Read Vac	0	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Operations Counter AL	168	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Operations Counter AF	168	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Maintenance Operations	0	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	General Comments		
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	FE000841	Fence	546-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	9 Month Operations	6	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Regulator As Left Counter	39631	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	R1501	Regulator	680-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	PF000259	PowerFuse	NA-12KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	LTCC000661	LTCControl	546-1	LTC Control Insp	Follow-up Action Required?	n	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	LTCC000661	LTCControl	546-1	LTC Control Insp	All Connections OK?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	LTCC000659	LTCControl	565-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	PF000257	PowerFuse	NA-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	OK	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	PF000257	PowerFuse	NA-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	PF000256	PowerFuse	NA-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	OK	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	PF000256	PowerFuse	NA-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	PF000255	PowerFuse	NA-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	OK	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	PF000255	PowerFuse	NA-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	General Comments	L and B open	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	General Comments		
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Foundation Condition	Good	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Follow-up Action Required?	n	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Follow-up Action Required?	n	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Foundation Condition	Good	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	General Comments		
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	General Comments		
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	9 Month Operations	11	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Grounds in Place?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Grounds in Place?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	General Comments		
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	General Comments		
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Foundation Condition	Good	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Follow-up Action Required?	n	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Unknown Operations	0	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Switching Operations	0	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Amps A Ø	59.0	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Amps B Ø	51.0	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Amps C Ø	58.0	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0095	RecloserElectronic	604-2444	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Fault Operations Ground	0	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Operations This Read Vac	0	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Operations Counter AL	719	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Operations Counter AF	719	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Maintenance Operations	0	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Grounds in Place?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	General Comments		
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	General Comments		
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Fault Operations C Ø	0	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0152	BreakerVacuum	680-0642	VCB Readings	Fault Operations B Ø	0	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Foundation Condition	Good	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Follow-up Action Required?	n	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	General Comments		
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	BAT000017	Battery	NA-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Unknown Operations	0	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	General Comments		
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Foundation Condition	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Follow-up Action Required?	n	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Fault Operations Ground	0	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Fault Operations C Ø	1	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	9 Month Operations	62	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Amps A Ø	176.0	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Amps B Ø	178.0	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Amps C Ø	180.0	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Bushing Condition	Good	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	Totalizer Meter Reading	.8598	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Broom on Site?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	General Comments		
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Fault Operations A Ø	0	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	BK001445	BreakerVacuum	546-0543	VCB Readings	Fault Operations B Ø	0	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	9 Month Operations	2	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Amps A Ø	240.0	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Amps B Ø	210.0	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Amps C Ø	190.0	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Bushing Condition	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Fault Operations B Ø	1	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Fault Operations A Ø	0	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Fault Adjusted Amps C Phase V	6.41	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Fault Adjusted Amps B Phase V	6.41	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0697	BreakerVacuum	NA-12KV TR 3	VCB Readings	Unknown Operations	0	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	General Comments		
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	General Comments		
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	C0305	NonLTC	759-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	BCH001351	Charger	546-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	BCH001351	Charger	546-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	BCH001351	Charger	546-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	BCH001351	Charger	546-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	BCH001351	Charger	546-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	BCH001351	Charger	546-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	BCH001351	Charger	546-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	BCH001351	Charger	546-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.900	millivolts
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Follow-up Action Required?	n	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Foundation Condition	Good	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	General Comments		
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	General Comments		
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	B0384	WithLTC	932-Offline Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Grounds in Place?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	BCH001350	Charger	868-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	BCH001350	Charger	868-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	BCH001350	Charger	868-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	BCH001350	Charger	868-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	BCH001350	Charger	868-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	BCH001350	Charger	868-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Maintenance Operations	0	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	BCH001350	Charger	868-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	BCH001350	Charger	868-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Operations Counter AF	158	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Operations Counter AL	159	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Operations This Read Vac	0	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Readings	Switching Operations	0	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001437	BreakerVacuum	790-0530	VCB Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	n	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	ST000030	Structure	802-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Operations Counter AF	198	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Maintenance Operations	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Patrol Inspection	General Comments		
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Follow-up Action Required?	n	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Fault Operations Ground	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Fault Operations C Ø	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Fault Operations B Ø	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Fault Operations A Ø	0	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	BAT000563	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Patrol Inspection	Fault Adjusted Amps A Phase V	0.00	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Amps C Ø	0.0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Amps B Ø	22.0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Amps A Ø	0.0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	9 Month Operations	0	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	SWG000087	Switchgear	NA-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Amps A Ø	60.0	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Amps B Ø	48.0	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	Amps C Ø	67.0	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Bushing Condition	Good	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Fault Operations A Ø	0	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Fault Operations B Ø	0	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Patrol Inspection	Fault Operations C Ø	0	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Fault Operations Ground	0	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0136	WithLTC	NA-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	General Comments		
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Operations Counter	297	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Switching Operations	0	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BK001438	BreakerVacuum	790-0531	VCB Readings	9 Month Operations	36	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Patrol Inspection	Bushing Condition	Good	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	9 Month Operations	6	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Amps A Ø	0.0	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Amps B Ø	0.0	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Readings	Amps C Ø	0.0	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Bushing Condition	Good	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	BB0409	BreakerVacuum	565-4517	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Operations This Read Vac	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0690	BreakerVacuum	NA-1273	VCB Readings	Operations Counter AL	198	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	Oil Temp Present	50	°C
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	Oil Temp Max	60	°C
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	LTC Totalizer Reading	8254.08	kw
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Amps C Ø	230.0	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	K0132	BreakerVacuum	774-2429	VCB Readings	Amps B Ø	230.0	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	General Comments		
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	General Comments		
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Restroom Clean & OK?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Trash Emptied?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	CH000192	ControlHouse	NA-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	BX0732	RecloserElectronic	845-2458	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	MB0146	BreakerVacuum	779-4508	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Fault Operations B Ø	0	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Fault Operations C Ø	0	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Fault Operations Ground	0	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Follow-up Action Required?	n	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Foundation Condition	Good	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	General Comments		
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	General Comments		
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Grounds in Place?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	Totalizer Meter Multiplier	4200	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	Totalizer Meter Reading	1.4020	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	245.00	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Yard Lights Working?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Maintenance Operations	0	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Operations Counter AF	268	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Operations Counter AL	271	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Operations This Read Vac	3	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Switching Operations	2	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Unknown Operations	0	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	General Comments		
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Operations Counter	92	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	FE000834	Fence	790-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	General Comments		
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	General Comments		
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Mechanism Patrol Inspection	General Comments		
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	LTC As Found Counter	231045	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	LTC As Left Counter	231051	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	LTC Max Tap Position	7L	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	General Comments		
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	General Comments		
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	LTC Totalizer Reading	5888.40	kw
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	Oil Temp Max	102	°C
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Readings	Oil Temp Present	60	°C
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	M0072	WithLTC	868-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	LTC Min Tap Position	1R	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	LTC Operations Since Last Insp	871	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LTCC000211	LTCCControl	NA-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LTCC000211	LTCCControl	NA-TRANS 3	LTC Control Insp	General Comments		
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LTCC000211	LTCCControl	NA-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Operations Counter	1454	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Amps C Ø	35.0	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Bushing Condition	Good	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Fault Adjusted Amps A Phase V	5.33	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Fault Operations A Ø	1	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Amps A Ø	158.0	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Amps B Ø	159.0	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Amps C Ø	137.0	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Bushing Condition	Good	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Fault Operations A Ø	0	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Fault Operations B Ø	0	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	LTC Min Tap Position	1L	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	LTC Max Tap Position	3R	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	LTC Current Tap Position	3R	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	LTC As Left Counter	41346	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	LTC As Found Counter	41337	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Mechanism Patrol Inspection	General Comments		
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	General Comments		
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	Follow-up Action Required?	n	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Fault Operations C Ø	0	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Fault Operations Ground	0	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Unknown Operations	0	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Fault Operations A Ø	0	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Fault Operations B Ø	0	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Fault Operations C Ø	0	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Fault Operations Ground	0	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Follow-up Action Required?	n	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Foundation Condition	Good	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	General Comments		
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	General Comments		
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Grounds in Place?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Follow-up Action Required?	n	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Maintenance Operations	0	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Fault Operations A Ø	0	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Fault Operations C Ø	0	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Fault Operations Ground	0	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Follow-up Action Required?	n	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Foundation Condition	Good	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	General Comments		
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	General Comments		
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Grounds in Place?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Maintenance Operations	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	3	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Counter Readings	LTC Operations Since Last Insp	1758	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	M0072	LTCMechanism	868-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	3.0	psi
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Operations Counter AF	293	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Operations Counter AL	293	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	General Comments	fence is rusty with wash out spots on creek side mentioned in previous inspection. some gaps in wire and multiple bends on posts.	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Amps C Ø	26.0	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Amps B Ø	22.0	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	General Comments		
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Operations This Read Vac	0	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Switching Operations	0	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	BX0820	RecloserElectronic	845-2456	Recloser Electronic Patrol Inspection	Amps A Ø	24.0	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	9 Month Operations	18	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	FE000041	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	General Comments		
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	47	°C
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/11/2020 13:31	Distribution	Middletown Quarterly Inspection	PF000235	PowerFuse	MT-STA SER NO 4 LINE	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/11/2020 13:31	Distribution	Middletown Quarterly Inspection	PF000235	PowerFuse	MT-STA SER NO 4 LINE	Disconnect Powerfuse Inspection	General Comments	ok	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Amps A Ø	55.0	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Amps B Ø	40.0	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Amps C Ø	55.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	General Comments		
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Operations Counter	429	
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	140.0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	104.0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	117.0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/11/2020 11:58	Distribution	Rio Quarterly Inspection	CX0069	RecloserHydraulic	759-2451	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	80	°C
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	56	°C
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	90	°C
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	42	°C
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	75	°C
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AL	253	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Operations This Read Vac	2	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Switching Operations	2	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0694	BreakerVacuum	NA-12KV BUS TIE SEC 3	VCB Readings	Unknown Operations	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	130	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	130	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	BCH001322	Charger	779-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	BCH001322	Charger	779-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	BCH001322	Charger	779-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	BCH001322	Charger	779-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	BCH001322	Charger	779-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	BCH001322	Charger	779-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	BCH001322	Charger	779-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
9/11/2020 11:01	Distribution	Somerset 2 Quarterly Inspection	BCH001322	Charger	779-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.1	VDC
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.2	VDC
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	General Comments		
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Ambient Temp	81	°F
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	General Comments		
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Vegetation	None	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	YD000176	Yard	790-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	BCH001375	Charger	680-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	BCH001375	Charger	680-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	BCH001375	Charger	680-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	BCH001375	Charger	680-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	BCH001375	Charger	680-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	BCH001375	Charger	680-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	BCH001375	Charger	680-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	BCH001375	Charger	680-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	*F
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	BAT001389	Battery	802-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	FE000039	Fence	565-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0685	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	B0477	WithLTC	790-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Ambient Temp	77	*F
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	9 Month Operations	0	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Amps A Ø	70.0	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Amps B Ø	40.0	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Readings	Amps C Ø	40.0	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Bushing Condition	Good	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	MB0155	BreakerVacuum	802-0522	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Positive DC Ground	22.4	VDC
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.2	VDC
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	General Comments		
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	YD000455	Yard	774-Yard	Yard Patrol Inspection	Vegetation	None	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Counter Readings	Follow-up Action Required?	n	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	C0469	LTCMechanism	845-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Ambient Temp	76	*F
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	9 Month Operations	12	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Amps A Ø	40.0	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	K0124	BreakerVacuum	680-0555	VCB Readings	Amps B Ø	40.0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	30.00	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	ST000183	Structure	790-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Yard Lights Working?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Vegetation	None	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	95	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	95	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C ∅	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B ∅	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A ∅	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C ∅	190.0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B ∅	230.0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A ∅	220.0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0686	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	15	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	General Comments		
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/11/2020 14:25	Distribution	Winchester Water Quarterly Inspection	YD000300	Yard	680-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LT0137	WithLTC	NA-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	9 Month Operations	4	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Amps A ∅	68.0	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Amps B ∅	38.0	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Readings	Amps C ∅	49.0	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Bushing Condition	Good	
9/11/2020 11:53	Distribution	Somerset South Quarterly Inspection	KB0020	BreakerVacuum	546-0541	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	General Comments		
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Operations Counter	61	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	81	°F
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Amps C ∅	9.0	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Amps B ∅	10.0	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Amps A ∅	10.0	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	LTCC000373	LTCControl	845-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2020 11:05	Distribution	Denham Street Quarterly Inspection	BAT001196	Battery	790-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Current Tap Position	4L	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	General Comments		
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Max Tap Position	11L	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Min Tap Position	2L	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Regulator As Left Counter	77822	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Tank Leaks	None	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	R1486	Regulator	774-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	LTCC000373	LTCControl	845-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	General Comments		
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LTCC000213	LTCControl	NA-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	paralleIPAR	Position
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LTCC000213	LTCControl	NA-TRANS 2	LTC Control Insp	General Comments		
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LTCC000213	LTCControl	NA-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LTCC000212	LTCControl	NA-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	paralleIPAR	Position
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LTCC000212	LTCControl	NA-TRANS 1	LTC Control Insp	General Comments		
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LTCC000212	LTCControl	NA-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	Follow-up Action Required?	n	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	General Comments		
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Mechanism Patrol Inspection	General Comments	oil filter changed for ltc causing oil level to fall farther	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	LTC As Found Counter	76903	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	LTC As Left Counter	76935	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	LTC Current Tap Position	5L	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	LTC Max Tap Position	2L	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	LTC Min Tap Position	14L	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	LTC Operations Since Last Insp	909	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Very Low	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	General Comments		
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Operations Counter	220	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Amps C Ø	12.0	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Amps B Ø	9.0	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	CX0885	RecloserElectronic	774-2467	Recloser Electronic Patrol Inspection	Amps A Ø	11.0	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/11/2020 12:24	Distribution	Somerset GE Quarterly Inspection	ST000040	Structure	565-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Trash Emptied?	n	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	General Comments		
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Floor Swept?	n	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	General Comments		
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Amps C Ø	42.0	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Amps B Ø	38.0	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	CX0131	RecloserElectronic	845-2457	Recloser Electronic Patrol Inspection	Amps A Ø	37.0	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Operations Counter	3	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/11/2020 11:27	Distribution	New Haven Quarterly Inspection	KX0098	RecloserElectronic	604-2333	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	LTCC000373	LTCControl	845-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Operations Counter AF	225	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Operations Counter AL	225	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	80	*F
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	BAT000160	Battery	868-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	LTCC000373	LTCControl	845-1	LTC Control Insp	LTC Output Voltage Level	1234.0	VAC
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	LTCC000373	LTCControl	845-1	LTC Control Insp	LTC Operation Checked?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	LTCC000373	LTCControl	845-1	LTC Control Insp	General Comments		
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Amps A Ø	65.0	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Broom on Site?	n	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Amps B Ø	65.0	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Amps C Ø	65.0	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/11/2020 6:39	Distribution	Clarkson Quarterly Inspection	CX0112	RecloserElectronic	597-2405	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	LTCC000373	LTCControl	845-1	LTC Control Insp	All Connections OK?	y	
9/11/2020 13:57	Distribution	Sonora Quarterly Inspection	LTCC000373	LTCControl	845-1	LTC Control Insp	Follow-up Action Required?	n	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	CH000244	ControlHouse	868-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	General Comments		
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Mechanism Patrol Inspection	General Comments		
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	LTC As Found Counter	84215	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	LTC As Left Counter	84217	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	LTC Max Tap Position	4R	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	LTC Min Tap Position	4L	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	130.0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	200.0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	180.0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	LTC Operations Since Last Insp	668	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Amps C Ø	20.0	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Foundation Condition	Good	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Amps B Ø	12.0	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	General Comments		
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Operations Counter	1972	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	161	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Amps A Ø	12.0	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/11/2020 10:14	Distribution	Somerset 1 Quarterly Inspection	0981	LTCMechanism	802-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/11/2020 12:50	Distribution	Nachand Quarterly Inspection	LB0683	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	161	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	General Comments		
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Patrol Inspection	Grounds in Place?	y	
9/11/2020 13:39	Distribution	Somerset 3 Quarterly Inspection	KB0115	BreakerVacuum	868-4500	VCB Readings	Maintenance Operations	0	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	Follow-up Action Required?	n	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	C0439	LTCMechanism	774-1	LTC Counter Readings	General Comments		
9/11/2020 11:43	Distribution	Hodgenville Quarterly Inspection	MX0323	RecloserElectronic	774-2431	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1300	psi
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.5	psi
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Readings	X1 Winding Temp Max	55	°C
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Max	53	°C
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Present	45	°C
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Readings	General Comments	Oil Temp guage is bad, Pic sent to stinson	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Readings	Follow-up Action Required?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0113	WithLTC	Retired Distribution	LTC Transformer Readings	X1 Winding Temp Present	45	°C
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	General Comments	leak in tap changer cabinet	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Counter Readings	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Found Counter	37999	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Left Counter	37999	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Current Tap Position	6R	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Max Tap Position	10R	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Min Tap Position	1R	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Operations Since Last Insp	639	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0113	LTCMechanism	Retired Distribution	LTC Counter Readings	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1000	psi
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Present	50	°C
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Readings	Oil Temp Max	59	°C
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Readings	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Readings	X1 Winding Temp Present	52	°C
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Readings	X1 Winding Temp Max	60	°C
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0109	WithLTC	Retired Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Found Counter	10351	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC As Left Counter	10351	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Current Tap Position	9R	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Max Tap Position	14R	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Min Tap Position	2R	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Counter Readings	LTC Operations Since Last Insp	394	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Counter Readings	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Counter Readings	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LTCC000283	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LTCC000283	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LTCC000283	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0109	LTCMechanism	Retired Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LTCC000597	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LTCC000597	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LTCC000597	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BCH000033	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	3.5	amps
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BCH000033	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BCH000033	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BCH000033	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BCH000033	Charger	Retired Distribution	Battery Charger Patrol Insp	Ground Lights	None	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BCH000033	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	134.5	VDC
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BCH000033	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	134.5	VDC
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BCH000033	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	9.200	millivolts
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BAT000141	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	General Comments		
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Follow-up Action Required?	n	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Fault Operations Ground	0	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Min Tap Position	16L	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Max Tap Position	1L	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Fault Operations C ∅	0	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Fault Operations B ∅	0	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Min Tap Position	16L	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A ∅	0.0	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C ∅	0.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Winding Temp Max	40	°C
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	General Comments	10-OPS 3-c-g/3B-G/2-C-G	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Grounds in Place?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	9 Months Operations	0	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Regulator As Left Counter	38553	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4656	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Maintenance Operations	0	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3600	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Amps A ∅	355.0	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Amps B ∅	200.0	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Amps C ∅	150.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	BCH001404	Charger	798-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	BCH001404	Charger	798-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	BCH001404	Charger	798-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	BCH001404	Charger	798-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Fault Operations A Ø	0	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	General Comments		
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	BCH001404	Charger	798-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	BCH001404	Charger	798-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	BCH001404	Charger	798-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	BCH001404	Charger	798-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Current Tap Position	7L	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Bushing Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Unknown Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Switching Operations	0	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Operations This Read Vac	10	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Operations Counter AL	233	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Operations Counter AF	233	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Readings	Winding Temp Present	66	°C
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0264	GroundTransformer	SSC-Offline-Distribution	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	88	*F
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Readings	Oil Temp Present	62	*C
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	2000	psi
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	General Comments	secondary needs wildlife protection installed	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Readings	General Comments	ok	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Patrol Inspection	General Comments		
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	General Comments		
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Maintenance Operations	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Operations Counter AF	455	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.1	VDC
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LTCC000098	LTCControl	WO-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LTCC000098	LTCControl	WO-TRANS 2	LTC Control Insp	General Comments		
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Unknown Operations	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LTCC000098	LTCControl	WO-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Operations Counter AL	455	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Operations This Read Vac	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Switching Operations	0	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Operations Counter	109	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Current Tap Position	7L	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Unknown Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	1	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Winding Temp Present	40	*C
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	General Comments		
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Amps C Ø	26.0	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Amps B Ø	21.0	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	X0321	RecloserElectronic	894-0577	Recloser Electronic Patrol Inspection	Amps A Ø	46.0	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Regulator As Left Counter	27894	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3984	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Max Tap Position	6R	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	General Comments		
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	BAT001080	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Fault Operations A Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	88	*F
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Bushing Condition	Good	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Amps C Ø	50.0	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Amps B Ø	90.0	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Amps A Ø	100.0	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	Totalizer Meter Multiplier	6000	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	Oil Temp Present	40	°C
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	Oil Temp Max	60	°C
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Amps B Ø	0.0	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	Oil Temp Max	50	°C
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.8	psi
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	General Comments	Trans needs nitrogen	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Min	.40	MegaWatts
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	MegaWatt Demand Meter Max	1.60	MegaWatts
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Min	-.35	MegaVars
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	MegaVar Demand Meter Max	.25	MegaVars
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	General Comments		
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Operations This Read Vac	2	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Operations Counter AL	99956	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Operations Counter AF	99956	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Maintenance Operations	1	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Grounds in Place?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	General Comments	Repair Arrestors Txfmr & TC	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	General Comments		
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Foundation Condition	Good	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Follow-up Action Required?	n	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Fault Operations Ground	0	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Fault Operations C Ø	0	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Fault Operations B Ø	0	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	General Comments	ok	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	L70263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Amps C Ø	0.0	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Bushing Condition	Good	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	General Comments		
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	BAT001469	Battery	798-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	General Comments		tower leg foundations crumbling, as well as transformer
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Foundation Condition	Crumbling	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	ST000020	Structure	494-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	LTC Totalizer Reading	6978.00	kw
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	General Comments		
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	ST000160	Structure	815-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	General Comments		
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	RC000348	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	RC000348	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	9 Month Operations	2	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	Oil Temp Max	35	°C
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1912.32	kw
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	General Comments		Wasp nest in control cabinet, needs repair from rust hole lower rt.
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	General Comments		
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps A Ø	0.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps B Ø	0.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps C Ø	0.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	PF000226	PowerFuse	MG-STA SER NO 5	Disconnect Powerfuse Inspection	General Comments	ok	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	PF000226	PowerFuse	MG-STA SER NO 5	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Unknown Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Switching Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations This Read AM	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AL	485	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Regulator As Left Counter	27866	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0105	Regulator	481-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	40	°C
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Operations A Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	0	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	9 Month Operations	4	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Operations B Ø	0	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Operations C Ø	0	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Fault Operations Ground	0	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Operations Counter	113	
9/10/2020 13:17	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Follow-up Action Required?	n	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Patrol Inspection	General Comments		
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	General Comments		
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0104	Regulator	481-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Maintenance Operations	0	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Operations Counter AF	419	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Operations Counter AL	419	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Operations This Read AM	0	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Switching Operations	0	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0571	BreakerAirMagnetic	LN-3	AMCB Readings	Unknown Operations	0	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Switching Operations	0	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Unknown Operations	2	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Fault Operations B Ø	0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Fault Operations A Ø	0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	General Comments		
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	General Comments		
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	75.00	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0263	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushing Condition	Good	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #~'s
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	76	°F
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BAT001120	Battery	836-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	FE000201	Fence	736-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	Oil Temp Present	35	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AF	485	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	PF000225	PowerFuse	MG-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	ok	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	PF000225	PowerFuse	MG-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	PF000224	PowerFuse	MG-STA SER NO 3	Disconnect Powerfuse Inspection	General Comments	ok	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	PF000224	PowerFuse	MG-STA SER NO 3	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	W0363	NonLTC	596-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Amps A Ø	0.0	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	40.00	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	B0317	WithLTC	836-1	LTC Transformer Readings	Totalizer Meter Reading	1.1630	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Readings	Switching Operations	1	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BB0416	BreakerVacuum	596-1498	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0642	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	50	°C
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	40	°C
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN40	WithLTC	LN-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	60	°C
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	PF000221	PowerFuse	MG-14KV BUS SEC A POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	PF000221	PowerFuse	MG-14KV BUS SEC A POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	PF000220	PowerFuse	MG-1322 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	PF000220	PowerFuse	MG-1322 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Operations Counter AF	99980	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Maintenance Operations	0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Grounds in Place?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	General Comments		
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	General Comments		
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Foundation Condition	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Follow-up Action Required?	n	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Fault Operations Ground	0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Fault Operations C Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	28.33	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Readings	Oil Temp Max	50	°C
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Readings	Oil Temp Present	40	°C
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Readings	Winding Temp Max	48	°C
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Readings	Winding Temp Present	40	°C
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Operating Linkage OK?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Ground Connections Intact?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	General Comments	ok	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Foundation Condition	Good	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	ST000154	Structure	142-Structure 34.5	Structure Patrol Inspection	All Identified and Legible?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Vegetation	None	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	General Comments	ok	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	YD000150	Yard	142-Yard	Yard Patrol Inspection	Ambient Temp	83	°F
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	General Comments	ok	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	FE000151	Fence	142-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Regulator As Left Counter	27946	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Switching Operations	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Unknown Operations	0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/10/2020 13:17	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	Totalizer Meter Reading	.7900	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	Oil Temp Present	45	°C
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	Oil Temp Max	69	°C
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.5	psi
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	LTC Totalizer Reading	5688.00	kw
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	1L	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	General Comments		
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	3R	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	12L	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	65987	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	General Comments		
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	General Comments		
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 13:17	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Readings	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000247	NonLTC	MG-TRANS 2 A PHASE	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	General Comments		
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	100.00	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	7192.80	kw
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	General Comments		
9/10/2020 13:17	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	General Comments	added 3 lbs nitrogen	
9/10/2020 13:17	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	LTC Totalizer Reading	11318.40	kw
9/10/2020 13:17	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	9 Months Operations	1	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Amps A Ø	0.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Amps B Ø	0.0	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Grounds in Place?	y	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	General Comments		
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	General Comments		
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Foundation Condition	Good	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Follow-up Action Required?	n	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Fault Operations Ground	0	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Fault Operations C Ø	0	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Fault Operations B Ø	0	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Fault Operations A Ø	0	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Fault Adjusted Amps C Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	9 Months Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Amps A Ø	329.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Amps B Ø	311.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Amps C Ø	331.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Unknown Operations	0	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	General Comments		
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Foundation Condition	Good	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Follow-up Action Required?	n	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Fault Operations Ground	0	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Fault Operations C Ø	0	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Fault Operations B Ø	0	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Fault Operations A Ø	0	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Bushing Condition	Good	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Amps C Ø	54.0	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	M0078	WithLTC	570-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Unknown Operations	0	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Switching Operations	0	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Operations This Read Vac	1	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Operations Counter AL	194	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Operations Counter AF	194	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Maintenance Operations	1	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Readings	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	8.33	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Readings	Oil Temp Max	49	°C
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Unknown Operations	0	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Switching Operations	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Operations This Read Vac	24	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Operations Counter AL	333	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Operations Counter AF	333	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Maintenance Operations	23	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Patrol Inspection	Grounds in Place?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Readings	Oil Temp Present	42	°C
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Readings	Winding Temp Max	48	°C
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000248	NonLTC	MG-TRANS 2 B PHASE	NonLTC Transformer Readings	Winding Temp Present	42	°C
9/10/2020 13:17	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 13:17	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/10/2020 13:17	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 13:17	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	Follow-up Action Required?	n	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Fault Operations A Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Fault Operations B Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Fault Operations C Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Fault Operations Ground	0	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Follow-up Action Required?	n	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Foundation Condition	Good	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	General Comments		
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	General Comments	1- Trip Check	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Grounds in Place?	y	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Maintenance Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Operations Counter AF	242	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Operations Counter AL	242	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	LTC Operations Since Last Insp	278	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	LTC Min Tap Position	1L	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	LTC Max Tap Position	4R	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	LTC Current Tap Position	2R	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	LTC As Left Counter	127937	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	LTC As Found Counter	127937	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Mechanism Patrol Inspection	General Comments		
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	General Comments		
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	B0475	LTCMechanism	727-1	LTC Counter Readings	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Operations This Read AM	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Switching Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Unknown Operations	0	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Maintenance Operations	1	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	General Comments		
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	LTC As Found Counter	35887	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	LTC As Left Counter	35887	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	LTC Current Tap Position	7L	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	LTC Max Tap Position	5R	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	LTC Min Tap Position	11L	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Operations Counter AF	147	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Operations Counter AL	147	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Operations This Read Vac	1	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	General Comments		
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	FE000312	Fence	836-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Switching Operations	0	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Unknown Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	9 Month Operations	0	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Fault Operations A Ø	0	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Fault Operations B Ø	0	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Fault Operations C Ø	0	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Fault Operations Ground	0	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	9 Months Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Amps A Ø	467.4	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	8.33	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000224	NonLTC	SSC-Offline-Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Amps B Ø	578.0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Amps C Ø	644.0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Bushing Condition	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Fault Operations A Ø	0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Fault Operations B Ø	0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Fault Operations C Ø	0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Fault Operations Ground	0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Follow-up Action Required?	n	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Foundation Condition	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	General Comments		
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	General Comments		
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Grounds in Place?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Maintenance Operations	0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Operations Counter AF	252	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Operations Counter AL	252	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Operations This Read Vac	0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Switching Operations	0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Unknown Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Amps B Ø	435.4	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0638	BreakerAirMagnetic	MG-4KV TR 2	AMCB Readings	Amps C Ø	436.9	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	75.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	75.0	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	General Comments		
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Follow-up Action Required?	n	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Patrol Inspection	General Comments		
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	General Comments		
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Maintenance Operations	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Operations Counter AF	369	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Operations Counter AL	369	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Operations This Read Vac	0	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Ambient Temp	76	°F
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Readings	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	8.33	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Readings	Oil Temp Max	48	°C
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Readings	Oil Temp Present	40	°C
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Readings	Winding Temp Max	47	°C
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	TX000246	NonLTC	MG-TRANS 2 C PHASE	NonLTC Transformer Readings	Winding Temp Present	40	°C
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	YD000316	Yard	836-Yard	Yard Patrol Inspection	Vegetation	None	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	General Comments		
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1414	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	ST000323	Structure	836-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	2092	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Operations Counter AL	376	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Operations This Read AM	1	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Switching Operations	1	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Unknown Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0315	LTCMechanism	WO-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Panels Dusted?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	SWG000135	Switchgear	MG-4KV Sec 2 Swgr	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	SWG000136	Switchgear	MG-14KV Sec C Swgr	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	SWG000136	Switchgear	MG-14KV Sec C Swgr	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	SWG000136	Switchgear	MG-14KV Sec C Swgr	Switchgear Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	SWG000136	Switchgear	MG-14KV Sec C Swgr	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	SWG000136	Switchgear	MG-14KV Sec C Swgr	Switchgear Patrol Inspection	Panels Dusted?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	SWG000136	Switchgear	MG-14KV Sec C Swgr	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Amps A \emptyset	0.0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Amps B \emptyset	0.0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Amps C \emptyset	0.0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Fault Operations A \emptyset	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Fault Operations B \emptyset	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Fault Operations C \emptyset	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1156	BreakerVacuum	WO-1176	VCB Readings	Fault Operations Ground	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	General Comments		
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Platform/Walkway/Railing OK?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	573	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	573	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	ST000645	Structure	WO-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps C Ø	0.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps B Ø	0.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps A Ø	0.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Maintenance Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Operations Counter AF	99969	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Operations Counter AL	99969	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Operations This Read AM	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Switching Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Unknown Operations	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Operations This Read Vac	0	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	3R	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Operations Counter AL	405	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	Totalizer Meter Reading	.9576	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	Winding Temp Present	0	°C
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/10/2020 13:17	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
9/10/2020 13:17	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	Oil Temp Max	80	°C
9/10/2020 13:17	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	Oil Temp Present	55	°C
9/10/2020 13:17	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/10/2020 13:17	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Operations Counter AF	405	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	BAT000471	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	BAT000471	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	BAT000471	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	BAT000471	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	BAT000471	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	.7	VDC
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	BAT000471	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	3.9	VDC
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	BAT000471	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	BAT000471	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	General Comments		
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Readings	General Comments		
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Readings	Oil Temp Max	40	°C
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Readings	Oil Temp Present	30	°C
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0224	NonLTC	693-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Maintenance Operations	0	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Current Tap Position	5L	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Maintenance Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Operations Counter AF	314	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	General Comments		
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Max Tap Position	4R	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Min Tap Position	9L	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.0	volts
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Regulator As Left Counter	31269	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Unknown Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Switching Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations This Read AM	0	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Tank Leaks	None	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Current Tap Position	7L	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	General Comments		
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Max Tap Position	1L	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Min Tap Position	11L	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	122.0	volts
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Regulator As Left Counter	26451	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Tank Leaks	None	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1459	Regulator	006-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Operations Counter AL	314	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Operations This Read AM	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Switching Operations	0	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AL	1432	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AF	1432	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0613	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	75	*F
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	LTC Current Tap Position	6L	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	LTC As Left Counter	92420	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	LTC As Found Counter	92420	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	General Comments		
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Fault Operations C Ø	0	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Fault Operations Ground	0	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Operations Counter AF	276	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Operations Counter AL	276	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Operations This Read AM	0	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Switching Operations	0	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Unknown Operations	0	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Follow-up Action Required?	n	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Foundation Condition	Good	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	General Comments	ok	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	General Comments	ok	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Grounds in Place?	y	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Maintenance Operations	0	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Operations Counter AF	141	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Operations Counter AL	141	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Operations This Read Vac	0	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Switching Operations	0	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Unknown Operations	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	9 Month Operations	3	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Vegetation	None	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	General Comments		
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	YD000200	Yard	736-Yard	Yard Patrol Inspection	Ambient Temp	82	*F
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	General Comments	ok	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	RC000348	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	RC000348	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	RC000348	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	RC000348	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	RC000348	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	RC000348	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	233	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Ambient Temp	84	°F
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	FE000158	Fence	815-Fence	Fence Patrol Inspection	General Comments	ok	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	T0170	NonLTC	142-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	General Comments		
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Patrol Inspection	General Comments		
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Follow-up Action Required?	n	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Fault Operations Ground	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Fault Operations C Ø	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Fault Operations B Ø	0	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	RC000348	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	58.0	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	RC000348	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	57.0	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	RC000348	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	65.0	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	RC000348	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	RC000348	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Fault Operations A Ø	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	9 Month Operations	1	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Amps A Ø	160.0	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Amps B Ø	105.0	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Amps C Ø	115.0	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Bushing Condition	Good	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	9 Months Operations	0	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Amps A Ø	0.0	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Amps B Ø	0.0	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Amps C Ø	0.0	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Fault Operations A Ø	0	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Fault Operations B Ø	0	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Fault Operations C Ø	0	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Fault Operations Ground	0	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Follow-up Action Required?	n	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Patrol Inspection	General Comments		
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	General Comments		
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0575	BreakerAirMagnetic	LN-SEC 1 SPARE	AMCB Readings	Maintenance Operations	0	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Unknown Operations	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Amps C Ø	110.0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Amps B Ø	99.0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Amps A Ø	158.0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Fault Operations A Ø	0	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	K0112	BreakerVacuum	815-1907	VCB Readings	Fault Operations B Ø	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	Vegetation	None	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	YD000155	Yard	815-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	2039	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	LTC Min Tap Position	10L	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0225	LTCMechanism	WO-TRANS 1	LTC Counter Readings	LTC Max Tap Position	8R	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BAT000340	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	General Comments		
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	General Comments		
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Foundation Condition	Good	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	75.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0623	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Fault Operations Ground	0	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Fault Operations C Ø	0	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Fault Operations B Ø	0	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Fault Operations A Ø	0	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Fault Adjusted Amps C Phase V	1.93	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Fault Adjusted Amps B Phase V	1.93	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Fault Adjusted Amps A Phase V	1.93	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Bushing Condition	Good	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Amps C Ø	10.0	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Fault Operations A Ø	0	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Fault Operations B Ø	0	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Fault Operations C Ø	0	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Fault Operations Ground	0	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Follow-up Action Required?	n	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Foundation Condition	Good	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	General Comments		
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	General Comments		
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Grounds in Place?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Maintenance Operations	0	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Operations Counter AF	115	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Operations Counter AL	115	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Operations This Read Vac	1	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Switching Operations	1	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Positive DC Ground	11.8	VDC
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Negative DC Ground	12.2	VDC
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	General Comments		
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Unknown Operations	0	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	7200	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	S0045	NonLTC	798-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9990	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Fault Operations A Ø	0	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Fault Operations B Ø	0	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Fault Operations C Ø	0	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Water Added	If low,note cell #'s
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	*F
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BAT001127	Battery	570-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Adequate	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 13:17	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/10/2020 13:17	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	LTC Operations Since Last Insp	2173	
9/10/2020 13:17	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	LTC Min Tap Position	12L	
9/10/2020 13:17	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	LTC Max Tap Position	4R	
9/10/2020 13:17	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	LTC Current Tap Position	Neutral	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Amps B Ø	53.0	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Amps A Ø	39.0	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0160	BreakerVacuum	537-0534	VCB Readings	9 Month Operations	28	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Switching Operations	0	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Patrol Inspection	Bushing Condition	Good	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Amps C Ø	41.0	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Amps B Ø	86.0	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Amps A Ø	42.0	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0134	BreakerVacuum	467-1914	VCB Readings	9 Month Operations	4	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Operations This Read Vac	0	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Operations Counter AL	184	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Operations Counter AF	184	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Maintenance Operations	0	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Grounds in Place?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	General Comments		
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	General Comments		
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Foundation Condition	Good	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Follow-up Action Required?	n	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Fault Operations Ground	0	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Fault Operations C Ø	0	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Fault Operations B Ø	0	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Fault Operations A Ø	0	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Unknown Operations	1	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Switching Operations	0	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Operations This Read Vac	2	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Operations Counter AL	220	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Operations Counter AF	220	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	9 Month Operations	5	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Amps A Ø	100.0	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Amps B Ø	100.0	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Amps C Ø	150.0	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Bushing Condition	Good	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0130	BreakerVacuum	771-1643	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Amps C Ø	151.0	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Maintenance Operations	1	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Patrol Inspection	Grounds in Place?	y	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	BAT000471	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	3R	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/10/2020 9:46	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/10/2020 9:46	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/10/2020 9:46	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
9/10/2020 9:46	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	.3	VDC
9/10/2020 9:46	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	.9	VDC
9/10/2020 9:46	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/10/2020 9:46	Distribution	Island Quarterly Inspection	BAT000333	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	General Comments		
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	General Comments		
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	LTC Totalizer Reading	9192.96	kw
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	Oil Temp Max	70	°C
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	157293	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Fault Operations A Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Fault Operations B Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Fault Operations C Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Fault Operations Ground	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0606	BreakerAirMagnetic	MG-1328	AMCB Readings	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Fault Operations Ground	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Follow-up Action Required?	n	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Unknown Operations	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1157	BreakerVacuum	WO-1177	VCB Readings	Switching Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	General Comments		
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Unknown Operations	0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Switching Operations	0	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	4L	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	6R	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Operations This Read Vac	0	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	General Comments	ok	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0479	Regulator	SSC-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0172	BreakerVacuum	093-BT6-5	VCB Readings	Operations Counter AL	99980	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	Oil Temp Present	34	°C
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1458	Regulator	006-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	LTC As Left Counter	299786	
9/10/2020 13:17	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	LTC As Found Counter	299797	
9/10/2020 13:17	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Mechanism Patrol Inspection	General Comments		
9/10/2020 13:17	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	General Comments		
9/10/2020 13:17	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 13:17	Distribution	London Quarterly Inspection	LTCM000058	LTCMechanism	093-5	LTC Counter Readings	Follow-up Action Required?	n	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Amps B Ø	10.0	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Amps A Ø	10.0	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0069	BreakerVacuum	006-1602	VCB Readings	9 Month Operations	4	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Fault Operations Ground	0	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Follow-up Action Required?	n	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Foundation Condition	Good	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	General Comments		
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	General Comments		
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Amps B Ø	145.0	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Amps A Ø	140.0	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Accumulated Fault Duty C Ph V	.72	%
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	W0329	WithLTC	641-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	Accumulated Fault Duty A Ph V	.36	%
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001159	BreakerVacuum	850-4512	VCB Readings	9 Month Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Amps C Ø	0.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Fault Operations A Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Fault Operations B Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0643	BreakerAirMagnetic	MG-GND TR 5	AMCB Readings	Fault Operations C Ø	0	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	BAT000471	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Grounds in Place?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Maintenance Operations	0	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Operations Counter AF	299	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Operations Counter AL	299	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Operations This Read Vac	0	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Switching Operations	0	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Unknown Operations	0	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	218279	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	5L	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	6R	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments	ok	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0480	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	BAT000471	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	83	*F
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	BAT000471	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	BAT000471	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps B Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps A Ø	0.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Unknown Operations	0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Switching Operations	1	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Operations This Read Vac	1	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Operations Counter AL	413	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Operations Counter AF	413	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Unknown Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Switching Operations	0	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	Follow-up Action Required?	n	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	General Comments		
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Mechanism Patrol Inspection	General Comments		
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	LTC As Found Counter	13388	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	LTC As Left Counter	13401	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	LTC Current Tap Position	4R	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	LTC Max Tap Position	12R	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	LTC Min Tap Position	5L	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Operations This Read AM	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Operations Counter AL	246	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Operations Counter AF	246	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Maintenance Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	SWG000176	Switchgear	WO-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Fault Operations Ground	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Fault Operations C Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Fault Operations B Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Fault Operations A Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Maintenance Operations	0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Grounds in Place?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	General Comments		
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	General Comments		
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Foundation Condition	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Grounds in Place?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Amps C Ø	0.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Amps B Ø	0.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Amps A Ø	0.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	9 Months Operations	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Fault Operations A Ø	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	General Comments		
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	General Comments		
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Foundation Condition	Good	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Follow-up Action Required?	n	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Fault Operations Ground	0	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Fault Operations C Ø	0	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Fault Operations B Ø	0	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Fault Operations A Ø	0	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Unknown Operations	0	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	General Comments		
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Unknown Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Switching Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Operations This Read AM	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Operations Counter AL	444	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Operations Counter AF	444	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Maintenance Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0630	BreakerAirMagnetic	MG-417	AMCB Readings	Fault Operations Ground	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Amps C Ø	313.0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Amps B Ø	324.0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Amps A Ø	321.0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Bushing Condition	Good	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Amps C Ø	67.0	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Amps B Ø	45.0	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Amps A Ø	68.0	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Switching Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations This Read AM	0	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	9 Month Operations	42	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	9 Month Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AL	504	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AF	504	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0621	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	General Comments		
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Fault Operations Ground	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Fault Operations Ground	0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Fault Operations C Ø	0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Fault Operations B Ø	0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Fault Operations A Ø	0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	LTC Operations Since Last Insp	1200	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	W0329	LTCMechanism	641-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	50.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Amps C Ø	25.3	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Amps B Ø	27.2	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	50.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	50.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0622	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Unknown Operations	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Maintenance Operations	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	General Comments		
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.9	VDC
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.2	VDC
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	General Comments	ok	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	86	°F
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Amps A Ø	19.5	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0635	BreakerAirMagnetic	MG-4KV REA TIE	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Patrol Inspection	Bushing Condition	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Amps C Ø	287.0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Amps B Ø	240.0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Amps A Ø	300.0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0077	BreakerVacuum	093-0201	VCB Readings	9 Month Operations	14	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	BAT001418	Battery	142-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Patrol Inspection	General Comments		
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Fault Operations Ground	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Switching Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Operations This Read AM	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Operations Counter AL	40	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Amps C Ø	521.0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Amps B Ø	565.0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Amps A Ø	591.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BCH000134	Charger	MG-Battery Charger-Distribution	Battery Charger Patrol Insp	General Comments		
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Fault Adjusted Amps A Phase V	13.43	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Fault Adjusted Amps B Phase V	13.43	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Fault Operations A Ø	1	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Fault Operations B Ø	1	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Fault Operations C Ø	0	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Fault Operations Ground	0	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Follow-up Action Required?	n	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Foundation Condition	Good	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	General Comments		
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	General Comments		
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Grounds in Place?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Maintenance Operations	2	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Operations Counter AF	189	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Operations Counter AL	191	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Operations This Read Vac	5	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Switching Operations	1	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Unknown Operations	0	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	9 Month Operations	1	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Amps A Ø	133.0	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Amps B Ø	149.0	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Amps C Ø	118.0	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Bushing Condition	Good	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Fault Operations A Ø	0	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Fault Operations B Ø	0	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Fault Operations C Ø	0	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Fault Operations Ground	0	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Follow-up Action Required?	n	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Foundation Condition	Good	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	General Comments		
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	General Comments		
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Grounds in Place?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Maintenance Operations	0	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Operations Counter AF	190	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Operations Counter AL	190	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Operations This Read Vac	0	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	SWG000127	Switchgear	LN-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Switching Operations	0	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000900	BreakerVacuum	439-1612	VCB Readings	Unknown Operations	0	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	9 Month Operations	8	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Bushing Condition	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Amps C Ø	102.0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Amps B Ø	101.0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Amps A Ø	85.0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Operations This Read Vac	2	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Switching Operations	1	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Unknown Operations	0	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	9 Month Operations	1	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	LTC Operations Since Last Insp	1007	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	LTC Min Tap Position	7L	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	LTC Max Tap Position	4R	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	LTC Current Tap Position	1L	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	LTC As Left Counter	232783	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	LTC As Found Counter	232783	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Mechanism Patrol Inspection	General Comments		
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	General Comments		
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	B0317	LTCMechanism	836-1	LTC Counter Readings	Follow-up Action Required?	n	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	General Comments		
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	9 Month Operations	7	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Amps A Ø	77.0	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Amps B Ø	82.0	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Readings	Amps C Ø	100.0	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Bushing Condition	Good	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	SWG000050	Switchgear	MG-4KV Sec 1 Swgr	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	SWG000050	Switchgear	MG-4KV Sec 1 Swgr	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	SWG000050	Switchgear	MG-4KV Sec 1 Swgr	Switchgear Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	SWG000050	Switchgear	MG-4KV Sec 1 Swgr	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	SWG000050	Switchgear	MG-4KV Sec 1 Swgr	Switchgear Patrol Inspection	Panels Dusted?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	SWG000050	Switchgear	MG-4KV Sec 1 Swgr	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	ST000080	Structure	537-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000899	BreakerVacuum	736-1911	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	BCH000237	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments	ok	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	BCH000237	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	BCH000237	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.3	VDC
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BCH000134	Charger	MG-Battery Charger-Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BCH000134	Charger	MG-Battery Charger-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	133.1	VDC
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BCH000134	Charger	MG-Battery Charger-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	133.1	VDC
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BCH000134	Charger	MG-Battery Charger-Distribution	Battery Charger Patrol Insp	Battery Charger Current	6.1	amps
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BCH000134	Charger	MG-Battery Charger-Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BCH000134	Charger	MG-Battery Charger-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	9 Month Operations	1	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Amps A Ø	38.0	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Amps B Ø	76.0	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Amps C Ø	54.0	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Bushing Condition	Good	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Fault Operations A Ø	0	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Fault Operations B Ø	0	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Fault Operations C Ø	0	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Fault Operations Ground	0	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Follow-up Action Required?	n	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Foundation Condition	Good	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	General Comments	ok	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	General Comments	ok	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Grounds in Place?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Maintenance Operations	0	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Operations Counter AF	187	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Operations Counter AL	187	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Operations This Read Vac	0	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Switching Operations	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Operations Counter AL	363	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Operations Counter AF	363	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Unknown Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Switching Operations	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Unknown Operations	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Switching Operations	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Operations This Read Vac	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Operations This Read AM	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Operations Counter AL	476	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Operations Counter AF	476	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Maintenance Operations	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	General Comments		
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Patrol Inspection	General Comments		
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	BK000902	BreakerVacuum	142-1666	VCB Readings	Unknown Operations	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Follow-up Action Required?	n	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Fault Operations Ground	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Fault Operations C Ø	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Fault Operations B Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Maintenance Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Fault Operations Ground	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Fault Operations C Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Fault Operations B Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Fault Operations A Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Operations Counter AL	224	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1162	BreakerVacuum	WO-12KV TR 1	VCB Readings	Operations Counter AF	224	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0608	BreakerAirMagnetic	MG-1330	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Unknown Operations	0	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Switching Operations	8	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Operations This Read Vac	8	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Operations Counter AL	212	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Operations Counter AF	212	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	BK001436	BreakerVacuum	494-0575	VCB Readings	Maintenance Operations	0	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Amps A Ø	244.0	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Amps B Ø	255.0	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Amps C Ø	354.0	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Bushing Condition	Good	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Fault Adjusted Amps A Phase V	10.13	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Fault Adjusted Amps B Phase V	15.20	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Fault Adjusted Amps C Phase V	5.07	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Fault Operations A Ø	1	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	UG Pothead Condition Good?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Fault Operations B Ø	2	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Fault Operations C Ø	0	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Fault Operations Ground	0	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Follow-up Action Required?	n	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Foundation Condition	Good	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	General Comments		
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	General Comments		
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Grounds in Place?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Maintenance Operations	0	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Operations Counter AF	183	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Operations Counter AL	183	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Operations This Read Vac	4	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Switching Operations	0	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BK000901	BreakerVacuum	439-1609	VCB Readings	Unknown Operations	1	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	General Comments		
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	FE000316	Fence	641-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	ST000217	Structure	693-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	118	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	LTC Min Tap Position	9L	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	LTC Max Tap Position	5L	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	LTC Current Tap Position	8L	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	LTC As Left Counter	7156	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	LTC As Found Counter	7156	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	General Comments		
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN40	LTCMechanism	LN-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Unknown Operations	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Switching Operations	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1160	BreakerVacuum	WO-1180	VCB Readings	Operations This Read Vac	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	PF000209	PowerFuse	MG-464 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	PF000210	PowerFuse	MG-411 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	PF000210	PowerFuse	MG-411 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	General Comments	ok	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	General Comments	secondary of xfmr needswildlife protection installed.	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	315.84	kw
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	Oil Temp Max	53	°C
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	Oil Temp Present	45	°C
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	W0245	NonLTC	212-5	NonLTC Transformer Readings	Totalizer Meter Reading	.3948	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	PF000213	PowerFuse	MG-4KV REA TIE POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	PF000213	PowerFuse	MG-4KV REA TIE POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	PF000214	PowerFuse	MG-4KV TFR POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	PF000214	PowerFuse	MG-4KV TFR POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	PF000215	PowerFuse	MG-451 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	PF000215	PowerFuse	MG-451 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	Totalizer Meter Reading	.8568	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	Oil Temp Present	36	°C
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	Oil Temp Max	58	°C
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	LTC Totalizer Reading	6168.96	kw

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Unknown Operations	0	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Switching Operations	4	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Operations This Read Vac	4	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Operations Counter AL	174	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Operations Counter AF	170	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Maintenance Operations	0	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Grounds in Place?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	General Comments		
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	General Comments		
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Foundation Condition	Good	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Follow-up Action Required?	n	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Fault Operations Ground	0	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Fault Operations C Ø	0	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Fault Operations B Ø	0	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Fault Operations A Ø	0	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Ambient Temp	83	°F
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Broom on Site?	n	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Ambient Temp	84	°F
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	General Comments		
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Vegetation	None	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	YD000587	Yard	LN-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	77098	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	General Comments		
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Readings	General Comments		
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Readings	Oil Temp Max	60	°C
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Readings	Oil Temp Present	50	°C
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0226	NonLTC	693-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	0	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps A Ø	0.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps B Ø	0.0	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	LTCC000847	LTCControl	537-1	LTC Control Insp	VRR Time Delay	60	Seconds
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	LTCC000847	LTCControl	537-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	LTCC000847	LTCControl	537-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	LTCC000847	LTCControl	537-1	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Operations Counter	304	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	General Comments		
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Amps C Ø	50.0	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Amps B Ø	27.0	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	X0132	RecloserHydraulic	727-0613	Recloser Hydraulic Patrol Inspection	Amps A Ø	14.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	PF000208	PowerFuse	MG-454 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	PF000208	PowerFuse	MG-454 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	PF000209	PowerFuse	MG-464 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	9 Month Operations	1	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	9 Months Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Amps A Ø	71.7	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Amps B Ø	57.2	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Amps C Ø	65.7	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Fault Operations A Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Fault Operations B Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Fault Operations C Ø	0	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	15L	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	Neutral	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	General Comments		
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Fault Operations Ground	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Follow-up Action Required?	n	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	LTC As Found Counter	259377	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	LTC As Left Counter	259377	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	LTC Current Tap Position	8L	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	LTC Max Tap Position	7L	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	LTC Min Tap Position	9L	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	162	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Maintenance Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Operations Counter AF	358	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Operations Counter AL	358	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Operations This Read AM	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Switching Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0631	BreakerAirMagnetic	MG-451	AMCB Readings	Unknown Operations	0	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	Neutral	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps C Ø	0.0	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	LTCC000847	LTCControl	537-1	LTC Control Insp	All Connections OK?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	LTCC000847	LTCControl	537-1	LTC Control Insp	Follow-up Action Required?	n	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	LTCC000847	LTCControl	537-1	LTC Control Insp	General Comments		
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	LTCC000847	LTCControl	537-1	LTC Control Insp	LTC Operation Checked?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BCH001285	Charger	850-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.100	millivolts
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BCH001285	Charger	850-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BCH001285	Charger	850-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BCH001285	Charger	850-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Patrol Inspection	Bushing Condition	Good	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Amps C Ø	780.0	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Amps B Ø	780.0	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Amps A Ø	780.0	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0350	BreakerVacuum	836-0621	VCB Readings	9 Month Operations	8	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BCH001285	Charger	850-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BCH001285	Charger	850-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BCH001285	Charger	850-Battery Charger	Battery Charger Patrol Insp	General Comments	Light in the battery house is not working, checked the breaker, its not tripped.	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BCH001285	Charger	850-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Unknown Operations	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Switching Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Unknown Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Switching Operations	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Operations This Read Vac	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Operations Counter AL	121	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Operations Counter AF	121	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Maintenance Operations	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	General Comments		
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Patrol Inspection	General Comments		
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Follow-up Action Required?	n	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Counter Readings	General Comments		
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN61	LTCMechanism	LN-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Fault Operations C Ø	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Fault Operations B Ø	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Fault Operations A Ø	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	BCH001323	Charger	494-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	BCH001323	Charger	494-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	BCH001323	Charger	494-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	BCH001323	Charger	494-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	BCH001323	Charger	494-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	BCH001323	Charger	494-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	BCH001323	Charger	494-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Amps C Ø	182.0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Amps B Ø	198.0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Amps A Ø	189.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations This Read AM	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AL	685	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AF	685	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0610	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000049	BreakerVacuum	WO-1184	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	BCH001323	Charger	494-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1415	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Readings	General Comments		
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	C0471	WithLTC	736-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Fault Operations B Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Fault Operations C Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Fault Operations Ground	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	1	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Amps B Ø	148.0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Amps C Ø	158.0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Maintenance Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Operations Counter AF	146	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Unknown Operations	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Switching Operations	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Operations This Read Vac	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Operations Counter AL	147	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Operations Counter AF	147	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Maintenance Operations	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	General Comments		
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Patrol Inspection	General Comments		
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Follow-up Action Required?	n	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Fault Operations Ground	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Operations Counter AL	146	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Operations This Read AM	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Fault Operations C Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Switching Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Unknown Operations	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Fault Operations B Ø	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Fault Adjusted Amps B Phase V	11.18	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Fault Operations A Ø	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Fault Operations B Ø	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Fault Operations C Ø	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Fault Operations Ground	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Follow-up Action Required?	n	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Patrol Inspection	General Comments		
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Vegetation	None	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	General Comments		
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	General Comments		
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	General Comments		
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	10523.52	kw
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	70.00	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Oil Temp Max	78	°C
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Oil Temp Present	45	°C
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Amps C Ø	523.0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Amps B Ø	468.0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Amps A Ø	475.0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000052	BreakerVacuum	WO-12KV TR 2	VCB Readings	9 Month Operations	1	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Fault Operations Ground	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Fault Operations C Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Fault Operations B Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Fault Operations A Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Amps C Ø	47.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Amps B Ø	47.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Amps A Ø	47.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0598	BreakerAirMagnetic	MG-1314	AMCB Readings	9 Months Operations	0	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	LTCC000771	LTCControl	727-1	LTC Control Insp	All Connections OK?	y	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	LTCC000771	LTCControl	727-1	LTC Control Insp	Follow-up Action Required?	n	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	LTCC000771	LTCControl	727-1	LTC Control Insp	General Comments		
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	LTCC000771	LTCControl	727-1	LTC Control Insp	LTC Operation Checked?	y	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	LTCC000771	LTCControl	727-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	LTCC000771	LTCControl	727-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	LTCC000771	LTCControl	727-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	LTCC000771	LTCControl	727-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	LTCC000771	LTCControl	727-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	9 Months Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	9 Month Operations	2	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Amps A Ø	154.0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	142	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	142	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	General Comments		
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Amps A Ø	180.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Amps B Ø	176.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Amps C Ø	177.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0607	BreakerAirMagnetic	MG-1329	AMCB Readings	Fault Operations A Ø	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Amps C Ø	0.0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Amps B Ø	0.0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Amps A Ø	0.0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000051	BreakerVacuum	WO-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Maintenance Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Operations Counter AF	861	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Operations Counter AL	861	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Operations This Read AM	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Switching Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Unknown Operations	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	9 Month Operations	0	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	General Comments		
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	9 Month Operations	32	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Amps A Ø	234.0	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Amps B Ø	292.0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	LTCC000777	LTCControl	093-5	LTC Control Insp	All Connections OK?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	LTCC000777	LTCControl	093-5	LTC Control Insp	Follow-up Action Required?	n	
9/10/2020 13:17	Distribution	London Quarterly Inspection	LTCC000777	LTCControl	093-5	LTC Control Insp	General Comments		
9/10/2020 13:17	Distribution	London Quarterly Inspection	LTCC000777	LTCControl	093-5	LTC Control Insp	LTC Operation Checked?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	LTCC000777	LTCControl	093-5	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
9/10/2020 13:17	Distribution	London Quarterly Inspection	LTCC000777	LTCControl	093-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/10/2020 13:17	Distribution	London Quarterly Inspection	LTCC000777	LTCControl	093-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/10/2020 13:17	Distribution	London Quarterly Inspection	LTCC000777	LTCControl	093-5	LTC Control Insp	VRR Time Delay	30	Seconds
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Amps C Ø	223.0	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Bushing Condition	Good	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Fault Operations A Ø	0	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Fault Operations B Ø	0	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Fault Operations C Ø	0	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Fault Operations Ground	0	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Follow-up Action Required?	n	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Foundation Condition	Good	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	General Comments		
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	General Comments		
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Grounds in Place?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Maintenance Operations	27	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Operations Counter AF	479	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Operations Counter AL	479	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Operations This Read Vac	28	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Switching Operations	1	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	MB0159	BreakerVacuum	537-0533	VCB Readings	Unknown Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Vegetation	None	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	YD000593	Yard	MG-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.0962	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Winding Temp Max	75	°C
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	S0056	NonLTC	850-1	NonLTC Transformer Readings	Winding Temp Present	65	°C
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	General Comments		
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Evidence of Insects	Yes_needs_sprayed	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Filters Condition OK?	y	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Floor Swept?	n	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Maintenance Operations	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Operations Counter AF	154	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Operations Counter AL	154	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Operations This Read Vac	1	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Switching Operations	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000048	BreakerVacuum	WO-1183	VCB Readings	Unknown Operations	1	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	General Comments		
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	CH000411	ControlHouse	570-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	YD000141	Yard	771-Yard	Yard Patrol Inspection	Ambient Temp	78	°F
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Fault Operations A Ø	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Amps C Ø	0.0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Amps B Ø	0.0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Amps A Ø	0.0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000050	BreakerVacuum	WO-1185	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	FE000582	Fence	LN-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Trash Emptied?	n	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	General Comments		
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Floor Swept?	n	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	CH000466	ControlHouse	850-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	9 Months Operations	2	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Amps A Ø	229.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Amps B Ø	236.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Amps C Ø	215.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Fault Operations A Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Fault Operations B Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Fault Operations C Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Readings	Fault Operations Ground	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0605	BreakerAirMagnetic	MG-1327	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Adjusted Amps B Phase V	4.63	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Adjusted Amps A Phase V	1.85	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Unknown Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Switching Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Operations This Read AM	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Operations Counter AL	370	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Operations Counter AF	370	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	1	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	400.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	400.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	400.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	116	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	116	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000876	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	1	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/10/2020 13:17	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	Totalizer Meter Reading	.7860	
9/10/2020 13:17	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	Winding Temp Max	50	°C
9/10/2020 13:17	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	Winding Temp Present	45	°C
9/10/2020 13:17	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	300.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	300.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	300.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Follow-up Action Required?	n	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Patrol Inspection	General Comments		
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	General Comments		
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Maintenance Operations	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Operations Counter AF	205	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Operations Counter AL	205	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Operations This Read Vac	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Switching Operations	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Unknown Operations	0	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	General Comments		
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Yard Lights Working?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Vegetation	None	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	General Comments		
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	YD000017	Yard	894-Yard	Yard Patrol Inspection	Ambient Temp	84	*F
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	General Comments	fence and barb wire rusty, gaps under fence more than 4 inches	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	105	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	105	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	FE000022	Fence	894-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	9 Month Operations	3	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Operations A Ø	0	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Adjusted Amps C Phase V	6.48	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	99978	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	99978	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Acceptable Building Appearance?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Broom on Site?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Control House Lighting OK?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Door Alarms OK?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Evidence of Insects	None	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Floor Condition Acceptable?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Floor Swept?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Readings	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	General Comments	X2 will not reset	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	60	°C
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	40	°C
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Panel Lights OK?	y	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Panels Dusted?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Restroom Clean & OK?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Station Ground Set On Site?	y	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Trash Emptied?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	CH000167	ControlHouse	MG-Control House-Distribution	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Unknown Operations	0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Tank Paint Condition	Good	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	900	psi
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	Oil Temp Max	65	°C
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	114	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	114	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000877	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Maintenance Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Fault Operations C Ø	0	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Bushing Condition	Good	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Fault Operations B Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Fault Operations A Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Amps C Ø	9.7	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Amps B Ø	15.3	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Amps A Ø	20.2	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/10/2020 13:17	Distribution	London Quarterly Inspection	C0484	WithLTC	093-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0633	BreakerAirMagnetic	MG-454	AMCB Readings	9 Months Operations	0	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Current Tap Position	2R	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	General Comments	ok	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Max Tap Position	5R	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Min Tap Position	4L	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Regulator As Left Counter	22022	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Leaks	None	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	R0481	Regulator	Retired Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0639	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Amps C Ø	0.0	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Amps B Ø	0.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	X0322	RecloserElectronic	894-0578	Recloser Electronic Patrol Inspection	Amps A Ø	0.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	General Comments		
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.1	volts
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Regulator As Left Counter	34615	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0024	Regulator	494-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Amps C Ø	0.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Amps B Ø	0.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Readings	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	415.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	400.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Readings	Oil Temp Max	55	°C
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Readings	Oil Temp Present	35	°C
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0116	NonLTC	MG-TRANS 1 B PHASE	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Amps A Ø	0.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1676.16	kw
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	General Comments		
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	General Comments		
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	119	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	119	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KT0053	NonLTC	481-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Operations This Read AM	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Operations Counter AL	424	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Operations Counter AF	424	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Maintenance Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Fault Operations Ground	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Fault Operations C ∅	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Fault Operations B ∅	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Fault Operations A ∅	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000873	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	1	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Amps C ∅	41.0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Unknown Operations	0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Switching Operations	1	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Operations This Read Vac	3	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Operations Counter AL	186	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Operations Counter AF	186	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Maintenance Operations	0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Grounds in Place?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	General Comments		
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Foundation Condition	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Follow-up Action Required?	n	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Fault Operations Ground	0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Fault Operations C Ø	0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Fault Operations B Ø	1	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Fault Operations A Ø	1	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Fault Adjusted Amps B Phase V	5.72	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Fault Adjusted Amps A Phase V	5.72	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Patrol Inspection	Bushing Condition	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Amps C Ø	141.0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Amps B Ø	133.0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Amps A Ø	144.0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000590	BreakerVacuum	093-0200	VCB Readings	9 Month Operations	5	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Amps B Ø	47.0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	9 Month Operations	1	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Amps A Ø	27.0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Amps B Ø	23.0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Amps C Ø	26.0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Amps A Ø	21.0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	1	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000875	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	ST000016	Structure	894-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Fault Operations A Ø	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Fault Operations B Ø	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Fault Operations C Ø	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Readings	Fault Operations Ground	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000046	BreakerVacuum	WO-1181	VCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	BCH001052	Charger	467-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.6	VDC
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	BCH001052	Charger	467-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.6	VDC
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	BCH001052	Charger	467-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	BCH001052	Charger	467-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	BCH001052	Charger	467-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	BCH001052	Charger	467-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0636	BreakerAirMagnetic	MG-4KV TFR	AMCB Readings	9 Months Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Ambient Temp	84	*F
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	General Comments		
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Vegetation	None	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Foundation Condition	Good	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Follow-up Action Required?	n	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Operations Ground	0	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Operations C Ø	5	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	143	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	YD000322	Yard	641-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	143	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	General Comments		
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000874	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	General Comments		
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Fault Operations B Ø	3	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Current Tap Position	1R	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0025	Regulator	494-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1158	BreakerVacuum	WO-1178	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	ST000328	Structure	641-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Foundation Condition	Good	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Follow-up Action Required?	n	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Fault Operations C Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Fault Operations B Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Fault Operations A Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Amps C Ø	600.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Amps B Ø	600.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Amps A Ø	600.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	9 Months Operations	3	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Fault Operations Ground	0	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Fault Operations C Ø	0	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Fault Operations B Ø	0	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Fault Operations A Ø	0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Unknown Operations	0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Switching Operations	1	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Operations This Read Vac	1	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Operations Counter AL	230	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Operations Counter AF	230	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Maintenance Operations	0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Grounds in Place?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	General Comments		
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	General Comments		
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Bushing Condition	Good	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Amps C Ø	0.0	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Amps B Ø	0.0	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Amps A Ø	0.0	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	9 Month Operations	13	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	General Comments		
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Foundation Condition	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Panels Dusted?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Operations Counter AF	110	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Fault Operations Ground	0	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Fault Operations A Ø	0	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Fault Operations B Ø	0	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Fault Operations C Ø	0	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Fault Operations Ground	0	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Follow-up Action Required?	n	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Foundation Condition	Good	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	General Comments		
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	General Comments		
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Grounds in Place?	y	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Maintenance Operations	0	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Operations Counter AF	182	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Operations Counter AL	182	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Operations This Read Vac	0	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Switching Operations	0	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Unknown Operations	0	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	SWG000170	Switchgear	MG-14KV Sec A Swgr	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	SWG000170	Switchgear	MG-14KV Sec A Swgr	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	SWG000170	Switchgear	MG-14KV Sec A Swgr	Switchgear Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	SWG000170	Switchgear	MG-14KV Sec A Swgr	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	SWG000170	Switchgear	MG-14KV Sec A Swgr	Switchgear Patrol Inspection	Panels Dusted?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	SWG000170	Switchgear	MG-14KV Sec A Swgr	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Evidence of Insects	None	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	General Comments		
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Unknown Operations	0	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Switching Operations	1	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Operations This Read Vac	10	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Operations Counter AL	628	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Operations Counter AF	618	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	Maintenance Operations	9	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	Grounds in Place?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Readings	General Comments		
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BB0377	BreakerVacuum	836-0620	VCB Patrol Inspection	General Comments		
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	FE000072	Fence	537-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Min Tap Position	8L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Fault Operations A Ø	0	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Vegetation	None	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Fault Operations B Ø	0	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Max Tap Position	2R	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	General Comments	ok	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Current Tap Position	1R	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Fault Operations C Ø	0	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Fault Operations Ground	0	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Follow-up Action Required?	n	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Foundation Condition	Good	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	General Comments		
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	General Comments	1 - Trip Check, 1 - Switching for Outage	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Grounds in Place?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Readings	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	225.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	220.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Readings	Oil Temp Max	55	°C
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Readings	Oil Temp Present	35	°C
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0117	NonLTC	MG-TRANS 1 C PHASE	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Maintenance Operations	1	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Operations Counter AF	195	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Operations Counter AL	196	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	General Comments	Some ruts and washout forming at the bottom of the hill as you turn up to sub.	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	n	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	n	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	YD000021	Yard	494-Yard	Yard Patrol Inspection	Ambient Temp	85	°F
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Fault Operations Ground	0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Fault Operations C Ø	0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Fault Operations B Ø	0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Fault Operations A Ø	0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0146	BreakerVacuum	093-0203	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	SWG000171	Switchgear	MG-14KV Sec 5 Swgr	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Current Tap Position	2R	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Ambient Temp	75	°F
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	General Comments	Under Frequency box has been removed.	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Vegetation	None	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	YD000073	Yard	537-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	General Comments		
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Max Tap Position	5R	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	9 Month Operations	4	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Amps A Ø	56.0	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Amps B Ø	61.0	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Amps C Ø	70.0	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Bushing Condition	Good	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Regulator As Left Counter	42448	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	FE000589	Fence	MG-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	KR0023	Regulator	494-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BK000898	BreakerVacuum	736-1913	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Tank Leaks	None	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Regulator As Left Counter	208502	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R1051	Regulator	142-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	9 Month Operations	2	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Operations This Read AM	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Operations Counter AL	432	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	9 Month Operations	14	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Operations Counter AF	432	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Maintenance Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Patrol Inspection	General Comments		
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Fault Operations Ground	0	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Fault Operations C Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Fault Operations B Ø	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	9 Month Operations	2	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Amps A Ø	1089.0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Amps B Ø	107.0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Amps C Ø	163.0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Fault Operations A Ø	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Fault Operations B Ø	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Fault Operations C Ø	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Fault Operations Ground	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Fault Operations A Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Regulator As Left Counter	61318	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Follow-up Action Required?	n	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Patrol Inspection	General Comments		
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	General Comments		
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Maintenance Operations	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Operations Counter AF	147	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Operations Counter AL	147	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Operations This Read Vac	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Switching Operations	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	BK000047	BreakerVacuum	WO-1182	VCB Readings	Unknown Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Amps C Ø	125.1	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Amps B Ø	255.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Amps A Ø	177.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	9 Months Operations	6	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	KB0034	BreakerVacuum	009-3412	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Ambient Temp	80	*F
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	General Comments	A couple of trees are starting to have some limbs to grow over the top of the fence line at the back of the station.	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	FE000063	Fence	570-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Current Tap Position	7L	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	General Comments		
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Min Tap Position	16L	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	70	°C
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	40	°C
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	70	°C
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	40	°C
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	55	°C
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0225	WithLTC	WO-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	40	°C
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Switching Operations	2	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Operations This Read Vac	2	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Operations Counter AL	406	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Operations Counter AF	406	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Maintenance Operations	0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Grounds in Place?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	General Comments		
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	General Comments		
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Foundation Condition	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Follow-up Action Required?	n	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Fault Operations Ground	0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Fault Operations C Ø	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LTCC000388	LTCControl	WO-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LTCC000388	LTCControl	WO-TRANS 1	LTC Control Insp	General Comments		
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LTCC000388	LTCControl	WO-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Unknown Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0628	BreakerAirMagnetic	MG-407	AMCB Readings	Switching Operations	0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/10/2020 13:17	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	LTC Operations Since Last Insp	1997	
9/10/2020 13:17	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	LTC Min Tap Position	8L	
9/10/2020 13:17	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	LTC Max Tap Position	8R	
9/10/2020 13:17	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	LTC Current Tap Position	4R	
9/10/2020 13:17	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	LTC As Left Counter	126354	
9/10/2020 13:17	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	LTC As Found Counter	126344	
9/10/2020 13:17	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Mechanism Patrol Inspection	General Comments		
9/10/2020 13:17	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	General Comments		
9/10/2020 13:17	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 13:17	Distribution	London Quarterly Inspection	M0101	LTCMechanism	093-6	LTC Counter Readings	Follow-up Action Required?	n	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Fault Operations B Ø	0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Fault Operations A Ø	0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Patrol Inspection	Bushing Condition	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Amps C Ø	317.0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Amps B Ø	321.0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Amps A Ø	318.0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0105	BreakerVacuum	093-0204	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	50.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	50.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	50.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	1	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	SWG000033	Switchgear	LN-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	301	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	301	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	163.0	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Current Tap Position	5L	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	General Comments		
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Min Tap Position	9L	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	163.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	168.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000568	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	0	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	122.0	volts
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Regulator As Left Counter	21135	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Tank Leaks	None	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	9 Month Operations	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Unknown Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Switching Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Operations This Read AM	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0627	BreakerAirMagnetic	MG-14KV TR 5	AMCB Readings	Operations Counter AL	110	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Amps A Ø	120.0	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Amps B Ø	129.0	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Readings	Amps C Ø	119.0	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Bushing Condition	Good	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000892	BreakerVacuum	570-0545	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	ST000587	Structure	MG-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1448	Regulator	771-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	80	*F
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	LTC Operations Since Last Insp	1356	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	LTC Min Tap Position	12L	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	LTC Max Tap Position	1R	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	LTC Current Tap Position	3L	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	LTC As Left Counter	197837	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	LTC As Found Counter	197827	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Mechanism Patrol Inspection	General Comments		
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	General Comments		
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	M0078	LTCMechanism	570-1	LTC Counter Readings	Follow-up Action Required?	n	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Exp/Missing Not Repl	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	General Comments		
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	BAT001392	Battery	494-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	244	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	244	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	80.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	80.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	80.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	R1457	Regulator	006-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000570	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	161	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	161	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000569	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	9 Months Operations	3	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Current Tap Position	3L	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	General Comments		
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Max Tap Position	2L	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Min Tap Position	11L	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Regulator As Left Counter	46028	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	General Comments		
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	9 Month Operations	4	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Amps A Ø	0.0	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Amps B Ø	0.0	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Amps C Ø	0.0	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Bushing Condition	Good	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Current Tap Position	1L	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	General Comments		
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	LTCC000141	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	LTCC000141	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	LTCC000141	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	237	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	237	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Vegetation	None	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	LTCC000141	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	LTCC000141	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	LTCC000141	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	LTCC000141	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	LTCC000731	LTCControl	570-1	LTC Control Insp	VRR Time Delay	60	Seconds
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	LTCC000731	LTCControl	570-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	LTCC000731	LTCControl	570-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	LTCC000731	LTCControl	570-1	LTC Control Insp	LTC Output Voltage Level	124.8	VAC
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	LTCC000731	LTCControl	570-1	LTC Control Insp	LTC Operation Checked?	y	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	LTCC000731	LTCControl	570-1	LTC Control Insp	General Comments		
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	LTCC000731	LTCControl	570-1	LTC Control Insp	Follow-up Action Required?	n	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	LTCC000731	LTCControl	570-1	LTC Control Insp	All Connections OK?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	General Comments		
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Max Tap Position	8R	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1527	Regulator	894-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Unknown Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Switching Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Operations This Read AM	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Operations Counter AL	98	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Operations Counter AF	98	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Maintenance Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Fault Operations Ground	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Fault Operations C Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Fault Operations B Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Amps C Ø	0.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Amps B Ø	0.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Amps A Ø	0.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0619	BreakerAirMagnetic	MG-14KV BUS TIE SEC 5-C	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	General Comments		
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Ambient Temp	80	*F
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	General Comments		
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	General Comments		
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	YD000363	Yard	727-Yard	Yard Patrol Inspection	Vegetation	None	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	General Comments		
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	General Comments		
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	9694.08	kw
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	Oil Temp Present	55	°C
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.0098	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Trash Emptied?	n	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Regulator As Left Counter	53615	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1528	Regulator	894-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Fault Operations A Ø	0	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Fault Operations B Ø	0	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Fault Operations C Ø	0	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Fault Operations Ground	0	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Follow-up Action Required?	n	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Foundation Condition	Good	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	General Comments		
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	General Comments		Repair Arrestors Txmtr and TC
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Grounds in Place?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Regulator As Left Counter	100099	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	PF000428	PowerFuse	WO-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	PF000428	PowerFuse	WO-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	ST000257	Structure	596-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Operations Counter	205	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	General Comments		New controller installed
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Maintenance Operations	1	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Operations Counter AF	159	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Operations Counter AL	159	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Operations This Read Vac	2	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Amps C Ø	214.0	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Amps B Ø	205.0	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	KX0129	RecloserElectronic	142-3405	Recloser Electronic Patrol Inspection	Amps A Ø	201.0	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	S0038	NonLTC	439-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	FE000357	Fence	727-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	72404	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	16L	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	2L	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	General Comments		
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	2L	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	R1416	Regulator	930-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	PF000222	PowerFuse	MG-14KV BUS SEC B POT	Disconnect PowerFuse Inspection	General Comments	ok	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	General Comments	all cells need water	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Follow-up Action Required?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Low	If low,note cell #'s
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	75	*F
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BAT000015	Battery	MG-Battery Bank-Distribution	Battery Patrol Inspection	All Connections OK?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	133	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	133	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	1	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	144	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	General Comments		
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Current Tap Position	1L	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	Totalizer Meter Reading	.5586	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	800	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	Oil Temp Present	48	°C
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	446.88	kw
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	General Comments	secondary needs wildlife protection installed	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	General Comments	ok	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	B0256	NonLTC	142-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	1	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000777	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	LTCC000157	LTCControl	467-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	LTCC000157	LTCControl	467-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	LTCC000157	LTCControl	467-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Regulator As Left Counter	62274	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	122.8	volts
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Max Tap Position	6R	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1417	Regulator	850-1 A	Regulator Patrol Inspection	General Comments		
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2713.60	kw

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	General Comments		
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	General Comments		
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	General Comments		
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.8	VDC
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.6	VDC
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	General Comments		
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	164	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	164	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R1186	Regulator	596-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	1	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000780	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	LTCC000141	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	LTCC000141	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	General Comments		
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Trash Emptied?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	84	°F
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BAT001359	Battery	736-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #""s
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	146	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	146	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000778	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	1	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	100.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	100.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	100.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000779	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	Totalizer Meter Reading	.8480	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	C0339	NonLTC	771-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps C Ø	0.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps B Ø	0.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps A Ø	0.0	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	5	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	505	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	505	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Maintenance Operations	1	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Grounds in Place?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	General Comments	1 - Trip Check, 1 - switching for Outage	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	General Comments		
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Foundation Condition	Good	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	BCH000420	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
9/10/2020 9:46	Distribution	Island Quarterly Inspection	BCH000420	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
9/10/2020 9:46	Distribution	Island Quarterly Inspection	BCH000420	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	BCH000420	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Follow-up Action Required?	n	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Fault Operations Ground	0	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Fault Operations C Ø	0	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	0	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Unknown Operations	0	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Switching Operations	1	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Operations This Read Vac	1	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Operations Counter AL	142	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Operations Counter AF	142	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Maintenance Operations	0	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Grounds in Place?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	General Comments		
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	General Comments		
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Foundation Condition	Good	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Follow-up Action Required?	n	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Fault Operations Ground	0	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	General Comments		
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	General Comments		
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	General Comments		
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Grounds in Place?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Maintenance Operations	0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Operations Counter AF	143	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Operations Counter AL	143	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Operations This Read Vac	0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Switching Operations	0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Unknown Operations	0	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Unknown Operations	2	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Switching Operations	0	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Operations This Read Vac	3	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Operations Counter AL	187	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Operations Counter AF	187	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Maintenance Operations	1	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Grounds in Place?	y	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	General Comments		
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	General Comments		
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Foundation Condition	Good	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Follow-up Action Required?	n	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Unknown Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Switching Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations This Read AM	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AL	1878	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Unknown Operations	0	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Switching Operations	1	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Operations This Read Vac	2	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Operations Counter AL	227	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Operations Counter AF	226	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Fault Operations Ground	0	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Fault Operations C Ø	0	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Fault Operations B Ø	0	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Fault Operations A Ø	0	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Fault Adjusted Amps C Phase V	8.38	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Fault Adjusted Amps B Phase V	8.38	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Fault Adjusted Amps A Phase V	8.38	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AF	1878	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0604	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	Winding Temp Max	50	°C
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	Winding Temp Present	40	°C
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	9 Month Operations	3	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Bushing Condition	Good	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Amps C Ø	120.0	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Amps B Ø	100.0	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Switching Operations	0	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Operations This Read Vac	0	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Operations Counter AL	206	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Operations Counter AF	206	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Maintenance Operations	0	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Grounds in Place?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	General Comments		
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	General Comments		
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Foundation Condition	Good	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Follow-up Action Required?	n	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Fault Operations Ground	0	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Fault Operations C Ø	0	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Fault Operations B Ø	0	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Fault Operations A Ø	0	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Patrol Inspection	Bushing Condition	Good	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Amps C Ø	150.0	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Amps B Ø	145.0	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Amps A Ø	180.0	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0120	BreakerVacuum	641-0919	VCB Readings	9 Month Operations	5	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	9 Months Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	General Comments		
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	ST000261	Structure	006-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	As Found Float Voltage	26.6	VDC
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Fault Operations C Ø	0	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Fault Operations B Ø	0	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Fault Operations A Ø	0	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	As Left Float Voltage	26.6	VDC
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	General Comments		
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	BCH001228	Charger	LN-Battery Bank	Battery Charger Patrol Insp	Ground Lights	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Battery Area Ambient Temp	83	°F
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Battery Bank Amps	.1	AMPS
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Battery Bank Volts	26.6	VDC
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Battery Overall Condition	Good	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	General Comments		
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	BAT001284	Battery	LN-Battery Charger	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	General Comments		
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	General Comments		
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	900	psi
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	217.50	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	210.00	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	Oil Temp Max	50	°C
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Readings	Oil Temp Present	40	°C
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	T0240	NonLTC	009-9	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BCH000427	Charger	596-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BCH000427	Charger	596-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BCH000427	Charger	596-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BCH000427	Charger	596-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BCH000427	Charger	596-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	General Comments		
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	General Comments		
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	928.08	kw
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	71.00	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	65.00	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	Oil Temp Max	60	°C
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	Oil Temp Present	30	°C
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.7734	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Vegetation	None	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	General Comments		
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	YD000250	Yard	596-Yard	Yard Patrol Inspection	Ambient Temp	74	°F
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Ambient Temp	88	°F
9/10/2020 13:17	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Wood Structures OK?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	General Comments		
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Floor Swept?	n	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	CH000415	ControlHouse	494-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BCH000203	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	3.800	millivolts
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BCH000203	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.5	VDC
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BCH000203	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	52.5	VDC
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BCH000203	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	2.2	amps
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BCH000203	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BCH000203	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	General Comments		
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Max Tap Position	8R	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Min Tap Position	11L	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Regulator As Left Counter	62842	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R0999	Regulator	596-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	General Comments		
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Switching Operations	1	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	BK000493	BreakerVacuum	596-1497	VCB Readings	Unknown Operations	0	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	ST000366	Structure	727-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Vegetation	None	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	General Comments		
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	FE000664	Fence	WO-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	YD000290	Yard	798-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	W0223	NonLTC	693-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	General Comments	ok	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Max Tap Position	1R	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Min Tap Position	6L	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Regulator As Left Counter	120107	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Tank Leaks	None	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	1	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps A Ø	0.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps B Ø	0.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps C Ø	0.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AF	693	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AL	693	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations This Read AM	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Switching Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0620	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Unknown Operations	0	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	195.0	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	235.0	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	195.0	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	BB0100	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	9 Month Operations	0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Amps A Ø	480.0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Amps B Ø	490.0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Amps C Ø	530.0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Bushing Condition	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Fault Operations A Ø	0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Fault Operations B Ø	0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Fault Operations C Ø	0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Fault Operations Ground	0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Readings	Follow-up Action Required?	n	
9/10/2020 13:17	Distribution	London Quarterly Inspection	BK000497	BreakerVacuum	093-5	VCB Patrol Inspection	Foundation Condition	Good	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	SWG000200	Switchgear	WO-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	General Comments		
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	110.00	
9/10/2020 13:17	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	Winding Temp Present	68	°C
9/10/2020 13:17	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	Winding Temp Max	70	°C
9/10/2020 13:17	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	Totalizer Meter Reading	1.5238	
9/10/2020 13:17	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/10/2020 13:17	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/10/2020 13:17	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/10/2020 13:17	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	Oil Temp Present	55	°C
9/10/2020 13:17	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	Oil Temp Max	65	°C
9/10/2020 13:17	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
9/10/2020 13:17	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	LTC Totalizer Reading	14628.48	kw
9/10/2020 13:17	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	General Comments	added 2 lbs nitrogen	
9/10/2020 13:17	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	General Comments		
9/10/2020 13:17	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 13:17	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Readings	Follow-up Action Required?	n	
9/10/2020 13:17	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 13:17	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 13:17	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	M0101	WithLTC	093-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	.5	VDC
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	1.6	VDC
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	BAT001145	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	FE000249	Fence	596-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Current Tap Position	1R	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R0758	Regulator	142-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Bushing Condition	Good	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Amps C Ø	120.0	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Amps B Ø	11.0	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Amps A Ø	125.0	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	9 Month Operations	2	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	General Comments		
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	LTCC000746	LTCControl	641-1	LTC Control Insp	All Connections OK?	y	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	LTCC000746	LTCControl	641-1	LTC Control Insp	Follow-up Action Required?	n	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	LTCC000746	LTCControl	641-1	LTC Control Insp	General Comments		
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	LTCC000746	LTCControl	641-1	LTC Control Insp	LTC Operation Checked?	y	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	LTCC000746	LTCControl	641-1	LTC Control Insp	LTC Output Voltage Level	123.5	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	LTCC000746	LTCControl	641-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	LTCC000746	LTCControl	641-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	LTCC000746	LTCControl	641-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	LTCC000748	LTCControl	736-1	LTC Control Insp	All Connections OK?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	LTCC000748	LTCControl	736-1	LTC Control Insp	Follow-up Action Required?	n	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	LTCC000748	LTCControl	736-1	LTC Control Insp	General Comments		
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	LTCC000748	LTCControl	736-1	LTC Control Insp	LTC Operation Checked?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	LTCC000748	LTCControl	736-1	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	LTCC000748	LTCControl	736-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	LTCC000748	LTCControl	736-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	LTCC000748	LTCControl	736-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Fault Operations Ground	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Fault Operations C Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Fault Operations B Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Fault Operations A Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Amps C Ø	203.1	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Amps B Ø	255.6	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Amps A Ø	180.8	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	LTC As Found Counter	10737	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	LTC As Left Counter	10737	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	LTC Current Tap Position	6L	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	General Comments		
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Vegetation	None	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	General Comments		
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	General Comments		
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Foundation Condition	Good	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Follow-up Action Required?	n	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Fault Operations Ground	0	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Fault Operations C Ø	0	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Fault Operations B Ø	0	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Fault Operations A Ø	0	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	General Comments		
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	General Comments		
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	4176.00	kw
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	Oil Temp Max	60	°C
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	Oil Temp Present	50	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	General Comments		
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	122.8	volts
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Regulator As Left Counter	47830	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	R1526	Regulator	894-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	M0057	NonLTC	494-1	NonLTC Transformer Readings	Totalizer Meter Reading	.8700	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	LTC As Left Counter	5448	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	LTC As Found Counter	5440	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Mechanism Patrol Inspection	General Comments		
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	General Comments		
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	Follow-up Action Required?	n	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	LTC Operations Since Last Insp	820	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	LTC Min Tap Position	9L	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	LTC Max Tap Position	1L	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	LTC Current Tap Position	3L	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	LTC As Left Counter	10195	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	LTC As Found Counter	10187	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	General Comments	124.1V	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Mechanism Patrol Inspection	General Comments		
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	C0471	LTCMechanism	736-1	LTC Counter Readings	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	9 Months Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Amps A Ø	5.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Amps B Ø	4.2	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Amps C Ø	4.4	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Fault Operations A Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Fault Operations B Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Fault Operations C Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Fault Operations Ground	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Maintenance Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Operations Counter AF	348	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Operations Counter AL	348	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Operations This Read AM	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Switching Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0634	BreakerAirMagnetic	MG-464	AMCB Readings	Unknown Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	Oil Temp Max	66	°C
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	General Comments	ok	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Operations Counter	213	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Amps A Ø	0.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Amps B Ø	0.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Amps C Ø	0.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	LTC Max Tap Position	2L	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	9 Months Operations	12	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	ST000248	Structure	467-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	9 Months Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	LTC Min Tap Position	12L	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	General Comments		
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	FE000210	Fence	693-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	51	°C
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	43	°C
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	LTC Operations Since Last Insp	984	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LTCM000073	LTCMechanism	MG-TRANS 5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Amps A Ø	2.9	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	General Comments		
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	Oil Temp Present	58	°C
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.1	VDC
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BAT001195	Battery	850-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Amps B Ø	34.7	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Amps C Ø	1.6	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	LTC Operations Since Last Insp	1395	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	LTC Min Tap Position	9L	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	LTC Max Tap Position	3R	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	X0252	RecloserHydraulic	419-0557	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	General Comments		
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	M0099	LTCMechanism	537-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Readings	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	CAP000056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Warning Signs OK?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	General Comments		
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Vegetation	None	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	Totalizer Meter Reading	.9360	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	Oil Temp Present	45	°C
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	Oil Temp Max	65	°C
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	LTC Totalizer Reading	8985.60	kw
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	General Comments		
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	General Comments		
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	S0049	WithLTC	467-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	General Comments	ok	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Ground Connections Intact?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Ambient Temp	88	°F
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	CAP000056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	CAP000056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Readings	Oil Temp Present	35	°C
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Readings	Oil Temp Max	50	°C
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	400.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	415.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Readings	General Comments	Guage is hard to read	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0115	NonLTC	MG-TRANS 1 A PHASE	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	X3 Winding Temp Present	65	°C
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	X3 Winding Temp Max	74	°C
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	X2 Winding Temp Present	65	°C
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	YD000256	Yard	439-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BCH001209	Charger	439-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.6	VDC
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BCH001209	Charger	439-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.6	VDC
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BCH001209	Charger	439-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BCH001209	Charger	439-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BCH001209	Charger	439-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	CAP000056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Foundation Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	CAP000056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	CAP000056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	CAP000056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	CAP000056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Grounds in Place?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	CAP000056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	CAP000056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	CAP000056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	CAP000056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	CAP000056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	CAP000056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Capacitor Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	CAP000056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Cap bank CT in Good Condition?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	CAP000056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	All Identified and Legible?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	0.0	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	General Comments		
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	CH000441	ControlHouse	LN-Battery Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	0.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	0.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	CAP000056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Bushing Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	CAP000056	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	All Connections OK?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Ambient Temp	67	°F
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	General Comments		
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	99972	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	99972	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	FE000252	Fence	006-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	X2 Winding Temp Max	74	°C
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	X1 Winding Temp Present	65	°C
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	X1 Winding Temp Max	74	°C
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	General Comments		
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	FE000243	Fence	467-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0640	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Unknown Operations	0	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Switching Operations	0	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Operations This Read Vac	0	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Operations Counter AL	233	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Operations Counter AF	233	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Readings	Maintenance Operations	0	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	KB0081	BreakerVacuum	798-0611	VCB Patrol Inspection	Grounds in Place?	y	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Ambient Temp	89	°F
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	YD000242	Yard	467-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	ST000714	Structure	142-Structure Dist	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	General Comments		
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	LTCC000241	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
9/10/2020 13:17	Distribution	London Quarterly Inspection	LTCC000241	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/10/2020 13:17	Distribution	London Quarterly Inspection	LTCC000241	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/10/2020 13:17	Distribution	London Quarterly Inspection	LTCC000241	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.6	VAC
9/10/2020 13:17	Distribution	London Quarterly Inspection	LTCC000241	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	LTCC000241	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
9/10/2020 13:17	Distribution	London Quarterly Inspection	LTCC000241	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
9/10/2020 13:17	Distribution	London Quarterly Inspection	LTCC000241	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	ST000263	Structure	439-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	9 Month Operations	4	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Amps A Ø	94.0	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Amps B Ø	109.0	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Amps C Ø	89.0	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Bushing Condition	Good	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Fault Operations A Ø	0	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Fault Operations B Ø	0	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Fault Operations C Ø	0	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Fault Operations Ground	0	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Follow-up Action Required?	n	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Foundation Condition	Good	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	General Comments		
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	General Comments		
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Grounds in Place?	y	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Maintenance Operations	0	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Unknown Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Switching Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Operations This Read AM	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Operations Counter AL	593	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Operations Counter AF	593	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0629	BreakerAirMagnetic	MG-411	AMCB Readings	Maintenance Operations	0	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Operations Counter AF	169	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Operations Counter AL	169	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Operations This Read Vac	1	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Switching Operations	1	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	BK000753	BreakerVacuum	570-0544	VCB Readings	Unknown Operations	0	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Vegetation	None	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	General Comments		
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	YD000254	Yard	006-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9768	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	PF000429	PowerFuse	WO-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Regulator As Left Counter	61661	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	PF000212	PowerFuse	MG-417 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	PF000212	PowerFuse	MG-417 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	PF000222	PowerFuse	MG-14KV BUS SEC B POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Min Tap Position	9L	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Max Tap Position	6R	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	General Comments		
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Current Tap Position	Neutral	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	1	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Current Tap Position	1R	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	General Comments		
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	General Comments		
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Broom on Site?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Max Tap Position	3R	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Regulator As Left Counter	29643	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1397	Regulator	439-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Vegetation	None	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	CH000206	ControlHouse	WO-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	Oil Temp Present	45	°C
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Current Tap Position	6L	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	BCH001273	Charger	641-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	BCH001273	Charger	641-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.1	VDC
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	BCH001273	Charger	641-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.1	VDC
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	BCH001273	Charger	641-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.6350	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	BCH001273	Charger	641-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	BCH001273	Charger	641-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	BCH001274	Charger	771-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.1	VDC
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	BCH001274	Charger	771-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.1	VDC
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	BCH001274	Charger	771-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	BCH001274	Charger	771-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	BCH001274	Charger	771-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Fans Operational?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	PF000227	PowerFuse	MG-14KV TR 5 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	PF000227	PowerFuse	MG-14KV TR 5 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	PF000211	PowerFuse	MG-4KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	PF000211	PowerFuse	MG-4KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	PF000223	PowerFuse	MG-14KV BUS SEC C POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	PF000223	PowerFuse	MG-14KV BUS SEC C POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	PF000216	PowerFuse	MG-407 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	PF000216	PowerFuse	MG-407 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	LTCC000157	LTCControl	467-1	LTC Control Insp	All Connections OK?	y	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	LTCC000157	LTCControl	467-1	LTC Control Insp	Follow-up Action Required?	n	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	LTCC000157	LTCControl	467-1	LTC Control Insp	General Comments		
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	LTCC000157	LTCControl	467-1	LTC Control Insp	LTC Operation Checked?	y	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	LTCC000157	LTCControl	467-1	LTC Control Insp	LTC Output Voltage Level	124.6	VAC
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	General Comments	No AC to fans	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	General Comments	ok	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1562.88	kw
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	117.50	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	110.00	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	Oil Temp Max	54	°C
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	Oil Temp Present	43	°C
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	PF000429	PowerFuse	WO-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 10:59	Distribution	Riverview Quarterly Inspection	C0334	NonLTC	815-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1600	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Current Tap Position	3R	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	General Comments		
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Regulator As Left Counter	31097	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Regulator As Left Counter	66274	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Max Tap Position	5R	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1418	Regulator	850-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	9 Month Operations	3	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	80.0	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	80.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	80.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000776	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	144	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	General Comments		
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Ambient Temp	70	*F
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	YD000210	Yard	693-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Ambient Temp	80	*F
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Filters Condition OK?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	YD000670	Yard	WO-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps A Ø	80.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps B Ø	80.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Amps C Ø	80.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Maintenance Operations	0	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	87	*F
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	General Comments		
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.9	VDC
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.6	VDC
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	BAT001355	Battery	641-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	85	*F
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	General Comments		
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.1	VDC
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Positive DC Ground	27.0	VDC
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	BAT001356	Battery	771-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AF	153	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1398	Regulator	439-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	CH000399	ControlHouse	537-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations Counter AL	153	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Switching Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	BK000775	BreakerVacuum	MG-Offline-Distribution	VCB Readings	Unknown Operations	0	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	R1419	Regulator	850-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Grounds in Place?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	General Comments	Trans needs nitrogen	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Foundation Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Follow-up Action Required?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BCH000518	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BCH000518	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BCH000518	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Amps A Ø	220.0	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Amps B Ø	220.0	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Amps C Ø	180.0	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Operations A Ø	0	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Operations B Ø	0	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Operations C Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Bushing Condition	Good	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Fault Operations Ground	0	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Follow-up Action Required?	n	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Patrol Inspection	General Comments		
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	General Comments		
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Maintenance Operations	0	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Operations Counter AF	3	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Operations Counter AL	3	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Operations This Read AM	1	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Switching Operations	1	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Unknown Operations	0	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BCH000518	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.5	amps
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BCH000518	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	General Comments		
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	General Comments		
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	LTC Totalizer Reading	1214.40	kw
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	Oil Temp Max	40	°C
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	Oil Temp Present	40	°C
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Fault Operations A Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Fault Operations B Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Fault Operations Ground	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Maintenance Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Operations Counter AF	318	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Operations Counter AL	318	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0114	WithLTC	MG-TRANS 5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Regulator As Left Counter	105153	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	General Comments		
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	ST000207	Structure	736-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	9 Months Operations	1	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Operations This Read AM	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Switching Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0602	BreakerAirMagnetic	MG-1322	AMCB Readings	Unknown Operations	0	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0572	BreakerAirMagnetic	LN-4	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Min Tap Position	10L	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Max Tap Position	8R	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	General Comments		
9/10/2020 8:34	Distribution	Perdue Quarterly Inspection	R1187	Regulator	596-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Tank Leaks	None	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LT0262	GroundTransformer	Retired Distribution	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BCH000518	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	BCH001353	Charger	537-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	BCH001353	Charger	537-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	BCH001353	Charger	537-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	BCH001353	Charger	537-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	BCH001353	Charger	537-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Exp/Missing Not Repl	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Regulator As Left Counter	83633	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	BCH001353	Charger	537-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	BCH001353	Charger	537-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	BCH001353	Charger	537-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BCH001271	Charger	736-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.9	VDC
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Min Tap Position	16L	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	General Comments		
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Current Tap Position	6L	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BCH001271	Charger	736-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.9	VDC
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BCH001271	Charger	736-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	4.4	amps
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BCH001271	Charger	736-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	BCH001271	Charger	736-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1435	Regulator	771-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	26.00	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Regulator As Left Counter	79534	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Min Tap Position	12L	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	General Comments	Adjust Voltage band, loose knob	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	R1433	Regulator	771-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	Oil Temp Max	55	*C
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	Totalizer Meter Reading	.2530	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/10/2020 13:21	Distribution	Salt Lick Quarterly Inspection	B0475	WithLTC	727-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	LTC Operations Since Last Insp	888	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	LTC Min Tap Position	11L	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	LTC Max Tap Position	3R	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	LTC Current Tap Position	3R	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	FE000215	Fence	439-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	LTC As Left Counter	42042	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	General Comments		
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	General Comments		
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	W0213	NonLTC	006-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	3924.00	kw
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	LTC As Found Counter	42034	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Mechanism Patrol Inspection	General Comments		
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	General Comments		
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	S0049	LTCMechanism	467-1	LTC Counter Readings	Follow-up Action Required?	n	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.1	VDC
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	General Comments		
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	BAT001060	Battery	537-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	General Comments		
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	ST000146	Structure	771-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/10/2020 13:02	Distribution	Morehead East Quarterly Inspection	BCH000518	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Amps C Ø	0.0	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Amps B Ø	0.0	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Amps A Ø	0.0	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	RLY027318	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Prove All BFI DC Paths	na	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	RLY027318	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Trip Bkr Coil 1 or Aux Rly	n	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	RLY027318	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Trip Bkr Coil 2 or Aux Rly	na	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Alarm Operation Correct?	n	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Follow-up Action Required?	n	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	General Comments		
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Prove All BFI DC Paths	na	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Relay Trip Targets OK?	na	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Trip Bkr Coil 1 or Aux Rly	n	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	RLY027319	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Trip Bkr Coil 2 or Aux Rly	na	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Current Tap Position	2R	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Regulator As Left Counter	99787	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	9 Month Operations	4	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Max Tap Position	8R	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	General Comments		
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Current Tap Position	5R	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1199	Regulator	693-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	General Comments		
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	General Comments		
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Grounds in Place?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	General Comments		
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Bushing Condition	Good	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Bushing Condition	Good	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Amps C Ø	81.0	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Amps B Ø	118.0	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Amps A Ø	119.0	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Fault Operations Ground	0	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Foundation Condition	Good	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Fault Operations C Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Fault Operations B Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Fault Operations A Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Winding Temp Present	40	°C
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Winding Temp Max	42	°C
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Totalizer Meter Reading	.7614	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	RLY027318	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	Follow-up Action Required?	n	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Fault Operations Ground	0	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Fault Operations C Ø	0	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Fault Operations B Ø	0	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Fault Operations A Ø	0	
9/10/2020 12:14	Distribution	Green River Quarterly Inspection	RLY027318	RelayMicroprocessor	009-3412 Panel	Relay Microprocessor DC Circuit Check	General Comments		
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	9 Month Operations	18	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	BCH001231	Charger	142-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Oil Temp Max	36	°C
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	PF000219	PowerFuse	MG-1330 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	9 Months Operations	0	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Operations Counter AF	512	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	PF000219	PowerFuse	MG-1330 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	PF000218	PowerFuse	MG-452 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	20.3	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	PF000218	PowerFuse	MG-452 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	PF000217	PowerFuse	MG-4KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	PF000217	PowerFuse	MG-4KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	28.6	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	39.5	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Operations Counter AL	512	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Operations This Read AM	0	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Switching Operations	0	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Unknown Operations	0	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	9 Month Operations	3	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	BCH001231	Charger	142-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	BCH001231	Charger	142-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	BCH001231	Charger	142-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	BCH001231	Charger	142-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	General Comments		
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	MegaVar Demand Meter Max	0.00	MegaVars
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	MegaVar Demand Meter Min	-.02	MegaVars
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	MegaWatt Demand Meter Max	2.00	MegaWatts
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	MegaWatt Demand Meter Min	.05	MegaWatts

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	Oil Temp Max	45	°C
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	Oil Temp Present	35	°C
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	Vegetation	None	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	YD000063	Yard	570-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	General Comments	2 blown LA on A and B phase....one structure leg foundation is crumbling and another is starting to	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Maintenance Operations	1	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	9 Month Operations	4	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Operations B Ø	0	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Operations C Ø	0	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Operations Ground	0	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Operations Counter AF	142	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Oil Temp Present	33	°C
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Operations Counter AL	142	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Operations This Read Vac	1	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Follow-up Action Required?	n	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Patrol Inspection	General Comments		
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	General Comments		
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Switching Operations	0	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Unknown Operations	0	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Maintenance Operations	0	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	608	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments	ok	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:56	Distribution	Simmons Quarterly Inspection	WX0369	RecloserHydraulic	912-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/10/2020 11:18	Distribution	Burnside Quarterly Inspection	ST000071	Structure	570-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations C Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	General Comments	ok	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	CAP000057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	CAP000057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Tank Leaks	None	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	CAP000057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	CAP000057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Insulators in Good Condition?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	CAP000057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Grounds in Place?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	CAP000057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	CAP000057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	CAP000057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	CAP000057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Foundation Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	CAP000057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	CAP000057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	CAP000057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	CAP000057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Capacitor Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	CAP000057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Cap bank CT in Good Condition?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	CAP000057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	CAP000057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Bushing Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	CAP000057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	All Connections OK?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Fault Operations A Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AF	485	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Fault Operations B Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations Counter AL	485	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Operations This Read AM	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Switching Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Unknown Operations	0	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Maintenance Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Operations Counter AF	272	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Operations Counter AL	272	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Operations This Read AM	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Switching Operations	0	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Amps B Ø	35.0	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Amps C Ø	40.0	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Bushing Condition	Good	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Unknown Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Unknown Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Switching Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Operations This Read AM	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Operations Counter AL	42	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Foundation Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	General Comments	Back w 2 washouts	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Ambient Temp	84	°F
9/10/2020 9:46	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	General Comments		
9/10/2020 9:46	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	FE000254	Fence	481-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Vegetation	None	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	YD000257	Yard	481-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	General Comments		
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	CAP000057	CapacitorBank	SSC-Offline-Distribution	Capacitor Patrol Inspection	Warning Signs OK?		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps A Ø	0.0	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Amps A Ø	0.0	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Tank Leaks	None	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Regulator As Left Counter	91558	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps B Ø	0.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Amps C Ø	0.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Min Tap Position	9L	
9/10/2020 14:16	Distribution	Bevier Quarterly Inspection	R1206	Regulator	142-5 C	Regulator Patrol Inspection	Max Tap Position	3R	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations A Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0641	BreakerAirMagnetic	MG-Offline-Distribution	AMCB Readings	Fault Operations B Ø	0	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	General Comments		
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	40	°C
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	66	°C
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	40	°C
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	66	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Amps B Ø	270.0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Amps A Ø	319.0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	33	°C
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	54	°C
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	Oil Temp Present	40	°C
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Readings	Oil Temp Max	63	°C
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1500	psi
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LT0315	WithLTC	WO-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	General Comments		
9/10/2020 9:46	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	K0108	BreakerVacuum	494-0576	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	ST000264	Structure	481-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Unknown Operations	0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Switching Operations	1	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Operations This Read Vac	1	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Operations Counter AL	334	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Operations Counter AF	334	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Maintenance Operations	0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Grounds in Place?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	General Comments		
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	General Comments		
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Foundation Condition	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Follow-up Action Required?	n	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Fault Operations Ground	0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Fault Operations C Ø	0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Fault Operations B Ø	0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Fault Operations A Ø	0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Operations Counter AF	42	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Patrol Inspection	Bushing Condition	Good	
9/10/2020 13:17	Distribution	London Quarterly Inspection	K0078	BreakerVacuum	093-0205	VCB Readings	Amps C Ø	340.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Maintenance Operations	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Patrol Inspection	General Comments		
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	FE000142	Fence	771-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Min Tap Position	16L	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Max Tap Position	1R	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	General Comments		
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	ST000298	Structure	798-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	KR0106	Regulator	481-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Bushing Condition	Good	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1827.36	kw
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	9 Month Operations	3	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Amps C Ø	15.0	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Amps B Ø	5.0	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Amps A Ø	5.0	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Max Tap Position	7R	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/10/2020 9:46	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/10/2020 9:46	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/10/2020 9:46	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	9 Month Operations	5	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Bushing Condition	Good	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	BCH000425	Charger	006-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	BCH000425	Charger	006-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Regulator As Left Counter	177304	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Follow-up Action Required?	n	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Patrol Inspection	General Comments		
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Maintenance Operations	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Operations Counter AF	343	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Operations Counter AL	343	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Operations This Read Vac	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Switching Operations	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Unknown Operations	0	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Amps A Ø	622.0	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Fault Operations C Ø	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Fault Operations Ground	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Current Tap Position	2R	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/10/2020 9:46	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Operations This Read Vac	1	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Operations Counter AL	198	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Operations Counter AF	198	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Maintenance Operations	1	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Grounds in Place?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	General Comments		
9/10/2020 9:46	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	General Comments		
9/10/2020 9:46	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Foundation Condition	Good	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Follow-up Action Required?	n	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Fault Operations Ground	0	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Fault Operations C Ø	0	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Fault Operations B Ø	0	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Fault Operations A Ø	0	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	General Comments		
9/10/2020 9:46	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	BCH000425	Charger	006-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	BCH000425	Charger	006-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	BCH000425	Charger	006-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
9/10/2020 9:46	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	9 Months Operations	1	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Max Tap Position	6R	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	9 Month Operations	10	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	SWG000169	Switchgear	MG-14KV Sec B Swgr	Switchgear Patrol Inspection	Panels Dusted?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	SWG000169	Switchgear	MG-14KV Sec B Swgr	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	SWG000169	Switchgear	MG-14KV Sec B Swgr	Switchgear Patrol Inspection	General Comments		
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	SWG000169	Switchgear	MG-14KV Sec B Swgr	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	SWG000169	Switchgear	MG-14KV Sec B Swgr	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Regulator As Left Counter	78201	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Max Tap Position	6R	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	General Comments		
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	Totalizer Meter Reading	.9168	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/10/2020 13:17	Distribution	London Quarterly Inspection	MB0170	BreakerVacuum	093-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Operations Counter AF	376	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Maintenance Operations	0	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/10/2020 15:02	Distribution	Owingsville Quarterly Inspection	FE000287	Fence	798-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Patrol Inspection	Heaters (All) Functioning?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	General Comments		
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Patrol Inspection	General Comments		
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Follow-up Action Required?	n	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Operations Ground	0	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Operations C Ø	0	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Current Tap Position	3R	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Operations B Ø	0	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Operations A Ø	0	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	SWG000169	Switchgear	MG-14KV Sec B Swgr	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Amps C Ø	200.0	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Amps B Ø	200.0	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1140	Regulator	693-1 A	Regulator Patrol Inspection	General Comments		
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0570	BreakerAirMagnetic	LN-2	AMCB Readings	Amps A Ø	100.0	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Regulator As Left Counter	34469	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #-'s
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Unknown Operations	0	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Switching Operations	0	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Operations This Read Vac	4	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Operations Counter AL	207	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Operations Counter AF	206	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Amps C Ø	0.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Amps B Ø	0.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Amps A Ø	0.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0603	BreakerAirMagnetic	MG-1323	AMCB Readings	9 Months Operations	0	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Maintenance Operations	1	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.4	VDC
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.1	VDC
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Grounds in Place?	y	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	General Comments	Inst.,C,N 51 - 3 operations	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	General Comments		
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Foundation Condition	Good	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	Oil Temp Max	48	°C
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Amps A Ø	394.0	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Follow-up Action Required?	n	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Fault Operations Ground	0	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Fault Operations C Ø	3	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	General Comments		
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	LTC Totalizer Reading	8801.28	kw
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 11:26	Distribution	Beaver Dam North Quarterly Inspection	K0119	BreakerVacuum	641-0918	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	9 Months Operations	0	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/10/2020 10:39	Distribution	Hartford Quarterly Inspection	WB0157	BreakerVacuum	736-1912	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Operations A Ø	0	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	909	°F
9/10/2020 9:14	Distribution	Livermore Quarterly Inspection	K0131	BreakerVacuum	771-1642	VCB Readings	Amps A Ø	130.0	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	9 Month Operations	1	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Accumulated Fault Duty B Ph V	.36	%
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Amps A Ø	177.0	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Amps B Ø	171.0	
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	General Comments		
9/10/2020 13:28	Distribution	Whitley City Quarterly Inspection	FE000025	Fence	494-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Readings	Amps C Ø	172.0	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Unknown Operations	0	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 9:46	Distribution	Island Quarterly Inspection	K0135	BreakerVacuum	481-1638	VCB Readings	Switching Operations	0	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Amps A Ø	210.0	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	BAT000469	Battery	439-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Amps B Ø	250.0	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Amps C Ø	280.0	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	LB0569	BreakerAirMagnetic	LN-1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	9 Month Operations	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Fault Operations A Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	265.00	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Amps C Ø	345.0	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	9 Month Operations	6	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Amps A Ø	90.0	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Amps B Ø	50.0	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Current Tap Position	3R	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Readings	Amps C Ø	90.0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/10/2020 10:09	Distribution	Lynn Quarterly Inspection	PN61	WithLTC	LN-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	General Comments		
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Bushing Condition	Good	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Readings	General Comments		
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 8:02	Distribution	Graham Quarterly Inspection	K0072	BreakerVacuum	006-1603	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Amps A Ø	96.0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Amps B Ø	109.0	
9/10/2020 8:38	Distribution	Stringtown Quarterly Inspection	R1142	Regulator	693-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Fault Operations B Ø	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Amps C Ø	72.0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Fault Operations A Ø	0	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/14/2020 6:36	Distribution	Worthington Quarterly Inspection	LB1159	BreakerVacuum	WO-1179	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	BK001169	BreakerVacuum	850-4511	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Fault Operations B Ø	0	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Fault Operations A Ø	0	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Fault Adjusted Amps C Phase V	12.58	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Amps B Ø	379.2	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/10/2020 15:10	Distribution	Revelo Quarterly Inspection	S0065	NonLTC	894-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 10:44	Distribution	Waitsboro Quarterly Inspection	M0099	WithLTC	537-1	LTC Transformer Readings	Oil Temp Present	48	°C
9/10/2020 14:10	Distribution	Shavers Chapel Quarterly Inspection	R1329	Regulator	439-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Patrol Inspection	Bushing Condition	Good	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Amps C Ø	218.0	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Amps B Ø	236.0	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Amps A Ø	244.0	
9/10/2020 13:02	Distribution	Beaver Dam Quarterly Inspection	KB0135	BreakerVacuum	467-1916	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Fault Operations Ground	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Fault Operations C Ø	0	
9/10/2020 11:57	Distribution	Magazine Quarterly Inspection	LB0637	BreakerAirMagnetic	MG-4KV TR 1	AMCB Readings	Fault Operations B Ø	0	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Operations Counter AL	235	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Max Tap Position	3L	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	General Comments		
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Min Tap Position	3L	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Operations This Read Vac	4	
9/9/2020 11:24	Distribution	Jeffersonstown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Tank Leaks	None	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/9/2020 11:24	Distribution	Jeffersonton Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/9/2020 11:24	Distribution	Jeffersonton Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Reg Operation Checked?	n	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Foundation Condition	Good	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Follow-up Action Required?	n	
9/9/2020 11:24	Distribution	Jeffersonton Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	9 Month Operations	2	
9/9/2020 11:24	Distribution	Jeffersonton Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Regulator As Left Counter	96678	
9/9/2020 11:24	Distribution	Jeffersonton Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Follow-up Action Required?	n	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Fault Operations Ground	0	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/9/2020 11:24	Distribution	Jeffersonton Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Patrol Inspection	General Comments		
9/9/2020 11:24	Distribution	Jeffersonton Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Follow-up Action Required?	n	
9/9/2020 11:24	Distribution	Jeffersonton Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Patrol Inspection	Follow-up Action Required?	n	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	General Comments		
9/9/2020 11:24	Distribution	Jeffersonton Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Fault Operations Ground	0	
9/9/2020 11:24	Distribution	Jeffersonton Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Fault Operations C Ø	0	
9/9/2020 11:24	Distribution	Jeffersonton Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Fault Operations B Ø	0	
9/9/2020 11:24	Distribution	Jeffersonton Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Fault Operations A Ø	0	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	General Comments		
9/9/2020 11:24	Distribution	Jeffersonton Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	1.93	%
9/9/2020 11:24	Distribution	Jeffersonton Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	1.93	%
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Grounds in Place?	y	
9/9/2020 11:24	Distribution	Jeffersonton Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Amps A Ø	279.0	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Unknown Operations	0	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Tank Paint Condition	Good	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Switching Operations	2	
9/9/2020 11:24	Distribution	Jeffersonton Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Amps B Ø	290.0	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Maintenance Operations	0	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	LTCC000380	LTCControl	175-5	LTC Control Insp	VRR Time Delay	30	Seconds
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	LTCC000380	LTCControl	175-5	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	LTCC000380	LTCControl	175-5	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
9/9/2020 11:24	Distribution	Jeffersonton Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Amps C Ø	328.0	
9/9/2020 11:24	Distribution	Jeffersonton Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/9/2020 11:24	Distribution	Jeffersonton Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/9/2020 11:24	Distribution	Jeffersonton Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/9/2020 11:24	Distribution	Jeffersonton Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/9/2020 11:24	Distribution	Jeffersonton Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
9/9/2020 11:24	Distribution	Jeffersonton Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	LTCC000380	LTCControl	175-5	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	LTCC000380	LTCControl	175-5	LTC Control Insp	LTC Operation Checked?	y	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	LTCC000380	LTCControl	175-5	LTC Control Insp	General Comments		
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	LTCC000380	LTCControl	175-5	LTC Control Insp	Follow-up Action Required?	n	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	LTCC000380	LTCControl	175-5	LTC Control Insp	All Connections OK?	y	
9/9/2020 11:24	Distribution	Jeffersonton Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	9 Month Operations	1	
9/9/2020 11:24	Distribution	Jeffersonton Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	1.93	%
9/9/2020 11:24	Distribution	Jeffersonton Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/9/2020 11:24	Distribution	Jeffersonton Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	General Comments		
9/9/2020 11:24	Distribution	Jeffersonton Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/9/2020 11:24	Distribution	Jeffersonton Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/9/2020 11:24	Distribution	Jeffersonton Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/9/2020 11:24	Distribution	Jeffersonton Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/9/2020 11:24	Distribution	Jeffersonton Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/9/2020 11:24	Distribution	Jeffersonton Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/9/2020 11:24	Distribution	Jeffersonton Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/9/2020 11:24	Distribution	Jeffersonton Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/9/2020 11:24	Distribution	Jeffersonton Quarterly Inspection	FE000595	Fence	JT-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Current Tap Position	3L	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1081	Regulator	090-5 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/9/2020 11:24	Distribution	Jeffersonton Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Amps B Ø	87.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Amps C Ø	74.0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Fault Adjusted Amps C Phase V	11.18	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Fault Operations A Ø	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Fault Operations B Ø	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Fault Operations C Ø	1	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Fault Operations Ground	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Patrol Inspection	Follow-up Action Required?	n	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Follow-up Action Required?	n	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Operations Counter AL	409	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Operations This Read Vac	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Switching Operations	0	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Patrol Inspection	General Comments		
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	General Comments		
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Maintenance Operations	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Operations Counter AF	139	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	3.85	%
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	3.85	%
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Patrol Inspection	General Comments		
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	General Comments	C phase IOC	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Maintenance Operations	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Operations Counter AL	139	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Operations Counter AF	344	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Operations Counter AL	344	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Operations This Read Vac	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Switching Operations	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Operations This Read Vac	1	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Unknown Operations	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Switching Operations	0	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Maintenance Operations	0	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Accumulated Fault Duty C Ph V	3.19	%
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Amps A Ø	40.0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Amps B Ø	49.0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Amps C Ø	0.0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	General Comments		
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Fault Operations A Ø	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	General Comments		
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	9 Month Operations	2	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Tank Leaks	None	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Operations Counter AF	409	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Accumulated Fault Duty A Ph V	6.38	%
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Accumulated Fault Duty B Ph V	3.19	%
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Regulator As Left Counter	93731	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Reg Operation Checked?	n	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Reg Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Min Tap Position	16L	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Max Tap Position	2R	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	General Comments		
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Current Tap Position	3L	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1080	Regulator	090-5 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Tank Leaks	None	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Regulator As Left Counter	120164	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Reg Operation Checked?	n	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Min Tap Position	10L	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Max Tap Position	4R	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	General Comments		
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Fault Operations A Ø	0	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Fault Operations B Ø	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Fault Operations C Ø	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Fault Operations Ground	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Patrol Inspection	Follow-up Action Required?	n	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Follow-up Action Required?	n	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Current Tap Position	1L	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	R1079	Regulator	090-5 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	9 Month Operations	1	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Accumulated Fault Duty A Ph V	9.57	%
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Accumulated Fault Duty B Ph V	11.16	%
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Accumulated Fault Duty C Ph V	7.17	%
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Amps A Ø	61.0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Accumulated Fault Duty B Ph V	2.39	%
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Accumulated Fault Duty C Ph V	1.59	%
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Amps A Ø	122.0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Amps B Ø	115.0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Amps C Ø	147.0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Amps C Ø	25.0	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Bushing Condition	Good	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Min Tap Position	Neutral	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Max Tap Position	13L	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Unknown Operations	0	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	General Comments		
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Fault Adjusted Amps A Phase V	11.18	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Accumulated Fault Duty C Ph V	.8	%
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Accumulated Fault Duty B Ph V	.8	%
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Accumulated Fault Duty A Ph V	.8	%
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	9 Month Operations	0	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Fault Operations A Ø	0	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Fault Operations B Ø	0	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Fault Operations C Ø	0	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	General Comments		
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	General Comments		
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Operations Counter	1490	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Fault Operations B Ø	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Fault Operations C Ø	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Amps C Ø	0.0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Amps B Ø	0.0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Fault Operations Ground	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Patrol Inspection	Follow-up Action Required?	n	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Follow-up Action Required?	n	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Trash Emptied?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Patrol Inspection	General Comments		
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	General Comments		
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Maintenance Operations	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Operations Counter AF	161	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Operations Counter AL	161	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Regulator As Left Counter	30866	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	122.7	volts
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1335	BreakerVacuum	JT-1128	VCB Readings	Amps A Ø	0.0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Operations This Read Vac	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Switching Operations	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1334	BreakerVacuum	JT-1127	VCB Readings	Unknown Operations	0	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	General Comments		
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	ST000451	Structure	562-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	9 Month Operations	7	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0110	Regulator	562-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Amps A Ø	80.0	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Amps B Ø	80.0	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Amps C Ø	80.0	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0520	BreakerVacuum	JT-1121	VCB Readings	Unknown Operations	0	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Amps A Ø	25.0	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Amps B Ø	30.0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	9 Month Operations	3	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Accumulated Fault Duty A Ph V	10.36	%
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	General Comments		
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	9 Month Operations	4	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Accumulated Fault Duty A Ph V	19.93	%
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Accumulated Fault Duty B Ph V	14.35	%
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Accumulated Fault Duty C Ph V	23.92	%
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Amps A Ø	37.0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Amps B Ø	25.0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Amps C Ø	51.0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Ambient Temp	72	*F
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Fault Operations A Ø	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Fault Operations B Ø	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Fault Operations C Ø	0	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	LTC Operations Since Last Insp	1003	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	LTC Min Tap Position	5L	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	LTC Max Tap Position	3R	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	LTC Current Tap Position	1L	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	LTC As Left Counter	24038	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	LTC As Found Counter	24038	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Mechanism Patrol Inspection	General Comments		
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	General Comments		
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	C0432	LTCMechanism	175-5	LTC Counter Readings	Follow-up Action Required?	n	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	Follow-up Action Required?	n	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Amps A Ø	25.0	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Amps B Ø	20.0	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Amps C Ø	9.0	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Battery Load Check OK?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	General Comments		
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Operations Counter	99	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	CX0119	RecloserElectronic	090-0623	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Bushing Condition	Good	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Fault Adjusted Amps A Phase V	5.87	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	General Comments		
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Mechanism Patrol Inspection	General Comments		
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Fault Operations A Ø	2	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	LTC As Found Counter	14158	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	LTC As Left Counter	14161	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	LTC Current Tap Position	4L	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	LTC Max Tap Position	3R	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	LTC Min Tap Position	13L	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	LTC Operations Since Last Insp	1435	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	9 Month Operations	8	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Amps A Ø	45.0	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Amps B Ø	65.0	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Amps C Ø	50.0	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Bushing Condition	Good	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Fault Operations B Ø	0	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Fault Operations C Ø	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Operations Counter AF	180	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Maintenance Operations	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	General Comments		
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Patrol Inspection	General Comments		
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Follow-up Action Required?	n	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Patrol Inspection	Follow-up Action Required?	n	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Fault Operations Ground	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Fault Operations C Ø	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Fault Operations A Ø	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	General Comments		
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Mechanism Patrol Inspection	General Comments		
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	LTC As Found Counter	19712	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	LTC As Left Counter	19712	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	LTC Max Tap Position	4R	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	LTC Min Tap Position	8L	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	LTC Operations Since Last Insp	1243	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Fault Operations Ground	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Patrol Inspection	Follow-up Action Required?	n	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Follow-up Action Required?	n	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Patrol Inspection	General Comments		
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	General Comments		
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	ST000572	Structure	JT-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	General Comments		
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Maintenance Operations	0	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Operations Counter AF	222	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Operations Counter AL	222	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Operations This Read Vac	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Switching Operations	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1332	BreakerVacuum	JT-1125	VCB Readings	Unknown Operations	0	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	C0442	LTCMechanism	793-1	LTC Counter Readings	Follow-up Action Required?	n	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Amps A Ø	31.0	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Amps B Ø	21.0	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Amps C Ø	33.0	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	Oil Temp Present	38	°C
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	Oil Temp Max	52	°C
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1000	psi
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1123	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	28	°C
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	General Comments		
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Vegetation	None	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	46	°C
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	LTC Min Tap Position	11L	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1L	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	Totalizer Meter Reading	.4206	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	90	°F
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	General Comments		
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BAT001226	Battery	406-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	General Comments		
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	FE000445	Fence	562-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	38	°C
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	53	°C
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	38	°C
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	52	°C
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	38	°C
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	53	°C
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	LTC As Found Counter	20845	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	YD000468	Yard	793-Yard	Yard Patrol Inspection	General Comments		
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	9 Month Operations	8	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Amps A ∅	100.0	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Amps B ∅	95.0	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Amps C ∅	120.0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	General Comments		
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	General Comments		
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Operations Counter	50	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.4	amps
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BCH001175	Charger	406-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/9/2020 11:24	Distribution	Jeffersonstown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	LTC Current Tap Position	9L	
9/9/2020 11:24	Distribution	Jeffersonstown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/9/2020 11:24	Distribution	Jeffersonstown Quarterly Inspection	LT0314	LTCMechanism	JT-TRANS 1	LTC Counter Readings	LTC As Left Counter	20845	
9/9/2020 11:24	Distribution	Jeffersonstown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
9/9/2020 11:24	Distribution	Jeffersonstown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/9/2020 11:24	Distribution	Jeffersonstown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KX0207	RecloserElectronic	562-2441	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/9/2020 11:24	Distribution	Jeffersonstown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Unknown Operations	0	
9/9/2020 11:24	Distribution	Jeffersonstown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Switching Operations	0	
9/9/2020 11:24	Distribution	Jeffersonstown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Operations This Read Vac	0	
9/9/2020 11:24	Distribution	Jeffersonstown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Operations Counter AL	180	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	Oil Temp Present	50	°C
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	Oil Temp Max	60	°C
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	LTC Totalizer Reading	3028.32	kw
9/9/2020 11:24	Distribution	Jeffersonstown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/9/2020 11:24	Distribution	Jeffersonstown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/9/2020 11:24	Distribution	Jeffersonstown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/9/2020 11:24	Distribution	Jeffersonstown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/9/2020 11:24	Distribution	Jeffersonstown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	General Comments		
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	General Comments		
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Readings	Follow-up Action Required?	n	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/9/2020 11:24	Distribution	Jeffersonstown Quarterly Inspection	LT0314	WithLTC	JT-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	C0432	WithLTC	175-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/9/2020 11:24	Distribution	Jeffersonstown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Operations Counter AF	475	
9/9/2020 11:24	Distribution	Jeffersonstown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Maintenance Operations	0	
9/9/2020 11:24	Distribution	Jeffersonstown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	General Comments	A,C phase IOC	
9/9/2020 11:24	Distribution	Jeffersonstown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Patrol Inspection	General Comments		
9/9/2020 11:24	Distribution	Jeffersonstown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Follow-up Action Required?	n	
9/9/2020 11:24	Distribution	Jeffersonstown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Patrol Inspection	Follow-up Action Required?	n	
9/9/2020 11:24	Distribution	Jeffersonstown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Fault Operations Ground	0	
9/9/2020 11:24	Distribution	Jeffersonstown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Fault Operations C ∅	0	
9/9/2020 11:24	Distribution	Jeffersonstown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Fault Operations B ∅	0	
9/9/2020 11:24	Distribution	Jeffersonstown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Fault Operations A ∅	1	
9/9/2020 11:24	Distribution	Jeffersonstown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/9/2020 11:24	Distribution	Jeffersonstown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Min Tap Position	1L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Max Tap Position	13L	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	General Comments		
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Current Tap Position	5L	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Operations Counter AF	244	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Maintenance Operations	0	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	9 Month Operations	4	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Amps A Ø	18.0	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Amps B Ø	30.0	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Amps C Ø	20.0	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Switching Operations	0	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	ST000471	Structure	793-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	General Comments		
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Operations Counter	1425	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Operations This Read Vac	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Operations Counter AL	244	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Regulator As Left Counter	28299	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.8	volts
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Tank Paint Condition	Good	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Unknown Operations	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Unknown Operations	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Switching Operations	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Operations This Read Vac	1	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0522	BreakerVacuum	JT-1123	VCB Readings	Operations Counter AL	475	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	General Comments		
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Follow-up Action Required?	n	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Follow-up Action Required?	n	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Foundation Condition	Good	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	General Comments		
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	General Comments		
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Grounds in Place?	y	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Operations Counter AF	233	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Operations Counter	880	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Unknown Operations	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Switching Operations	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Operations This Read Vac	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Operations Counter AL	211	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Operations Counter AF	211	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Maintenance Operations	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	General Comments		
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Patrol Inspection	General Comments		
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Follow-up Action Required?	n	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Patrol Inspection	Follow-up Action Required?	n	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Fault Operations Ground	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Fault Operations C Ø	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Fault Operations B Ø	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Fault Operations A Ø	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Amps C Ø	87.0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Amps B Ø	101.0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Amps A Ø	85.0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Accumulated Fault Duty C Ph V	12.75	%
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Accumulated Fault Duty B Ph V	13.55	%
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	Accumulated Fault Duty A Ph V	19.13	%
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1333	BreakerVacuum	JT-1126	VCB Readings	9 Month Operations	7	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Fault Operations A Ø	0	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Fault Operations B Ø	0	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Fault Operations C Ø	0	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Fault Operations Ground	0	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Follow-up Action Required?	n	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	General Comments		
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	General Comments		
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Maintenance Operations	0	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Operations Counter AF	213	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Operations Counter AL	215	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Operations This Read Vac	2	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Switching Operations	2	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Readings	Unknown Operations	0	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Amps A Ø	20.0	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Amps B Ø	25.0	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Amps C Ø	30.0	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	General Comments		
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	FE000463	Fence	793-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Patrol Inspection	General Comments		
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Fault Operations Ground	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BK000251	BreakerVacuum	406-0616	VCB Readings	Fault Operations Ground	0	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	BX0808	RecloserElectronic	793-2438	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Fault Operations A Ø	0	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Fault Operations B Ø	0	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Fault Operations C Ø	0	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Amps A Ø	70.0	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Fault Operations Ground	0	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Follow-up Action Required?	n	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Amps B Ø	70.0	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	BX0856	RecloserElectronic	793-2437	Recloser Electronic Patrol Inspection	Amps C Ø	70.0	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Follow-up Action Required?	n	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Foundation Condition	Good	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	General Comments		
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	General Comments		
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Grounds in Place?	y	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Maintenance Operations	0	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Operations Counter AF	161	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	O0188	LTCMechanism	406-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/9/2020 11:24	Distribution	Jeffersonstown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Amps A Ø	28.0	
9/9/2020 11:24	Distribution	Jeffersonstown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Accumulated Fault Duty C Ph V	8.77	%
9/9/2020 11:24	Distribution	Jeffersonstown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Accumulated Fault Duty B Ph V	6.38	%
9/9/2020 11:24	Distribution	Jeffersonstown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Accumulated Fault Duty A Ph V	12.75	%
9/9/2020 11:24	Distribution	Jeffersonstown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	9 Month Operations	1	
9/9/2020 11:24	Distribution	Jeffersonstown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/9/2020 11:24	Distribution	Jeffersonstown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
9/9/2020 11:24	Distribution	Jeffersonstown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Vegetation	None	
9/9/2020 11:24	Distribution	Jeffersonstown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
9/9/2020 11:24	Distribution	Jeffersonstown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/9/2020 11:24	Distribution	Jeffersonstown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/9/2020 11:24	Distribution	Jeffersonstown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/9/2020 11:24	Distribution	Jeffersonstown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/9/2020 11:24	Distribution	Jeffersonstown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/9/2020 11:24	Distribution	Jeffersonstown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	General Comments		
9/9/2020 11:24	Distribution	Jeffersonstown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/9/2020 11:24	Distribution	Jeffersonstown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/9/2020 11:24	Distribution	Jeffersonstown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/9/2020 11:24	Distribution	Jeffersonstown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/9/2020 11:24	Distribution	Jeffersonstown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Amps C Ø	62.0	
9/9/2020 11:24	Distribution	Jeffersonstown Quarterly Inspection	LB1331	BreakerVacuum	JT-1120	VCB Readings	Amps B Ø	46.0	
9/9/2020 11:24	Distribution	Jeffersonstown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	Totalizer Meter Reading	.8260	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	Oil Temp Present	45	°C
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	Oil Temp Max	60	°C
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	LTC Totalizer Reading	5947.20	kw
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Readings	General Comments		
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	General Comments		
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	O0188	WithLTC	406-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	General Comments		
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	General Comments		
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	LTC Totalizer Reading	6670.08	kw
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	Oil Temp Max	50	°C
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	Oil Temp Present	40	°C
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	Totalizer Meter Reading	.6948	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	C0442	WithLTC	793-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0111	Regulator	562-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Broom on Site?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	CH000149	ControlHouse	JT-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0526	BreakerVacuum	JT-12KV TR 2	VCB Readings	Unknown Operations	0	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Ambient Temp	75	°F
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Operations Counter AL	163	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Operations This Read Vac	2	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001337	BreakerVacuum	175-0615	VCB Readings	Switching Operations	2	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	General Comments		
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Vegetation	None	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	YD000450	Yard	562-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Regulator As Left Counter	299927	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	122.9	volts

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Min Tap Position	1R	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Max Tap Position	13L	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	General Comments		
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KR0112	Regulator	562-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Operations This Read Vac	2	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Switching Operations	2	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	LTCC000142	LTCControl	406-1	LTC Control Insp	All Connections OK?	y	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	LTCC000142	LTCControl	406-1	LTC Control Insp	Follow-up Action Required?	n	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	LTCC000142	LTCControl	406-1	LTC Control Insp	General Comments		
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	LTCC000142	LTCControl	406-1	LTC Control Insp	LTC Operation Checked?	y	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	LTCC000142	LTCControl	406-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	LTCC000142	LTCControl	406-1	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	LTCC000142	LTCControl	406-1	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	Non LTC Totalizer Reading	1129.68	kw
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	Oil Temp Max	55	°C
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	LTCC000142	LTCControl	406-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Tank Paint Condition	Good	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Unknown Operations	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	General Comments		
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1600	psi
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	Oil Temp Max	50	°C
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	Oil Temp Present	29	°C
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Amps C Ø	35.0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Amps B Ø	23.0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Amps A Ø	0.0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Accumulated Fault Duty C Ph V	23.92	%
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Accumulated Fault Duty B Ph V	19.13	%
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Accumulated Fault Duty A Ph V	16.74	%
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	9 Month Operations	2	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Fault Operations B Ø	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Fault Operations C Ø	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Fault Operations Ground	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Operations This Read Vac	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Operations Counter AL	140	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Operations Counter AF	140	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Equipment Properly Labeled?		
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Maintenance Operations	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	General Comments		
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Patrol Inspection	General Comments		
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Fault Operations Ground	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Amps C Ø	69.0	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	General Comments		
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Operations Counter AF	176	
9/9/2020 13:42	Distribution	Farmers Quarterly Inspection	BK001340	BreakerVacuum	175-0614	VCB Readings	Operations Counter AL	178	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Ambient Temp	90	*F
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Operations Counter AL	206	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Operations This Read Vac	1	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Switching Operations	1	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Unknown Operations	0	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	46	*C
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	26	*C
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	984	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	333	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	328	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Amps B Ø	69.0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Amps A Ø	85.0	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Accumulated Fault Duty C Ph V	20.73	%
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Accumulated Fault Duty B Ph V	17.54	%
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	Accumulated Fault Duty A Ph V	23.92	%
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	120.0	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	160.0	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	PF000185	PowerFuse	JT-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Follow-up Action Required?	n	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Patrol Inspection	General Comments		
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	General Comments		
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Maintenance Operations	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	54	°C
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	30	°C
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	53	°C
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	29	°C
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	General Comments		
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	53	°C
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	TX000243	WithLTC	JT-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	29	°C
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	General Comments		
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	LTC As Found Counter	5230	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	LTC As Left Counter	5230	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Operations Counter AF	206	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	LTC Current Tap Position	9L	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	LTC Max Tap Position	2L	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LTCM000099	LTCMechanism	JT-TRANS 2	LTC Counter Readings	LTC Min Tap Position	11L	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	Oil Temp Present	45	°C
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	Totalizer Meter Multiplier	1800	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Readings	Totalizer Meter Reading	.6276	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	YD000568	Yard	JT-Yard	Yard Patrol Inspection	Ambient Temp	80	°F
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Amps A Ø	0.0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Amps B Ø	0.0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Unknown Operations	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Amps C Ø	0.0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	PF000185	PowerFuse	JT-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	LTCC000261	LTCControl	793-1	LTC Control Insp	General Comments		
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	LTCC000261	LTCControl	793-1	LTC Control Insp	LTC Operation Checked?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	LTCC000261	LTCControl	793-1	LTC Control Insp	LTC Output Voltage Level	123.3	VAC
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	LTCC000261	LTCControl	793-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Maintenance Operations	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	General Comments		
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	LTCC000261	LTCControl	793-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	LTCC000261	LTCControl	793-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Follow-up Action Required?	n	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Patrol Inspection	Follow-up Action Required?	n	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Fault Operations Ground	0	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Amps C Ø	47.0	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Amps B Ø	51.0	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Winding Temp Present	40	°C
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Amps A Ø	41.0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Fault Operations C Ø	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Fault Operations B Ø	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	General Comments	This TR has been removed from station, needs to be removed from insp.	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LT0099	WithLTC	Retired Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	WX0258	RecloserElectronic	793-2439	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Fault Operations A Ø	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Fault Operations A Ø	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	PF000188	PowerFuse	JT-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	PF000187	PowerFuse	JT-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Operations Counter	99992	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	General Comments		
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	PF000187	PowerFuse	JT-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	PF000188	PowerFuse	JT-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	LTCC000261	LTCControl	793-1	LTC Control Insp	All Connections OK?	y	
9/9/2020 10:45	Distribution	Leitchfield City Quarterly Inspection	LTCC000261	LTCControl	793-1	LTC Control Insp	Follow-up Action Required?	n	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	3.85	%
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Amps A Ø	183.0	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KX0208	RecloserElectronic	562-2440	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Amps B Ø	219.0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Amps C Ø	202.0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	9 Month Operations	2	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty A Ph V	30.8	%
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty B Ph V	30.8	%
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Operations Counter AF	375	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Operations Counter AL	375	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	FE000387	Fence	406-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Operations This Read Vac	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Switching Operations	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1330	BreakerVacuum	JT-12KV BUS TIE SEC 1	VCB Readings	Accumulated Fault Duty C Ph V	30.8	%
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	General Comments		
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	General Comments		
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Vegetation	None	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	General Comments		
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	YD000391	Yard	406-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0521	BreakerVacuum	JT-1122	VCB Readings	9 Month Operations	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Unknown Operations	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB1329	BreakerVacuum	JT-12KV TR 1	VCB Readings	Switching Operations	0	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	SWG000024	Switchgear	JT-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	PF000186	PowerFuse	JT-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	PF000186	PowerFuse	JT-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Winding Temp Max	45	°C
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4968	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	4800	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2384.64	kw
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/9/2020 11:09	Distribution	Millwood Quarterly Inspection	KT0049	NonLTC	562-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	4.0	psi
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	LB0523	BreakerVacuum	JT-1124	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/9/2020 11:24	Distribution	Jeffersontown Quarterly Inspection	SWG000129	Switchgear	JT-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	BB0202	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	140.0	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Arching Horns Good Condition?	y	
9/9/2020 14:02	Distribution	Morehead West Quarterly Inspection	ST000394	Structure	406-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Amps C Ø	28.0	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Amps B Ø	20.0	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Amps A Ø	24.0	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	General Comments		
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Foundation Condition	Good	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Min Tap Position	12L	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Max Tap Position	3R	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Grounds in Place?	y	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	General Comments		
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Current Tap Position	1L	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 13:17	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/8/2020 13:17	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Foundation Condition	Good	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushing Condition	Good	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2020 13:17	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Vegetation	None	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2020 13:17	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	General Comments		
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	BK001338	BreakerVacuum	090-0622	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Free of Audible Arching?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	96	°F
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	General Comments		
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Operations Counter	96	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/8/2020 13:17	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
9/8/2020 13:17	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
9/8/2020 13:17	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/8/2020 13:17	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 13:17	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/8/2020 13:17	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/8/2020 13:17	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/8/2020 13:17	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/8/2020 13:17	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/8/2020 13:17	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
9/8/2020 13:17	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/8/2020 13:17	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	General Comments		
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.2	VDC
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	General Comments		
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BAT001387	Battery	500-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Winding Temp Present	30	°C
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Winding Temp Max	49	°C
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.1040	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	X0307	RecloserElectronic	751-0527	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	General Comments	A few limbs starting to grow over fence on one side.	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	FE000023	Fence	751-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Ambient Temp	82	°F
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	General Comments		
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Vegetation	None	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	YD000018	Yard	751-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	General Comments		
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	ST000017	Structure	751-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	ST000021	Structure	573-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Vegetation	None	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	General Comments		
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2649.60	kw
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	YD000022	Yard	573-Yard	Yard Patrol Inspection	Ambient Temp	74	°F
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	General Comments	Fabric and top rails rusty.	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	General Comments		
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	General Comments		
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	S0059	NonLTC	573-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	FE000027	Fence	573-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Fault Operations A Ø	0	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Fault Operations B Ø	0	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Fault Operations C Ø	0	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Fault Operations Ground	0	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Follow-up Action Required?	n	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	General Comments		
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	General Comments		
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Maintenance Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Operations Counter AF	210	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Operations Counter AL	210	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Operations This Read Vac	0	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Switching Operations	0	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	Totalizer Meter Reading	.7752	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	Oil Temp Present	48	°C
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	Oil Temp Max	60	°C
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	LTC Totalizer Reading	5581.44	kw
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	General Comments		
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	General Comments		
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Filters Condition OK?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Floor Swept?	n	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	General Comments		
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Fault Operations B ∅	0	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Fault Operations C ∅	0	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Fault Operations Ground	0	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Follow-up Action Required?	n	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	General Comments		
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	General Comments		
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Maintenance Operations	0	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Operations Counter AF	164	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Operations Counter AL	164	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Operations This Read Vac	0	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Switching Operations	0	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Unknown Operations	0	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	9 Month Operations	1	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Amps A Ø	135.0	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Amps B Ø	130.0	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Amps C Ø	142.0	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2020 13:17	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	General Comments	one insulator is chipped	
9/8/2020 13:17	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/8/2020 13:17	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 13:17	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/8/2020 13:17	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/8/2020 13:17	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/8/2020 13:17	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Vegetation	Light	
9/8/2020 13:17	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Ambient Temp	88	°F
9/8/2020 13:17	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/8/2020 13:17	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001253	BreakerVacuum	500-0540	VCB Readings	Unknown Operations	0	
9/8/2020 13:17	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	General Comments		
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	YD000167	Yard	500-Yard	Yard Patrol Inspection	Ambient Temp	84	°F
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	General Comments	top half fence rusty	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	FE000169	Fence	500-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	General Comments		
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Adequate	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	LTC Operations Since Last Insp	1277	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	LTC Min Tap Position	8L	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	LTC Max Tap Position	6R	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	LTC Current Tap Position	4R	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	LTC As Left Counter	8974	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	LTC As Found Counter	8965	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Mechanism Patrol Inspection	General Comments		
9/8/2020 13:17	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/8/2020 13:17	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/8/2020 13:17	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/8/2020 13:17	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	General Comments		
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	C0511	LTCMechanism	500-1	LTC Counter Readings	Follow-up Action Required?	n	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Operations Counter	81	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	General Comments		
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	C0511	WithLTC	500-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/8/2020 13:17	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/8/2020 13:17	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/8/2020 13:17	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Insulators In Good Condition?	n	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	ST000174	Structure	500-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/8/2020 13:17	Distribution	Ferguson Quarterly Inspection	ST000086	Structure	856-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Operations Counter	22	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	General Comments		
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	100.00	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BCH001292	Charger	500-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BCH001292	Charger	500-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BCH001292	Charger	500-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BCH001292	Charger	500-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BCH001292	Charger	500-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.9	amps
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BCH001292	Charger	500-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.2	VDC
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BCH001292	Charger	500-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.2	VDC
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BCH001292	Charger	500-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	5.500	millivolts
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	General Comments	top rail rusty .bottom of alot of the fence has a large gap	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Amps A Ø	42.0	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Amps B Ø	49.0	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Amps C Ø	70.0	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	X0306	RecloserElectronic	751-0528	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	FE000108	Fence	850-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Winding Temp Present	43	°C
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Winding Temp Max	50	°C
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Oil Level	Good	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Regulator As Left Counter	353210	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Leaks	None	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1439	Regulator	951-Offline-Distribution	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/8/2020 13:17	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/8/2020 13:17	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/8/2020 13:17	Distribution	Ferguson Quarterly Inspection	YD000079	Yard	856-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Amps A Ø	25.0	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Amps B Ø	42.0	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Amps C Ø	19.0	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Current Tap Position	3L	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	General Comments		
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Min Tap Position	14L	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Regulator As Left Counter	67693	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Unable to Reset	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/9/2020 12:59	Distribution	Rodburn Quarterly Inspection	B0283	NonLTC	090-5	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	General Comments	27/24.8	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	MX0324	RecloserElectronic	573-0547	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1441	Regulator	573-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	9 Month Operations	3	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Amps A Ø	76.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Amps B Ø	71.0	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Amps C Ø	45.0	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Current Tap Position	3R	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	BK001252	BreakerVacuum	500-0539	VCB Readings	Fault Operations A Ø	0	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	General Comments		
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Max Tap Position	7R	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Regulator As Left Counter	52592	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1497	Regulator	751-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	CH000410	ControlHouse	500-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.0290	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Oil Temp Present	46	°C
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Oil Temp Max	52	°C
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2469.60	kw
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	General Comments		
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	General Comments		
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Amps A Ø	37.0	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Amps B Ø	30.0	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Amps C Ø	42.0	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	General Comments	26.9/24.8	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Operations Counter	11	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	MX0304	RecloserElectronic	573-0546	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	S0058	NonLTC	751-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	LTCC000822	LTCControl	500-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	LTCC000822	LTCControl	500-1	LTC Control Insp	LTC Operation Checked?	n	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	LTCC000822	LTCControl	500-1	LTC Control Insp	General Comments		
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Regulator As Left Counter	50854	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	General Comments		
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Max Tap Position	5R	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	General Comments		
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	LTCC000822	LTCControl	500-1	LTC Control Insp	Follow-up Action Required?	n	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	LTCC000822	LTCControl	500-1	LTC Control Insp	All Connections OK?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.1	volts
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Regulator As Left Counter	46013	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Ambient Temp	85	°F
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Current Tap Position	2R	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	General Comments		
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Vegetation	None	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	YD000107	Yard	850-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 13:17	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/8/2020 13:17	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	General Comments		two large gaps on side closest to the scrap yard. very rusty, one bayonet is broken
9/8/2020 13:17	Distribution	Ferguson Quarterly Inspection	FE000079	Fence	856-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	General Comments		
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Min Tap Position	12L	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	General Comments		
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	125.0	volts
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Regulator As Left Counter	59323	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Current Tap Position	1R	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Trash Emptied?	n	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	General Comments		
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	LTCC000822	LTCControl	500-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	n	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	LTCC000822	LTCControl	500-1	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Broom on Site?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 11:45	Distribution	Waynesburg Quarterly Inspection	R1440	Regulator	573-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Control House Lighting OK?	n	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1499	Regulator	751-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	R1498	Regulator	751-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2020 13:08	Distribution	Ferguson South Quarterly Inspection	LTCC000822	LTCControl	500-1	LTC Control Insp	VRR Time Delay	45	Seconds
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/10/2020 10:09	Distribution	McKee Road Quarterly Inspection	ST000112	Structure	850-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/8/2020 13:06	Distribution	Science Hill Quarterly Inspection	CH000479	ControlHouse	751-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Fault Operations	0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Operations This Read SF6	0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Operations Counter AL	1418	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Operations Counter AF	1418	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Num Operations Last 9 Months	0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Maintenance Operations	0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	General Comments		
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Patrol Inspection	General Comments		
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Follow-up Action Required?	n	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Patrol Inspection	Follow-up Action Required?	n	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Fault Operations	0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	123	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	123	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Amps C Ø	600.0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Amps B Ø	700.0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0862	BreakerSF6	SH-12KV TR 2	GCB Readings	Amps A Ø	550.0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Amps A Ø	140.0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Amps B Ø	160.0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Amps C Ø	160.0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Fault Operations	6	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Patrol Inspection	Follow-up Action Required?	n	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Follow-up Action Required?	n	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Patrol Inspection	General Comments		
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	General Comments	a/b phase ioc	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Maintenance Operations	0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Num Operations Last 9 Months	29	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Operations Counter AF	679	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Operations Counter AL	679	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	PF000356	PowerFuse	SH-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	PF000356	PowerFuse	SH-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	280.0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	290.0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	280.0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Operations This Read SF6	6	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Switching Operations	0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0857	BreakerSF6	SSC-Offline-Distribution	GCB Readings	Unknown Operations	0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	General Comments		
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Maintenance Operations	0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Num Operations Last 9 Months	1	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Operations Counter AF	777	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Operations Counter AL	777	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Operations This Read SF6	0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Switching Operations	0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0858	BreakerSF6	SH-1283	GCB Readings	Unknown Operations	0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	Oil Temp Present	41	°C
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	Oil Temp Max	58	°C
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-5	psi
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	General Comments		
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	16.0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	29.0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	23.0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0864	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	5	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	PF000359	PowerFuse	SH-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	PF000359	PowerFuse	SH-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	9	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	10.0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	10.0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	10.0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0865	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Operations Counter AF	690	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Operations Counter AL	690	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Operations This Read SF6	0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Switching Operations	0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Follow-up Action Required?	n	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Unknown Operations	0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Patrol Inspection	Follow-up Action Required?	n	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	60	°C
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Fault Operations	0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Amps C Ø	120.0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Amps B Ø	140.0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Amps A Ø	120.0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Needs Replaced	check oil cup

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	42	°C
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	60	°C
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	161.0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	168.0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	LTC As Left Counter	85907	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	LTC As Found Counter	85907	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	42	°C
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	60	°C
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Mechanism Patrol Inspection	General Comments	need desiccant	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Num Operations Last 9 Months	12	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	LTC Current Tap Position	3L	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	LTC Max Tap Position	9L	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	LTC Min Tap Position	3R	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0867	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	3	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Operations Counter AF	398	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	3	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	SWG000180	Switchgear	SH-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Operations Counter AL	398	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Operations This Read SF6	0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Switching Operations	0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Maintenance Operations	0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	General Comments		
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Patrol Inspection	General Comments		
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	7	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0856	BreakerSF6	SH-1285	GCB Readings	Unknown Operations	0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	73.0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Amps A Ø	140.0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Amps B Ø	140.0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Amps C Ø	160.0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Fault Operations	0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Patrol Inspection	Follow-up Action Required?	n	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Follow-up Action Required?	n	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Patrol Inspection	General Comments		
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	General Comments	correct vc	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Maintenance Operations	0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0860	BreakerSF6	SH-1282	GCB Readings	Num Operations Last 9 Months	5	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1033	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Operations This Read SF6	0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Operations Counter AL	82	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Operations Counter AF	82	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Switching Operations	0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	SWG000072	Switchgear	SH-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Unknown Operations	0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Num Operations Last 9 Months	4	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Maintenance Operations	0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	General Comments		
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Patrol Inspection	General Comments		
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Readings	Follow-up Action Required?	n	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0859	BreakerSF6	SH-1284	GCB Patrol Inspection	Follow-up Action Required?	n	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	General Comments		
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0170	LTCMechanism	SH-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	171.0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	99956	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	99956	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0863	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0868	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	90.0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0170	WithLTC	SH-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	42	°C
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	PF000357	PowerFuse	SH-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	PF000357	PowerFuse	SH-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	100.0	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LB0866	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Current Tap Position	6L	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	General Comments		
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Switching Operations	0	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	9 Month Operations	0	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	9 Month Operations	2	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Amps A Ø	360.0	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Amps B Ø	360.0	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Amps A Ø	95.0	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Regulator As Left Counter	102244	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	80	°F
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Fault Operations B Ø	0	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	General Comments		
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	General Comments		
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	LTC Totalizer Reading	5644.80	kw
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	LTC Current Tap Position	3R	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	LTC Max Tap Position	3R	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	LTC Min Tap Position	9L	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	LTC Operations Since Last Insp	1725	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	LTC As Left Counter	93420	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	LTC As Found Counter	93409	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Mechanism Patrol Inspection	General Comments		
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	General Comments		
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	LTCC000565	LTCCControl	743-2	LTC Control Insp	Follow-up Action Required?	n	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	LTCC000565	LTCCControl	743-2	LTC Control Insp	General Comments		
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	LTCC000565	LTCCControl	743-2	LTC Control Insp	LTC Operation Checked?	y	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	LTCC000565	LTCCControl	743-2	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	LTCC000565	LTCCControl	743-2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	C0531	LTCMechanism	566-1	LTC Counter Readings	Follow-up Action Required?	n	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Winding Temp Present	77	°C
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	LTCC000565	LTCCControl	743-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	LTCC000565	LTCCControl	743-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	LTCC000565	LTCCControl	743-2	LTC Control Insp	VRR Time Delay	30	Seconds
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	General Comments		
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	General Comments		
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	LTCC000565	LTCCControl	743-2	LTC Control Insp	All Connections OK?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Winding Temp Max	77	°C
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9770	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Unknown Operations	0	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	General Comments	lightening arrestors have come loose at the chance clamp. 4618 circuit	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Tank Paint Condition	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Fault Operations B Ø	0	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Amps C Ø	400.0	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	General Comments		
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	Totalizer Meter Reading	.6060	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Max Tap Position	3L	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	LTC Min Tap Position	7L	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	LTC Max Tap Position	14L	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	LTC Current Tap Position	10L	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	General Comments		
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	LTC As Left Counter	2412	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	Winding Temp Max	60	°C
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	Winding Temp Present	45	°C
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	310.00	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	General Comments		
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	LTC As Found Counter	2412	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	Oil Temp Present	45	°C
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	Oil Temp Max	45	°C
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	75.00	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	83.33	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	Non LTC Totalizer Reading	4358.40	kw
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	LTC Current Tap Position	2R	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	LTC Max Tap Position	7R	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	LTC Min Tap Position	9L	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	LTC Operations Since Last Insp	1826	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	Totalizer Meter Reading	.4540	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	LTC As Left Counter	166522	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	LTC As Found Counter	166512	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Mechanism Patrol Inspection	General Comments		
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	General Comments		
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	M0100	LTCMechanism	566-2	LTC Counter Readings	Follow-up Action Required?	n	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	General Comments		
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	General Comments		
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Bushing Condition	Good	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Amps C Ø	300.0	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Amps B Ø	310.0	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Amps A Ø	260.0	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	LTC Totalizer Reading	9446.40	kw
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BAT000435	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	General Comments		
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	General Comments		
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	9 Month Operations	4	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Fault Operations A Ø	0	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Ambient Temp	70	*F
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BCH001217	Charger	743-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	General Comments		
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0026	NonLTC	819-2	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Vegetation	None	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	YD000170	Yard	778-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	ST000384	Structure	743-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	80	*F
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Operations This Read Vac	0	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Operations Counter AL	151	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Unknown Operations	0	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Operations Counter AF	151	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Maintenance Operations	0	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Grounds in Place?	y	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	General Comments		
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	General Comments	low spots in the station with standing water.	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Vegetation	None	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	General Comments		
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Foundation Condition	Good	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Follow-up Action Required?	n	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Vegetation	None	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	9 Month Operations	12	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Amps A Ø	110.0	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Amps B Ø	120.0	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Amps C Ø	95.0	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Bushing Condition	Good	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Fault Adjusted Amps A Phase V	10.39	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Fault Adjusted Amps B Phase V	10.39	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Fault Adjusted Amps C Phase V	10.39	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Fault Operations A Ø	2	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Fault Operations B Ø	2	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Fault Operations C Ø	2	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Fault Operations Ground	0	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Follow-up Action Required?	n	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Fault Operations Ground	0	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Fault Operations C Ø	0	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Unknown Operations	0	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Tank Paint Condition	Good	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Switching Operations	0	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Maintenance Operations	0	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	General Comments		
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	Follow-up Action Required?	n	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	9 Month Operations	4	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Grounds in Place?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	General Comments		
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Ambient Temp	80	*F
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	YD000051	Yard	411-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	General Comments		
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	General Comments		
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Current Tap Position	7L	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Ambient Temp	80	*F
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Fault Operations Ground	0	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Follow-up Action Required?	n	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Bushing Condition	Good	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	LTCC000922	LTCControl	778-1	LTC Control Insp	VRR Time Delay	60	Seconds
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	LTCC000922	LTCControl	778-1	LTC Control Insp	VRR Base Voltage AL	123.1	VAC
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	LTCC000922	LTCControl	778-1	LTC Control Insp	VRR Base Voltage AF	123.1	VAC
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	LTCC000922	LTCControl	778-1	LTC Control Insp	LTC Output Voltage Level	123.1	VAC
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	LTCC000922	LTCControl	778-1	LTC Control Insp	LTC Operation Checked?	y	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	LTCC000922	LTCControl	778-1	LTC Control Insp	General Comments		
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	LTCC000922	LTCControl	778-1	LTC Control Insp	Follow-up Action Required?	n	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	LTCC000922	LTCControl	778-1	LTC Control Insp	All Connections OK?	y	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Bushing Condition	Good	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Amps C Ø	60.0	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Amps B Ø	120.0	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Amps A Ø	120.0	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Acceptable Building Appearance?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Control House Lighting OK?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Evidence of Insects	None	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Floor Swept?	n	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Follow-up Action Required?	n	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	General Comments		
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Trash Emptied?	n	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	9 Month Operations	7	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	CH000006	ControlHouse	Retired Distribution	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Follow-up Action Required?	n	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Foundation Condition	Good	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	General Comments		
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	General Comments		
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Grounds in Place?	y	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Maintenance Operations	0	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Operations Counter AF	213	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Operations Counter AL	215	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Operations This Read Vac	2	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Switching Operations	2	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Patrol Inspection	Tank Paint Condition	Good	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Amps A Ø	310.0	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Amps B Ø	215.0	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Amps C Ø	225.0	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Fault Operations B Ø	0	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Fault Operations A Ø	0	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	General Comments		
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Follow-up Action Required?	n	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Follow-up Action Required?	n	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Foundation Condition	Good	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	General Comments		
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	Totalizer Meter Reading	.5880	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	Oil Temp Present	45	°C
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	Oil Temp Max	60	°C
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	General Comments		
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Grounds in Place?	y	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Maintenance Operations	0	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Operations Counter AF	1052	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Operations Counter AL	1054	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Operations This Read Vac	8	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Switching Operations	2	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Patrol Inspection	Tank Paint Condition	Good	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BB0372	BreakerVacuum	743-0802	VCB Readings	Unknown Operations	0	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	YD000042	Yard	566-Yard	Yard Patrol Inspection	Ambient Temp	85	°F
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BK000249	BreakerVacuum	743-0801	VCB Readings	Fault Operations C Ø	0	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	MB0121	BreakerVacuum	778-0221	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	Follow-up Action Required?	n	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	General Comments		
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	General Comments		
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Moisture and Leak Free?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Indicator Zone	OK	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Tank Leaks	None	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Regulator As Left Counter	11963	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Unknown Operations	0	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Tank Paint Condition	Good	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Switching Operations	0	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Operations This Read Vac	0	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Operations Counter AL	251	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Operations Counter AF	251	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Maintenance Operations	0	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Grounds in Place?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	General Comments		
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	General Comments		
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Foundation Condition	Good	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Follow-up Action Required?	n	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Follow-up Action Required?	n	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Fault Operations Ground	0	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Fault Operations C Ø	0	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Fault Operations B Ø	0	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Fault Operations A Ø	0	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Patrol Inspection	Bushing Condition	Good	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Amps C Ø	232.0	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Min Tap Position	12L	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Amps A Ø	370.0	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Amps B Ø	415.0	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Amps C Ø	400.0	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Bushing Condition	Good	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	Oil Temp Present	45	°C
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	Oil Temp Max	50	°C
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	ST000056	Structure	411-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Trash Emptied?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Fault Operations A Ø	0	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Fault Operations B Ø	0	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Fault Operations C Ø	0	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Fault Operations Ground	0	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Follow-up Action Required?	n	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Foundation Condition	Good	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	General Comments		
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	General Comments		
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Fault Operations C Ø	0	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Fault Operations Ground	0	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Follow-up Action Required?	n	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Follow-up Action Required?	n	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Foundation Condition	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	General Comments		
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	Oil Temp Max	59	°C
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	Oil Temp Present	39	°C
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	LTCC000201	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	LTCC000201	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	LTCC000201	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Operations Counter AL	164	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Operations This Read Vac	0	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Switching Operations	0	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Tank Paint Condition	Good	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Unknown Operations	0	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	LTCC000201	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Amps B Ø	215.0	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Amps A Ø	222.0	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	KB0114	BreakerVacuum	566-0285	VCB Readings	9 Month Operations	8	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	LTCC000201	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	LTCC000201	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	LTCC000201	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	LTCC000201	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	LTC Totalizer Reading	10908.00	kw
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Vegetation	None	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	FE000170	Fence	778-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	General Comments		
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	B0392	WithLTC	743-2	LTC Transformer Readings	General Comments		
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	General Comments	barb wire rusty	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	9 Month Operations	31	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Operations Counter AL	165	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Operations Counter AF	165	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BAT000970	Battery	566-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Max Tap Position	5L	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000009	Regulator	819-2 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	General Comments		
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Maintenance Operations	0	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Operations Counter AF	258	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Operations Counter AL	258	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	CH000239	ControlHouse	411-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Switching Operations	0	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0064	BreakerVacuum	951-Offline-Distribution	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	General Comments		
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Grounds in Place?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Maintenance Operations	0	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	KB0083	BreakerVacuum	743-2	VCB Readings	Operations Counter AF	164	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	Totalizer Meter Reading	.9840	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	C0531	WithLTC	566-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	537	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0271	GroundTransformer	SH-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	YD000304	Yard	819-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	LTC As Left Counter	97416	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	LTC Max Tap Position	5R	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	LTC Min Tap Position	5L	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	LTC Operations Since Last Insp	1286	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Foundation Condition	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	General Comments		
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	General Comments		
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	General Comments		
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Grounds in Place?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Maintenance Operations	0	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Amps A Ø	165.0	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Amps B Ø	165.0	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Amps C Ø	160.0	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Bushing Condition	Good	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	BCH001406	Charger	411-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.400	millivolts
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	BCH001406	Charger	411-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	BCH001406	Charger	411-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	General Comments		
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	BCH001406	Charger	411-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Unknown Operations	0	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Tank Paint Condition	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Operations Counter AF	189	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Operations Counter AL	191	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	Oil Temp Max	45	°C
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	Oil Temp Present	40	°C
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	General Comments		
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	FE000052	Fence	411-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Bushing Condition	Good	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Amps C Ø	0.0	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	Totalizer Meter Reading	.4460	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Max Tap Position	5R	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	9 Month Operations	6	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.2	volts
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Regulator As Left Counter	96211	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	General Comments		
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Mechanism Patrol Inspection	General Comments		
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	LTC As Found Counter	97405	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	General Comments		
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	General Comments		
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	BCH001406	Charger	411-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	BCH001406	Charger	411-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BCH000497	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Ambient Temp	75	°F
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BCH000497	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Current Tap Position	7L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	BCH001408	Charger	778-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.000	millivolts
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	BCH001408	Charger	778-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	BCH001408	Charger	778-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	BCH001408	Charger	778-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	0.0	amps
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	BCH001408	Charger	778-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	BCH001408	Charger	778-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	BCH001408	Charger	778-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	LTCC000892	LTCControl	566-2	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	General Comments		
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Fault Operations B Ø	0	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Fault Operations C Ø	0	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	General Comments		
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Fault Operations Ground	0	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Follow-up Action Required?	n	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Oil Temp Present	59	°C
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Fault Adjusted Amps C Phase V	9.62	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Fault Operations A Ø	0	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	BCH001406	Charger	411-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	BCH001406	Charger	411-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	Follow-up Action Required?	n	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	General Comments		
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Fault Operations B Ø	0	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Fault Operations C Ø	2	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Fault Operations Ground	0	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Mechanism Patrol Inspection	General Comments		
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	LTC As Found Counter	27335	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	M0100	WithLTC	566-2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	LTC As Left Counter	27335	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	LTC Current Tap Position	5L	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	LTC Max Tap Position	2R	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	LTC Min Tap Position	10L	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	LTC Operations Since Last Insp	1482	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	LTCM000051	LTCMechanism	743-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	°F
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Follow-up Action Required?	n	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Follow-up Action Required?	n	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	LTC Totalizer Reading	4281.60	kw
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	General Comments		
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Fault Adjusted Amps C Phase V	4.94	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Fault Operations A Ø	0	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Amps C Ø	79.0	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Operations Counter AL	186	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Operations Counter AF	186	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Fault Operations C Ø	0	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Fault Operations B Ø	0	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Fault Operations A Ø	0	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	LTCC000893	LTCControl	566-1	LTC Control Insp	General Comments		
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	LTCC000893	LTCControl	566-1	LTC Control Insp	Follow-up Action Required?	n	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	LTCC000893	LTCControl	566-1	LTC Control Insp	All Connections OK?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Fault Operations B Ø	0	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Maintenance Operations	0	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Fault Operations C Ø	1	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Fault Operations Ground	0	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Follow-up Action Required?	n	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Follow-up Action Required?	n	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Foundation Condition	Good	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Grounds in Place?	y	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	BAT001474	Battery	778-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Bushing Condition	Good	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	50	°C
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	60	°C
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	Oil Temp Present	60	°C
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	Oil Temp Max	65	°C
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1400	psi
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	General Comments		
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Operations This Read Vac	0	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	LTCC000893	LTCControl	566-1	LTC Control Insp	LTC Output Voltage Level	124.4	VAC
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Current Tap Position	1R	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.6	psi
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	General Comments		
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	LTCC000893	LTCControl	566-1	LTC Control Insp	LTC Operation Checked?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Fault Operations Ground	0	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	LTC As Found Counter	13261	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	LTCC000892	LTCControl	566-2	LTC Control Insp	VRR Time Delay	30	Seconds
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Mechanism Patrol Inspection	General Comments		
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	General Comments		
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	Follow-up Action Required?	n	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	B0476	LTCMechanism	778-1	LTC Counter Readings	Follow-up Action Required?	n	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	LTCC000892	LTCControl	566-2	LTC Control Insp	VRR Base Voltage AL	124.1	VAC
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	LTCC000892	LTCControl	566-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Fault Operations A Ø	0	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	General Comments		
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Foundation Condition	Good	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Follow-up Action Required?	n	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	General Comments		
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	CH000492	ControlHouse	778-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	General Comments		
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Amps B Ø	97.0	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Amps A Ø	80.0	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	ST000312	Structure	819-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	9 Month Operations	2	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0008	WithLTC	819-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Switching Operations	0	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Tank Paint Condition	Good	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	Unknown Operations	0	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Readings	General Comments		
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0171	WithLTC	SH-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BCH001348	Charger	566-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	3.000	millivolts
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BCH001348	Charger	566-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BCH001348	Charger	566-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BCH001348	Charger	566-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BCH001348	Charger	566-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK000890	BreakerVacuum	566-0287	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BCH001348	Charger	566-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BCH001348	Charger	566-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	LTC Operations Since Last Insp	774	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	LTC Min Tap Position	9L	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	LTC Max Tap Position	1L	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	LTC Current Tap Position	5L	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BCH001348	Charger	566-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	S0008	LTCMechanism	819-1	LTC Counter Readings	LTC As Left Counter	13261	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Grounds in Place?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	General Comments		
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	General Comments		
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Foundation Condition	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Tank Paint Condition	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Switching Operations	2	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Operations This Read Vac	2	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Follow-up Action Required?	n	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Follow-up Action Required?	n	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Internal Condition?	Clean	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Follow-up Action Required?	n	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Operations Counter AL	202	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Operations Counter AF	200	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Maintenance Operations	0	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Grounds in Place?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	General Comments		
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	General Comments		
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Foundation Condition	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Follow-up Action Required?	n	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Follow-up Action Required?	n	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Amps A Ø	0.0	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Amps B Ø	0.0	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Vegetation	None	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	9379.20	kw
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	General Comments		
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Bushing Condition	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Amps C Ø	75.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	LTCC000893	LTCControl	566-1	LTC Control Insp	VRR Time Delay	60	Seconds
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Amps B Ø	65.0	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Fault Operations A Ø	0	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Amps A Ø	75.0	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Unknown Operations	0	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	General Comments	cg	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Operations Counter AL	287	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Operations Counter AF	287	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	9 Month Operations	4	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	*F
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Maintenance Operations	0	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Amps B Ø	125.0	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	Totalizer Meter Reading	.4730	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Current Tap Position	2R	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Operations This Read Vac	0	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Switching Operations	0	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	General Comments		
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Operations Counter	7	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Patrol Inspection	Tank Paint Condition	Good	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	*F
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	FE000867	Fence	743-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	K0199	BreakerVacuum	819-0806	VCB Readings	Unknown Operations	0	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Grounds in Place?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Maintenance Operations	0	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Operations Counter AF	191	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Operations Counter AL	191	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	BK001442	BreakerVacuum	566-0286	VCB Readings	Operations This Read Vac	1	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Fault Operations Ground	0	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Fault Operations C Ø	0	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Fault Operations B Ø	0	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Fault Operations A Ø	0	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	Negative DC Ground	26.0	VDC
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Regulator As Left Counter	143795	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.1	volts
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Current Tap Position	Neutral	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	General Comments		
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	General Comments		
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Patrol Inspection	Bushing Condition	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000888	BreakerVacuum	819-0795	VCB Readings	Amps C Ø	90.0	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1359	Regulator	411-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Oil Temp Max	66	°C
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Tank Leaks	None	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Ambient Temperature	80	°F
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Bushings Connection/Risers	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	CS000007	CircuitSwitcher	819-2 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Heaters Functioning?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Operations This Read Vac	2	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Switching Operations	2	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Switching Operations	0	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	9 Month Operations	3	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Regulator As Left Counter	12113	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Regulator As Left Counter	13574	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	General Comments		
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000010	Regulator	819-2 B	Regulator Patrol Inspection	Min Tap Position	10L	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BCH000497	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BCH000497	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BCH000497	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	BCH000497	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Max Tap Position	4L	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	LTCC000892	LTCControl	566-2	LTC Control Insp	LTC Operation Checked?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	LTCC000892	LTCControl	566-2	LTC Control Insp	General Comments		
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	LTCC000892	LTCControl	566-2	LTC Control Insp	Follow-up Action Required?	n	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	LTCC000892	LTCControl	566-2	LTC Control Insp	All Connections OK?	y	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Amps C Ø	48.0	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Min Tap Position	11L	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	ST000044	Structure	566-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	YD000380	Yard	743-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/5/2020 16:58	Distribution	Shively Quarterly Inspection	LT0171	LTCMechanism	SH-TRANS 1	LTC Counter Readings	General Comments		
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1358	Regulator	411-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Amps B Ø	21.0	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	MX0350	RecloserElectronic	778-0222	Recloser Electronic Patrol Inspection	Amps A Ø	24.0	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	General Comments		
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Follow-up Action Required?	n	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	FE000845	Fence	Retired Distribution	Fence Patrol Inspection	Fence Ties Intact?	y	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	BCH001408	Charger	778-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	General Comments		
9/4/2020 13:35	Distribution	Paris 12kV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/4/2020 13:35	Distribution	Paris 12KV Quarterly Inspection	FE000300	Fence	819-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	General Comments		
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	ST000177	Structure	778-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	LTCC000893	LTCControl	566-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	LTC Totalizer Reading	4540.80	kw
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.9	psi
9/4/2020 13:49	Distribution	Hopewell Quarterly Inspection	LTCC000893	LTCControl	566-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	Oil Temp Max	46	°C
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/4/2020 13:35	Distribution	Paris 12KV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Readings	Unknown Operations	0	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Readings	Oil Temp Present	42	°C
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/4/2020 13:35	Distribution	Paris 12KV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/4/2020 11:29	Distribution	Detroit Harvester Quarterly Inspection	BAT001305	Battery	743-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/4/2020 13:35	Distribution	Paris 12KV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/4/2020 13:35	Distribution	Paris 12KV Quarterly Inspection	RG000011	Regulator	819-2 A	Regulator Patrol Inspection	Tank Leaks	None	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	R1357	Regulator	411-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/4/2020 9:59	Distribution	East Bernstadt Quarterly Inspection	B0476	WithLTC	778-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	BAT001471	Battery	411-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	S0074	NonLTC	411-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/4/2020 13:35	Distribution	Paris 12KV Quarterly Inspection	BK000292	BreakerVacuum	819-0805	VCB Patrol Inspection	Tank Paint Condition	Good	
9/4/2020 11:32	Distribution	Aisin Quarterly Inspection	K0063	BreakerVacuum	411-4618	VCB Readings	Operations This Read Vac	2	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	260.0	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	300.0	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	240.0	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Amps B Ø	0.0	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	LTC Operations Since Last Insp	1794	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	1	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	9 Month Operations	1	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Operations Counter AL	89	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Operations This Read Vac	0	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	General Comments		
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Amps B Ø	92.0	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Amps A Ø	93.0	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	General Comments		
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Amps A Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Switching Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Unknown Operations	0	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Operations Counter	160	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	8.76	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Operations Counter AF	89	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	LTC Min Tap Position	11L	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	General Comments		
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Max Tap Position	8R	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Unknown Operations	2	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Switching Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Operations This Read Vac	2	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	LTC Max Tap Position	8R	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Operations Counter AL	281	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Regulator As Left Counter	155203	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Operations Counter AF	281	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Maintenance Operations	0	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Patrol Inspection	General Comments		
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	PF000066	PowerFuse	CR-14KV TR 1-A POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Fault Operations C Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Fault Operations B Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	9 Month Operations	5	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Fault Operations A Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.2	psi
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	LTC Current Tap Position	Neutral	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Mechanism Patrol Inspection	General Comments		
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	LTC As Found Counter	3783	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	LTC As Left Counter	3793	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0378	LTCMechanism	478-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000389	PowerFuse	WS-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Amps B Ø	160.0	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Amps C Ø	139.0	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Maintenance Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Amps C Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Amps C Ø	90.0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	PF000066	PowerFuse	Retired Distribution	Disconnect Powerfuse Inspection	Follow-up Action Required?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	PF000334	PowerFuse	SP-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	k	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	PF000066	PowerFuse	CR-14KV TR 1-A POT	Disconnect Powerfuse Inspection	General Comments	These 14KV SEC 1A BUS POTS are no longer on the bus, they were removed, needs to be removed from insp & cascade	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Fault Operations C Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Fault Operations Ground	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Current Tap Position	4R	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	10	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	General Comments		
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	BCH000212	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	BCH000212	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	BCH000212	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	BCH000212	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	BCH000212	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Fault Operations B Ø	0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Bushing Condition	Good	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Amps C Ø	0.0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Amps B Ø	0.0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Amps A Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	9 Month Operations	9	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Unknown Operations	1	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Switching Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Operations This Read Vac	1	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Operations Counter AL	80	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Operations Counter AF	80	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Maintenance Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Fault Operations Ground	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Fault Operations C Ø	0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	General Comments		
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Amps C Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9240	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Fault Operations A Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Fault Operations B Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Fault Operations C Ø	0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Fault Operations C Ø	0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Fault Operations B Ø	3	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Fault Operations A Ø	0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Fault Operations Ground	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Maintenance Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Operations Counter AF	171	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Operations Counter AL	171	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Operations This Read Vac	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Switching Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Unknown Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000417	PowerFuse	WS-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000417	PowerFuse	WS-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	ok	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	9 Month Operations	1	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Fault Adjusted Amps B Phase V	7.86	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Fault Operations Ground	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Fault Operations C Ø	0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Amps B Ø	97.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Amps A Ø	98.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	9 Month Operations	2	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	77	*F
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	ANN000019	Annunciator	CG-Annunciator Panel	Annunciator Patrol Inspection	All Lights Functioning?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	ANN000019	Annunciator	CG-Annunciator Panel	Annunciator Patrol Inspection	Control House Alarm Audible?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	ANN000019	Annunciator	CG-Annunciator Panel	Annunciator Patrol Inspection	ESOC Received Alarm Test?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	ANN000019	Annunciator	CG-Annunciator Panel	Annunciator Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	ANN000019	Annunciator	CG-Annunciator Panel	Annunciator Patrol Inspection	General Comments		
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Trash Emptied?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Amps C Ø	50.0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Amps B Ø	44.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Amps A Ø	46.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	5	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Fault Operations B Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Fault Operations A Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Amps C Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000395	PowerFuse	WS-1428 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000395	PowerFuse	WS-1428 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	General Comments		
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	15.3	VDC
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	16.5	VDC
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BAT001095	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Max Tap Position	8R	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Fault Operations Ground	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Fault Operations C Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Fault Operations B Ø	0	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Regulator As Left Counter	210427	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Fault Operations B Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Fault Operations A Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Fault Adjusted Amps C Phase V	34.02	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Fault Adjusted Amps B Phase V	34.02	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Fault Adjusted Amps A Phase V	34.02	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1245	BreakerVacuum	WS-1336-4	VCB Readings	Amps C Ø	95.0	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	General Comments		
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	General Comments		
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Fault Operations Ground	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Fault Operations C Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Fault Operations B Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Fault Operations A Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Fault Adjusted Amps C Phase V	34.02	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Fault Adjusted Amps B Phase V	34.02	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Fault Adjusted Amps A Phase V	34.02	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Maintenance Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	General Comments		
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	PF000036	PowerFuse	CG-14KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	PF000037	PowerFuse	CG-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	PF000037	PowerFuse	CG-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0117	BreakerVacuum	CG-1436	VCB Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Operations Counter AF	183	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Operations Counter AL	183	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Operations This Read Vac	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Amps C Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Amps B Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Amps A Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	9 Month Operations	1	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Fault Adjusted Amps A Phase V	34.02	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000389	PowerFuse	WS-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000388	PowerFuse	WS-14KV BUS SEC 4 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000388	PowerFuse	WS-14KV BUS SEC 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	9 Month Operations	1	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Unknown Operations	1	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Switching Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Operations This Read Vac	1	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Operations Counter AL	116	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Operations Counter AF	116	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Maintenance Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1246	BreakerVacuum	WS-1337-4	VCB Readings	Follow-up Action Required?	n	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	PF000036	PowerFuse	CG-14KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Amps A Ø	79.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Amps B Ø	77.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Amps C Ø	77.0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	Totalizer Meter Reading	.9264	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	Oil Temp Max	40	°C
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	27.50	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2223.36	kw
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	B0202	NonLTC	817-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Amps A Ø	108.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	9 Month Operations	1	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Amps A Ø	0.0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000402	PowerFuse	WS-1336 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000402	PowerFuse	WS-1336 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Foundation Condition	Good	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000387	PowerFuse	WS-14KV BUS SEC 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000387	PowerFuse	WS-14KV BUS SEC 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000415	PowerFuse	WS-FUTURE SOUTH LINE POTS	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000415	PowerFuse	WS-FUTURE SOUTH LINE POTS	Disconnect Powerfuse Inspection	General Comments	ok	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000416	PowerFuse	WS-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	268	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	268	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000416	PowerFuse	WS-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	9 Month Operations	1	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Amps A Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1204	BreakerVacuum	WS-1473-2	VCB Readings	Amps B Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Fault Adjusted Amps C Phase V	34.02	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Fault Adjusted Amps B Phase V	34.02	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Fault Adjusted Amps A Phase V	34.02	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Fault Operations Ground	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Amps B Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Unknown Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Fault Adjusted Amps B Phase V	34.02	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Fault Adjusted Amps C Phase V	34.02	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	9 Month Operations	1	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Fault Operations A Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Switching Operations	0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1214	BreakerVacuum	WS-1324-2	VCB Readings	Unknown Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000386	PowerFuse	WS-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000386	PowerFuse	WS-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000385	PowerFuse	WS-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000385	PowerFuse	WS-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Fans Operational?	n	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Readings	Follow-up Action Required?	n	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Unknown Operations	1	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	General Comments		
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Readings	General Comments		
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	General Comments	All the ACB's for the fans are off, have been since TR-1A has been in service, in the new configuration	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Switching Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Operations This Read Vac	1	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Operations Counter AL	90	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Operations Counter AF	90	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	Maintenance Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1243	BreakerVacuum	WS-1331-4	VCB Readings	General Comments		
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0164	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Current Tap Position	3R	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LTCC000531	LTCControl	CG-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	FE000627	Fence	CG-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Readings	Oil Temp Present	45	°C
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	9 Months Operations	0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Basement Condition Acceptable	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Broom on Site?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	BAT000162	Battery	536-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Unknown Operations	0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Switching Operations	0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Operations This Read AM	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Amps B Ø	82.0	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	LTC Totalizer Reading	3312.00	kw
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	General Comments	Need to add nitrogen	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	General Comments		
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Amps A Ø	82.0	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Regulator As Left Counter	67414	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Unknown Operations	0	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	General Comments		
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Current Tap Position	Neutral	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LTCC000531	LTCControl	CG-TRANS 1	LTC Control Insp	General Comments	ok	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	9 Month Operations	1	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Amps C Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Amps B Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Amps A Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Maintenance Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Fault Operations Ground	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Fault Operations C Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Fault Operations B Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Fault Operations A Ø	0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Amps A Ø	30.0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Amps B Ø	30.0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Amps C Ø	30.0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	LTC Operations Since Last Insp	1989	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Fault Operations A Ø	0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Fault Operations B Ø	0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Fault Operations C Ø	0	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Amps A Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Amps B Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Switching Operations	0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Amps C Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Operations This Read Vac	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Operations Counter AL	45	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Unknown Operations	1	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000410	PowerFuse	WS-1475 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000410	PowerFuse	WS-1475 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000414	PowerFuse	WS-1471 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000414	PowerFuse	WS-1471 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Switching Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Operations This Read Vac	1	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Operations Counter AF	45	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Maintenance Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Operations Counter AL	145	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Operations Counter AF	145	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Maintenance Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Fault Operations Ground	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Fault Operations C Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Fault Operations B Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Fault Operations A Ø	0	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0663	Regulator	646-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Operations Counter AL	230	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Operations Counter AF	230	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Unknown Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Switching Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Operations This Read Vac	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Operations Counter AL	146	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Amps A Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Amps B Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Amps C Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000405	PowerFuse	WS-1333 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Fault Operations A Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Fault Operations B Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Amps C Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Amps B Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Amps A Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Fault Operations C Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Fault Operations Ground	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Follow-up Action Required?	n	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Broom on Site?	n	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000404	PowerFuse	WS-1334 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	9 Month Operations	0	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	Totalizer Meter Reading	.6900	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Maintenance Operations	0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000412	PowerFuse	WS-1473 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000412	PowerFuse	WS-1473 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Unknown Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Switching Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Operations This Read Vac	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Operations Counter AL	223	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Operations Counter AF	223	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Maintenance Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000411	PowerFuse	WS-1474 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000411	PowerFuse	WS-1474 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000409	PowerFuse	WS-1303 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000413	PowerFuse	WS-1472 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000413	PowerFuse	WS-1472 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Trash Emptied?	n	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LTCC000533	LTCControl	CR-TRANS 2-B	LTC Control Insp	All Connections OK?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LTCC000533	LTCControl	CR-TRANS 2-B	LTC Control Insp	Follow-up Action Required?	n	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LTCC000533	LTCControl	CR-TRANS 2-B	LTC Control Insp	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000409	PowerFuse	WS-1303 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000408	PowerFuse	WS-1304 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Fault Operations Ground	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Fault Operations C Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Fault Operations B Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1215	BreakerVacuum	WS-CAP BK 2	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000408	PowerFuse	WS-1304 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Amps C Ø	80.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	9 Month Operations	1	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000407	PowerFuse	WS-1331 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000407	PowerFuse	WS-1331 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000405	PowerFuse	WS-1333 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Fault Operations Ground	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Fault Operations C Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Fault Operations B Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Fault Operations A Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Amps C Ø	595.0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Fault Operations Ground	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Fault Operations C Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Fault Operations B Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Fault Operations A Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	General Comments		
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Amps B Ø	599.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Amps A Ø	607.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	9 Month Operations	1	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000403	PowerFuse	WS-1335 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000403	PowerFuse	WS-1335 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	PF000070	PowerFuse	Retired Distribution	Disconnect Powerfuse Inspection	General Comments	There are no CRG-1422 Line pots, needs to be removed from insp.	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Switching Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Operations This Read Vac	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Operations Counter AL	151	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Operations Counter AF	151	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Maintenance Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Follow-up Action Required?	n	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Readings	Oil Temp Max	50	°C
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Unknown Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Switching Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Operations This Read Vac	0	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	Oil Temp Present	43	°C
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	CH000241	ControlHouse	536-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Max Tap Position	5R	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Operations Counter AL	188	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Operations Counter AF	188	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	General Comments		
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1231	Regulator	817-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000404	PowerFuse	WS-1334 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000401	PowerFuse	WS-1337 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000401	PowerFuse	WS-1337 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	SWG000001	Switchgear	CG-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	Oil Temp Max	57	°C
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	Maintenance Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1236	BreakerVacuum	WS-14KV TR 4	VCB Patrol Inspection	General Comments		
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Fault Operations B Ø	0	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BCH001054	Charger	665-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BCH001054	Charger	665-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000398	PowerFuse	WS-1425 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000397	PowerFuse	WS-1426 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000397	PowerFuse	WS-1426 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1349	CircuitSwitcher	WS-Vista Switchgear	Circuit Switcher Inspection	Comments		
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	LTCC000068	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	LTCC000068	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	45	Seconds
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1349	CircuitSwitcher	WS-Vista Switchgear	Circuit Switcher Inspection	Ambient Temp	75	°F
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000396	PowerFuse	WS-1427 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000396	PowerFuse	WS-1427 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000393	PowerFuse	WS-FUTURE NORTH LINE POTS	Disconnect Powerfuse Inspection	General Comments	ok	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000393	PowerFuse	WS-FUTURE NORTH LINE POTS	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000392	PowerFuse	WS-14KV TR 4 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000392	PowerFuse	WS-14KV TR 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000391	PowerFuse	WS-14KV TR 3 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000391	PowerFuse	WS-14KV TR 3 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	PF000070	PowerFuse	Retired Distribution	Disconnect Powerfuse Inspection	Follow-up Action Required?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	PF000069	PowerFuse	Retired Distribution	Disconnect Powerfuse Inspection	General Comments	There are no CRG-1421 Line pots, needs to be removed from insp.	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	PF000069	PowerFuse	Retired Distribution	Disconnect Powerfuse Inspection	Follow-up Action Required?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	PF000068	PowerFuse	Retired Distribution	Disconnect Powerfuse Inspection	General Comments	There are no CRG-1420 Line pots, needs to be removed from insp.	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000390	PowerFuse	WS-14KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000390	PowerFuse	WS-14KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1227	BreakerVacuum	WS-1428-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000394	PowerFuse	WS-1429 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	Oil Temp Max	100	°C
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	Oil Temp Present	55	°C
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	General Comments		
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Unknown Operations	0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Switching Operations	0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Operations This Read Vac	0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Operations Counter AL	128	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Operations Counter AF	128	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Maintenance Operations	0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	General Comments		
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Patrol Inspection	General Comments		
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0045	WithLTC	CR-TRANS 1-A	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Follow-up Action Required?	n	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Fault Operations Ground	0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	General Comments		
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000399	PowerFuse	WS-FUTURE 7-8 LINE POTS	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000398	PowerFuse	WS-1425 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BCH001054	Charger	665-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.3	VDC
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BCH001054	Charger	665-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.3	VDC
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BCH001054	Charger	665-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BCH001054	Charger	665-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Fault Operations C ∅	0	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Switching Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Amps A ∅	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Fault Operations A ∅	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Fault Operations B ∅	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Fault Operations C ∅	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Fault Operations Ground	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Amps B ∅	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Operations This Read Vac	1	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Operations Counter AL	190	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Operations Counter AF	190	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Maintenance Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Fault Operations Ground	0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Fault Operations C ∅	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Fault Operations B ∅	0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Maintenance Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	RC000434	RecloserElectronic	817-1674	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Amps C Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Fault Adjusted Amps A Phase V	34.02	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Fault Adjusted Amps B Phase V	34.02	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	PF000333	PowerFuse	SP-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	PF000333	PowerFuse	SP-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	k	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	PF000334	PowerFuse	SP-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Fault Adjusted Amps C Phase V	34.02	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Fault Operations A Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Fault Operations Ground	0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1700	psi
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000394	PowerFuse	WS-1429 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000406	PowerFuse	WS-1332 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000406	PowerFuse	WS-1332 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Vegetation	None	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Fault Operations A Ø	0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Amps C Ø	0.0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Amps B Ø	0.0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Amps A Ø	0.0	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	FE000126	Fence	008-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0120	BreakerVacuum	CG-1439	VCB Readings	9 Month Operations	0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0662	Regulator	646-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	9 Month Operations	1	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1180	BreakerVacuum	WS-1308-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1209	BreakerVacuum	WS-1305-2	VCB Readings	Unknown Operations	1	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	General Comments	gap under fence in back right corner. Barb wire and some of the posts and rails have some rust.	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	FE000038	Fence	478-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Unknown Operations	0	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Ambient Temp	73	°F
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Readings	Oil Temp Present	35	°C
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Readings	Oil Temp Max	35	°C
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	General Comments	There is no power on the annun. couldn't get alarms to light up	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	LTC Min Tap Position	15L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Readings	General Comments		
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	LTC Max Tap Position	4R	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	LTC Operations Since Last Insp	978	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	LTC Min Tap Position	5L	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	LTC Max Tap Position	7R	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	LTC Current Tap Position	3R	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	LTC As Left Counter	8579	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	LTC As Found Counter	8566	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Mechanism Patrol Inspection	General Comments	ok	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	General Comments	ok	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	C0504	LTCMechanism	665-1	LTC Counter Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1181	BreakerVacuum	WS-1310-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1349	CircuitSwitcher	WS-Vista Switchgear	Circuit Switcher Inspection	SF6 Indicator Zone	OK	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1349	CircuitSwitcher	WS-Vista Switchgear	Circuit Switcher Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1349	CircuitSwitcher	WS-Vista Switchgear	Circuit Switcher Inspection	Equipment Properly Labeled?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	YD000634	Yard	CR-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Unknown Operations	0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Tank Paint Condition	Good	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Fault Operations Ground	0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	General Comments		
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	CH000146	ControlHouse	CR-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Patrol Inspection	General Comments		
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Fault Operations C ∅	0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Fault Operations B ∅	0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Fault Operations A ∅	0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Amps C ∅	450.0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Amps B ∅	500.0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Amps A ∅	400.0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0027	WithLTC	CG-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0893	BreakerAirMagnetic	SP-12KV TR 2	AMCB Readings	9 Months Operations	0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Readings	Percent Thermal Load B ∅ Max	-60	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Operations Counter AF	129	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Follow-up Action Required?	n	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Patrol Inspection	General Comments		
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Unknown Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Switching Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Operations This Read Vac	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Operations Counter AL	180	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1207	BreakerVacuum	WS-1303-2	VCB Readings	Operations Counter AF	180	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	ST000615	Structure	CG-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Maintenance Operations	0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Operations Counter AF	240	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Operations Counter AL	240	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Operations This Read AM	0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0891	BreakerAirMagnetic	SP-1117	AMCB Readings	Switching Operations	0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Operations Counter AL	714	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Operations Counter AF	714	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Maintenance Operations	0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Grounds in Place?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	General Comments		
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	9 Month Operations	2	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Amps A Ø	94.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Amps B Ø	93.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Amps C Ø	91.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Operations Counter AF	146	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Maintenance Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Fault Operations Ground	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Fault Operations C Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Fault Operations B Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Unknown Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1182	BreakerVacuum	WS-1315-1	VCB Readings	9 Month Operations	1	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1185	BreakerVacuum	WS-1324-1	VCB Readings	Fault Operations A Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Fault Adjusted Amps A Phase V	68.05	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Fault Adjusted Amps B Phase V	68.05	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1228	BreakerVacuum	WS-1333-4	VCB Readings	Fault Adjusted Amps C Phase V	68.05	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	General Comments	ok	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	-1.0	psi
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	S0021	NonLTC	410-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	8870.40	kw
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Switching Operations	0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	LTC Current Tap Position	4L	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	B0289	WithLTC	536-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LT0037	WithLTC	CR-TRANS 2-B	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	LTC As Left Counter	344108	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	LTC As Found Counter	344098	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Mechanism Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000400	PowerFuse	WS-FUTURE 5-6 LINE POTS	Disconnect Powerfuse Inspection	General Comments	ok	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Operations Counter AL	129	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Operations This Read Vac	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1200	BreakerVacuum	WS-1427-3	VCB Readings	Switching Operations	0	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Readings	General Comments		
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	General Comments		
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	General Comments		
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	FE000576	Fence	SP-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	LTCC000068	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	LTCC000068	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	LTCC000068	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000400	PowerFuse	WS-FUTURE 5-6 LINE POTS	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	PF000399	PowerFuse	WS-FUTURE 7-8 LINE POTS	Disconnect Powerfuse Inspection	General Comments	ok	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	LTCC000068	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	LTCC000068	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	LTCC000068	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	General Comments		
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	B0289	LTCMechanism	536-1	LTC Counter Readings	Follow-up Action Required?	n	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0176	NonLTC	646-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	KB0035	BreakerVacuum	SP-3302	VCB Readings	Operations This Read Vac	3	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	General Comments		
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	General Comments	BFTC	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Maintenance Operations	3	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Operations Counter AF	293	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Operations Counter AL	293	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Operations This Read Vac	3	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Switching Operations	0	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Unknown Operations	0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Trash Emptied?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	General Comments		
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	n	If Bkr is Closed
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Broom on Site?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	CH000127	ControlHouse	CG-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Unknown Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Switching Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Operations This Read Vac	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Operations Counter AL	144	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Operations Counter AF	144	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Maintenance Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Fault Operations Ground	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Fault Operations C ∅	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Fault Operations B ∅	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Fault Operations A ∅	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Amps C Ø	104.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Amps B Ø	104.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1173	BreakerVacuum	WS-1473-1	VCB Readings	Amps A Ø	105.0	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Amps A Ø	0.0	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Amps B Ø	0.0	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Amps C Ø	0.0	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0162	BreakerVacuum	951-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Amps A Ø	55.0	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	9 Month Operations	4	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Amps A Ø	239.0	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Amps B Ø	209.0	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Amps C Ø	217.0	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Bushing Condition	Good	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0889	BreakerAirMagnetic	SP-1115	AMCB Readings	9 Months Operations	1	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Fault Operations A Ø	0	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Fault Operations B Ø	0	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Fault Operations C Ø	0	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Follow-up Action Required?	n	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Foundation Condition	Good	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	General Comments	1 trip check	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	General Comments	ok	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Grounds in Place?	y	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Maintenance Operations	1	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Operations Counter AF	185	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Operations Counter AL	186	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Operations This Read Vac	1	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Switching Operations	0	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Patrol Inspection	Tank Paint Condition	Good	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BK000829	BreakerVacuum	665-1626	VCB Readings	Unknown Operations	0	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	General Comments	ok	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Max Tap Position	1R	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Min Tap Position	11L	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Regulator As Left Counter	32619	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1212	BreakerVacuum	WS-1315-2	VCB Readings	9 Month Operations	1	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	General Comments	ok	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Min Tap Position	10L	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Regulator As Left Counter	33158	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	R1320	Regulator	410-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	R1321	Regulator	410-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	Follow-up Action Required?	n	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	General Comments		
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	General Comments		
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	LTC Totalizer Reading	5624.64	kw
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	Oil Temp Max	64	°C
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	Oil Temp Present	49	°C
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	Totalizer Meter Reading	.7812	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Fault Operations Ground	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Maintenance Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Operations Counter AF	50	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Operations Counter AL	50	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Operations This Read Vac	1	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Switching Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Unknown Operations	1	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	BCH001143	Charger	410-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	54.0	VDC
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	BCH001143	Charger	410-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	54.0	VDC
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	BCH001143	Charger	410-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	BCH001143	Charger	410-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	BCH001143	Charger	410-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Unknown Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Switching Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Operations This Read Vac	0	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	82	°F
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	26.3	VDC
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	25.7	VDC
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	BAT001203	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Operations Counter AL	150	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Operations Counter AF	150	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Fault Operations A Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Amps C Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Amps B Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Amps A Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	9 Month Operations	0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	9 Months Operations	0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Amps A Ø	30.0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Amps B Ø	35.0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Amps C Ø	30.0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Fault Operations A Ø	0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Fault Operations B Ø	0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Fault Operations C Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Operations Counter AF	140	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Operations Counter AL	140	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Operations This Read Vac	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Switching Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Unknown Operations	0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Fault Operations Ground	0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Follow-up Action Required?	n	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Patrol Inspection	General Comments		
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	General Comments		
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Maintenance Operations	0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Operations Counter AF	102	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Operations Counter AL	102	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Operations This Read AM	0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Switching Operations	0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0888	BreakerAirMagnetic	SP-1114	AMCB Readings	Unknown Operations	0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	BCH001089	Charger	SP-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	BCH001089	Charger	SP-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	BCH001089	Charger	SP-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	BCH001089	Charger	SP-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	3.8	amps
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	BCH001089	Charger	SP-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	BCH001089	Charger	SP-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	BCH001089	Charger	SP-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.900	millivolts
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Fault Operations A Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Fault Operations B Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Fault Operations C Ø	0	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0378	WithLTC	478-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Amps C Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Amps B Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Amps A Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1242	BreakerVacuum	WS-GND TR 2	VCB Readings	9 Month Operations	1	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Unknown Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Switching Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Operations This Read Vac	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Operations Counter AL	53	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Operations Counter AF	53	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Maintenance Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Fault Operations Ground	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Fault Operations C Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Fault Operations B Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Fault Operations A Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Amps C Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Amps B Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Amps A Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1195	BreakerVacuum	WS-1336-3	VCB Readings	9 Month Operations	1	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Unknown Operations	0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Tank Paint Condition	Good	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Switching Operations	0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Operations This Read Vac	0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Operations Counter AL	134	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Operations Counter AF	134	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Maintenance Operations	0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Grounds in Place?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	General Comments		
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	General Comments		
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Foundation Condition	Good	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Readings	Follow-up Action Required?	n	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1276	BreakerVacuum	CR-1420-A	VCB Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	General Comments		
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1200	psi
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	Oil Temp Max	64	°C
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	Oil Temp Present	42	°C
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	64	°C
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	42	°C
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	71	°C
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	General Comments		
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	LTC As Found Counter	226093	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	LTC As Left Counter	226093	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	LTC Current Tap Position	6L	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	LTC Max Tap Position	Neutral	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	LTC Min Tap Position	11L	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	44	°C
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	69	°C
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	44	°C
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	9 Month Operations	1	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Amps A Ø	41.0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1154	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0174	LTCMechanism	SP-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Amps B Ø	37.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Amps C Ø	33.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1235	BreakerVacuum	WS-SEC TIE 2-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Operations Counter AF	107	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Maintenance Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Fault Operations Ground	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Amps C Ø	181.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Amps B Ø	184.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Amps A Ø	180.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Fault Operations C Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Fault Operations B Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Fault Operations A Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Amps C Ø	104.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Amps B Ø	105.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Amps A Ø	109.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	9 Month Operations	1	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	9 Month Operations	1	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Unknown Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Switching Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Operations This Read Vac	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Operations Counter AL	175	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Operations Counter AF	175	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Maintenance Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Fault Operations Ground	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Fault Operations C Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Fault Operations B Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Fault Operations A Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Amps C Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Amps B Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Amps A Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1206	BreakerVacuum	WS-1475-2	VCB Readings	9 Month Operations	1	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0174	WithLTC	SP-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Maintenance Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Operations Counter AF	88	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Operations Counter AL	88	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Operations This Read Vac	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Switching Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1178	BreakerVacuum	WS-1305-1	VCB Readings	Unknown Operations	0	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Current Tap Position	3R	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Unknown Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Switching Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Operations This Read Vac	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Operations Counter AL	71	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Operations Counter AF	71	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Maintenance Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	General Comments		
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	General Comments		
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Max Tap Position	8R	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Regulator As Left Counter	45476	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	R0661	Regulator	646-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Amps A Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Amps B Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Amps C Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Fault Operations A Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Fault Operations B Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Fault Operations C Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Fault Operations Ground	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Follow-up Action Required?	n	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	9 Month Operations	0	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Switching Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Unknown Operations	0	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	General Comments		
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	FE000161	Fence	817-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Ambient Temp	85	*F
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	9 Month Operations	1	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Amps A Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Amps B Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Amps C Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Fault Operations A Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Fault Operations B Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Fault Operations C Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Fault Operations Ground	0	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	General Comments		
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Vegetation	None	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	YD000158	Yard	817-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1193	BreakerVacuum	WS-1334-3	VCB Readings	9 Month Operations	1	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Unknown Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Switching Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Operations This Read Vac	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Operations Counter AL	150	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Operations Counter AF	150	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Maintenance Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Fault Operations Ground	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Fault Operations C Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Fault Operations B Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Fault Operations A Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Amps C Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Amps B Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Amps A Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1194	BreakerVacuum	WS-1335-3	VCB Readings	9 Month Operations	1	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	General Comments		
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	ST000161	Structure	646-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	9 Month Operations	1	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Amps A Ø	102.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Amps B Ø	102.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Amps C Ø	99.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Fault Operations A Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Fault Operations B Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Fault Operations C Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Readings	Fault Operations Ground	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1238	BreakerVacuum	WS-1425-3	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Patrol Inspection	General Comments		
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	General Comments		
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	CH000039	ControlHouse	008-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Fault Operations Ground	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Fault Operations C Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Fault Operations B Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Fault Operations A Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Amps C Ø	553.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Amps B Ø	556.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Amps A Ø	562.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	9 Month Operations	1	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Unknown Operations	0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Patrol Inspection	General Comments		
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0122	BreakerVacuum	CG-14KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Switching Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Operations This Read Vac	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Operations Counter AL	178	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Operations Counter AF	178	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Maintenance Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Fault Operations Ground	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Fault Operations C Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Fault Operations B Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Fault Operations A Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1211	BreakerVacuum	WS-1310-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Unknown Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Switching Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Operations This Read Vac	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1201	BreakerVacuum	WS-1428-3	VCB Readings	Operations Counter AL	107	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Follow-up Action Required?	n	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	9 Month Operations	1	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Amps A Ø	120.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Amps B Ø	116.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Amps C Ø	119.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Fault Adjusted Amps A Phase V	34.02	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Fault Adjusted Amps B Phase V	34.02	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Fault Adjusted Amps C Phase V	34.02	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Fault Operations A Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Fault Operations B Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Fault Operations C Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Fault Operations Ground	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Maintenance Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Operations Counter AF	190	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Operations Counter AL	190	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Operations This Read Vac	1	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Switching Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1172	BreakerVacuum	WS-1472-1	VCB Readings	Unknown Operations	1	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Maintenance Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Operations Counter AF	170	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Operations Counter AL	170	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Operations This Read Vac	0	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	ST000164	Structure	817-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Switching Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1186	BreakerVacuum	WS-1330-1	VCB Readings	Unknown Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Unknown Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Switching Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Operations This Read Vac	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Operations Counter AL	182	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Operations Counter AF	182	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1233	BreakerVacuum	WS-14KV TR 3	VCB Readings	Maintenance Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Amps C Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Fault Adjusted Amps A Phase V	34.02	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Fault Adjusted Amps B Phase V	34.02	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Fault Adjusted Amps C Phase V	34.02	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Fault Operations A Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Fault Operations B Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Fault Operations C Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Fault Operations Ground	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Unknown Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Switching Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Operations This Read Vac	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Operations Counter AL	99	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Operations Counter AF	99	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Maintenance Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Fault Operations Ground	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Fault Operations C Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Fault Operations B Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Fault Operations A Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Amps C Ø	576.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Amps B Ø	582.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Amps A Ø	587.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1251	BreakerVacuum	WS-14KV TR 2	VCB Readings	9 Month Operations	1	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Maintenance Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Operations Counter AF	181	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Operations Counter AL	181	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	SWG000100	Switchgear	SP-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	General Comments		
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Vegetation	None	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Unknown Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Switching Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Operations This Read Vac	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Operations Counter AL	107	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Operations Counter AF	107	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Maintenance Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Patrol Inspection	General Comments	Alert Cap close fail, and MB com fail	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Fault Operations Ground	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Fault Operations C Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Fault Operations B Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Fault Operations A Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Amps C Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Amps B Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Amps A Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1189	BreakerVacuum	WS-CAP BK 3	VCB Readings	9 Month Operations	0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	General Comments		
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	YD000582	Yard	SP-Yard	Yard Patrol Inspection	Ambient Temp	75	*F
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	9 Month Operations	2	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Amps A Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Amps B Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Fault Operations C Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Fault Operations B Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Fault Operations A Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Maintenance Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Fault Operations Ground	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Fault Operations C Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Fault Operations B Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Fault Operations A Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Amps C Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Amps B Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Amps A Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Amps C Ø	72.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Amps B Ø	58.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Amps A Ø	49.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	9 Month Operations	1	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	9 Month Operations	1	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Unknown Operations	0	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Tank Paint Condition	Good	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Switching Operations	0	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Operations This Read Vac	0	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Operations Counter AL	521	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Operations Counter AF	521	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	General Comments		
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	General Comments		
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	548.64	kw
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	50.00	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	Oil Temp Present	45	°C
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	LTCC000750	LTCControl	665-1	LTC Control Insp	All Connections OK?	y	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	LTCC000750	LTCControl	665-1	LTC Control Insp	Follow-up Action Required?	n	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	LTCC000750	LTCControl	665-1	LTC Control Insp	General Comments	ok	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	LTCC000750	LTCControl	665-1	LTC Control Insp	LTC Operation Checked?	y	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	LTCC000750	LTCControl	665-1	LTC Control Insp	LTC Output Voltage Level	124.1	VAC
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	LTCC000750	LTCControl	665-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	LTCC000750	LTCControl	665-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	LTCC000750	LTCControl	665-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Operations This Read Vac	1	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Switching Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1170	BreakerVacuum	WS-1330-2	VCB Readings	Unknown Operations	1	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	9 Month Operations	22	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Bushing Condition	Good	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Fault Operations A Ø	0	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Fault Operations B Ø	0	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Fault Operations C Ø	0	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Fault Operations Ground	0	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Follow-up Action Required?	n	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Foundation Condition	Good	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	General Comments		
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	General Comments		
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Maintenance Operations	0	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Operations Counter AF	135	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Operations Counter AL	135	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Operations This Read Vac	5	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Switching Operations	5	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Patrol Inspection	Tank Paint Condition	Good	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	KB0071	BreakerVacuum	008-3424	VCB Readings	Unknown Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Unknown Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Switching Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Operations This Read Vac	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Operations Counter AL	70	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1188	BreakerVacuum	WS-GND TR 3	VCB Readings	Operations Counter AF	70	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Unknown Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Switching Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Operations This Read Vac	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Operations Counter AL	147	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Operations Counter AF	147	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Maintenance Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1231	BreakerVacuum	WS-SEC TIE 1-3	VCB Readings	Fault Operations Ground	0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Oil Temp Max	45	°C
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Fault Operations A Ø	0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Fault Operations B Ø	0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Fault Operations C Ø	0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Fault Operations Ground	0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Follow-up Action Required?	n	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Patrol Inspection	General Comments		
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	General Comments		
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Maintenance Operations	0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Operations Counter AF	149	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Operations Counter AL	149	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Operations This Read Vac	0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Switching Operations	0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Unknown Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	9 Month Operations	1	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Amps A Ø	118.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Amps B Ø	115.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Amps C Ø	115.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Fault Operations A Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Fault Operations B Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Fault Operations C Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Fault Operations Ground	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Maintenance Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Operations Counter AF	82	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Operations Counter AL	82	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Operations This Read Vac	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Switching Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1174	BreakerVacuum	WS-1474-1	VCB Readings	Unknown Operations	0	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	9 Month Operations	2	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Amps A Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Amps B Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Amps C Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Fault Adjusted Amps A Phase V	34.02	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Fault Adjusted Amps B Phase V	34.02	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Fault Adjusted Amps C Phase V	34.02	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Fault Operations A Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Fault Operations B Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Fault Operations C Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Fault Operations Ground	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Maintenance Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Operations Counter AF	63	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Operations Counter AL	63	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Operations This Read Vac	1	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Switching Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1229	BreakerVacuum	WS-1429-4	VCB Readings	Unknown Operations	1	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	9 Month Operations	0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	General Comments		
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Readings	General Comments	cant read guage	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Readings	Oil Temp Present	0	°C
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0178	NonLTC	646-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Amps A Ø	0.0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Amps B Ø	0.0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Amps C Ø	0.0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0123	BreakerVacuum	CG-14KV GND TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Winding Temp Max	45	°C
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	20.0	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	120.0	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	100.0	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	14	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	LTC Totalizer Reading	8484.48	kw
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.7	psi
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	Oil Temp Max	49	°C
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	Oil Temp Present	49	°C
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	Totalizer Meter Reading	.8838	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	100.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Unknown Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Switching Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Operations This Read Vac	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Operations Counter AL	126	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Operations Counter AF	126	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Maintenance Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Fault Operations Ground	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Fault Operations C Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Fault Operations B Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Fault Operations A Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Amps C Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Amps B Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Amps A Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1203	BreakerVacuum	WS-1472-2	VCB Readings	9 Month Operations	1	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	ST000582	Structure	SP-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Readings	General Comments		
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0479	WithLTC	478-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0026	GroundTransformer	CG-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Unknown Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Switching Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Operations This Read Vac	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Operations Counter AL	120	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Operations Counter AF	120	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Maintenance Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Fault Operations Ground	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Fault Operations C Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Fault Operations B Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Fault Operations A Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Amps C Ø	116.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Amps B Ø	117.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Amps A Ø	118.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1237	BreakerVacuum	WS-1471-1	VCB Readings	9 Month Operations	1	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	5	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	5	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	286	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	286	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	General Comments	BFTC	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	MB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Current Tap Position	2R	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Gate Locks Functioning?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	General Comments	ok	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	FE000264	Fence	410-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Ambient Temp	83	°F
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	General Comments	ok	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Vegetation	None	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	YD000266	Yard	410-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	General Comments	ok	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	ST000273	Structure	410-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	BCH001099	Charger	008-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	BCH001099	Charger	008-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	BCH001099	Charger	008-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	General Comments	ok	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Ambient Temp	81	*F
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	General Comments	NO SPR	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Vegetation	None	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	YD000262	Yard	665-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	General Comments	ok	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	ST000270	Structure	665-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Regulator As Left Counter	46601	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.8	volts
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Max Tap Position	6R	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	General Comments		
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1229	Regulator	817-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Switching Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Unknown Operations	0	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Unknown Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Switching Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Operations This Read Vac	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Operations Counter AL	71	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Operations Counter AF	71	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Maintenance Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	General Comments		
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	LTC As Found Counter	102578	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	LTC As Left Counter	102578	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	LTC Current Tap Position	1L	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	LTC Max Tap Position	1R	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	LTC Min Tap Position	7L	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	311	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LT0027	LTCMechanism	CG-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	9 Month Operations	2	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Amps A Ø	96.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Amps B Ø	95.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Amps C Ø	95.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Amps A Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Amps B Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Amps C Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Fault Adjusted Amps A Phase V	34.02	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Fault Adjusted Amps B Phase V	34.02	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	Fault Adjusted Amps C Phase V	34.02	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Fault Operations A Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Fault Operations B Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Fault Operations C Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Fault Operations Ground	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1241	BreakerVacuum	WS-1319-2	VCB Readings	Maintenance Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Fault Operations Ground	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Fault Operations C Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1247	BreakerVacuum	WS-FUTURE-6	VCB Readings	Fault Operations B Ø	0	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	BCH001099	Charger	008-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	BCH001099	Charger	008-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	136.4	VDC
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	9 Month Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Amps A Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Amps B Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Amps C Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Fault Operations A Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Fault Operations B Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Fault Operations C Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Fault Operations Ground	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	General Comments		
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Tank Leaks	None	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Operations Counter	130	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	General Comments		
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Amps C Ø	98.0	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Amps B Ø	102.0	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	KX0066	RecloserElectronic	817-1673	Recloser Electronic Patrol Inspection	Amps A Ø	130.0	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	BCH001099	Charger	008-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	136.4	VDC
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	BCH001099	Charger	008-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.600	millivolts
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	66.2	VDC
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	69.0	VDC
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	90	*F
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	BAT001138	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Patrol Inspection	General Comments	Alert Cap close fail, and MB com fail	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Maintenance Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Operations Counter AF	205	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Operations Counter AL	205	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1249	BreakerVacuum	WS-1426-4	VCB Readings	9 Month Operations	1	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1187	BreakerVacuum	WS-CAP BK 1	VCB Readings	Operations This Read Vac	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Unknown Operations	0	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Regulator As Left Counter	48723	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Unknown Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Switching Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Operations This Read Vac	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Operations Counter AL	149	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Operations Counter AF	149	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Maintenance Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Fault Operations Ground	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Fault Operations C Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Fault Operations B Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Fault Operations A Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Amps C Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Amps B Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Amps A Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1197	BreakerVacuum	WS-FUTURE-5	VCB Readings	9 Month Operations	0	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Min Tap Position	7L	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	General Comments		
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Current Tap Position	1R	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/3/2020 14:08	Distribution	Drakesboro Quarterly Inspection	R1233	Regulator	817-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	9 Month Operations	2	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Amps A Ø	25.0	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Amps B Ø	25.0	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Readings	Amps C Ø	27.0	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Bushing Condition	Good	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	BK000782	BreakerVacuum	665-1625	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LTCC000567	LTCControl	SP-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LTCC000567	LTCControl	SP-TRANS 2	LTC Control Insp	General Comments	k	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	W0177	NonLTC	646-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.4572	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Maintenance Operations	0	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Grounds in Place?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	General Comments		
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	General Comments		
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Foundation Condition	Good	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Follow-up Action Required?	n	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Fault Operations Ground	0	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Fault Operations C Ø	0	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Fault Operations B Ø	0	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Fault Operations A Ø	0	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Amps C Ø	133.0	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Amps B Ø	146.0	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Amps A Ø	163.0	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	MB0171	BreakerVacuum	478-0226	VCB Readings	9 Month Operations	47	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	9 Month Operations	1	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Amps A Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Amps B Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Amps C Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Fault Operations A Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Fault Operations B Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Fault Operations C Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Fault Operations Ground	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Maintenance Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Operations Counter AF	67	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Operations Counter AL	67	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Operations This Read Vac	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1184	BreakerVacuum	WS-1322-1	VCB Readings	Switching Operations	0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Fault Operations A Ø	0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Fault Operations B Ø	0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Fault Operations C Ø	0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Fault Operations Ground	0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Follow-up Action Required?	n	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Foundation Condition	Good	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	General Comments		
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	General Comments		
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Grounds in Place?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Maintenance Operations	0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Operations Counter AF	106	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Operations Counter AL	106	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Operations This Read Vac	0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Switching Operations	0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Tank Paint Condition	Good	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Readings	Unknown Operations	0	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	FE000260	Fence	665-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Unknown Operations	2	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Switching Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Operations This Read Vac	2	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Operations Counter AL	239	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Operations Counter AF	239	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Maintenance Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Fault Operations Ground	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1213	BreakerVacuum	WS-1322-2	VCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1280	BreakerVacuum	CR-1422-A	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	General Comments		
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Readings	General Comments		
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	225.00	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	220.00	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Readings	Oil Temp Max	64	°C
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Readings	Oil Temp Present	42	°C
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Fault Operations A Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Fault Operations B Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Fault Operations C Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Fault Operations Ground	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Patrol Inspection	General Comments	Alert Counter diff	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Maintenance Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Operations Counter AF	207	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Operations Counter AL	207	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Operations This Read Vac	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Switching Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Unknown Operations	0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LTCC000883	LTCControl	CR-TRANS 1-A	LTC Control Insp	All Connections OK?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LTCC000883	LTCControl	CR-TRANS 1-A	LTC Control Insp	Follow-up Action Required?	n	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LTCC000883	LTCControl	CR-TRANS 1-A	LTC Control Insp	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Operations Counter AL	90	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Operations This Read Vac	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Switching Operations	0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Operations Counter AF	57	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Maintenance Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Fault Operations Ground	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Fault Operations C Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Fault Operations B Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Fault Operations A Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Amps C Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Amps B Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Amps A Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Fault Operations C Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Amps A Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Amps B Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Fault Operations Ground	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Maintenance Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Operations Counter AF	175	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Operations Counter AL	175	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Operations This Read Vac	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Switching Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Unknown Operations	0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Amps C Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Fault Operations A Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Fault Operations B Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Fault Operations C Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	9 Month Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Amps A Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Amps B Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Fault Operations Ground	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Maintenance Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Operations Counter AF	90	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Amps C Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1216	BreakerVacuum	WS-CAP BK 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LT0175	NonLTC	SP-TRANS 3	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Amps C Ø	0.0	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1176	BreakerVacuum	WS-1303-1	VCB Readings	Unknown Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Unknown Operations	1	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Switching Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Operations This Read Vac	1	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Operations Counter AL	51	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Operations Counter AF	51	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Amps A Ø	138.0	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Amps B Ø	102.0	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Amps C Ø	108.0	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Bushing Condition	Good	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	9 Month Operations	1	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Fault Adjusted Amps B Phase V	5.20	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Fault Adjusted Amps C Phase V	5.20	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Fault Operations A Ø	0	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Fault Operations B Ø	1	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Fault Operations C Ø	1	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Fault Operations Ground	0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Amps B Ø	0.0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Amps A Ø	0.0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	9 Months Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	9 Month Operations	1	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Amps A Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Amps B Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	9 Month Operations	0	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Follow-up Action Required?	n	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Foundation Condition	Good	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	General Comments	1 trip check, 1 unknown, B&C 51T	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	General Comments	ok	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Grounds in Place?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	9 Month Operations	1	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Unknown Operations	0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Tank Paint Condition	Good	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Switching Operations	0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Operations This Read Vac	0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Operations Counter AL	108	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Operations Counter AF	187	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Maintenance Operations	0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Grounds in Place?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	General Comments		
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Foundation Condition	Good	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Follow-up Action Required?	n	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Fault Operations Ground	0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Fault Operations C Ø	0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Fault Operations B Ø	0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Fault Operations A Ø	0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Fault Adjusted Amps C Phase V	0.00	%
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Fault Adjusted Amps B Phase V	0.00	%
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Fault Adjusted Amps A Phase V	0.00	%
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Patrol Inspection	Bushing Condition	Good	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Amps C Ø	258.0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Amps B Ø	317.0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Amps A Ø	289.0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000914	BreakerVacuum	CR-14KV TRANS 1-A	VCB Readings	9 Month Operations	1	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Unknown Operations	0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Switching Operations	0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Operations This Read AM	0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AL	81	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Operations Counter AF	81	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Maintenance Operations	0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	General Comments		
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Patrol Inspection	General Comments		
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Follow-up Action Required?	n	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations Ground	0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations C Ø	0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations B Ø	0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0892	BreakerAirMagnetic	SP-12KV BUS TIE SEC 2	AMCB Readings	Fault Operations A Ø	0	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Tank Paint Condition	Good	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Unknown Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	9 Month Operations	1	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1192	BreakerVacuum	WS-1333-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Fault Operations Ground	0	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Follow-up Action Required?	n	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Foundation Condition	Good	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	General Comments		
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Grounds in Place?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Fault Operations Ground	1	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Follow-up Action Required?	n	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Foundation Condition	Good	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	General Comments		
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	General Comments		
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Grounds in Place?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Maintenance Operations	0	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Maintenance Operations	0	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Operations Counter AF	178	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Operations Counter AL	178	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Operations This Read Vac	1	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Switching Operations	1	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Patrol Inspection	Tank Paint Condition	Good	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Unknown Operations	0	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Operations Counter AF	211	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Operations Counter AL	211	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Operations This Read Vac	2	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Switching Operations	0	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	9 Month Operations	1	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Amps A Ø	123.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Amps B Ø	120.0	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	General Comments		
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	FE000831	Fence	536-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Fault Operations C Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Fault Operations B Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Fault Operations A Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Fault Adjusted Amps C Phase V	34.02	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Fault Adjusted Amps B Phase V	34.02	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Fault Adjusted Amps A Phase V	34.02	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Amps C Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Amps B Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Amps A Ø	0.0	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	9 Month Operations	4	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1240	BreakerVacuum	WS-1308-2	VCB Readings	9 Month Operations	1	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Unknown Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Switching Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Operations This Read Vac	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1226	BreakerVacuum	WS-1427-4	VCB Readings	Operations Counter AL	57	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Amps C Ø	123.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1210	BreakerVacuum	WS-1306-2	VCB Readings	Fault Operations A Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1208	BreakerVacuum	WS-1304-2	VCB Readings	Operations Counter AF	176	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Amps B Ø	0.0	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Fault Operations A Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Fault Adjusted Amps C Phase V	34.02	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Fault Adjusted Amps B Phase V	34.02	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Fault Adjusted Amps A Phase V	34.02	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Amps C Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Amps B Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Amps A Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	9 Month Operations	2	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Patrol Inspection	General Comments		
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0116	BreakerVacuum	CG-1435	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Patrol Inspection	General Comments		
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0118	BreakerVacuum	CG-1437	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	General Comments	ok	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	General Comments	ok	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	LTC Totalizer Reading	6128.64	kw
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	Oil Temp Max	60	°C
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	Oil Temp Present	45	°C
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Switching Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Operations This Read Vac	1	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Operations Counter AL	98	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Operations Counter AF	98	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Maintenance Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Fault Operations Ground	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Fault Operations C Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Fault Operations B Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Fault Operations A Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Fault Adjusted Amps C Phase V	34.02	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Fault Adjusted Amps B Phase V	34.02	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	9 Month Operations	1	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Trash Emptied?	n	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	n	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Station Ground Set On Site?	n	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Panels Dusted?	n	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Panel Lights OK?	n	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	General Comments		
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Floor Swept?	n	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	CH000489	ControlHouse	478-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	9 Month Operations	2	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1196	BreakerVacuum	WS-1337-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Unknown Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Switching Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Operations This Read Vac	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Operations Counter AL	61	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Operations Counter AF	61	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Maintenance Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	Totalizer Meter Reading	.6384	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
9/3/2020 12:17	Distribution	Powderly Quarterly Inspection	C0504	WithLTC	665-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Amps C Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Fault Operations A Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Fault Operations B Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Fault Operations C Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Fault Operations Ground	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Tank Paint Condition	Good	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Unknown Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	9 Month Operations	1	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Maintenance Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Operations Counter AF	144	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Operations Counter AL	144	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Operations This Read Vac	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Switching Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1250	BreakerVacuum	WS-SEC TIE 1-2	VCB Readings	Unknown Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Amps A Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Amps B Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1232	BreakerVacuum	WS-SEC TIE 3-4	VCB Readings	Amps C Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Fault Operations Ground	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Fault Operations C Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Fault Operations B Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Fault Operations A Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	9 Month Operations	1	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1191	BreakerVacuum	WS-1332-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Fault Adjusted Amps C Phase V	5.20	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Fault Adjusted Amps B Phase V	5.20	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Fault Adjusted Amps A Phase V	5.20	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Bushing Condition	Good	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Amps C Ø	228.0	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Amps B Ø	252.0	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Amps A Ø	240.0	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Amps C Ø	0.0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Amps B Ø	0.0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Amps A Ø	0.0	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Maintenance Operations	1	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Moisture and Leak Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Operations Counter AF	185	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Operations Counter AL	185	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Operations This Read Vac	3	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Readings	Switching Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	9 Month Operations	207	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	LTC Operations Since Last Insp	3121	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	LTC Min Tap Position	12L	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	LTC Max Tap Position	11R	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	LTC As Left Counter	29232	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	LTC As Found Counter	29222	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Unknown Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Switching Operations	0	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Mechanism Patrol Inspection	General Comments		
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	General Comments		
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	B0479	LTCMechanism	478-1	LTC Counter Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Operations This Read Vac	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Operations Counter AL	72	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Operations Counter AF	72	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Maintenance Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Fault Operations Ground	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Fault Operations C ∅	0	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0034	BreakerVacuum	410-1327	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1225	BreakerVacuum	WS-1425-4	VCB Readings	Amps C ∅	0.0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Unknown Operations	0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Tank Paint Condition	Good	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Switching Operations	0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Operations This Read Vac	0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Operations Counter AL	208	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Operations Counter AF	208	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Maintenance Operations	0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Amps A ∅	0.0	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Unknown Operations	0	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Tank Paint Condition	Good	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Switching Operations	0	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Operations This Read Vac	2	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Operations Counter AL	302	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Operations Counter AF	302	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Maintenance Operations	1	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Grounds in Place?	y	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	General Comments	ok	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	General Comments	ok	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Grounds in Place?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	General Comments		
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	General Comments		
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Foundation Condition	Good	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Follow-up Action Required?	n	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Fault Operations Ground	0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Fault Operations C ∅	0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Fault Operations B ∅	0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Fault Operations A ∅	0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Foundation Condition	Good	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Patrol Inspection	Bushing Condition	Good	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Follow-up Action Required?	n	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Fault Operations Ground	1	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Fault Operations C Ø	0	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Fault Operations B Ø	0	
9/3/2020 14:12	Distribution	Greenville North Quarterly Inspection	K0033	BreakerVacuum	410-1328	VCB Readings	Fault Operations A Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Maintenance Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Fault Operations Ground	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Fault Operations C Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Fault Operations B Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Fault Operations A Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Amps C Ø	93.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Amps B Ø	95.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Amps A Ø	96.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	9 Month Operations	8	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BCH001389	Charger	478-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.300	millivolts
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BCH001389	Charger	478-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BCH001389	Charger	478-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BCH001389	Charger	478-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.1	amps
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BCH001389	Charger	478-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BCH001389	Charger	478-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BCH001389	Charger	478-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BCH001389	Charger	478-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Fault Operations B Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Fault Operations C Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Fault Operations Ground	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Maintenance Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Fault Operations Ground	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Fault Operations C Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1190	BreakerVacuum	WS-1331-3	VCB Readings	Fault Operations B Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Maintenance Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Operations Counter AF	161	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Operations Counter AL	161	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Operations This Read Vac	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Switching Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Unknown Operations	0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	BK000913	BreakerVacuum	CR-GND TRANS 1-A	VCB Readings	9 Month Operations	1	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1217	BreakerVacuum	WS-1332-4	VCB Readings	Unknown Operations	1	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Fault Operations B Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Fault Operations A Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Amps C Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Amps B Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Amps A Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1198	BreakerVacuum	WS-FUTURE-7	VCB Readings	9 Month Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Amps B Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Amps C Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Fault Operations A Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Fault Operations B Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Fault Operations C Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Fault Operations Ground	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Maintenance Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Operations Counter AF	81	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	LTCC000887	LTCControl	478-2	LTC Control Insp	All Connections OK?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	LTCC000887	LTCControl	478-2	LTC Control Insp	Follow-up Action Required?	n	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	LTCC000887	LTCControl	478-2	LTC Control Insp	General Comments		
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	LTCC000887	LTCControl	478-2	LTC Control Insp	LTC Operation Checked?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	LTCC000887	LTCControl	478-2	LTC Control Insp	LTC Output Voltage Level	125.3	VAC
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	LTCC000887	LTCControl	478-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	LTCC000887	LTCControl	478-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Amps A Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Amps B Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Amps C Ø	0.0	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	LTCC000887	LTCControl	478-2	LTC Control Insp	VRR Time Delay	45	Seconds
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Operations Counter AL	81	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Operations This Read Vac	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Switching Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1179	BreakerVacuum	WS-1306-1	VCB Readings	Unknown Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1248	BreakerVacuum	WS-FUTURE-8	VCB Readings	Fault Operations A Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Unknown Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Switching Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Operations This Read Vac	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Operations Counter AL	101	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1218	BreakerVacuum	WS-1334-4	VCB Readings	Operations Counter AF	101	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Ambient Temp	78	*F
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	General Comments		
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Vegetation	None	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	YD000239	Yard	646-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Unknown Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Switching Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Operations This Read Vac	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Operations Counter AL	3	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Operations Counter AF	3	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Maintenance Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	*F
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BAT001497	Battery	478-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Readings	Oil Temp Present	40	*C
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Readings	Oil Temp Max	45	*C
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Operations Counter AL	423	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Operations Counter AF	423	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Maintenance Operations	0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	General Comments	A phase IOC	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Patrol Inspection	General Comments		
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	*F
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	General Comments		
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Interrupters/Puffrs Visual OK?	y	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Follow-up Action Required?	n	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Fault Operations Ground	0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Fault Operations C Ø	0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Fault Operations B Ø	0	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	ST000135	Structure	008-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	General Comments		
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Follow-up Action Required?	n	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Fault Operations Ground	0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Fault Operations C Ø	0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Fault Operations B Ø	0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Fault Operations A Ø	0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Amps C Ø	545.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Amps B Ø	546.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Amps A Ø	556.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	9 Month Operations	1	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Bushing Condition	Good	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Amps C Ø	258.0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Amps B Ø	317.0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Amps A Ø	289.0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	9 Month Operations	5	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	General Comments		
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	52.50	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	9 Month Operations	1	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Unknown Operations	0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Tank Paint Condition	Good	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Switching Operations	0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Operations This Read Vac	0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Operations Counter AL	104	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Operations Counter AF	104	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	Maintenance Operations	0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Grounds in Place?	y	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Readings	General Comments		
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	General Comments		
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	T0193	NonLTC	008-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Fault Operations A Ø	0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Amps C Ø	200.0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Amps B Ø	220.0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Amps A Ø	110.0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	9 Months Operations	8	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Fault Operations Ground	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Fault Operations C Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Fault Operations B Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1230	BreakerVacuum	WS-14KV TR 1	VCB Readings	Fault Operations A Ø	0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	General Comments		
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB1277	BreakerVacuum	CR-1421-A	VCB Patrol Inspection	Foundation Condition	Good	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Amps B Ø	93.0	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Amps C Ø	100.0	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Bushing Condition	Good	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	General Comments		
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Fault Operations A Ø	0	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Fault Operations B Ø	0	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Fault Operations C Ø	0	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Fault Operations Ground	0	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Follow-up Action Required?	n	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Foundation Condition	Good	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	General Comments		
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	General Comments		
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Grounds in Place?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Maintenance Operations	0	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Operations Counter AF	189	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Operations Counter AL	189	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Operations This Read Vac	0	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Switching Operations	0	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Patrol Inspection	Tank Paint Condition	Good	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Unknown Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Maintenance Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Operations Counter AF	159	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Operations Counter AL	159	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Operations This Read Vac	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Switching Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1183	BreakerVacuum	WS-1319-1	VCB Readings	Unknown Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Unknown Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Switching Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Operations This Read Vac	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Operations Counter AL	100	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Operations Counter AF	100	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Maintenance Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Fault Operations Ground	0	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	LTCC000702	LTCControl	536-1	LTC Control Insp	VRR Time Delay	45	Seconds
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	LTCC000702	LTCControl	536-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	LTCC000702	LTCControl	536-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	LTCC000702	LTCControl	536-1	LTC Control Insp	LTC Output Voltage Level	123.6	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	LTCC000702	LTCControl	536-1	LTC Control Insp	LTC Operation Checked?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	LTCC000702	LTCControl	536-1	LTC Control Insp	General Comments		
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	LTCC000702	LTCControl	536-1	LTC Control Insp	Follow-up Action Required?	n	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	LTCC000702	LTCControl	536-1	LTC Control Insp	All Connections OK?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Fault Operations A Ø	0	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Fault Operations B Ø	0	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Fault Operations C Ø	0	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Fault Operations Ground	0	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Follow-up Action Required?	n	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	Foundation Condition	Good	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	General Comments		
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	General Comments		
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	Grounds in Place?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Maintenance Operations	0	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Operations Counter AF	197	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Operations Counter AL	197	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Fault Operations Ground	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Fault Operations C Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Fault Operations B Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Fault Operations A Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Amps C Ø	0.0	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Operations This Read Vac	0	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Switching Operations	0	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Patrol Inspection	Tank Paint Condition	Good	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001443	BreakerVacuum	478-0230	VCB Readings	Unknown Operations	0	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	9 Month Operations	53	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK001444	BreakerVacuum	478-0231	VCB Readings	Amps A Ø	99.0	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Vegetation	None	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	Need size info and qty
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	General Comments		
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	YD000632	Yard	CG-Yard	Yard Patrol Inspection	Ambient Temp	80	*F
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	SWG000179	Switchgear	SP-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Unknown Operations	0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Switching Operations	0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	LB0890	BreakerAirMagnetic	SP-1116	AMCB Readings	Operations This Read AM	0	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Positive DC Ground	.8	VDC
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	Negative DC Ground	.8	VDC
9/3/2020 9:33	Distribution	South Park Quarterly Inspection	BAT001509	Battery	SP-Battery Bank	Battery Patrol Inspection	General Comments		
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Fault Operations C Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Fault Operations B Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Fault Operations A Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Amps C Ø	37.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Amps B Ø	37.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Amps A Ø	38.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Amps B Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Amps A Ø	0.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1205	BreakerVacuum	WS-1474-2	VCB Readings	9 Month Operations	1	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1177	BreakerVacuum	WS-1304-1	VCB Readings	9 Month Operations	1	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Unknown Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Switching Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Operations This Read Vac	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Operations Counter AL	79	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Operations Counter AF	79	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Maintenance Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	General Comments		
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Patrol Inspection	General Comments		
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 11:38	Distribution	Campground Quarterly Inspection	LB0119	BreakerVacuum	CG-1438	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Fault Operations Ground	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Fault Operations C Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Fault Operations B Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Fault Operations A Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Amps C Ø	106.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Amps B Ø	109.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Amps A Ø	110.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1199	BreakerVacuum	WS-1426-3	VCB Readings	9 Month Operations	1	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/3/2020 12:33	Distribution	Reed Minerals Quarterly Inspection	FE000240	Fence	646-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Ambient Temp	77	*F
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Readings	Unknown Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Follow-up Action Required?	n	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Tank Paint Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Fault Operations Ground	0	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Foundation Condition	Crumbling	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	General Comments	Breaker 234,235 the foundation is crumbling.	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Tank Leaks	None	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Grounds in Place?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Readings	Maintenance Operations	0	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	9 Month Operations	26	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Fault Operations C ∅	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Fault Operations B ∅	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Fault Operations A ∅	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Amps A ∅	5.0	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Amps B ∅	4.0	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Amps C ∅	2.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Tank 3 Oil Level	Good	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Tank 2 Oil level	Good	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Tank 1 Oil Level	Good	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Readings	Switching Operations	0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Pressure Vessel Condition	Good	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Readings	Operations This Read Oil	0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Readings	Operations Counter AL	1407	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Readings	Operations Counter AF	1407	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Readings	Number of Ops last 9 Months	0	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Bushing Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Amps C ∅	89.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Amps B ∅	91.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Amps A ∅	92.0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Ambient Temp	82	*F
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	ST000037	Structure	536-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Vegetation	None	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	General Comments		
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Readings	General Comments	OCB Carded, GEN-11 has been torn down	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Operations Counter AL	186	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Operations This Read Vac	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Switching Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Unknown Operations	0	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	9 Month Operations	14	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	BK000894	BreakerVacuum	478-0225	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	General Comments	OCB Carded, GEN-11 has been torn down	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Operations Counter AF	186	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Gauge(s) Condition	Good	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Foundation Condition	Good	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Bushing Condition	Good	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Bushing Oil Level	Good	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Bushings Connection/Risers	Good	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	Maintenance Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LB1202	BreakerVacuum	WS-1429-3	VCB Patrol Inspection	General Comments		
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Fault Operations C Ø	0	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Fault Operations B Ø	1	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Fault Operations A Ø	0	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Fault Adjusted Amps C Phase V	3.95	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Fault Adjusted Amps B Phase V	7.91	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Readings	Fault Adjusted Amps A Phase V	3.95	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Readings	Follow-up Action Required?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Readings	Fault Operations	0	
9/3/2020 11:20	Distribution	Williamsburg Quarterly Inspection	YD000034	Yard	536-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	General Comments		
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Vegetation	None	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	YD000035	Yard	478-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/3/2020 12:23	Distribution	Cane Run Generating Quarterly Inspection	LB0152	BreakerOil	CR-SPARE 1-A	OCB Patrol Inspection	Follow-up Action Required?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	K0030	BreakerVacuum	478-0227	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/3/2020 13:49	Distribution	Williamsburg South Quarterly Inspection	ST000039	Structure	478-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	329	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	28.2	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	45.6	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	31.1	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	255	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	259	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments	ok	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	WX0445	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	9 Months Operations	0	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Amps A Ø	20.0	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	9 Month Operations	5	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	General Comments		
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Amps B Ø	20.0	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Amps C Ø	20.0	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Bushing Condition	Good	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	9 Month Operations	2	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Amps A Ø	863.0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Amps B Ø	839.0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Amps C Ø	811.0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Amps A Ø	140.0	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Amps B Ø	140.0	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	9 Months Operations	2	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Switching Operations	0	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Switching Operations	0	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Unknown Operations	0	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	LTC Current Tap Position	3L	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	LTC As Left Counter	126971	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Operations This Read Vac	0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Operations Counter AL	243	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	LTC As Found Counter	126971	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	General Comments		
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Operations Counter AF	243	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Maintenance Operations	0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	General Comments		
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Patrol Inspection	General Comments		
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Fault Operations Ground	0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Amps C Ø	135.0	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB1323	BreakerVacuum	AK-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Fault Operations A Ø	0	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Fault Operations B Ø	0	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Fault Operations C Ø	0	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Fault Operations Ground	0	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Min Tap Position	8L	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Max Tap Position	5R	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Mechanism Patrol Inspection	General Comments		
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	*F
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	LTC As Found Counter	26439	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	LTC As Left Counter	26439	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	LTC Current Tap Position	1R	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	General Comments		
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	General Comments		
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	General Comments		
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	BAT000888	Battery	SV-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Current Tap Position	1R	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	Winding Temp Present	51	*C
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	Winding Temp Max	59	*C
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Regulator As Left Counter	2341	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Max Tap Position	5R	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	General Comments		
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Current Tap Position	1R	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	General Comments		
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	LTC As Found Counter	38244	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	LTC As Left Counter	38244	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	LTC Current Tap Position	5L	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	LTC Max Tap Position	2L	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	LTC Min Tap Position	11L	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	40	*C
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	1441	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LT0300	LTCMechanism	CS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000197	Regulator	468-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Regulator As Left Counter	2347	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.3	volts
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000196	Regulator	468-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Amps A Ø	110.0	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Amps B Ø	119.0	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Amps C Ø	110.0	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Amps A Ø	0.0	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Amps B Ø	0.0	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Amps C Ø	0.0	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	General Comments		
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	80	°F
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Follow-up Action Required?	n	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Fault Operations	2	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Current Tap Position	2R	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	General Comments		
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Max Tap Position	4R	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Amps C Ø	200.0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Amps B Ø	200.0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Amps A Ø	200.0	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Min Tap Position	4L	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Regulator As Left Counter	122313	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0910	Regulator	797-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	2033	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	Totalizer Meter Reading	1.1586	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Fault Operations A Ø	0	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Fault Operations C Ø	0	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Fault Operations Ground	0	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Follow-up Action Required?	n	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Foundation Condition	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	General Comments		
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	General Comments		
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Grounds in Place?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Maintenance Operations	0	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Operations Counter AF	368	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Operations Counter AL	372	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Operations This Read Vac	4	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Switching Operations	4	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Unknown Operations	0	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	80	*F
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	49	°C
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	59	°C
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	49	°C
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.9	VDC
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.1	VDC
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	General Comments		
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Patrol Inspection	General Comments		
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	59	°C
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	49	°C
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	59	°C
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	General Comments		
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Maintenance Operations	0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Num Operations Last 9 Months	17	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Operations Counter AF	895	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Operations Counter AL	895	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Operations This Read SF6	2	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0007	BreakerSF6	AK-1296	GCB Readings	Switching Operations	0	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	9 Months Operations	1	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	FE000356	Fence	773-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Fault Operations	0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Follow-up Action Required?	n	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Patrol Inspection	General Comments		
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	General Comments		
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Maintenance Operations	0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Num Operations Last 9 Months	2	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Operations Counter AF	1321	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Operations Counter AL	1321	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Operations This Read SF6	0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Switching Operations	0	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Fault Operations Ground	0	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Fault Operations A Ø	0	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Fault Operations B Ø	0	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Fault Operations C Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Fault Operations Ground	0	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Follow-up Action Required?	n	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Patrol Inspection	General Comments		
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	General Comments		
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Maintenance Operations	0	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Operations Counter AF	578	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Operations Counter AL	578	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Operations This Read AM	1	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Switching Operations	1	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Fault Operations C Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	General Comments		
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	General Comments		
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Foundation Condition	Good	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Follow-up Action Required?	n	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Fault Operations Ground	0	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Fault Operations C Ø	0	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Fault Operations B Ø	0	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Fault Operations A Ø	0	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4R	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Operations Counter AF	175	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Operations Counter AL	175	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Operations This Read Vac	1	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Fault Operations B Ø	0	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Fault Operations A Ø	0	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Grounds in Place?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	BAT001354	Battery	571-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0001	LTCMechanism	AK-TRANS 1	LTC Counter Readings	LTC Min Tap Position	9L	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	LTCC000843	LTCControl	100-7	LTC Control Insp	VRR Time Delay	30	Seconds
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	LTCC000843	LTCControl	100-7	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	LTCC000843	LTCControl	100-7	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	LTCC000843	LTCControl	100-7	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	LTCC000843	LTCControl	100-7	LTC Control Insp	LTC Output Voltage Level	124.3	VAC
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	LTCC000843	LTCControl	100-7	LTC Control Insp	LTC Operation Checked?	y	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	LTCC000843	LTCControl	100-7	LTC Control Insp	General Comments		
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Readings	Maintenance Operations	1	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0162	BreakerVacuum	571-1645	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0852	BreakerAirMagnetic	SV-12KV BUS TIE SEC 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Amps A Ø	60.0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Amps B Ø	60.0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000082	BreakerSF6	AK-1294	GCB Readings	Amps C Ø	40.0	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	LTCC000843	LTCControl	100-7	LTC Control Insp	Follow-up Action Required?	n	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	LTCC000843	LTCControl	100-7	LTC Control Insp	All Connections OK?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Switching Operations	1	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Operations This Read AM	1	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Operations Counter AL	810	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Operations Counter AF	810	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Maintenance Operations	0	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	General Comments		
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Patrol Inspection	General Comments		
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0855	BreakerAirMagnetic	SV-12KV TR 2	AMCB Readings	Follow-up Action Required?	n	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	Oil Temp Present	45	°C
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	Oil Temp Max	55	°C
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	90.00	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	97.50	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2780.64	kw
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	General Comments		
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	General Comments		
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	C0343	NonLTC	797-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	9 Month Operations	1	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	964.80	kw
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	7.50	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4020	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	Follow-up Action Required?	n	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	n	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	General Comments	k	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	850	psi
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	Oil Temp Max	57	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	Oil Temp Present	47	°C
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	SWG000177	Switchgear	SV-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Unknown Operations	0	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	General Comments		
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	General Comments		
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	4135.68	kw
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Oil Temp Max	35	°C
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4308	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Winding Temp Max	35	°C
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	KT0044	NonLTC	571-1	NonLTC Transformer Readings	Winding Temp Present	40	°C
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	General Comments		
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	General Comments		
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	LTC Totalizer Reading	7039.68	kw
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	Oil Temp Max	50	°C
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	Oil Temp Present	50	°C
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	LTC Operations Since Last Insp	548	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	Totalizer Meter Reading	.7333	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	B0414	WithLTC	084-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	General Comments	ok	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	LTC Min Tap Position	4L	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	LTC Max Tap Position	4R	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	LTC Current Tap Position	1L	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	LTC As Left Counter	1773	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	LTC As Found Counter	1762	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Mechanism Patrol Inspection	General Comments		
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	General Comments		
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0316	LTCMechanism	100-6	LTC Counter Readings	Follow-up Action Required?	n	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	FE000218	Fence	479-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	LTC Operations Since Last Insp	526	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	50	°C
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	LTC Min Tap Position	3L	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0286	LTCMechanism	WS-TRANS 4	LTC Counter Readings	LTC Max Tap Position	4R	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	Winding Temp Present	48	°C
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	Winding Temp Max	62	°C
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	Totalizer Meter Reading	.9300	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	Totalizer Meter Reading	.5100	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	Oil Temp Present	49	°C
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	Oil Temp Max	60	°C
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	LTC Totalizer Reading	4896.00	kw
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	General Comments	top fan is not working	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	General Comments	liquid temp gauge is broke and will not reset	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	Oil Temp Present	38	°C
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	Oil Temp Max	52	°C
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	WithLTC	497-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Switching Operations	0	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Operations This Read Vac	0	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Operations Counter AL	183	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Operations Counter AF	183	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Maintenance Operations	0	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	General Comments		
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Patrol Inspection	General Comments		
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Follow-up Action Required?	n	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Operations Ground	0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Operations C Ø	0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	9 Month Operations	0	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Amps A Ø	450.0	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Amps B Ø	450.0	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Amps C Ø	450.0	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Bushing Condition	Good	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Fault Operations A Ø	0	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Fault Operations B Ø	0	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Fault Operations C Ø	0	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Fault Operations Ground	0	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Follow-up Action Required?	n	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Operations B Ø	0	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Operations A Ø	0	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.9	VDC
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Negative DC Ground	28.1	VDC
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	General Comments		
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BAT001360	Battery	405-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Follow-up Action Required?	n	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Patrol Inspection	General Comments		
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	General Comments		
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Maintenance Operations	0	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Operations Counter AF	523	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Operations Counter AL	523	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Operations This Read AM	0	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0854	BreakerAirMagnetic	SV-12KV TR 1	AMCB Readings	Switching Operations	0	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Readings	LTC Totalizer Reading	13392.00	kw
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	B0423	WithLTC	416-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	Totalizer Meter Reading	.8640	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Regulator As Left Counter	325696	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	SWG000104	Switchgear	AK-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Min Tap Position	12L	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Max Tap Position	1L	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	General Comments	ok	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0842	Regulator	479-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	C0325	NonLTC	682-1	NonLTC Transformer Readings	General Comments	ok	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Unknown Operations	0	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Bushing Condition	Good	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	9 Month Operations	1	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	Follow-up Action Required?	n	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	General Comments		
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	General Comments		
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0285	WithLTC	WS-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Switching Operations	0	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Unknown Operations	0	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	Oil Temp Present	68	°C
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	Oil Temp Max	70	°C
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	LTC Totalizer Reading	12441.60	kw
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Readings	General Comments		
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	General Comments		
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	M0092	WithLTC	721-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	Oil Temp Max	60	°C
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0333	WithLTC	100-7	LTC Transformer Readings	Oil Temp Present	60	°C
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Amps C Ø	205.0	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Amps B Ø	220.0	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Amps A Ø	217.0	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Accumulated Fault Duty C Ph V	17.54	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Accumulated Fault Duty B Ph V	26.31	%
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1297	BreakerVacuum	CS-1261	VCB Readings	Accumulated Fault Duty A Ph V	23.12	%
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Foundation Condition	Good	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	General Comments		
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	General Comments		
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Grounds in Place?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Readings	Oil Temp Present	42	°C
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Readings	Oil Temp Max	56	°C
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	110.00	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	117.50	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Readings	General Comments	ok	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	General Comments	ok	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	0942	NonLTC	479-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Maintenance Operations	0	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Operations Counter AF	162	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Operations Counter AL	162	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	MB0151	BreakerVacuum	721-1	VCB Readings	Operations This Read Vac	0	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Unknown Operations	0	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Switching Operations	0	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Operations This Read Vac	0	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Operations Counter AL	183	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Operations Counter AF	183	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Maintenance Operations	0	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Grounds in Place?	y	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	General Comments		
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Foundation Condition	Good	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Follow-up Action Required?	n	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Fault Operations Ground	0	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Fault Operations C ∅	0	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Fault Operations B ∅	0	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Fault Operations A ∅	0	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	BK000781	BreakerVacuum	100-1679	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	9 Month Operations	4	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Accumulated Fault Duty A Ph V	22.32	%
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Accumulated Fault Duty B Ph V	32.68	%
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Accumulated Fault Duty C Ph V	19.93	%
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Amps A ∅	115.0	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Amps B ∅	141.0	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Amps C ∅	110.0	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Operations A ∅	0	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Operations B ∅	0	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Operations C ∅	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Fault Operations Ground	0	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Follow-up Action Required?	n	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Patrol Inspection	General Comments		
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	General Comments		
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Maintenance Operations	0	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Operations Counter AF	213	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Operations Counter AL	213	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Operations This Read Vac	0	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Switching Operations	0	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1298	BreakerVacuum	CS-1262	VCB Readings	Unknown Operations	0	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Unknown Operations	2	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Switching Operations	0	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Operations This Read Vac	3	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Operations Counter AL	259	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Operations Counter AF	259	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Maintenance Operations	1	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Grounds in Place?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	General Comments		
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	General Comments		
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Foundation Condition	Good	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Follow-up Action Required?	n	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	General Comments		
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1300	psi
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	Oil Temp Max	64	°C
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	Oil Temp Present	46	°C
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	56	°C
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	40	°C
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	64	°C
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	46	°C
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	63	°C
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	47	°C
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	Oil Temp Present	40	°C
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	Oil Temp Max	50	°C
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	7384.32	kw
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	100.00	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	General Comments		
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	General Comments		
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	49	°C
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	59	°C
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	Oil Temp Present	47	°C
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	Oil Temp Max	57	°C
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1600	psi
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.5	psi
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	Follow-up Action Required?	n	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	General Comments		
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Mechanism Patrol Inspection	General Comments		
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	LTC As Found Counter	198528	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	LTC As Left Counter	198538	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	LTC Current Tap Position	1L	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	LTC Max Tap Position	2R	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	LTC Min Tap Position	11L	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	LTC Operations Since Last Insp	1724	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	M0092	LTCMechanism	721-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Fault Operations Ground	0	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Fault Operations C ∅	0	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Fault Operations B ∅	0	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Fault Operations A ∅	0	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Fault Adjusted Amps C Phase V	32.38	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Fault Adjusted Amps B Phase V	32.38	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Fault Adjusted Amps A Phase V	32.38	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Patrol Inspection	Bushing Condition	Good	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Amps C ∅	60.0	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Amps B ∅	90.0	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Amps A ∅	40.0	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0161	BreakerVacuum	571-1648	VCB Readings	9 Month Operations	4	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	40	°C
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0124	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	49	°C
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	59	°C
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	49	°C
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	59	°C
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	Follow-up Action Required?	n	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	General Comments		
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Mechanism Patrol Inspection	General Comments		
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	LTC As Found Counter	290	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	LTC As Left Counter	299	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	LTC Current Tap Position	1R	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	LTC Max Tap Position	4R	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	LTC Min Tap Position	4L	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	LTC Operations Since Last Insp	129	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0333	LTCMechanism	100-7	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Switching Operations	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	High	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	520	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	49	°C
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	LTC Min Tap Position	3L	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4R	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	LTC Current Tap Position	1R	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Operations This Read AM	0	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Operations Counter AL	1282	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Operations Counter AF	1282	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Maintenance Operations	0	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	General Comments		
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Patrol Inspection	General Comments		
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Follow-up Action Required?	n	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Fault Operations Ground	0	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Fault Operations C Ø	0	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Fault Operations B Ø	0	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Fault Operations A Ø	0	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Amps C Ø	120.0	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Amps B Ø	140.0	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Amps A Ø	140.0	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Amps C Ø	113.0	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Amps B Ø	115.0	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Amps A Ø	115.0	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	9 Month Operations	4	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BCH001233	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BCH001233	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BCH001233	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BCH001233	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	2.0	amps
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BCH001233	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	52.0	VDC
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BCH001233	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	52.0	VDC
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BCH001233	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.800	millivolts
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	General Comments		
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	90	*F
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BAT001299	Battery	721-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Positive DC Ground	14.2	VDC
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Negative DC Ground	12.2	VDC
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	General Comments		
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	80	*F
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BAT001297	Battery	843-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Ambient Temp	81	*F
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	General Comments	ok	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	General Comments		
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	Totalizer Meter Reading	.7692	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	S0041	NonLTC	773-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Vegetation	None	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	YD000317	Yard	682-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LT0300	WithLTC	CS-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0851	BreakerAirMagnetic	SV-1122	AMCB Readings	9 Months Operations	1	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	LTC As Left Counter	24205	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	LTC As Found Counter	24205	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Mechanism Patrol Inspection	General Comments	Ltc tank oil level is high pic sent to Stinson	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0283	LTCMechanism	WS-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	9 Month Operations	0	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Amps A Ø	578.0	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Amps B Ø	584.0	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Amps C Ø	532.0	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Bushing Condition	Good	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Fault Operations A Ø	0	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Fault Operations B Ø	0	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Fault Operations C Ø	0	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Fault Operations Ground	0	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Follow-up Action Required?	n	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Foundation Condition	Good	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	General Comments		
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	General Comments		
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Grounds in Place?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Maintenance Operations	0	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Operations Counter AF	227	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Operations Counter AL	227	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Operations This Read Vac	0	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Switching Operations	0	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0019	BreakerVacuum	416-1	VCB Readings	Unknown Operations	0	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	FE000318	Fence	643-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	General Comments		
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Mechanism Patrol Inspection	General Comments	LTC OIL IS LOW	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	LTC As Found Counter	220381	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	LTC As Left Counter	220381	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	LTC Current Tap Position	4L	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	LTC Max Tap Position	7L	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	LTC Min Tap Position	4R	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	66	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0168	LTCMechanism	SV-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	General Comments		
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Mechanism Patrol Inspection	General Comments	LTC OIL LEVEL LOW	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	LTC As Found Counter	87092	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Mechanism Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	LTC As Found Counter	26626	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	LTC As Left Counter	26626	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	LTC Current Tap Position	2R	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	LTC Max Tap Position	4R	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	LTC Min Tap Position	3L	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	50	°C
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	528	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0285	LTCMechanism	WS-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	LTC As Left Counter	87092	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	LTC Current Tap Position	4L	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	LTC Max Tap Position	4R	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	LTC Min Tap Position	5L	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	963	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Regulator As Left Counter	426763	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Min Tap Position	4L	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	General Comments	ok	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Current Tap Position	3R	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0702	Regulator	618-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Regulator As Left Counter	116702	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Min Tap Position	3L	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Max Tap Position	5R	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	General Comments		
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Current Tap Position	2R	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0698	Regulator	797-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	General Comments	1 trip check, 1 51A Inst	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	BCH001218	Charger	497-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.800	millivolts
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	BCH001218	Charger	497-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	BCH001218	Charger	497-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	BCH001218	Charger	497-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	BCH001218	Charger	497-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	BCH001218	Charger	497-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	BCH001218	Charger	497-Battery Charger	Battery Charger Patrol Insp	General Comments	ok	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	9 Month Operations	5	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	83	*F
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Foundation Condition	Good	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Follow-up Action Required?	n	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Fault Operations Ground	0	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Fault Operations C Ø	0	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Fault Operations B Ø	0	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Fault Operations A Ø	1	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Fault Adjusted Amps A Phase V	4.56	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Bushing Condition	Good	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Amps C Ø	180.0	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Amps B Ø	175.0	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Amps A Ø	150.0	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	26.9	VDC
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	28.2	VDC
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	ok	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	BAT001274	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Low	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0169	LTCMechanism	SV-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	Follow-up Action Required?	n	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	General Comments		
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Mechanism Patrol Inspection	General Comments		
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	LTC As Found Counter	115008	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	LTC As Left Counter	115008	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	LTC Current Tap Position	8R	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	LTC Max Tap Position	11R	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	LTC Min Tap Position	4L	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	LTC Operations Since Last Insp	0	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	B0423	LTCMechanism	416-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	General Comments		
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	CH000398	ControlHouse	843-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Unknown Operations	0	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Switching Operations	0	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Operations This Read Vac	2	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Operations Counter AL	317	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Operations Counter AF	317	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Readings	Maintenance Operations	1	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	Grounds in Place?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0152	BreakerVacuum	497-0657	VCB Patrol Inspection	General Comments	ok	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Bushing Condition	Good	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Amps C Ø	483.0	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Amps B Ø	484.0	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Amps A Ø	441.0	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	9 Month Operations	0	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	General Comments	ok	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	FE000241	Fence	618-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Unknown Operations	0	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Switching Operations	0	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Operations This Read Vac	0	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Operations Counter AL	139	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Operations Counter AF	139	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Maintenance Operations	0	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Grounds in Place?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	General Comments		
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Foundation Condition	Good	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Follow-up Action Required?	n	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Fault Operations Ground	0	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Ambient Temp	75	*F
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Fault Operations C Ø	0	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Fault Operations B Ø	0	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0283	WithLTC	WS-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	SWG000124	Switchgear	CS-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Unknown Operations	0	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Switching Operations	0	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Operations This Read Vac	0	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Operations Counter AL	179	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Operations Counter AF	179	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Maintenance Operations	0	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Grounds in Place?	y	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	General Comments		
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	General Comments		
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Foundation Condition	Good	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Follow-up Action Required?	n	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Fault Operations Ground	0	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Fault Operations C Ø	0	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Fault Operations B Ø	0	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Fault Operations A Ø	0	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0096	BreakerVacuum	223-5	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Current Tap Position	5L	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Regulator As Left Counter	4585	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Min Tap Position	6R	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Max Tap Position	12R	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	General Comments	ok	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0703	Regulator	618-1 B	Regulator Patrol Inspection	Current Tap Position	3R	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	General Comments		
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Interruptrs/Puffrs Visual OK?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	ST000303	Structure	773-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Fault Operations A Ø	0	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Patrol Inspection	Bushing Condition	Good	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Amps C Ø	150.0	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Amps B Ø	150.0	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Amps A Ø	150.0	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	General Comments		
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Vegetation	None	
9/3/2020 6:38	Distribution	Rumsey Quarterly Inspection	YD000127	Yard	008-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0114	BreakerVacuum	797-1606	VCB Readings	9 Month Operations	2	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Regulator As Left Counter	95086	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Min Tap Position	2L	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Max Tap Position	6R	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	General Comments	ok	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	R0704	Regulator	618-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Fault Operations Ground	0	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Fault Operations C Ø	0	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Fault Operations B Ø	0	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Fault Operations A Ø	0	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Amps C Ø	105.0	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Amps B Ø	110.0	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Amps A Ø	110.0	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	9 Months Operations	0	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Unknown Operations	0	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	General Comments		
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Max Tap Position	5R	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Switching Operations	4	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Operations This Read Vac	4	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Operations Counter AL	243	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Operations Counter AF	239	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Maintenance Operations	0	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Grounds in Place?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	General Comments		
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	General Comments		
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Foundation Condition	Good	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Regulator As Left Counter	11174	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Follow-up Action Required?	n	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Switching Operations	0	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Operations This Read Vac	1	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Operations Counter AL	166	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Operations Counter AF	166	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Maintenance Operations	1	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Grounds in Place?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	General Comments		
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	General Comments		
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Foundation Condition	Good	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Follow-up Action Required?	n	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Fault Operations Ground	0	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Fault Operations C Ø	0	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Fault Operations B Ø	0	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Fault Operations A Ø	0	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Bushing Condition	Good	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Amps C Ø	74.0	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Amps B Ø	48.0	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Amps A Ø	48.0	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	9 Month Operations	2	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Switching Operations	0	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Operations This Read AM	0	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Operations Counter AL	204	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Operations Counter AF	204	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Maintenance Operations	0	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	General Comments		
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Patrol Inspection	General Comments		
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LB0850	BreakerAirMagnetic	SV-1121	AMCB Readings	Follow-up Action Required?	n	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	General Comments		
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Floor Swept?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Broom on Site?	n	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Ambient Temperature	73	*F
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Fault Operations	0	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Follow-up Action Required?	n	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Foundation Condition	Good	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Gauge(s) Condition	Good	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	General Comments		
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	General Comments	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Grounds in Place?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Heaters (All) Functioning?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Maintenance Operations	0	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Num Operations Last 9 Months	1	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Operations Counter AF	43	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Operations Counter AL	43	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Operations This Read SF6	0	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	SF6 Bushing Condition	Good	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	SF6 Pressure	65	psi
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	SF6 Pressure Indicator	good	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Readings	Switching Operations	0	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	BK000223	BreakerSF6	CS-6676	GCB Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Fault Operations Ground	0	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Fault Operations C Ø	0	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Fault Operations B Ø	0	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Fault Operations A Ø	0	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Patrol Inspection	Bushing Condition	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Amps C Ø	60.0	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Amps B Ø	60.0	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Amps A Ø	60.0	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0109	BreakerVacuum	773-0930	VCB Readings	9 Month Operations	6	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Trash Emptied?	n	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	CH000467	ControlHouse	721-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	General Comments	ok	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	ST000234	Structure	497-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	General Comments		
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Unknown Operations	0	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Switching Operations	2	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Operations This Read Vac	2	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Operations Counter AL	231	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Operations Counter AF	229	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Maintenance Operations	0	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Grounds in Place?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	General Comments		
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	General Comments		
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Foundation Condition	Good	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Follow-up Action Required?	n	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Fault Operations Ground	0	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Fault Operations C ∅	0	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Fault Operations B ∅	0	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Fault Operations A ∅	0	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Patrol Inspection	Bushing Condition	Good	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Amps C ∅	51.0	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Amps B ∅	37.0	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Amps A ∅	56.0	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001156	BreakerVacuum	084-0937	VCB Readings	9 Month Operations	12	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Amps A ∅	320.0	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Unknown Operations	0	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Patrol Inspection	Bushing Condition	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Amps C ∅	50.0	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Amps B ∅	20.0	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Amps A ∅	20.0	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	K0110	BreakerVacuum	773-0929	VCB Readings	9 Month Operations	8	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Current Tap Position	1R	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	General Comments		
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	ST000648	Structure	CS-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Regulator As Left Counter	10992	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000064	Regulator	405-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Operations Counter AL	347	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Operations Counter AF	342	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Maintenance Operations	0	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Grounds in Place?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	General Comments		
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	General Comments		
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Foundation Condition	Good	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Follow-up Action Required?	n	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Fault Operations Ground	0	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Fault Operations C Ø	0	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Fault Operations B Ø	3	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Fault Operations A Ø	3	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Fault Adjusted Amps B Phase V	18.39	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Fault Adjusted Amps A Phase V	18.39	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Bushing Condition	Good	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Amps C Ø	39.0	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Amps B Ø	80.0	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Amps A Ø	56.0	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Accumulated Fault Duty B Ph V	1.83	%
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Accumulated Fault Duty A Ph V	1.83	%
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	9 Month Operations	49	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	General Comments		
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Maintenance Operations	0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Num Operations Last 9 Months	16	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Operations Counter AF	591	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Operations Counter AL	591	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Operations This Read SF6	0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Switching Operations	0	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000065	Regulator	405-1 B	Regulator Patrol Inspection	Current Tap Position	2R	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Readings	Unknown Operations	0	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000432	BreakerVacuum	405-1649	VCB Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Switching Operations	0	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Operations This Read Vac	1	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Operations Counter AL	175	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Operations Counter AF	175	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Maintenance Operations	1	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Grounds in Place?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	General Comments		
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Foundation Condition	Good	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Follow-up Action Required?	n	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Fault Operations Ground	0	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Fault Operations C Ø	0	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Fault Operations B Ø	0	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Fault Operations A Ø	0	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Patrol Inspection	Bushing Condition	Good	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Amps C Ø	26.0	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Amps B Ø	31.0	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Amps A Ø	36.0	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BK000433	BreakerVacuum	405-1651	VCB Readings	9 Month Operations	2	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Amps B Ø	350.0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Amps C Ø	380.0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Fault Operations	0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Readings	Follow-up Action Required?	n	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0005	BreakerSF6	AK-1295	GCB Patrol Inspection	General Comments		
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Unknown Operations	0	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Switching Operations	5	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BB0467	BreakerVacuum	416-0629	VCB Readings	Operations This Read Vac	11	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Operations Counter	112	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	General Comments	ok	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Amps C Ø	98.0	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Amps B Ø	97.0	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RC000436	RecloserElectronic	682-1683	Recloser Electronic Patrol Inspection	Amps A Ø	84.0	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Regulator As Left Counter	12359	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	LTC As Found Counter	22480	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	LTC As Left Counter	22480	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	LTC Current Tap Position	2R	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	LTC Max Tap Position	4R	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	LTC Min Tap Position	3L	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	52	°C
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	515	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0284	LTCMechanism	WS-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	LTCC000826	LTCControl	497-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	LTCC000826	LTCControl	497-1	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	LTCC000826	LTCControl	497-1	LTC Control Insp	LTC Operation Checked?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	LTCC000826	LTCControl	497-1	LTC Control Insp	General Comments	ok	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	LTCC000826	LTCControl	497-1	LTC Control Insp	Follow-up Action Required?	n	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	LTCC000826	LTCControl	497-1	LTC Control Insp	All Connections OK?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	General Comments		
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	General Comments		
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	ST000332	Structure	468-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Current Tap Position	2R	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	General Comments		
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Max Tap Position	5R	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LTCC000231	LTCControl	WS-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LTCC000231	LTCControl	WS-TRANS 1	LTC Control Insp	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LTCC000231	LTCControl	WS-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Unknown Operations	0	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Switching Operations	2	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Operations This Read Vac	2	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Operations Counter AL	201	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Operations Counter AF	199	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Maintenance Operations	0	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Grounds in Place?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	General Comments		
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	General Comments		
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Foundation Condition	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Follow-up Action Required?	n	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Fault Operations Ground	0	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Fault Operations C Ø	0	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Fault Operations B Ø	0	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Fault Operations A Ø	0	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	BK001094	BreakerVacuum	773-0931	VCB Patrol Inspection	Bushing Condition	Good	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	LTC As Left Counter	168630	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	LTC Current Tap Position	1L	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	LTC Max Tap Position	2R	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	LTC Min Tap Position	9L	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1924	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	General Comments		
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	General Comments	same as previous inspection	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	FE000053	Fence	721-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Ambient Temp	85	*F
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0002	LTCMechanism	AK-TRANS 2	LTC Counter Readings	LTC As Found Counter	168630	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	General Comments		
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	n	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Vegetation	None	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	YD000055	Yard	721-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	General Comments		
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	ST000060	Structure	721-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1700	psi
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	Oil Temp Max	58	°C
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	Oil Temp Present	48	°C
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Ambient Temp	82	°F
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	General Comments		
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	60	°C
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	51	°C
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	60	°C
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1150	psi
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Regulator As Left Counter	371924	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Min Tap Position	5L	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	RG000066	Regulator	405-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LTCC000265	LTCControl	WS-TRANS 4	LTC Control Insp	Parallel / Ind. Sw Position	paralleIPAR	Position
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LTCC000265	LTCControl	WS-TRANS 4	LTC Control Insp	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LTCC000265	LTCControl	WS-TRANS 4	LTC Control Insp	Follow-up Action Required?	n	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Max Tap Position	3R	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	General Comments	ok	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Current Tap Position	Neutral	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0841	Regulator	479-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	LTCC000830	LTCControl	100-6	LTC Control Insp	VRR Time Delay	30	Seconds
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	LTCC000830	LTCControl	100-6	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	LTCC000830	LTCControl	100-6	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	LTCC000830	LTCControl	100-6	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	LTCC000830	LTCControl	100-6	LTC Control Insp	LTC Output Voltage Level	123.8	VAC
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	LTCC000830	LTCControl	100-6	LTC Control Insp	LTC Operation Checked?	y	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	LTCC000830	LTCControl	100-6	LTC Control Insp	General Comments		
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	LTCC000830	LTCControl	100-6	LTC Control Insp	Follow-up Action Required?	n	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Regulator As Left Counter	311606	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Min Tap Position	4L	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	General Comments		
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Current Tap Position	3R	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	R0912	Regulator	797-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	LTCC000830	LTCControl	100-6	LTC Control Insp	All Connections OK?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	LTCC000826	LTCControl	497-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	LTCC000826	LTCControl	497-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	Oil Temp Max	57	°C
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	Oil Temp Present	46	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	X1 Winding Temp Max	59	°C
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	X1 Winding Temp Present	49	°C
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	X2 Winding Temp Max	59	°C
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	X2 Winding Temp Present	49	°C
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	X3 Winding Temp Max	59	°C
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0286	WithLTC	WS-TRANS 4	LTC Transformer Readings	X3 Winding Temp Present	49	°C
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	51	°C
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	60	°C
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0284	WithLTC	WS-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	51	°C
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	General Comments	Washout starting in drive in front of entry gate	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Vegetation	None	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	YD000319	Yard	643-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	ST000324	Structure	643-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	General Comments		
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	ST000378	Structure	416-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Ambient Temp	83	°F
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Vegetation	None	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	9 Month Operations	0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Amps A Ø	200.0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Amps B Ø	100.0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Amps C Ø	100.0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Fault Operations A Ø	0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Fault Operations B Ø	0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Fault Operations C Ø	0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Fault Operations Ground	0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Follow-up Action Required?	n	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	General Comments	b loc	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	General Comments		
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	General Comments		
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	LTC Min Tap Position	2L	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	LTC Operations Since Last Insp	1879	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations C ∅	0	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations B ∅	0	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations A ∅	0	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	3	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Amps A ∅	0.0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Amps B ∅	0.0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Amps C ∅	0.0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A ∅	0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B ∅	0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C ∅	0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Unknown Operations	0	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Switching Operations	0	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations This Read Vac	1	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations Counter AL	212	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	General Comments		
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	131	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Vegetation	None	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	131	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations Counter AF	212	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	Follow-up Action Required?	n	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	General Comments		
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	LTC As Found Counter	404726	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	LTC As Left Counter	404726	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	LTC Current Tap Position	4R	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	M0036	LTCMechanism	843-1	LTC Counter Readings	LTC Max Tap Position	10R	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Maintenance Operations	1	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000012	BreakerVacuum	AK-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	0	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	General Comments	ok	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	YD000240	Yard	618-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	General Comments		
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Ambient Temp	73	°F
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	General Comments		
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Maintenance Operations	0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Operations Counter AF	155	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Operations Counter AL	155	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Operations This Read Vac	0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Switching Operations	0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	9 Month Operations	0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Amps A Ø	180.0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Amps B Ø	200.0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Amps C Ø	180.0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Fault Operations A Ø	0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Fault Operations B Ø	0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Fault Operations C Ø	0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Fault Operations Ground	0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Follow-up Action Required?	n	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Patrol Inspection	General Comments		
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	General Comments	a ioc	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Maintenance Operations	0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Operations Counter AF	154	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Operations Counter AL	154	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Operations This Read Vac	0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000017	BreakerVacuum	AK-1292	VCB Readings	Switching Operations	0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	9 Month Operations	1	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Amps A Ø	580.0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Amps B Ø	550.0	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps C Ø	150.0	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps B Ø	100.0	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps A Ø	160.0	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0092	BreakerVacuum	912-Offline-Distribution	VCB Readings	9 Month Operations	2	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Maintenance Operations	0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Operations Counter AF	92	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Operations Counter AL	92	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Operations This Read Vac	0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000013	BreakerVacuum	AK-1290	VCB Readings	Switching Operations	0	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	General Comments		
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	YD000388	Yard	084-Yard	Yard Patrol Inspection	Ambient Temp	85	°F
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	9 Month Operations	0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Amps A Ø	250.0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Amps B Ø	250.0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Amps C Ø	250.0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Fault Operations A Ø	0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Fault Operations B Ø	0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Fault Operations C Ø	0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Fault Operations Ground	0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Readings	Follow-up Action Required?	n	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000016	BreakerVacuum	AK-1291	VCB Patrol Inspection	General Comments		
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Vegetation	None	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	YD000673	Yard	CS-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	General Comments		
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	2200	psi
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	Oil Temp Max	65	°C
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	Oil Temp Present	50	°C
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	70	°C
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	50	°C
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	75	°C
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	60	°C
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	75	°C
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	60	°C
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Readings	Oil Temp Present	27	°C
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Readings	Oil Temp Max	38	°C
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Readings	General Comments	ok	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	General Comments	ok	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Broom on Site?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	85	°F
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	General Comments		
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Current Tap Position	2L	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	BAT001405	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	BAT001405	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	BAT001405	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	BAT001405	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	BAT001405	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	BAT001405	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	BAT001405	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	90	*F
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	BAT001405	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	B0127	NonLTC	479-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0002	WithLTC	AK-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	General Comments		
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Vegetation	None	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	General Comments		
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	ST000179	Structure	843-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	General Comments	ok	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	ST000209	Structure	682-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	General Comments		
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Trash Emptied?	n	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	CH000208	ControlHouse	CS-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	General Comments		
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	FE000666	Fence	CS-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	General Comments		
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	FE000173	Fence	843-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Ambient Temp	80	*F
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	YD000172	Yard	843-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Retired Distribution	y	If no, which cells in comments
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Unknown Operations	0	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	85	*F
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	General Comments		
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	General Comments		
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.1	VDC
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.2	VDC
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	BCH001088	Charger	SV-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	.500	millivolts
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	BCH001088	Charger	SV-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	BCH001088	Charger	SV-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	BCH001088	Charger	SV-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.2	amps
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	BCH001088	Charger	SV-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	BCH001088	Charger	SV-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	BCH001088	Charger	SV-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Regulator As Left Counter	51394	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	General Comments		
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Maintenance Operations	0	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Operations Counter AF	147	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Operations Counter AL	147	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Operations This Read Vac	1	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	9 Month Operations	4	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Switching Operations	0	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Unknown Operations	1	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Amps A Ø	72.0	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Amps B Ø	75.0	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Amps C Ø	73.0	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Bushing Condition	Good	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Fault Operations A Ø	0	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Fault Operations B Ø	0	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Fault Operations C Ø	0	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Fault Operations Ground	0	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Foundation Condition	Good	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	General Comments		
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	General Comments		
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Grounds in Place?	y	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Maintenance Operations	0	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Operations Counter AF	228	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Operations Counter AL	230	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Operations This Read Vac	2	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	K0115	BreakerVacuum	223-0947	VCB Readings	Switching Operations	2	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	Follow-up Action Required?	n	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	General Comments		
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	General Comments		
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	LTC Totalizer Reading	10817.28	kw
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	700	psi
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	Oil Temp Max	40	°C
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	Oil Temp Present	40	°C
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	Totalizer Meter Reading	.7512	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	Winding Temp Max	60	°C
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	Winding Temp Present	45	°C
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	Follow-up Action Required?	n	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Regulator As Left Counter	40348	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Min Tap Position	10L	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Max Tap Position	16R	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	General Comments		
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Mechanism Patrol Inspection	General Comments		
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	LTC As Found Counter	18037	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	LTC As Left Counter	18037	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	LTC Current Tap Position	5L	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	LTC Max Tap Position	1R	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	LTC Min Tap Position	8L	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	LTC Operations Since Last Insp	841	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Current Tap Position	2L	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1412	Regulator	773-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Regulator As Left Counter	50015	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Min Tap Position	4L	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	General Comments		
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Current Tap Position	Neutral	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1411	Regulator	773-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BCH001392	Charger	468-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BCH001392	Charger	468-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BCH001392	Charger	468-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.9	amps
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BCH001392	Charger	468-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BCH001392	Charger	468-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	BAT000143	Battery	CS-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	TX000003	WithLTC	223-5	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	Follow-up Action Required?	n	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	General Comments		
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	General Comments		
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	LTC Totalizer Reading	4518.72	kw
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	Oil Temp Max	59	°C
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	Oil Temp Present	43	°C
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Adequate	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	9 Month Operations	3	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Current Tap Position	1R	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Amps A Ø	140.0	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Amps B Ø	150.0	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Amps C Ø	140.0	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Bushing Condition	Good	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	General Comments		
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Amps C Ø	550.0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Fault Operations Ground	0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Patrol Inspection	General Comments		
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	General Comments		
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Maintenance Operations	0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Operations Counter AF	76	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Operations Counter AL	76	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Operations This Read Vac	0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	BK000018	BreakerVacuum	AK-12KV TR 2	VCB Readings	Switching Operations	0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Switching Operations	0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Operations This Read SF6	1	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Operations Counter AL	697	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Operations Counter AF	697	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Num Operations Last 9 Months	1	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Maintenance Operations	0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Patrol Inspection	Grounds in Place?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	General Comments		
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Patrol Inspection	General Comments		
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Follow-up Action Required?	n	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Fault Operations	1	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Amps C Ø	240.0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Amps B Ø	240.0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0001	BreakerSF6	AK-1289	GCB Readings	Amps A Ø	260.0	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	General Comments	ok	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	FE000313	Fence	682-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BCH001373	Charger	416-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BCH001373	Charger	416-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BCH001373	Charger	416-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BCH001373	Charger	416-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BCH001373	Charger	416-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BCH001373	Charger	416-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BCH001373	Charger	416-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BCH001373	Charger	416-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BCH001374	Charger	084-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BCH001374	Charger	084-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Fault Adjusted Amps B Phase V	6.27	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Fault Adjusted Amps C Phase V	6.27	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Fault Operations A Ø	0	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BCH001374	Charger	084-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BCH001374	Charger	084-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.3	amps
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BCH001374	Charger	084-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BCH001374	Charger	084-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BCH001374	Charger	084-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BCH001374	Charger	084-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	PF000327	PowerFuse	SV-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	PF000327	PowerFuse	SV-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	k	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	PF000003	PowerFuse	AK-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	PF000003	PowerFuse	AK-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	69	*F
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Battery Bank Amps	2.9	AMPS
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.9	volts
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Regulator As Left Counter	2108	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Fault Operations B Ø	0	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Fault Operations C Ø	0	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Fault Operations Ground	0	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Follow-up Action Required?	n	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Foundation Condition	Good	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	General Comments		
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	General Comments		
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Grounds in Place?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Battery Bank Volts	53.5	VDC
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BAT001442	Battery	468-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	BAT000214	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Max Tap Position	5R	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Min Tap Position	8L	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	RG000136	Regulator	468-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	Totalizer Meter Reading	.9414	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	M0036	WithLTC	843-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	PF000328	PowerFuse	SV-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	PF000328	PowerFuse	SV-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	k	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	PF000329	PowerFuse	SV-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	PF000329	PowerFuse	SV-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	k	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	PF000330	PowerFuse	SV-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	PF000330	PowerFuse	SV-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	k	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	K0111	BreakerVacuum	797-1607	VCB Readings	Fault Adjusted Amps A Phase V	6.27	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	LTC Operations Since Last Insp	1104	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	LTC Min Tap Position	9L	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	LTC Max Tap Position	Neutral	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	LTC Current Tap Position	2L	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	LTC As Left Counter	11199	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	LTC As Found Counter	11199	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Mechanism Patrol Inspection	General Comments		
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	General Comments		
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	LTCM000032	LTCMechanism	084-5	LTC Counter Readings	Follow-up Action Required?	n	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Vegetation	None	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	General Comments	ok	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	YD000227	Yard	497-Yard	Yard Patrol Inspection	Ambient Temp	83	*F
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Fault Operations Ground	0	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	BCH000487	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	BCH000487	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	BCH000487	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	BCH000487	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	BCH000487	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Amps C Ø	0.0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Amps B Ø	0.0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Amps A Ø	0.0	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Current Tap Position	2R	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	General Comments		
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Max Tap Position	5R	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Regulator As Left Counter	10172	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000130	Regulator	571-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	BCH000487	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	BCH000487	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Fault Operations C Ø	0	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Fault Operations B Ø	0	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Fault Operations A Ø	0	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Grounds in Place?	y	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	General Comments		
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Regulator As Left Counter	8183	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	LTCC000877	LTCControl	721-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	LTC000877	LTCControl	721-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	LTC000877	LTCControl	721-1	LTC Control Insp	VRR Time Delay	60	Seconds
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Max Tap Position	2R	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	General Comments	ok	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Current Tap Position	1R	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	PF000076	PowerFuse	CS-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	k	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	PF000076	PowerFuse	CS-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	PF000075	PowerFuse	CS-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	k	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	PF000075	PowerFuse	CS-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	General Comments		
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Foundation Condition	Good	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Switching Operations	0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Operations This Read SF6	0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Operations Counter AL	645	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Operations Counter AF	645	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Num Operations Last 9 Months	0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Maintenance Operations	0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	General Comments		
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Patrol Inspection	General Comments		
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Follow-up Action Required?	n	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0006	BreakerSF6	SH-1281	GCB Readings	Fault Operations	0	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000105	Regulator	682-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Follow-up Action Required?	n	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Bushing Condition	Good	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Amps C Ø	60.0	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Amps B Ø	48.0	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Current Tap Position	Neutral	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	General Comments		
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Max Tap Position	4R	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	PF000001	PowerFuse	AK-STA SER NO 1	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	PF000001	PowerFuse	AK-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Regulator As Left Counter	9164	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000132	Regulator	571-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Amps A Ø	72.0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	PF000001	PowerFuse	AK-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	PF000002	PowerFuse	AK-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	PF000002	PowerFuse	AK-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	PF000004	PowerFuse	AK-STA SER NO 2	Disconnect Powerfuse Inspection	Equipment Properly Labeled?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	PF000004	PowerFuse	AK-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	PF000004	PowerFuse	AK-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	All Connections OK?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Bushing Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	9 Month Operations	2	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Capacitor Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Unknown Operations	0	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Switching Operations	0	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Operations This Read Vac	0	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Operations Counter AL	201	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Operations Counter AF	201	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Maintenance Operations	0	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Grounds in Place?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	General Comments	ok	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	General Comments	ok	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Foundation Condition	Good	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Follow-up Action Required?	n	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Fault Operations Ground	0	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Fault Operations C Ø	0	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Fault Operations B Ø	0	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Fault Operations A Ø	0	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Current Tap Position	Neutral	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	General Comments		
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Max Tap Position	4R	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Min Tap Position	6L	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Regulator As Left Counter	9702	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	RG000131	Regulator	571-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	WB0153	BreakerVacuum	497-0656	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Fault Operations B Ø	0	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Fault Operations A Ø	0	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Bushing Condition	Good	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Amps C Ø	259.0	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Amps B Ø	265.0	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Amps A Ø	318.0	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	9 Month Operations	36	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	WithLTC Trn Dynamic Health	90.00	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	Totalizer Meter Reading	.0006	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	Oil Temp Present	40	°C
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	Oil Temp Max	60	°C
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	LTC Totalizer Reading	5.76	kw
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	General Comments		
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	General Comments		
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	Follow-up Action Required?	n	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Tank Leaks	None	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Regulator As Left Counter	8494	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.4	volts
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	LTCC000877	LTCControl	721-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelloff	Position
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	LTCC000877	LTCControl	721-1	LTC Control Insp	LTC Output Voltage Level	124.5	VAC
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	LTCC000877	LTCControl	721-1	LTC Control Insp	LTC Operation Checked?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	LTCC000877	LTCControl	721-1	LTC Control Insp	General Comments		
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	LTCC000877	LTCControl	721-1	LTC Control Insp	Follow-up Action Required?	n	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	LTCC000877	LTCControl	721-1	LTC Control Insp	All Connections OK?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Regulator As Left Counter	48599	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.5	volts
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Min Tap Position	7L	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Max Tap Position	7R	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	General Comments		
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Current Tap Position	3R	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1409	Regulator	866-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Unknown Operations	0	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Switching Operations	2	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Operations This Read Vac	2	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Operations Counter AL	165	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Operations Counter AF	163	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Maintenance Operations	0	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	General Comments		
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	General Comments		
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Foundation Condition	Good	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Follow-up Action Required?	n	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Fault Operations Ground	0	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BK001440	BreakerVacuum	416-0631	VCB Readings	Fault Operations C Ø	0	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Min Tap Position	6L	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Max Tap Position	2R	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	General Comments	ok	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Current Tap Position	1R	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Unknown Operations	0	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Switching Operations	2	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Operations This Read Vac	2	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Operations Counter AL	218	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Operations Counter AF	216	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Maintenance Operations	0	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	9 Month Operations	2	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Accumulated Fault Duty A Ph V	8.77	%
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Accumulated Fault Duty B Ph V	8.77	%
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Accumulated Fault Duty C Ph V	30.29	%
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Amps A Ø	73.0	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Amps B Ø	0.0	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Amps C Ø	12.0	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Operations A Ø	0	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Operations B Ø	0	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Operations C Ø	0	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Fault Operations Ground	0	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Follow-up Action Required?	n	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Patrol Inspection	General Comments		
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	General Comments		
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Maintenance Operations	0	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Operations Counter AF	197	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Operations Counter AL	197	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Operations This Read Vac	0	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Switching Operations	0	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1296	BreakerVacuum	CS-1260	VCB Readings	Unknown Operations	0	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	General Comments	ok	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Current Tap Position	2R	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	General Comments		
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	ST000199	Structure	405-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	W0316	WithLTC	100-6	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000107	Regulator	682-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/2/2020 10:54	Distribution	Centertown South Quarterly Inspection	RG000106	Regulator	682-1 A	Regulator Patrol Inspection	Regulator As Left Counter	8537	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Grounds in Place?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	General Comments		
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	General Comments		
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Foundation Condition	Good	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Follow-up Action Required?	n	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Fault Operations Ground	0	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Fault Operations C ∅	4	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Fault Operations B ∅	0	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Fault Operations A ∅	0	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Fault Adjusted Amps C Phase V	24.53	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	All Connections OK?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Bushing Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Capacitor Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Bushing Condition	Good	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Amps C ∅	248.0	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Amps B ∅	227.0	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Amps A ∅	268.0	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Accumulated Fault Duty C Ph V	7.31	%
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Accumulated Fault Duty B Ph V	3.2	%
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Accumulated Fault Duty A Ph V	5.94	%
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	9 Month Operations	28	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Foundation Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Grounds in Place?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Tank Leaks	None	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Vegetation	None	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	General Comments	ok	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 14:28	Distribution	Clark County Quarterly Inspection	BCH001032	Charger	475-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/2/2020 14:28	Distribution	Clark County Quarterly Inspection	BCH001032	Charger	475-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/2/2020 14:28	Distribution	Clark County Quarterly Inspection	BCH001032	Charger	475-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/2/2020 14:28	Distribution	Clark County Quarterly Inspection	BCH001032	Charger	475-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.9	amps
9/2/2020 14:28	Distribution	Clark County Quarterly Inspection	BCH001032	Charger	475-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	132.0	VDC
9/2/2020 14:28	Distribution	Clark County Quarterly Inspection	BCH001032	Charger	475-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	132.0	VDC
9/2/2020 14:28	Distribution	Clark County Quarterly Inspection	BCH001032	Charger	475-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Ambient Temp	79	*F
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Unknown Operations	0	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Switching Operations	6	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	General Comments	ok	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Operations This Read Vac	12	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	ST000246	Structure	618-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Operations Counter AL	366	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Operations Counter AF	366	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Readings	Maintenance Operations	2	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	KB0002	BreakerVacuum	416-0630	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Min Tap Position	5L	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	General Comments	ok	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Current Tap Position	1L	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	SWG000020	Switchgear	AK-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	BAT001405	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	BAT001405	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	BAT001405	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	9.5	VDC
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	BAT001405	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	9.1	VDC
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	BAT001405	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	R1413	Regulator	773-1 A	Regulator Patrol Inspection	Regulator As Left Counter	47567	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000067	CapacitorBank	WS-Cap Bank 3	Capacitor Patrol Inspection	Warning Signs OK?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	7.5	VDC
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	2.5	VDC
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	BAT000396	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Tank Leaks	None	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Regulator As Left Counter	20110	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.9	volts
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	R0840	Regulator	479-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	General Comments		
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Panels Dusted?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Station Ground Set On Site?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	SWG000098	Switchgear	SV-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	40	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0126	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Grounds in Place?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Maintenance Operations	0	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Grounds in Place?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	General Comments		
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	General Comments		
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Foundation Condition	Good	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Follow-up Action Required?	n	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Amps A Ø	250.0	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Tank Leaks	None	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Warning Signs OK?	y	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	9 Month Operations	5	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Fault Operations Ground	0	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Fault Operations C Ø	0	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Fault Operations B Ø	0	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Fault Operations A Ø	0	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Fault Adjusted Amps C Phase V	12.58	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Fault Adjusted Amps B Phase V	12.58	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	All Connections OK?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Bushing Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Capacitor Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Patrol Inspection	Bushing Condition	Good	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Amps C Ø	280.0	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0093	BreakerVacuum	223-0945	VCB Readings	Amps B Ø	282.0	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Unknown Operations	0	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Switching Operations	2	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Foundation Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000069	CapacitorBank	WS-Cap Bank 1	Capacitor Patrol Inspection	General Comments		
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Operations This Read Vac	2	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Operations Counter AL	172	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Operations Counter AF	170	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Maintenance Operations	0	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Grounds in Place?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	General Comments		
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	General Comments		
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Foundation Condition	Good	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Follow-up Action Required?	n	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Fault Operations Ground	0	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Fault Operations C Ø	0	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Fault Operations B Ø	0	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Fault Operations A Ø	0	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Patrol Inspection	Bushing Condition	Good	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Amps C Ø	59.0	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Amps B Ø	43.0	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Amps A Ø	49.0	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001427	BreakerVacuum	084-0936	VCB Readings	9 Month Operations	2	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Unknown Operations	3	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Switching Operations	2	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Operations This Read Vac	5	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Operations Counter AL	179	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Operations Counter AF	177	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Capacitor Rack Condition OK?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Capacitor Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Cap bank PT in Good Condition?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Bushings Connection/Risers	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Bushing Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	All Connections OK?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	LTCC000871	LTCControl	416-1	LTC Control Insp	VRR Time Delay	30	Seconds
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	LTCC000871	LTCControl	416-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	LTCC000871	LTCControl	416-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	LTCC000871	LTCControl	416-1	LTC Control Insp	LTC Output Voltage Level	126.0	VAC
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	LTCC000871	LTCControl	416-1	LTC Control Insp	LTC Operation Checked?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	LTCC000871	LTCControl	416-1	LTC Control Insp	General Comments		
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	LTCC000871	LTCControl	416-1	LTC Control Insp	Follow-up Action Required?	n	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	LTCC000871	LTCControl	416-1	LTC Control Insp	All Connections OK?	y	
9/2/2020 14:28	Distribution	Clark County Quarterly Inspection	BCH001032	Charger	475-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	200.00	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	63	°C
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	38	°C
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	60	°C
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	30	°C
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	30	°C
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	55	°C
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	General Comments	ok	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	ST000190	Structure	479-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	YD000184	Yard	479-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Foundation Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Grounds in Place?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Insulators in Good Condition?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Fault Adjusted Amps A Phase V	12.58	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Patrol Inspection	Bushing Condition	Good	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Amps C Ø	146.0	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Amps B Ø	159.0	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Amps A Ø	124.0	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Tank Leaks	None	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000070	CapacitorBank	WS-Cap Bank 4	Capacitor Patrol Inspection	Warning Signs OK?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	General Comments		
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	H2 Winding Temp Max	0	°C
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	H2 Winding Temp Present	0	°C
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	Oil Temp Max	38	°C
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Readings	Oil Temp Present	38	°C
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BK001426	BreakerVacuum	084-0935	VCB Readings	9 Month Operations	5	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LT0001	WithLTC	AK-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Warning Signs OK?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Tank Paint Condition	Adequate	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Tank Leaks	None	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Insulators In Good Condition?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Grounds in Place?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Fuses Blown? Y / N	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Fuse Barrels Good Condition?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	CAP000068	CapacitorBank	WS-Cap Bank 2	Capacitor Patrol Inspection	Foundation Condition	Good	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Operations This Read Vac	0	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Operations Counter AL	175	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Operations Counter AF	175	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Maintenance Operations	0	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Grounds in Place?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	General Comments		
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	General Comments		
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Foundation Condition	Good	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Follow-up Action Required?	n	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Fault Operations Ground	0	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Fault Operations C Ø	0	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Fault Operations B Ø	0	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Bushing Condition	Good	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Amps C Ø	178.0	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Amps B Ø	205.0	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Amps A Ø	195.0	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	9 Month Operations	1	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Unknown Operations	0	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Switching Operations	0	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Operations This Read Vac	0	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Operations Counter AL	230	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Operations Counter AF	230	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Maintenance Operations	0	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Grounds in Place?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	General Comments		
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	General Comments		
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Foundation Condition	Good	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Follow-up Action Required?	n	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Fault Operations Ground	0	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Fault Operations C Ø	0	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Fault Operations B Ø	0	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	General Comments		
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Switch Stick Next Test Date	2021-03-26 00:00:00.000000	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Vegetation	None	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	80	*F
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Fault Operations Ground	0	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Fault Operations C Ø	0	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Fault Operations B Ø	0	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Fault Operations A Ø	0	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Tank Leaks	None	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Radiator Leaks	None	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Bushing Condition	Good	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Amps C Ø	35.0	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Amps B Ø	29.0	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Amps A Ø	55.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Grounds in Place?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Foundation Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0288	GroundTransformer	WS-GND TR 3	Ground Transformer Patrol Inspection	Cleaned Mechanism Cabinet?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	9 Month Operations	2	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Unknown Operations	0	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001272	BreakerVacuum	721-0212	VCB Readings	Switching Operations	0	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Foundation Condition	Good	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Follow-up Action Required?	n	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Fault Operations Ground	0	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Fault Operations C Ø	0	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Fault Operations B Ø	2	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Low	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	Percent Thermal Load C Ø Max	55	%
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	Percent Thermal Load B Ø Max	40	%
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	Oil Temp Present	40	°C
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	Oil Temp Max	60	°C
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Tank Leaks	None	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Radiator Leaks	None	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Grounds in Place?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Foundation Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Cleaned Mechanism Cabinet?	y	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LT0287	GroundTransformer	WS-GND TR 2	Ground Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	General Comments	TRANSFORMER OIL LEVEL IS LOW	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	General Comments		
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	General Comments	ok	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Fault Operations A Ø	0	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	General Comments		
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	BAT001459	Battery	416-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Unknown Operations	0	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Switching Operations	2	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Operations This Read Vac	4	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Operations Counter AL	273	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Operations Counter AF	269	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Maintenance Operations	0	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Grounds in Place?	y	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	General Comments		
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	General Comments		
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Patrol Inspection	Bushing Condition	Good	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Amps C Ø	94.0	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Amps B Ø	104.0	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Amps A Ø	96.0	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001271	BreakerVacuum	721-0211	VCB Readings	9 Month Operations	1	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Ambient Temp	73	*F
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	General Comments		
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	YD000581	Yard	SV-Yard	Yard Patrol Inspection	Vegetation	None	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Operations Ground	0	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Operations C Ø	0	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Operations B Ø	0	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Operations A Ø	0	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Amps C Ø	0.0	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Amps B Ø	0.0	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Amps A Ø	0.0	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Accumulated Fault Duty C Ph V	5.58	%
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Accumulated Fault Duty B Ph V	5.58	%
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Accumulated Fault Duty A Ph V	5.58	%
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	9 Month Operations	2	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	9 Month Operations	20	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Amps A Ø	150.0	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Amps B Ø	100.0	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Amps C Ø	80.0	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Bushing Condition	Good	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Fault Operations A Ø	0	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Fault Operations B Ø	0	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Fault Operations C Ø	0	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Fault Operations Ground	0	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Follow-up Action Required?	n	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Foundation Condition	Good	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	General Comments		
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	Oil Temp Present	45	°C
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	Oil Temp Max	100	°C
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	General Comments		
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Unknown Operations	0	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Switching Operations	0	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	General Comments	ok	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	General Comments	ok	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	Non LTC Totalizer Reading	889.92	kw
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	27.50	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	Oil Temp Max	55	°C
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	Oil Temp Present	43	°C
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	0943	NonLTC	479-1 A	NonLTC Transformer Readings	Totalizer Meter Reading	.7416	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Operations This Read Vac	0	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Operations Counter AL	133	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Operations Counter AF	133	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Maintenance Operations	0	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	General Comments		
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Patrol Inspection	General Comments		
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1299	BreakerVacuum	CS-1263	VCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Switching Operations	0	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Operations This Read Vac	0	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Operations Counter AL	211	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Operations Counter AF	211	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Maintenance Operations	0	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Grounds in Place?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	General Comments		
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	General Comments		
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Foundation Condition	Good	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Follow-up Action Required?	n	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	Oil Temp Present	35	°C
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	Oil Temp Max	47	°C
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	110.00	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	117.50	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1031.76	kw
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LTCC000405	LTCControl	WS-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LTCC000405	LTCControl	WS-TRANS 3	LTC Control Insp	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LTCC000405	LTCControl	WS-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	General Comments	ok	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	General Comments	ok	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LTCC000409	LTCControl	WS-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LTCC000409	LTCControl	WS-TRANS 2	LTC Control Insp	General Comments		
9/8/2020 6:43	Distribution	Waterside West Quarterly Inspection	LTCC000409	LTCControl	WS-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Multiplier	3200	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Readings	Totalizer Meter Reading	.8250	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Ambient Temp	85	°F
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	YD000295	Yard	773-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	General Comments		
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Grounds in Place?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Maintenance Operations	1	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Operations Counter AF	220	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Operations Counter AL	220	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Operations This Read Vac	1	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Switching Operations	0	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	K0159	BreakerVacuum	405-1650	VCB Readings	Unknown Operations	0	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	General Comments		
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Readings	General Comments		
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Readings	Non LTC Totalizer Reading	2640.00	kw
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Readings	Oil Temp Present	40	°C
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	B0125	NonLTC	Retired Distribution	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	General Comments		
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	CH000368	ControlHouse	084-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	Totalizer Meter Reading	.8598	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/2/2020 13:31	Distribution	Nelson Quarterly Inspection	C0332	NonLTC	618-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Readings	Unknown Operations	0	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001273	BreakerVacuum	721-0213	VCB Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	9 Month Operations	2	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	3.85	%
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	3.85	%
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	3.85	%
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Amps A Ø	404.0	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Amps B Ø	374.0	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Amps C Ø	324.0	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Fault Operations Ground	0	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Patrol Inspection	General Comments		
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	General Comments		
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Maintenance Operations	0	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Operations Counter AF	158	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Operations Counter AL	158	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Operations This Read Vac	0	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Switching Operations	0	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LB1294	BreakerVacuum	CS-12KV TR 1	VCB Readings	Unknown Operations	0	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Ambient Temp	82	°F
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	General Comments		
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Vegetation	None	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	YD000326	Yard	468-Yard	Yard Patrol Inspection	Yard Lights Working?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	General Comments		
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	General Comments		
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Vegetation	None	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Oil stop valve operational?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	General Comments		
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	YD000194	Yard	797-Yard	Yard Patrol Inspection	Ambient Temp	80	*F
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	General Comments		
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	FE000323	Fence	468-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	General Comments		
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	FE000196	Fence	797-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Follow-up Action Required?	n	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Fault Operations Ground	0	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Fault Operations C Ø	0	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Fault Operations B Ø	0	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Fault Operations A Ø	0	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Bushing Condition	Good	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Amps C Ø	0.0	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Amps B Ø	0.0	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Amps A Ø	0.0	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	9 Month Operations	23	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BCH000446	Charger	405-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BCH000446	Charger	405-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BCH000446	Charger	405-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.3	amps
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BCH000446	Charger	405-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	BCH000446	Charger	405-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	General Comments		
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	-1	psi
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	S0050	NonLTC	405-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	FE000195	Fence	571-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Vegetation	None	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	General Comments		
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	YD000192	Yard	405-Yard	Yard Patrol Inspection	Ambient Temp	76	*F
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	General Comments		
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/2/2020 9:03	Distribution	Central City South Quarterly Inspection	FE000194	Fence	405-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	BCH000452	Charger	571-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	BCH000452	Charger	571-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	BCH000452	Charger	571-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	BCH000452	Charger	571-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	55.0	VDC
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	BCH000452	Charger	571-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	55.0	VDC
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Unknown Operations	0	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Switching Operations	0	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Operations This Read Vac	21	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Operations Counter AL	209	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Operations Counter AF	209	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	Maintenance Operations	21	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Grounds in Place?	y	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Readings	General Comments	off line	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	General Comments		
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	WB0162	BreakerVacuum	100-1676	VCB Patrol Inspection	Foundation Condition	Good	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Unknown Operations	0	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	General Comments		
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Switching Operations	0	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Operations This Read Vac	0	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Operations Counter AL	174	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Operations Counter AF	174	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Maintenance Operations	0	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Grounds in Place?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	General Comments		
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	General Comments		
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Foundation Condition	Good	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Follow-up Action Required?	n	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Fault Operations Ground	0	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Fault Operations C ∅	0	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Fault Operations B ∅	0	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Fault Operations A ∅	0	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	LTCC000675	LTCControl	843-1	LTC Control Insp	VRR Time Delay	50	Seconds
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	LTCC000675	LTCControl	843-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	LTCC000675	LTCControl	843-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	LTCC000675	LTCControl	843-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	LTCC000675	LTCControl	843-1	LTC Control Insp	LTC Operation Checked?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	LTCC000675	LTCControl	843-1	LTC Control Insp	General Comments		
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	LTCC000675	LTCControl	843-1	LTC Control Insp	Follow-up Action Required?	n	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	LTCC000675	LTCControl	843-1	LTC Control Insp	All Connections OK?	y	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Patrol Inspection	Bushing Condition	Good	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Amps C ∅	189.0	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Amps B ∅	154.0	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Amps A ∅	192.0	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BK001267	BreakerVacuum	721-0210	VCB Readings	9 Month Operations	1	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	C ∅ Operations Counter	120	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	171	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Amps C Ø	32.8	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Amps B Ø	39.8	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	Amps A Ø	29.5	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 11:49	Distribution	Echols Quarterly Inspection	WX0515	RecloserHydraulic	479-1903	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	156	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	Follow-up Action Required?	n	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	General Comments	ok	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Mechanism Patrol Inspection	General Comments	ok	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	LTC As Found Counter	7416	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	LTC As Left Counter	7427	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	LTC Current Tap Position	1R	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	LTC Max Tap Position	3R	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	LTC Min Tap Position	7L	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	LTC Operations Since Last Insp	762	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	W0357	LTCMechanism	497-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	General Comments		
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	ST000581	Structure	SV-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	FE000575	Fence	SV-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	General Comments		
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Vegetation	None	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	2.1	amps
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	134.3	VDC
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	134.3	VDC
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.100	millivolts
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	General Comments		
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Vegetation	None	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	SPR "System Normal" Light Lit	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	General Comments		
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	YD000196	Yard	571-Yard	Yard Patrol Inspection	Ambient Temp	76	*F
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	ST000201	Structure	797-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0168	WithLTC	SV-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Fault Operations A Ø	0	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Fault Adjusted Amps B Phase V	10.13	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Patrol Inspection	Bushing Condition	Good	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Amps C Ø	28.0	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Amps B Ø	30.0	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Amps A Ø	27.0	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0095	BreakerVacuum	223-0948	VCB Readings	9 Month Operations	6	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	ST000203	Structure	571-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	BCH000035	Charger	CS-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	General Comments		
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	FE000368	Fence	416-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Ambient Temp	75	*F
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/2/2020 15:32	Distribution	Parker Seal Quarterly Inspection	YD000374	Yard	416-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	9 Month Operations	1	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps C Ø	100.0	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps B Ø	90.0	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Amps A Ø	120.0	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	9 Month Operations	2	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Fault Operations A Ø	0	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Bushing Condition	Good	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Amps C Ø	19.0	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Amps B Ø	13.0	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Amps A Ø	33.0	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	9 Month Operations	4	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Amps A Ø	100.0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Amps B Ø	100.0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Amps C Ø	100.0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Fault Operations	4	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Follow-up Action Required?	n	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Patrol Inspection	General Comments		
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	General Comments		
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Maintenance Operations	0	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Num Operations Last 9 Months	4	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Operations Counter AF	258	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Operations Counter AL	258	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Operations This Read SF6	4	
9/2/2020 13:25	Distribution	Aiken Quarterly Inspection	LB0004	BreakerSF6	AK-1293	GCB Readings	Switching Operations	0	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Y3 Winding Temp Present	0	°C
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Y3 Winding Temp Max	0	°C
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Y2 Winding Temp Present	0	°C
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Y2 Winding Temp Max	0	°C
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Y1 Winding Temp Present	0	°C
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Y1 Winding Temp Max	0	°C
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	X3 Winding Temp Present	0	°C
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	X3 Winding Temp Max	0	°C
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	X2 Winding Temp Present	0	°C
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	X2 Winding Temp Max	0	°C
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Maintenance Operations	1	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	General Comments		
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Unknown Operations	0	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Switching Operations	0	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Operations This Read Vac	0	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Operations Counter AL	181	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Operations Counter AF	181	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Maintenance Operations	0	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Grounds in Place?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	General Comments		
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	General Comments		
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Foundation Condition	Good	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Follow-up Action Required?	n	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Fault Operations Ground	0	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Fault Operations C Ø	0	%
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Fault Operations B Ø	0	%
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Fault Operations A Ø	0	%
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Patrol Inspection	Bushing Condition	Good	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Amps C Ø	26.0	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Amps B Ø	30.0	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Amps A Ø	26.0	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000495	BreakerVacuum	843-0216	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Conservator Tank Desiccant	Good	check oil cup
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	9 Month Operations	6	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Amps A Ø	20.0	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Amps B Ø	20.0	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Amps C Ø	20.0	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Bushing Condition	Good	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Fault Operations A Ø	0	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Fault Operations B Ø	0	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Fault Operations C Ø	0	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Fault Operations Ground	0	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	LTCC000853	LTCControl	084-5	LTC Control Insp	VRR Time Delay	30	Seconds
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	LTCC000853	LTCControl	084-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	LTCC000853	LTCControl	084-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	LTCC000853	LTCControl	084-5	LTC Control Insp	LTC Output Voltage Level	124.0	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	LTCC000853	LTCControl	084-5	LTC Control Insp	LTC Operation Checked?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	LTCC000853	LTCControl	084-5	LTC Control Insp	General Comments		
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	LTCC000853	LTCControl	084-5	LTC Control Insp	Follow-up Action Required?	n	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	LTCC000853	LTCControl	084-5	LTC Control Insp	All Connections OK?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Follow-up Action Required?	n	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Foundation Condition	Good	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	General Comments		
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	General Comments		
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Grounds in Place?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Maintenance Operations	1	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Operations Counter AF	220	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Operations Counter AL	220	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Operations This Read Vac	1	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Switching Operations	0	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 8:38	Distribution	Central City Quarterly Inspection	K0160	BreakerVacuum	571-1646	VCB Readings	Unknown Operations	0	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	X1 Winding Temp Present	0	°C
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	X1 Winding Temp Max	0	°C
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Winding Temp Present	40	°C
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Winding Temp Max	50	°C
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	TV Winding Temp Present	0	°C
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	TV Winding Temp Max	0	°C
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Totalizer Meter Reading	.6066	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Top Oil Temperature Present	0	°C
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Top Oil Temperature Max	0	°C
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Surge Arrester Counter C Ø	0	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Surge Arrester Counter B Ø	0	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Surge Arrester Counter A Ø	0	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Pumps Operational?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Pumps Condition	Good	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Percent Thermal Load C Ø Max	0	%
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Percent Thermal Load B Ø Max	0	%
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Percent Thermal Load A Ø Max	0	%
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Oil Temp Present	0	°C
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Oil Temp Max	5040	°C
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	1455.84	kw
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	0	psi
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	LV Winding Temp Present	0	°C
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	LV Winding Temp Max	0	°C
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	HV Winding Temp Present	0	°C
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	HV Winding Temp Max	0	°C
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	H3 Winding Temp Present	0	°C
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	H3 Winding Temp Max	0	°C
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	H2 Winding Temp Present	0	°C
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	H2 Winding Temp Max	0	°C
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	H1 Winding Temp Present	0	°C
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	H1 Winding Temp Max	0	°C
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	General Comments		
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	General Comments		
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Gas Accumulation Gauge	Normal	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	TX000253	NonLTC	468-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Bushing Condition	Good	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Amps C Ø	16.0	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Amps B Ø	19.0	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Amps A Ø	16.0	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Min Tap Position	9L	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Max Tap Position	7R	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	General Comments		
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Current Tap Position	3R	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	9 Month Operations	0	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Unknown Operations	0	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Switching Operations	0	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Operations This Read Vac	2	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Operations Counter AL	208	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Operations Counter AF	208	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Maintenance Operations	2	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Grounds in Place?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	General Comments		
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LTCC000482	LTCControl	SV-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LTCC000482	LTCControl	SV-TRANS 1	LTC Control Insp	General Comments		
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LTCC000482	LTCControl	SV-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	General Comments		
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Foundation Condition	Good	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Follow-up Action Required?	n	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Fault Operations Ground	0	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Fault Operations C Ø	0	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Fault Operations B Ø	0	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Fault Operations A Ø	0	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Mechanism Patrol Inspection	MFD Breather green light	OK	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	LTCM000007	LTCMechanism	223-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	LTCC000008	LTCControl	223-5	LTC Control Insp	All Connections OK?	y	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	LTCC000008	LTCControl	223-5	LTC Control Insp	Follow-up Action Required?	n	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	LTCC000008	LTCControl	223-5	LTC Control Insp	General Comments		
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	LTCC000008	LTCControl	223-5	LTC Control Insp	LTC Operation Checked?	y	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	LTCC000008	LTCControl	223-5	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	LTCC000008	LTCControl	223-5	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	LTCC000008	LTCControl	223-5	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	LTCC000008	LTCControl	223-5	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	LTCC000008	LTCControl	223-5	LTC Control Insp	VRR Time Delay	30	Seconds
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Unknown Operations	0	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Switching Operations	0	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Operations This Read Vac	0	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Operations Counter AL	189	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Operations Counter AF	189	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Maintenance Operations	0	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	General Comments		
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	General Comments		
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Foundation Condition	Good	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Follow-up Action Required?	n	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	General Comments		
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Current Tap Position	3R	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1410	Regulator	866-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Tank Leaks	None	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Regulator As Left Counter	50303	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	R1408	Regulator	866-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Fault Operations Ground	0	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Fault Operations C Ø	0	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Fault Operations B Ø	0	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Fault Operations A Ø	0	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001325	BreakerVacuum	468-308	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Fault Operations C Ø	0	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Fault Operations B Ø	0	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Switching Operations	0	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Operations This Read Vac	0	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Operations Counter AL	183	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Operations Counter AF	183	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Maintenance Operations	0	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Grounds in Place?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	General Comments		
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	General Comments		
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Foundation Condition	Good	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Follow-up Action Required?	n	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Fault Operations Ground	0	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Fault Operations C Ø	0	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Fault Operations B Ø	0	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Fault Operations A Ø	0	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Patrol Inspection	Bushing Condition	Good	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Amps C Ø	194.0	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Amps B Ø	174.0	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Amps A Ø	150.0	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	9 Month Operations	1	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Unknown Operations	0	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Switching Operations	0	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations This Read Vac	1	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations Counter AL	221	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	K0093	BreakerVacuum	912-Offline-Distribution	VCB Readings	Operations Counter AF	221	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	85	*F
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	14.3	VDC
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	8.2	VDC
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	BAT001146	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Patrol Inspection	Bushing Condition	Good	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Amps C Ø	20.0	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Amps B Ø	39.0	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Amps A Ø	15.0	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001324	BreakerVacuum	468-1671	VCB Readings	9 Month Operations	11	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LTCC000577	LTCControl	SV-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LTCC000577	LTCControl	SV-TRANS 2	LTC Control Insp	General Comments		
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LTCC000577	LTCControl	SV-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/2/2020 14:17	Distribution	Fariston Quarterly Inspection	BK000496	BreakerVacuum	843-0217	VCB Readings	Unknown Operations	0	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	BCH000851	Charger	100-Battery Charger 2	Battery Charger Patrol Insp	As Found Float Voltage	56.0	VDC
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	BCH000851	Charger	100-Battery Charger 2	Battery Charger Patrol Insp	As Left Float Voltage	56.0	VDC
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	BCH000851	Charger	100-Battery Charger 2	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/2/2020 10:29	Distribution	Green River Steel Quarterly Inspection	BCH000851	Charger	100-Battery Charger 2	Battery Charger Patrol Insp	General Comments		
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	General Comments		
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	FE000383	Fence	084-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Unknown Operations	0	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Switching Operations	0	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Operations This Read Vac	2	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Operations Counter AL	179	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Operations Counter AF	179	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Maintenance Operations	2	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Grounds in Place?	y	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	General Comments		
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	General Comments		
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Foundation Condition	Good	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Follow-up Action Required?	n	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 12:03	Distribution	Beech Creek Quarterly Inspection	BK001323	BreakerVacuum	468-1668	VCB Readings	Fault Operations Ground	0	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Amps A Ø	76.0	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Amps B Ø	77.0	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Amps C Ø	78.0	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Bushing Condition	Good	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Fault Operations A Ø	0	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Fault Operations B Ø	0	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Fault Operations C Ø	0	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Fault Operations Ground	0	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Follow-up Action Required?	n	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Foundation Condition	Good	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	General Comments		
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	General Comments		
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Grounds in Place?	y	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Maintenance Operations	0	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Operations Counter AF	223	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Operations Counter AL	225	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Operations This Read Vac	2	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Switching Operations	2	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	Unknown Operations	0	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	General Comments		
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	ST000391	Structure	084-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BCH001284	Charger	721-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	2.400	millivolts
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BCH001284	Charger	721-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.5	VDC
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BCH001284	Charger	721-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.5	VDC
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BCH001284	Charger	721-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.9	amps
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	265.00	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	65	°C
9/2/2020 9:33	Distribution	Shepherdsville Quarterly Inspection	LT0169	WithLTC	SV-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	45	°C
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	General Comments		
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	85	*F
9/2/2020 9:38	Distribution	Sharon Quarterly Inspection	BAT001452	Battery	084-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	General Comments	ok	
9/2/2020 14:35	Distribution	Muhlenberg Prison Quarterly Inspection	FE000227	Fence	497-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	BCH000458	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	56.0	VDC
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	BCH000458	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/2/2020 15:34	Distribution	Calhoun Quarterly Inspection	BCH000458	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	BCH000462	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	As Found Float Voltage	54.8	VDC
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	BCH000462	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	As Left Float Voltage	54.8	VDC
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	BCH000462	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	Battery Charger Current	.3	amps
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	BCH000462	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LTCC000522	LTCControl	CS-TRANS 1	LTC Control Insp	General Comments		
9/2/2020 13:44	Distribution	Conestoga Quarterly Inspection	LTCC000522	LTCControl	CS-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
9/2/2020 12:26	Distribution	Beechmont Quarterly Inspection	BCH000462	Charger	912-Offline-Distribution	Battery Charger Patrol Insp	General Comments		
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Ambient Temperature	85	*F
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Bushings Connection/Risers	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Heaters Functioning?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Cabinet Internal Condition?	Clean	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Foundation Condition	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	General Comments		
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Grounds in Place?	y	
9/2/2020 9:31	Distribution	Carntown Quarterly Inspection	KB0094	BreakerVacuum	223-0946	VCB Readings	9 Month Operations	4	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Moisture and Leak Free?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	85	*F
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	BAT000425	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BCH001284	Charger	721-Battery Charger	Battery Charger Patrol Insp	General Comments		
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BCH001284	Charger	721-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Bushing Condition	Good	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	SF6 Indicator Zone	OK	
9/2/2020 9:15	Distribution	Augusta Quarterly Inspection	KB0132	CircuitSwitcher	773-1 Trans-Rupter	Circuit Switcher Patrol Inspection	Trip-energy Supply Verified	y	LED lights?
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BCH001284	Charger	721-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
9/2/2020 13:36	Distribution	Caron Quarterly Inspection	BCH001284	Charger	721-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	82	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	82	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	4	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	35.0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	77.0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	84.0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LB0648	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Fault Operations A Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Fault Operations B Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Fault Operations C Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Fault Operations Ground	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Operations This Read Vac	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Operations Counter AL	27	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0331	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Operations Counter AF	27	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Maintenance Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Unknown Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Switching Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Operations This Read Vac	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AL	74	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AF	74	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Amps C Ø	66.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	LTC Current Tap Position	4L	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	LTC As Left Counter	115992	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	LTC As Found Counter	115991	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	General Comments		
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	9 Month Operations	9	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	409.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	427.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	454.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Evidence of Insects	None	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0348	BreakerVacuum	FV-1475	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	9 Month Operations	13	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Unknown Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Switching Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Fault Operations Ground	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Fault Operations C Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Fault Operations B Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Fault Operations A Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	9	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	9	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0341	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Amps C Ø	508.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Amps B Ø	536.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Amps A Ø	543.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001503	BreakerVacuum	FV-12KV TR 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Patrol Inspection	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Patrol Inspection	Heaters (All) Functioning?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001469	BreakerVacuum	FV-1137	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	884	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	LTC Min Tap Position	7L	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LT0118	LTCMechanism	MK-TRANS 1	LTC Counter Readings	LTC Max Tap Position	2R	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LTCC000607	LTCControl	FV-TRANS 8	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LTCC000607	LTCControl	FV-TRANS 8	LTC Control Insp	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Unknown Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LTCC000607	LTCControl	FV-TRANS 8	LTC Control Insp	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Operations Counter AL	301	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Operations Counter AF	301	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Maintenance Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	LV Winding Temp Max	55	°C
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	General Comments	none	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	General Comments	Heaters not working	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Tank Leaks	None	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Radiator Leaks	None	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Maintenance Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Operations This Read Vac	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Spring Compression Ind.	springcharged	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Switching Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Fault Operations A Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Fault Operations B Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Fault Operations C Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Fault Operations Ground	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Amps A Ø	68.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	9 Month Operations	4	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	SWG000031	Switchgear	FV-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0334	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0347	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Amps B Ø	64.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	LTC Current Tap Position	8L	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	LTC Max Tap Position	1L	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1200	psi
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	Oil Temp Max	53	°C
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0346	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Readings	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001479	BreakerVacuum	FV-1472	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Evidence of Insects	None	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Broom on Site?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Amps C Ø	0.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Amps B Ø	0.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001504	BreakerVacuum	FV-12KV BUS TIE SEC 3	VCB Readings	Amps A Ø	0.0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Grounds in Place?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Foundation Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001470	BreakerVacuum	FV-1135	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	SWG000113	Switchgear	MK-Swgr Sec 1	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0227	GroundTransformer	FV-GND TR 8	Ground Transformer Patrol Inspection	Bushing Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0344	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001467	BreakerVacuum	FV-1134	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001468	BreakerVacuum	FV-1138	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Trash Emptied?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Station Ground Set On Site?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Panels Dusted?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Readings	LV Winding Temp Present	40	°C
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0073	WithLTC	FV-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Floor Swept?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	CH000205	ControlHouse	MK-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Mechanism Patrol Inspection	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	LTC As Found Counter	187717	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0077	LTCMechanism	FV-TRANS 4	LTC Counter Readings	LTC As Left Counter	187717	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Maintenance Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Patrol Inspection	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Fault Operations Ground	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Fault Operations C Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Fault Operations B Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Fault Operations A Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Amps C Ø	0.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Amps B Ø	0.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Amps A Ø	0.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	9 Month Operations	13	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Bushing Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Foundation Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Grounds in Place?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Radiator Leaks	None	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	General Comments		
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1750	psi
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	Oil Temp Max	54	°C
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	Oil Temp Present	41	°C
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	41	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	41	°C
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	41	°C
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	41	°C
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	42	°C
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	TX000034	WithLTC	MK-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	41	°C
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Tank Leaks	None	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Tank Oil Level	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Tank Paint Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0253	GroundTransformer	FV-GND TR 1	Ground Transformer Patrol Inspection	Winding Temp Max	45	°C
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	General Comments		
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	LTC As Found Counter	11203	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	LTC As Left Counter	11203	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	LTC Current Tap Position	3L	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	LTC Max Tap Position	3R	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	LTC Min Tap Position	5L	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	54	°C
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	41	°C
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Grounds in Place?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	General Comments		
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Evidence of Insects	None	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	General Comments		
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Panels Dusted?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	SWG000211	Switchgear	MK-Swgr Sec 2	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Foundation Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Bushing Condition	Good	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Water Spigots OK?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Vegetation	None	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Trench Covers in Place	Good	Need size info and qty
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0351	BreakerVacuum	FV-1478	VCB Patrol Inspection	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Patrol Inspection	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0349	BreakerVacuum	FV-1476	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	General Comments		
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Clear of Trash?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	YD000577	Yard	MK-Yard	Yard Patrol Inspection	Ambient Temp	78	*F
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Whips Correctly Engaged?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	General Comments		
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Foundation Condition	Good	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	ST000577	Structure	MK-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Unknown Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Switching Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Operations This Read Vac	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Operations Counter AL	155	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0352	BreakerVacuum	FV-1479	VCB Readings	Operations Counter AF	155	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	LTC As Left Counter	265737	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	LTC Current Tap Position	10L	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	LTC Max Tap Position	13L	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	LTC Min Tap Position	9L	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	301	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0073	LTCMechanism	FV-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Mechanism Patrol Inspection	General Comments	Desiccant needs to be replaced	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	LTC As Found Counter	47290	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	LTC As Left Counter	47290	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	PF001201	PowerFuse	MK-STA SER NO 2	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	PF001201	PowerFuse	MK-STA SER NO 2	Disconnect Powerfuse Inspection	General Comments	ok	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	PF001202	PowerFuse	MK-12KV TR 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	PF001202	PowerFuse	MK-12KV TR 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	LTC Current Tap Position	8L	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	LTC Max Tap Position	1L	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	LTC Min Tap Position	15L	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	LTC Operations Since Last Insp	825	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Needs Replaced	check oil cup
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0074	LTCMechanism	FV-TRANS 3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Mechanism Patrol Inspection	General Comments	LEAK IN LTC FILTER CABINET	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	LTC As Found Counter	16530	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	LTC As Left Counter	16530	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	9 Month Operations	6	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Amps A Ø	0.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Amps B Ø	0.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	LTC Current Tap Position	9L	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	LTC Max Tap Position	Neutral	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	LTC Min Tap Position	9L	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	1072	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0075	LTCMechanism	FV-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Amps C Ø	0.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Fault Operations A Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Fault Operations B Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Fault Operations C Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Fault Operations Ground	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Patrol Inspection	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Mechanism Patrol Inspection	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	LTC As Found Counter	70942	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	LTC As Left Counter	70942	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	LTC Current Tap Position	4L	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	LTC Max Tap Position	Neutral	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	LTC Min Tap Position	8L	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	LTC Operations Since Last Insp	761	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0076	LTCMechanism	FV-TRANS 8	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	998	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0357	BreakerVacuum	FV-14KV TR 8	VCB Patrol Inspection	General Comments		
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	General Comments		
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	FE000568	Fence	MK-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Evidence of Insects	None	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LTCM000018	LTCMechanism	MK-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Panels Dusted?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	SWG000112	Switchgear	FV-Swgr Sec 8	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LTCC000622	LTCControl	MK-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LTCC000622	LTCControl	MK-TRANS 2	LTC Control Insp	General Comments		
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LTCC000622	LTCControl	MK-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	paralleIPAR	Position
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LTCC000578	LTCControl	FV-TRANS 4	LTC Control Insp	All Connections OK?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LTCC000578	LTCControl	FV-TRANS 4	LTC Control Insp	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LTCC000578	LTCControl	FV-TRANS 4	LTC Control Insp	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LTCC000578	LTCControl	FV-TRANS 4	LTC Control Insp	Parallel / Ind. Sw Position	paralleIPAR	Position
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0336	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	General Comments		
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Follow-up Action Required?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Fault Operations Ground	0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Fault Operations C Ø	0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Fault Operations B Ø	0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Switching Operations	0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Unknown Operations	0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Fault Operations A Ø	0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	Oil Temp Max	65	°C
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	Oil Temp Present	48	°C
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	X1 Winding Temp Max	70	°C
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	X1 Winding Temp Present	50	°C
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	X2 Winding Temp Max	75	°C
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	X2 Winding Temp Present	50	°C
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	9 Month Operations	1	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Amps A Ø	463.0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Amps B Ø	425.0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Amps C Ø	381.0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Fault Operations A Ø	0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Fault Operations B Ø	0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Fault Operations C Ø	0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Fault Operations Ground	0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Follow-up Action Required?	n	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	General Comments		
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	General Comments		
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Maintenance Operations	0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Operations Counter AF	85	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Operations Counter AL	85	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Operations This Read Vac	0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Switching Operations	0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000742	BreakerVacuum	MK-12KV TR 2	VCB Readings	Unknown Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0338	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	9 Month Operations	1	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Amps A Ø	51.0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Amps B Ø	64.0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Readings	Amps C Ø	33.0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000743	BreakerVacuum	MK-1290	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	700	psi
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0332	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	General Comments	Needs desiccant filters changed out	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Follow-up Action Required?	n	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations A Ø	0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations B Ø	0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations C Ø	0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Fault Operations Ground	0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Follow-up Action Required?	n	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	General Comments		
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	General Comments		
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Maintenance Operations	0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AF	99	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Operations Counter AL	99	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Operations This Read Vac	1	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Switching Operations	1	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Unknown Operations	0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Fault Operations Ground	0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Fault Operations C Ø	0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Fault Operations B Ø	0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Fault Operations A Ø	0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Amps C Ø	132.0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Amps B Ø	163.0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Amps A Ø	129.0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000739	BreakerVacuum	MK-1293	VCB Readings	9 Month Operations	0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Switching Operations	0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Operations This Read Vac	0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Operations Counter AL	85	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Operations Counter AF	85	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Maintenance Operations	0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	General Comments		
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Follow-up Action Required?	n	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Fault Operations Ground	0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Fault Operations C Ø	0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Fault Operations B Ø	0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Fault Operations A Ø	0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Amps C Ø	30.0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Amps B Ø	16.0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Amps A Ø	52.0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000738	BreakerVacuum	MK-1294	VCB Readings	9 Month Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Tank Oil Level	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Tank Leaks	None	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB1290	BreakerOil	FV-GND TR 1	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	X3 Winding Temp Max	70	°C
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0077	WithLTC	FV-TRANS 4	LTC Transformer Readings	X3 Winding Temp Present	50	°C
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Amps C Ø	37.0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Amps B Ø	0.0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Amps A Ø	37.0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000741	BreakerVacuum	MK-1291	VCB Readings	9 Month Operations	2	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0350	BreakerVacuum	FV-1477	VCB Patrol Inspection	General Comments		
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Unknown Operations	0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Switching Operations	0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Operations This Read Vac	0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Operations Counter AL	70	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Operations Counter AF	70	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Maintenance Operations	0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	General Comments		
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	General Comments		
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	9 Month Operations	2	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000744	BreakerVacuum	MK-12KV BUS TIE SEC 2	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Follow-up Action Required?	n	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Fault Operations Ground	0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Fault Operations C Ø	0	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	BK000740	BreakerVacuum	MK-1292	VCB Readings	Fault Operations B Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	Oil Temp Max	70	°C
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	Oil Temp Present	55	°C
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001359	BreakerVacuum	FV-1140	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	85	°C
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	60	°C
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	PF000229	PowerFuse	MK-12KV TR 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	PF000229	PowerFuse	MK-12KV TR 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	PF000228	PowerFuse	MK-STA SER NO 1	Disconnect Powerfuse Inspection	General Comments	ok	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	PF000228	PowerFuse	MK-STA SER NO 1	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Tank Bleed (> 40°F)?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Pressure OK?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Leaks	None	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Air Compressor Belt Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	9 Month Operations	1	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Amps A Ø	0.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Amps B Ø	0.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Amps C Ø	0.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Fault Operations A Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Fault Operations B Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Fault Operations C Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Fault Operations Ground	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Maintenance Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Operations Counter AF	138	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Operations Counter AL	138	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Operations This Read Vac	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Switching Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001357	BreakerVacuum	FV-1136	VCB Readings	Unknown Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Door Alarms OK?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Amps A Ø	379.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Amps B Ø	380.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Amps C Ø	381.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Fault Operations A Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Fault Operations B Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Fault Operations C Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Fault Operations Ground	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Maintenance Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Operations Counter AF	298	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Operations Counter AL	298	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Operations This Read Vac	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Switching Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Unknown Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	Oil Temp Max	50	°C
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	Oil Temp Present	45	°C
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Pumps Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Pumps Operational?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	Top Oil Temperature Max	50	°C
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	X3 Winding Temp Present	45	°C
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	X3 Winding Temp Max	80	°C
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	X2 Winding Temp Present	45	°C
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	X2 Winding Temp Max	130	°C
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	X1 Winding Temp Present	45	°C
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	X1 Winding Temp Max	70	°C
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	40.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	45	°C
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	30	°C
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	55	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	45	°C
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	65	°C
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0075	WithLTC	FV-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	50	°C
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Readings	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0076	WithLTC	FV-TRANS 8	LTC Transformer Patrol Inspection	General Comments	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Bushing Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Foundation Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Grounds in Place?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Heaters (All) Functioning?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001360	BreakerVacuum	FV-1141	VCB Patrol Inspection	Tank Paint Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	9 Month Operations	8	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	BK001361	BreakerVacuum	FV-12KV TR 4	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Vent Fans OK?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Panels Dusted?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Panel Lights OK?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Evidence of Insects	None	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	SWG000110	Switchgear	FV-Swgr Sec 3 & 4	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Amps C Ø	0.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Amps B Ø	0.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Amps A Ø	0.0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	9 Month Operations	1	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	55	°C
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0335	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	65	°C
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	50	°C
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	60	°C
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	Oil Temp Present	55	°C
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	Oil Temp Max	55	°C
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	General Comments		
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	Oil Temp Max	120	°C
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0337	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Maintenance Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Operations Counter AF	185	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Operations Counter AL	185	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Operations This Read Vac	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Switching Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0353	BreakerVacuum	FV-GND TR 8	VCB Readings	Unknown Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Unknown Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Switching Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Operations This Read Vac	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LTCC000436	LTCControl	FV-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LTCC000436	LTCControl	FV-TRANS 1	LTC Control Insp	General Comments	ok	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Operations Counter AL	174	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Operations Counter AF	174	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0328	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Maintenance Operations	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Patrol Inspection	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Patrol Inspection	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Fault Operations Ground	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LTCC000437	LTCControl	FV-TRANS 3	LTC Control Insp	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LTCC000437	LTCControl	FV-TRANS 3	LTC Control Insp	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LTCC000437	LTCControl	FV-TRANS 3	LTC Control Insp	Parallel / Ind. Sw Position	paralleIPAR	Position
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LTCC000438	LTCControl	FV-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LTCC000438	LTCControl	FV-TRANS 2	LTC Control Insp	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LTCC000438	LTCControl	FV-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	paralleIIND	Position

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	55	°C
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LT0118	WithLTC	MK-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	65	°C
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Fans Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Fans Operational?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Fault Operations C Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Fault Operations B Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0354	BreakerVacuum	FV-14KV BUS TIE SEC 8	VCB Readings	Fault Operations A Ø	0	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	Oil Temp Present	55	°C
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LTCC000273	LTCControl	MK-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LTCC000273	LTCControl	MK-TRANS 1	LTC Control Insp	General Comments		
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Tank Leaks	None	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	285.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	80	°C
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	55	°C
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	80	°C
9/1/2020 11:20	Distribution	Manslick Quarterly Inspection	LTCC000273	LTCControl	MK-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LT0074	WithLTC	FV-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	55	°C
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Pressure Vessel Condition	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 1 Oil Level	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 2 Oil level	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank 3 Oil Level	Good	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
9/1/2020 12:30	Distribution	Fern Valley Quarterly Inspection	LB0356	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
7/1/2020 12:32	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
7/1/2020 12:32	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	X1 Winding Temp Max	67	°C
7/1/2020 12:32	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	X1 Winding Temp Present	56	°C
7/1/2020 12:32	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	X2 Winding Temp Max	67	°C
7/1/2020 12:32	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	X2 Winding Temp Present	56	°C
7/1/2020 12:32	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	X3 Winding Temp Max	67	°C
7/1/2020 12:32	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	X3 Winding Temp Present	56	°C
7/1/2020 12:32	Distribution	Breckenridge Quarterly Inspection	ANN000006	Annunciator	BR-Annunciator Panel 1	Annunciator Patrol Inspection	General Comments		
7/1/2020 12:32	Distribution	Breckenridge Quarterly Inspection	ANN000006	Annunciator	BR-Annunciator Panel 1	Annunciator Patrol Inspection	Follow-up Action Required?	n	
7/1/2020 12:32	Distribution	Breckenridge Quarterly Inspection	ANN000006	Annunciator	BR-Annunciator Panel 1	Annunciator Patrol Inspection	ESOC Received Alarm Test?	y	
7/1/2020 12:32	Distribution	Breckenridge Quarterly Inspection	ANN000006	Annunciator	BR-Annunciator Panel 1	Annunciator Patrol Inspection	Control House Alarm Audible?	y	
7/1/2020 12:32	Distribution	Breckenridge Quarterly Inspection	ANN000006	Annunciator	BR-Annunciator Panel 1	Annunciator Patrol Inspection	All Lights Functioning?	y	
7/1/2020 12:32	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	X3 Winding Temp Present	65	°C
7/1/2020 12:32	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	X3 Winding Temp Max	73	°C
7/1/2020 12:32	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	X2 Winding Temp Present	65	°C
7/1/2020 12:32	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	X2 Winding Temp Max	74	°C
7/1/2020 12:32	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	X1 Winding Temp Present	65	°C
7/1/2020 12:32	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	X1 Winding Temp Max	74	°C
7/1/2020 12:32	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
7/1/2020 12:32	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	WithLTC Trn Dynamic Health	30.00	
7/1/2020 12:32	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	Oil Temp Present	65	°C
7/1/2020 12:32	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	Oil Temp Max	74	°C
7/1/2020 12:32	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	General Comments		
7/1/2020 12:32	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	Follow-up Action Required?	n	
7/1/2020 12:32	Distribution	Breckenridge Quarterly Inspection	LT0024	WithLTC	BR-TRANS 5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
7/1/2020 12:32	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	Oil Temp Max	62	°C
7/1/2020 12:32	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	Oil Temp Present	55	°C
7/1/2020 12:32	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
7/1/2020 12:32	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
7/1/2020 12:32	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Readings	Oil Temp Present	50	°C
7/1/2020 12:32	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Readings	Oil Temp Max	50	°C
7/1/2020 12:32	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Readings	General Comments		
7/1/2020 12:32	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
7/1/2020 12:32	Distribution	Breckenridge Quarterly Inspection	LT0022	WithLTC	BR-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
7/1/2020 12:32	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	General Comments		
7/1/2020 12:32	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	n	
7/1/2020 12:32	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
7/1/2020 12:32	Distribution	Breckenridge Quarterly Inspection	LT0025	WithLTC	BR-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	40.00	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Switching Operations	1	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Tank Paint Condition	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Unknown Operations	0	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Cabinet Paint Condition	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Accumulated Fault Duty A Ph V	0	%
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	9 Month Operations	7	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Accumulated Fault Duty B Ph V	0	%
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	General Comments		
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	LTC Totalizer Reading	17524.8	kw
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	Top Oil Temperature Max	60	°C
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	Top Oil Temperature Present	35	°C
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Accumulated Fault Duty C Ph V	0	%
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Amps A Ø	100	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Amps B Ø	80	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Amps C Ø	100	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Fault Adjusted Amps A Phase V	0	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Fault Adjusted Amps B Phase V	0	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Fault Adjusted Amps C Phase V	0	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Fault Operations A Ø	0	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Fault Operations B Ø	0	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	Totalizer Meter Reading	1.217	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	Winding Temp Max	55	°C
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	Winding Temp Present	35	°C
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	20	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	KT0011	WithLTC	723-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Fault Operations C Ø	0	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Fault Operations Ground	0	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Operations This Read Vac	1	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Operations Counter AL	125	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Operations Counter AF	125	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Maintenance Operations	0	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Heaters (All) Functioning?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Grounds in Place?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	General Comments		
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	9 Month Operations	6	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Accumulated Fault Duty A Ph V	6.25	%
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Accumulated Fault Duty B Ph V	6.7	%
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Accumulated Fault Duty C Ph V	7.15	%
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Amps A Ø	128	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Amps B Ø	146	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Amps C Ø	136	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Fault Adjusted Amps A Phase V	0	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Fault Adjusted Amps B Phase V	0	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Fault Adjusted Amps C Phase V	0	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Fault Operations A Ø	0	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Fault Operations B Ø	0	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Fault Operations C Ø	0	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Fault Operations Ground	0	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Follow-up Action Required?	n	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	General Comments		
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Maintenance Operations	0	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Operations Counter AF	301	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Operations Counter AL	303	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Operations This Read Vac	2	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Switching Operations	2	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	KB0032	BreakerVacuum	723-0440	VCB Readings	Unknown Operations	0	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	General Comments		
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Foundation Condition	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Readings	Follow-up Action Required?	n	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	K0023	BreakerVacuum	221-122	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Grounds in Place?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Readings	General Comments		
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	Foundation Condition	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0422	BreakerVacuum	221-108	VCB Patrol Inspection	General Comments		
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Maintenance Operations	0	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	General Comments		
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	K0043	BreakerVacuum	723-0443	VCB Readings	Follow-up Action Required?	n	
8/14/2020 13:49	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Accumulated Fault Duty A Ph V	2.23	%
8/14/2020 13:49	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Accumulated Fault Duty B Ph V	2.68	%
8/14/2020 13:49	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Accumulated Fault Duty C Ph V	3.13	%
8/14/2020 13:49	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Amps A Ø	120	
8/14/2020 13:49	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Amps B Ø	120	
8/14/2020 13:49	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Amps C Ø	120	
8/14/2020 13:49	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Fault Adjusted Amps A Phase V	0	
8/14/2020 13:49	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Fault Adjusted Amps B Phase V	0	
8/14/2020 13:49	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Fault Adjusted Amps C Phase V	0	
8/14/2020 13:49	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Fault Operations A Ø	0	
8/14/2020 13:49	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Fault Operations B Ø	0	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Unknown Operations	0	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Tank Paint Condition	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Switching Operations	1	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Operations This Read Vac	1	
8/14/2020 13:49	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Fault Operations C Ø	0	
8/14/2020 13:49	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Fault Operations Ground	0	
8/14/2020 13:49	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Follow-up Action Required?	n	
8/14/2020 13:49	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	General Comments		
8/14/2020 13:49	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Maintenance Operations	0	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Operations Counter AL	99872	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Operations Counter AF	99872	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Maintenance Operations	0	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Heaters (All) Functioning?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Grounds in Place?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	General Comments		
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	General Comments		
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Foundation Condition	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Follow-up Action Required?	n	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Follow-up Action Required?	n	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Fault Operations Ground	0	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Fault Operations C Ø	0	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Fault Operations B Ø	0	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Fault Operations A Ø	0	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/14/2020 13:49	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Operations Counter AF	349	
8/14/2020 13:49	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Operations Counter AL	349	
8/14/2020 13:49	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Operations This Read Vac	3	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	Totalizer Meter Multiplier	15240	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	Totalizer Meter Reading	.9704	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	Winding Temp Max	60	°C
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	Winding Temp Present	55	°C
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	55.00	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	Winding Temp Present	40	°C
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	Winding Temp Max	40	°C
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	Totalizer Meter Reading	.6260	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	Totalizer Meter Multiplier	15240	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	Oil Temp Present	45	°C
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	Oil Temp Max	55	°C
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	LTC Totalizer Reading	9540.24	kw
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	General Comments		
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	Follow-up Action Required?	n	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Accumulated Fault Duty A Ph V	2.23	%
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Accumulated Fault Duty B Ph V	2.68	%
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Accumulated Fault Duty C Ph V	3.13	%
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Amps A Ø	100	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Amps B Ø	100	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Amps C Ø	100	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Fault Adjusted Amps A Phase V	0	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Fault Adjusted Amps B Phase V	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Fault Adjusted Amps C Phase V	0	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Fault Operations A Ø	0	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Fault Operations B Ø	0	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Fault Operations C Ø	0	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Fault Operations Ground	0	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Follow-up Action Required?	n	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	General Comments		
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Maintenance Operations	0	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Operations Counter AF	341	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Operations Counter AL	345	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Operations This Read Vac	4	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Switching Operations	4	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Unknown Operations	0	
8/14/2020 13:49	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	9 Month Operations	8	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	9 Month Operations	1	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	Winding Temp Present	45	°C
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	Winding Temp Max	45	°C
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	Totalizer Meter Reading	.6126	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	Totalizer Meter Multiplier	15240	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Pumps Operational?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Pumps Condition	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	Oil Temp Present	45	°C
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	Oil Temp Max	45	°C
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	LTC Totalizer Reading	9336.02	kw
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	General Comments		
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	General Comments		
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0456	WithLTC	221-3	LTC Transformer Readings	Follow-up Action Required?	n	
8/14/2020 13:49	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Switching Operations	3	
8/14/2020 13:49	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	Unknown Operations	0	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Cabinet Paint Condition	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Bushings Connection/Risers	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Patrol Inspection	Bushing Condition	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	LTCC000860	LTCControl	221-1	LTC Control Insp	All Connections OK?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	LTCC000860	LTCControl	221-1	LTC Control Insp	Follow-up Action Required?	n	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	LTCC000860	LTCControl	221-1	LTC Control Insp	General Comments		
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	LTCC000860	LTCControl	221-1	LTC Control Insp	LTC Operation Checked?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	LTCC000860	LTCControl	221-1	LTC Control Insp	LTC Output Voltage Level	120.0	VAC
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	LTCC000860	LTCControl	221-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	LTCC000860	LTCControl	221-1	LTC Control Insp	VRR Base Voltage AF	120.0	VAC
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	LTCC000860	LTCControl	221-1	LTC Control Insp	VRR Base Voltage AL	120.0	VAC
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	LTCC000860	LTCControl	221-1	LTC Control Insp	VRR Time Delay	30	Seconds
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	LTCC000861	LTCControl	221-2	LTC Control Insp	All Connections OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	LTCC000861	LTCControl	221-2	LTC Control Insp	Follow-up Action Required?	n	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	LTCC000861	LTCControl	221-2	LTC Control Insp	General Comments		
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	LTCC000861	LTCControl	221-2	LTC Control Insp	LTC Operation Checked?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	LTCC000861	LTCControl	221-2	LTC Control Insp	LTC Output Voltage Level	119.0	VAC
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	LTCC000861	LTCControl	221-2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	LTCC000861	LTCControl	221-2	LTC Control Insp	VRR Base Voltage AF	120.0	VAC
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	LTCC000861	LTCControl	221-2	LTC Control Insp	VRR Base Voltage AL	120.0	VAC
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	LTCC000861	LTCControl	221-2	LTC Control Insp	VRR Time Delay	30	Seconds
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	LTCC000862	LTCControl	221-3	LTC Control Insp	All Connections OK?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	LTCC000862	LTCControl	221-3	LTC Control Insp	Follow-up Action Required?	n	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	LTCC000862	LTCControl	221-3	LTC Control Insp	General Comments		
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	LTCC000862	LTCControl	221-3	LTC Control Insp	LTC Operation Checked?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	LTCC000862	LTCControl	221-3	LTC Control Insp	LTC Output Voltage Level	119.0	VAC
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	LTCC000862	LTCControl	221-3	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	LTCC000862	LTCControl	221-3	LTC Control Insp	VRR Base Voltage AF	120.0	VAC
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	LTCC000862	LTCControl	221-3	LTC Control Insp	VRR Base Voltage AL	120.0	VAC
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	LTCC000862	LTCControl	221-3	LTC Control Insp	VRR Time Delay	30	Seconds
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Amps C Ø	0.0	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Amps B Ø	0.0	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Amps A Ø	0.0	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0420	BreakerVacuum	221-102	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Amps A Ø	400.0	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Amps B Ø	400.0	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Amps C Ø	400.0	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Bushing Condition	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Bushings Connection/Risers	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Cabinet Paint Condition	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Fault Operations A Ø	0	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Fault Operations B Ø	0	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Fault Operations C Ø	0	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Fault Operations Ground	0	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Follow-up Action Required?	n	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Follow-up Action Required?	n	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Foundation Condition	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	General Comments		
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	General Comments		
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Grounds in Place?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Heaters (All) Functioning?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Maintenance Operations	0	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Operations Counter AF	107	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Operations Counter AL	1070	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Operations This Read Vac	1	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Switching Operations	1	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Patrol Inspection	Tank Paint Condition	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Unknown Operations	0	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	9 Month Operations	4	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Accumulated Fault Duty A Ph V	1.37	%
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Accumulated Fault Duty B Ph V	0	%
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Accumulated Fault Duty C Ph V	0	%
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Amps A Ø	264	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Amps B Ø	277	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Amps C Ø	265	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Fault Adjusted Amps A Phase V	0	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Unknown Operations	0	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Tank Paint Condition	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Switching Operations	1	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Operations This Read Vac	1	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Operations Counter AL	99896	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Operations Counter AF	99896	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Maintenance Operations	0	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Heaters (All) Functioning?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Grounds in Place?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	General Comments		
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Foundation Condition	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Follow-up Action Required?	n	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Follow-up Action Required?	n	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Fault Operations Ground	0	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Fault Operations C Ø	0	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Fault Operations B Ø	0	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Fault Operations A Ø	0	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Cabinet Paint Condition	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Bushings Connection/Risers	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Patrol Inspection	Bushing Condition	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Amps C Ø	600.0	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Amps B Ø	600.0	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Amps A Ø	600.0	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BB0421	BreakerVacuum	221-118	VCB Readings	9 Month Operations	1	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	9 Month Operations	1	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Accumulated Fault Duty A Ph V	13.66	%
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Accumulated Fault Duty B Ph V	13.66	%
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	K0022	BreakerVacuum	221-112	VCB Readings	Accumulated Fault Duty C Ph V	13.66	%
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Counter Readings	LTC Current Tap Position	4L	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Counter Readings	LTC Max Tap Position	2L	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Counter Readings	LTC Min Tap Position	10L	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	2.0	psi
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Counter Readings	LTC Operations Since Last Insp	954	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0452	LTCMechanism	221-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	K0042	BreakerVacuum	723-0442	VCB Readings	9 Month Operations	8	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	Follow-up Action Required?	n	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	General Comments		
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	General Comments		
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	LTC Totalizer Reading	14788.90	kw
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	Oil Temp Max	65	°C
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Readings	Oil Temp Present	60	°C
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0452	WithLTC	221-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Fault Adjusted Amps B Phase V	0	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Fault Adjusted Amps C Phase V	0	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Fault Operations A Ø	0	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Fault Operations B Ø	0	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Fault Operations C Ø	0	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	KB0012	BreakerVacuum	723-0444	VCB Readings	Fault Operations Ground	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BK000790	BreakerVacuum	221-128	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
2/27/2020 14:45	Distribution	Lemons Mill Quarterly Inspection	BB0415	BreakerVacuum	723-0441	VCB Readings	Accumulated Fault Duty C Ph V	5.77	%
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Counter Readings	Follow-up Action Required?	n	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	Totalizer Meter Reading	.9244	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	Winding Temp Max	55	°C
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	Winding Temp Present	46	°C
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	LTCC000766	LTCControl	221-4	LTC Control Insp	VRR Base Voltage AF	120.0	VAC
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	LTCC000766	LTCControl	221-4	LTC Control Insp	Parallel / Ind. Sw Position	paralleIPAR	Position
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Counter Readings	General Comments		
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Mechanism Patrol Inspection	General Comments		
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Counter Readings	LTC As Found Counter	95568	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	LTCC000766	LTCControl	221-4	LTC Control Insp	LTC Output Voltage Level	119.0	VAC
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	LTCC000766	LTCControl	221-4	LTC Control Insp	LTC Operation Checked?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Counter Readings	LTC As Left Counter	95568	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Counter Readings	LTC Current Tap Position	6L	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Patrol Inspection	Foundation Condition	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Patrol Inspection	General Comments		
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Unknown Operations	0	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Patrol Inspection	Tank Paint Condition	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Switching Operations	1	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Operations This Read Vac	1	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Operations Counter AL	144	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Operations Counter AF	144	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	LTCC000766	LTCControl	221-4	LTC Control Insp	General Comments		
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	LTCC000766	LTCControl	221-4	LTC Control Insp	Follow-up Action Required?	n	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	LTCC000766	LTCControl	221-4	LTC Control Insp	All Connections OK?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Counter Readings	LTC Operations Since Last Insp	727	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.5	psi
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Counter Readings	LTC Min Tap Position	11L	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Counter Readings	LTC Max Tap Position	3L	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Counter Readings	Reset Tap Drag Hands	Reset	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.2	psi
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	LTC Totalizer Reading	14087.86	kw
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	General Comments		
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Patrol Inspection	Grounds in Place?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Maintenance Operations	0	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	General Comments		
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	General Comments		
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Counter Readings	LTC Operations Since Last Insp	673	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	50	°C
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	46	°C
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Counter Readings	LTC Min Tap Position	11L	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Counter Readings	Follow-up Action Required?	n	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Counter Readings	General Comments		
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Mechanism Patrol Inspection	General Comments		
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Counter Readings	LTC As Found Counter	8618	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Counter Readings	LTC Max Tap Position	2L	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Counter Readings	LTC Current Tap Position	3L	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	LTCM000079	LTCMechanism	221-4	LTC Counter Readings	LTC As Left Counter	8618	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	LTCC000766	LTCControl	221-4	LTC Control Insp	VRR Time Delay	30	Seconds
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Counter Readings	LTC Max Tap Position	3L	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Counter Readings	LTC Current Tap Position	5L	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Counter Readings	LTC As Left Counter	131625	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Counter Readings	LTC As Found Counter	131625	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Counter Readings	General Comments		
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Counter Readings	Follow-up Action Required?	n	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0456	LTCMechanism	221-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Tank Leaks	None	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Radiator Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Counter Readings	LTC Min Tap Position	12L	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	Oil Temp Present	45	°C
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	Oil Temp Max	55	°C
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	400	psi
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Readings	Follow-up Action Required?	n	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	BK000791	BreakerVacuum	221-132	VCB Patrol Inspection	Follow-up Action Required?	n	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	LTCC000766	LTCControl	221-4	LTC Control Insp	VRR Base Voltage AL	120.0	VAC
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	TX000193	WithLTC	221-4	LTC Transformer Readings	Totalizer Meter Multiplier	15240	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Counter Readings	LTC Operations Since Last Insp	675	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Clear of Trash?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Ambient Temp	88	°F
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Ambient Temp	85	°F
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Clear of Trash?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	General Comments		
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Foundation Condition	Good	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Vegetation	None	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	General Comments		
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	YD000499	Yard	422-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	Oil Temp Present	50	°C
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	Oil Temp Max	55	°C
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	LTC Totalizer Reading	12877.80	kw
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	General Comments		
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	Follow-up Action Required?	n	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.5	psi
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	General Comments		
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	General Comments		
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	LTC Totalizer Reading	0.00	kw
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	Oil Temp Present	30	°C
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Counter Readings	LTC As Left Counter	945526	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Counter Readings	LTC Current Tap Position	3L	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Counter Readings	LTC Max Tap Position	2L	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Counter Readings	LTC Min Tap Position	8L	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	Oil Temp Max	35	°C
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Counter Readings	LTC Operations Since Last Insp	779	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	2.5	psi
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Counter Readings	LTC Min Tap Position	10L	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Counter Readings	LTC Max Tap Position	2L	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Counter Readings	LTC Current Tap Position	3L	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Counter Readings	LTC As Left Counter	304166	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	ST000502	Structure	422-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Counter Readings	Follow-up Action Required?	n	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	Winding Temp Present	45	°C
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	Winding Temp Max	45	°C
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	Totalizer Meter Reading	.8450	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Readings	Totalizer Meter Multiplier	15240	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0437	WithLTC	220-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Counter Readings	LTC As Found Counter	304166	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Mechanism Patrol Inspection	General Comments		
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Counter Readings	General Comments		
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Mechanism Patrol Inspection	General Comments		
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Counter Readings	LTC As Found Counter	945526	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	Winding Temp Present	30	°C
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	Winding Temp Max	30	°C

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	Totalizer Meter Reading	0.0000	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Counter Readings	General Comments		
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0436	LTCMechanism	220-2	LTC Counter Readings	Follow-up Action Required?	n	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0437	LTCMechanism	220-1	LTC Counter Readings	LTC Operations Since Last Insp	822	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	0	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Bushings Connection/Risers	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Bushing Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Amps C Ø	400.0	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Amps B Ø	400.0	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Amps A Ø	400.0	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	9 Month Operations	6	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Mechanism Patrol Inspection	General Comments		
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0455	LTCMechanism	221-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	LTCC000469	LTCControl	220-1	LTC Control Insp	VRR Time Delay	30	Seconds
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	LTCC000469	LTCControl	220-1	LTC Control Insp	VRR Base Voltage AL	121.0	VAC
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	LTCC000469	LTCControl	220-1	LTC Control Insp	VRR Base Voltage AF	121.0	VAC
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	LTCC000469	LTCControl	220-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	LTCC000469	LTCControl	220-1	LTC Control Insp	LTC Output Voltage Level	120.0	VAC
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	LTCC000469	LTCControl	220-1	LTC Control Insp	LTC Operation Checked?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	LTCC000469	LTCControl	220-1	LTC Control Insp	General Comments		
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	LTCC000469	LTCControl	220-1	LTC Control Insp	Follow-up Action Required?	n	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	LTCC000469	LTCControl	220-1	LTC Control Insp	All Connections OK?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	LTCC000468	LTCControl	220-2	LTC Control Insp	VRR Time Delay	30	Seconds
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	LTCC000468	LTCControl	220-2	LTC Control Insp	VRR Base Voltage AL	121.0	VAC
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	LTCC000468	LTCControl	220-2	LTC Control Insp	VRR Base Voltage AF	121.0	VAC
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	LTCC000468	LTCControl	220-2	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	LTCC000468	LTCControl	220-2	LTC Control Insp	LTC Output Voltage Level	120.0	VAC
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Counter Readings	Reset Tap Drag Hands	Reset	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Counter Readings	LTC Operations Since Last Insp	1005	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.0	psi
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Counter Readings	LTC Min Tap Position	8L	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Counter Readings	LTC Max Tap Position	2L	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Counter Readings	LTC Current Tap Position	3L	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Counter Readings	LTC As Left Counter	161180	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Counter Readings	LTC As Found Counter	161180	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	LTCC000468	LTCControl	220-2	LTC Control Insp	LTC Operation Checked?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	LTCC000468	LTCControl	220-2	LTC Control Insp	General Comments		
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	LTCC000468	LTCControl	220-2	LTC Control Insp	Follow-up Action Required?	n	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	LTCC000468	LTCControl	220-2	LTC Control Insp	All Connections OK?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Mechanism Patrol Inspection	General Comments		
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Counter Readings	General Comments		
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0449	LTCMechanism	220-3	LTC Counter Readings	Follow-up Action Required?	n	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	9 Month Operations	5	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Amps A Ø	200.0	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Amps B Ø	200.0	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Amps C Ø	200.0	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Bushing Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Bushings Connection/Risers	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Fault Operations C Ø	0	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Fault Operations B Ø	0	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Counter Readings	LTC Operations Since Last Insp	0	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Counter Readings	LTC Current Tap Position	Neutral	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Counter Readings	LTC As Left Counter	13386	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Counter Readings	LTC As Found Counter	13386	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Mechanism Patrol Inspection	General Comments		
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Counter Readings	General Comments		
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	S0012	LTCMechanism	220-Offline-Distribution	LTC Counter Readings	Follow-up Action Required?	n	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Fault Operations Ground	0	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Follow-up Action Required?	n	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Follow-up Action Required?	n	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Foundation Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	General Comments		
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	General Comments		
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Grounds in Place?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Heaters (All) Functioning?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Maintenance Operations	0	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Operations Counter AF	268	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Operations Counter AL	268	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Operations This Read Vac	1	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Switching Operations	1	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Tank Paint Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Unknown Operations	0	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Fault Operations A Ø	0	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Fault Operations B Ø	0	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Fault Operations C Ø	0	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Cabinet Paint Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Bushings Connection/Risers	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Patrol Inspection	Bushing Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Amps C Ø	400.0	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Amps B Ø	400.0	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Amps A Ø	400.0	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Fault Operations Ground	0	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Follow-up Action Required?	n	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Follow-up Action Required?	n	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Foundation Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0370	BreakerVacuum	220-118	VCB Readings	9 Month Operations	4	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Cabinet Paint Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Grounds in Place?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	LTC Totalizer Reading	13178.03	kw
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	Oil Temp Max	55	°C
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Operations Counter AF	58	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Operations Counter AL	58	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Operations This Read Vac	1	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Switching Operations	1	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Tank Paint Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Unknown Operations	0	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	Oil Temp Present	50	°C
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Pumps Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Pumps Operational?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Radiator Leaks	None	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Tank Leaks	None	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	Totalizer Meter Multiplier	15240	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	Totalizer Meter Reading	.8647	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	Winding Temp Max	55	°C
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	Winding Temp Present	45	°C
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	General Comments		
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Foundation Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	ST000411	Structure	220-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Vegetation	None	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	General Comments		
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	YD000409	Yard	220-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Cabinet Paint Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	General Comments		
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	General Comments		
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Grounds in Place?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Heaters (All) Functioning?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Maintenance Operations	0	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	BCH000562	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	BCH000562	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Fault Operations A ∅	0	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Fault Operations B ∅	0	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Fault Operations C ∅	0	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Fault Operations Ground	0	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	General Comments		
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	FE000493	Fence	422-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Operations Counter AF	274	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Operations Counter AL	274	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Operations This Read Vac	1	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Switching Operations	1	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Patrol Inspection	Tank Paint Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0369	BreakerVacuum	220-108	VCB Readings	Unknown Operations	0	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Follow-up Action Required?	n	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Foundation Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	General Comments		
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	General Comments		
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Grounds in Place?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Heaters (All) Functioning?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Readings	Maintenance Operations	0	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0408	BreakerVacuum	220-112	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Bushing Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	BCH000562	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	.6	amps
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	BCH000562	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	BCH000562	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	BCH000562	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Fans Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Fans Operational?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	Follow-up Action Required?	n	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Foundation Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Patrol Inspection	General Comments		
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0449	WithLTC	220-3	LTC Transformer Readings	General Comments		
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	110.00	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	Totalizer Meter Reading	.9880	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	Totalizer Meter Multiplier	1800	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	General Comments		
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Safety Barrier Condition OK?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Vegetation	None	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	General Comments		
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	FE000400	Fence	220-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	9 Month Operations	6	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Amps A Ø	200.0	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Amps B Ø	300.0	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	Oil Temp Present	45	°C
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	Oil Temp Max	45	°C
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	LTC Totalizer Reading	1778.40	kw
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	General Comments		
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	General Comments		
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	LTCC000204	LTCControl	220-Offline-Distribution	LTC Control Insp	Follow-up Action Required?	n	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	LTCC000204	LTCControl	220-Offline-Distribution	LTC Control Insp	All Connections OK?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	General Comments		
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Ambient Temp	80	*F
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Clear of Trash?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	YD000306	Yard	221-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.5	psi
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	General Comments		
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	LTCC000548	LTCControl	220-3	LTC Control Insp	VRR Time Delay	30	Seconds
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	LTCC000548	LTCControl	220-3	LTC Control Insp	VRR Base Voltage AL	121.0	VAC
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	LTCC000548	LTCControl	220-3	LTC Control Insp	VRR Base Voltage AF	121.0	VAC
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	LTCC000548	LTCControl	220-3	LTC Control Insp	Parallel / Ind. Sw Position	parallelPAR	Position
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	LTCC000548	LTCControl	220-3	LTC Control Insp	LTC Output Voltage Level	120.0	VAC
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	LTCC000548	LTCControl	220-3	LTC Control Insp	LTC Operation Checked?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	LTCC000548	LTCControl	220-3	LTC Control Insp	General Comments		
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	Winding Temp Present	60	°C
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Counter Readings	LTC As Found Counter	206994	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Mechanism Patrol Inspection	General Comments		
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Counter Readings	General Comments		
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	LTCC000548	LTCControl	220-3	LTC Control Insp	Follow-up Action Required?	n	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	LTCC000548	LTCControl	220-3	LTC Control Insp	All Connections OK?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Counter Readings	Follow-up Action Required?	n	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Fault Operations A ∅	0	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Fault Operations B ∅	0	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Fault Operations C ∅	0	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Fault Operations Ground	0	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Follow-up Action Required?	n	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Follow-up Action Required?	n	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Foundation Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	General Comments		
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	General Comments		
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Grounds in Place?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Heaters (All) Functioning?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Maintenance Operations	0	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Operations Counter AF	67	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Operations Counter AL	67	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Operations This Read Vac	1	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Switching Operations	1	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Tank Paint Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Unknown Operations	0	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Evidence of Insects	None	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Tank Leaks	None	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Operations Counter	10	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	General Comments		
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Readings	Amps C Ø	200.0	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Bushing Condition	Good	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Readings	Follow-up Action Required?	n	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Bushings Connection/Risers	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	LTCC000682	LTCControl	422-1	LTC Control Insp	All Connections OK?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	LTCC000682	LTCControl	422-1	LTC Control Insp	Follow-up Action Required?	n	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	LTCC000682	LTCControl	422-1	LTC Control Insp	General Comments		
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	LTCC000682	LTCControl	422-1	LTC Control Insp	LTC Operation Checked?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	B0338	WithLTC	422-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Panels Dusted?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	LTCC000682	LTCControl	422-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	LTCC000682	LTCControl	422-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	LTCC000682	LTCControl	422-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	LTCC000682	LTCControl	422-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	LTCC000682	LTCControl	422-1	LTC Control Insp	VRR Time Delay	30	Seconds
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	General Comments		
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Floor Swept?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	CH000338	ControlHouse	422-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Amps A Ø	60.0	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Amps B Ø	71.0	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Amps C Ø	95.0	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	X0314	RecloserElectronic	422-0700	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0407	BreakerVacuum	220-122	VCB Patrol Inspection	Cabinet Paint Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	9 Month Operations	10	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Maintenance Operations	0	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Operations Counter AF	65	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Operations Counter AL	65	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Operations This Read Vac	1	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Switching Operations	1	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Tank Paint Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Unknown Operations	0	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	68	*F
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	BAT000627	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Fans Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Fans Operational?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	Follow-up Action Required?	n	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	General Comments		
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	General Comments		
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Foundation Condition	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	General Comments		
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	ST000295	Structure	221-Structure	Structure Patrol Inspection	UG Pothead Condition Good?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Fault Operations B Ø	0	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Fault Operations A Ø	0	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Fault Operations C Ø	0	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Fault Operations Ground	0	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Follow-up Action Required?	n	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Follow-up Action Required?	n	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Foundation Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	General Comments		
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	General Comments		
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Heaters (All) Functioning?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Cabinet Paint Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Bushings Connection/Risers	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Patrol Inspection	Bushing Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Amps C Ø	200.0	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Amps B Ø	200.0	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Amps A Ø	200.0	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	BB0371	BreakerVacuum	220-102	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	LTCC000204	LTCControl	220-Offline-Distribution	LTC Control Insp	General Comments		
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	Winding Temp Max	60	°C
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	Totalizer Meter Reading	.8407	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	Totalizer Meter Multiplier	15240	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Tank Leaks	None	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Counter Readings	LTC As Left Counter	206994	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Counter Readings	LTC Current Tap Position	6L	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Counter Readings	LTC Max Tap Position	5L	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Counter Readings	LTC Min Tap Position	10L	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Counter Readings	LTC Operations Since Last Insp	388	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
8/20/2020 15:10	Distribution	Bedford Quarterly Inspection	B0338	LTCMechanism	422-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	B0455	WithLTC	221-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
8/27/2020 9:09	Distribution	Toyota South Quarterly Inspection	FE000302	Fence	221-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	S0012	WithLTC	220-Offline-Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	Oil Temp Present	55	°C
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	Oil Temp Max	60	°C
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.5	psi
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
8/26/2020 15:46	Distribution	Toyota North Quarterly Inspection	B0436	WithLTC	220-2	LTC Transformer Readings	LTC Totalizer Reading	12812.27	kw
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	LTCC000773	LTCControl	696-1	LTC Control Insp	All Connections OK?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	LTCC000773	LTCControl	696-1	LTC Control Insp	Follow-up Action Required?	n	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	LTCC000773	LTCControl	696-1	LTC Control Insp	General Comments		
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	LTCC000773	LTCControl	696-1	LTC Control Insp	LTC Operation Checked?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	LTCC000773	LTCControl	696-1	LTC Control Insp	LTC Output Voltage Level	123.0	VAC
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	LTCC000773	LTCControl	696-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	LTCC000773	LTCControl	696-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	LTCC000773	LTCControl	696-1	LTC Control Insp	VRR Time Delay	30	Seconds
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Fault Operations Ground	0	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Follow-up Action Required?	n	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Maintenance Operations	0	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Operations Counter AF	395	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Operations Counter AL	397	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Operations This Read Vac	2	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Switching Operations	2	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Unknown Operations	0	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Fault Operations C Ø	0	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Fault Operations B Ø	0	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Fault Operations A Ø	0	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Amps C Ø	245.0	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Amps B Ø	275.0	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Amps A Ø	230.0	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	9 Month Operations	5	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Readings	Unknown Operations	0	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Readings	Switching Operations	2	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Readings	Operations This Read Oil	2	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AL	302	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Readings	Operations Counter AF	300	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Readings	Number of Ops last 9 Months	6	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Readings	Maintenance Operations	0	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Readings	General Comments		
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Readings	Follow-up Action Required?	n	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Readings	Fault Operations	0	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Readings	Amps C Ø	240.0	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Readings	Amps B Ø	240.0	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Readings	Amps A Ø	240.0	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Follow-up Action Required?	n	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Foundation Condition	Good	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	General Comments		
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Grounds in Place?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Heaters (All) Functioning?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Cabinet Paint Condition	Good	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Bushings Connection/Risers	Good	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Bushing Condition	Good	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0040	BreakerVacuum	343-0751	VCB Patrol Inspection	Tank Paint Condition	Good	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Paint Condition	Good	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Oil Level	Good	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Patrol Inspection	Tank Leaks	None	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Patrol Inspection	Spring Compression Ind.	springcharged	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Patrol Inspection	Moisture and Leak Free?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Patrol Inspection	Heaters (All) Functioning?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Patrol Inspection	Grounds in Place?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Patrol Inspection	General Comments		
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Patrol Inspection	Gauge(s) Condition	Good	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Patrol Inspection	Foundation Condition	Good	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Patrol Inspection	Follow-up Action Required?	n	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Patrol Inspection	Equipment Properly Labeled?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Paint Condition	Good	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Heaters Functioning?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Patrol Inspection	Cabinet Door Seals OK?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushings Connection/Risers	Good	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Oil Level	Good	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	BB0204	BreakerOil	Retired Distribution	OCB Patrol Inspection	Bushing Condition	Good	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	LTCC000029	LTCControl	932-Offline Distribution	LTC Control Insp	LTC Operation Checked?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	LTCC000029	LTCControl	932-Offline Distribution	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	LTCC000029	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	LTCC000029	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	LTCC000029	LTCControl	932-Offline Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	Winding Temp Max	51	°C
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	Winding Temp Present	45	°C
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	51	°C
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	40.0	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	30.0	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	40.0	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	2	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations This Read Vac	5	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	270	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	268	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.0	psi
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1200	psi
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	Oil Temp Max	50	°C
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	1	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	2	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	6.13	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	General Comments		
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Ambient Temp	88	°F
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Clear of Trash?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	Oil Temp Present	44	°C
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	12.26	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	LTCC000029	LTCControl	932-Offline Distribution	LTC Control Insp	All Connections OK?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	LTCC000029	LTCControl	932-Offline Distribution	LTC Control Insp	Follow-up Action Required?	n	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	LTCC000029	LTCControl	932-Offline Distribution	LTC Control Insp	General Comments		
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Pumps Condition	Good	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Pumps Operational?	y	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	161	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	161	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations This Read Vac	0	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	0	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Counter Readings	LTC As Found Counter	10019	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Counter Readings	LTC As Left Counter	10019	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Counter Readings	LTC Current Tap Position	1L	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Counter Readings	LTC Max Tap Position	1R	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Counter Readings	LTC Min Tap Position	6L	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Counter Readings	LTC Operations Since Last Insp	315	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Cabinet Door Seals OK?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Cabinet Paint Condition	Good	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Foundation Condition	Good	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	General Comments		
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	LT0079	LTCMechanism	FD-Offline Distribution	LTC Counter Readings	Follow-up Action Required?	n	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	LT0079	LTCMechanism	FD-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	y	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	LT0079	LTCMechanism	FD-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments	LTC oil level is low pic sent to Stinson	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	MOD Cabinet Heater functional?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	MOD Cabinet Internals Clean?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	MOD Motor Jaw Coupling	Good	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Moisture and Leak Free?	y	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	LT0079	LTCMechanism	FD-Offline Distribution	LTC Counter Readings	General Comments	ok	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	ST000367	Structure	747-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0036	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	7	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	45	°C
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	51	°C
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	0	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	505.0	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	530.0	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	510.0	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	45	°C
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	51	°C
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	45	°C
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	General Comments		
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Vegetation	None	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	YD000364	Yard	747-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Counter Readings	Follow-up Action Required?	n	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Counter Readings	General Comments		
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	B0408	LTCMechanism	747-1	LTC Mechanism Patrol Inspection	General Comments		
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KB0041	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Operations This Read Vac	0	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Switching Operations	0	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Patrol Inspection	Tank Paint Condition	Good	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Unknown Operations	0	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BCH001371	Charger	402-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BCH001371	Charger	402-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.0	VDC
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	Winding Temp Present	0	°C
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	Winding Temp Max	0	°C
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	Totalizer Meter Reading	.8580	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BCH001371	Charger	402-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.0	VDC
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BCH001371	Charger	402-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.9	amps
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BCH001371	Charger	402-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	Oil Temp Present	45	°C
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	Oil Temp Max	55	°C
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BCH001371	Charger	402-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BCH001371	Charger	402-Battery Charger	Battery Charger Patrol Insp	General Comments	DC VOLTAGE RANGE SET WRONG	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	BCH001307	Charger	777-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	BCH001307	Charger	777-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	BCH001307	Charger	777-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BCH001371	Charger	402-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	9 Month Operations	0	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Amps A Ø	40.0	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Amps B Ø	40.0	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Amps C Ø	75.0	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Patrol Inspection	Bushing Condition	Good	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Counter Readings	Follow-up Action Required?	n	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Counter Readings	General Comments		
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Patrol Inspection	Bushings Connection/Risers	Good	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Patrol Inspection	Cabinet Paint Condition	Good	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Mechanism Patrol Inspection	General Comments		
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Counter Readings	LTC As Found Counter	103764	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Counter Readings	LTC As Left Counter	103764	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Counter Readings	LTC Current Tap Position	1R	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Counter Readings	LTC Max Tap Position	5R	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Counter Readings	LTC Min Tap Position	5L	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Counter Readings	LTC Operations Since Last Insp	1158	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	S0004	LTCMechanism	777-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Fault Operations A Ø	0	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Fault Operations B Ø	0	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Fault Operations C Ø	0	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Fault Operations Ground	0	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Patrol Inspection	Follow-up Action Required?	n	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Follow-up Action Required?	n	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Patrol Inspection	Foundation Condition	Good	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Patrol Inspection	General Comments		
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	General Comments		
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Patrol Inspection	Grounds in Place?	y	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Maintenance Operations	0	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Operations Counter AF	179	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	BK001160	BreakerVacuum	777-0430	VCB Readings	Operations Counter AL	179	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Drive/Lot Drainage	Good	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Clear of Trash?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Clear of Obstacles?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Ambient Temp	84	*F
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	General Comments		
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Readings	General Comments		
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	General Comments		
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	BCH001307	Charger	777-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.5	amps
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	BCH001307	Charger	777-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	BCH001307	Charger	777-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	BCH001307	Charger	777-Battery Charger	Battery Charger Patrol Insp	General Comments		
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	BCH001307	Charger	777-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	FE000394	Fence	830-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	Clean	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	General Comments		
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Foundation Condition	Good	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	FE000358	Fence	747-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000092	WithLTC	FD-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	ST000403	Structure	830-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Yard Lights Working?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Vegetation	None	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Switch Stick and Container OK?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	General Comments		
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Follow-up Action Required?	n	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	LTC Totalizer Reading	8236.80	kw
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	General Comments		
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	General Comments		
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	YD000400	Yard	830-Yard Distribution	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Readings	Follow-up Action Required?	n	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	B0408	WithLTC	747-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Readings	General Comments	ok	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Maintenance Operations	0	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	BCH000535	Charger	Retired Distribution	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	BCH000535	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	BCH000535	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	BCH000535	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.4	amps
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	BCH000535	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	BCH000535	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	BCH000535	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Operations Counter AF	536	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Operations Counter AL	538	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Operations This Read Vac	2	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	Winding Temp Present	50	°C
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	Winding Temp Max	70	°C
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Reading	.8610	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	Totalizer Meter Multiplier	18000	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Present	40	°C
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	Oil Temp Max	55	°C
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1300	psi
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	LTC Totalizer Reading	15498.00	kw
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Grounds in Place?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	General Comments		
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	General Comments		
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Foundation Condition	Good	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	Follow-up Action Required?	n	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Switching Operations	2	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Tank Paint Condition	Good	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Unknown Operations	0	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Patrol Inspection	Bushings Connection/Risers	Good	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Patrol Inspection	Bushing Condition	Good	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Amps C Ø	135.0	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Amps B Ø	110.0	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Amps A Ø	130.0	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	9 Month Operations	4	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Operational?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Fans Condition	Good	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Operations Counter AF	278	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Operations Counter AL	278	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Operations This Read Vac	2	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	9 Month Operations	27	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Amps A Ø	40.0	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Amps B Ø	50.0	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Amps C Ø	95.0	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Bushing Condition	Good	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Bushings Connection/Risers	Good	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	General Comments		
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Cabinet Paint Condition	Good	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	88	°F
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BAT000951	Battery	747-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Control Handle "Red Flagged"?	y	If Bkr is Closed
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Evidence of Insects	None	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Floor Swept?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	General Comments		
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Panels Dusted?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	CH000363	ControlHouse	747-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Fault Operations A Ø	0	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Fault Operations B Ø	0	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Fault Operations C Ø	0	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Fault Operations Ground	0	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Follow-up Action Required?	n	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	Follow-up Action Required?	n	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Foundation Condition	Good	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	General Comments		
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Readings	General Comments		
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Grounds in Place?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BB0464	BreakerVacuum	747-0504	VCB Patrol Inspection	Heaters (All) Functioning?	y	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	Tank Leaks	None	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	LT0079	WithLTC	FD-Offline Distribution	LTC Transformer Patrol Inspection	Radiator Leaks	None	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	General Comments		
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Vegetation	None	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Foundation Condition	Good	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	969	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	49	°C
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	39	°C
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Counter Readings	LTC Min Tap Position	13L	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Counter Readings	LTC Max Tap Position	Neutral	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Counter Readings	LTC Current Tap Position	7L	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Counter Readings	LTC As Left Counter	14591	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Counter Readings	LTC As Found Counter	14591	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Counter Readings	General Comments		
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	LTCM000045	LTCMechanism	FD-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	X3 Winding Temp Present	43	°C
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	X3 Winding Temp Max	50	°C
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	X2 Winding Temp Present	43	°C
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	X2 Winding Temp Max	50	°C
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	43	°C
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	50	°C
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	10.00	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	Winding Temp Present	43	°C
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	Winding Temp Max	50	°C
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	General Comments		
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	ST000407	Structure	777-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	General Comments		
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Switching Operations	2	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Tank Paint Condition	Good	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Unknown Operations	0	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	FE000401	Fence	777-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Patrol Inspection	Bushing Condition	Good	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KT0028	WithLTC	932-Offline Distribution	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Cooling Group Position	Bank2	chg 1st quarter
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	General Comments		
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	General Comments		
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1800	psi
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	Oil Temp Max	49	°C
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	LTCC000546	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	LTCC000546	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	LTCC000546	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	LTCC000546	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	LTCC000546	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.0	VAC

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	LTCC000546	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	LTCC000546	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	LTCC000546	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Ambient Temp	75	°F
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	YD000405	Yard	777-Yard	Yard Patrol Inspection	Clear of Trash?	y	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Readings	Oil Temp Present	42	°C
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Pumps Condition	Good	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	TX000093	WithLTC	FD-TRANS 1	LTC Transformer Patrol Inspection	Pumps Operational?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	9 Month Operations	4	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Amps A Ø	175.0	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Amps B Ø	155.0	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Amps C Ø	190.0	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Patrol Inspection	Bushing Condition	Good	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Patrol Inspection	Bushings Connection/Risers	Good	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Operations Counter AF	141	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Maintenance Operations	0	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Patrol Inspection	Grounds in Place?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	General Comments		
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Patrol Inspection	General Comments		
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Patrol Inspection	Foundation Condition	Good	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Follow-up Action Required?	n	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Patrol Inspection	Follow-up Action Required?	n	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Fault Operations Ground	0	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Counter Readings	General Comments		
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Fault Operations C Ø	0	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Fault Operations B Ø	0	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Fault Operations A Ø	0	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Patrol Inspection	Cabinet Paint Condition	Good	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Fault Operations A Ø	0	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Fault Operations B Ø	0	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Fault Operations C Ø	0	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Counter Readings	LTC As Found Counter	13344	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Counter Readings	LTC As Left Counter	13344	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Counter Readings	LTC Current Tap Position	8L	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Counter Readings	LTC Max Tap Position	2L	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Counter Readings	LTC Min Tap Position	12L	
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	42	°C
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	49	°C
8/26/2020 6:50	Distribution	Ford Quarterly Inspection	LTCM000044	LTCMechanism	FD-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	733	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Fault Operations Ground	0	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Patrol Inspection	Follow-up Action Required?	n	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Cabinet Paint Condition	Good	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Fault Operations A Ø	0	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Fault Operations B Ø	0	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Fault Operations C Ø	0	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Fault Operations Ground	0	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Follow-up Action Required?	n	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Foundation Condition	Good	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	General Comments		
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	General Comments		
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Grounds in Place?	y	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Maintenance Operations	0	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Follow-up Action Required?	n	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Patrol Inspection	Foundation Condition	Good	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Patrol Inspection	General Comments		
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	General Comments		
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Unknown Operations	0	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	65.00	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Readings	Totalizer Meter Reading	1.0000	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Readings	Totalizer Meter Multiplier	7200	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Readings	Oil Temp Present	40	°C
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Readings	Oil Temp Max	40	°C
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Readings	LTC Totalizer Reading	7200.00	kw
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Readings	General Comments		
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	General Comments		
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Readings	Follow-up Action Required?	n	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	9 Month Operations	8	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Amps A Ø	120.0	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Amps B Ø	85.0	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	S0004	WithLTC	777-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	General Comments		
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #''s
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	°F
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	BAT000500	Battery	777-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #''s

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	BAT000499	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	84	*F
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Readings	Amps C Ø	100.0	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Bushing Condition	Good	
8/25/2020 10:07	Distribution	Newtown Quarterly Inspection	KB0061	BreakerVacuum	777-0431	VCB Patrol Inspection	Bushings Connection/Risers	Good	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Patrol Inspection	Tank Paint Condition	Good	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Switching Operations	2	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Operations This Read Vac	2	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Readings	Operations Counter AL	143	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Max Tap Position	3R	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Min Tap Position	8L	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	60	*C
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	40	*C
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Operations Since Last Insp	1138	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Reset Tap Drag Hands	Reset	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC Current Tap Position	1L	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Left Counter	42075	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Counter Readings	LTC As Found Counter	42075	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	General Comments		
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Counter Readings	General Comments		
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Patrol Inspection	Grounds in Place?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Maintenance Operations	0	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Operations Counter AF	184	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
8/25/2020 11:35	Distribution	Hoover 1 Quarterly Inspection	KT0028	LTCMechanism	932-Offline Distribution	LTC Counter Readings	Follow-up Action Required?	n	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001413	BreakerVacuum	747-0503	VCB Patrol Inspection	Cabinet Paint Condition	Good	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Unknown Operations	0	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Patrol Inspection	Tank Paint Condition	Good	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Switching Operations	2	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Operations This Read Vac	2	
8/25/2020 13:55	Distribution	Midway Quarterly Inspection	BK001414	BreakerVacuum	747-0516	VCB Readings	Operations Counter AL	186	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	681.0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	691.0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	713.0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	18	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	General Comments		
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Maintenance Operations	0	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Operations Counter AF	166	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Operations Counter AL	166	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Operations This Read Vac	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Amps A Ø	157.0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Switching Operations	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	9 Months Operations	2	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Follow-up Action Required?	n	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Fault Operations Ground	0	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Fault Operations C Ø	0	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Fault Operations B Ø	0	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Fault Operations A Ø	0	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	4	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations This Read Vac	4	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	39	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	35	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Counter Readings	LTC Operations Since Last Insp	970	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	118	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Fault Operations A Ø	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Fault Operations A Ø	0	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Fault Operations B Ø	0	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Fault Operations C Ø	0	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Fault Operations Ground	0	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Follow-up Action Required?	n	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	General Comments		
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Maintenance Operations	0	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Operations Counter AF	161	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Operations Counter AL	161	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Operations This Read Vac	0	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Operations This Read AM	0	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Switching Operations	0	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Unknown Operations	0	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	22	°C
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Switching Operations	0	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Unknown Operations	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Fault Operations B Ø	0	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	40	°C
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	22	°C
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	40	°C
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	15	°C
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	34	°C
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	Oil Temp Present	21	°C
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	Oil Temp Max	40	°C
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	General Comments		
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Fault Operations C Ø	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Fault Operations Ground	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Patrol Inspection	Follow-up Action Required?	n	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Follow-up Action Required?	n	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Patrol Inspection	General Comments		
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	General Comments		
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Amps B Ø	120.0	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Amps A Ø	142.0	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Amps C Ø	140.0	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Amps B Ø	140.0	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Amps A Ø	140.0	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000764	BreakerVacuum	LS-1245	VCB Readings	9 Month Operations	3	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Amps C Ø	171.0	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Unknown Operations	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Amps B Ø	153.0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Maintenance Operations	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Operations Counter AF	875	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Operations Counter AL	875	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Operations This Read AM	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Switching Operations	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1129	BreakerAirMagnetic	WT-1151	AMCB Readings	Unknown Operations	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	1	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A Ø	0.0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B Ø	0.0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C Ø	0.0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	PF000424	PowerFuse	WT-12KV TR 5 POT	Disconnect Powerfuse Inspection	General Comments	ok	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	PF000424	PowerFuse	WT-12KV TR 5 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	PF000423	PowerFuse	WT-STA SER NO 5	Disconnect Powerfuse Inspection	General Comments	ok	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	PF000423	PowerFuse	WT-STA SER NO 5	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	PF000422	PowerFuse	WT-12KV TR 4 POT	Disconnect Powerfuse Inspection	General Comments	ok	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations A Ø	0	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Door Alarms OK?	y	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	9 Month Operations	25	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	PF000422	PowerFuse	WT-12KV TR 4 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Bushing Condition	Good	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps C Ø	170.0	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps B Ø	110.0	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Amps A Ø	160.0	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	9 Month Operations	8	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	PF000421	PowerFuse	WT-STA SER NO 4	Disconnect Powerfuse Inspection	General Comments	ok	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	80	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Readings	Oil Temp Present	60	°C
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Readings	Oil Temp Max	65	°C
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	80	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1138	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	PF000421	PowerFuse	WT-STA SER NO 4	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	9 Month Operations	0	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Fault Adjusted Amps A Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Amps C Ø	0.0	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Amps B Ø	0.0	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Amps A Ø	0.0	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	118	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1140	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Present	30	°C
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Mechanism Patrol Inspection	LTC Oil Temp Max	45	°C
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Counter Readings	LTC Min Tap Position	11L	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Counter Readings	LTC Max Tap Position	2L	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Counter Readings	LTC Current Tap Position	4L	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	79	°F
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	110.00	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Readings	Totalizer Meter Reading	1.3660	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Readings	Follow-up Action Required?	n	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	General Comments		
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Readings	General Comments		
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	BCH000572	Charger	Retired Distribution	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	BCH000572	Charger	Retired Distribution	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	BCH000572	Charger	Retired Distribution	Battery Charger Patrol Insp	Battery Charger Current	1.2	amps
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	BCH000572	Charger	Retired Distribution	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	BCH000572	Charger	Retired Distribution	Battery Charger Patrol Insp	Follow-up Action Required?	n	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	BCH000572	Charger	Retired Distribution	Battery Charger Patrol Insp	General Comments		
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Grounds in Place?	y	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	General Comments		
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	General Comments		
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Foundation Condition	Good	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Follow-up Action Required?	n	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations Ground	0	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Readings	LTC Totalizer Reading	6556.80	kw
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations C Ø	0	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BB0483	BreakerVacuum	930-Offline-Distribution	VCB Readings	Fault Operations B Ø	0	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000765	BreakerVacuum	LS-1246	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	3.5	psi
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Counter Readings	LTC As Left Counter	41062	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Counter Readings	LTC As Found Counter	41062	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Mechanism Patrol Inspection	General Comments		
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Counter Readings	General Comments		
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KT0016	LTCMechanism	695-1	LTC Counter Readings	Follow-up Action Required?	n	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	BAT000572	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	337	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	337	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1133	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	General Comments		
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	FE000408	Fence	695-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Ambient Temp	85	°F
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Clear of Trash?	y	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	General Comments		
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Vegetation	None	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	YD000415	Yard	695-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Foundation Condition	Good	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	General Comments		
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	45	°C
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Amps A Ø	84.0	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	Oil Temp Present	30	°C
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	Oil Temp Max	47	°C
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	General Comments		
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Fault Operations Ground	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Follow-up Action Required?	n	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Operations This Read AM	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Operations Counter AL	746	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Operations Counter AF	746	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Maintenance Operations	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	General Comments		
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Patrol Inspection	General Comments		
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Patrol Inspection	General Comments		
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	General Comments		
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Follow-up Action Required?	n	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Patrol Inspection	Follow-up Action Required?	n	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Fault Operations Ground	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Fault Operations C Ø	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Fault Operations B Ø	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Fault Operations A Ø	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Amps C Ø	139.0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Amps B Ø	96.0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Amps A Ø	93.0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Vegetation	None	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	General Comments		
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Maintenance Operations	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Operations Counter AF	69	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Operations Counter AL	69	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Operations This Read AM	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Switching Operations	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1135	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Unknown Operations	0	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Clear of Trash?	y	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	YD000446	Yard	871-Yard	Yard Patrol Inspection	Ambient Temp	79	°F
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1137	BreakerAirMagnetic	WT-1212	AMCB Readings	9 Months Operations	7	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	ST000417	Structure	695-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	X3 Winding Temp Present	50	°C
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	X3 Winding Temp Max	110	°C
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	X2 Winding Temp Present	50	°C
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	X2 Winding Temp Max	110	°C
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	X1 Winding Temp Present	50	°C
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	X1 Winding Temp Max	110	°C
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Tank Leaks	None	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Radiator Leaks	None	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	Oil Temp Present	45	°C
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	Oil Temp Max	75	°C
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	400	psi
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.8	psi
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Grounds in Place?	y	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	General Comments		
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Foundation Condition	Good	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	Follow-up Action Required?	n	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Fans Operational?	y	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Fans Condition	Good	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Patrol Inspection	Bushing Condition	Good	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0220	WithLTC	WT-TRANS 4	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	General Comments		
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Foundation Condition	Good	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	ST000447	Structure	871-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	LTCC000580	LTCControl	695-1	LTC Control Insp	VRR Time Delay	30	Seconds
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	LTCC000580	LTCControl	695-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	LTCC000580	LTCControl	695-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	LTCC000580	LTCControl	695-1	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	LTCC000580	LTCControl	695-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	LTCC000580	LTCControl	695-1	LTC Control Insp	LTC Operation Checked?	y	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	LTCC000580	LTCControl	695-1	LTC Control Insp	General Comments		
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Operations Counter AL	211	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Operations This Read Vac	21	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Follow-up Action Required?	n	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	General Comments		
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Panel Lights OK?	y	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Panels Dusted?	y	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations B Ø	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations A Ø	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Vent Fans OK?	y	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Switching Operations	1	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Unknown Operations	0	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	9 Month Operations	22	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Amps A Ø	171.0	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Amps B Ø	140.0	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Amps C Ø	148.0	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Amps C Ø	38.0	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Amps B Ø	49.0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Operations A Ø	0	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Operations B Ø	0	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Operations C Ø	0	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Operations Ground	0	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Follow-up Action Required?	n	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	LTC Operations Since Last Insp	1558	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	LTC Min Tap Position	10L	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	General Comments	Actual Counter	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Maintenance Operations	0	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Operations Counter AF	219	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Operations Counter AL	219	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Operations This Read Vac	0	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Switching Operations	0	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Unknown Operations	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	LTC Max Tap Position	4R	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	LTC Current Tap Position	3L	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	LTC As Left Counter	272616	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	LTC As Found Counter	272616	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Mechanism Patrol Inspection	General Comments		
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	General Comments		
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0221	LTCMechanism	WT-TRANS 5	LTC Counter Readings	Follow-up Action Required?	n	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Unknown Operations	0	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	Follow-up Action Required?	n	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	General Comments		
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	Oil Temp Max	62	°C
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	Oil Temp Present	44	°C
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X1 Winding Temp Max	52	°C
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X1 Winding Temp Present	39	°C
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X2 Winding Temp Max	66	°C
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X2 Winding Temp Present	45	°C
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X3 Winding Temp Max	66	°C
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	LT0320	WithLTC	HK-TRANS 3	LTC Transformer Readings	X3 Winding Temp Present	45	°C
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Operations Counter AL	232	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Operations Counter AF	232	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Maintenance Operations	0	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	General Comments		
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Follow-up Action Required?	n	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Fault Operations Ground	0	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Fault Operations C Ø	0	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Fault Operations B Ø	0	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Fault Operations A Ø	0	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	9 Month Operations	8	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Amps C Ø	130.0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Evidence of Insects	None	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	SWG000067	Switchgear	WT-Swgr Sec 5	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Operations A Ø	0	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Amps A Ø	250.0	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Amps B Ø	250.0	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Amps C Ø	240.0	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Fault Adjusted Amps B Phase V	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Fault Operations A Ø	0	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Fault Operations B Ø	0	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Fault Operations C Ø	0	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Fault Operations Ground	0	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Follow-up Action Required?	n	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	General Comments		
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Maintenance Operations	0	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Operations Counter AF	168	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Operations Counter AL	168	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Operations This Read Vac	0	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Switching Operations	0	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000767	BreakerVacuum	LS-1248	VCB Readings	Unknown Operations	0	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Operations B Ø	0	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Operations C Ø	0	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Fault Operations Ground	0	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Follow-up Action Required?	n	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	General Comments		
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Maintenance Operations	20	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000510	BreakerVacuum	HK-1235	VCB Readings	Operations Counter AF	211	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	19	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	19	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	LTC Totalizer Reading	6514.56	kw
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.5	psi
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Nitrogen Bottle Pressure	1100	psi
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	Oil Temp Max	40	°C
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	Oil Temp Present	30	°C
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	Totalizer Meter Multiplier	14400	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	Totalizer Meter Reading	.4524	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Cabinet Paint Condition	Good	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Bushings Connection/Risers	Good	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Bushing Condition	Good	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Amps C Ø	0.0	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Amps B Ø	0.0	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	Winding Temp Max	35	°C
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	Winding Temp Present	30	°C
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Amps A Ø	0.0	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	9 Month Operations	8	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Unknown Operations	0	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Amps A Ø	28.0	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	LB0450	BreakerAirMagnetic	HK-1238	AMCB Readings	9 Months Operations	39	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Switching Operations	5	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	45	°C
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	65	°C
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	45	°C
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	65	°C
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	45	°C
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations This Read Vac	5	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AL	416	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	60	°C
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	20.00	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	Oil Temp Present	50	°C
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	Oil Temp Max	65	°C
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	General Comments		
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X3 Winding Temp Present	30	°C
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Operations Counter AF	411	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Readings	Maintenance Operations	0	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BB0482	BreakerVacuum	930-Offline-Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X3 Winding Temp Max	45	°C
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X2 Winding Temp Present	30	°C
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X2 Winding Temp Max	40	°C
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	LT0089	WithLTC	HK-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	30	°C
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Tank Paint Condition	Good	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps C ∅	110.0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps B ∅	106.0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Amps A ∅	116.0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	General Comments		
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	FE000461	Fence	871-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1134	BreakerAirMagnetic	Retired Distribution	AMCB Readings	9 Months Operations	19	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Switching Operations	4	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Operations This Read Vac	4	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Operations Counter AL	305	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Operations Counter AF	301	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Maintenance Operations	0	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Heaters (All) Functioning?	y	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Grounds in Place?	y	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	General Comments		
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	General Comments		
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Foundation Condition	Good	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Follow-up Action Required?	n	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Patrol Inspection	Follow-up Action Required?	n	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Fault Operations Ground	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	9 Months Operations	12	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1131	BreakerAirMagnetic	SSC-Offline-Distribution	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Fault Operations C ∅	0	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Fault Operations B ∅	0	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Fault Operations A ∅	0	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	K0087	BreakerVacuum	871-2315	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KT0016	WithLTC	695-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Fault Operations B Ø	0	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Fault Operations A Ø	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Patrol Inspection	Bushing Condition	Good	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0221	WithLTC	WT-TRANS 5	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Amps C Ø	78.0	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Amps B Ø	53.0	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Equipment Properly Labeled?	y	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Amps A Ø	62.0	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Cabinet Paint Condition	Good	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000068	BreakerVacuum	HK-1242	VCB Readings	9 Month Operations	1	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Bushings Connection/Risers	Good	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Patrol Inspection	Bushing Condition	Good	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Amps C Ø	421.0	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Amps B Ø	416.0	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Amps A Ø	404.0	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	BK000546	BreakerVacuum	871-2317	VCB Readings	9 Month Operations	4	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Unknown Operations	0	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Tank Paint Condition	Good	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Unknown Operations	2	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Switching Operations	0	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Operations This Read Vac	2	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Operations Counter AL	173	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Operations Counter AF	173	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Maintenance Operations	0	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	General Comments		
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Follow-up Action Required?	n	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Operations Ground	0	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Operations C Ø	0	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Operations B Ø	0	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Operations A Ø	0	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Adjusted Amps C Phase V	54.00	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Adjusted Amps B Phase V	54.00	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Fault Adjusted Amps A Phase V	54.00	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Amps C Ø	383.0	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000066	BreakerVacuum	HK-12KV TR 3	VCB Readings	Amps B Ø	337.0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Mechanism Patrol Inspection	General Comments		
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Counter Readings	General Comments		
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Counter Readings	Follow-up Action Required?	n	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BAT000504	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BAT000504	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BAT000504	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BAT000504	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BAT000504	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BAT000504	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BAT000504	Battery	Retired Distribution	Battery Patrol Inspection	Eyewash Solution	Good	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BAT000504	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BAT000504	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BAT000504	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BAT000504	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BAT000504	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BAT000504	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BAT000504	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	85	*F

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BAT000504	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	9 Months Operations	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Amps A Ø	426.0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Amps B Ø	417.0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Amps C Ø	473.0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Fault Operations A Ø	0	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	LTCC000906	LTCControl	871-1	LTC Control Insp	All Connections OK?	y	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	LTCC000906	LTCControl	871-1	LTC Control Insp	Follow-up Action Required?	n	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	LTCC000906	LTCControl	871-1	LTC Control Insp	General Comments		
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	LTCC000906	LTCControl	871-1	LTC Control Insp	LTC Operation Checked?	y	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	LTCC000906	LTCControl	871-1	LTC Control Insp	LTC Output Voltage Level	123.8	VAC
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	LTCC000906	LTCControl	871-1	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	LTCC000906	LTCControl	871-1	LTC Control Insp	VRR Base Voltage AF	123.0	VAC
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LTCC000341	LTCControl	WT-TRANS 4	LTC Control Insp	Follow-up Action Required?	n	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LTCC000341	LTCControl	WT-TRANS 4	LTC Control Insp	General Comments		
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LTCC000341	LTCControl	WT-TRANS 4	LTC Control Insp	Parallel / Ind. Sw Position	parallelIND	Position
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	LTCC000906	LTCControl	871-1	LTC Control Insp	VRR Base Voltage AL	123.0	VAC
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	LTCC000906	LTCControl	871-1	LTC Control Insp	VRR Time Delay	30	Seconds
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Fault Operations B Ø	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Fault Operations C Ø	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Unknown Operations	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Switching Operations	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations This Read AM	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AL	369	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Fault Operations Ground	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Patrol Inspection	Follow-up Action Required?	n	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Follow-up Action Required?	n	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Patrol Inspection	General Comments		
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	General Comments		
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Maintenance Operations	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Operations Counter AF	368	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Operations Counter AL	368	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Operations This Read AM	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Switching Operations	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1141	BreakerAirMagnetic	WT-12KV TR 5	AMCB Readings	Unknown Operations	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Operations Counter AF	369	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Maintenance Operations	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	General Comments		
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	General Comments		
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Follow-up Action Required?	n	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Patrol Inspection	Follow-up Action Required?	n	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations Ground	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1132	BreakerAirMagnetic	Retired Distribution	AMCB Readings	Fault Operations C Ø	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Follow-up Action Required?	n	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Fresh Rat/Mouse Poison?	y	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	General Comments		
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Heaters (All) Functioning?	y	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Moisture and Leak Free?	y	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Panel Lights OK?	y	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Panels Dusted?	y	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Grounds in Place?	y	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Switchgear Lighting OK?	y	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Vent Fans OK?	y	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Ventilation Free of Debris?	y	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	General Comments		
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Maintenance Operations	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Filters Cleaned or Replaced?	y	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Filter Blanks Install/Remove?	y	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Evidence of Insects	None	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Equipment Properly Labeled?	y	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Doors and Locks Secure?	y	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Door Alarms OK?	y	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Aisles Clean/ Free of Debris?	y	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Operations Counter AF	914	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Operations Counter AL	914	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Operations This Read AM	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Switching Operations	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Unknown Operations	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	SWG000068	Switchgear	WT-Swgr Sec 4	Switchgear Patrol Inspection	Acceptable Building Appearance?	y	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Patrol Inspection	General Comments		
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Follow-up Action Required?	n	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Patrol Inspection	Follow-up Action Required?	n	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Fault Operations Ground	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Fault Operations C Ø	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Fault Operations B Ø	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Fault Operations A Ø	0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Amps C Ø	0.0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Amps B Ø	0.0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Amps A Ø	0.0	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1136	BreakerAirMagnetic	WT-1211	AMCB Readings	9 Months Operations	0	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Counter Readings	LTC Operations Since Last Insp	316	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Counter Readings	LTC Min Tap Position	2R	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Counter Readings	LTC Max Tap Position	5L	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Counter Readings	LTC Current Tap Position	Neutral	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Counter Readings	LTC As Left Counter	83363	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Counter Readings	LTC As Found Counter	83360	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Mechanism Patrol Inspection	General Comments		
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Counter Readings	General Comments		
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	C0390	LTCMechanism	871-1	LTC Counter Readings	Follow-up Action Required?	n	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Counter Readings	Reset Tap Drag Hands	Reset	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Counter Readings	LTC Operations Since Last Insp	1569	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Counter Readings	LTC Min Tap Position	10L	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Counter Readings	LTC Max Tap Position	6R	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Counter Readings	LTC Current Tap Position	6L	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Counter Readings	LTC As Left Counter	76687	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LT0220	LTCMechanism	WT-TRANS 4	LTC Counter Readings	LTC As Found Counter	76687	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Operations This Read Vac	2	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Operations Counter AL	284	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Operations Counter AF	284	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Maintenance Operations	0	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	General Comments		
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Follow-up Action Required?	n	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Operations Ground	0	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Operations C Ø	0	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Operations B Ø	0	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Operations A Ø	0	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Adjusted Amps C Phase V	22.36	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Adjusted Amps B Phase V	22.36	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Adjusted Amps A Phase V	22.36	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Amps C Ø	10.0	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Amps B Ø	10.0	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Amps A Ø	10.0	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	9 Month Operations	2	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Unknown Operations	0	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Switching Operations	0	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Operations This Read Vac	0	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Operations Counter AL	282	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Operations Counter AF	282	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Maintenance Operations	0	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	General Comments		
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Follow-up Action Required?	n	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Operations Ground	0	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Operations C Ø	0	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Operations B Ø	0	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Operations Counter AF	225	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Maintenance Operations	0	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	General Comments		
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Follow-up Action Required?	n	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Operations Ground	0	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Operations C Ø	0	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Operations B Ø	0	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Operations A Ø	0	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Amps C Ø	0.0	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Amps B Ø	0.0	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Amps A Ø	0.0	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000074	BreakerVacuum	HK-12KV BUS TIE SEC 3	VCB Readings	9 Month Operations	6	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LTO221	WithLTC	WT-TRANS 5	LTC Transformer Readings	X3 Winding Temp Present	55	°C
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BCH001290	Charger	529-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BCH001290	Charger	529-Battery Charger	Battery Charger Patrol Insp	General Comments		
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BCH001290	Charger	529-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BCH001290	Charger	529-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BCH001290	Charger	529-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.8	amps
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BCH001290	Charger	529-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BCH001290	Charger	529-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	BCH001290	Charger	529-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Unknown Operations	2	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000071	BreakerVacuum	HK-1245	VCB Readings	Switching Operations	0	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Unknown Operations	0	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Tank Paint Condition	Good	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Switching Operations	1	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Amps A Ø	182.0	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Switching Operations	1	
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	9 Month Operations	27	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Amps A Ø	378.0	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Amps B Ø	386.0	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Amps C Ø	370.0	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Operations A Ø	0	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Operations B Ø	0	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Operations C Ø	0	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Fault Operations Ground	0	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	Follow-up Action Required?	n	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000507	BreakerVacuum	HK-12KV TR 1	VCB Readings	General Comments		
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
8/24/2020 12:38	Distribution	Watterson Quarterly Inspection	LB1130	BreakerAirMagnetic	WT-1152	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Operations This Read Vac	1	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Operations Counter AL	166	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Operations Counter AF	166	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Maintenance Operations	0	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Operations This Read Vac	18	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Heaters (All) Functioning?	y	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Grounds in Place?	y	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	General Comments		
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	General Comments		
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Foundation Condition	Good	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Follow-up Action Required?	n	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Patrol Inspection	Follow-up Action Required?	n	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Fault Operations Ground	0	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Fault Operations C Ø	0	
8/24/2020 13:46	Distribution	Rogers Gap Quarterly Inspection	KB0050	BreakerVacuum	526-1	VCB Readings	Fault Operations B Ø	0	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Amps B Ø	65.0	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Amps A Ø	43.0	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Operations This Read Vac	0	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Operations Counter AL	137	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Operations Counter AF	137	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Maintenance Operations	0	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	General Comments		
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Follow-up Action Required?	n	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Fault Operations Ground	0	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Fault Operations C Ø	0	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Fault Operations B Ø	0	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	9 Month Operations	2	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Fault Operations A Ø	0	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Adjusted Amps C Phase V	22.36	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Adjusted Amps B Phase V	22.36	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Fault Adjusted Amps A Phase V	22.36	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Amps C Ø	122.0	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	C0390	WithLTC	871-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Amps C Ø	43.0	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Amps B Ø	49.0	
8/11/2020 12:33	Distribution	Lyndon South Quarterly Inspection	BK000524	BreakerVacuum	LS-1243	VCB Readings	Amps A Ø	37.0	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Unknown Operations	2	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	9 Month Operations	3	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Operations Counter AF	312	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Operations B Ø	0	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Operations A Ø	0	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Maintenance Operations	0	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	General Comments		
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Follow-up Action Required?	n	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Switching Operations	0	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Operations This Read Vac	2	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Operations Counter AL	225	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Operations Counter AF	225	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	Maintenance Operations	0	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000508	BreakerVacuum	HK-1233	VCB Readings	General Comments		
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Operations Counter AL	312	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Operations Ground	0	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Operations This Read Vac	0	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Switching Operations	0	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Amps A Ø	442.0	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Amps B Ø	435.0	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Readings	Amps C Ø	454.0	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Bushing Condition	Good	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Unknown Operations	0	
7/24/2020 14:19	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	9 Month Operations	17	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Bushings Connection/Risers	Good	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Amps C Ø	44.0	
4/2/2020 9:19	Distribution	Harrods Creek Quarterly Inspection	BK000060	BreakerVacuum	HK-1241	VCB Readings	Fault Operations C Ø	0	
8/24/2020 10:36	Distribution	Richmond 4 Quarterly Inspection	BK000545	BreakerVacuum	871-2163	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	Totalizer Meter Multiplier	1800	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	Oil Temp Present	38	°C
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	Oil Temp Max	47	°C
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	LTC Totalizer Reading	130.68	kw
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	General Comments		
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	Totalizer Meter Reading	.0726	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Amps C Ø Max	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Amps C Ø	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Amps B Ø Max	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	Follow-up Action Required?	n	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	O0189	WithLTC	519-2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	9 Months Operations	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Unknown Operations	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Fault Operations A Ø	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Amps A Ø	93.7	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Amps A Ø Max	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Amps B Ø	96.8	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	333	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Amps A Ø	1.3	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Amps B Ø Max	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Amps C Ø	94.9	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Amps C Ø Max	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Fault Operations B Ø	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Fault Operations C Ø	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Fault Operations A Ø	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Fault Operations B Ø	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Fault Operations C Ø	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Fault Operations Ground	0	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	General Comments		
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Fault Operations A Ø	0	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Amps B Ø	118.3	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Amps A Ø Max	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Amps A Ø	49.2	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Fault Operations B Ø	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Amps B Ø Max	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Fault Operations C Ø	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Fault Operations Ground	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Amps C Ø	120.4	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Amps C Ø Max	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Amps C Ø Max	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Amps C Ø	116.3	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Amps B Ø Max	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Amps B Ø	86.3	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Amps A Ø Max	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Amps A Ø	110.9	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	BCH001073	Charger	S-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	BCH001073	Charger	S-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	133.9	VDC
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	BCH001073	Charger	S-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	133.9	VDC
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	BCH001073	Charger	S-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.9	amps
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	BCH001073	Charger	S-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	80	*F
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	9 Months Operations	0	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Amps A Ø Max	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Amps B Ø	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	BCH001073	Charger	S-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	BCH001073	Charger	S-Battery Charger	Battery Charger Patrol Insp	General Comments		
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Amps C Ø	1.0	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Amps B Ø	2.0	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Amps A Ø	2.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	BCH001073	Charger	S-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	9 Months Operations	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	Oil Temp Present	40	°C
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	Oil Temp Max	50	°C
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Follow-up Action Required?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Patrol Inspection	Follow-up Action Required?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	9 Months Operations	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Fault Operations A Ø	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Fault Operations B Ø	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Fault Operations C Ø	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Fault Operations Ground	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Patrol Inspection	Follow-up Action Required?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Follow-up Action Required?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Patrol Inspection	General Comments		
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Amps A Ø	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Unknown Operations	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Switching Operations	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Operations This Read AM	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Unknown Operations	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Switching Operations	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Operations This Read AM	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Operations Counter AL	11587	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Operations Counter AL	257	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Operations Counter AF	257	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	Follow-up Action Required?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	General Comments		
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Maintenance Operations	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Operations Counter AF	743	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Operations Counter AL	743	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Operations This Read AM	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Switching Operations	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Maintenance Operations	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	General Comments		
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Patrol Inspection	General Comments		
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Follow-up Action Required?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Patrol Inspection	Follow-up Action Required?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Fault Operations Ground	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Fault Operations C Ø	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Fault Operations B Ø	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0962	BreakerAirMagnetic	S-STATION SERVICE	AMCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Unknown Operations	0	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	General Comments		
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	General Comments		
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	LTC Totalizer Reading	3945.60	kw
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Patrol Inspection	Follow-up Action Required?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Follow-up Action Required?	n	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Amps B Ø	.9	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Patrol Inspection	General Comments		
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Switching Operations	0	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Amps C Ø	.2	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	207	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	General Comments		
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Maintenance Operations	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0926	BreakerAirMagnetic	S-451	AMCB Readings	Operations Counter AF	11587	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	Totalizer Meter Reading	.4110	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	299	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	9 Months Operations	5	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Amps A Ø	109.5	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Amps A Ø Max	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Amps B Ø	96.9	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Amps B Ø Max	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Amps C Ø	68.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	9 Months Operations	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Amps A Ø	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Amps C Ø Max	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Fault Operations A Ø	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Fault Operations B Ø	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Fault Operations C Ø	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Fault Operations Ground	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Patrol Inspection	Follow-up Action Required?	n	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Follow-up Action Required?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Patrol Inspection	General Comments		
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	General Comments		
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Maintenance Operations	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Operations Counter AF	4503	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	General Comments		
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	DX0078	RecloserHydraulic	519-0305	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Operations Counter AL	4503	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Operations This Read AM	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Switching Operations	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0927	BreakerAirMagnetic	S-453	AMCB Readings	Unknown Operations	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Amps A Ø Max	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Amps B Ø	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Amps B Ø Max	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Amps C Ø	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Amps C Ø Max	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0919	BreakerAirMagnetic	S-1496	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	B0320	WithLTC	895-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Operations This Read AM	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0924	BreakerAirMagnetic	S-421	AMCB Readings	Operations Counter AL	417	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Follow-up Action Required?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Patrol Inspection	General Comments		
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	General Comments		
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Maintenance Operations	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Operations Counter AF	312	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0928	BreakerAirMagnetic	S-454	AMCB Readings	Operations Counter AL	312	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Readings	Non LTC Totalizer Reading	206.40	kw
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Unknown Operations	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0916	BreakerAirMagnetic	S-1308	AMCB Readings	Switching Operations	0	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	M0009	NonLTC	519-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	LTCC000234	LTCControl	895-1	LTC Control Insp	General Comments		
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	LTCC000234	LTCControl	895-1	LTC Control Insp	LTC Operation Checked?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	LTCC000234	LTCControl	895-1	LTC Control Insp	LTC Output Voltage Level	124.0	VAC
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	LTCC000234	LTCControl	895-1	LTC Control Insp	VRR Base Voltage AF	125.0	VAC
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	LTCC000234	LTCControl	895-1	LTC Control Insp	VRR Base Voltage AL	125.0	VAC
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	LTCC000234	LTCControl	895-1	LTC Control Insp	VRR Time Delay	30	Seconds
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	9 Months Operations	0	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	General Comments		
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Operations Counter	12	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	LTCC000354	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	60	Seconds
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	LTCC000354	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	LTCC000354	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	LTCC000354	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.6	VAC
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	LTCC000354	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	LTCC000354	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	LTCC000354	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Unknown Operations	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Switching Operations	1	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Operations This Read AM	1	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Operations Counter AL	526	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Operations Counter AF	526	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Maintenance Operations	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	General Comments		
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Patrol Inspection	General Comments		
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Follow-up Action Required?	n	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	LTCC000354	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Tank Leaks	None	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Amps A Ø	344.5	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Amps A Ø Max	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Amps B Ø	342.3	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Amps B Ø Max	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Follow-up Action Required?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Patrol Inspection	Follow-up Action Required?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Fault Operations Ground	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Fault Operations C Ø	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Fault Operations B Ø	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Fault Operations A Ø	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Amps C Ø Max	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Amps C Ø	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Amps B Ø Max	0.0	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Amps A Ø	13.0	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Amps B Ø	1.0	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Amps C Ø	8.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	KX0236	RecloserElectronic	575-0319	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Amps C Ø	375.1	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Amps C Ø Max	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Fault Operations A Ø	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Fault Operations B Ø	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Fault Operations C Ø	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Readings	Fault Operations Ground	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0923	BreakerAirMagnetic	S-410	AMCB Patrol Inspection	Follow-up Action Required?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Amps B Ø	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Amps A Ø Max	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Amps A Ø	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0933	BreakerAirMagnetic	S-4KV TR 1 TFR	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	LTCC000234	LTCControl	895-1	LTC Control Insp	All Connections OK?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	LTCC000234	LTCControl	895-1	LTC Control Insp	Follow-up Action Required?	n	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Readings	Follow-up Action Required?	n	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Follow-up Action Required?	n	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Follow-up Action Required?	n	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Foundation Condition	Good	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Unknown Operations	0	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Tank Paint Condition	Good	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	General Comments		
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	General Comments		
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Grounds in Place?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Heaters (All) Functioning?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Maintenance Operations	0	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Switching Operations	2	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Operations This Read Vac	2	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Operations Counter AL	1584	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Operations Counter AF	1582	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Maintenance Operations	0	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Heaters (All) Functioning?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Grounds in Place?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	General Comments		
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	General Comments		
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Foundation Condition	Good	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Follow-up Action Required?	n	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Follow-up Action Required?	n	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Fault Operations Ground	0	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Fault Operations C Ø	0	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Fault Operations B Ø	0	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Fault Operations A Ø	0	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Cabinet Paint Condition	Good	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	General Comments		
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	BAT001460	Battery	895-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	9 Month Operations	6	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Amps A Ø	0.0	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Amps B Ø	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Amps C ∅	0.0	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Bushing Condition	Good	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Bushings Connection/Risers	Good	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Fault Operations Ground	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Patrol Inspection	Follow-up Action Required?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Follow-up Action Required?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Patrol Inspection	General Comments		
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	General Comments		
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Maintenance Operations	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Operations Counter AF	4987	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Operations Counter AL	4987	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Operations This Read AM	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Switching Operations	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0931	BreakerAirMagnetic	S-405	AMCB Readings	Unknown Operations	0	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Cabinet Paint Condition	Good	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Fault Operations A ∅	0	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Fault Operations B ∅	0	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Fault Operations C ∅	0	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Fault Operations Ground	0	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Current Tap Position	5L	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Tank Leaks	None	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	9 Months Operations	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Amps A ∅	34.4	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Amps A ∅ Max	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Amps B ∅	26.3	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Amps B ∅ Max	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Amps C ∅	24.8	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Amps C ∅ Max	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Fault Operations A ∅	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Fault Operations B ∅	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Fault Operations C ∅	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Fault Operations Ground	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Patrol Inspection	Follow-up Action Required?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Follow-up Action Required?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Patrol Inspection	General Comments		
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	General Comments		
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Maintenance Operations	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Operations Counter AF	270	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Operations Counter AL	270	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Operations This Read AM	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Switching Operations	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0922	BreakerAirMagnetic	S-409	AMCB Readings	Unknown Operations	0	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Bushings Connection/Risers	Good	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Bushing Condition	Good	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	General Comments		
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Readings	General Comments		
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	206.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	200.00	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Readings	Oil Temp Max	45	°C
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Readings	Oil Temp Present	33	°C
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	M0007	NonLTC	519-1 B	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	KX0238	RecloserElectronic	519-0304	Recloser Electronic Patrol Inspection	Operations Counter	24	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	BB0216	BreakerVacuum	895-0713	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Operations Counter AF	224	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Operations Counter AL	226	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Operations This Read Vac	2	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Switching Operations	2	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Patrol Inspection	Tank Paint Condition	Good	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	WB0139	BreakerVacuum	895-0714	VCB Readings	Unknown Operations	0	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Tank Leaks	None	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Regulator As Left Counter	107009	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.4	volts
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Min Tap Position	9L	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Max Tap Position	3R	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	General Comments		
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1101	Regulator	519-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	General Comments		
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Foundation Condition	Good	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	9 Months Operations	1	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Amps A Ø	307.7	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Amps A Ø Max	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Amps B Ø	239.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Amps B Ø Max	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Amps C Ø	250.9	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Amps C Ø Max	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	9 Months Operations	3	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Amps A Ø	250.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Amps A Ø Max	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Amps B Ø	300.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Amps B Ø Max	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Amps C Ø	300.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Amps C Ø Max	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Follow-up Action Required?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Fault Operations A Ø	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Fault Operations B Ø	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Fault Operations C Ø	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Fault Operations Ground	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Patrol Inspection	Follow-up Action Required?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Follow-up Action Required?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Patrol Inspection	General Comments		
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	General Comments		
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Maintenance Operations	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Operations Counter AF	915	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Operations Counter AL	915	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Operations This Read AM	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Switching Operations	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0934	BreakerAirMagnetic	S-4KV TR 2	AMCB Readings	Unknown Operations	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Fault Operations A Ø	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Fault Operations B Ø	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Fault Operations C Ø	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Fault Operations Ground	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Patrol Inspection	Follow-up Action Required?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Follow-up Action Required?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Patrol Inspection	General Comments		
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	General Comments		
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Counter Readings	LTC Operations Since Last Insp	1203	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Counter Readings	LTC Min Tap Position	8L	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Counter Readings	LTC Max Tap Position	4R	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	ST000630	Structure	S-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	ST000630	Structure	S-Structure	Structure Patrol Inspection	General Comments		
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Ambient Temp	65	°F
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	ST000630	Structure	S-Structure	Structure Patrol Inspection	Foundation Condition	Good	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	ST000630	Structure	S-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Readings	X1 Winding Temp Max	55	°C
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Tank Leaks	None	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Readings	Oil Temp Present	40	°C
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Readings	Oil Temp Max	60	°C
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	General Comments	Transformer needs nitrogen	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Readings	General Comments		
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	PF000337	PowerFuse	S-1378 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	PF000337	PowerFuse	S-1378 POT	Disconnect Powerfuse Inspection	General Comments	ok	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Readings	Follow-up Action Required?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Fans Operational?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	ST000630	Structure	S-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Unknown Operations	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Amps C Ø Max	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Amps C Ø	280.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Amps B Ø Max	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Fans Condition	Good	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Amps B Ø	280.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Amps A Ø Max	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Amps A Ø	300.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	9 Months Operations	0	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Tank Paint Condition	Good	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Switching Operations	4	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Operations This Read Vac	4	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Operations Counter AL	269	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Operations Counter AF	265	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Maintenance Operations	0	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Heaters (All) Functioning?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Grounds in Place?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	General Comments		
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Current Tap Position	4L	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Radiator Leaks	None	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Tank Leaks	None	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Regulator As Left Counter	127262	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	123.7	volts
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Min Tap Position	7L	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Max Tap Position	5R	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	General Comments		
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Current Tap Position	4L	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1102	Regulator	519-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	Oil Temp Present	35	°C
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	Oil Temp Max	60	°C
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	0.0	psi
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Grounds in Place?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	General Comments	Transformer needs nitrogen	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	General Comments		
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Foundation Condition	Good	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Follow-up Action Required?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	Follow-up Action Required?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Fans Operational?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Fans Condition	Good	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Cooling Group Position	Bank1	chg 1st quarter
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Bushing Condition	Good	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Counter Readings	LTC Current Tap Position	5L	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Counter Readings	LTC As Left Counter	373875	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Counter Readings	LTC As Found Counter	373867	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Counter Readings	General Comments		
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	O0189	LTCMechanism	519-2	LTC Counter Readings	Follow-up Action Required?	n	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Follow-up Action Required?	n	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Tank Leaks	None	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Maintenance Operations	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Operations Counter AF	391	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Operations Counter AL	391	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Operations This Read AM	1	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Switching Operations	1	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0925	BreakerAirMagnetic	S-422	AMCB Readings	Unknown Operations	0	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	LTC Operations Since Last Insp	815	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Mechanism Patrol Inspection	LTC Oil Filter Condition	Good	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	LTC Min Tap Position	7L	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	LTC Max Tap Position	Neutral	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	LTC Current Tap Position	5L	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	LTC As Left Counter	96632	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	LTC As Found Counter	96632	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Mechanism Patrol Inspection	General Comments		
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	General Comments		
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0186	LTCMechanism	S-TRANS 1	LTC Counter Readings	Follow-up Action Required?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	X1 Winding Temp Present	38	°C
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	X1 Winding Temp Max	65	°C
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Regulator As Left Counter	110514	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.1	volts
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0185	WithLTC	S-TRANS 2	LTC Transformer Patrol Inspection	Tank Leaks	None	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Min Tap Position	8L	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Max Tap Position	3R	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	General Comments		
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	R1103	Regulator	519-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Amps A Ø	85.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Amps A Ø Max	0.0	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	MX0302	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	16.3	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	MX0302	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	14.2	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	MX0302	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	12.9	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	MX0302	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	MX0302	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	MX0302	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	MX0302	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	MX0302	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	MX0302	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	MX0302	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	MX0302	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	24	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	MX0302	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	MX0302	RecloserHydraulic	Retired Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Unknown Operations	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Switching Operations	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Operations This Read AM	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Operations Counter AL	2558	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Operations Counter AF	2558	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Maintenance Operations	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	General Comments		
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Patrol Inspection	General Comments		
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Follow-up Action Required?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Patrol Inspection	Follow-up Action Required?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Amps B Ø	80.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Amps B Ø Max	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Amps C Ø	85.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Amps C Ø Max	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Unknown Operations	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Switching Operations	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Operations This Read AM	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Operations Counter AL	354	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Operations Counter AF	354	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Maintenance Operations	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	General Comments		
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Patrol Inspection	General Comments		
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Follow-up Action Required?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Patrol Inspection	Follow-up Action Required?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Fault Operations Ground	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Fault Operations C Ø	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Fault Operations B Ø	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0932	BreakerAirMagnetic	S-4KV TR 1	AMCB Readings	Fault Operations A Ø	0	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Fault Operations Ground	0	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	PF000335	PowerFuse	S-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	PF000335	PowerFuse	S-14KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	PF000336	PowerFuse	S-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	PF000336	PowerFuse	S-14KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Counter Readings	LTC Operations Since Last Insp	86	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Counter Readings	LTC Min Tap Position	16L	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	PF000338	PowerFuse	S-1308 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	PF000338	PowerFuse	S-1308 POT	Disconnect Powerfuse Inspection	General Comments	ok	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Counter Readings	LTC Max Tap Position	2R	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Counter Readings	LTC Current Tap Position	2L	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Counter Readings	LTC As Left Counter	103090	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Counter Readings	Follow-up Action Required?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Counter Readings	General Comments		
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Mechanism Patrol Inspection	General Comments		
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Counter Readings	LTC As Found Counter	9614	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Counter Readings	LTC As Left Counter	9614	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Counter Readings	LTC Current Tap Position	8L	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Counter Readings	LTC Max Tap Position	1R	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Counter Readings	LTC As Found Counter	103084	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Mechanism Patrol Inspection	General Comments		
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Counter Readings	General Comments		
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	LTCMechanism	575-1	LTC Counter Readings	Follow-up Action Required?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Counter Readings	LTC Min Tap Position	10L	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Counter Readings	LTC Operations Since Last Insp	911	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Counter Readings	Reset Tap Drag Hands	Reset	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	BCH001378	Charger	895-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	BCH001378	Charger	895-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	BCH001378	Charger	895-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	BCH001378	Charger	895-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	BCH001378	Charger	895-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	BCH001378	Charger	895-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0185	LTCMechanism	S-TRANS 2	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	BCH001378	Charger	895-Battery Charger	Battery Charger Patrol Insp	General Comments		
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	BCH001378	Charger	895-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	General Comments		
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	9 Months Operations	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LT0186	WithLTC	S-TRANS 1	LTC Transformer Readings	X1 Winding Temp Present	45	°C
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Follow-up Action Required?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Patrol Inspection	General Comments		
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	General Comments		
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	PF000343	PowerFuse	S-4KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	General Comments	ok	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	PF000343	PowerFuse	S-4KV BUS SEC 2 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	PF000341	PowerFuse	S-STA SER	Disconnect Powerfuse Inspection	General Comments	ok	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	PF000341	PowerFuse	S-STA SER	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	PF000340	PowerFuse	S-1496 POT	Disconnect Powerfuse Inspection	General Comments	ok	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	PF000340	PowerFuse	S-1496 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	PF000339	PowerFuse	S-1372 POT	Disconnect Powerfuse Inspection	General Comments	ok	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	PF000339	PowerFuse	S-1372 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Maintenance Operations	0	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	FE000372	Fence	895-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Operations Counter AF	1127	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Operations Counter AL	1127	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Operations This Read AM	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Switching Operations	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Unknown Operations	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Vegetation	None	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Landscape Good Condition?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	General Comments		
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Clear of Trash?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	General Comments		
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Amps A Ø Max	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Amps A Ø	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	9 Months Operations	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	YD000651	Yard	S-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	FE000646	Fence	S-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	ST000630	Structure	S-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Fault Operations C Ø	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Fault Operations B Ø	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Fault Operations A Ø	0	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	General Comments		
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	ST000126	Structure	575-Structure	Structure Patrol Inspection	All Identified and Legible?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Vegetation	None	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Amps C Ø Max	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Amps C Ø	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Amps B Ø Max	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0921	BreakerAirMagnetic	S-406	AMCB Readings	Amps B Ø	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Fault Operations A Ø	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Fault Operations B Ø	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Fault Operations C Ø	0	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	General Comments		
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Readings	Fault Operations Ground	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0918	BreakerAirMagnetic	S-1378	AMCB Patrol Inspection	Follow-up Action Required?	n	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Clear of Trash?	y	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	YD000122	Yard	575-Yard	Yard Patrol Inspection	Ambient Temp	69	°F
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	General Comments	the back right corner of fence is a foot off groundleft corner post of station is washing out	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	FE000120	Fence	575-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Mechanism Patrol Inspection	General Comments		
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	General Comments		
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	Follow-up Action Required?	n	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Amps A Ø	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Amps A Ø Max	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Amps B Ø	0.0	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Fault Operations Ground	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Patrol Inspection	Follow-up Action Required?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Follow-up Action Required?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Patrol Inspection	General Comments		
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	General Comments		
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Maintenance Operations	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Operations Counter AF	840	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Operations Counter AL	840	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Operations This Read AM	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Switching Operations	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Unknown Operations	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Amps B Ø Max	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Amps C Ø	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Amps C Ø Max	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Amps C Ø	180.0	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	Totalizer Meter Reading	.2520	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	Totalizer Meter Multiplier	2400	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Amps B Ø	180.0	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	Oil Temp Present	35	°C
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	Oil Temp Max	50	°C
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	LTC Totalizer Reading	604.80	kw
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LTCC000331	LTCControl	S-TRANS 1	LTC Control Insp	Parallel / Ind. Sw Position	parallellIND	Position
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LTCC000331	LTCControl	S-TRANS 1	LTC Control Insp	General Comments		
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LTCC000331	LTCControl	S-TRANS 1	LTC Control Insp	Follow-up Action Required?	n	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Amps C Ø	5.7	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Amps B Ø	6.2	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Amps A Ø	4.9	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	LTCC000763	LTCControl	519-2	LTC Control Insp	Follow-up Action Required?	n	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	LTCC000763	LTCControl	519-2	LTC Control Insp	All Connections OK?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	LTC Operations Since Last Insp	197	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	LTC Min Tap Position	Neutral	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	General Comments		
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Maintenance Operations	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Operations Counter AF	1044	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Operations Counter AL	1044	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Operations This Read AM	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Switching Operations	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Unknown Operations	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Fault Operations A Ø	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	9 Months Operations	1	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	LTC Max Tap Position	4R	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	LTC Current Tap Position	3R	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	9 Months Operations	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Amps A Ø	60.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Amps A Ø Max	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Amps B Ø	90.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Amps B Ø Max	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Amps C Ø	80.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Amps C Ø Max	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Fault Operations A Ø	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Fault Operations B Ø	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0917	BreakerAirMagnetic	S-1372	AMCB Readings	Fault Operations C Ø	0	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Fault Operations B Ø	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Fault Operations C Ø	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Fault Operations Ground	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Patrol Inspection	Follow-up Action Required?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	LTC As Left Counter	9967	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	B0320	LTCMechanism	895-1	LTC Counter Readings	LTC As Found Counter	9967	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Fault Operations Ground	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Patrol Inspection	Follow-up Action Required?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Follow-up Action Required?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Patrol Inspection	General Comments		
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	General Comments		
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Maintenance Operations	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Operations Counter AF	923	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Operations Counter AL	923	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Operations This Read AM	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Trash Emptied?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Switch Diagram Present/Current	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Switching Operations	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Unknown Operations	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Unknown Operations	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Switching Operations	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Operations This Read AM	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Operations Counter AL	794	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Operations Counter AF	794	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Maintenance Operations	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	General Comments		
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Patrol Inspection	General Comments		
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Follow-up Action Required?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	General Comments		
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Restroom Clean & OK?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Panels Dusted?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	70	*F
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	BAT000118	Battery	S-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Panel Lights OK?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	General Comments		
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Floor Swept?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Evidence of Insects	None	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Door Alarms OK?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Broom on Site?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	CH000198	ControlHouse	S-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	General Comments		
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LTCC000330	LTCControl	S-TRANS 2	LTC Control Insp	Parallel / Ind. Sw Position	paralleIND	Position
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LTCC000330	LTCControl	S-TRANS 2	LTC Control Insp	General Comments		
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LTCC000330	LTCControl	S-TRANS 2	LTC Control Insp	Follow-up Action Required?	n	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Foundation Condition	Good	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	ST000382	Structure	895-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Vegetation	None	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	General Comments		
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	General Comments		
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Amps A Ø	180.0	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	Follow-up Action Required?	n	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	9 Month Operations	10	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Fault Operations A Ø	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Fault Operations B Ø	0	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
8/21/2020 9:57	Distribution	Deer Branch Quarterly Inspection	B0466	WithLTC	575-1	LTC Transformer Readings	All Temp Gauges MAX Reset	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Clear of Trash?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	YD000378	Yard	895-Yard	Yard Patrol Inspection	Ambient Temp	80	*F
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0929	BreakerAirMagnetic	S-4KV BUS TIE	AMCB Readings	Fault Operations C Ø	0	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Cabinet Paint Condition	Good	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Fault Operations A Ø	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Fault Operations B Ø	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Fault Operations C Ø	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Fault Operations Ground	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Patrol Inspection	Follow-up Action Required?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Follow-up Action Required?	n	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Patrol Inspection	General Comments		
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	LTCC000763	LTCControl	519-2	LTC Control Insp	General Comments		
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	LTCC000763	LTCControl	519-2	LTC Control Insp	LTC Operation Checked?	y	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	LTCC000763	LTCControl	519-2	LTC Control Insp	LTC Output Voltage Level	122.7	VAC
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	LTCC000763	LTCControl	519-2	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	LTCC000763	LTCControl	519-2	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	LTCC000763	LTCControl	519-2	LTC Control Insp	VRR Time Delay	60	Seconds
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	General Comments		
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Amps A Ø	0.0	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Amps A Ø Max	0.0	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Fault Operations Ground	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Fault Adjusted Amps C Phase AM	0.00	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	9 Months Operations	0	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Bushings Connection/Risers	Good	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Fault Operations C Ø	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Amps B Ø	0.0	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Patrol Inspection	Bushing Condition	Good	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	PF000342	PowerFuse	S-4KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	General Comments	ok	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	PF000342	PowerFuse	S-4KV BUS SEC 1 POT	Disconnect Powerfuse Inspection	Follow-up Action Required?	n	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Amps C Ø	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Amps C Ø Max	0.0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Fault Operations A Ø	0	
8/21/2020 9:08	Distribution	Dow Corning Quarterly Inspection	K0140	BreakerVacuum	895-0712	VCB Readings	Fault Operations B Ø	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Amps B Ø Max	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Amps A Ø	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Amps A Ø Max	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Amps A Ø	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Fault Adjusted Amps B Phase AM	0.00	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Operations Counter	286	
8/21/2020 9:04	Distribution	Crockett Quarterly Inspection	MX0454	RecloserHydraulic	519-0306	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Accumulated Fault Duty C Ph AM	0.00	%
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Accumulated Fault Duty B Ph AM	0.00	%
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	Accumulated Fault Duty A Ph AM	0.00	%
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0935	BreakerAirMagnetic	S-4KV TR 2 TFR	AMCB Readings	9 Months Operations	0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Fault Adjusted Amps A Phase AM	0.00	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Patrol Inspection	Equipment Properly Labeled?	y	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Amps C Ø Max	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Amps C Ø	0.0	
8/21/2020 11:13	Distribution	Southern Quarterly Inspection	LB0930	BreakerAirMagnetic	S-4KV BUS TIE REACTOR	AMCB Readings	Amps B Ø Max	0.0	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	General Comments	Potholes coming into station , had water standing in them.	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Insulators in Good Condition?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Unknown Operations	0	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Tank Paint Condition	Good	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Switching Operations	0	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Vegetation	None	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Tank Leaks	None	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Min Tap Position	12L	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Controlhouse Grounds in Place?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Control House Lighting OK?	y	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Vegetation	None	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Operations Counter	42	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Amps A Ø	8.5	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Amps B Ø	9.3	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	General Comments		
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Ambient Temp	75	*F
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Tank Leaks	None	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	0.0	psi
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Counter Readings	LTC Operations Since Last Insp	2394	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	75	*F
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	BCH001246	Charger	601-Battery Charger	Battery Charger Patrol Insp	General Comments		
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	BCH001246	Charger	601-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Clear of Trash?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	BCH001246	Charger	601-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	BCH001246	Charger	601-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.1	amps

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Amps C Ø	7.6	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	BCH001246	Charger	601-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	BCH001246	Charger	601-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	BCH001246	Charger	601-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.0	VDC
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.0	VDC
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	General Comments		
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	591	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	103	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	General Comments		
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	122.9	volts
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Regulator As Left Counter	304612	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	YD000440	Yard	652-Yard	Yard Patrol Inspection	General Comments		
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Operations Counter AF	37	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Maintenance Operations	0	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Heaters (All) Functioning?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Grounds in Place?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	General Comments		
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	General Comments		
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	n	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	n	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	General Comments		
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	AC/DC Dist Panels Labeled?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Acceptable Building Appearance?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Counter Readings	Follow-up Action Required?	n	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Clear of Trash?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Foundation Condition	Good	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Follow-up Action Required?	n	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	YD000178	Yard	503-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Poor	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	10.0	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	10.0	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Mechanism Patrol Inspection	LTC Tank Desiccant	Good	check oil cup
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	10.0	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	LTCC000732	LTCControl	882-1	LTC Control Insp	VRR Time Delay	60	Seconds
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	LTCC000732	LTCControl	882-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	0.00	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	Totalizer Meter Reading	.0030	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	LTCC000732	LTCControl	882-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	LTCC000732	LTCControl	882-1	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	LTCC000732	LTCControl	882-1	LTC Control Insp	LTC Operation Checked?	y	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	LTCC000732	LTCControl	882-1	LTC Control Insp	General Comments		
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	LTCC000732	LTCControl	882-1	LTC Control Insp	Follow-up Action Required?	n	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	LTCC000732	LTCControl	882-1	LTC Control Insp	All Connections OK?	y	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Operations This Read Vac	0	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	General Comments		Cross arm that holds the metering has termite damage
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Eyewash Solution	Good	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Current Tap Position	9L	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Min Tap Position	14L	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Max Tap Position	5L	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	General Comments		
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Max Tap Position	8L	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Min Tap Position	15L	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	83	*F
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	BAT001307	Battery	601-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	124.1	volts
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Regulator As Left Counter	272822	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1005	Regulator	632-1 C	Regulator Patrol Inspection	Tank Leaks	None	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	9	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	General Comments		
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	MB0132	BreakerVacuum	704-0254	VCB Readings	Operations Counter AL	37	
8/20/2020 10:11	Distribution	Foumle Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.6	volts
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Regulator As Left Counter	35031	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Tank Leaks	None	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	Totalizer Meter Reading	.4056	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Ambient Temp	83	°F
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Clear of Trash?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	General Comments		
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	Totalizer Meter Reading	.3696	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Current Tap Position	9L	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	General Comments		
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	443.52	kw
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	51.00	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	45.00	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	Oil Temp Max	44	°C
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	Oil Temp Present	33	°C
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Max Tap Position	Neutral	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Min Tap Position	11L	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	General Comments		
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	General Comments		
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	LTCC000679	LTCCControl	069-6	LTC Control Insp	VRR Time Delay	30	Seconds

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	LTCC000679	LTCControl	069-6	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	973.44	kw
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	217.50	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	200.00	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	Oil Temp Max	115	°C
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Readings	Oil Temp Present	38	°C
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	LTCC000679	LTCControl	069-6	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	LTCC000679	LTCControl	069-6	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	LTCC000679	LTCControl	069-6	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	LTCC000679	LTCControl	069-6	LTC Control Insp	LTC Operation Checked?	y	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	LTCC000679	LTCControl	069-6	LTC Control Insp	General Comments		
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	LTCC000679	LTCControl	069-6	LTC Control Insp	Follow-up Action Required?	n	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	LTCC000679	LTCControl	069-6	LTC Control Insp	All Connections OK?	y	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	0961	NonLTC	800-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Windows/Doors Condition OK?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Ventilation Free of Debris?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Panels Dusted?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Moisture and Leak Free?	y	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	General Comments		
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Fresh Rat/Mouse Poison?	n	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Floor Swept?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Floor Condition Acceptable?	y	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	General Comments		
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Fans/AC/Heater(s) Working?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Evidence of Insects	None	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	CH000408	ControlHouse	704-Control House	Control House Patrol Inspection	Doors and Locks Secure?	y	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	General Comments		
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	BAT001189	Battery	652-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	MX0271	RecloserHydraulic	632-0380	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	142	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	FE000436	Fence	652-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	General Comments		
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0852	Regulator	800-1 B	Regulator Patrol Inspection	Max Tap Position	4L	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Current Tap Position	6L	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	SPCC Strongwell Containment OK	y	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	General Comments		
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Amps C Ø	104.0	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Amps B Ø	101.0	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Amps A Ø	103.0	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	KX0167	RecloserElectronic	882-0318	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Switch Stick and Container OK?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Counter Readings	General Comments		
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Mechanism Patrol Inspection	General Comments		
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Vegetation	None	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	ST000184	Structure	503-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	YD000539	Yard	601-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Counter Readings	LTC As Found Counter	53661	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Counter Readings	LTC As Left Counter	53671	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Counter Readings	LTC Current Tap Position	5R	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Counter Readings	LTC Max Tap Position	11R	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	LTCM000046	LTCMechanism	704-1	LTC Counter Readings	LTC Min Tap Position	6L	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0734	Regulator	800-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	ST000081	Structure	632-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	FE000060	Fence	504-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	General Comments		
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	LTCC000663	LTCControl	704-1	LTC Control Insp	LTC Operation Checked?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	LTCC000663	LTCControl	704-1	LTC Control Insp	General Comments		
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	LTCC000663	LTCControl	704-1	LTC Control Insp	Follow-up Action Required?	n	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	LTCC000663	LTCControl	704-1	LTC Control Insp	All Connections OK?	y	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Max Tap Position	5L	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	General Comments	A few limbs starting to grow over the fence.	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Min Tap Position	14L	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.3	volts
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Regulator As Left Counter	288212	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Tank Leaks	None	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Grounds in Place?	y	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Max Tap Position	4L	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Min Tap Position	15L	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	LTCC000663	LTCControl	704-1	LTC Control Insp	VRR Time Delay	60	Seconds
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	LTCC000663	LTCControl	704-1	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
8/20/2020 8:41	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
8/20/2020 8:41	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Tank Leaks	None	
8/20/2020 8:41	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
8/20/2020 8:41	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	123.1	volts
8/20/2020 8:41	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
8/20/2020 8:41	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
8/20/2020 8:41	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
8/20/2020 8:41	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
8/20/2020 8:41	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Min Tap Position	15L	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	General Comments		
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	General Comments		
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	LTCC000663	LTCControl	704-1	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	LTCC000663	LTCControl	704-1	LTC Control Insp	LTC Output Voltage Level	124.2	VAC
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
8/20/2020 8:41	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Max Tap Position	6L	
8/20/2020 8:41	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
8/20/2020 8:41	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	General Comments		
8/20/2020 8:41	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
8/20/2020 8:41	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
8/20/2020 8:41	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 8:41	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
8/20/2020 8:41	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Current Tap Position	12L	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Current Tap Position	9L	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	R0854	Regulator	800-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/20/2020 8:41	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
8/20/2020 8:41	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
8/20/2020 8:41	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
8/20/2020 8:41	Distribution	Brush Creek Quarterly Inspection	MR0086	Regulator	517-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Tank Paint Condition	Good	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Tank Leaks	None	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Surge Arrester Condition	Good	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Regulator As Left Counter	7179	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Reg Output Voltage Level	122.7	volts
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Reg Operation Checked?	y	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Reg Oil Level	Good	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Moisture and Leak Free?	y	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Min Tap Position	6L	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Fault Operations A Ø	0	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Fault Operations B Ø	0	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Max Tap Position	2R	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Grounds in Place?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Foundation Condition	Good	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Fault Operations C Ø	0	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Fault Operations Ground	0	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	General Comments		
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	General Comments		
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Foundation Condition	Good	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	124.0	volts
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Regulator As Left Counter	123312	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Tank Leaks	None	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Bushing Condition	Good	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Current Tap Position	7L	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	ST000106	Structure	800-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	9 Month Operations	1	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Amps A Ø	120.0	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Amps B Ø	130.0	
8/20/2020 8:41	Distribution	Brush Creek Quarterly Inspection	MRO086	Regulator	517-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Amps C Ø	120.0	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Bushing Condition	Good	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Bushings Connection/Risers	Good	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Cabinet Paint Condition	Good	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	LTCC000306	LTCControl	Retired Distribution	LTC Control Insp	Parallel / Ind. Sw Position	paralleloff	Position
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	LTCC000306	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AF	124.0	VAC
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	LTCC000306	LTCControl	Retired Distribution	LTC Control Insp	VRR Base Voltage AL	124.0	VAC
8/20/2020 8:41	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Readings	General Comments		
8/20/2020 8:41	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/20/2020 8:41	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
8/20/2020 8:41	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	25.00	
8/20/2020 8:41	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	20.00	
8/20/2020 8:41	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Readings	Oil Temp Max	46	°C
8/20/2020 8:41	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Readings	Oil Temp Present	36	°C
8/20/2020 8:41	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
8/20/2020 8:41	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
8/20/2020 8:41	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	LTCC000306	LTCControl	Retired Distribution	LTC Control Insp	VRR Time Delay	30	Seconds
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Bushing Condition	Good	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
8/20/2020 8:41	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
8/20/2020 8:41	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
8/20/2020 8:41	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	Follow-up Action Required?	n	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	General Comments		
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	General Comments		
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	ST000068	Structure	504-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	LTCC000306	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	General Comments		
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	LTCC000306	LTCControl	Retired Distribution	LTC Control Insp	General Comments		
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	LTCC000306	LTCControl	Retired Distribution	LTC Control Insp	LTC Operation Checked?	y	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	LTCC000306	LTCControl	Retired Distribution	LTC Control Insp	LTC Output Voltage Level	123.5	VAC
8/20/2020 8:41	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
8/20/2020 8:41	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/20/2020 8:41	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
8/20/2020 8:41	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
8/20/2020 8:41	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 8:41	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Readings	Follow-up Action Required?	n	
8/20/2020 8:41	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
8/20/2020 8:41	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
8/20/2020 8:41	Distribution	Brush Creek Quarterly Inspection	0926	NonLTC	517-1 C	NonLTC Transformer Patrol Inspection	General Comments		
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	General Comments		
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Amps A Ø	0.0	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Amps B Ø	0.0	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Amps C Ø	0.0	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	General Comments		
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Operations Counter	143	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	MX0452	RecloserHydraulic	503-4330	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0269	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Current Tap Position	7L	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Foundation Condition	Good	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	Gauge(s) Condition	Good	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1266	Regulator	632-1 A	Regulator Patrol Inspection	General Comments		
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	General Comments		
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	LTC Totalizer Reading	3902.40	kw
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	.5	psi
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	Oil Temp Max	72	°C
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	Oil Temp Present	40	°C
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	Totalizer Meter Multiplier	4800	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	n	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	ST000070	Structure	890-Structure	Structure Patrol Inspection	Wood Structures OK?	y	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	Totalizer Meter Reading	.8130	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	75.00	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	M0059	WithLTC	534-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	Totalizer Meter Reading	.0036	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	1200	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	Oil Temp Present	39	°C
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	Oil Temp Max	45	°C
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	4.32	kw
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	0986	NonLTC	632-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	FE000820	Fence	704-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	General Comments		
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	General Comments		
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	9 Month Operations	29	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Amps A Ø	86.0	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Amps B Ø	64.0	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Amps C Ø	85.0	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Patrol Inspection	Bushing Condition	Good	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Patrol Inspection	Bushings Connection/Risers	Good	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Patrol Inspection	Cabinet Paint Condition	Good	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Fault Operations A Ø	0	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Fault Operations B Ø	0	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Fault Operations C Ø	0	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Fault Operations Ground	0	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Follow-up Action Required?	n	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Patrol Inspection	Foundation Condition	Good	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Patrol Inspection	General Comments		
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	General Comments		
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Patrol Inspection	Grounds in Place?	y	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Maintenance Operations	0	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Operations Counter AF	190	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Operations Counter AL	191	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Operations This Read Vac	1	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Switching Operations	1	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Patrol Inspection	Tank Paint Condition	Good	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001405	BreakerVacuum	882-0311	VCB Readings	Unknown Operations	0	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	9 Month Operations	38	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Cabinet Paint Condition	Good	
8/20/2020 9:56	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
8/20/2020 9:56	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	100	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Cabinet Internal Condition?	Clean	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Cabinet Door Seals OK?	y	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Bushings Connection/Risers	Good	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Bushing Condition	Good	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	General Comments		

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	Follow-up Action Required?	n	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	General Comments		
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	General Comments		
8/20/2020 9:56	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Readings	Totalizer Meter Reading	.0290	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Regulator As Left Counter	363871	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	123.0	volts
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	n	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	B0261	NonLTC	504-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Patrol Inspection	Grounds in Place?	y	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Maintenance Operations	0	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	PT/CT/CCVT Properly Grounded?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	PT/CT/CCVT Visible Condition	Good	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Signage Visible, and Proper?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Site Service Trans Condition	OK	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Spr Fuse Barrels/Links Qty OK?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	181	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	177	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Operations Counter AF	191	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Operations Counter AL	192	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Operations This Read Vac	1	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Switching Operations	1	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Patrol Inspection	Tank Paint Condition	Good	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Unknown Operations	0	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C ∅	0	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B ∅	0	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A ∅	0	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Amps A Ø	31.0	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Amps B Ø	32.0	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Amps C Ø	12.0	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Patrol Inspection	Bushing Condition	Good	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Patrol Inspection	Bushings Connection/Risers	Good	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Patrol Inspection	Cabinet Paint Condition	Good	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	LTC Totalizer Reading	14.40	kw
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	Oil Temp Max	48	°C
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Readings	Oil Temp Present	40	°C
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	M0095	WithLTC	503-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Fault Operations A Ø	0	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Fault Operations B Ø	0	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Foundation Condition	Good	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	ST000543	Structure	601-Structure	Structure Patrol Inspection	General Comments		
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	CB0163	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Fault Operations C Ø	0	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Fault Operations Ground	0	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	Follow-up Action Required?	n	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Patrol Inspection	Foundation Condition	Good	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Patrol Inspection	General Comments		
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BK001406	BreakerVacuum	882-0312	VCB Readings	General Comments		
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	224	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Counter Readings	LTC Max Tap Position	11L	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Counter Readings	LTC Min Tap Position	15R	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Counter Readings	LTC Operations Since Last Insp	914	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Counter Readings	Reset Tap Drag Hands	Unable to Reset	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Amps B Ø	60.0	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Amps C Ø	60.0	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Bushing Condition	Good	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Bushings Connection/Risers	Good	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	All Connections OK?	y	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Battery Area Ambient Temp	85	°F
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Battery Overall Condition	Good	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	General Comments		
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Negative DC Ground	27.3	VDC
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Positive DC Ground	26.1	VDC
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BAT001058	Battery	882-Battery Bank	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Cabinet Paint Condition	Good	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Fault Operations A Ø	0	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Heaters (All) Functioning?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Maintenance Operations	0	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Operations Counter AF	46	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Operations Counter AL	46	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Operations This Read Vac	0	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Steel Structures Rust Free?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	ST000007	Structure	704-Structure	Structure Patrol Inspection	Surge Arrester Condition	Good	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	FE000822	Fence	534-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	LTC000306	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Follow-up Action Required?	n	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Foundation Condition	Good	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Gauge(s) Condition	Good	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	General Comments		
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Grounds in Place?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	4	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	9 Month Operations	17	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Amps A Ø	60.0	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Counter Readings	Follow-up Action Required?	n	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Counter Readings	General Comments		
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Mechanism Patrol Inspection	General Comments		
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Counter Readings	LTC As Found Counter	239244	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Counter Readings	LTC As Left Counter	239249	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Max Tap Position	4L	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Min Tap Position	15L	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Moisture and Leak Free?	y	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Reg Oil Level	Good	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Reg Operation Checked?	y	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Reg Output Voltage Level	124.2	volts
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Regulator As Left Counter	130714	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Foundation Condition	Good	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	General Comments		
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	General Comments		
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Grounds in Place?	y	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	4	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	228	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	M0053	LTCMechanism	652-1	LTC Counter Readings	LTC Current Tap Position	6L	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	60.0	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	60.0	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	60.0	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	R1167	Regulator	890-1 A	Regulator Patrol Inspection	Tank Leaks	None	
8/20/2020 9:56	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Chipped	
8/20/2020 9:56	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
8/20/2020 9:56	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	8	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
8/20/2020 9:56	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
8/20/2020 9:56	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/20/2020 9:56	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
8/20/2020 9:56	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Crumbling	
8/20/2020 9:56	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
8/20/2020 9:56	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Readings	General Comments		
8/20/2020 9:56	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	General Comments	Transformer foundation is crumbling. High side bushing is chipped.	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	FE000534	Fence	601-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	General Comments		
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Gauge(s) Condition	Good	
8/20/2020 9:56	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
8/20/2020 9:56	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
8/20/2020 9:56	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	2.90	kw
8/20/2020 9:56	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	6.00	
8/20/2020 9:56	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
8/20/2020 9:56	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
8/20/2020 9:56	Distribution	Chunklick Branch Quarterly Inspection	C0392	NonLTC	644-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Foundation Condition	Good	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Equipment Properly Labeled?	y	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	RG000138	Regulator	504-1 C	Regulator Patrol Inspection	Current Tap Position	2L	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Switching Operations	0	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Patrol Inspection	Tank Paint Condition	Good	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	MB0131	BreakerVacuum	704-0253	VCB Readings	Unknown Operations	0	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Surge Arrester Condition	Good	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Tank Leaks	None	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	R1267	Regulator	632-1 B	Regulator Patrol Inspection	Tank Paint Condition	Good	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C ∅	0	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B ∅	0	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A ∅	0	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Fault Operations B ∅	0	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Fault Operations C ∅	0	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Fault Operations Ground	0	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Follow-up Action Required?	n	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Foundation Condition	Good	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	General Comments		
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	General Comments		
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Grounds in Place?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Heaters (All) Functioning?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Maintenance Operations	0	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Operations Counter AF	293	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Operations Counter AL	297	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Operations This Read Vac	4	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Switching Operations	4	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Patrol Inspection	Tank Paint Condition	Good	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	WB0171	BreakerVacuum	601-0337	VCB Readings	Unknown Operations	0	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	CB0284	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Tank Leaks	None	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Panel Lights OK?	y	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Operations Counter	55	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Readings	LTC Totalizer Reading	4877.28	kw

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AF	24	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Maintenance Operations	0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Heaters (All) Functioning?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Readings	General Comments		
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	General Comments		
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Readings	Follow-up Action Required?	n	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Grounds in Place?	y	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	General Comments		
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	General Comments		
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Foundation Condition	Good	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Moisture and Leak Free?	y	
8/20/2020 14:02	Distribution	Zorn Generating Quarterly Inspection	FE000609	Fence	Retired Distribution	Fence Patrol Inspection	Fence Gates Aligned?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Follow-up Action Required?	n	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Follow-up Action Required?	n	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations Ground	0	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	M0075	WithLTC	704-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations C Ø	0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations B Ø	0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Fault Operations A Ø	0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps C Phase V	0.00	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps B Phase V	0.00	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Fault Adjusted Amps A Phase V	0.00	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Clear of Trash?	y	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Ambient Temp	70	°F
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Vegetation	None	
8/20/2020 8:41	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
8/20/2020 8:41	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	General Comments		
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	General Comments		
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	SPCC Berms in Good Condition	Good	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Vegetation	None	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Operations Counter AL	24	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BCH001346	Charger	882-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	1.120	millivolts
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	X0072	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Operations Counter	196	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	X0072	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	X0072	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BCH001346	Charger	882-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.4	VDC
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BCH001346	Charger	882-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.4	VDC
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BCH001346	Charger	882-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	1.0	amps
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BCH001346	Charger	882-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BCH001346	Charger	882-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BCH001346	Charger	882-Battery Charger	Battery Charger Patrol Insp	General Comments		
8/20/2020 13:50	Distribution	Calloway Quarterly Inspection	BCH001346	Charger	882-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Clear of Trash?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Ambient Temp	79	*F
8/20/2020 8:41	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Amps A Ø	11.6	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Tank Paint Condition	Good	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	9 Month Operations	2	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	BCH001044	Charger	652-Battery Charger	Battery Charger Patrol Insp	General Comments		
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	BCH001044	Charger	652-Battery Charger	Battery Charger Patrol Insp	Ground Lights	None	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Mechanism Patrol Inspection	General Comments		
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	C0525	LTCMechanism	069-6	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Counter Readings	Reset Tap Drag Hands	Reset	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Counter Readings	LTC Operations Since Last Insp	976	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Mechanism Patrol Inspection	LTC Nitrogen Blanket Press	1.5	psi
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Counter Readings	LTC Min Tap Position	4L	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Counter Readings	LTC Max Tap Position	8L	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Counter Readings	LTC Current Tap Position	6L	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Counter Readings	LTC As Left Counter	97580	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	n	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Reg Output Voltage Level	122.9	volts
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Reg Operation Checked?	y	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Reg Oil Level	Good	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Radiator Free of Obstructions?	y	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Moisture and Leak Free?	y	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	LTCC000186	LTCControl	Retired Distribution	LTC Control Insp	All Connections OK?	y	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	LTCC000186	LTCControl	Retired Distribution	LTC Control Insp	Follow-up Action Required?	n	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Counter Readings	Follow-up Action Required?	n	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Counter Readings	General Comments		
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Mechanism Patrol Inspection	General Comments		
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Counter Readings	LTC As Found Counter	41627	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	M0059	LTCMechanism	534-1	LTC Counter Readings	LTC As Left Counter	41635	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Counter Readings	LTC As Found Counter	97575	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	C0486	LTCMechanism	069-5	LTC Mechanism Patrol Inspection	General Comments		
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Paint Condition	Good	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Tank Paint Condition	Good	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Mechanism Patrol Inspection	Tank Paint Condition	Good	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Counter Readings	Reset Tap Drag Hands	Reset	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Mechanism Patrol Inspection	LTC Tank Oil Level	Good	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Counter Readings	LTC Operations Since Last Insp	624	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Counter Readings	LTC Min Tap Position	3L	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Counter Readings	LTC Max Tap Position	8L	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Counter Readings	LTC Current Tap Position	5L	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Mechanism Patrol Inspection	LTC Compartment Gasket	Good	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Counter Readings	LTC As Left Counter	70713	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Counter Readings	LTC As Found Counter	70710	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Mechanism Patrol Inspection	General Comments		
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Counter Readings	General Comments		
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	General Comments	barbed wire is rusty and fence post	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Tank Leaks	None	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Surge Arrester Condition	Good	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Reset Tap Drag Hands	Reset	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	KR0029	Regulator	504-1 A	Regulator Patrol Inspection	Regulator As Left Counter	6898	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	FE000073	Fence	632-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushings Connection/Risers	Good	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Bushing Condition	Good	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Amps C Ø	300.0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Amps B Ø	300.0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Amps A Ø	300.0	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Accumulated Fault Duty C Ph V	0.00	%
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Mechanism Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	C0530	LTCMechanism	601-1	LTC Counter Readings	Follow-up Action Required?	n	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	BCH001044	Charger	652-Battery Charger	Battery Charger Patrol Insp	A.C. Ripple on Batteries	0.000	millivolts
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	BCH001044	Charger	652-Battery Charger	Battery Charger Patrol Insp	As Found Float Voltage	53.0	VDC
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	BCH001044	Charger	652-Battery Charger	Battery Charger Patrol Insp	As Left Float Voltage	53.0	VDC
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	BCH001044	Charger	652-Battery Charger	Battery Charger Patrol Insp	Battery Charger Current	.2	amps
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	BCH001044	Charger	652-Battery Charger	Battery Charger Patrol Insp	Charger Alarms Present	None	note in comments if present
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	BCH001044	Charger	652-Battery Charger	Battery Charger Patrol Insp	Follow-up Action Required?	n	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	General Comments		
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Operations Counter	270	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
8/20/2020 10:47	Distribution	Alva Quarterly Inspection	MX0453	RecloserHydraulic	503-4331	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
8/20/2020 8:41	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 8:41	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
8/20/2020 9:56	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
8/20/2020 12:22	Distribution	Apollo Quarterly Inspection	YD000074	Yard	632-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	General Comments	barbed wire on front half of station is rusty	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	y	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	y	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Drainage/Culverts Debris Free?	y	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	All Temp Gauges MAX Reset	n	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Bushing Condition	Good	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Bushing Oil Level	Good	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	Follow-up Action Required?	n	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Foundation Condition	Good	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	General Comments		
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	General Comments		
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	LTC Totalizer Reading	6860.16	kw
8/20/2020 9:56	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	General Comments		
8/20/2020 9:56	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 9:56	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	n	
8/20/2020 9:56	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	n	
8/20/2020 9:56	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	n	
8/20/2020 9:56	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Bad	
8/20/2020 9:56	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	Clear of Trash?	n	
8/20/2020 9:56	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Vegetation	None	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	SPCC Spill Kit Complete?	y	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	General Comments		
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Equipment Properly Labeled?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Contacts Engaged Properly?	y	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Conductors and Connectors OK?	y	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	Arcing Horns Good Condition?	y	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	ST000510	Structure	652-Structure	Structure Patrol Inspection	All Identified and Legible?	y	
8/20/2020 9:56	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	Banks/Rip Rap Good Condition?	y	
8/20/2020 9:56	Distribution	Chunklick Branch Quarterly Inspection	YD000075	Yard	644-Yard	Yard Patrol Inspection	Ambient Temp	75	*F
8/20/2020 9:56	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Signage Visible, and Proper?	y	
8/20/2020 9:56	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	General Comments	ence is old, and looks rough	Large rock has rolled off the mountain and into the fence pushing it in toward the transformer
8/20/2020 9:56	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Gate Locks Functioning ?	y	
8/20/2020 9:56	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Gate Has 911 Info On Sign?	n	
8/20/2020 9:56	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Gap Beneath Fence < 4 Inches?	n	
8/20/2020 9:56	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Free of Overhanging Limbs?	n	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
8/20/2020 9:56	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 9:56	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Fence Ties Intact?	y	
8/20/2020 8:41	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
8/20/2020 8:41	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
8/20/2020 8:41	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Operations Counter	140	
8/20/2020 8:41	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
8/20/2020 8:41	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	General Comments		
8/20/2020 9:56	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Fence Posts Condition OK?	y	
8/20/2020 9:56	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Fence Grounds in Place?	y	
8/20/2020 9:56	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
8/20/2020 9:56	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
8/20/2020 9:56	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	n	
8/20/2020 9:56	Distribution	Chunklick Branch Quarterly Inspection	FE000075	Fence	644-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	n	
8/20/2020 8:41	Distribution	Brush Creek Quarterly Inspection	MX0330	RecloserHydraulic	517-0324 C	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	X0072	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps B Ø	28.8	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Grounds in Place?	y	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	General Comments		
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	DX0120	RecloserHydraulic	890-0257	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.0	psi
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	NLTC Bushing Dyanmic Health	0.00	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	Non LTC Totalizer Reading	15.84	kw
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Non LTC Trn Health	5.00	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	NonLTC Trn Dynamic Health	0.00	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	Oil Temp Max	52	°C
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	Oil Temp Present	44	°C
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Radiator Leaks	None	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Tank Leaks	None	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Tank Oil Level	Good	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Tank Paint Condition	Good	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	Totalizer Meter Multiplier	2400	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	Totalizer Meter Reading	.0066	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Ambient Temp	68	*F
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Clear of Trash?	y	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Drive/Lot Drainage	Good	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	YD000061	Yard	504-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	X0072	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps C Ø	38.1	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	X0072	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	X0072	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	X0072	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	X0072	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	X0072	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	X0072	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	General Comments		
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	X0072	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Drive/Lot Free of Washouts?	y	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Drive/Lot Free of Ruts?	y	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0185	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Drive/Lot Free of Potholes?	y	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	1.5	psi
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	Oil Temp Max	65	°C
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	Oil Temp Present	45	°C
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Patrol Inspection	Tank Paint Condition	Good	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	Totalizer Meter Multiplier	9600	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	Totalizer Meter Reading	.7146	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	WithLTC Trn Dynamic Health	45.00	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	M0053	WithLTC	652-1	LTC Transformer Readings	WLTC Bushing Dynamic Health	0.00	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Fence Gates Aligned?	y	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Fence Gate Gap < 6 Inches?	y	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Fence Fabric Condition OK?	y	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Fence >5' Clearance To Trees?	y	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	FE000100	Fence	800-Fence	Fence Patrol Inspection	Barbed Wire Condition OK?	n	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Clear of Trash?	y	
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Yard Lights Working?	y	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	Vegetation	None	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	YD000062	Yard	890-Yard	Yard Patrol Inspection	General Comments		
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	YD000100	Yard	800-Yard	Yard Patrol Inspection	Ambient Temp	74	*F
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	All Temp Gauges MAX Reset	y	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Bushing Condition	Good	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Bushing Oil Level	Good	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Bushings Connection/Risers	Good	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Cabinet Door Seals OK?	y	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Cabinet Heaters Functioning?	y	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Fans Condition	Good	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Fans Operational?	y	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	Follow-up Action Required?	n	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Foundation Condition	Good	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	Gauge(s) Condition	Good	
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Patrol Inspection	General Comments		
8/20/2020 10:39	Distribution	Garrard Quarterly Inspection	M0087	NonLTC	890-1	NonLTC Transformer Readings	General Comments		
8/20/2020 11:25	Distribution	Puckett Creek Quarterly Inspection	X0072	RecloserHydraulic	951-Offline-Distribution	Recloser Hydraulic Patrol Inspection	Amps A Ø	29.5	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Cabinet Heaters Functioning?	y	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	Equipment Properly Labeled?	y	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	C Ø Operations Counter	439	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	Bushings Connection/Risers	Good	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	Bushing Condition	Good	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	B Ø Operations Counter	12	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	Amps C Ø	17.6	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	Amps B Ø	18.1	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	Amps A Ø	12.2	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	A Ø Operations Counter	398	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Tank Paint Condition	Good	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Spring Compression Ind.	springcharged	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Moisture and Leak Free?	y	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Heaters (All) Functioning?	y	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Grounds in Place?	y	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	General Comments		
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Foundation Condition	Good	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Follow-up Action Required?	n	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Equipment Properly Labeled?	y	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Cabinet Paint Condition	Good	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Cabinet Internal Condition?	Clean	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Cabinet Internal Condition?	Clean	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Cabinet Heaters Functioning?	y	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Cabinet Door Seals OK?	y	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Bushings Connection/Risers	Good	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0226	BreakerVacuum	069-2329	VCB Patrol Inspection	Bushing Condition	Good	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Free of Audible Arcing?	y	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Fuse Barrels Good Condition?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Cabinet Paint Condition	Good	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Equipment Properly Labeled?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Fans Condition	Good	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Fans Operational?	y	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	General Comments		
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Ground Connections Intact?	y	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Insulators In Good Condition?	y	

EndDate	aeoperatingclass	AssetInspectionDesc	EquipmentNumber	EquipmentType	Position	AssetInspectionType	AssetInspectionQuestion	ReadingValue	AssetInspectionQuestionUnit
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Linkage Grounds in Place?	y	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Live Parts Good Condition?	y	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	Operating Linkage OK?	y	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	PT/CT/CCVT Leaks	None	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	ST000090	Structure	534-Structure	Structure Patrol Inspection	PT/CT/CCVT Oil Level OK?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Readings	Follow-up Action Required?	n	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Amps C Ø	132.0	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Battery Load Check OK?	y	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	BAT000176	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	BAT000176	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	BAT000176	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	10.3	VDC
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	BAT000176	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	10.0	VDC
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	BAT000176	Battery	Retired Distribution	Battery Patrol Inspection	General Comments		
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	BAT000176	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	BAT000176	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	BAT000176	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Bushing Condition	Good	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Operations This Read Vac	0	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Bushings Connection/Risers	Good	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Switching Operations	0	
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Patrol Inspection	Tank Paint Condition	Good	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	BAT000176	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	y	If no, which cells in comments
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	BAT000176	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	BAT000176	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	BAT000176	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Good	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	BAT000176	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	80	°F
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	BAT000176	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	BAT000172	Battery	Retired Distribution	Battery Patrol Inspection	Tray/Cab/Rack Corrosion Free?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	BAT000172	Battery	Retired Distribution	Battery Patrol Inspection	Straps Corrosion Free?	y	If no, which cells in comments
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	BAT000172	Battery	Retired Distribution	Battery Patrol Inspection	Positive DC Ground	0.0	VDC
8/20/2020 11:54	Distribution	Irvine Quarterly Inspection	CB0135	BreakerVacuum	Retired Distribution	VCB Readings	Unknown Operations	0	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	BAT000172	Battery	Retired Distribution	Battery Patrol Inspection	Negative DC Ground	0.0	VDC
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	BAT000172	Battery	Retired Distribution	Battery Patrol Inspection	General Comments	Added water to several cells.	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	BAT000172	Battery	Retired Distribution	Battery Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	BAT000172	Battery	Retired Distribution	Battery Patrol Inspection	Cells Free of Leaks?	y	If no, which cells in comments
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	BAT000172	Battery	Retired Distribution	Battery Patrol Inspection	Cell Electrolyte Level	Good	If low,note cell #'s
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	BAT000172	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Cracks?	n	If no, which cells in comments
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	BAT000172	Battery	Retired Distribution	Battery Patrol Inspection	Cases Free of Bulges?	y	If no, which cells in comments
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	BAT000172	Battery	Retired Distribution	Battery Patrol Inspection	Battery Post Condition OK?	y	If no, which cells in comments
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	BAT000172	Battery	Retired Distribution	Battery Patrol Inspection	Battery Overall Condition	Fair	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	BAT000172	Battery	Retired Distribution	Battery Patrol Inspection	Battery Area Ambient Temp	80	°F
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	BAT000172	Battery	Retired Distribution	Battery Patrol Inspection	All Connections OK?	y	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	Tank Paint Condition	Good	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	Tank Leaks	None	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	Operations Counter	0	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	Grounds in Place?	y	
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	General Comments		
8/20/2020 10:11	Distribution	Fourmile Quarterly Inspection	MX0053	RecloserHydraulic	504-4340	Recloser Hydraulic Patrol Inspection	Foundation Condition	Good	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Cabinet Door Seals OK?	y	
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Accumulated Fault Duty B Ph V	0.00	%
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	Accumulated Fault Duty A Ph V	0.00	%
8/21/2020 5:25	Distribution	Richmond Quarterly Inspection	CB0270	BreakerVacuum	069-6	VCB Readings	9 Month Operations	1	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Readings	General Comments		
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Cabinet Internal Condition?	Clean	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Cabinet Paint Condition	Good	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Equipment Properly Labeled?	y	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Follow-up Action Required?	n	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Foundation Condition	Good	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	General Comments	26.7/24.3	
8/20/2020 12:05	Distribution	Manchester Quarterly Inspection	MX0328	RecloserElectronic	534-0250	Recloser Electronic Patrol Inspection	Grounds in Place?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Grounds in Place?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Readings	LTC Totalizer Reading	3749.76	kw
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Moisture and Leak Free?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Nitrogen Blanket Pressure	2.0	psi
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Readings	Oil Temp Max	55	°C
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Clear of Obstacles?	y	
8/20/2020 13:01	Distribution	Manchester South Quarterly Inspection	YD000005	Yard	704-Yard	Yard Patrol Inspection	Clear of Trash?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Readings	Oil Temp Present	45	°C
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Radiator Free of Obstructions?	y	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Radiator Leaks	None	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Radiator Paint Condition	Good	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Surge Arrester Condition	Good	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Tank Leaks	None	
8/20/2020 14:21	Distribution	Dark Hollow Quarterly Inspection	C0530	WithLTC	601-1	LTC Transformer Patrol Inspection	Tank Oil Level	Good	